

# Chicago Public Schools

## 6 Month Asbestos Surveillance

### 2017 - Fall

**School:** Emiliano Zapata Elementary Academy  
**Address:** 2725 Kolin

**Oracle Unit:** 23611  
**Region:** 04

**Building ID:** 3821  
**Mail Room:** 37

**CHECK HERE IF NO CHANGE TO ASBESTOS**

**Asbestos Surveyor:** Coates, Thomas  
**Survey Date:** 12/19/2017  
**Email Address:** tmcoates@cps.edu

A copy of the 2016/2017 notice to parents and staff regarding the asbestos management plan notifications was distributed via:  
 *Each child's backpack*   
 *Notice printed in school's newsletter*   
 *Notice printed in school's calendar*   
 *Other*

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
001	2'x4' Lay In Ceiling Panels	1876	SF	Basement		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002-A	9"x9" Lt. Brown w/Brn & White Floor Tile	1876	SF	Lunchroom, Lunchroom Manager's Office and Custodial Storage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002-B	9"x9" Med. Brown w/Brn & White Floor Tile	1700	SF	Lunchroom, Kitchen, Frezer Room, Corridor Behind Stage, Kitchen Storage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002-C	9"x9" Green w/Brown & White Floor Tile	1300	SF	Lunchroom & 1st Floor Corridor		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002-D	9"x9" Red Floor Tile	25	SF	First Floor Corridor		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002-E	9"x9" Green w/White Specks Floor Tile	2000	SF	First & Second Floor Corridors, CCD		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002-F	9"x9" Gray w/White & Pink Specks Floor Tile	900	SF	Classrooms 401 & 403		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002-G	9"x9" Pink w/Gray & White Specks Floor Tile	900	SF	Classrooms 401 & 403		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002-H	9"x9" Aqua w/White & Black Streaks Floor Tile	900	SF	Classroom 402		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-A	12"x12" Beige & Brown Mix Floor Tile	300	SF	Office		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-B	12"x12" White w/Gray Specks Floor Tile	50	SF	Custodian's Closet		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-C	12"x12" Green Mix Floor Tile	450	SF	Classrooms 404 & 405		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-D	12"x12" Orange Mix Floor Tile	450	SF	Classrooms 404 & 405		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-E	12"x12" Green w/White Streaks Floor Tile	450	SF	Teacher's Lounge		Miscellaneous	No	Loc	3		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-F	12"x12" Beige w/Orange & Brown Streaks Floor Tile			Teacher's Washroom		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-G	12"x12" Wood Patterned Floor Tile	80	SF	Teacher's Washroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-H	12"x12" Pink Mix Floor Tile	2700	SF	Classrooms 501, 502, 503, 504, 505, 506		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-I	12"x12" Gray Mix Floor Tile	2700	SF	Classrooms 501, 502, 503, 504, 505, 506		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003-J	12"x12" Dark Gray Mix Floor Tile	100	SF	Corridor to Basement Washroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
004	Cementitious Pipe Joint Insulation			Inspector did not observe		TSI		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
005	Aircell Pipe Insulation	200	LF	Basement		TSI	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006-A	9"x9" Lt. Brown w/Brn & White Floor Tile Mastic	1876	SF	Lunchroom, Lunchroom Manager's Office and Custodial Storage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006-B	9"x9" Med. Brown w/Brn & White Floor Tile Mastic	1700	SF	Lunchroom, Kitchen, Freezer Room, Corridor Behind Stage, Kitchen Storage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006-C	9"x9" Green w/Brown & White Floor Tile Mastic	1300	SF	Lunchroom & 1st Floor Corridor		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006-D	9"x9" Red Floor Tile Mastic	25	SF	First Floor Corridor		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006-E	9"x9" Green w/White Specks Floor Tile Mastic	2000	SF	First & Second Floor Corridors, CCD		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006-F	9"x9" Gray w/White & Pink Specks Floor Tile Mastic	900	SF	Classrooms 401 & 403		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006-G	9"x9" Pink w/Gray & White Specks Floor Tile Mastic	900	SF	Classrooms 401 & 403		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006-H	9"x9" Aqua w/White & Black Strks Floor Tile Mastic	900	SF	Classroom 402		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-A	12"x12" Beige & Brown Mix Floor Tile Mastic	300	SF	Office		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-B	12"x12" White w/Gray Specks Floor Tile Mastic	50	SF	Custodian's Closet		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-C	12"x12" Green Mix Floor Tile Mastic	450	SF	Classrooms 404 & 405		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-D	12"x12" Orange Mix Floor Tile Mastic	450	SF	Classrooms 404 & 405		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-E	12"x12" Green w/White Streaks Floor Tile Mastic	450	SF	Teacher's Lounge		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-F	12"x12" Beige w/Orng & Brn Strks Floor Tile Mastic	10	SF	Teacher's Washroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-G	12"x12" Wood Patterned Floor Tile Mastic	80	SF	Teacher's Washroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-H	12"x12" Pink Mix Floor Tile Mastic	2700	SF	Classrooms 501, 502, 503, 504, 505, 506		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-I	12"x12" Gray Mix Floor Tile Mastic	2700	SF	Classrooms 501, 502, 503, 504, 505, 506		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007-J	12"x12" Dark Gray Mix Floor Tile Mastic	100	SF	Corridor to Basement Washroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
008	Hard Plaster on Walls & Ceilings			Throughout Facility		Surface					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
009	Acoustical Wall Plaster	5000	SF	Lunchroom		Surface	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
010	Acoustical Ceiling Plaster	80	SF	Main Entrance		Surface	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
011	Paper Beneath 9"x9" Floor Tile	3960	SF	Corridors & Classrooms 401 & 403		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
012	Drywall	980	SF	lunchroom Manager's Office and Custodian Storage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
013	Drywall Compound	980	SF	lunchroom Manager's Office and Custodian Storage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
014	4" Black Vinyl Baseboard	15	LF	First Floor Corridor and Janitor's Closet		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
015	4" Black Vinyl Baseboard Adhesive	15	LF	First Floor Corridor and Janitor's Closet		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
016	4" Brown Vinyl Baseboard	1500	LF	All Classrooms, Corridors, Office and Basement		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
017	4" Brown Vinyl Baseboard Adhesive	1500	LF	All Classrooms, Corridors, Office and Basement		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
018	2'x4' Lay In Ceiling Panels	576	SF	Lunchroom Managers Office and Custodial Storage		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
019	Chalk Board Adhesive	900	SF	All Classrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
020	Pipe Joint Insulation on Aircell Insulated Piping	30	SF	Basement		TSI	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
021	Gray Carpet Adhesive	800	SF	Office		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
022	Brown Vinyl Stair Treads	384	SF	East & West Stairs		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
023	Brown Vinyl Stair Tread Adhesive	384	SF	East & West Stairs		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
024	Brown Vinyl Stair Treads	96	SF	Stage Stairs		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
025	Brown Vinyl Stair Tread Adhesive	96	SF	Stage Stairs		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
026	Mastic Associated with Hardwood Flooring	500	SF	Stage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
027	Insulation in Fire Doors	140	SF	Entrances		TSI	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
028	Sink Undercoating	8	SF	Teacher's Lounge		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
029	1' x 1' Pinhole Ceiling Tile	100	SF	Main Entrance		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
30	Tan w/Brown Terrazzo	1200	SF	Stairs and Landings (front stairwell)		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



*ALL LEA Responsibilities, for this school, will be met.*



---

Robert Christlieb

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***

NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Emiliano Zapata Elementary Academy

Date: 12/22/2017

---

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2016. Asbestos surveillances are conducted every six months.

CHECK ONE

- A copy of this notice was sent home in each child's backpack.
- A copy of this notice was printed in the school's newsletter and sent home with each child
- A copy of this notice was printed in the school's calendar and sent home with each child
- Other.
- 

A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**