

# Chicago Public Schools

## 6 Month Asbestos Surveillance

### 2017 - Fall

**School:** Louis Pasteur Elementary School  
**Address:** 5825 South Kostner Avenue

**Oracle Unit:** 24851  
**Region:** 05

**Building ID:** 6410  
**Mail Room:** 44

**CHECK HERE IF NO CHANGE TO ASBESTOS**

**Asbestos Surveyor:** \_\_\_\_\_  
**Survey Date:** \_\_\_\_\_  
**Email Address:** \_\_\_\_\_

A copy of the 2016/2017 notice to parents and staff regarding the asbestos management plan notifications was distributed via:  
 Each child's backpack   
 Notice printed in school's newsletter   
 Notice printed in school's calendar   
 Other |

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
001	9"x 9" Green Floor Tile	4200	SF	First and Second Floor Corridors, Custodial Closets, Rooms 4, 5, 701 and 804, Administration Office		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change  
Comments:  


---

2017 - Spring: No Change  
Comments:  


---

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002	9"x 9" White Floor Tile	1500	SF	Rooms 4 and 5		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change  
Comments:  


---

2017 - Spring: No Change  
Comments:  


---

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003	9"x 9" Brown Floor Tile	750	SF	Classrooms 7, 8, 703, 704		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
004	9"x 9" Tan Floor Tile	1500	SF	Classrooms 7 and 8, 701,702,703,704		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
005	9"x9" Gray Floor Tile	375	SF	Classroom 6		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006	9"x 9" White w/Black Streaks Floor Tile	375	SF	Rooms 2 and 6		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
007	12"x 12" Tan Floor Tile	100	SF	As Replacement Tile Throughout School, 801,802,803		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
008	9"x 9" Green Floor Tile Mastic	4200	SF	First and Second Floor Corridors, Custodial Closets, Rooms 4 and 5, Administration Office, Room 701		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
009	9"x 9" White Floor Tile Mastic	1500	SF	Rooms 4 and 5		Miscellaneous	No	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
010	9"x 9" Brown Floor Tile Mastic	750	SF	Rooms 7, and 8, 703, 704		Miscellaneous	No	Unknown	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
011	9"x 9" Tan Floor Tile Mastic	750	SF	Rooms 701,702,703,704, 7,and 8		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
012	9"x 9" Gray Floor Tile	375	SF	Room 6		Miscellaneous	No	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
013	9"x 9" White w/Black Streaks Floor Tile Mastic	375	SF	Room 6		Miscellaneous	No	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
014	12"x 12" Tan Floor Tile Mastic	100	SF	As Replacement Tile Throughout School		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
015	Plaster	10000	SF	Throughout Facility		Surface	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
016	12"x 12" Ceiling Tile	750	SF	School Office		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
017	12"x 12" Ceiling Tile Adhesive	750	SF	School Office		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
018	4" Black Vinyl Baseboard	200	LF	Throughout School		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
019	4" Black Baseboard Adhesive	200	LF	Throughout School		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
020	4" Brown Baseboard	100	LF	School Office, Classrooms Throughout School		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
021	4" Brown Baseboard Adhesive	100	LF	School Office, Classrooms Throughout School		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
022	12"x12" Light Brown w/Blue Floor Tile	2250	SF	Classrooms 1, 2, and 3, 801,802,803		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
023	12"x12" Light Brown w/Blue Floor Tile Adhesive	2250	SF	Classrooms 1, 2, and 3, 801,802,803		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
024	Ceramic Tile Grout	150	SF	Washrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
025	Terrazzo	300	SF	Stairs		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
026	Insulation in Fire Doors	200	SF	Entrances		Surface	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
100	9"x 9" Beige Floor Tile	1000	SF	Main Hall and Lunchroom, Room 702		Miscellaneous	No	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
101	9"x 9" Brown Floor Tile	1000	SF	Main Hall and Lunchroom, Room 702		Miscellaneous	No	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
102	12"x 12" Beige Floor Tile	505	SF	East Hall		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
103	12"x 12" Taupe Floor Tile	1000	SF	Lunchroom, 705 and 706		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
104	12"x 12" Gray Floor Tile	700	SF	Kindergarten		Miscellaneous	No				<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
105	12"x 12" Tan Floor Tile	750	SF	Kindergarten		Miscellaneous	No	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
106	12"x 12" Tan Floor Tile	2000	SF	Throughout Facility		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
107	12"x12" Beige Floor Tile Adhesive	200	SF	Stage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
108	12"x12" Tan Floor Tile	1500	SF	Kindergarten		Miscellaneous	Yes				<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
109	2'x 2' Lay In Ceiling Panels	1000	SF	West Side of Church		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
110	Aircell Pipe Insulation	500	LF	Boiler Room and Church Crawlspace		TSI	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
111	12"x 12" Beige Floor Tile	200	SF	Stage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
112	12"x12" Tan Floor Tile	200	SF	Third Floor Classrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
113	Non-Skid Strips on Stairs	10	SF	Stairs		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
114	Wall Tile Grout	200	SF	Kitchen		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
115	Ceramic Tile Grout	300	SF	Washrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
116	Terrazzo Flooring	750	SF	Kitchen and Stairs		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
117	4" Brown Vinyl Baseboards	400	LF	Throughout Facility		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
118	4" Brown Vinyl Baseboard Adhesive	400	LF	Throughout Facility		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
119	9"x9" Beige Floor Tile Mastic	2000	SF	Lunchroom and Auditorium Rooms 702,703,704		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
120	9"x9" Brown Floor Tile Mastic	2000	SF	Auditorium and Lunchroom, Room 702,703,704		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
121	12"x12" Beige Floor Tile Mastic	500	SF	First Floor East Hall		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
122	12"x12" Taupe Floor Tile Mastic	1000	SF	Lunchroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
123	12"x 12" Gray Floor Tile Mastic	100	SF	Kindergarten Classrooms		Miscellaneous	No				<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
124	12"x12" Tan Floor Tile Mastic	1000	SF	Kindergarten Classrooms		Miscellaneous	No	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
125	12"x12" Tan Floor Tile Mastic	500	SF	As Patches Throughout Building		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
126	12"x12" Baige Floor Tile Mastic	200	SF	Stage		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
127	12"x12" Tan Floor Tile Mastic	1500	SF	Kindergarten Classrooms		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
128	Insulation in Fire Doors	288	SF	All Entrances		TSI	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
129	Plaster	15000	SF	Throughout Facility		Surface	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
130	12"x 12" Beige Floor Tile	1500	SF	4th Floor Classrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
131	12"x 12" Beige Floor Tile Mastic	1500	SF	4th Floor Classrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
132	Joint Compound on Fiberglass Pipe Insulation	50	LF	Throughout Facility		TSI	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
133	2' x 4' Lay In Ceiling Panels	1000	SF	Throughout Church Building		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
134	Lay in Ceiling Panels	250	SF	Boiler Room		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
135	9"x 9" Green Floor Tile	200	SF	Second and Third Floor Corridors		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
136	9"x 9" Gray Floor Tile	1200	SF	Second Floor Corridors		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
137	9"x9" Green Floor Tile Mastic	1200	SF	3rd Floor North Classroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
138	9"x 9" Gray Floor Tile Mastic	1500	SF	Second Floor Corridor		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
139	Blue Carpet Adhesive	1500	SF	Second Floor Art and Computer Room		Miscellaneous	No	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
027	Interior Window Caulk	100	SF	School Office		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

ALL LEA Responsibilities, for this school, will be met.

NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Louis Pasteur Elementary School  
Date: \_\_\_\_\_

---

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2016. Asbestos surveillances are conducted every six months.

CHECK ONE

- A copy of this notice was sent home in each child's backpack.
- A copy of this notice was printed in the school's newsletter and sent home with each child
- A copy of this notice was printed in the school's calendar and sent home with each child
- Other.

---

A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**