

# Chicago Public Schools

## 6 Month Asbestos Surveillance

### 2017 - Fall

**School:** Pulaski International School of Chicago  
**Address:** 2230 W. McLean Avenue

**Oracle Unit:** 31211  
**Region:** 02

**Building ID:** 5520 M  
**Mail Room:** 35

**CHECK HERE IF NO CHANGE TO ASBESTOS**

**Asbestos Surveyor:** Heneghan, James  
**Survey Date:** 12/19/2017  
**Email Address:** \_\_\_\_\_

A copy of the 2016/2017 notice to parents and staff regarding the asbestos management plan notifications was distributed via:  
 *Each child's backpack*   
 *Notice printed in school's newsletter*   
 *Notice printed in school's calendar*   
 *Other* |

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
008	Drywall / Compound	50000	SF	Throughout 1974 Addition		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
039	12"x12" White VFT- NOT OBSERVED			Kitchen Serving Area - 1974 New Ceramic Floor Tile		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
040	12"x12" White VFT Mastic- NOT OBSERVED			Kitchen Serving Area - 1974 1 x 1 New Red Ceramic Floor Tile		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
104	12"x12" Tan w/ White Streaks VFT	2800	SF	Gym, 008 1/2, Computer Room, Switch Gear Room, Kitchen Storage - 1974		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
105	12"x12" Tan w/ White Streaks VFT Mastic	2800	SF	Gym, 008 1/2, Computer Room, Switch Gear Room, Kitchen Storage - 1974		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
106	12"x12" Tan w/ Tan Streaks VFT	1000	SF	1st Floor Corridor, Kitchen - 1974		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
107	12"x12" Tan w/ Tan Streaks VFT Mastic	1000	SF	1st Floor Corridor, Kitchen - 1974		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
108	2'x4' Ceiling Tile	10000	SF	Throughout 1974		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
L	MJP E/F/V on Fiberglass Pipe Insulation	500	FITTING	Throughout Modular Building		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

*ALL LEA Responsibilities, for this school, will be met.*



---

Robert Christlieb

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***

NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Pulaski International School of Chicago

Date: 12/22/2017

---

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2016. Asbestos surveillances are conducted every six months.

CHECK ONE

- A copy of this notice was sent home in each child's backpack.
- A copy of this notice was printed in the school's newsletter and sent home with each child
- A copy of this notice was printed in the school's calendar and sent home with each child
- Other.
- 

A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**