

Chicago Public Schools

6 Month Asbestos Surveillance

Fall 2011

School Attucks School (Vacant)
Address 3813 S. Dearborn

Oracle Unit 31021 **Building ID** 2100
Region 4 **General Services Route** 42

Asbestos Surveyor: _____

Survey Date: _____

E-mail Address: _____

CHECK HERE IF NO CHANGE TO ASBESTOS

A copy of the 2011/2012 notice to parents and staff regarding the asbestos management plan notification was distributed via:

Each child's backpack
 Notice printed in school's newsletter/calendar
 Other _____

Principal Signature _____

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	Sink Top Caulking	120	LF	Distributed Throughout 109, 111, 122, 124, 126, 127, 209, 211, 222, 226, 227, 228, 229, 129, 202	Chrysotile	MISC	No	None	120	LF	
<i>3YR Inspector Comments:</i>											
Condition Not Changed in Fall 2010			LF		Chrysotile	MISC				LF	
<i>Comments:</i>											
Condition Not Changed in Spring 2011			LF		Chrysotile	MISC				LF	
<i>Comments:</i>											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

Oracle Unit: 31021

Page 1

Please send a copy of this report to Lynn Crivello, 125 S. Clark St., 17th Floor, GSR #125

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
35	Exterior Door Caulking - NON AHERA			Exterior Door Caulk	Chrysotile			None			
3YR Inspector Comments:											
Condition Not Changed in Fall 2010					Chrysotile						
Comments:											
Condition Not Changed in Spring 2011					Chrysotile						
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
3A	9" x 9" Brown w/Brown & White Streaks Floor Tile	40000	SF	1st & 2nd Corridors, Rms. 110, 112, 115, 114, 129, 204, 206-211, 215-222, 224, 226-229, Storage, 120, 122	Chrysotile	MISC	No	Dist	1890	SF	
3YR Inspector Comments: Damage located in the 1st Floor Hall, Rooms 110, 112, 114, 115, 120, 121, 122, 124, 129, 202, 209, 220, 221, 222, 229 and the 2nd Floor Hall. 2007 Comments: Additional locations Gym storage, Engineers office, and Asst. Principals office.											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
3B	9"x 9" Green with Beige Streaks Floor Tile	900	SF	Office Throughout Corridors and room 112	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments: 2001 - All damaged areas have been abated. 2004 - New damage located in the 1st Floor Corridor.											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
3E	9" x 9" Cream w/Off-White Streaks Floor Tile	9	SF	1st Floor Corridor Areas Across From Room 109	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
3F	9" x 9" Lt. Green w/Off-white & Blue Streaks FT			1st Floor Corridor Areas Across From Room 109	Chrysotile						
3YR Inspector Comments: 2007 Comments: Material not observed no abatement records.											
Condition Not Changed in Fall 2010					Chrysotile						
Comments:											
Condition Not Changed in Spring 2011					Chrysotile						
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
42	12" x 12" Cream and Tan Mix Floor Tile Mastic	20	SF	Principal's Office Toilet	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
45A	Roofing Material - NON AHERA			Building Exterior	Assumed						
3YR Inspector Comments:											
Condition Not Changed in Fall 2010					Assumed						
Comments:											
Condition Not Changed in Spring 2011					Assumed						
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
4A	9" x 9" Brown w/Brown and White Streaks Mastic	40000	SF	Room 219 SW Courtroom, 2nd Floor Hallway NW Corner by Room 202, by Room 112 Entrance	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
4B	9" x 9" Green With Beige Streaks Floor Tile Mastic	900	SF	Distributed Throughout Corridors and Room 112	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
4C	9"x9" Light Brown w/Brown & White Streak FT Mastic	500	SF	Faculty Toilet, Rooms 110 and 122.	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
4D	9"x9" Brown/Gray w/Brown & White Streaks FT Mastic	200	SF	2nd Floor Hallway by Room 216, Room 229 by Entrance Door, Room 219 Near South Side	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
4E	9"x9" Cream w/Off-White Streaks Floor Tile Mastic	9	SF	1st Floor Corridor Areas Across From 109	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
4F	9"x9 Lt. Green w/Off-White & Blue Streak FT Mastic			1st Floor Corridor Areas Across Room 109	Chrysotile	MISC	No				
3YR Inspector Comments: This material was abated 1998.											
Condition Not Changed in Fall 2010					Chrysotile	MISC					
Comments:											
Condition Not Changed in Spring 2011					Chrysotile	MISC					
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
55	Sink Undercoating	32	SF	Rooms 103, 109, 111, 122, 124, 127, 129, 209, 211, 222, 226, 227, 228, 229, 202, 204, &126	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
56	Gray Carpet Adhesive	768	SF	Room 109	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
57	Chalk Board/Poster Board/Marker Board Adhesive	1000	SF	Throughout Classrooms and Corridors	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
58	Interior Lining of Vault Door	325	SF	Office	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
59	Blue Carpet Adhesive	200	SF	Office	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6	12"x12" Beige/Gray w/Beige & Gray Streak FT Mastic	100	SF	2nd Floor Hallway Between Rooms 218 and 219	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
60	Grey Carpet Adhesive	800	SF	Office, Rm 109	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
61	Black Board Adhesive	5000	SF	Classrooms	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
A	Pipe Fittings on Fiberglass Runs	60	LF	Distributed Randomly in Building Interior accessible at unit ventilators, Library, 104 & 103.	Chrysotile	TSI	Yes	None		LF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			LF		Chrysotile	TSI				LF	
Comments:											
Condition Not Changed in Spring 2011			LF		Chrysotile	TSI				LF	
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
C	Joint Compound of Aircell Pipe Insulation	300	LF	Gym Storage, Mechanical Areas, Crawlspace, Engineers Rm, Above ceilings in 1st fl. Hallway, washrooms	Chrysotile	TSI	Yes	Dist	10	LF	
3YR Inspector Comments: 2001 - Slight damage in the 2nd Floor Fan Room, above the 1st Floor Ceiling in the pipe tunnel. 2004 - Damage located in the 2nd Floor Fan Room, above the 1st Floor Corridor and in the Mechanical Areas/Crawlspace. 2007-Damage same as 2004. Additional locations: Above Ceiling kitchen, library, Rms: 122, 124 & 126.											
Condition Not Changed in Fall 2010			LF		Chrysotile	TSI					LF
Comments:											
Condition Not Changed in Spring 2011			LF		Chrysotile	TSI					LF
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
D	Aircell Pipe Insulation	2800	LF	2nd Floor Air Handling Rm., Kitchen	Chrysotile	TSI	Yes	Dist	30	LF	
3YR Inspector Comments: 2001 - Slight damage noted in the 2nd Floor Fan Room, Engineer's Room and Room 101 and Gym Storage. 2004 - Damage located in the 2nd Floor Fan Room, Room 101, Gym Storage and the Mechanical Area. 2007- Additional locations: above ceiling: kitchen library, Rms. 122, 124, & 126.											
Condition Not Changed in Fall 2010			LF		Chrysotile	TSI					LF
Comments:											
Condition Not Changed in Spring 2011			LF		Chrysotile	TSI					LF
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.


HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
E	Cardboard Pipe Insulation	1800	LF	Distributed in Ceiling Areas of the Building and Mechanical Areas	Chrysotile	TSI	Yes	Dist		LF	
3YR Inspector Comments: 2004 - 15 LF significantly damaged insulation located in Kitchen dry food storage. High potential for further disturbance.											
Condition Not Changed in Fall 2010			LF		Chrysotile	TSI				LF	
Comments:											
Condition Not Changed in Spring 2011			LF		Chrysotile	TSI				LF	
Comments:											
Fall 2011											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
M	Joint Compound on Cardboard Pipe Insulation	19	LF	Distributed in Ceiling Areas of Building and Mechanical Areas	Chrysotile	TSI	Yes	None		LF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			LF		Chrysotile	TSI				LF	
Comments:											
Condition Not Changed in Spring 2011			LF		Chrysotile	TSI				LF	
Comments:											
Fall 2011											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

All LEA Responsibilities, for this school, will be met.



Lynn A. Crivello

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

**NOTICE TO PARENTS AND STAFF REGARDING THE
ASBESTOS MANAGEMENT PLAN NOTIFICATION**

School: _____

Date: _____

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all schools every three years. The last inspection was completed in 2010. Asbestos surveillances are conducted every six months.

CHECK ONE

- A copy of this notice was sent home in each child's backpack.
- A copy of this notice was printed in the school's newsletter or calendar and sent home with each child.
- Other – Please indicate how this notice was delivered to parents and staff.

**A COPY OF THIS NOTICE MUST BE PLACED IN THE
SCHOOL'S ASBESTOS MANAGEMENT PLAN.**

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.