

# Chicago Public Schools

## 6 Month Asbestos Surveillance

Fall 2011

School     Fenger Academy  
 Address   11220 S. Wallace

Oracle Unit 46111   Building ID 1310  
 Region 6           General Services Route 48

Asbestos Surveyor: \_\_\_\_\_

Survey Date: \_\_\_\_\_

E-mail Address: \_\_\_\_\_

CHECK HERE IF NO CHANGE TO ASBESTOS

A copy of the 2011/2012 notice to parents and staff regarding the asbestos management plan notification was distributed via:

Each child's backpack    
  Notice printed in school's newsletter/calendar    
  Other \_\_\_\_\_

Principal Signature \_\_\_\_\_

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	<b>Change in Assessment Category</b>
01	12"x12" Off White w/Tan Specks Floor Tile	8976	SF	144, 148, 143, 130, 131, 129, 128, 127, 115, Main Office, Serving Area.	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments: Rooms 144 and 129 has 50sf of broken floor tile											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											<b>YES</b> <b>NO</b>
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

Oracle Unit: 46111

Page 1

Please send a copy of this report to Lynn Crivello, 125 S. Clark St., 17th Floor, GSR #125

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
02	9"x9" Cream Floor Tile w/Brown Streaks	2990	SF	Boiler Room, Engineer's Office, Cafeteria Office, Main Office Vault	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments: Engineer's Office 50sf broken floor tile											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
04	Wainscoat	20000	SF	NOT LISTED	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
08	9"x9" Cream w/Brown Streaks Floor Tile Mastic	2290	SF	Boiler Room, Engineer's Office, Main Hall, 1st Floor, Main Office Vault	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
09	12"x12" Off White w/Tan Specks Floor Tile Mastic	8976	SF	144, 148, 143, 130, 131, 129, 128, 127, 115, Main Office, Serving Area.	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments: 130 has been covered by carpeting, it is assumed that the floor tile is beneath the carpeting											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	9"x9" Beige Floor Tile w/ Tan Steaks	1820	SF	1st Floor North Corridor	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments: Removed Summer of 2009											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
100	12" x 12" White Floor Tile w/ Black Swirls	750	SF	Room 500	Assumed	MISC	Yes	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments: No Room 500											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10A	9"x9" Beige w/Tan Streaks Floor Tile Mastic	1820	SF	1st Floor North Corridor	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments: Removed Summer of 2009											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11	9"x9" Brown Floor Tile w/ Red Streaks	570	SF	ROTC Vault Room	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments: The floor tiles are in poor condition											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11A	9"X9" Brown W/Red Streaks Floor Tile Mastic	570	SF	ROTC Vault Room	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	9"x9" Green Floor Tile w/Tan Streaks	40	SF	Main Office Vault	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12A	9"x9" Green w/Tan Streaks Floor Tile Mastic	40	SF	Main Office Vault	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	9"x9" Pink Floor Tile- ABATED	1050	SF	Room 331	Chrysotile	MISC	No				
3YR Inspector Comments: FLOOR TILE ABATED IN 1999 PER ENGINEER NEW FLOOR TILE INSTALLED ASSUMED ACBM											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC					
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC					
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13A	9"x9" Pink Floor Tile Mastic- ABATED	1050	SF	Room 331	Chrysotile	MISC	No				
3YR Inspector Comments: FLOOR TILE ABATED IN 1999 PER ENGINEER NEW FLOOR TILE INSTALLED ASSUMED ACBM											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC					
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC					
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14	12"x12" Cream Floor Tile w/Tan Specks	19730	SF	Throughout Facility Including: 1st Floor Hall, 2nd and 3rd Floor Hall, Rooms 135, 235, 232, 211, 201, 342, 333, 329, 326, 322, 320, 315, 316, 313, 314, and 311. Rooms 342, 335, 329, 326, 322, 320, 315, 316, 313, and 314	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments: Room 232 floor has wood floors											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14A	12"x12" Cream w/Tan Streaks Floor Tile Mastic	19730	SF	Throughout Facility Including: 1st Floor Hall, 2nd and 3rd Floor Hall, Rooms 135, 235, 232, 211, 201, 342, 333, 329, 326, 322, 320, 315, 316, 313, 314, and 311. Rooms 342, 335, 329, 326, 322, 320, 315, 316, 313, and 314	Chrysotile	MISC	No	None	0	SF	

3YR Inspector Comments:

Condition Not Changed in Fall 2010		SF		Chrysotile	MISC					SF	
------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

Condition Not Changed in Spring 2011		SF		Chrysotile	MISC					SF	
--------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

<b>Fall 2011</b>											<b>YES</b>	<b>NO</b>
------------------	--	--	--	--	--	--	--	--	--	--	------------	-----------

Comment:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	12"x12" Light Gray Floor Tile w/ Gray Streaks	20363	SF	Rooms 111, 113, 212, 214, 216, 228, 233, 242, 244, 319, 322, 326, 330, 335, 344, 348, 350, Cafeteria, Serving Line.	Chrysotile	MISC	No	None	0	SF	

3YR Inspector Comments: MISSING TILES IN SOME AREAS CLASSROOMS CAFERTIA, SERVING LINES

Condition Not Changed in Fall 2010		SF		Chrysotile	MISC					SF	
------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

Condition Not Changed in Spring 2011		SF		Chrysotile	MISC					SF	
--------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

<b>Fall 2011</b>											<b>YES</b>	<b>NO</b>
------------------	--	--	--	--	--	--	--	--	--	--	------------	-----------

Comment:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15A	12"x12" Light Gray w/ Gray Streaks Floor Tile Mastic	20363	SF	Rooms 111, 113, 212, 214, 216, 228, 233, 242, 244, 319, 322, 326, 330, 335, 344, 348, 350, Cafeteria, Serving Line.	Chrysotile	MISC	No	None	0	SF	

3YR Inspector Comments:

Condition Not Changed in Fall 2010		SF		Chrysotile	MISC					SF	
------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

Condition Not Changed in Spring 2011		SF		Chrysotile	MISC					SF	
--------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

<b>Fall 2011</b>											YES NO
------------------	--	--	--	--	--	--	--	--	--	--	--------

Comment:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16	12"x12" Dark Beige Floor Tile w/Beige Specks	5096	SF	Rms 317, 318, Serving Line, Kitchen, Dishwashing Area, Central Hall 1st Floor, Eng's Wshrm	Chrysotile	MISC	No	None	0	SF	

3YR Inspector Comments:

Condition Not Changed in Fall 2010		SF		Chrysotile	MISC					SF	
------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

Condition Not Changed in Spring 2011		SF		Chrysotile	MISC					SF	
--------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

<b>Fall 2011</b>											YES NO
------------------	--	--	--	--	--	--	--	--	--	--	--------

Comment:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16A	12"x12" Dark Beige w/Brown Specks Floor Tile Mastic	5096	SF	Rooms 317, 318, Serving Line, Kitchen, Dishwashing Area, Central Hall 1st Floor, Engineer's Washroom	Chrysotile	MISC	No	None	0	SF	

3YR Inspector Comments:

Condition Not Changed in Fall 2010		SF		Chrysotile	MISC					SF	
------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

Condition Not Changed in Spring 2011		SF		Chrysotile	MISC					SF	
--------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

<b>Fall 2011</b>											YES NO
------------------	--	--	--	--	--	--	--	--	--	--	--------

Comment:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17	12"x12" Gray Floor Tile	5846	SF	Rooms 101, 105, 203, 207, 303, and 307	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments: The inspector found gray linoleum in rooms 101, 105, 303 and 307. No record of abatement on site											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments: Removed Summer of 2009											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17A	12"x12" Gray Floor Tile Mastic	5846	SF	Rooms 101, 105, 203, 207, 303, and 307	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments: The inspector found linoleum in rooms 101, 105, 303 and 307. No record of abatement on site											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments: Removed Summer of 2009											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18	Black Linoleum-carpeted over	5472	SF	Auditorium	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18A	Black Linoleum Mastic	5472	SF	Auditorium	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	Transite Panels (Exhaust Hoods)	0	SF	Rooms 303	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	Aircell Sheeting- ABATED		SF	Swimming Pool Area (Behind Radiator) - abated	Chrysotile	TSI	Yes				
3YR Inspector Comments: Material abated (2001)											
Condition Not Changed in Fall 2010			SF		Chrysotile	TSI					
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	TSI					
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
A	Aircell Duct Wrap	105	SF	Auditorium (Stage)	Chrysotile	TSI	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	TSI				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	TSI				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
AA	12"x12: White Floor Tile	2500	SF	Rooms 201,318, Engineer's Office and Serving Area	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
BB	12"x12" White Floor Tile Mastic	2500	SF	Rooms 201, 218, Engineers Office and Serving Area	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
CC	12"x12" Brown Floor Tile	4000	SF	Rooms 201,318, Cafeteria, Serving Area and Engineer's Office	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
DD	12"x12" Brown Floor Tile Mastic	4000	SF	Room 201,318, Cafeteria, Serving Area and Engineers Office	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
EE	12"x12" Cream w/ Brown Specks Floor Tile	900	SF	Rm 150	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
FF	12"x12" Cream w/Brown Specks Floor Tile Mastic	900	SF	Room 150	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
GG	12"x12" Grey Floor Tile (NOT OBSERVED)			Room 307	Assumed	MISC	No				
3YR Inspector Comments: These floor tiles were not observed by the inspector. No abatement records on site. This room has gray linoleum (HA X).											
Condition Not Changed in Fall 2010					Assumed	MISC					
Comments:											
Condition Not Changed in Spring 2011					Assumed	MISC					
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
HA-1000	2'x4' White Lay In Ceiling Tile	200000	SF	Hallways and Classrooms	Assumed	MISC	Yes	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

Oracle Unit: 46111

Page 13

Please send a copy of this report to Lynn Crivello, 125 S. Clark St., 17th Floor, GSR #125

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
HA-1001	1'x1' White Ceiling Tile	2400	SF	Kitchen Serving Line	Assumed	MISC	Yes	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
HA-1002	Glue for 1'x1' White Ceiling Tile	2400	SF	Kitchen Serving Line	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
HA-1003	2'x2' White Ceiling Tile	1000	SF	Kitchen Food Prep Area	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
HH	12"x12" Grey Floor Tile Mastic (NOT OBSERVED)			Room 307	Assumed	MISC	No				
3YR Inspector Comments: These floor tiles were not observed by the inspector. No abatement records on site. This room has gray linoleum (HA X).											
Condition Not Changed in Fall 2010					Assumed	MISC					
Comments:											
Condition Changed in Spring 2011					Assumed	MISC					
Comments: Removed Summer of 2009											
<b>Fall 2011</b>										<b>YES</b>	<b>NO</b>
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
II	Orange Linoleum and Adhesive	900	LF	Room 301	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			LF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			LF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>										<b>YES</b>	<b>NO</b>
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
JJ	2'x2' Creamic Floor Tile	1500	SF	Washrooms	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>										<b>YES</b>	<b>NO</b>
<b>Comment:</b>											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
MFT-1	12 x 12 Red Floor Tile	180	SF	1st Floor Hallway	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments: Newly Installed in 2009											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
MFT-2	12 x 12 Beige with Brown Streaks Floor Tile	9000	SF	1st Floor Hallway	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments: Newly Installed in 2009											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
MFTM-1	12 x 12 Red Floor Tile Mastic	180	SF	1st Floor Hallway	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments: Newly Installed in 2009											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
MFTM-2	12 x 12 Beige with Brown Streaks Floor Tile Mastic	9000	SF	1st Floor Hallway	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments: Newly Installed in 2009											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
MM	Silver Duct Insulation	300	LF	Basement	Assumed	TSI	Yes	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			LF		Assumed	TSI				SF	
Comments:											
Condition Not Changed in Spring 2011			LF		Assumed	TSI				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
NN	Hair Dryer Insulation	100	SF	Drying Room	Assumed	TSI	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	TSI				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	TSI				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
P	Wire Insulation	250	LF	Auditorium	Chrysotile	MISC	No	None	0	LF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			LF		Chrysotile	MISC					LF
Comments:											
Condition Not Changed in Spring 2011			LF		Chrysotile	MISC					LF
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
PP	MJP E/F/V on Pipe Insulation	50	LF	Boiler Room	Chrysotile	TSI	Yes	None	0	LF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			LF		Chrysotile	TSI					LF
Comments:											
Condition Not Changed in Spring 2011			LF		Chrysotile	TSI					LF
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
Q	Carpet Mastic	8272	SF	Auditorium, 114, 123, 126, 130	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments: This mastic should be sampled by carpet color and style prior to any disturbance of the carpet											
Condition Not Changed in Fall 2010			SF		Assumed	MISC					SF
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC					SF
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

Oracle Unit: 46111

Page 18

Please send a copy of this report to Lynn Crivello, 125 S. Clark St., 17th Floor, GSR #125

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
QQ	MJP E/F/V on Pipe Insulation	3000	LF	Air Tunnels and Basement Corridors	Chrysotile	TSI	Yes	None	0	LF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			LF		Chrysotile	TSI				LF	
Comments:											
Condition Not Changed in Spring 2011			LF		Chrysotile	TSI				LF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
R	Brown Carpet & Carpet Adhesive	1500	SF	Main Office	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
RR	Fire Brick and Mortar	5000	SF	Throughout interior Wall Cavities and Roof Deck	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
S	Grey/Purple Carpet Adhesive	3200	SF	Rooms 118, 132, 171 and 220	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments: Room 171 has no carpeting											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
SPA-1	Plaster on Wire Mesh	50000	SF	Throughout School	Assumed	SURFACE	Yes	None			
3YR Inspector Comments: This plaster was not identified in previous inspections											
Condition Not Changed in Fall 2010			SF		Assumed	SURFACE					
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	SURFACE					
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
SS	Black Pool Lining Material	2000	SF	Pool Room	Assumed	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Assumed	MISC				SF	
Comments:											
Condition Not Changed in Spring 2011			SF		Assumed	MISC				SF	
Comments:											
<b>Fall 2011</b>											YES NO
<b>Comment:</b>											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
T	Green Carpet Adhesive (NOT OBSERVED)			Rooms 117 and 223	Assumed	MISC	No				
3YR Inspector Comments: The inspector did not observe carpeting in these rooms											
Condition Not Changed in Fall 2010					Assumed	MISC					
Comments:											
Condition Not Changed in Spring 2011					Assumed	MISC					
Comments:											
<b>Fall 2011</b>											YES NO
Comment:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
V	12"x12" Off White Floor Tile	8900	SF	Rooms 115, 113, 111, Cafateria, Band Rm. 202, 209, 212, 211, 214, 213, 230, 231, 232, 235, 242, 244, 248, 250, 337, and 342	Chrysotile	MISC	No	None	0	SF	
3YR Inspector Comments:											
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC				SF	
Comments:											
Condition Changed in Spring 2011			SF		Chrysotile	MISC				SF	
Comments: Room 232 has a wood floor											
<b>Fall 2011</b>											YES NO
Comment:											

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
W	12"x12" Off White Floor Tile Mastic	8900	SF	Rooms 115, 113, 111, Cafateria, Band Rm, 202, 209, 212, 211, 214, 213, 230, 231, 232, 235, 242, 244, 248, 250, 337, and 342	Chrysotile	MISC	No	None	0	SF	

3YR Inspector Comments:

Condition Not Changed in Fall 2010		SF		Chrysotile	MISC					SF	
------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

Condition Changed in Spring 2011		SF		Chrysotile	MISC					SF	
----------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments: Room 232 has a wood floor

<b>Fall 2011</b>											YES NO
------------------	--	--	--	--	--	--	--	--	--	--	--------

Comment:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
X	Grey Linoleum and Adhesive	6200	SF	Rooms: 101,105, 203, 207, 244A, 301, 303, 307, 346	Assumed	MISC	No	None	0	SF	

3YR Inspector Comments:

Condition Not Changed in Fall 2010		SF		Assumed	MISC					SF	
------------------------------------	--	----	--	---------	------	--	--	--	--	----	--

Comments:

Condition Not Changed in Spring 2011		SF		Assumed	MISC					SF	
--------------------------------------	--	----	--	---------	------	--	--	--	--	----	--

Comments:

<b>Fall 2011</b>											YES NO
------------------	--	--	--	--	--	--	--	--	--	--	--------

Comment:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
Y	9'x9' Beige Floor Tile	100	SF	Room 100C	Chrysotile	MISC	No	None	0	SF	

3YR Inspector Comments:

Condition Not Changed in Fall 2010		SF		Chrysotile	MISC					SF	
------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

Condition Not Changed in Spring 2011		SF		Chrysotile	MISC					SF	
--------------------------------------	--	----	--	------------	------	--	--	--	--	----	--

Comments:

<b>Fall 2011</b>											YES NO
------------------	--	--	--	--	--	--	--	--	--	--	--------

Comment:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**


HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	
Z	9'x9' Beige Floor Tile Mastic	100	SF	100C	Chrysotile	MISC	No	None	0	SF		
3YR Inspector Comments:												
Condition Not Changed in Fall 2010			SF		Chrysotile	MISC					SF	
Comments:												
Condition Not Changed in Spring 2011			SF		Chrysotile	MISC					SF	
Comments: Location not mentioned?												
<b>Fall 2011</b>											<b>YES</b>	<b>NO</b>
<b>Comment:</b>												

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

Please send a copy of this report to Lynn Crivello, 125 S. Clark St., 17th Floor, GSR #125

*All LEA Responsibilities, for this school, will be met.*



*Lynn A. Crivello*

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

**NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION**

School: \_\_\_\_\_

Date: \_\_\_\_\_

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all schools every three years. The last inspection was completed in 2010. Asbestos surveillances are conducted every six months.

CHECK ONE

- A copy of this notice was sent home in each child's backpack.
- A copy of this notice was printed in the school's newsletter or calendar and sent home with each child.
- Other – Please indicate how this notice was delivered to parents and staff.

**A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.**

*VFT = Vinyl Floor Tile*

*Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.*

Please send a copy of this report to Lynn Crivello, 125 S. Clark St., 17th Floor, GSR #125