

ILLINOIS DEPARTMENT OF PUBLIC HEALTH
AHERA THREE YEAR REINSPECTION
ASBESTOS ABATEMENT PROGRAM
SCHOOL INFORMATION FORM

SECTION I

NAME OF SCHOOL DISTRICT: CHICAGO SCHOOL DIST 299
SCHOOL ID NUMBER: 14-016-2990-0021
SCHOOL NAME: Hyde Park Academy
ADDRESS OF SCHOOL: 6220 S. Stony Island
CITY: Chicago, IL, 60637

DATE LAST THREE YEAR REINSPECTION WAS COMPLETED **3/1/2013**

If the address on this form is different than the address of the building, submit a written explanation.

SECTION II (Please type or print)

PLEASE COMPLETE THE FOLLOWING FOR YOUR THREE YEAR REINSPECTION:

DATE REINSPECTION COMPLETED: 3/9/2016 ENROLLMENT 715
IDPH INSPECTOR LICENSE NUMBER: 100-11167
IDPH LICENSED INSPECTOR NAME (Please Print): Brian Barry
IDPH MP LICENSE NUMBER: 100-03613
IDPH LICENSED MANAGEMENT PLANNER NAME (Please Print): Daniel Juneau

DESIGNATED PERSON (Please Print): Robert Christlieb PHONE: (773) 553-3197



3/9/2016

Signature of Designated Person

Date

SECTION III

PLEASE COMPLETE THE FOLLOWING INFORMATION FOR ANY CHANGES WITHIN THE SCHOOL DISTRICT.

School building has been sold. Date of Sale: _____

School has been closed. Date closed: _____

School building has been demolished. Date: _____

School building is asbestos free since last reinspection: _____

Please explain in writing why the school building is now asbestos free and include the supporting documentation.

If a new school building has been added to the district, submit either an exclusionary statement or a management plan and inspection report. Include the complete name, address and city of school building.

Explain in writing if the address of the building is different than the address on this form:

THREE-YEAR REINSPECTION

CHICAGO SCHOOL DIST 299

Hyde Park Academy

6220 S. Stony Island
Chicago, IL, 60637

Unit: 46171
Building ID: 1390

IDPH ID Number: 14-016-2990-0021

REPORT DATE:

Wednesday, March 09, 2016

Prepared for:

Chicago Public Schools
125 S. Clark Street
Chicago, IL 60603

Prepared by:

Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone (312) 762-2900

Fax (312) 782-5145

**DO NOT REMOVE FROM SCHOOL
REQUIRED BY FEDERAL LAW**

February 23, 2016

Mr. R. Kent Cook
Asbestos Program
Illinois Department of Public Health
525 West Jefferson Street
Springfield, Illinois 62761

Re: Chicago Public Schools - 2016 Three-Year Reinspections

Dear Mr. Cook:

Carnow, Conibear and Associates, Managing Environmental Consultant (MEC), conducted the Three-Year Reinspections and performed management plan updates for the Chicago Public Schools (CPS) facilities in Region 3,4,5 Elementary Schools. Please update your records with the following information.

School District: 299 Unit: 46171 Region: 05 IDPH ID: 14-016-2990-0021

School: Hyde Park Academy Building ID: 1390

Address: 6220 S. Stony Island
Chicago, IL, 60637

Building Contact: Williams, Jesse Contact Phone: 773-469-9926


Current Building Owners: Chicago Public Schools

Review Date: 03/09/2016

Inspector: Brian Barry Inspector IDPH License: 100-11167
Management Planner: Daniel Juneau Management Planner IDPH License: 100-03613

If you have any questions or comments, please contact us at (312) 762-2900

Sincerely,
Carnow, Conibear and Associates



Daniel Juneau
100-03613

Environmental Notification to Occupants

To: Faculty, Staff and Parents
From: Chicago Public Schools
Date: February 23, 2016

RE: Hyde Park Academy, Unit 46171
6220 S. Stony Island
Chicago, IL, 60637

Dear Faculty, Staff and Parents,

This letter is to notify you that the 2016 asbestos three year re-inspection has been completed at Hyde Park Academy , following the Federal Asbestos Hazard Emergency Response Act (AHERA), 40 CFR Part 763, Subpart E and is available for your review at the main office of the school.

Although asbestos-containing materials have been identified at Hyde Park Academy, there is no reason to believe that any threat to the health of students or staff exists at this time. CPS will continue to carefully monitor the condition of asbestos-containing materials and if conditions warrant, all appropriate steps will be taken to maintain the health and safety of all building occupants.

If you have any questions regarding this matter or require additional information, please feel free to contact Robert Christlieb, the designated Local Education Authority's Designated Person at (773) 553-3197 .

Table of Contents

- I. School and Inspection Information
- II. Executive Summary
- III. Methodology
- IV. Abatement History
- V. Reassessments and Recommendations
- VI. Conclusions

Table I: Inspector's Reinspection Findings

Table II: Management Planner's Review

APPENDICES:

- Appendix A: Assessment Sheets, Drawings and Photos
- Appendix B: Inspector and Management Planner Licenses
- Appendix C: Laboratory Accreditations
- Appendix D: Laboratory Results
- Appendix E: Chain of Custody Forms

SCHOOL AND INSPECTION INFORMATION

1. School Information

School: Hyde Park Academy
Address: 6220 S. Stony Island
IDPH ID: 14-016-2990-0021
Contact: Williams, Jesse

Unit: 46171
Chicago, IL, 60637
Building ID: 1390
Phone: 773-469-9926

Region: 05

2. Description of Facility

Original Construction: 1937
Total Square Footage: 23690
Current Occupancy: 715

Additional Construction: 1911,1970,1937
No of Floors: 3

3. LEA Designated Person

Contact: Robert Christlieb
Address: 125 South Clark Street, 17th Floor
Chicago, IL 60603

Phone: (773) 553-3197

4. Managing Environmental Consultant

MEC: Carnow, Conibear and Associates
Contact: Dan Juneau
Address 600 West Van Buren St., Ste 500
Phone: (312) 762-2900

Fax: (312) 782-5145

5. Inspector

Inspector Name: Brian Barry


Inspector IDPH license # 100-11167

Signature:
Date: 2/23/2016

6. Management Planner

Management Planner Name: Daniel Juneau

Management Planner IDPH license # 100-03613

Signature: 
Date: 03/09/2016

7. Review Date: 03/09/2016

8. LEA Designated Person's Acknowledgement

The reinspection report and recommendations have been received by me and appropriate action will be taken by the School District.

Signature: 

Date: 3/9/2016

Name: Robert Christlieb

II. EXECUTIVE SUMMARY

Carnow, Conibear and Associates was retained by the Chicago Public Schools (CPS) to perform a three-year asbestos reinspection of the Hyde Park Academy. This inspection was conducted in accordance with the United States Environmental Protection Agency (USEPA) Asbestos Hazard Emergency Response Act (AHERA) part 763.92 (b), and the ongoing Operations and Maintenance Program (O&M) originally designed in the School's Asbestos Management Plan. The purpose of this three-year reinspection is to record any condition changes in the asbestos-containing building material (ACBM) in the school since the previous three-year reinspection and the six-month periodic surveillance, to identify, assess, and include any Homogeneous Areas (HA) not identified in the Management Plan, and to recommend an appropriate response action to manage asbestos.

The inspector conducted a three-year reinspection of this facility under Illinois Department of Public Health (IDPH) school reinspection requirements and AHERA, sections 763.85 and 763.88. The main building and each addition to the main building, if constructed at different dates, were inspected separately. Laboratory accreditations are included in Appendix C, laboratory results are included in Appendix D, and chain of custody forms are included in Appendix E.

Note: During previous inspections, some of the HA(s) were identified together as 9" x 9" floor tile (FT), mastics assoc. with 9" x 9" FT, 12" x 12" FT, mastics assoc. with 12" x 12" FT, pipe insulation, etc. Some of these HA(s) have been re-identified by areas that are uniform in color, texture, construction date, application date, and general appearance.

The inspector has determined the following:

A. The following HAs have changed assessment categories for Building 1390:

02	hard plaster
05	12x12 ceiling tile
06	2x2 ceiling tile
07	2x4 pinhole ceiling tile
08	2x4 perforated ceiling tile
17	spray-on fireproofing
24	2' ceiling tile
25	2' ceiling tile
34	12x12 lt. Brn. F.T.

64	12x12 ceiling tile text
93	2' x 2' Carpet Square Mastic
94	12" x 12" Gray Floor Tile
95	Mastic Associated w/ 12" x 12" Gray Floor Tile
HA-1001	new 2'x2' white ceiling tile
HA-1002	new 2'x4' white ceiling tile
J	fiberglass fittings

B. The following new homogenous areas have been identified for Building 1390:

- | | |
|----|------------------------------------------------|
| 93 | 2' x 2' Carpet Square Mastic |
| 94 | 12" x 12" Gray Floor Tile |
| 95 | Mastic Associated w/ 12" x 12" Gray Floor Tile |

C. This reinspection covered only physically accessible and visible areas and materials that were identified in the LEA's management plan. The following materials were concealed and/or contained in areas that were inaccessible for sampling and have been classified as Assumed:

01	plaster
03	hard plaster
05	12x12 ceiling tile
07	2x4 pinhole ceiling tile
08	2x4 perforated ceiling tile
09	ceiling tectum panels
12	12x12 metal ceiling tile
16	12x12 ceiling tile text (material not observed)
24	2' ceiling tile
25	2' ceiling tile
27	9x9 med.brn. F.T.
29	12x12 lt. Brn. F.T.
34	12x12 lt. Brn. F.T.
37	12x12 off-white F.T.
38	12x12 white F.T.
42	12x12 lt. Brn. F.T.
44	9x9 tan F.T.
52	12x12 dark tan F.T. mastic
55	12x12 white F.T. mastic
64	12x12 ceiling tile text
65	12x12 ceiling tile text mastic
66	ceiling/tile system
67	12x12 ceiling tile mastic
68	2'x4' ceiling tile
69	drop-in ceiling tile
70	2'x4' ceiling tile
71	black trim vinyl baseboard
75	black trim vinyl baseboard
77	transite wind/sill
78	transite windowsill
79	grey carpet mastic
80	green carpet mastic
81	brown carpet mastic
82	dr. orange carpet mastic
83	orange carpet mastic
84	12" x 12" Light gray with white floor tile
85	Mastic for 12" x 12" Light gray with white floor tile
86	Gray mix Terrazzo
87	12" x 12" White w/gray and black floor tile
88	Mastic for 12" x 12" white with gray and black floor tile
89	12" x 12" white with blue and red floor tile

90	Mastic for 12" x 12" white with Blue and Ref floor tile
91	Black Chalk boards
92	Black Chalk Board Adhesive
93	2' x 2' Carpet Square Mastic
94	12" x 12" Gray Floor Tile
95	Mastic Associated w/ 12" x 12" Gray Floor Tile
HA-1000	Glue for 1'x1' white ceiling tile with grooves
HA-1001	new 2'x2' white ceiling tile
HA-1002	new 2'x4' white ceiling tile
HA-1003	Black sink undercoating
P	2'x2' WHITE CEILING TILE
Q	LINOLEUM FLOORING Grey with white
Q-1	LINOLEUM FLOORING-MASTIC
R	12x12 BROWN VFT
R-1	12x12 BROWN VFT-MASTIC
S	12x12 BLUE VFT
S-1	12x12 BLUE VFT-MASTIC
T	12x12 ORANGE W/ GREEN VFT
T-1	12x12 ORANGE W/ GREEN VFT-MASTIC

The following areas were deemed to be inaccessible:

04	12x12 ceiling tile text
09	ceiling tectum panels
12	12x12 metal ceiling tile
18	9x9 light brown F.T. mastic
19	9x9 tan F.T. mastic
20	9x9 med. Brn. F.T. mastic
21	12x12 tan F.T. mastic
22	12x12 tan F.T. mastic
23	12x12 lt. Brn. Tile mastic
47	9x9 med. brn. F.T. mastic
48	9x9 tan F.T. mastic
49	12x12 beige F.T. Mastic
50	12x12 brown F.T. mastic
52	12x12 dark tan F.T. mastic
53	12x12 lt. Grn. F.T. mastic
54	12x12 off-white F.T. mastic
56	12x12 Tan speckled F.T. mastic
57	9x9 brown F.T. mastic
58	9x9 drk.brn. F.T. mastic
59	12x12 lt. Brn. F.T. mastic
60	9x9 med. Brn. F.T. mastic
61	9x9 tan F.T. mastic
62	9x9 brown F.T. mastic

65	12x12 ceiling tile text mastic
67	12x12 ceiling tile mastic
72	black trim vinyl baseboard mastic
74	blk. Trim vinyl baseboard mastic
76	black trim vinyl baseboard mastic
79	grey carpet mastic
80	green carpet mastic
81	brown carpet mastic
82	dr. orange carpet mastic
83	orange carpet mastic
85	Mastic for 12" x 12" Light gray with white floor tile
88	Mastic for 12" x 12" white with gray and black floor tile
90	Mastic for 12" x 12" white with Blue and Ref floor tile
92	Black Chalk Board Adhesive
93	2' x 2' Carpet Square Mastic
95	Mastic Associated w/ 12" x 12" Gray Floor Tile
I	cardboard fittings
J	fiberglass fittings
K	aircell duct insulation
L	aircell pipe insulation
N	fiber glass fittings
Q-1	LINOLEUM FLOORING-MASTIC
R-1	12x12 BROWN VFT-MASTIC
S-1	12x12 BLUE VFT-MASTIC
T-1	12x12 ORANGE W/ GREEN VFT-MASTIC

Materials were also listed as "assumed" if they were in good condition and sampling was not conducted to avoid damage.

This reinspection was conducted by Brian Barry, IDPH License # 100-11167. The Management Plan was updated by Daniel Juneau, IDPH License # 100-03613. Inspector and Management Planner Licenses are included in Appendix B.

III. METHODOLOGY

Tasks performed on-site included the following:

1. Review current management plan, identify HA(s) and extract appropriate information.
2. Examine and verify abatement records.
3. Touch and visually and physically reinspect and reassess the condition of all friable known or assumed ACBM.
4. Touch and visually and physically reinspect all non-friable known or assumed ACBM to determine whether these materials have become friable since the last inspection or periodic surveillance.
5. Identify any condition changes that may affect Hazard Ranking of known ACBM or Assumed ACBM, as well as any HA(s) that have become friable since the last reinspection.
6. Collect bulk samples from each newly discovered friable HA or previously assumed and submit for laboratory analysis.
7. Tabulate reinspection findings and submit for management planner review and recommendations with appropriate response actions based on the AHERA Damage Category of the ACBM.
8. Submit reinspection findings and management planner recommendations to the LEA within thirty (30) days for inclusion into the management plan.

IV. ABATEMENT HISTORY

The information collected from the existing management plan and inspection report(s) and from interviews with the school official revealed that the following asbestos abatement was conducted at the school since the previous Three year Reinspection.

Abatement Dates:

V. REASSESSMENTS AND RECOMMENDATIONS

The reassessments and recommendations are summarized in Tables I and II on the following pages. Detailed Hazard Assessment Sheets and Drawings and Photos (if applicable) are included in Appendix A.

VI. CONCLUSIONS

The Hyde Park Academy Building 1390 Three-Year reinspection has been completed and response actions have been recommended for both friable and non-friable materials. A timely execution of the response actions recommended will enable the LEA and the Designated Person(s) to effectively manage the existing ACBM.

This three-year reinspection report should be inspected in the current Management plan at the CPS Central Office, and one (1) copy should be kept at the school for use when planning any renovation and/or demolition activities in areas where ACBM has been identified. Also, periodic surveillance documentation and any summary reports from any response actions that are executed at the school should be used to update the Management Plan.

Table I
Inspector's Reinspection Findings

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
01	plaster	140,000	SF	building 1911	ASSUMED	SURFACE	N	NONE	0		No	ACBM with the potential for damage		LOW
02	hard plaster	140,000	SF	building 1937	CHR	SURFACE	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
03	hard plaster	140,000	SF	building 1970	ASSUMED	SURFACE	N	NONE	0		No	ACBM with the potential for damage		LOW
04	12x12 ceiling tile text	700	SF	1937 building room 142	CHR	MISC	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
05	12x12 ceiling tile	10,000	SF	1937 building	ASSUMED	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
06	2x2 ceiling tile	34,500	SF	1911 building	AMO	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
07	2x4 pinhole ceiling tile	34,500	SF	1911 building	ASSUMED	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
08	2x4 perforated ceiling tile	1,500	SF	1911 building	ASSUMED	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
09	ceiling tectum panels	13,000	SF	1911 buildings (50 ft. in air inaccessible to sample)	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
10	9x9 light brown F.T.	16,800	SF	130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346	CHR	MISC	N	DIST	500		No	ACBM with the potential for damage	5	LOW
11	12x12 tan F.T.	99,000	SF	130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346	CHR	MISC	N	DIST	100		No	ACBM with the potential for damage	5	LOW
12	12x12 metal ceiling tile	3,750	SF	1911 natatorium (ceiling is inaccessible)	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
13	transite table tops	1,000	SF	Science labs	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
14	transite panel material	2,500	SF	Science labs 312, 316	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
15	acoustical ceiling tile (no material)			1911 building	UNDEFINE D									
16	12x12 ceiling tile text (material not observed)			1937 building	ASSUMED	MISC								
17	spray-on fireproofing	45,000	SF	BLDG 1911 above 2nd & 3rd floor ceiling tile	CHR	SURFACE	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
18	9x9 light brown F.T. mastic	16,800	SF	130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
19	9x9 tan F.T. mastic	11,400	SF	1st, 2nd & 3rd floor south hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
20	9x9 med. Brn. F.T. mastic	21,000	SF	SEE COMMENTS FOR ROOM LOCATIONS	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
21	12x12 tan F.T. mastic	99,000	SF	SEE COMMENTS FOR ROOM LOCATIONS	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
22	12x12 tan F.T. mastic	900	SF	1937 building, patched areas of 1st, 2nd flr hallway	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
23	12x12 lt. Brn. Tile mastic	1,700	SF	1970 building, weight room	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
24	2' ceiling tile	14,000	SF	1937 building	ASSUMED	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
25	2' ceiling tile	1,200	SF	1970/ rear of rm. 143 2nd flr. S/W corridor	ASSUMED	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
26	9x9 tan F.T.	11,400	SF	1st, 2nd & 3rd floor south hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
27	9x9 med.brn. F.T.	21,000	SF	SEE COMMENTS FOR ROOM LOCATIONS	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
28	12x12 tan F.T.	900	SF	1937 building, patched areas of 1st, 2nd flr hallway	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
29	12x12 lt. Brn. F.T.	1,700	SF	1970 building,	ASSUMED	MISC	N	NONE	0		No	ACBM with the		LOW

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				weight room								potential for damage		
30	9x9 med. Brn. F.T.	2,500	SF	Room 246, southeastern hall on 2nd floor	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
31	9x9 tan F.T.	1,300	SF	Room 210, 311	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
32	12x12 beige F.T.	750	SF	Small hallways leading to library on 2nd and 3rd floors.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
33	12x12 brown F.T.	4,000	SF	Locker rooms 1st floor	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
34	12x12 lt. Brn. F.T.	11,000	SF	1911 building	ASSUMED	MISC	N	NONE	0		Yes	ACBM with the potential for damage		LOW
35	12x12 dark tan F.T.	800	SF	1911 building, patched areas	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
36	12x12 lt. Grn. F.T.	1,600	SF	Room 133	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
37	12x12 off-white F.T.	1,825	SF	Engineer's office	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
38	12x12 white F.T.	2,500	SF	Rooms 135, 137	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
39	12x12 Tan speckled F.T.	490	SF	Patched areas of 1st flr north hallway	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
40	9x9 brown F.T.	950	SF	1937 building, patched areas of 1st, 2nd, 3rd flr hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
41	9x9 drk.brn. F.T.	75	SF	1937 building, patched areas of 1st, 2nd, 3rd flr hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
42	12x12 lt. Brn. F.T.	1,500	SF	1937 building, patched areas of 1st, 2nd & 3rd floor south hallways	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
43	9x9 med. Brn. F.T.	1,800	SF	Team, Visitor, Boy's & Girl's Locker Rooms	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
44	9x9 tan F.T.	425	SF	1937 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
45	9x9 brown F.T.	3,100	SF	SEE COMMENTS FOR ROOM LOCATIONS	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
46	9x9 brown F.T.	600	SF	Patched areas of 1st, 2nd & 3rd floor south hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
47	9x9 med. brn. F.T. mastic	2,500	SF	Room 246, southeastern hall on 2nd floor	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
48	9x9 tan F.T. mastic	1,300	SF	Room 210, 311	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
49	12x12 beige F.T. Mastic	750	SF	Small hallways leading to library on 2nd and 3rd floors.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
50	12x12 brown F.T. mastic	4,000	SF	Locker rooms 1st floor	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
51	12x12 lt. Brn. F.T. mastic			Auditorium	ABATED	MISC								
52	12x12 dark tan F.T. mastic	800	SF	1911 building, patched areas	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
53	12x12 lt. Grn. F.T. mastic	1,600	SF	Room 133	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
54	12x12 off-white F.T. mastic	1,825	SF	Engineer's office	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
55	12x12 white F.T. mastic	2,500	SF	Rooms 135, 137	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
56	12x12 Tan speckled F.T. mastic	490	SF	Patched areas of 1st flr north hallway	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
57	9x9 brown F.T. mastic	950	SF	1937 building, patched areas of 1st, 2nd, 3rd flr hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
58	9x9 drk.brn. F.T. mastic	75	SF	1937 building, patched areas of 1st, 2nd, 3rd flr hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
59	12x12 lt. Brn. F.T. mastic	1,500	SF	1937 building, patched areas of 1st, 2nd & 3rd floor south hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
60	9x9 med. Brn. F.T. mastic	1,800	SF	Team, Visitor, Boy's & Girl's Locker Rooms	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
61	9x9 tan F.T. mastic	425	SF	1937 building	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
62	9x9 brown F.T. mastic	3,100	SF	SEE COMMENTS FOR ROOM LOCATIONS	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
63	9x9 lt. Brn. F.T. mastic	600	SF	Patched areas of 1st, 2nd & 3rd floor south hallways	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
64	12x12 ceiling tile text	25,000	SF	1911 building	ASSUMED	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable		LOW

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
												suspect ACBM		
65	12x12 ceiling tile text mastic	25,000	SF	1911 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
66	ceiling/tile system	15,000	SF	1911 building	ASSUMED	MISC	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
67	12x12 ceiling tile mastic	1,300	SF	1937 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
68	2'x4' ceiling tile	800	SF	1937 building	ASSUMED	MISC	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
69	drop-in ceiling tile	8,500	SF	1937 building	ASSUMED	MISC	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
70	2'x4' ceiling tile	1,200	SF	1970 building	ASSUMED	MISC	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
71	black trim vinyl baseboard	18,000	LF	1911 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
72	black trim vinyl baseboard mastic	18,000	LF	1911 building	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
73	blk. Trim vinyl baseboard	275	LF	1937 building	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
74	blk. Trim vinyl baseboard mastic	275	LF	1937 building	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
75	black trim vinyl baseboard	300	LF	1970 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
76	black trim vinyl baseboard mastic	300	LF	1970 building	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
77	transite wind/sill	3,000	SF	1911 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
78	transite windowsill	550	SF	1937 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
79	grey carpet mastic	950	SF	1911 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
80	green carpet mastic	1,900	SF	1911 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
81	brown carpet mastic	1,200	SF	1911 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
82	dr. orange carpet mastic	15,000	SF	1911 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
83	orange carpet mastic	21,000	SF	1911 building	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
84	12" x 12" Light gray with white floor tile	3,600	SF	Auditorium, Rm 142	ASSUMED	MISC	N	NONE	0		No	ACBM with the		LOW

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
												potential for damage		
85	Mastic for 12" x 12" Light gray with white floor tile	3,000	SF	Auditorium	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
86	Gray mix Terrazzo	5,000	SF	Entrance and stairwells	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
87	12" x 12" White w/gray and black floor tile	3,200	SF	Room 114 and patches in room 210	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
88	Mastic for 12" x 12" white with gray and black floor tile	500	SF	Room 114 and patches in Room 210	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
89	12" x 12" white with blue and red floor tile	1,800	SF	Room 117	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
90	Mastic for 12" x 12" white with Blue and Ref floor tile	1,800	SF	Room 117	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
91	Black Chalk boards	13,000	SF	Classrooms	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
92	Black Chalk Board Adhesive	13,000	SF	Classrooms	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
93	2' x 2' Carpet Square Mastic	2,000	SF	Library	ASSUMED	MISC	N	NONE	0		Yes	ACBM with the potential for damage		LOW
94	12" x 12" Gray Floor Tile	8,000	SF	Rooms 142, 341, 344, 345, and Stage 107A	ASSUMED	MISC	N	NONE	0		Yes	ACBM with the potential for damage		LOW
95	Mastic Associated w/ 12" x 12" Gray Floor Tile	8,000	SF	Rooms 142, 341, 344, 345, and Stage 107A	ASSUMED	MISC	N	NONE	0		Yes	ACBM with the potential for damage		LOW
A	Mag block			boiler	ABATED	TSI		None						
B	mag block			garage	ABATED	TSI								
C	mag block			suspended in pump room	ABATED	TSI								
D	mag block ABATED			pump rm.	ABATED	TSI								
E	mag block			boiler room	ABATED	TSI								
F	preform pipe			boiler room & tunnel	ABATED	TSI		None						Moderate
G	preform fittings			basement & tunnels	ABATED	TSI		None						Moderate
H	cardboard pipe insulation			compressor rm./ pump rm. Absorption rm./ tunnels	ABATED	TSI								
HA-1000	Glue for 1'x1' white ceiling tile with grooves	34,500	SF	Rm. 301, 303, 305, 307, 309, 311	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
HA-1001	new 2'x2' white ceiling tile	35,000	SF	throughout 1st and 3rd floor	ASSUMED	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
HA-1002	new 2'x4' white ceiling tile	35,000	SF	throughout 1st and 3rd floors	ASSUMED	MISC	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
HA-1003	Black sink undercoating	15	SF	Art rooms 401, 402, 406	ASSUMED	SURFACE	N	NONE	0		No	ACBM with potential for significant damage		LOW
I	cardboard fittings	40	LF	tunnels/compressor rm.	CHR	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
J	fiberglass fittings	1,800	LF	1911 building	CHR	TSI	Y	NONE	0		Yes	Any remaining friable ACBM or friable suspect ACBM		LOW
K	aircell duct insulation	30	SF	tunnels	CHR	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
L	aircell pipe insulation	2,240	LF	pump rm. Tunnels	CHR	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
M	fittings on aircell	140	LF	pump room 1911	CHR	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
N	fiber glass fittings	400	LF	1937 building	CHR	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
O	fiberglass fittings			1970bldg	NOT_TEST ED	MISC		None						Moderate
P	2'x2' WHITE CEILING TILE	69,000	SF	THROUGHOUT 1911 BLDG	ASSUMED	MISC	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
Q	LINOLEUM FLOORING Grey with white	2,000	SF	ROOM 245, and 343	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
Q-1	LINOLEUM FLOORING-MASTIC	950	SF	ROOM 245, and 343	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
R	12x12 BROWN VFT	2,300	SF	ROOMS 341, 333	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
R-1	12x12 BROWN VFT-MASTIC	2,300	SF	ROOMS 341, 333	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
S	12x12 BLUE VFT	3,250	SF	EAST STAIRWELL, FRONT OF AUDITORIUM & ALL OF AUDITORIUM	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
S-1	12x12 BLUE VFT-MASTIC	3,250	SF	EAST STAIRWELL,	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				FRONT OF AUDITORIUM & ALL OF AUDITORIUM										
T	12x12 ORANGE W/ GREEN VFT	450	SF	BACK STAGE OF AUDITORIUM W/ HALLWAY	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
T-1	12x12 ORANGE W/ GREEN VFT-MASTIC	450	SF	BACK STAGE OF AUDITORIUM W/ HALLWAY	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

Reinspection Date <u>2/23/2016</u>
Inspector Name <u>Brian Barry</u>
<u>100-11167</u> <u>5/15/2017</u>
Inspector's IDPH License Number / Expiration Date

Inspector's Comments

HA Number:	Inspector Comments:
01	
02	
03	
04	
05	
06	
07	
08	
09	
10	Damage is located throughout the 1st, 2nd, and 3rd corridors
11	Damage is located in the 1st, 2nd, and 3rd floor corridors
12	
13	
14	
15	
16	Not observed 2016
17	
18	
19	
20	
21	
22	
23	
24	

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	
81	
82	

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
A	
B	
C	
D	
E	
F	
G	
H	
HA-1000	
HA-1001	
HA-1002	
HA-1003	
I	
J	
K	
L	

Chicago Public Schools

School Hyde Park Academy Unit 46171 Building ID 1390

Address 6220 S. Stony Island Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900 Fax: (312) 782-5145

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
M	
N	
O	
P	
Q	
Q-1	
R	
R-1	
S	
S-1	
T	
T-1	

Table II

Management Planner's Review

Chicago Public Schools

School Hyde Park Academy
Address 6220 S. Stony Island

Unit 46171
Chicago, IL, 60637

Building ID 1390
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Num	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
01	plaster	140,000	SF	building 1911	Assumed	SURFACE	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
02	hard plaster	140,000	SF	building 1937	Chrysotile	SURFACE	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
03	hard plaster	140,000	SF	building 1970	Assumed	SURFACE	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
04	12x12 ceiling tile text	700	SF	1937 building room 142	Chrysotile	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
05	12x12 ceiling tile	10,000	SF	1937 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
06	2x2 ceiling tile	34,500	SF	1911 building	Amosite	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
07	2x4 pinhole ceiling tile	34,500	SF	1911 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
08	2x4 perforated ceiling tile	1,500	SF	1911 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
09	ceiling tectum panels	13,000	SF	1911 buildings (50 ft. in air inaccessible to sample)	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
10	9x9 light brown F.T.	16,800	SF	130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346	Chrysotile	MISC	No	500	SF	6 ACBM with the potential for damage	Follow O&M Plan
11	12x12 tan F.T.	99,000	SF	130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346	Chrysotile	MISC	No	100	SF	6 ACBM with the potential for damage	Follow O&M Plan
12	12x12 metal ceiling tile	3,750	SF	1911 natatorium (ceiling is inaccessible)	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
13	transite table tops	1,000	SF	Science labs	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
14	transite panel material	2,500	SF	Science labs 312, 316	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
15	accoustical ceiling tile (no material)			1911 building	Undefined						
16	12x12 ceiling tile text (material not observed)			1937 building	Assumed	MISC					
17	spray-on fireproofing	45,000	SF	BLDG 1911 above 2nd & 3rd floor ceiling tile	Chrysotile	SURFACE	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
18	9x9 light brown F.T. mastic	16,800	SF	130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Hyde Park Academy

Unit 46171

Building ID 1390

Address 6220 S. Stony Island

Chicago, IL, 60637

Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Num	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
19	9x9 tan F.T. mastic	11,400	SF	1st, 2nd & 3rd floor south hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
20	9x9 med. Brn. F.T. mastic	21,000	SF	SEE COMMENTS FOR ROOM LOCATIONS	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
21	12x12 tan F.T. mastic	99,000	SF	SEE COMMENTS FOR ROOM LOCATIONS	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
22	12x12 tan F.T. mastic	900	SF	1937 building, patched areas of 1st, 2nd flr hallway	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
23	12x12 lt. Brn. Tile mastic	1,700	SF	1970 building, weight room	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
24	2' ceiling tile	14,000	SF	1937 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
25	2' ceiling tile	1,200	SF	1970/ rear of rm. 143 2nd flr. S/W corridor	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
26	9x9 tan F.T.	11,400	SF	1st, 2nd & 3rd floor south hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
27	9x9 med.brn. F.T.	21,000	SF	SEE COMMENTS FOR ROOM LOCATIONS	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
28	12x12 tan F.T.	900	SF	1937 building, patched areas of 1st, 2nd flr hallway	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
29	12x12 lt. Brn. F.T.	1,700	SF	1970 building, weight room	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
30	9x9 med. Brn. F.T.	2,500	SF	Room 246, southeastern hall on 2nd floor	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
31	9x9 tan F.T.	1,300	SF	Room 210, 311	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
32	12x12 beige F.T.	750	SF	Small hallways leading to library on 2nd and 3rd floors.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
33	12x12 brown F.T.	4,000	SF	Locker rooms 1st floor	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
34	12x12 lt. Brn. F.T.	11,000	SF	1911 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
35	12x12 dark tan F.T.	800	SF	1911 building, patched areas	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
36	12x12 lt. Grn. F.T.	1,600	SF	Room 133	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
37	12x12 off-white F.T.	1,825	SF	Engineer's office	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
38	12x12 white F.T.	2,500	SF	Rooms 135, 137	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
39	12x12 Tan speckled F.T.	490	SF	Patched areas of 1st flr north hallway	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
40	9x9 brown F.T.	950	SF	1937 building, patched areas of 1st, 2nd, 3rd flr hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
41	9x9 drk.brn. F.T.	75	SF	1937 building, patched areas of 1st, 2nd, 3rd flr hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
42	12x12 lt. Brn. F.T.	1,500	SF	1937 building, patched areas of 1st, 2nd & 3rd floor south hallways	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Hyde Park Academy

Unit 46171

Building ID 1390

Address 6220 S. Stony Island

Chicago, IL, 60637

Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Num	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
43	9x9 med. Brn. F.T.	1,800	SF	Team, Visitor, Boy's & Girl's Locker Rooms	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
44	9x9 tan F.T.	425	SF	1937 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
45	9x9 brown F.T.	3,100	SF	SEE COMMENTS FOR ROOM LOCATIONS	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
46	9x9 brown F.T.	600	SF	Patched areas of 1st, 2nd & 3rd floor south hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
47	9x9 med. brn. F.T. mastic	2,500	SF	Room 246, southeastern hall on 2nd floor	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
48	9x9 tan F.T. mastic	1,300	SF	Room 210, 311	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
49	12x12 beige F.T. Mastic	750	SF	Small hallways leading to library on 2nd and 3rd floors.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
50	12x12 brown F.T. mastic	4,000	SF	Locker rooms 1st floor	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
51	12x12 lt. Brn. F.T. mastic			Auditorium	Abated	MISC					
52	12x12 dark tan F.T. mastic	800	SF	1911 building, patched areas	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
53	12x12 lt. Grn. F.T. mastic	1,600	SF	Room 133	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
54	12x12 off-white F.T. mastic	1,825	SF	Engineer's office	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
55	12x12 white F.T. mastic	2,500	SF	Rooms 135, 137	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
56	12x12 Tan speckled F.T. mastic	490	SF	Patched areas of 1st flr north hallway	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
57	9x9 brown F.T. mastic	950	SF	1937 building, patched areas of 1st, 2nd, 3rd flr hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
58	9x9 drk.brn. F.T. mastic	75	SF	1937 building, patched areas of 1st, 2nd, 3rd flr hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
59	12x12 lt. Brn. F.T. mastic	1,500	SF	1937 building, patched areas of 1st, 2nd & 3rd floor south hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
60	9x9 med. Brn. F.T. mastic	1,800	SF	Team, Visitor, Boy's & Girl's Locker Rooms	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
61	9x9 tan F.T. mastic	425	SF	1937 building	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
62	9x9 brown F.T. mastic	3,100	SF	SEE COMMENTS FOR ROOM LOCATIONS	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
63	9x9 lt. Brn. F.T. mastic	600	SF	Patched areas of 1st, 2nd & 3rd floor south hallways	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
64	12x12 ceiling tile text	25,000	SF	1911 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
65	12x12 ceiling tile text mastic	25,000	SF	1911 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
66	ceiling/tile system	15,000	SF	1911 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable	Follow O&M Plan

Chicago Public Schools

School Hyde Park Academy

Unit 46171

Building ID 1390

Address 6220 S. Stony Island

Chicago, IL, 60637

Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Num	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
										suspect ACBM	
67	12x12 ceiling tile matsic	1,300	SF	1937 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
68	2'x4' ceiling tile	800	SF	1937 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
69	drop-in ceiling tile	8,500	SF	1937 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
70	2'x4' ceiling tile	1,200	SF	1970 building	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
71	black trim vinyl baseboard	18,000	LF	1911 building	Assumed	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
72	black trim vinyl baseboard mastic	18,000	LF	1911 building	Chrysotile	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
73	blk. Trim vinyl baseboard	275	LF	1937 building	Chrysotile	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
74	blk. Trim vinyl baseboard mastic	275	LF	1937 building	Chrysotile	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
75	black trim vinyl baseboard	300	LF	1970 building	Assumed	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
76	black trim vinyl baseboard mastic	300	LF	1970 building	Chrysotile	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
77	transite wind/sill	3,000	SF	1911 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
78	transite windowsill	550	SF	1937 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
79	grey carpet mastic	950	SF	1911 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
80	green carpet mastic	1,900	SF	1911 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
81	brown carpet mastic	1,200	SF	1911 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
82	dr. orange carpet mastic	15,000	SF	1911 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
83	orange carpet mastic	21,000	SF	1911 building	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
84	12" x 12" Light gray with white floor tile	3,600	SF	Auditorium, Rm 142	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
85	Mastic for 12" x 12" Light gray with white floor tile	3,000	SF	Auditorium	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
86	Gray mix Terrazzo	5,000	SF	Entrance and stairwells	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
87	12" x 12" White w/gray and black floor tile	3,200	SF	Room 114 and patches in room 210	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
88	Mastic for 12" x 12" white with gray and black floor tile	500	SF	Room 114 and patches in Room 210	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
89	12" x 12" white with blue and red floor tile	1,800	SF	Room 117	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
90	Mastic for 12" x 12" white with Blue and Ref floor tile	1,800	SF	Room 117	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
91	Black Chalk boards	13,000	SF	Classrooms	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
92	Black Chalk Board Adhesive	13,000	SF	Classrooms	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
93	2' x 2' Carpet Square Mastic	2,000	SF	Library	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
94	12" x 12" Gray Floor Tile	8,000	SF	Rooms 142, 341, 344, 345, and Stage 107A	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Hyde Park Academy

Unit 46171

Building ID 1390

Address 6220 S. Stony Island

Chicago, IL, 60637

Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Num	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
95	Mastic Associated w/ 12" x 12" Gray Floor Tile	8,000	SF	Rooms 142, 341, 344, 345, and Stage 107A	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
A	Mag block			boiler	Abated	TSI					
B	mag block			garage	Abated	TSI					
C	mag block			suspended in pump room	Abated	TSI					
D	mag block ABATED			pump rm.	Abated	TSI					
E	mag block			boiler room	Abated	TSI					
F	preform pipe			boiler room & tunnel	Abated	TSI					
G	preform fittings			basement & tunnels	Abated	TSI					
H	cardboard pipe insulation			compressor rm./ pump rm. Absorption rm./ tunnels	Abated	TSI					
HA-1000	Glue for 1'x1' white ceiling tile with grooves	34,500	SF	Rm. 301, 303, 305, 307, 309, 311	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
HA-1001	new 2'x2' white ceiling tile	35,000	SF	throughout 1st and 3rd floor	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
HA-1002	new 2'x4' white ceiling tile	35,000	SF	throughout 1st and 3rd floors	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
HA-1003	Black sink undercoating	15	SF	Art rooms 401, 402, 406	Assumed	SURFACE	No	0	SF	5 ACBM with potential for significant damage	Follow O&M Plan
I	cardboard fittings	40	LF	tunnels/compressor rm.	Chrysotile	TSI	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
J	fiberglass fittings	1,800	LF	1911 building	Chrysotile	TSI	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
K	aircell duct insulation	30	SF	tunnels	Chrysotile	TSI	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
L	aircell pipe insulation	2,240	LF	pump rm. Tunnels	Chrysotile	TSI	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
M	fittings on aircell	140	LF	pump room 1911	Chrysotile	TSI	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
N	fiber glass fittings	400	LF	1937 building	Chrysotile	TSI	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
O	fiberglass fittings			1970bldg	Not Tested	MISC					
P	2'x2' WHITE CEILING TILE	69,000	SF	THROUGHOUT 1911 BLDG	Assumed	MISC	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
Q	LINOLEUM FLOORING Grey with white	2,000	SF	ROOM 245, and 343	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
Q-1	LINOLEUM FLOORING-MASTIC	950	SF	ROOM 245, and 343	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Hyde Park Academy
Address 6220 S. Stony Island

Unit 46171
 Chicago, IL, 60637

Building ID 1390
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Num	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
R	12x12 BROWN VFT	2,300	SF	ROOMS 341, 333	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
R-1	12x12 BROWN VFT-MASTIC	2,300	SF	ROOMS 341, 333	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
S	12x12 BLUE VFT	3,250	SF	EAST STAIRWELL, FRONT OF AUDITORIUM & ALL OF AUDITORIUM	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
S-1	12x12 BLUE VFT-MASTIC	3,250	SF	EAST STAIRWELL, FRONT OF AUDITORIUM & ALL OF AUDITORIUM	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
T	12x12 ORANGE W/ GREEN VFT	450	SF	BACK STAGE OF AUDITORIUM W/ HALLWAY	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
T-1	12x12 ORANGE W/ GREEN VFT-MASTIC	450	SF	BACK STAGE OF AUDITORIUM W/ HALLWAY	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Hyde Park Academy
Address 6220 S. Stony Island

Unit 46171
 Chicago, IL, 60637

Building ID 1390
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

Review Date	3/9/2016
Manager Planner Name	Daniel Juneau
100-03613	5/15/2016
Manager IDPH License No/Expiration	

HA Number	Management Comments
01	
02	
03	
04	
05	
06	
07	
08	
09	
10	Repair or Replace when possible. Continue O&M
11	Repair or Replace when possible. Continue O&M
12	
13	
14	
15	
16	If observed, implement O&M.
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	

Chicago Public Schools

School Hyde Park Academy

Unit 46171

Building ID 1390

Address 6220 S. Stony Island

Chicago, IL, 60637

Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	

Chicago Public Schools

School Hyde Park Academy
Address 6220 S. Stony Island

Unit 46171
Chicago, IL, 60637

Building ID 1390
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	

Chicago Public Schools

School Hyde Park Academy
Address 6220 S. Stony Island

Unit 46171
 Chicago, IL, 60637

Building ID 1390
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
A	
B	
C	
D	
E	
F	
G	
H	
HA-1000	
HA-1001	
HA-1002	
HA-1003	

Chicago Public Schools

School Hyde Park Academy

Unit 46171

Building ID 1390

Address 6220 S. Stony Island

Chicago, IL, 60637

Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) Carnow, Conibear and Associates

600 West Van Buren St., Ste 500

Phone: (312) 762-2900

Fax: (312) 782-5145

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
I	
J	
K	
L	
M	
N	
O	
P	
Q	
Q-1	
R	
R-1	
S	
S-1	
T	
T-1	

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **01**
MATERIAL DESCRIPTION: **plaster**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **building 1911**

MATERIAL QUANTITY: **140000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **01**
MATERIAL DESCRIPTION: **plaster**
MATERIAL LOCATION: **building 1911**
MATERIAL QUANTITY: **140000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **02**
MATERIAL DESCRIPTION: **hard plaster**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **building 1937**
MATERIAL QUANTITY: **140000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **02**
MATERIAL DESCRIPTION: **hard plaster**
MATERIAL LOCATION: **building 1937**
MATERIAL QUANTITY: **140000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **03**
MATERIAL DESCRIPTION: **hard plaster**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **building 1970**
MATERIAL QUANTITY: **140000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **03**
MATERIAL DESCRIPTION: **hard plaster**
MATERIAL LOCATION: **building 1970**
MATERIAL QUANTITY: **140000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **04**
MATERIAL DESCRIPTION: **12x12 ceiling tile text**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building room 142**
MATERIAL QUANTITY: **700** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **04**
MATERIAL DESCRIPTION: **12x12 ceiling tile text**
MATERIAL LOCATION: **1937 building room 142**
MATERIAL QUANTITY: **700** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **05**
MATERIAL DESCRIPTION: **12x12 ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **10000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **05**
MATERIAL DESCRIPTION: **12x12 ceiling tile**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **10000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **06**
MATERIAL DESCRIPTION: **2x2 ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with potential for significant damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Amosite** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **34500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **06**
MATERIAL DESCRIPTION: **2x2 ceiling tile**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **34500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **07**
MATERIAL DESCRIPTION: **2x4 pinhole ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **34500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **07**
MATERIAL DESCRIPTION: **2x4 pinhole ceiling tile**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **34500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **08**
MATERIAL DESCRIPTION: **2x4 perforated ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **08**
MATERIAL DESCRIPTION: **2x4 perforated ceiling tile**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **09**
MATERIAL DESCRIPTION: **ceiling tectum panels**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 buildings (50 ft. in air inaccessible to sample)**
MATERIAL QUANTITY: **13000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **09**
MATERIAL DESCRIPTION: **ceiling tectum panels**
MATERIAL LOCATION: **1911 buildings (50 ft. in air inaccessible to sample)**
MATERIAL QUANTITY: **13000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **10**
MATERIAL DESCRIPTION: **9x9 light brown F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON: **Physical Damage**
DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346**
MATERIAL QUANTITY: **16800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS: **Damage is located throughout the 1st, 2nd, and 3rd corridors**

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **10**
MATERIAL DESCRIPTION: **9x9 light brown F.T.**
MATERIAL LOCATION: **130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346**
MATERIAL QUANTITY: **16800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **500** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.


The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Repair or Replace when possible. Continue O&M

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **11**
MATERIAL DESCRIPTION: **12x12 tan F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON: **Physical Damage**
DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346**
MATERIAL QUANTITY: **99000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS: **Damage is located in the 1st, 2nd, and 3rd floor corridors**

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **11**
MATERIAL DESCRIPTION: **12x12 tan F.T.**
MATERIAL LOCATION: **130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346**
MATERIAL QUANTITY: **99000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **100** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.


The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Repair or Replace when possible. Continue O&M

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **12**
MATERIAL DESCRIPTION: **12x12 metal ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **1911 natatorium (ceiling is inaccessible)**

MATERIAL QUANTITY: **3750**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **12**
MATERIAL DESCRIPTION: **12x12 metal ceiling tile**
MATERIAL LOCATION: **1911 natatorium (ceiling is inaccessible)**
MATERIAL QUANTITY: **3750** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **13**
MATERIAL DESCRIPTION: **transite table tops**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Science labs**
MATERIAL QUANTITY: **1000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **13**
MATERIAL DESCRIPTION: **transite table tops**
MATERIAL LOCATION: **Science labs**
MATERIAL QUANTITY: **1000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **14**
MATERIAL DESCRIPTION: **transite panel material**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Science labs 312, 316**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **14**
MATERIAL DESCRIPTION: **transite panel material**
MATERIAL LOCATION: **Science labs 312, 316**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **15**
MATERIAL DESCRIPTION: **accoustical ceiling tile (no material)**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Undefined** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **1911 building**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **15**

MATERIAL DESCRIPTION: **accoustical ceiling tile (no material)**

MATERIAL LOCATION: **1911 building**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:


DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **16**
MATERIAL DESCRIPTION: **12x12 ceiling tile text (material not observed)**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Assumed** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **1937 building**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS: **Not observed 2016**

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **16**

MATERIAL DESCRIPTION: **12x12 ceiling tile text (material not observed)**

MATERIAL LOCATION: **1937 building**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

If observed, implement O&M.

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **17**
MATERIAL DESCRIPTION: **spray-on fireproofing**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with potential for significant damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **BLDG 1911 above 2nd & 3rd floor ceiling tile**
MATERIAL QUANTITY: **45000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **17**
MATERIAL DESCRIPTION: **spray-on fireproofing**
MATERIAL LOCATION: **BLDG 1911 above 2nd & 3rd floor ceiling tile**
MATERIAL QUANTITY: **45000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **18**
MATERIAL DESCRIPTION: **9x9 light brown F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346**

MATERIAL QUANTITY: **16800**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **18**
MATERIAL DESCRIPTION: **9x9 light brown F.T. mastic**
MATERIAL LOCATION: **130, 132, 136, 138, 140, 142-145, 210, 232, 236, 238, 240, 303, 305, 307, 309, 310, 332, 334, 336, 338, 340, 344, 345, 346**
MATERIAL QUANTITY: **16800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **19**
MATERIAL DESCRIPTION: **9x9 tan F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **11400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **19**
MATERIAL DESCRIPTION: **9x9 tan F.T. mastic**
MATERIAL LOCATION: **1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **11400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **20**
MATERIAL DESCRIPTION: **9x9 med. Brn. F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**

MATERIAL QUANTITY: **21000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **20**
MATERIAL DESCRIPTION: **9x9 med. Brn. F.T. mastic**
MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**
MATERIAL QUANTITY: **21000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **21**
MATERIAL DESCRIPTION: **12x12 tan F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**

MATERIAL QUANTITY: **99000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **21**
MATERIAL DESCRIPTION: **12x12 tan F.T. mastic**
MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**
MATERIAL QUANTITY: **99000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **22**
MATERIAL DESCRIPTION: **12x12 tan F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd flr hallway**
MATERIAL QUANTITY: **900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **22**
MATERIAL DESCRIPTION: **12x12 tan F.T. mastic**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd flr hallway**
MATERIAL QUANTITY: **900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **23**
MATERIAL DESCRIPTION: **12x12 lt. Brn. Tile mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1970 building, weight room**
MATERIAL QUANTITY: **1700** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **23**
MATERIAL DESCRIPTION: **12x12 lt. Brn. Tile mastic**
MATERIAL LOCATION: **1970 building, weight room**
MATERIAL QUANTITY: **1700** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **24**
MATERIAL DESCRIPTION: **2' ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY: **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **14000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **24**
MATERIAL DESCRIPTION: **2' ceiling tile**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **14000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **25**
MATERIAL DESCRIPTION: **2' ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1970/ rear of rm. 143 2nd flr. S/W corridor**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **25**
MATERIAL DESCRIPTION: **2' ceiling tile**
MATERIAL LOCATION: **1970/ rear of rm. 143 2nd flr. S/W corridor**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **26**
MATERIAL DESCRIPTION: **9x9 tan F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **11400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **26**
MATERIAL DESCRIPTION: **9x9 tan F.T.**
MATERIAL LOCATION: **1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **11400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **27**
MATERIAL DESCRIPTION: **9x9 med.brn. F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**

MATERIAL QUANTITY: **21000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **27**

MATERIAL DESCRIPTION: **9x9 med.brn. F.T.**

MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**

MATERIAL QUANTITY: **21000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **28**
MATERIAL DESCRIPTION: **12x12 tan F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd flr hallway**
MATERIAL QUANTITY: **900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **28**
MATERIAL DESCRIPTION: **12x12 tan F.T.**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd flr hallway**
MATERIAL QUANTITY: **900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **29**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1970 building, weight room**
MATERIAL QUANTITY: **1700** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **29**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T.**
MATERIAL LOCATION: **1970 building, weight room**
MATERIAL QUANTITY: **1700** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **30**
MATERIAL DESCRIPTION: **9x9 med. Brn. F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Room 246, southeastern hall on 2nd floor**

MATERIAL QUANTITY: **2500**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **30**
MATERIAL DESCRIPTION: **9x9 med. Brn. F.T.**
MATERIAL LOCATION: **Room 246, southeastern hall on 2nd floor**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **31**
MATERIAL DESCRIPTION: **9x9 tan F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 210, 311**
MATERIAL QUANTITY: **1300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **31**
MATERIAL DESCRIPTION: **9x9 tan F.T.**
MATERIAL LOCATION: **Room 210, 311**
MATERIAL QUANTITY: **1300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **32**
MATERIAL DESCRIPTION: **12x12 beige F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Small hallways leading to library on 2nd and 3rd floors.**

MATERIAL QUANTITY: **750** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **32**
MATERIAL DESCRIPTION: **12x12 beige F.T.**
MATERIAL LOCATION: **Small hallways leading to library on 2nd and 3rd floors.**
MATERIAL QUANTITY: **750** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **33**
MATERIAL DESCRIPTION: **12x12 brown F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Locker rooms 1st floor**
MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **33**
MATERIAL DESCRIPTION: **12x12 brown F.T.**
MATERIAL LOCATION: **Locker rooms 1st floor**
MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **34**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **11000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **34**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T.**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **11000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **35**
MATERIAL DESCRIPTION: **12x12 dark tan F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **1911 building, patched areas**

MATERIAL QUANTITY: **800**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **35**
MATERIAL DESCRIPTION: **12x12 dark tan F.T.**
MATERIAL LOCATION: **1911 building, patched areas**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **36**
MATERIAL DESCRIPTION: **12x12 lt. Grn. F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 133**
MATERIAL QUANTITY: **1600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **36**
MATERIAL DESCRIPTION: **12x12 lt. Grn. F.T.**
MATERIAL LOCATION: **Room 133**
MATERIAL QUANTITY: **1600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **37**
MATERIAL DESCRIPTION: **12x12 off-white F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Engineer's office**

MATERIAL QUANTITY: **1825**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **37**
MATERIAL DESCRIPTION: **12x12 off-white F.T.**
MATERIAL LOCATION: **Engineer's office**
MATERIAL QUANTITY: **1825** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **38**
MATERIAL DESCRIPTION: **12x12 white F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 135, 137**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **38**
MATERIAL DESCRIPTION: **12x12 white F.T.**
MATERIAL LOCATION: **Rooms 135, 137**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **39**
MATERIAL DESCRIPTION: **12x12 Tan speckled F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Patched areas of 1st flr north hallway**

MATERIAL QUANTITY: **490**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **39**
MATERIAL DESCRIPTION: **12x12 Tan speckled F.T.**
MATERIAL LOCATION: **Patched areas of 1st flr north hallway**
MATERIAL QUANTITY: **490** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **40**
MATERIAL DESCRIPTION: **9x9 brown F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd, 3rd flr hallways**
MATERIAL QUANTITY: **950** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **40**
MATERIAL DESCRIPTION: **9x9 brown F.T.**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd, 3rd flr hallways**
MATERIAL QUANTITY: **950** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **41**
MATERIAL DESCRIPTION: **9x9 drk.brn. F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd, 3rd flr hallways**
MATERIAL QUANTITY: **75** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **41**
MATERIAL DESCRIPTION: **9x9 drk.brn. F.T.**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd, 3rd flr hallways**
MATERIAL QUANTITY: **75** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **42**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **42**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T.**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **43**
MATERIAL DESCRIPTION: **9x9 med. Brn. F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Team, Visitor, Boy's & Girl's Locker Rooms**

MATERIAL QUANTITY: **1800**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **43**
MATERIAL DESCRIPTION: **9x9 med. Brn. F.T.**
MATERIAL LOCATION: **Team, Visitor, Boy's & Girl's Locker Rooms**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **44**
MATERIAL DESCRIPTION: **9x9 tan F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **425** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **44**
MATERIAL DESCRIPTION: **9x9 tan F.T.**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **425** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **45**
MATERIAL DESCRIPTION: **9x9 brown F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**

MATERIAL QUANTITY: **3100**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **45**

MATERIAL DESCRIPTION: **9x9 brown F.T.**

MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**

MATERIAL QUANTITY: **3100**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **46**
MATERIAL DESCRIPTION: **9x9 brown F.T.**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Patched areas of 1st, 2nd & 3rd floor south hallways**

MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **46**
MATERIAL DESCRIPTION: **9x9 brown F.T.**
MATERIAL LOCATION: **Patched areas of 1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **47**
MATERIAL DESCRIPTION: **9x9 med. brn. F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Room 246, southeastern hall on 2nd floor**

MATERIAL QUANTITY: **2500**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **47**
MATERIAL DESCRIPTION: **9x9 med. brn. F.T. mastic**
MATERIAL LOCATION: **Room 246, southeastern hall on 2nd floor**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **48**
MATERIAL DESCRIPTION: **9x9 tan F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 210, 311**
MATERIAL QUANTITY: **1300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **48**
MATERIAL DESCRIPTION: **9x9 tan F.T. mastic**
MATERIAL LOCATION: **Room 210, 311**
MATERIAL QUANTITY: **1300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **49**
MATERIAL DESCRIPTION: **12x12 beige F.T. Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Small hallways leading to library on 2nd and 3rd floors.**

MATERIAL QUANTITY: **750** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **49**
MATERIAL DESCRIPTION: **12x12 beige F.T. Mastic**
MATERIAL LOCATION: **Small hallways leading to library on 2nd and 3rd floors.**
MATERIAL QUANTITY: **750** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **50**
MATERIAL DESCRIPTION: **12x12 brown F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Locker rooms 1st floor**
MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **50**
MATERIAL DESCRIPTION: **12x12 brown F.T. mastic**
MATERIAL LOCATION: **Locker rooms 1st floor**
MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **51**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Auditorium**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **51**

MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T. mastic**

MATERIAL LOCATION: **Auditorium**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **52**
MATERIAL DESCRIPTION: **12x12 dark tan F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building, patched areas**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **52**
MATERIAL DESCRIPTION: **12x12 dark tan F.T. mastic**
MATERIAL LOCATION: **1911 building, patched areas**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **53**
MATERIAL DESCRIPTION: **12x12 lt. Grn. F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 133**
MATERIAL QUANTITY: **1600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **53**
MATERIAL DESCRIPTION: **12x12 lt. Grn. F.T. mastic**
MATERIAL LOCATION: **Room 133**
MATERIAL QUANTITY: **1600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **54**
MATERIAL DESCRIPTION: **12x12 off-white F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Engineer's office**
MATERIAL QUANTITY: **1825** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **54**
MATERIAL DESCRIPTION: **12x12 off-white F.T. mastic**
MATERIAL LOCATION: **Engineer's office**
MATERIAL QUANTITY: **1825** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **55**
MATERIAL DESCRIPTION: **12x12 white F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 135, 137**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **55**
MATERIAL DESCRIPTION: **12x12 white F.T. mastic**
MATERIAL LOCATION: **Rooms 135, 137**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **56**
MATERIAL DESCRIPTION: **12x12 Tan speckled F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Patched areas of 1st flr north hallway**

MATERIAL QUANTITY: **490**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **56**
MATERIAL DESCRIPTION: **12x12 Tan speckled F.T. mastic**
MATERIAL LOCATION: **Patched areas of 1st flr north hallway**
MATERIAL QUANTITY: **490** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **57**
MATERIAL DESCRIPTION: **9x9 brown F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd, 3rd flr hallways**
MATERIAL QUANTITY: **950** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **57**
MATERIAL DESCRIPTION: **9x9 brown F.T. mastic**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd, 3rd flr hallways**
MATERIAL QUANTITY: **950** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **58**
MATERIAL DESCRIPTION: **9x9 drk.brn. F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd, 3rd flr hallways**
MATERIAL QUANTITY: **75** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **58**
MATERIAL DESCRIPTION: **9x9 drk.brn. F.T. mastic**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd, 3rd flr hallways**
MATERIAL QUANTITY: **75** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **59**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **59**
MATERIAL DESCRIPTION: **12x12 lt. Brn. F.T. mastic**
MATERIAL LOCATION: **1937 building, patched areas of 1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **60**
MATERIAL DESCRIPTION: **9x9 med. Brn. F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Team, Visitor, Boy's & Girl's Locker Rooms**

MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **60**
MATERIAL DESCRIPTION: **9x9 med. Brn. F.T. mastic**
MATERIAL LOCATION: **Team, Visitor, Boy's & Girl's Locker Rooms**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **61**
MATERIAL DESCRIPTION: **9x9 tan F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 buildng**
MATERIAL QUANTITY: **425** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **61**
MATERIAL DESCRIPTION: **9x9 tan F.T. mastic**
MATERIAL LOCATION: **1937 buildng**
MATERIAL QUANTITY: **425** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **62**
MATERIAL DESCRIPTION: **9x9 brown F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**

MATERIAL QUANTITY: **3100** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **62**
MATERIAL DESCRIPTION: **9x9 brown F.T. mastic**
MATERIAL LOCATION: **SEE COMMENTS FOR ROOM LOCATIONS**
MATERIAL QUANTITY: **3100** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **63**
MATERIAL DESCRIPTION: **9x9 lt. Brn. F.T. mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Patched areas of 1st, 2nd & 3rd floor south hallways**

MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **63**
MATERIAL DESCRIPTION: **9x9 lt. Brn. F.T. mastic**
MATERIAL LOCATION: **Patched areas of 1st, 2nd & 3rd floor south hallways**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **64**
MATERIAL DESCRIPTION: **12x12 ceiling tile text**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **25000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **64**
MATERIAL DESCRIPTION: **12x12 ceiling tile text**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **25000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **65**
MATERIAL DESCRIPTION: **12x12 ceiling tile text mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **25000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **65**
MATERIAL DESCRIPTION: **12x12 ceiling tile text mastic**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **25000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **66**
MATERIAL DESCRIPTION: **ceiling/tile system**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **15000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **66**
MATERIAL DESCRIPTION: **ceiling/tile system**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **15000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **67**
MATERIAL DESCRIPTION: **12x12 ceiling tile matsic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **1300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **67**
MATERIAL DESCRIPTION: **12x12 ceiling tile matsic**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **1300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **68**
MATERIAL DESCRIPTION: **2'x4' ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **68**
MATERIAL DESCRIPTION: **2'x4' ceiling tile**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **69**
MATERIAL DESCRIPTION: **drop-in ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **8500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **69**
MATERIAL DESCRIPTION: **drop-in ceiling tile**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **8500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **70**
MATERIAL DESCRIPTION: **2'x4' ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1970 building**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **70**
MATERIAL DESCRIPTION: **2'x4' ceiling tile**
MATERIAL LOCATION: **1970 building**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **71**
MATERIAL DESCRIPTION: **black trim vinyl baseboard**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **18000** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **71**

MATERIAL DESCRIPTION: **black trim vinyl baseboard**

MATERIAL LOCATION: **1911 building**

MATERIAL QUANTITY: **18000**

MATERIAL UNITS: **LF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **LF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **72**
MATERIAL DESCRIPTION: **black trim vinyl baseboard mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **18000** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **72**
MATERIAL DESCRIPTION: **black trim vinyl baseboard mastic**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **18000** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **73**
MATERIAL DESCRIPTION: **blk. Trim vinyl baseboard**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **275** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **73**
MATERIAL DESCRIPTION: **blk. Trim vinyl baseboard**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **275** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **74**
MATERIAL DESCRIPTION: **blk. Trim vinyl baseboard mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **275** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **74**
MATERIAL DESCRIPTION: **blk. Trim vinyl baseboard mastic**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **275** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **75**
MATERIAL DESCRIPTION: **black trim vinyl baseboard**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1970 building**
MATERIAL QUANTITY: **300** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **75**

MATERIAL DESCRIPTION: **black trim vinyl baseboard**

MATERIAL LOCATION: **1970 building**

MATERIAL QUANTITY: **300**

MATERIAL UNITS: **LF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **76**
MATERIAL DESCRIPTION: **black trim vinyl baseboard mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1970 building**
MATERIAL QUANTITY: **300** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **76**
MATERIAL DESCRIPTION: **black trim vinyl baseboard mastic**
MATERIAL LOCATION: **1970 building**
MATERIAL QUANTITY: **300** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **77**
MATERIAL DESCRIPTION: **transite wind/sill**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **3000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **77**
MATERIAL DESCRIPTION: **transite wind/sill**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **3000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **78**
MATERIAL DESCRIPTION: **transite windowsill**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **550** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **78**
MATERIAL DESCRIPTION: **transite windowsill**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **550** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **79**
MATERIAL DESCRIPTION: **grey carpet mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **950** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **79**
MATERIAL DESCRIPTION: **grey carpet mastic**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **950** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **80**
MATERIAL DESCRIPTION: **green carpet mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **1900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **80**
MATERIAL DESCRIPTION: **green carpet mastic**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **1900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **81**
MATERIAL DESCRIPTION: **brown carpet mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **81**
MATERIAL DESCRIPTION: **brown carpet mastic**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **82**
MATERIAL DESCRIPTION: **dr. orange carpet mastic**
HISTORICAL AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **15000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **82**
MATERIAL DESCRIPTION: **dr. orange carpet mastic**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **15000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **83**
MATERIAL DESCRIPTION: **orange carpet mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **21000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **83**
MATERIAL DESCRIPTION: **orange carpet mastic**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **21000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **84**
MATERIAL DESCRIPTION: **12" x 12" Light gray with white floor tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Auditorium, Rm 142**
MATERIAL QUANTITY: **3600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **84**
MATERIAL DESCRIPTION: **12" x 12" Light gray with white floor tile**
MATERIAL LOCATION: **Auditorium, Rm 142**
MATERIAL QUANTITY: **3600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **85**
MATERIAL DESCRIPTION: **Mastic for 12" x 12" Light gray with white floor tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Auditorium**

MATERIAL QUANTITY: **3000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **85**

MATERIAL DESCRIPTION: **Mastic for 12" x 12" Light gray with white floor tile**

MATERIAL LOCATION: **Auditorium**

MATERIAL QUANTITY: **3000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **86**
MATERIAL DESCRIPTION: **Gray mix Terrazzo**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Entrance and stairwells**
MATERIAL QUANTITY: **5000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **86**
MATERIAL DESCRIPTION: **Gray mix Terrazzo**
MATERIAL LOCATION: **Entrance and stairwells**
MATERIAL QUANTITY: **5000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **87**
MATERIAL DESCRIPTION: **12" x 12" White w/gray and black floor tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 114 and patches in room 210**
MATERIAL QUANTITY: **3200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **87**
MATERIAL DESCRIPTION: **12" x 12" White w/gray and black floor tile**
MATERIAL LOCATION: **Room 114 and patches in room 210**
MATERIAL QUANTITY: **3200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **88**
MATERIAL DESCRIPTION: **Mastic for 12" x 12" white with gray and black floor tile**
HISTORICAL AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 114 and patches in Room 210**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **88**
MATERIAL DESCRIPTION: **Mastic for 12" x 12" white with gray and black floor tile**
MATERIAL LOCATION: **Room 114 and patches in Room 210**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **89**
MATERIAL DESCRIPTION: **12" x 12" white with blue and red floor tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 117**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **89**
MATERIAL DESCRIPTION: **12" x 12" white with blue and red floor tile**
MATERIAL LOCATION: **Room 117**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **90**
MATERIAL DESCRIPTION: **Mastic for 12" x 12" white with Blue and Ref floor tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Room 117**

MATERIAL QUANTITY: **1800**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **90**
MATERIAL DESCRIPTION: **Mastic for 12" x 12" white with Blue and Ref floor tile**
MATERIAL LOCATION: **Room 117**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **91**
MATERIAL DESCRIPTION: **Black Chalk boards**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Classrooms**
MATERIAL QUANTITY: **13000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **91**
MATERIAL DESCRIPTION: **Black Chalk boards**
MATERIAL LOCATION: **Classrooms**
MATERIAL QUANTITY: **13000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **92**
MATERIAL DESCRIPTION: **Black Chalk Board Adhesive**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Classrooms**
MATERIAL QUANTITY: **13000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **92**
MATERIAL DESCRIPTION: **Black Chalk Board Adhesive**
MATERIAL LOCATION: **Classrooms**
MATERIAL QUANTITY: **13000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **A**
MATERIAL DESCRIPTION: **Mag block**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **boiler**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **A**

MATERIAL DESCRIPTION: **Mag block**

MATERIAL LOCATION: **boiler**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:


DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **B**
MATERIAL DESCRIPTION: **mag block**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **garage**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **B**

MATERIAL DESCRIPTION: **mag block**

MATERIAL LOCATION: **garage**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **C**
MATERIAL DESCRIPTION: **mag block**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **suspended in pump room**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **C**
MATERIAL DESCRIPTION: **mag block**
MATERIAL LOCATION: **suspened in pump room**
MATERIAL QUANTITY: MATERIAL UNITS:
DAMAGE QUANTITY: DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **D**
MATERIAL DESCRIPTION: **mag block ABATED**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **pump rm.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **D**

MATERIAL DESCRIPTION: **mag block ABATED**

MATERIAL LOCATION: **pump rm.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:


DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **E**
MATERIAL DESCRIPTION: **mag block**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **boiler room**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **E**

MATERIAL DESCRIPTION: **mag block**

MATERIAL LOCATION: **boiler room**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:


DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **F**
MATERIAL DESCRIPTION: **preform pipe**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL: **Moderate**

MATERIAL LOCATION: **boiler room & tunnel**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **F**

MATERIAL DESCRIPTION: **preform pipe**

MATERIAL LOCATION: **boiler room & tunnel**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **G**
MATERIAL DESCRIPTION: **preform fittings**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL: **Moderate**

MATERIAL LOCATION: **basement & tunnels**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **G**

MATERIAL DESCRIPTION: **preform fittings**

MATERIAL LOCATION: **basement & tunnels**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **H**
MATERIAL DESCRIPTION: **cardboard pipe insulation**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **compressor rm./ pump rm. Absorption rm./ tunnels**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**


HOMOGENEOUS AREA: **H**
MATERIAL DESCRIPTION: **cardboard pipe insulation**
MATERIAL LOCATION: **compressor rm./ pump rm. Absorption rm./ tunnels**
MATERIAL QUANTITY: MATERIAL UNITS:
DAMAGE QUANTITY: DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **HA-1000**
MATERIAL DESCRIPTION: **Glue for 1'x1' white ceiling tile with grooves**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rm. 301, 303, 305, 307, 309, 311**

MATERIAL QUANTITY: **34500**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY:

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **HA-1000**
MATERIAL DESCRIPTION: **Glue for 1'x1' white ceiling tile with grooves**
MATERIAL LOCATION: **Rm. 301, 303, 305, 307, 309, 311**
MATERIAL QUANTITY: **34500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **HA-1001**
MATERIAL DESCRIPTION: **new 2'x2' white ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY: **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **throughout 1st and 3rd floor**
MATERIAL QUANTITY: **35000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **HA-1001**
MATERIAL DESCRIPTION: **new 2'x2' white ceiling tile**
MATERIAL LOCATION: **throughout 1st and 3rd floor**
MATERIAL QUANTITY: **35000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **HA-1002**
MATERIAL DESCRIPTION: **new 2'x4' white ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **throughout 1st and 3rd floors**
MATERIAL QUANTITY: **35000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **HA-1002**
MATERIAL DESCRIPTION: **new 2'x4' white ceiling tile**
MATERIAL LOCATION: **throughout 1st and 3rd floors**
MATERIAL QUANTITY: **35000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **HA-1003**
MATERIAL DESCRIPTION: **Black sink undercoating**
HISTORICAL AHERA DAMAGE CATEGORY **5**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **5. ACBM with potential for significant damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Art rooms 401, 402, 406**
MATERIAL QUANTITY: **15** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **HA-1003**
MATERIAL DESCRIPTION: **Black sink undercoating**
MATERIAL LOCATION: **Art rooms 401, 402, 406**
MATERIAL QUANTITY: **15** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **I**
MATERIAL DESCRIPTION: **cardboard fittings**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **tunnels/compressor rm.**
MATERIAL QUANTITY: **40** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **I**
MATERIAL DESCRIPTION: **cardboard fittings**
MATERIAL LOCATION: **tunnels/compressor rm.**
MATERIAL QUANTITY: **40** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **J**
MATERIAL DESCRIPTION: **fiberglass fittings**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **J**
MATERIAL DESCRIPTION: **fiberglass fittings**
MATERIAL LOCATION: **1911 building**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **K**
MATERIAL DESCRIPTION: **aircell duct insulation**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **tunnels**
MATERIAL QUANTITY: **30** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **K**

MATERIAL DESCRIPTION: **aircell duct insulation**

MATERIAL LOCATION: **tunnels**

MATERIAL QUANTITY: **30**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **L**
MATERIAL DESCRIPTION: **aircell pipe insulation**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **pump rm. Tunnels**
MATERIAL QUANTITY: **2240** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **L**
MATERIAL DESCRIPTION: **aircell pipe insulation**
MATERIAL LOCATION: **pump rm. Tunnels**
MATERIAL QUANTITY: **2240** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M**
MATERIAL DESCRIPTION: **fittings on aircell**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **pump room 1911**
MATERIAL QUANTITY: **140** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **M**
MATERIAL DESCRIPTION: **fittings on aircell**
MATERIAL LOCATION: **pump room 1911**
MATERIAL QUANTITY: **140** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **N**
MATERIAL DESCRIPTION: **fiber glass fittings**
HISTORICAL AHERA DAMAGE CATEGORY: **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and its condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **400** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **N**
MATERIAL DESCRIPTION: **fiber glass fittings**
MATERIAL LOCATION: **1937 building**
MATERIAL QUANTITY: **400** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **0**
MATERIAL DESCRIPTION: **fiberglass fittings**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Not Tested** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL: **Moderate**

MATERIAL LOCATION: **1970bldg**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **0**

MATERIAL DESCRIPTION: **fiberglass fittings**

MATERIAL LOCATION: **1970bldg**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **P**
MATERIAL DESCRIPTION: **2'x2' WHITE CEILING TILE**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **THROUGHOUT 1911 BLDG**
MATERIAL QUANTITY: **69000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **P**
MATERIAL DESCRIPTION: **2'x2' WHITE CEILING TILE**
MATERIAL LOCATION: **THROUGHOUT 1911 BLDG**
MATERIAL QUANTITY: **69000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **Q**
MATERIAL DESCRIPTION: **LINOLEUM FLOORING Grey with white**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **ROOM 245, and 343**
MATERIAL QUANTITY: **2000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **Q**
MATERIAL DESCRIPTION: **LINOLEUM FLOORING Grey with white**
MATERIAL LOCATION: **ROOM 245, and 343**
MATERIAL QUANTITY: **2000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **Q-1**
MATERIAL DESCRIPTION: **LINOLEUM FLOORING-MASTIC**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **ROOM 245, and 343**
MATERIAL QUANTITY: **950** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **Q-1**
MATERIAL DESCRIPTION: **LINOLEUM FLOORING-MASTIC**
MATERIAL LOCATION: **ROOM 245, and 343**
MATERIAL QUANTITY: **950** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **R**
MATERIAL DESCRIPTION: **12x12 BROWN VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **ROOMS 341, 333**
MATERIAL QUANTITY: **2300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **R**
MATERIAL DESCRIPTION: **12x12 BROWN VFT**
MATERIAL LOCATION: **ROOMS 341, 333**
MATERIAL QUANTITY: **2300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **R-1**
MATERIAL DESCRIPTION: **12x12 BROWN VFT-MASTIC**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **ROOMS 341, 333**
MATERIAL QUANTITY: **2300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **R-1**
MATERIAL DESCRIPTION: **12x12 BROWN VFT-MASTIC**
MATERIAL LOCATION: **ROOMS 341, 333**
MATERIAL QUANTITY: **2300** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **S**
MATERIAL DESCRIPTION: **12x12 BLUE VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **EAST STAIRWELL, FRONT OF AUDITORIUM & ALL OF AUDITORIUM**
MATERIAL QUANTITY: **3250** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **S**
MATERIAL DESCRIPTION: **12x12 BLUE VFT**
MATERIAL LOCATION: **EAST STAIRWELL, FRONT OF AUDITORIUM & ALL OF AUDITORIUM**
MATERIAL QUANTITY: **3250** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **S-1**
MATERIAL DESCRIPTION: **12x12 BLUE VFT-MASTIC**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **EAST STAIRWELL, FRONT OF AUDITORIUM & ALL OF AUDITORIUM**
MATERIAL QUANTITY: **3250** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **S-1**
MATERIAL DESCRIPTION: **12x12 BLUE VFT-MASTIC**
MATERIAL LOCATION: **EAST STAIRWELL, FRONT OF AUDITORIUM & ALL OF AUDITORIUM**
MATERIAL QUANTITY: **3250** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **T**
MATERIAL DESCRIPTION: **12x12 ORANGE W/ GREEN VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **BACK STAGE OF AUDITORIUM W/ HALLWAY**
MATERIAL QUANTITY: **450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **T**
MATERIAL DESCRIPTION: **12x12 ORANGE W/ GREEN VFT**
MATERIAL LOCATION: **BACK STAGE OF AUDITORIUM W/ HALLWAY**
MATERIAL QUANTITY: **450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **T-1**
MATERIAL DESCRIPTION: **12x12 ORANGE W/ GREEN VFT-MASTIC**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was reinspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **BACK STAGE OF AUDITORIUM W/ HALLWAY**
MATERIAL QUANTITY: **450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUIDLING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

HOMOGENEOUS AREA: **T-1**
MATERIAL DESCRIPTION: **12x12 ORANGE W/ GREEN VFT-MASTIC**
MATERIAL LOCATION: **BACK STAGE OF AUDITORIUM W/ HALLWAY**
MATERIAL QUANTITY: **450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**


In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA: **94**
MATERIAL DESCRIPTION: **12" x 12" Gray Floor Tile**
MATERIAL LOCATION: **Rooms 142, 341, 344, 345, and Stage 107A**
MATERIAL QUANTITY: **8000** MATERIAL UNITS: **SF**
MATERIAL CATEGORY: **MISC** FRIABLE: **No**
ASBESTOS TYPE: **Assumed**
DISTURBANCE POTENTIAL: **LOW** CONDITION:
AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
ACCESSIBILITY: **Within Reach** DAMAGE REASON:
DAMAGE QUANTITY: **0** DAMAGE REASON:
DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**


HOMOGENEOUS AREA: **94**
MATERIAL DESCRIPTION: **12" x 12" Gray Floor Tile**
MATERIAL LOCATION: **Rooms 142, 341, 344, 345, and Stage 107A**
MATERIAL QUANTITY: **8000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA: **93**
MATERIAL DESCRIPTION: **2' x 2' Carpet Square Mastic**
MATERIAL LOCATION: **Library**
MATERIAL QUANTITY: **2000** MATERIAL UNITS: **SF**
MATERIAL CATEGORY: **MISC** FRIABLE: **No**
ASBESTOS TYPE: **Assumed**
DISTURBANCE POTENTIAL: **LOW** CONDITION:
AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
ACCESSIBILITY: **Not Reachable** DAMAGE REASON:
DAMAGE QUANTITY: **0** DAMAGE REASON:
DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 02/23/2016

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**


HOMOGENEOUS AREA: **93**
MATERIAL DESCRIPTION: **2' x 2' Carpet Square Mastic**
MATERIAL LOCATION: **Library**
MATERIAL QUANTITY: **2000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____



Date: **03/09/2016**

Chicago Public Schools

Carnow, Conibear and Associates

2016 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Brian Barry**
SCHOOL NAME: **Hyde Park Academy** INSPECTION DATE: **2/23/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA: **95**
MATERIAL DESCRIPTION: **Mastic Associated w/ 12" x 12" Gray Floor Tile**
MATERIAL LOCATION: **Rooms 142, 341, 344, 345, and Stage 107A**
MATERIAL QUANTITY: **8000** MATERIAL UNITS: **SF**
MATERIAL CATEGORY: **MISC** FRIABLE: **No**
ASBESTOS TYPE: **Assumed**
DISTURBANCE POTENTIAL: **LOW** CONDITION:
AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
ACCESSIBILITY: **Not Reachable** DAMAGE REASON:
DAMAGE QUANTITY: **0** DAMAGE REASON:
DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: **02/23/2016**

Chicago Public Schools

Carnow, Conibear and Associates 2016 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46171** BUILDING ID: **1390**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Daniel Juneau**
SCHOOL NAME: **Hyde Park Academy** REVIEW DATE: **3/9/2016**
ADDRESS: **6220 S. Stony Island** IDPH LICENSE NO: **100-11167**


HOMOGENEOUS AREA: **95**
MATERIAL DESCRIPTION: **Mastic Associated w/ 12" x 12" Gray Floor Tile**
MATERIAL LOCATION: **Rooms 142, 341, 344, 345, and Stage 107A**
MATERIAL QUANTITY: **8000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____



Date: 03/09/2016

APPENDIX B

Inspector and Management Planner Licenses

Brian Barry
Illinois Licensed Asbestos Inspector, Project Manager, and
Air Sampling Professional



**ASBESTOS
PROFESSIONAL
LICENSE**

ID NUMBER	ISSUED	EXPIRES
100 - 11167	3/16/2015	05/15/2016

BRIAN J BARRY
6020 GREEN DRIVE
WOODRIDGE, IL 60517
Environmental Health



ENDORSEMENTS

TC EXPIRES

INSPECTOR


12/2/2015

PROJECT MANAGER
AIR SAMPLING PROFESSIONAL

12/11/2015

Alteration of this license shall result in legal action
This license issued under authority of the State of Illinois
Department of Public Health
This license is valid only when accompanied by a valid
training course certificate.

**CARNOW
CONIBEAR**



THIS CERTIFIES THAT
Brian Barry

Has successfully completed the IL & IN Approved Asbestos Training Course and passed the Examination for purposes of accreditation under section 206 of Title II of the Toxic Substances Control Act (TSCA).
Conducted by the Amerisafe Training Services, 3990 Enterprise Court, Aurora IL 60504. (630) 862-2650

CLASS DATES: 12/17/2015

EXAMINATION: 12/17/2015

LOCATION: Amerisafe

EXPIRATION: 12/17/2016

CERTIFICATE NUMBER: 107966X15S103427



2016



OCCUPATIONAL TRAINING & SUPPLY, INC.

7233 S. Adams Street ♦ Willowbrook, IL 60527 ♦ (630) 655-3900

Asbestos Management Planner Refresher

Occupational Training & Supply, Inc. certifies that

Daniel Juneau

has successfully completed the Asbestos Management Planner Refresher course and has passed the competency exam with a minimum score of 70%. The course is accredited by the Illinois Department of Public Health and Indiana Department of Environmental Management for purposes of accreditation in accordance with EPA 40 CFR 763, Asbestos Hazard Emergency response Act (AHERA) and TSCA Title II.

Course Date: 1/6/2016

Exam Date: 1/6/2016

Expiration Date: 1/6/2017

Certificate Number: MPR1601060038



Kathy DeSalvo, Director

Daniel Juneau

Illinois Licensed Asbestos Inspector, Management Planner,
Project Manager, and Air Sampling Professional



ASBESTOS PROFESSIONAL LICENSE

ID NUMBER ISSUED EXPIRES
100 - 03613 **3/16/2015** **05/15/2016**

DANIEL J JUNEAU
1408 OAKWOOD AVENUE
DES PLAINES, IL 60016
Environmental Health



ENDORSEMENTS

TC EXPIRES

INSPECTOR	12/2/2015
MANAGEMENT PLANNER	1/20/2016
PROJECT MANAGER	12/11/2015
AIR SAMPLING PROFESSIONAL	

Alteration of this license shall result in legal action
This license issued under authority of the State of Illinois
Department of Public Health
This license is valid only when accompanied by a valid
training course certificate.

**CARNOW
CONIBEAR**

2015



OCCUPATIONAL TRAINING & SUPPLY, INC.

7233 S. Adams Street ♦ Willowbrook, IL 60527 ♦ (630) 655-3900

Asbestos Building Inspector Refresher

Occupational Training & Supply, Inc. certifies that

Daniel Juneau


has successfully completed the Asbestos Building Inspector Refresher course and has passed the competency exam with a minimum score of 70%. The course is accredited by the Illinois Department of Public Health and Indiana Department of Environmental Management for purposes of accreditation in accordance with EPA 40 CFR 763, Asbestos Hazard Emergency response Act (AHERA) and TSCA Title II.

Course Date: 12/2/2015

Exam Date: 12/2/2015

Expiration Date: 12/2/2016

Certificate Number: BIR1512024163


Kathy DeSalvo, Director

APPENDIX C

Laboratory Accreditations

APPENDIX D

Laboratory Results

APPENDIX E

Chain of Custody Forms

Three-Year Reinspection Key to Terms

	CODE	KEY
MATERIAL		
	ACBM	Asbestos Containing Building Materials
MATERIAL CATEGORY		
	MISC	Miscellaneous
	SURF	Surfacing
	TSI	Thermal System Insulation
MATERIAL UNITS		
	LF	Linear Feet
	SF	Square Feet
	CF	Cubic Feet
DAMAGE TYPE		
	Loc	Localized
	Dist	Distributed