

ILLINOIS DEPARTMENT OF PUBLIC HEALTH
AHERA THREE YEAR REINSPECTION
ASBESTOS ABATEMENT PROGRAM
SCHOOL INFORMATION FORM

SECTION I

NAME OF SCHOOL DISTRICT: CHICAGO SCHOOL DIST 299
SCHOOL ID NUMBER: 14-016-2990-0027
SCHOOL NAME: Lane Tech High School
ADDRESS OF SCHOOL: 2501 W. Addison
CITY: Chicago, IL, 60618

DATE LAST THREE YEAR REINSPECTION WAS COMPLETED **6/23/2016**

If the address on this form is different than the address of the building, submit a written explanation.

SECTION II (Please type or print)

PLEASE COMPLETE THE FOLLOWING FOR YOUR THREE YEAR REINSPECTION:

DATE REINSPECTION COMPLETED: 10/1/2019 ENROLLMENT 4453
IDPH INSPECTOR LICENSE NUMBER: 100-11093
IDPH LICENSED INSPECTOR NAME(Please Print): David Avila
IDPH MP LICENSE NUMBER: 100-04019
IDPH LICENSED MANAGEMENT PLANNER NAME (Please Print): Arturo Saenz

DESIGNATED PERSON (Please Print): Robert Christlieb PHONE: (773) 553-3197



10/1/2019

Signature of Designated Person

Date

SECTION III

PLEASE COMPLETE THE FOLLOWING INFORMATION FOR ANY CHANGES WITHIN THE SCHOOL DISTRICT.

School building has been sold. Date of Sale: _____

School has been closed. Date closed: _____

School building has been demolished. Date: _____

School building is asbestos free since last reinspection: _____

Please explain in writing why the school building is now asbestos free and include the supporting documentation.

If a new school building has been added to the district, submit either an exclusionary statement or a management plan and inspection report. Include the complete name, address and city of school building.

Explain in writing if the address of the building is different than the address on this form:

THREE-YEAR REINSPECTION

CHICAGO SCHOOL DIST 299

Lane Tech High School

2501 W. Addison
Chicago, IL, 60618

Unit: 46221
Building ID: 1440

IDPH ID Number: 14-016-2990-0027

REPORT DATE:

Tuesday, October 01, 2019

Prepared for:

**Chicago Public Schools
42 West Madison Street
Chicago, IL 60602**

Prepared by:

GSG-Probe Consulting, Inc.

2942 W. Van Buren

Chicago, IL, 60612

Phone 3123197575

Fax

**DO NOT REMOVE FROM SCHOOL
REQUIRED BY FEDERAL LAW**

Environmental Notification to Occupants

To: Faculty, Staff and Parents
From: Chicago Public Schools
Date: October 03, 2019

RE: Lane Tech High School, Unit 46221
2501 W. Addison
Chicago, IL, 60618

Dear Faculty, Staff and Parents,

This letter is to notify you that the 2019 asbestos three year re-inspection has been completed at Lane Tech High School, following the Federal Asbestos Hazard Emergency Response Act (AHERA), 40 CFR Part 763, Subpart E and is available for your review at the main office of the school.

Although asbestos-containing materials have been identified at Lane Tech High School, there is no reason to believe that any threat to the health of students or staff exists at this time. CPS will continue to carefully monitor the condition of asbestos-containing materials and if conditions warrant, all appropriate steps will be taken to maintain the health and safety of all building occupants.

If you have any questions regarding this matter or require additional information, please feel free to contact Robert Christlieb, the designated Local Education Authority's Designated Person at (773) 553-3197 .

Table of Contents

- I. School and Inspection Information
- II. Executive Summary
- III. Methodology
- IV. Abatement History
- V. Reassessments and Recommendations
- VI. Conclusions

Table I: Inspector's Reinspection Findings

Table II: Management Planner's Review

APPENDICES:

- Appendix A: Assessment Sheets, Drawings and Photos
- Appendix B: Inspector and Management Planner Licenses
- Appendix C: Laboratory Accreditations
- Appendix D: Laboratory Results
- Appendix E: Chain of Custody Forms

SCHOOL AND INSPECTION INFORMATION

1. School Information

School: Lane Tech High School Unit: 46221 Region: 01
Address: 2501 W. Addison Chicago, IL, 60618
IDPH ID: 14-016-2990-0027 Building ID: 1440
Contact: Cooney, Kurt Phone: 773 931 4287

2. Description of Facility

Original Construction: 1934 Additional Construction:
Total Square Footage: 707164 No of Floors: 4
Current Occupancy: 4453

3. LEA Designated Person

Contact: Robert Christlieb Phone: (773) 553-3197
Address: 42 West Madison Street
Chicago, IL 60602

4. Managing Environmental Consultant

MEC: GSG-Probe Consulting, Inc.
Contact: Jigar Shah
Address 2942 W. Van Buren
Chicago, IL, 60612
Phone: 3123197575 Fax:

5. Inspector

Inspector Name: David Avila

Inspector IDPH license # 100-11093

Signature:
Date: 10/3/2019

6. Management Planner

Management Planner Name: Arturo Saenz

Management Planner IDPH license # 100-04019

Signature:
Date: 10/25/2019

7. Review Date:10/25/2019

8. LEA Designated Person's Acknowledgement

The reinspection report and recommendations have been received by me and appropriate action will be taken by the School District.

Signature:



Date: 10/1/2019

Name: Robert Christlieb

II. EXECUTIVE SUMMARY

GSG-Probe Consulting, Inc. was retained by the Chicago Public Schools (CPS) to perform a three-year asbestos reinspection of the Lane Tech High School. This inspection was conducted in accordance with the United States Environmental Protection Agency (USEPA) Asbestos Hazard Emergency Response Act (AHERA) part 763.85 (b), and the ongoing Operations and Maintenance Program (O&M) originally designed in the School's Asbestos Management Plan. The purpose of this three-year reinspection is to record any condition changes in the asbestos-containing building material (ACBM) in the school since the previous three-year reinspection and the six-month periodic surveillance, to identify, assess, and include any Homogeneous Areas(HA) not identified in the Management Plan, and to recommend an appropriate response action to manage asbestos.

The inspector conducted a three-year reinspection of this facility under Illinois Department of Public Health (IDPH) school reinspection requirements and AHERA, sections 763.85 and 763.88. The main building and each addition to the main building, if constructed at different dates, were inspected separately. Laboratory accreditations are included in Appendix C, laboratory results are included in Appendix D, and chain of custody forms are included in Appendix E.

Note: During previous inspections, some of the HA(s) were identified together as 9" x 9" floor tile (FT), mastics assoc. with 9" x 9" FT, 12" x 12" FT, mastics assoc. with 12" x 12" FT, pipe insulation, etc. Some of these HA(s) have been re-identified by areas that are uniform in color, texture, construction date, application date, and general appearance.

The inspector has determined the following:

A. The following HAs have changed assessment categories for Building 1440:

B. The following new homogenous areas have been identified for Building 1440:

43	12" x 12" White w/ Blue & Red Specks VFT
44	12" x 12" White w/ Blue & Red Specks VFT Mastic
45	Yellow Linoleum
46	Yellow Linoleum Mastic
47	Blue Linoleum
48	Blue Linolum Mastic

C. This reinspection covered only physically accessible and visible areas and materials that were identified in the LEA's management plan. The following materials were concealed and/or contained in areas that were inaccessible for sampling and have been classified as Assumed:

2016-BBM1	Brown Vinyl Baseboard Mastic
2016-CT1	2' x 2' White w/pinhole dots ceiling tile
2016-CT2	2' x 2' White Rough with dots ceiling tile
2016-CT3	2' x 4' White Smooth Ceiling Tile
2016-DWS1	Drywall System
2016-FD1	Fire Doors rated 3/4 hour
2016-FDR1	Dark Gray fire proofed cloth draperies
2016-FDR2	LT. Green fire proofed cloth draperies
2016-FT1	2' x 2' Yellow w/yellow streaks VFT
2016-FT1M	2' x 2' Yellow w/yellow streaks VFT Mastic
2016-FT2	2' x 2' Gray w/Gray Streaks VFT
2016-FT2M	2' x 2' Gray w/Gray Streaks VFT Mastic
2016-FT3	2' x 2' Green w/Green Streaks VFT
2016-FT3M	2' x 2' Green w/Green Streaks VFT Mastic
2016-FT4	2' x 2' Blue w/Blue Gray Streaks VFT
2016-FT4M	2' x 2' Blue w/Blue Gray Streaks VFT Mastic
2016-FT5	12" x 12" Beige w/Brown and White Specks VFT
2016-FT5M	12" x 12" Beige w/Brown and White Specks VFT Mastic
2016-FT6M	12" x 12" Dark Brown w/Black Streaks VFT Mastic
216-FT6	12" x 12" Dark Brown w/black streaks VFT
29	Light Blue w/ Dark Spots Linoleum
30	Light Blue w/ Dark Spots Linoleum Mastic
31	2'x4' White w/ Holes & Grooves Ceiling Tile
32	Drywall
33	Drywall Joint Compound
34	Vinyl Baseboard
35	Vinyl Baseboard Mastic
36	12"x12" Light Beige w/ White and Brown Streaks VFT
36A	12"x12" Light Beige w/ White and Brown Streaks VFT MASTIC
37	12"x12" Dark Gray w/White Streaks VFT (Not Observed)
37A	12"x12" Dark Gray w/ White Streaks VFT MASTIC (Not Observed)
38	12"x12" Gray w/ Gray and White Streaks VFT
38A	12"x12" Gray w/ Gray and White Streaks VFT MASTIC
39	12"x12" Light Green Streaked VFT
39A	12"x12" Light Green Streaked VFT MASTIC
40	9"x9" Tan w/ brown & white streaks VFT

40A	9"x9" Tan w/brown & white streaks VFT MASTIC
41	12"x12" Green w/ white & black streaks VFT
41A	12"x12" Green w/ white & black streaks
43	12" x 12" White w/ Blue & Red Specks VFT
44	12" x 12" White w/ Blue & Red Specks VFT Mastic
45	Yellow Linoleum
46	Yellow Linoleum Mastic
47	Blue Linoleum
48	Blue Linoleum Mastic
AAA	2'x 2' Ceiling Tile fissured, white
BBB	Acoustical Wall Tile, Fissured
CCC	Textured Plaster, Walls and Ceiling
CT1	2' x 4' Ceiling Tiles with Grooves
DDD	Terrazzo Floor
FT10	12"x12" White w/ Tan Streaks VFT
FT11	12"x12" Dark Brown w/ Black Streaks VFT
FT20	9"x9" Maroon w/ White Streaks VFT
FT21	12"x12" Green w/ White Streaks VFT
FT23	6"x6" Black VFT
FT29	12" x 12" White w/Tan Streaks VFT
FT30	12" x 12" Pink VFT
FT6	6"x6" White VFT
FT9	12"x12" Sand VFT
KK	Tan Rubber Flooring
M11	6"x6" White VFT Mastic
M15	12"x12" White w/ Tan Streaks VFT Mastic
M18	12"x12" Off White w/ Brown Streaks VFT Mastic
M26	12"x12" Green w/ White Streaks VFT Mastic
M28	6"x6" Black VFT Mastic
M29	12" x 12" White w/Tan Streaks VFT Mastic
M30	12" x 12" Pink VFT Mastic
M31	Carpet Mastic

The following areas were deemed to be inaccessible:

Materials were also listed as "assumed" if they were in good condition and sampling was not conducted to avoid damage.

This reinspection was conducted by David Avila, IDPH License # 100-11093. The Management Plan was updated by Arturo Saenz, IDPH License # 100-04019. Inspector and Management Planner Licenses are included in Appendix B.

III. METHODOLOGY

Tasks performed on-site included the following:

1. Review current management plan, identify HA(s) and extract appropriate information.
2. Examine and verify abatement records.
3. Touch and visually and physically reinspect and reassess the condition of all friable known or assumed ACBM.
4. Touch and visually and physically reinspect all non-friable known or assumed ACBM to determine whether these materials have become friable since the last inspection or periodic surveillance.
5. Identify any condition changes that may affect Hazard ranking of known ACBM or Assumed ACBM, as well as any HA(s) that have become friable since the last reinspection.
6. Collect bulk samples from each newly discovered friable HA or previously assumed and submit for laboratory analysis.
7. Tabulate reinspection findings and submit for management planner review and recommendations with appropriate response actions based on the AHERA Damage Category of the ACBM.
8. Submit reinspection findings and management planner recommendations to the LEA within thirty (30) days for inclusion into the management plan.

IV. ABATEMENT HISTORY

The information collected from the existing management plan and inspection report(s) and from interviews with the school official revealed that the following asbestos abatement was conducted at the school since the previous Three year Reinspection.

Abatement Dates:

V. REASSESSMENTS AND RECOMMENDATIONS

The reassessments and recommendations are summarized in Tables I and II on the following pages. Detailed Hazard Assessment Sheets and Drawings and Photos (if applicable) are included in Appendix A.

VI. CONCLUSIONS

The Lane Tech High School Building 1440 Three-Year reinspection has been completed and response actions have been recommended for both friable and non-friable materials. Atimely execution of the response actions recommended will enable the LEA and the Designated Person(s) to effectively manage the existing ACBM.

This three-year reinspection report should be inspected in the current Management plan at the CPS Central Office, and one (1) copy should be kept at the school for use when planning any renovation and/or demolition activities in areas where ACBM has been identified. Also, periodic surveillance documentation and any summary reports from any response actions that are executed at the school should be used to update the Management Plan.

Table I
Inspector's Reinspection Findings

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
12	Aircell Pipe Insulation	1,300	LF	Unexcavated Areas, Pipe Chases - Rooms 253, and 153D (not observed in 251) - 1931 Bldg.	CHR	TSI	Y	NONE	4		No	Damaged or significantly damaged friable thermal system insulating ACBM		LOW
14	MJP E/F/V on Aircell Pipe Insulation	98	FITTING	Unexcavated Areas, Pipe Chases; Rooms 251, 253, and 153D - 1931 Bldg.	CHR	TSI	Y	NONE	0		No	ACBM with the potential for damage		LOW
2016-BBM1	Brown Vinyl Baseboard Mastic	600	SF	Rooms 119, 123, 125 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-CT1	2' x 2' White w/pinhole dots ceiling tile	3,900	SF	Rooms 119, 123, 125, 215B - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-CT2	2' x 2' White Rough with dots ceiling tile	2,500	SF	Rooms 145A, 138A, 115A, 213, 242A, 2nd floor boys washroom - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-CT3	2' x 4' White Smooth Ceiling Tile	3,000	SF	Rooms 120A, 123A, 220A, 214A, 323C, 320A, 487A, 2nd floor boys bathroom, 4th floor ADA bathroom - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-DWS1	Drywall System	6,700	SF	Rooms 119, 123, 125, 129, 130, 148, 150 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FD1	Fire Doors rated 3/4 hour	180	SF	2nd Floor boys bathroom, rooms 342A, 437A boys, 4th floor ADA bathroom - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FDR1	Dark Gray fire proofed cloth draperies	3,000	SF	Room 209 Auditorium balcony - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FDR2	LT. Green fire proofed cloth draperies	1,000	SF	Room 300 Gymnasium #2 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT1	2' x 2' Yellow w/yellow streaks VFT	10,170	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.										
2016-FT1M	2' x 2' Yellow w/yellow streaks VFT Mastic	10,170	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT2	2' x 2' Gray w/Gray Streaks VFT	4,000	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322 322A, 335, 336, 430, 434, 449,4th Floor ADA elevator pump - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT2M	2' x 2' Gray w/Gray Streaks VFT Mastic	4,000	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322 322A, 335, 336, 430, 434, 449,4th Floor ADA elevator pump - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT3	2' x 2' Green w/Green Streaks VFT	4,000	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT3M	2' x 2' Green w/Green Streaks VFT Mastic	4,000	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT4	2' x 2' Blue w/Blue Gray Streaks VFT	150	SF	Rooms 441B, 430, 434 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT4M	2' x 2' Blue w/Blue Gray Streaks VFT Mastic	150	SF	Rooms 441B, 430, 434 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT5	12" x 12" Beige w/Brown and White Specks VFT	5,000	SF	Rooms 435, 447, 245, (1st, 2nd, 3rd, 4th floor corridors) - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
2016-FT5M	12" x 12" Beige w/Brown and White Specks VFT Mastic	5,000	SF	Rooms 435, 447, 245, (1st, 2nd, 3rd,	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				4th floor corridors) - 1931 Bldg.										
2016-FT6M	12" x 12" Dark Brown w/Black Streaks VFT Mastic	4,400	SF	Main Corridors 12s, 2nd, 3rd, 4th floors - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
216-FT6	12" x 12" Dark Brown w/black streaks VFT	4,400	SF	Main Corridors 1st, 2nd, 3rd, 4th floors - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
29	Light Blue w/ Dark Spots Linoleum	1,200	SF	Room 115 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
30	Light Blue w/ Dark Spots Linoleum Mastic	1,200	SF	Room 115 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
31	2'x4' White w/ Holes & Grooves Ceiling Tile	1,200	SF	Room 115 - 1931 Bldg.	ASSUMED	MISC	Y	NONE	0		No	ACBM with the potential for damage		LOW
32	Drywall	500	SF	Room 115 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
33	Drywall Joint Compound	100	LF	Room 115 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
34	Vinyl Baseboard	150	LF	Room 115 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
35	Vinyl Baseboard Mastic	150	LF	Room 115 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
36	12"x12" Light Beige w/ White and Brown Streaks VFT	1,800	SF	Locker room & office & storage room and toilet (361A), 153A - 1931 Bldg.	ASSUMED	MISC	N	LOC	40		No	ACBM with potential for significant damage	3	LOW
36A	12"x12" Light Beige w/ White and Brown Streaks VFT MASTIC	1,800	SF	Locker room & office & storage room and toilet (361A), 153A - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
37	12"x12" Dark Gray w/White Streaks VFT (Not Observed)	800	SF	Room 340 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
37A	12"x12" Dark Gray w/ White Streaks VFT MASTIC (Not Observed)	800	SF	Room 340 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
38	12"x12" Gray w/ Gray and White Streaks VFT	1,900	SF	Rooms 133, (Not observed 129, 147) - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
38A	12"x12" Gray w/ Gray and White Streaks VFT MASTIC	1,900	SF	Rooms 133, (Not observed 129, 147) - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
39	12"x12" Light Green Streaked VFT	3,500	SF	Serving line room - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
39A	12"x12" Light Green Streaked VFT MASTIC	3,500	SF	Serving line room - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
40	9"x9" Tan w/ brown & white streaks VFT	40	SF	Library stairs landings - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
40A	9"x9" Tan w/brown & white streaks VFT MASTIC	40	SF	Library stairs landings - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
41	12"x12" Green w/ white & black streaks VFT	600	SF	Room 117 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
41A	12"x12" Green w/ white & black streaks	600	SF	Room 117 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
42	Black/gray lab counter tops	5,400	SF	Rooms 439, 435, 431, 438 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
43	12" x 12" White w/ Blue & Red Specks VFT	800	SF	Room 146 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
44	12" x 12" White w/ Blue & Red Specks VFT Mastic	800	SF	Room 146 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
45	Yellow Linoleum	100	SF	Library Entrance - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
46	Yellow Linoleum Mastic	100	SF	Library Entrance - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
47	Blue Linoleum	40	SF	Library Entrance - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
48	Blue Linolum Mastic	40	SF	Library Entrance - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
AA	Stage Door (Fire curtain)	1,000	SF	Auditorium Stage - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
AAA	2'x 2' Ceiling Tile fissured, white	800	SF	Room 445, Art Area corridor - 1931 Bldg.	ASSUMED	MISC	Y	NONE	0		No	ACBM with the potential for damage		LOW
BB	1'x1' White Wormy Ceiling Tile			Room 241, 437, Main Office, 113, 134, Auditorium, 252, 335, 433, 442, 444 (bandroom), 446, 400, 402, 403 - 1931 Bldg.	NO_ACBM						No			
BBB	Acoustical Wall Tile, Fissured	450	SF	Room 252 - 1931 Bldg.	ASSUMED	MISC	Y	NONE	0		No	ACBM with the potential for damage		LOW
CC	1'x1' White Wormy Ceiling Tile Mastic			Room 241, 437, Main Office 113, 134, Auditorium,	NO_ACBM						No			

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				252, 335, 433, 442, 444 (bandroom), 446, 400, 402, 403 - 1931 Bldg.										
CCC	Textured Plaster, Walls and Ceiling	4,500	SF	1st floor corridor by main office, Auditorium, Room 202 - 1931 Bldg.	ASSUMED	SURFACE	N	NONE	0		No	ACBM with the potential for damage		LOW
CT1	2' x 4' Ceiling Tiles with Grooves	800	SF	Engineer's Office - 1931 Bldg.	ASSUMED	MISC	Y	NONE	0		No	ACBM with the potential for damage		LOW
DD	2'x2' White Wormy Ceiling Tile			Serving Area, Lunchroom; 213, 252, Toilet rooms; 138A, 115A, 145A, 242A, 214A, 215B, 245A, 320A - 1931 Bldg.	NO_ACBM						No			
DDD	Terrazzo Floor	30,000	SF	All corridors, stairwells, auditorium vestibule, main office lobby - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
EE	2'x4' White Wormy Ceiling Tile (Not observed)			Room 125, 447, 112, 117, 119, 123, 205, 330 - 1931 Bldg.	NO_ACBM									
FF	Aircell Duct Insulation	2,000	SF	SW Unexcavated Area - 1931 Bldg.	CHR	TSI	Y	LOC	10		No	Damaged or significantly damaged friable thermal system insulating ACBM		LOW
FT10	12"x12" White w/ Tan Streaks VFT	1,200	SF	Room 443 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT11	12"x12" Dark Brown w/ Black Streaks VFT	16,270	SF	All corridors and auditorium - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT12	12"x12" Peach VFT	1,600	SF	Rooms 132, 203 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT13	12"x12" Off White w/ Brown Specks VFT (Abated)			Room 220 - 1931 Bldg.	ABATED	MISC						Any remaining friable ACBM or friable suspect ACBM		
FT14	9"x9" Off White w/ Gray Streaks VFT (ABATED)			Lunchroom - 1931 Bldg.	ABATED	MISC						Any remaining friable ACBM or friable suspect ACBM		
FT15	9"x9" Green VFT (ABATED)			Lunchroom - 1931 Bldg.	ABATED	MISC						Any remaining friable ACBM or friable		

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
												suspect ACBM		
FT16	9"x9" Beige w/ Brown Streaks VFT	1,000	SF	(Serving Area - ABATED) Room 134 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT17	12"x12" White w/ Brown Specks VFT	650	SF	Kitchen - 1931 Bldg.	CHR	MISC	N	LOC	500		No	ACBM with potential for significant damage		LOW
FT18	12"x12" Beige w/ Wavy Brown VFT	3,500	SF	Kitchen - 1931 Bldg.	CHR	MISC	N	LOC	30		No	ACBM with potential for significant damage		LOW
FT19	9"x9" Black w/ White Streaks VFT	600	SF	Lunchroom Storage, & Engineer's Office - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT20	9"x9" Maroon w/ White Streaks VFT	1,500	SF	Lunchroom Storage, & Engineer's Office; Gym III 361 mezzanine locker room - 1931 Bldg.	ASSUMED	MISC	N	LOC	10		No	ACBM with potential for significant damage		LOW
FT21	12"x12" Green w/ White Streaks VFT	200	SF	Engineers Locker Room - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT22	12"x12" Gray w/ White & Brown Specks VFT	2,737	SF	Girl's Locker Room Office, Shower Office, Storage, Laundry, 439, 431, 438, 340 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT23	6"x6" Black VFT	500	SF	Library Loft (balcony) - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT29	12" x 12" White w/Tan Streaks VFT	800	SF	Engineer's Office - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT30	12" x 12" Pink VFT	1,500	SF	Room 146 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT4	12"x12" Beige w/ Brown & White Specks VFT	44,600	SF	Corridors all floors, 441B, 435, 245, 125 work room, 315, 302A, 238, 236, Library, Auditorium, Men and Women toilets - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT5	9"x9" Peach w/ Cream Streaks VFT	5,200	SF	Vaults in rooms 131, 435, 438, 439, 217, 221, 241, 302A - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT6	6"x6" White VFT	500	SF	Library Loft (balcony) - 1931	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				Bldg.										
FT7	12"x12" Green VFT	1,884	SF	Driver's Education Building room 199 simulator room - 1975 Bldg.	CHR	MISC	N	LOC	100		No	Damaged or significantly damaged friable misc. ACBM		LOW
FT8	12"x12" Gray w/ White Streaks VFT	800	SF	Room 144 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT9	12"x12" Sand VFT	3,000	SF	Room 447, 116 (not observed in 145, 143) - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
GG	Interior Window Caulk			Throughout - 1931 Bldg.	NO_ACBM						No			
HH	Exterior Window Caulk			Throughout - 1931 Bldg.	NO_ACBM						No			
I	MJP E/F/V on Fiberglass Pipe Insulation			Boiler Room, Bathroom Pipe Chases, Janitors Closets - 1931 Bldg.	NO_ACBM						No			
II	MJP E/F/V on Fiberglass Pipe Insulation			Janitors Closet, Bathroom Pipe Chases - 1975 Bldg.	NO_ACBM						No			
JJ	2'x4' White Ceiling Tile			Drivers Education Building - 1975 Bldg.	NO_ACBM						No			
KK	Tan Rubber Flooring	600	SF	Old Dishwasher Room - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
L8	Brown Linoleum - ABATED			Room 124, 128, 133 - 1931 Bldg.	ABATED	MISC						Any remaining friable ACBM or friable suspect ACBM		
L9	Green & White Linoleum			Stage Crew Office - 1931 Bldg.	NO_ACBM	MISC					No			
LM10	Brown Linoleum Mastic - ABATED			Room 128 - 1931 Bldg.	ABATED	MISC		None				Any remaining friable ACBM or friable suspect ACBM		Low
LM11	Green & White Linoleum Mastic			Stage Crew Office - 1931 Bldg.	NO_ACBM	MISC					No			
M10	9"x9" Peach w/ cream streaks VFT Mastic	4,800	SF	Vaults in rooms 435, 438, 439, 217, 221, 241 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M11	6"x6" White VFT Mastic	500	SF	Library Loft (balcony) - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M12	12"x12" Green VFT Mastic	5,000	SF	Driver's Education Building - 1975	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				Bldg.										
M13	12"x12" Gray w/ White Streaks VFT Mastic	800	SF	Room 144 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M14	12"x12" Sand VFT Mastic	5,150	SF	Rooms 447, 116 (not observed in 145, 143) - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M15	12"x12" White w/ Tan Streaks VFT Mastic	1,200	SF	Room 443 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M16	12"x12" Dark Brown w/ Black Streaks VFT Mastic	16,270	SF	Corridors & Auditorium - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M17	12"x12" Peach VFT Mastic	1,450	SF	Rooms 203, 132 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M18	12"x12" Off White w/ Brown Streaks VFT Mastic	1,600	SF	Room 335, 220 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M19	9"x9" Off White w/ Gray Streaks VFT Mastic - ABATED			Lunchroom - 1931 Bldg.	ABATED	MISC						Any remaining friable ACBM or friable suspect ACBM		
M20	9"x9" Green VFT Mastic - ABATED			Lunchroom - 1931 Bldg.	ABATED	MISC	N				No	Any remaining friable ACBM or friable suspect ACBM		
M21	9"x9" Beige w/ Brown Streaks VFT Mastic	2,000	SF	(Serving Area - ABATED) Room 134 - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M22	12"x12" White w/ Brown Specks VFT Mastic	650	SF	Kitchen - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M23	12"x12" Beige w/ Wavy Brown VFT Mastic	3,500	SF	Kitchen - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M24	9"x9" Black w/ White Streaks VFT Mastic	600	SF	Lunchroom Storage & Engineer's Office - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M25	9"x9" Maroon w/ White Streaks VFT Mastic	1,500	SF	Lunchroom Storage & Engineer's Offices; Gym III 361 Mezzanine locker room - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M26	12"x12" Green w/ White Streaks VFT Mastic	200	SF	Engineers Locker Room - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M27	12"x12" Gray w/ White & Brown Specks VFT Mastic	2,737	SF	Girls' Locker Room & Office, Shower Office, Storage & Laundry, Rooms 439, 431, 438, 340 -	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				1931 Bldg.										
M28	6"x6" Black VFT Mastic	500	SF	Library Loft (balcony) - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M29	12" x 12" White w/Tan Streaks VFT Mastic	800	SF	Engineer's Office - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M30	12" x 12" Pink VFT Mastic	1,500	SF	Room 146 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M31	Carpet Mastic	2,400	SF	Rooms 130, 210, 235, 330, 205, 212, 213 - 1931 Bldg.	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
M9	12"x12" Beige w/ Brown & White Specks VFT Mastic	44,600	SF	Corridors all floors, 441B, 435, 245, 125 work room, 315, 302A, 238, 236, Libraryauditorium men & women toilets - 1931 Bldg.	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440
Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.
2942 W. Van Buren Chicago, IL, 60612
Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

Reinspection Date 10/3/2019
Inspector Name David Avila
100-11093 5/15/2020
Inspector's IDPH License Number / Expiration Date

Inspector's Comments

HA Number:	Inspector Comments:
12	
14	
2016-BBM1	
2016-CT1	
2016-CT2	
2016-CT3	
2016-DWS1	
2016-FD1	
2016-FDR1	
2016-FDR2	
2016-FT1	
2016-FT1M	
2016-FT2	
2016-FT2M	
2016-FT3	
2016-FT3M	
2016-FT4	
2016-FT4M	
2016-FT5	
2016-FT5M	
2016-FT6M	
216-FT6	
29	

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
30	
31	
32	
33	
34	
35	
36	
36A	
37	
37A	
38	
38A	
39	
39A	
40	
40A	
41	
41A	
42	
43	
44	
45	
46	
47	
48	
AA	
AAA	
BB	
BBB	

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
CC	
CCC	
CT1	
DD	
DDD	
EE	
FF	
FT10	
FT11	
FT12	
FT13	
FT14	
FT15	
FT16	
FT17	
FT18	
FT19	
FT20	
FT21	
FT22	
FT23	
FT29	
FT30	
FT4	
FT5	
FT6	
FT7	
FT8	
FT9	

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
GG	
HH	
I	
II	
JJ	
KK	
L8	
L9	
LM10	
LM11	
M10	
M11	
M12	
M13	
M14	
M15	
M16	
M17	
M18	
M19	
M20	
M21	
M22	
M23	
M24	
M25	
M26	
M27	
M28	

Chicago Public Schools

School Lane Tech High School Unit 46221 Building ID 1440

Address 2501 W. Addison Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
M29	
M30	
M31	
M9	

Table II

Management Planner's Review

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
12	Aircell Pipe Insulation	1,300	LF	Unexcavated Areas, Pipe Chases - Rooms 253, and 153D (not observed in 251) - 1931 Bldg.	Chrysotile	TSI	Yes	4	LF	1 Damaged or significantly damaged friable thermal system insulating ACBM	Repair
14	MJP E/F/V on Aircell Pipe Insulation	98	FITTING	Unexcavated Areas, Pipe Chases; Rooms 251, 253, and 153D - 1931 Bldg.	Chrysotile	TSI	Yes	0	FITTING	6 ACBM with the potential for damage	Follow O&M Plan
2016-BBM1	Brown Vinyl Baseboard Mastic	600	SF	Rooms 119, 123, 125 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-CT1	2' x 2' White w/pinhole dots ceiling tile	3,900	SF	Rooms 119, 123, 125, 215B - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-CT2	2' x 2' White Rough with dots ceiling tile	2,500	SF	Rooms 145A, 138A, 115A, 213, 242A, 2nd floor boys washroom - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-CT3	2' x 4' White Smooth Ceiling Tile	3,000	SF	Rooms 120A, 123A, 220A, 214A, 323C, 320A, 487A, 2nd floor boys bathroom, 4th floor ADA bathroom - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-DWS1	Drywall System	6,700	SF	Rooms 119, 123, 125, 129, 130, 148, 150 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FD1	Fire Doors rated 3/4 hour	180	SF	2nd Floor boys bathroom, rooms 342A, 437A boys, 4th floor ADA bathroom - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FDR1	Dark Gray fire proofed cloth draperies	3,000	SF	Room 209 Auditorium balcony - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FDR2	LT. Green fire proofed cloth draperies	1,000	SF	Room 300 Gymnasium #2 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT1	2' x 2' Yellow w/yellow streaks VFT	10,170	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT1M	2' x 2' Yellow w/yellow streaks VFT Mastic	10,170	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT2	2' x 2' Gray w/Gray Streaks VFT	4,000	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322 322A, 335, 336, 430, 434, 449, 4th Floor ADA elevator pump - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
2016-FT2M	2' x 2' Gray w/Gray Streaks VFT Mastic	4,000	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322 322A, 335, 336, 430, 434, 449,4th Floor ADA elevator pump - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT3	2' x 2' Green w/Green Streaks VFT	4,000	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT3M	2' x 2' Green w/Green Streaks VFT Mastic	4,000	SF	Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT4	2' x 2' Blue w/Blue Gray Streaks VFT	150	SF	Rooms 441B, 430, 434 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT4M	2' x 2' Blue w/Blue Gray Streaks VFT Mastic	150	SF	Rooms 441B, 430, 434 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT5	12" x 12" Beige w/Brown and White Specks VFT	5,000	SF	Rooms 435, 447, 245, (1st, 2nd, 3rd, 4th floor corridors) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT5M	12" x 12" Beige w/Brown and White Specks VFT Mastic	5,000	SF	Rooms 435, 447, 245, (1st, 2nd, 3rd, 4th floor corridors) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
2016-FT6M	12" x 12" Dark Brown w/Black Streaks VFT Mastic	4,400	SF	Main Corridors 12s, 2nd, 3rd, 4th floors - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
216-FT6	12" x 12" Dark Brown w/black streaks VFT	4,400	SF	Main Corridors 1st, 2nd, 3rd, 4th floors - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
29	Light Blue w/ Dark Spots Linoleum	1,200	SF	Room 115 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
30	Light Blue w/ Dark Spots Linoleum Mastic	1,200	SF	Room 115 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
31	2'x4' White w/ Holes & Grooves Ceiling Tile	1,200	SF	Room 115 - 1931 Bldg.	Assumed	MISC	Yes	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
32	Drywall	500	SF	Room 115 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
33	Drywall Joint Compound	100	LF	Room 115 - 1931 Bldg.	Assumed	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
34	Vinyl Baseboard	150	LF	Room 115 - 1931 Bldg.	Assumed	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
35	Vinyl Baseboard Mastic	150	LF	Room 115 - 1931 Bldg.	Assumed	MISC	No	0	LF	6 ACBM with the potential for damage	Follow O&M Plan
36	12"x12" Light Beige w/ White and Brown Streaks VFT	1,800	SF	Locker room & office & storage room and toilet (361A), 153A - 1931 Bldg.	Assumed	MISC	No	40	SF	5 ACBM with potential for significant damage	Follow O&M Plan
36A	12"x12" Light Beige w/ White and Brown Streaks VFT MASTIC	1,800	SF	Locker room & office & storage room and toilet (361A), 153A - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
37	12"x12" Dark Gray w/White Streaks VFT (Not Observed)	800	SF	Room 340 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
37A	12"x12" Dark Gray w/ White Streaks VFT	800	SF	Room 340 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
	MASTIC (Not Observed)										
38	12"x12" Gray w/ Gray and White Streaks VFT	1,900	SF	Rooms 133, (Not observed 129, 147) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
38A	12"x12" Gray w/ Gray and White Streaks VFT MASTIC	1,900	SF	Rooms 133, (Not observed 129, 147) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
39	12"x12" Light Green Streaked VFT	3,500	SF	Serving line room - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
39A	12"x12" Light Green Streaked VFT MASTIC	3,500	SF	Serving line room - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
40	9"x9" Tan w/ brown & white streaks VFT	40	SF	Library stairs landings - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
40A	9"x9" Tan w/brown & white streaks VFT MASTIC	40	SF	Library stairs landings - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
41	12"x12" Green w/ white & black streaks VFT	600	SF	Room 117 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
41A	12"x12" Green w/ white & black streaks	600	SF	Room 117 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
42	Black/gray lab counter tops	5,400	SF	Rooms 439, 435, 431, 438 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
43	12" x 12" White w/ Blue & Red Specks VFT	800	SF	Room 146 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
44	12" x 12" White w/ Blue & Red Specks VFT Mastic	800	SF	Room 146 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
45	Yellow Linoleum	100	SF	Library Entrance - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
46	Yellow Linoleum Mastic	100	SF	Library Entrance - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
47	Blue Linoleum	40	SF	Library Entrance - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
48	Blue Linoleum Mastic	40	SF	Library Entrance - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
AA	Stage Door (Fire curtain)	1,000	SF	Auditorium Stage - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
AAA	2' x 2' Ceiling Tile fissured, white	800	SF	Room 445, Art Area corridor - 1931 Bldg.	Assumed	MISC	Yes	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
BB	1'x1' White Wormy Ceiling Tile			Room 241, 437, Main Office, 113, 134, Auditorium, 252, 335, 433, 442, 444 (bandroom), 446, 400, 402, 403 - 1931 Bldg.	No ACBM						
BBB	Acoustical Wall Tile, Fissured	450	SF	Room 252 - 1931 Bldg.	Assumed	MISC	Yes	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
CC	1'x1' White Wormy Ceiling Tile Mastic			Room 241, 437, Main Office 113, 134, Auditorium, 252, 335, 433, 442, 444 (bandroom), 446, 400, 402, 403 - 1931 Bldg.	No ACBM						
CCC	Textured Plaster, Walls and Ceiling	4,500	SF	1st floor corridor by main office, Auditorium, Room 202 - 1931 Bldg.	Assumed	SURFACE	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
CT1	2' x 4' Ceiling Tiles with Grooves	800	SF	Engineer's Office - 1931 Bldg.	Assumed	MISC	Yes	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
DD	2'x2' White Wormy Ceiling Tile			Serving Area, Lunchroom; 213, 252, Toilet rooms; 138A, 115A, 145A, 242A, 214A, 215B, 245A, 320A - 1931 Bldg.	No ACBM						
DDD	Terrazzo Floor	30,000	SF	All corridors, stairwells, auditorium vestibule, main office lobby - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
EE	2'x4' White Wormy Ceiling Tile (Not observed)			Room 125, 447, 112, 117, 119, 123, 205, 330 - 1931 Bldg.	No ACBM						
FF	Aircell Duct Insulation	2,000	SF	SW Unexcavated Area - 1931 Bldg.	Chrysotile	TSI	Yes	10	SF	1 Damaged or significantly damaged friable thermal system insulating ACBM	Repair
FT10	12"x12" White w/ Tan Streaks VFT	1,200	SF	Room 443 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT11	12"x12" Dark Brown w/ Black Streaks VFT	16,270	SF	All corridors and auditorium - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT12	12"x12" Peach VFT	1,600	SF	Rooms 132, 203 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT13	12"x12" Off White w/ Brown Specks VFT (Abated)			Room 220 - 1931 Bldg.	Abated	MISC				7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
FT14	9"x9" Off White w/ Gray Streaks VFT (ABATED)			Lunchroom - 1931 Bldg.	Abated	MISC				7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
FT15	9"x9" Green VFT (ABATED)			Lunchroom - 1931 Bldg.	Abated	MISC				7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
FT16	9"x9" Beige w/ Brown Streaks VFT	1,000	SF	(Serving Area - ABATED) Room 134 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT17	12"x12" White w/ Brown Specks VFT	650	SF	Kitchen - 1931 Bldg.	Chrysotile	MISC	No	500	SF	5 ACBM with potential for significant damage	Follow O&M Plan
FT18	12"x12" Beige w/ Wavy Brown VFT	3,500	SF	Kitchen - 1931 Bldg.	Chrysotile	MISC	No	30	SF	5 ACBM with potential for significant damage	Follow O&M Plan
FT19	9"x9" Black w/ White Streaks VFT	600	SF	Lunchroom Storage, & Engineer's Office - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT20	9"x9" Maroon w/ White Streaks VFT	1,500	SF	Lunchroom Storage, & Engineer's Office; Gym III 361 mezzanine locker room - 1931 Bldg.	Assumed	MISC	No	10	SF	5 ACBM with potential for significant damage	Follow O&M Plan
FT21	12"x12" Green w/ White Streaks VFT	200	SF	Engineers Locker Room - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT22	12"x12" Gray w/ White & Brown Specks VFT	2,737	SF	Girl's Locker Room Office, Shower Office, Storage, Laundry, 439, 431, 438, 340 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
FT23	6"x6" Black VFT	500	SF	Library Loft (balcony) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT29	12" x 12" White w/Tan Streaks VFT	800	SF	Engineer's Office - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT30	12" x 12" Pink VFT	1,500	SF	Room 146 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT4	12"x12" Beige w/ Brown & White Specks VFT	44,600	SF	Corridors all floors, 441B, 435, 245, 125 work room, 315, 302A, 238, 236, Library, Auditorium, Men and Women toilets - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT5	9"x9" Peach w/ Cream Streaks VFT	5,200	SF	Vaults in rooms 131, 435, 438, 439, 217, 221, 241, 302A - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT6	6"x6" White VFT	500	SF	Library Loft (balcony) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT7	12"x12" Green VFT	1,884	SF	Driver's Education Building room 199 simulator room - 1975 Bldg.	Chrysotile	MISC	No	100	SF	4 Damaged or significantly damaged friable misc. ACBM	Follow O&M Plan
FT8	12"x12" Gray w/ White Streaks VFT	800	SF	Room 144 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT9	12"x12" Sand VFT	3,000	SF	Room 447, 116 (not observed in 145, 143) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
GG	Interior Window Caulk			Throughout - 1931 Bldg.	No ACBM						
HH	Exterior Window Caulk			Throughout - 1931 Bldg.	No ACBM						
I	MJP E/F/V on Fiberglass Pipe Insulation			Boiler Room, Bathroom Pipe Chases, Janitors Closets - 1931 Bldg.	No ACBM						
II	MJP E/F/V on Fiberglass Pipe Insulation			Janitors Closet, Bathroom Pipe Chases - 1975 Bldg.	No ACBM						
JJ	2'x4' White Ceiling Tile			Drivers Education Building - 1975 Bldg.	No ACBM						
KK	Tan Rubber Flooring	600	SF	Old Dishwasher Room - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
L8	Brown Linoleum - ABATED			Room 124, 128, 133 - 1931 Bldg.	Abated	MISC				7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
L9	Green & White Linoleum			Stage Crew Office - 1931 Bldg.	No ACBM	MISC					
LM10	Brown Linoleum Mastic - ABATED			Room 128 - 1931 Bldg.	Abated	MISC				7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
LM11	Green & White Linoleum Mastic			Stage Crew Office - 1931 Bldg.	No ACBM	MISC					
M10	9"x9" Peach w/ cream streaks VFT Mastic	4,800	SF	Vaults in rooms 435, 438, 439, 217, 221, 241 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M11	6"x6" White VFT Mastic	500	SF	Library Loft (balcony) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M12	12"x12" Green VFT Mastic	5,000	SF	Driver's Education Building - 1975 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M13	12"x12" Gray w/ White Streaks VFT Mastic	800	SF	Room 144 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
M14	12"x12" Sand VFT Mastic	5,150	SF	Rooms 447, 116 (not observed in 145, 143) - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M15	12"x12" White w/ Tan Streaks VFT Mastic	1,200	SF	Room 443 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M16	12"x12" Dark Brown w/ Black Streaks VFT Mastic	16,270	SF	Corridors & Auditorium - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M17	12"x12" Peach VFT Mastic	1,450	SF	Rooms 203, 132 -1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M18	12"x12" Off White w/ Brown Streaks VFT Mastic	1,600	SF	Room 335, 220 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M19	9"x9" Off White w/ Gray Streaks VFT Mastic - ABATED			Lunchroom - 1931 Bldg.	Abated	MISC				7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
M20	9"x9" Green VFT Mastic - ABATED			Lunchroom - 1931 Bldg.	Abated	MISC	No			7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
M21	9"x9" Beige w/ Brown Streaks VFT Mastic	2,000	SF	(Serving Area - ABATED) Room 134 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M22	12"x12" White w/ Brown Specks VFT Mastic	650	SF	Kitchen - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M23	12"x12" Beige w/ Wavy Brown VFT Mastic	3,500	SF	Kitchen - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M24	9"x9" Black w/ White Streaks VFT Mastic	600	SF	Lunchroom Storage & Engineer's Office - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M25	9"x9" Maroon w/ White Streaks VFT Mastic	1,500	SF	Lunchroom Storage & Engineer's Offices; Gym III 361 Mezzanine locker room - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M26	12"x12" Green w/ White Streaks VFT Mastic	200	SF	Engineers Locker Room - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M27	12"x12" Gray w/ White & Brown Specks VFT Mastic	2,737	SF	Girls' Locker Room & Office, Shower Office, Storage & Laundry, Rooms 439, 431, 438, 340 - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M28	6"x6" Black VFT Mastic	500	SF	Library Loft (balcony) - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M29	12" x 12" White w/Tan Streaks VFT Mastic	800	SF	Engineer's Office - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M30	12" x 12" Pink VFT Mastic	1,500	SF	Room 146 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M31	Carpet Mastic	2,400	SF	Rooms 130, 210, 235, 330, 205, 212, 213 - 1931 Bldg.	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
M9	12"x12" Beige w/ Brown & White Specks VFT Mastic	44,600	SF	Corridors all floors, 441B, 435, 245, 125 work room, 315, 302A, 238, 236, Library auditorium men & women toilets - 1931 Bldg.	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

Review Date	10/25/2019
Manager Planner Name	Arturo Saenz
100-04019	5/15/2020
Manager IDPH License No/Expiration	

HA Number	Management Comments
12	Isolate and Repair
14	
2016-BBM1	
2016-CT1	
2016-CT2	
2016-CT3	
2016-DWS1	
2016-FD1	

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
2016-FDR1	
2016-FDR2	
2016-FT1	
2016-FT1M	
2016-FT2	
2016-FT2M	
2016-FT3	
2016-FT3M	
2016-FT4	
2016-FT4M	
2016-FT5	
2016-FT5M	
2016-FT6M	
216-FT6	
29	
30	
31	
32	
33	
34	
35	
36	replace damaged VFT
36A	
37	
37A	
38	

Chicago Public Schools

School Lane Tech High School
Address 2501 W. Addison

Unit 46221
 Chicago, IL, 60618

Building ID 1440
Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.
 2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
38A	
39	
39A	
40	
40A	
41	
41A	
42	
43	
44	
45	
46	
47	
48	
AA	
AAA	
BB	
BBB	
CC	
CCC	
CT1	
DD	
DDD	
EE	
FF	Isolate Area, Repair ACM
FT10	

Chicago Public Schools

School Lane Tech High School
Address 2501 W. Addison

Unit 46221
 Chicago, IL, 60618

Building ID 1440
Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.
 2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575 Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
FT11	
FT12	
FT13	
FT14	
FT15	
FT16	
FT17	replace damaged VFT
FT18	replace damaged VFT
FT19	
FT20	replace damaged VFT
FT21	
FT22	
FT23	
FT29	
FT30	
FT4	
FT5	
FT6	
FT7	replace damaged VFT
FT8	
FT9	
GG	
HH	
I	
II	
JJ	

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
KK	
L8	
L9	
LM10	
LM11	
M10	
M11	
M12	
M13	
M14	
M15	
M16	
M17	
M18	
M19	
M20	
M21	
M22	
M23	
M24	
M25	
M26	
M27	
M28	
M29	
M30	

Chicago Public Schools

School Lane Tech High School

Unit 46221

Building ID 1440

Address 2501 W. Addison

Chicago, IL, 60618

Region 01

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) GSG-Probe Consulting, Inc.

2942 W. Van Buren Chicago, IL, 60612

Phone: 3123197575

Fax:

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
M31	
M9	

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **12**
MATERIAL DESCRIPTION: **Aircell Pipe Insulation**
HISTORICAL AHERA DAMAGE CATEGORY **1 Damaged or significantly damaged friable thermal system insulating ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Repair**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **1. Damaged or significantly damaged friable thermal system insulating ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Unexcavated Areas, Pipe Chases - Rooms 253, and 153D (not observed in 251) - 1931 Bldg.**

MATERIAL QUANTITY: **1300** MATERIAL UNITS: **LF**

DAMAGE QUANTITY: **4** DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **12**
MATERIAL DESCRIPTION: **Aircell Pipe Insulation**
MATERIAL LOCATION: **Unexcavated Areas, Pipe Chases - Rooms 253, and 153D (not observed in 251) - 1931 Bldg.**
MATERIAL QUANTITY: **1300** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **4** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Repair

Comments:

Isolate and Repair

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **14**
MATERIAL DESCRIPTION: **MJP E/F/V on Aircell Pipe Insulation**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Unexcavated Areas, Pipe Chases; Rooms 251, 253, and 153D - 1931 Bldg.**
MATERIAL QUANTITY: **98** MATERIAL UNITS: **FITTING**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **FITTING**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **14**
MATERIAL DESCRIPTION: **MJP E/F/V on Aircell Pipe Insulation**
MATERIAL LOCATION: **Unexcavated Areas, Pipe Chases; Rooms 251, 253, and 153D - 1931 Bldg.**
MATERIAL QUANTITY: **98** MATERIAL UNITS: **FITTING**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **FITTING**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-BBM1**
MATERIAL DESCRIPTION: **Brown Vinyl Baseboard Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 119, 123, 125 - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-BBM1**

MATERIAL DESCRIPTION: **Brown Vinyl Baseboard Mastic**

MATERIAL LOCATION: **Rooms 119, 123, 125 - 1931 Bldg.**

MATERIAL QUANTITY: **600**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-CT1**
MATERIAL DESCRIPTION: **2' x 2' White w/pinhole dots ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 119, 123, 125, 215B - 1931 Bldg.**
MATERIAL QUANTITY: **3900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-CT1**
MATERIAL DESCRIPTION: **2' x 2' White w/pinhole dots ceiling tile**
MATERIAL LOCATION: **Rooms 119, 123, 125, 215B - 1931 Bldg.**
MATERIAL QUANTITY: **3900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-CT2**
MATERIAL DESCRIPTION: **2' x 2' White Rough with dots ceiling tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 145A, 138A, 115A, 213, 242A, 2nd floor boys washroom - 1931 Bldg.**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-CT2**
MATERIAL DESCRIPTION: **2' x 2' White Rough with dots ceiling tile**
MATERIAL LOCATION: **Rooms 145A, 138A, 115A, 213, 242A, 2nd floor boys washroom - 1931 Bldg.**
MATERIAL QUANTITY: **2500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-CT3**
MATERIAL DESCRIPTION: **2' x 4' White Smooth Ceiling Tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 120A, 123A, 220A, 214A, 323C, 320A, 487A, 2nd floor boys bathroom, 4th floor ADA bathroom - 1931 Bldg.**

MATERIAL QUANTITY: **3000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-CT3**

MATERIAL DESCRIPTION: **2' x 4' White Smooth Ceiling Tile**

MATERIAL LOCATION: **Rooms 120A, 123A, 220A, 214A, 323C, 320A, 487A, 2nd floor boys bathroom, 4th floor ADA bathroom - 1931 Bldg.**

MATERIAL QUANTITY: **3000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-DWS1**
MATERIAL DESCRIPTION: **Drywall System**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 119, 123, 125, 129, 130, 148, 150 - 1931 Bldg.**
MATERIAL QUANTITY: **6700** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-DWS1**
MATERIAL DESCRIPTION: **Drywall System**
MATERIAL LOCATION: **Rooms 119, 123, 125, 129, 130, 148, 150 - 1931 Bldg.**
MATERIAL QUANTITY: **6700** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FD1**
MATERIAL DESCRIPTION: **Fire Doors rated 3/4 hour**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **2nd Floor boys bathroom, rooms 342A, 437A boys, 4th floor ADA bathroom - 1931 Bldg.**

MATERIAL QUANTITY: **180** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FD1**

MATERIAL DESCRIPTION: **Fire Doors rated 3/4 hour**

MATERIAL LOCATION: **2nd Floor boys bathroom, rooms 342A, 437A boys, 4th floor ADA bathroom - 1931 Bldg.**

MATERIAL QUANTITY: **180** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FDR1**
MATERIAL DESCRIPTION: **Dark Gray fire proofed cloth draperies**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 209 Auditorium balcony - 1931 Bldg.**
MATERIAL QUANTITY: **3000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FDR1**
MATERIAL DESCRIPTION: **Dark Gray fire proofed cloth draperies**
MATERIAL LOCATION: **Room 209 Auditorium balcony - 1931 Bldg.**
MATERIAL QUANTITY: **3000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FDR2**
MATERIAL DESCRIPTION: **LT. Green fire proofed cloth draperies**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 300 Gymnasium #2 - 1931 Bldg.**
MATERIAL QUANTITY: **1000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FDR2**
MATERIAL DESCRIPTION: **LT. Green fire proofed cloth draperies**
MATERIAL LOCATION: **Room 300 Gymnasium #2 - 1931 Bldg.**
MATERIAL QUANTITY: **1000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT1**
MATERIAL DESCRIPTION: **2' x 2' Yellow w/yellow streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.**

MATERIAL QUANTITY: **10170**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT1**
MATERIAL DESCRIPTION: **2' x 2' Yellow w/yellow streaks VFT**
MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.**
MATERIAL QUANTITY: **10170** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT1M**
MATERIAL DESCRIPTION: **2' x 2' Yellow w/yellow streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.**

MATERIAL QUANTITY: **10170**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT1M**
MATERIAL DESCRIPTION: **2' x 2' Yellow w/yellow streaks VFT Mastic**
MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.**
MATERIAL QUANTITY: **10170** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT2**
MATERIAL DESCRIPTION: **2' x 2' Gray w/Gray Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322 322A, 335, 336, 430, 434, 449,4th Floor ADA elevator pump - 1931 Bldg.**

MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT2**
MATERIAL DESCRIPTION: **2' x 2' Gray w/Gray Streaks VFT**
MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225. 234, 243, 247, 322 322A, 335, 336, 430, 434, 449,4th Floor
ADA elevator pump - 1931 Bldg.**
MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT2M**
MATERIAL DESCRIPTION: **2' x 2' Gray w/Gray Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322 322A, 335, 336, 430, 434, 449, 4th Floor ADA elevator pump - 1931 Bldg.**

MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT2M**
MATERIAL DESCRIPTION: **2' x 2' Gray w/Gray Streaks VFT Mastic**
MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225. 234, 243, 247, 322 322A, 335, 336, 430, 434, 449,4th Floor
ADA elevator pump - 1931 Bldg.**
MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT3**
MATERIAL DESCRIPTION: **2' x 2' Green w/Green Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.**

MATERIAL QUANTITY: **4000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT3**
MATERIAL DESCRIPTION: **2' x 2' Green w/Green Streaks VFT**
MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.**
MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT3M**
MATERIAL DESCRIPTION: **2' x 2' Green w/Green Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.**

MATERIAL QUANTITY: **4000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT3M**
MATERIAL DESCRIPTION: **2' x 2' Green w/Green Streaks VFT Mastic**
MATERIAL LOCATION: **Rooms 119, 123, 125, 215, 219, 223, 225, 234, 243, 247, 322, 322A, 335, 336, 430, 434, 449 - 1931 Bldg.**
MATERIAL QUANTITY: **4000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT4**
MATERIAL DESCRIPTION: **2' x 2' Blue w/Blue Gray Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 441B, 430, 434 - 1931 Bldg.**

MATERIAL QUANTITY: **150**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT4**

MATERIAL DESCRIPTION: **2' x 2' Blue w/Blue Gray Streaks VFT**

MATERIAL LOCATION: **Rooms 441B, 430, 434 - 1931 Bldg.**

MATERIAL QUANTITY: **150**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT4M**
MATERIAL DESCRIPTION: **2' x 2' Blue w/Blue Gray Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 441B, 430, 434 - 1931 Bldg.**
MATERIAL QUANTITY: **150** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT4M**

MATERIAL DESCRIPTION: **2' x 2' Blue w/Blue Gray Streaks VFT Mastic**

MATERIAL LOCATION: **Rooms 441B, 430, 434 - 1931 Bldg.**

MATERIAL QUANTITY: **150**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT5**
MATERIAL DESCRIPTION: **12" x 12" Beige w/Brown and White Specks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 435, 447, 245, (1st, 2nd, 3rd, 4th floor corridors) - 1931 Bldg.**
MATERIAL QUANTITY: **5000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT5**
MATERIAL DESCRIPTION: **12" x 12" Beige w/Brown and White Specks VFT**
MATERIAL LOCATION: **Rooms 435, 447, 245, (1st, 2nd, 3rd, 4th floor corridors) - 1931 Bldg.**
MATERIAL QUANTITY: **5000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT5M**
MATERIAL DESCRIPTION: **12" x 12" Beige w/Brown and White Specks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Rooms 435, 447, 245, (1st, 2nd, 3rd, 4th floor corridors) - 1931 Bldg.**

MATERIAL QUANTITY: **5000** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT5M**
MATERIAL DESCRIPTION: **12" x 12" Beige w/Brown and White Specks VFT Mastic**
MATERIAL LOCATION: **Rooms 435, 447, 245, (1st, 2nd, 3rd, 4th floor corridors) - 1931 Bldg.**
MATERIAL QUANTITY: **5000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **2016-FT6M**
MATERIAL DESCRIPTION: **12" x 12" Dark Brown w/Black Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Main Corridors 12s, 2nd, 3rd, 4th floors - 1931 Bldg.**
MATERIAL QUANTITY: **4400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **2016-FT6M**

MATERIAL DESCRIPTION: **12" x 12" Dark Brown w/Black Streaks VFT Mastic**

MATERIAL LOCATION: **Main Corridors 12s, 2nd, 3rd, 4th floors - 1931 Bldg.**

MATERIAL QUANTITY: **4400**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **216-FT6**
MATERIAL DESCRIPTION: **12" x 12" Dark Brown w/black streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Main Corridors 1st, 2nd, 3rd, 4th floors - 1931 Bldg.**

MATERIAL QUANTITY: **4400**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **216-FT6**
MATERIAL DESCRIPTION: **12" x 12" Dark Brown w/black streaks VFT**
MATERIAL LOCATION: **Main Corridors 1st, 2nd, 3rd, 4th floors - 1931 Bldg.**
MATERIAL QUANTITY: **4400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **29**
MATERIAL DESCRIPTION: **Light Blue w/ Dark Spots Linoleum**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **29**
MATERIAL DESCRIPTION: **Light Blue w/ Dark Spots Linoleum**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **30**
MATERIAL DESCRIPTION: **Light Blue w/ Dark Spots Linoleum Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **30**
MATERIAL DESCRIPTION: **Light Blue w/ Dark Spots Linoleum Mastic**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **31**
MATERIAL DESCRIPTION: **2'x4' White w/ Holes & Grooves Ceiling Tile**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **31**

MATERIAL DESCRIPTION: **2'x4' White w/ Holes & Grooves Ceiling Tile**

MATERIAL LOCATION: **Room 115 - 1931 Bldg.**

MATERIAL QUANTITY: **1200**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **32**
MATERIAL DESCRIPTION: **Drywall**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **32**
MATERIAL DESCRIPTION: **Drywall**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **33**
MATERIAL DESCRIPTION: **Drywall Joint Compound**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **100** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **33**
MATERIAL DESCRIPTION: **Drywall Joint Compound**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **100** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **34**
MATERIAL DESCRIPTION: **Vinyl Baseboard**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **150** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **34**

MATERIAL DESCRIPTION: **Vinyl Baseboard**

MATERIAL LOCATION: **Room 115 - 1931 Bldg.**

MATERIAL QUANTITY: **150**

MATERIAL UNITS: **LF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **35**
MATERIAL DESCRIPTION: **Vinyl Baseboard Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **150** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **35**
MATERIAL DESCRIPTION: **Vinyl Baseboard Mastic**
MATERIAL LOCATION: **Room 115 - 1931 Bldg.**
MATERIAL QUANTITY: **150** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **36**
MATERIAL DESCRIPTION: **12"x12" Light Beige w/ White and Brown Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **5 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON: **Deterioration**
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **5. ACBM with potential for significant damage**

DAMAGE REASON: **Deterioration**
DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Locker room & office & storage room and toilet (361A), 153A - 1931 Bldg.**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **40** DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **36**
MATERIAL DESCRIPTION: **12"x12" Light Beige w/ White and Brown Streaks VFT**
MATERIAL LOCATION: **Locker room & office & storage room and toilet (361A), 153A - 1931 Bldg.**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **40** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

replace damaged VFT

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **36A**
MATERIAL DESCRIPTION: **12"x12" Light Beige w/ White and Brown Streaks VFT MASTIC**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON: **Deterioration**
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Locker room & office & storage room and toilet (361A), 153A - 1931 Bldg.**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **36A**
MATERIAL DESCRIPTION: **12"x12" Light Beige w/ White and Brown Streaks VFT MASTIC**
MATERIAL LOCATION: **Locker room & office & storage room and toilet (361A), 153A - 1931 Bldg.**
MATERIAL QUANTITY: **1800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **37**
MATERIAL DESCRIPTION: **12"x12" Dark Gray w/White Streaks VFT (Not Observed)**
HISTORICAL AHERA DAMAGE CATEGORY **6 Damaged or significantly damaged friable misc. ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 340 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **37**
MATERIAL DESCRIPTION: **12"x12" Dark Gray w/White Streaks VFT (Not Observed)**
MATERIAL LOCATION: **Room 340 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **37A**
MATERIAL DESCRIPTION: **12"x12" Dark Gray w/ White Streaks VFT MASTIC (Not Observed)**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 340 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **37A**
MATERIAL DESCRIPTION: **12"x12" Dark Gray w/ White Streaks VFT MASTIC (Not Observed)**
MATERIAL LOCATION: **Room 340 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **38**
MATERIAL DESCRIPTION: **12"x12" Gray w/ Gray and White Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 133, (Not observed 129, 147) - 1931 Bldg.**
MATERIAL QUANTITY: **1900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **38**
MATERIAL DESCRIPTION: **12"x12" Gray w/ Gray and White Streaks VFT**
MATERIAL LOCATION: **Rooms 133, (Not observed 129, 147) - 1931 Bldg.**
MATERIAL QUANTITY: **1900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **38A**
MATERIAL DESCRIPTION: **12"x12" Gray w/ Gray and White Streaks VFT MASTIC**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 133, (Not observed 129, 147) - 1931 Bldg.**
MATERIAL QUANTITY: **1900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **38A**
MATERIAL DESCRIPTION: **12"x12" Gray w/ Gray and White Streaks VFT MASTIC**
MATERIAL LOCATION: **Rooms 133, (Not observed 129, 147) - 1931 Bldg.**
MATERIAL QUANTITY: **1900** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **39**
MATERIAL DESCRIPTION: **12"x12" Light Green Streaked VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Serving line room - 1931 Bldg.**
MATERIAL QUANTITY: **3500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **39**
MATERIAL DESCRIPTION: **12"x12" Light Green Streaked VFT**
MATERIAL LOCATION: **Serving line room - 1931 Bldg.**
MATERIAL QUANTITY: **3500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **39A**
MATERIAL DESCRIPTION: **12"x12" Light Green Streaked VFT MASTIC**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Serving line room - 1931 Bldg.**
MATERIAL QUANTITY: **3500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **39A**
MATERIAL DESCRIPTION: **12"x12" Light Green Streaked VFT MASTIC**
MATERIAL LOCATION: **Serving line room - 1931 Bldg.**
MATERIAL QUANTITY: **3500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **40**
MATERIAL DESCRIPTION: **9"x9" Tan w/ brown & white streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Library stairs landings - 1931 Bldg.**
MATERIAL QUANTITY: **40** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **40**

MATERIAL DESCRIPTION: **9"x9" Tan w/ brown & white streaks VFT**

MATERIAL LOCATION: **Library stairs landings - 1931 Bldg.**

MATERIAL QUANTITY: **40**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **40A**
MATERIAL DESCRIPTION: **9"x9" Tan w/brown & white streaks VFT MASTIC**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Library stairs landings - 1931 Bldg.**
MATERIAL QUANTITY: **40** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **40A**
MATERIAL DESCRIPTION: **9"x9" Tan w/brown & white streaks VFT MASTIC**
MATERIAL LOCATION: **Library stairs landings - 1931 Bldg.**
MATERIAL QUANTITY: **40** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **41**
MATERIAL DESCRIPTION: **12"x12" Green w/ white & black streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 117 - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **41**
MATERIAL DESCRIPTION: **12"x12" Green w/ white & black streaks VFT**
MATERIAL LOCATION: **Room 117 - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **41A**
MATERIAL DESCRIPTION: **12"x12" Green w/ white & black streaks**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 117 - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **41A**
MATERIAL DESCRIPTION: **12"x12" Green w/ white & black streaks**
MATERIAL LOCATION: **Room 117 - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **42**
MATERIAL DESCRIPTION: **Black/gray lab counter tops**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 439, 435, 431, 438 - 1931 Bldg.**
MATERIAL QUANTITY: **5400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **42**
MATERIAL DESCRIPTION: **Black/gray lab counter tops**
MATERIAL LOCATION: **Rooms 439, 435, 431, 438 - 1931 Bldg.**
MATERIAL QUANTITY: **5400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **AA**
MATERIAL DESCRIPTION: **Stage Door (Fire curtain)**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Auditorium Stage - 1931 Bldg.**
MATERIAL QUANTITY: **1000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **AA**
MATERIAL DESCRIPTION: **Stage Door (Fire curtain)**
MATERIAL LOCATION: **Auditorium Stage - 1931 Bldg.**
MATERIAL QUANTITY: **1000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **AAA**
MATERIAL DESCRIPTION: **2'x 2' Ceiling Tile fissured, white**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 445, Art Area corridor - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **AAA**
MATERIAL DESCRIPTION: **2'x 2' Ceiling Tile fissured, white**
MATERIAL LOCATION: **Room 445, Art Area corridor - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **BB**
MATERIAL DESCRIPTION: **1'x1' White Wormy Ceiling Tile**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Room 241, 437, Main Office, 113, 134, Auditorium, 252, 335, 433, 442, 444 (bandroom), 446, 400, 402, 403 - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **BB**

MATERIAL DESCRIPTION: **1'x1' White Wormy Ceiling Tile**

MATERIAL LOCATION: **Room 241, 437, Main Office, 113, 134, Auditorium, 252, 335, 433, 442, 444 (bandroom), 446, 400, 402, 403 - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **BBB**
MATERIAL DESCRIPTION: **Acoustical Wall Tile, Fissured**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 252 - 1931 Bldg.**
MATERIAL QUANTITY: **450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **BBB**
MATERIAL DESCRIPTION: **Acoustical Wall Tile, Fissured**
MATERIAL LOCATION: **Room 252 - 1931 Bldg.**
MATERIAL QUANTITY: **450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **CC**
MATERIAL DESCRIPTION: **1'x1' White Wormy Ceiling Tile Mastic**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Room 241, 437, Main Office 113, 134, Auditorium, 252, 335, 433, 442, 444 (bandroom), 446, 400, 402, 403 - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **CC**

MATERIAL DESCRIPTION: **1'x1' White Wormy Ceiling Tile Mastic**

MATERIAL LOCATION: **Room 241, 437, Main Office 113, 134, Auditorium, 252, 335, 433, 442, 444 (bandroom), 446, 400, 402, 403 - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: 10/25/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **CCC**
MATERIAL DESCRIPTION: **Textured Plaster, Walls and Ceiling**
HISTORICAL AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and its condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **1st floor corridor by main office, Auditorium, Room 202 - 1931 Bldg.**
MATERIAL QUANTITY: **4500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **CCC**
MATERIAL DESCRIPTION: **Textured Plaster, Walls and Ceiling**
MATERIAL LOCATION: **1st floor corridor by main office, Auditorium, Room 202 - 1931 Bldg.**
MATERIAL QUANTITY: **4500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **CT1**
MATERIAL DESCRIPTION: **2' x 4' Ceiling Tiles with Grooves**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **CT1**
MATERIAL DESCRIPTION: **2' x 4' Ceiling Tiles with Grooves**
MATERIAL LOCATION: **Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **DD**
MATERIAL DESCRIPTION: **2'x2' White Wormy Ceiling Tile**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Serving Area, Lunchroom; 213, 252, Toilet rooms; 138A, 115A, 145A, 242A, 214A, 215B, 245A, 320A - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **DD**

MATERIAL DESCRIPTION: **2'x2' White Wormy Ceiling Tile**

MATERIAL LOCATION: **Serving Area, Lunchroom; 213, 252, Toilet rooms; 138A, 115A, 145A, 242A, 214A, 215B, 245A, 320A - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **DDD**
MATERIAL DESCRIPTION: **Terrazzo Floor**
HISTORICAL AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and its condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **All corridors, stairwells, auditorium vestibule, main office lobby - 1931 Bldg.**
MATERIAL QUANTITY: **30000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **DDD**

MATERIAL DESCRIPTION: **Terrazzo Floor**

MATERIAL LOCATION: **All corridors, stairwells, auditorium vestibule, main office lobby - 1931 Bldg.**

MATERIAL QUANTITY: **30000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **EE**
MATERIAL DESCRIPTION: **2'x4' White Wormy Ceiling Tile (Not observed)**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Room 125, 447, 112, 117, 119, 123, 205, 330 - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **EE**

MATERIAL DESCRIPTION: **2'x4' White Wormy Ceiling Tile (Not observed)**

MATERIAL LOCATION: **Room 125, 447, 112, 117, 119, 123, 205, 330 - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FF**
MATERIAL DESCRIPTION: **Aircell Duct Insulation**
HISTORICAL AHERA DAMAGE CATEGORY **1 Damaged or significantly damaged friable thermal system insulating ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Repair**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **1. Damaged or significantly damaged friable thermal system insulating ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **SW Unexcavated Area - 1931 Bldg.**

MATERIAL QUANTITY: **2000**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **10**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FF**
MATERIAL DESCRIPTION: **Aircell Duct Insulation**
MATERIAL LOCATION: **SW Unexcavated Area - 1931 Bldg.**
MATERIAL QUANTITY: **2000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **10** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Repair

Comments:

Isolate Area, Repair ACM

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT10**
MATERIAL DESCRIPTION: **12"x12" White w/ Tan Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 443 - 1931 Bldg.**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT10**

MATERIAL DESCRIPTION: **12"x12" White w/ Tan Streaks VFT**

MATERIAL LOCATION: **Room 443 - 1931 Bldg.**

MATERIAL QUANTITY: **1200**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT11**
MATERIAL DESCRIPTION: **12"x12" Dark Brown w/ Black Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **All corridors and auditorium - 1931 Bldg.**
MATERIAL QUANTITY: **16270** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT11**
MATERIAL DESCRIPTION: **12"x12" Dark Brown w/ Black Streaks VFT**
MATERIAL LOCATION: **All corridors and auditorium - 1931 Bldg.**
MATERIAL QUANTITY: **16270** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT12**
MATERIAL DESCRIPTION: **12"x12" Peach VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 132, 203 - 1931 Bldg.**
MATERIAL QUANTITY: **1600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT12**
MATERIAL DESCRIPTION: **12"x12" Peach VFT**
MATERIAL LOCATION: **Rooms 132, 203 - 1931 Bldg.**
MATERIAL QUANTITY: **1600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT13**
MATERIAL DESCRIPTION: **12"x12" Off White w/ Brown Specks VFT (Abated)**
HISTORICAL AHERA DAMAGE CATEGORY **7 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Room 220 - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____

Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT13**

MATERIAL DESCRIPTION: **12"x12" Off White w/ Brown Specks VFT (Abated)**

MATERIAL LOCATION: **Room 220 - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT14**
MATERIAL DESCRIPTION: **9"x9" Off White w/ Gray Streaks VFT (ABATED)**
HISTORICAL AHERA DAMAGE CATEGORY **7**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Lunchroom - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT14**

MATERIAL DESCRIPTION: **9"x9" Off White w/ Gray Streaks VFT (ABATED)**

MATERIAL LOCATION: **Lunchroom - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT15**
MATERIAL DESCRIPTION: **9"x9" Green VFT (ABATED)**
HISTORICAL AHERA DAMAGE CATEGORY **7**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Lunchroom - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT15**

MATERIAL DESCRIPTION: **9"x9" Green VFT (ABATED)**

MATERIAL LOCATION: **Lunchroom - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT16**
MATERIAL DESCRIPTION: **9"x9" Beige w/ Brown Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **(Serving Area - ABATED) Room 134 - 1931 Bldg.**
MATERIAL QUANTITY: **1000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT16**
MATERIAL DESCRIPTION: **9"x9" Beige w/ Brown Streaks VFT**
MATERIAL LOCATION: **(Serving Area - ABATED) Room 134 - 1931 Bldg.**
MATERIAL QUANTITY: **1000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT17**
MATERIAL DESCRIPTION: **12"x12" White w/ Brown Specks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **5 Damaged or significantly damaged friable misc. ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **5. ACBM with potential for significant damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Kitchen - 1931 Bldg.**
MATERIAL QUANTITY: **650** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **500** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT17**
MATERIAL DESCRIPTION: **12"x12" White w/ Brown Specks VFT**
MATERIAL LOCATION: **Kitchen - 1931 Bldg.**
MATERIAL QUANTITY: **650** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **500** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:
replace damaged VFT

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT18**
MATERIAL DESCRIPTION: **12"x12" Beige w/ Wavy Brown VFT**
HISTORICAL AHERA DAMAGE CATEGORY **5 Damaged or significantly damaged friable misc. ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **5. ACBM with potential for significant damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Kitchen - 1931 Bldg.**
MATERIAL QUANTITY: **3500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **30** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT18**

MATERIAL DESCRIPTION: **12"x12" Beige w/ Wavy Brown VFT**

MATERIAL LOCATION: **Kitchen - 1931 Bldg.**

MATERIAL QUANTITY: **3500**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **30**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

replace damaged VFT

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT19**
MATERIAL DESCRIPTION: **9"x9" Black w/ White Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Lunchroom Storage, & Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT19**

MATERIAL DESCRIPTION: **9"x9" Black w/ White Streaks VFT**

MATERIAL LOCATION: **Lunchroom Storage, & Engineer's Office - 1931 Bldg.**

MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT20**
MATERIAL DESCRIPTION: **9"x9" Maroon w/ White Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **5 Damaged or significantly damaged friable misc. ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **5. ACBM with potential for significant damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Lunchroom Storage, & Engineer's Office; Gym III 361 mezzanine locker room - 1931 Bldg.**

MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **10** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT20**

MATERIAL DESCRIPTION: **9"x9" Maroon w/ White Streaks VFT**

MATERIAL LOCATION: **Lunchroom Storage, & Engineer's Office; Gym III 361 mezzanine locker room - 1931 Bldg.**

MATERIAL QUANTITY: **1500**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **10**

DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

replace damaged VFT

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT21**
MATERIAL DESCRIPTION: **12"x12" Green w/ White Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Engineers Locker Room - 1931 Bldg.**
MATERIAL QUANTITY: **200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT21**
MATERIAL DESCRIPTION: **12"x12" Green w/ White Streaks VFT**
MATERIAL LOCATION: **Engineers Locker Room - 1931 Bldg.**
MATERIAL QUANTITY: **200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT22**
MATERIAL DESCRIPTION: **12"x12" Gray w/ White & Brown Specks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Girl's Locker Room Office, Shower Office, Storage, Laundry, 439, 431, 438, 340 - 1931 Bldg.**

MATERIAL QUANTITY: **2737** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT22**
MATERIAL DESCRIPTION: **12"x12" Gray w/ White & Brown Specks VFT**
MATERIAL LOCATION: **Girl's Locker Room Office, Shower Office, Storage, Laundry, 439, 431, 438, 340 - 1931 Bldg.**
MATERIAL QUANTITY: **2737** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT23**
MATERIAL DESCRIPTION: **6"x6" Black VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Library Loft (balcony) - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT23**
MATERIAL DESCRIPTION: **6"x6" Black VFT**
MATERIAL LOCATION: **Library Loft (balcony) - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT29**
MATERIAL DESCRIPTION: **12" x 12" White w/Tan Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT29**
MATERIAL DESCRIPTION: **12" x 12" White w/Tan Streaks VFT**
MATERIAL LOCATION: **Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT30**
MATERIAL DESCRIPTION: **12" x 12" Pink VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 146 - 1931 Bldg.**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT30**
MATERIAL DESCRIPTION: **12" x 12" Pink VFT**
MATERIAL LOCATION: **Room 146 - 1931 Bldg.**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT4**
MATERIAL DESCRIPTION: **12"x12" Beige w/ Brown & White Specks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Corridors all floors, 441B, 435, 245, 125 work room, 315, 302A, 238, 236, Library, Auditorium, Men and Women toilets - 1931 Bldg.**

MATERIAL QUANTITY: **44600** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT4**
MATERIAL DESCRIPTION: **12"x12" Beige w/ Brown & White Specks VFT**
MATERIAL LOCATION: **Corridors all floors, 441B, 435, 245, 125 work room, 315, 302A, 238, 236, Library, Auditorium, Men and Women toilets - 1931 Bldg.**
MATERIAL QUANTITY: **44600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT5**
MATERIAL DESCRIPTION: **9"x9" Peach w/ Cream Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Vaults in rooms 131, 435, 438, 439, 217, 221, 241, 302A - 1931 Bldg.**
MATERIAL QUANTITY: **5200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT5**
MATERIAL DESCRIPTION: **9"x9" Peach w/ Cream Streaks VFT**
MATERIAL LOCATION: **Vaults in rooms 131, 435, 438, 439, 217, 221, 241, 302A - 1931 Bldg.**
MATERIAL QUANTITY: **5200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT6**
MATERIAL DESCRIPTION: **6"x6" White VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Library Loft (balcony) - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT6**
MATERIAL DESCRIPTION: **6"x6" White VFT**
MATERIAL LOCATION: **Library Loft (balcony) - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT7**
MATERIAL DESCRIPTION: **12"x12" Green VFT**
HISTORICAL AHERA DAMAGE CATEGORY **4 Damaged or significantly damaged friable misc. ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **4. Damaged or significantly damaged friable misc. ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Driver's Education Building room 199 simulator room - 1975 Bldg.**
MATERIAL QUANTITY: **1884** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **100** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT7**
MATERIAL DESCRIPTION: **12"x12" Green VFT**
MATERIAL LOCATION: **Driver's Education Building room 199 simulator room - 1975 Bldg.**
MATERIAL QUANTITY: **1884** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **100** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

replace damaged VFT

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT8**
MATERIAL DESCRIPTION: **12"x12" Gray w/ White Streaks VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 144 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT8**
MATERIAL DESCRIPTION: **12"x12" Gray w/ White Streaks VFT**
MATERIAL LOCATION: **Room 144 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **FT9**
MATERIAL DESCRIPTION: **12"x12" Sand VFT**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 447, 116 (not observed in 145, 143) - 1931 Bldg.**
MATERIAL QUANTITY: **3000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **FT9**
MATERIAL DESCRIPTION: **12"x12" Sand VFT**
MATERIAL LOCATION: **Room 447, 116 (not observed in 145, 143) - 1931 Bldg.**
MATERIAL QUANTITY: **3000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **GG**
MATERIAL DESCRIPTION: **Interior Window Caulk**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Throughout - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **GG**

MATERIAL DESCRIPTION: **Interior Window Caulk**

MATERIAL LOCATION: **Throughout - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **HH**
MATERIAL DESCRIPTION: **Exterior Window Caulk**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Throughout - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **HH**

MATERIAL DESCRIPTION: **Exterior Window Caulk**

MATERIAL LOCATION: **Throughout - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **I**
MATERIAL DESCRIPTION: **MJP E/F/V on Fiberglass Pipe Insulation**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Boiler Room, Bathroom Pipe Chases, Janitors Closets - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **I**

MATERIAL DESCRIPTION: **MJP E/F/V on Fiberglass Pipe Insulation**

MATERIAL LOCATION: **Boiler Room, Bathroom Pipe Chases, Janitors Closets - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **II**
MATERIAL DESCRIPTION: **MJP E/F/V on Fiberglass Pipe Insulation**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Janitors Closet, Bathroom Pipe Chases - 1975 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **II**

MATERIAL DESCRIPTION: **MJP E/F/V on Fiberglass Pipe Insulation**

MATERIAL LOCATION: **Janitors Closet, Bathroom Pipe Chases - 1975 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **JJ**
MATERIAL DESCRIPTION: **2'x4' White Ceiling Tile**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Drivers Education Building - 1975 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **JJ**

MATERIAL DESCRIPTION: **2'x4' White Ceiling Tile**

MATERIAL LOCATION: **Drivers Education Building - 1975 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **KK**
MATERIAL DESCRIPTION: **Tan Rubber Flooring**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Old Dishwasher Room - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **KK**

MATERIAL DESCRIPTION: **Tan Rubber Flooring**

MATERIAL LOCATION: **Old Dishwasher Room - 1931 Bldg.**

MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **L8**
MATERIAL DESCRIPTION: **Brown Linoleum - ABATED**
HISTORICAL AHERA DAMAGE CATEGORY **7**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Room 124, 128, 133 - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **L8**

MATERIAL DESCRIPTION: **Brown Linoleum - ABATED**

MATERIAL LOCATION: **Room 124, 128, 133 - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **L9**
MATERIAL DESCRIPTION: **Green & White Linoleum**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Stage Crew Office - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **L9**

MATERIAL DESCRIPTION: **Green & White Linoleum**

MATERIAL LOCATION: **Stage Crew Office - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **LM10**
MATERIAL DESCRIPTION: **Brown Linoleum Mastic - ABATED**
HISTORICAL AHERA DAMAGE CATEGORY **7**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **Low**

MATERIAL LOCATION: **Room 128 - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **LM10**

MATERIAL DESCRIPTION: **Brown Linoleum Mastic - ABATED**

MATERIAL LOCATION: **Room 128 - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **LM11**
MATERIAL DESCRIPTION: **Green & White Linoleum Mastic**
HISTORICAL AHERA DAMAGE CATEGORY
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **No ACBM** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be .

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Stage Crew Office - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **LM11**

MATERIAL DESCRIPTION: **Green & White Linoleum Mastic**

MATERIAL LOCATION: **Stage Crew Office - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M10**
MATERIAL DESCRIPTION: **9"x9" Peach w/ cream streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Vaults in rooms 435, 438, 439, 217, 221, 241 - 1931 Bldg.**
MATERIAL QUANTITY: **4800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M10**
MATERIAL DESCRIPTION: **9"x9" Peach w/ cream streaks VFT Mastic**
MATERIAL LOCATION: **Vaults in rooms 435, 438, 439, 217, 221, 241 - 1931 Bldg.**
MATERIAL QUANTITY: **4800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M11**
MATERIAL DESCRIPTION: **6"x6" White VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Library Loft (balcony) - 1931 Bldg.**

MATERIAL QUANTITY: **500**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M11**
MATERIAL DESCRIPTION: **6"x6" White VFT Mastic**
MATERIAL LOCATION: **Library Loft (balcony) - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M12**
MATERIAL DESCRIPTION: **12"x12" Green VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Driver's Education Building - 1975 Bldg.**
MATERIAL QUANTITY: **5000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M12**
MATERIAL DESCRIPTION: **12"x12" Green VFT Mastic**
MATERIAL LOCATION: **Driver's Education Building - 1975 Bldg.**
MATERIAL QUANTITY: **5000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M13**
MATERIAL DESCRIPTION: **12"x12" Gray w/ White Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 144 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M13**
MATERIAL DESCRIPTION: **12"x12" Gray w/ White Streaks VFT Mastic**
MATERIAL LOCATION: **Room 144 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M14**
MATERIAL DESCRIPTION: **12"x12" Sand VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 447, 116 (not observed in 145, 143) - 1931 Bldg.**
MATERIAL QUANTITY: **5150** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M14**
MATERIAL DESCRIPTION: **12"x12" Sand VFT Mastic**
MATERIAL LOCATION: **Rooms 447, 116 (not observed in 145, 143) - 1931 Bldg.**
MATERIAL QUANTITY: **5150** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M15**
MATERIAL DESCRIPTION: **12"x12" White w/ Tan Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 443 - 1931 Bldg.**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M15**
MATERIAL DESCRIPTION: **12"x12" White w/ Tan Streaks VFT Mastic**
MATERIAL LOCATION: **Room 443 - 1931 Bldg.**
MATERIAL QUANTITY: **1200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M16**
MATERIAL DESCRIPTION: **12"x12" Dark Brown w/ Black Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Corridors & Auditorium - 1931 Bldg.**
MATERIAL QUANTITY: **16270** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M16**
MATERIAL DESCRIPTION: **12"x12" Dark Brown w/ Black Streaks VFT Mastic**
MATERIAL LOCATION: **Corridors & Auditorium - 1931 Bldg.**
MATERIAL QUANTITY: **16270** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M17**
MATERIAL DESCRIPTION: **12"x12" Peach VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 203, 132 -1931 Bldg.**
MATERIAL QUANTITY: **1450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M17**
MATERIAL DESCRIPTION: **12"x12" Peach VFT Mastic**
MATERIAL LOCATION: **Rooms 203, 132 -1931 Bldg.**
MATERIAL QUANTITY: **1450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M18**
MATERIAL DESCRIPTION: **12"x12" Off White w/ Brown Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 335, 220 - 1931 Bldg.**
MATERIAL QUANTITY: **1600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M18**
MATERIAL DESCRIPTION: **12"x12" Off White w/ Brown Streaks VFT Mastic**
MATERIAL LOCATION: **Room 335, 220 - 1931 Bldg.**
MATERIAL QUANTITY: **1600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M19**
MATERIAL DESCRIPTION: **9"x9" Off White w/ Gray Streaks VFT Mastic - ABATED**
HISTORICAL AHERA DAMAGE CATEGORY **7**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE:

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Lunchroom - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M19**

MATERIAL DESCRIPTION: **9"x9" Off White w/ Gray Streaks VFT Mastic - ABATED**

MATERIAL LOCATION: **Lunchroom - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M20**
MATERIAL DESCRIPTION: **9"x9" Green VFT Mastic - ABATED**
HISTORICAL AHERA DAMAGE CATEGORY **7**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION:
ASBESTOS TYPE: **Abated** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:

MATERIAL LOCATION: **Lunchroom - 1931 Bldg.**

MATERIAL QUANTITY: MATERIAL UNITS:

DAMAGE QUANTITY: DAMAGE UNITS:

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M20**

MATERIAL DESCRIPTION: **9"x9" Green VFT Mastic - ABATED**

MATERIAL LOCATION: **Lunchroom - 1931 Bldg.**

MATERIAL QUANTITY:

MATERIAL UNITS:

DAMAGE QUANTITY:

DAMAGE UNITS:

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M21**
MATERIAL DESCRIPTION: **9"x9" Beige w/ Brown Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **(Serving Area - ABATED) Room 134 - 1931 Bldg.**
MATERIAL QUANTITY: **2000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M21**
MATERIAL DESCRIPTION: **9"x9" Beige w/ Brown Streaks VFT Mastic**
MATERIAL LOCATION: **(Serving Area - ABATED) Room 134 - 1931 Bldg.**
MATERIAL QUANTITY: **2000** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M22**
MATERIAL DESCRIPTION: **12"x12" White w/ Brown Specks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Kitchen - 1931 Bldg.**
MATERIAL QUANTITY: **650** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M22**
MATERIAL DESCRIPTION: **12"x12" White w/ Brown Specks VFT Mastic**
MATERIAL LOCATION: **Kitchen - 1931 Bldg.**
MATERIAL QUANTITY: **650** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M23**
MATERIAL DESCRIPTION: **12"x12" Beige w/ Wavy Brown VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Kitchen - 1931 Bldg.**
MATERIAL QUANTITY: **3500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M23**
MATERIAL DESCRIPTION: **12"x12" Beige w/ Wavy Brown VFT Mastic**
MATERIAL LOCATION: **Kitchen - 1931 Bldg.**
MATERIAL QUANTITY: **3500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M24**
MATERIAL DESCRIPTION: **9"x9" Black w/ White Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Lunchroom Storage & Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M24**
MATERIAL DESCRIPTION: **9"x9" Black w/ White Streaks VFT Mastic**
MATERIAL LOCATION: **Lunchroom Storage & Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M25**
MATERIAL DESCRIPTION: **9"x9" Maroon w/ White Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Lunchroom Storage & Engineer's Offices; Gym III 361 Mezzanine locker room - 1931 Bldg.**

MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M25**
MATERIAL DESCRIPTION: **9"x9" Maroon w/ White Streaks VFT Mastic**
MATERIAL LOCATION: **Lunchroom Storage & Engineer's Offices; Gym III 361 Mezzanine locker room - 1931 Bldg.**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M26**
MATERIAL DESCRIPTION: **12"x12" Green w/ White Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Engineers Locker Room - 1931 Bldg.**
MATERIAL QUANTITY: **200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M26**
MATERIAL DESCRIPTION: **12"x12" Green w/ White Streaks VFT Mastic**
MATERIAL LOCATION: **Engineers Locker Room - 1931 Bldg.**
MATERIAL QUANTITY: **200** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M27**
MATERIAL DESCRIPTION: **12"x12" Gray w/ White & Brown Specks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Girls' Locker Room & Office, Shower Office, Storage & Laundry, Rooms 439, 431, 438, 340 - 1931 Bldg.**

MATERIAL QUANTITY: **2737**

MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0**

DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M27**
MATERIAL DESCRIPTION: **12"x12" Gray w/ White & Brown Specks VFT Mastic**
MATERIAL LOCATION: **Girls' Locker Room & Office, Shower Office, Storage & Laundry, Rooms 439, 431, 438, 340 - 1931 Bldg.**
MATERIAL QUANTITY: **2737** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M28**
MATERIAL DESCRIPTION: **6"x6" Black VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Library Loft (balcony) - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M28**
MATERIAL DESCRIPTION: **6"x6" Black VFT Mastic**
MATERIAL LOCATION: **Library Loft (balcony) - 1931 Bldg.**
MATERIAL QUANTITY: **500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M29**
MATERIAL DESCRIPTION: **12" x 12" White w/Tan Streaks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M29**
MATERIAL DESCRIPTION: **12" x 12" White w/Tan Streaks VFT Mastic**
MATERIAL LOCATION: **Engineer's Office - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M30**
MATERIAL DESCRIPTION: **12" x 12" Pink VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Room 146 - 1931 Bldg.**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M30**
MATERIAL DESCRIPTION: **12" x 12" Pink VFT Mastic**
MATERIAL LOCATION: **Room 146 - 1931 Bldg.**
MATERIAL QUANTITY: **1500** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M31**
MATERIAL DESCRIPTION: **Carpet Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Rooms 130, 210, 235, 330, 205, 212, 213 - 1931 Bldg.**
MATERIAL QUANTITY: **2400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M31**
MATERIAL DESCRIPTION: **Carpet Mastic**
MATERIAL LOCATION: **Rooms 130, 210, 235, 330, 205, 212, 213 - 1931 Bldg.**
MATERIAL QUANTITY: **2400** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **M9**
MATERIAL DESCRIPTION: **12"x12" Beige w/ Brown & White Specks VFT Mastic**
HISTORICAL AHERA DAMAGE CATEGORY **6 ACBM with the potential for damage**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **No**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**

MATERIAL LOCATION: **Corridors all floors, 441B, 435, 245, 125 work room, 315, 302A, 238, 236, Library auditorium men & women toilets - 1931 Bldg.**

MATERIAL QUANTITY: **44600** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **M9**
MATERIAL DESCRIPTION: **12"x12" Beige w/ Brown & White Specks VFT Mastic**
MATERIAL LOCATION: **Corridors all floors, 441B, 435, 245, 125 work room, 315, 302A, 238, 236, Library auditorium men & women toilets - 1931 Bldg.**
MATERIAL QUANTITY: **44600** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA: **43**
MATERIAL DESCRIPTION: **12" x 12" White w/ Blue & Red Specks VFT**
MATERIAL LOCATION: **Room 146 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
MATERIAL CATEGORY: **MISC** FRIABLE:
ASBESTOS TYPE: **Assumed**
DISTURBANCE POTENTIAL: **LOW** CONDITION:
AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
ACCESSIBILITY: **Within Reach** DAMAGE REASON:
DAMAGE QUANTITY: **0** DAMAGE REASON:
DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **43**

MATERIAL DESCRIPTION: **12" x 12" White w/ Blue & Red Specks VFT**

MATERIAL LOCATION: **Room 146 - 1931 Bldg.**

MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME:	Chicago Public Schools	UNIT NUMBER: 46221	BUILDING ID: 1440
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	David Avila
SCHOOL NAME:	Lane Tech High School	INSPECTION DATE:	10/3/2019
ADDRESS:	2501 W. Addison	IDPH LICENSE NO:	100-11093

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA:	48		
MATERIAL DESCRIPTION:	Blue Linolium Mastic		
MATERIAL LOCATION:	Library Entrance - 1931 Bldg.		
MATERIAL QUANTITY:	40	MATERIAL UNITS:	SF
MATERIAL CATEGORY:	MISC	FRIABLE:	
ASBESTOS TYPE:	Assumed		
DISTURBANCE POTENTIAL:	LOW	CONDITION:	
AHERA DAMAGE CATEGORY:	6 ACBM with the potential for damage		
ACCESSIBILITY:	Within Reach	DAMAGE REASON:	
		DAMAGE REASON:	
DAMAGE QUANTITY:	0	DAMAGE REASON:	
		DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **48**
MATERIAL DESCRIPTION: **Blue Linolum Mastic**
MATERIAL LOCATION: **Library Entrance - 1931 Bldg.**
MATERIAL QUANTITY: **40** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____ Date: 10/25/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA: **44**

MATERIAL DESCRIPTION: **12" x 12" White w/ Blue & Red Specks VFT Mastic**

MATERIAL LOCATION: **Room 146 - 1931 Bldg.**

MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**

MATERIAL CATEGORY: **MISC** FRIABLE:

ASBESTOS TYPE: **Assumed**

DISTURBANCE POTENTIAL: **LOW** CONDITION:

AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**

ACCESSIBILITY: **Within Reach** DAMAGE REASON:
DAMAGE REASON:
DAMAGE REASON:

DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

COMMENTS:

Inspector's Signature: _____

Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **44**
MATERIAL DESCRIPTION: **12" x 12" White w/ Blue & Red Specks VFT Mastic**
MATERIAL LOCATION: **Room 146 - 1931 Bldg.**
MATERIAL QUANTITY: **800** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA: **47**
MATERIAL DESCRIPTION: **Blue Linoleum**
MATERIAL LOCATION: **Library Entrance - 1931 Bldg.**
MATERIAL QUANTITY: **40** MATERIAL UNITS: **SF**
MATERIAL CATEGORY: **MISC** FRIABLE:
ASBESTOS TYPE: **Assumed**
DISTURBANCE POTENTIAL: **LOW** CONDITION:
AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
ACCESSIBILITY: **Within Reach** DAMAGE REASON:
DAMAGE QUANTITY: **0** DAMAGE REASON:
DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **47**
MATERIAL DESCRIPTION: **Blue Linoleum**
MATERIAL LOCATION: **Library Entrance - 1931 Bldg.**
MATERIAL QUANTITY: **40** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____ Date: **10/25/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA: **45**
MATERIAL DESCRIPTION: **Yellow Linoleum**
MATERIAL LOCATION: **Library Entrance - 1931 Bldg.**
MATERIAL QUANTITY: **100** MATERIAL UNITS: **SF**
MATERIAL CATEGORY: **MISC** FRIABLE:
ASBESTOS TYPE: **Assumed**
DISTURBANCE POTENTIAL: **LOW** CONDITION:
AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
ACCESSIBILITY: **Within Reach** DAMAGE REASON:
DAMAGE QUANTITY: **0** DAMAGE REASON:
DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: **10/03/2019**

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **45**
MATERIAL DESCRIPTION: **Yellow Linoleum**
MATERIAL LOCATION: **Library Entrance - 1931 Bldg.**
MATERIAL QUANTITY: **100** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____ Date: 10/25/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (New Homogeneous Area)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUIDLING ID: **1440**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **David Avila**
SCHOOL NAME: **Lane Tech High School** INSPECTION DATE: **10/3/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

INFORMATION FROM CURRENT INSPECTION

HOMOGENEOUS AREA: **46**
MATERIAL DESCRIPTION: **Yellow Linoleum Mastic**
MATERIAL LOCATION: **Library Entrance - 1931 Bldg.**
MATERIAL QUANTITY: **100** MATERIAL UNITS: **SF**
MATERIAL CATEGORY: **MISC** FRIABLE:
ASBESTOS TYPE: **Assumed**
DISTURBANCE POTENTIAL: **LOW** CONDITION:
AHERA DAMAGE CATEGORY: **6 ACBM with the potential for damage**
ACCESSIBILITY: **Within Reach** DAMAGE REASON:
DAMAGE QUANTITY: **0** DAMAGE REASON:
DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: 10/03/2019

Chicago Public Schools

GSG-Probe Consulting, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **46221** BUILDING ID: **1440**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Arturo Saenz**
SCHOOL NAME: **Lane Tech High School** REVIEW DATE: **10/25/2019**
ADDRESS: **2501 W. Addison** IDPH LICENSE NO: **100-11093**

HOMOGENEOUS AREA: **46**
MATERIAL DESCRIPTION: **Yellow Linoleum Mastic**
MATERIAL LOCATION: **Library Entrance - 1931 Bldg.**
MATERIAL QUANTITY: **100** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

COMMENTS:

Management Planner's Signature: _____ Date: 10/25/2019

APPENDIX B

Inspector and Management Planner Licenses

CERTIFICATE OF ACHIEVEMENT ASBESTOS ABATEMENT

Accredited by the Illinois Department of Public Health

This is to certify that DAVID AVILA
has completed the ASBESTOS INSPECTOR'S REFRESHER course and successfully passed the
examination on 02/13/2016 with a minimum score of 70% or better. Training was in accordance
with U.S. E.P.A. 40 CFR 763 Subpart E, Appendix C, Asbestos Containing Materials in Schools:
Model Accreditation Plan, TSCA II, Authorized by both AHERA & ASHARA.

02/13/2016

Course Dates:

02/13/2017

Expires:

1602BTR08

Certificate Number:



PUBLIC HEALTH & SAFETY inc.

Environmental and Occupational Services
105 S. Ashland Ave., Chicago, IL 60607

Director of Training
Nicholas J. Penoff
Doctor of Public Health

Phone: 312-491-0081

FORM # A-010B



525-535 West Jefferson Street • Springfield, Illinois 62761-0001 • www.dph.illinois.gov

DAVID AVILA
2942 W VAN BUREN ST
CHICAGO, IL 60612

5/9/2018


ASBESTOS PROFESSIONAL LICENSE ID NUMBER: 11093

Enclosed is your Asbestos Professional License. Please note the expiration date on the card and in the image depicted below.

COPY OF THE ASBESTOS PROFESSIONAL LICENSE

Front of License

Back of License

			ASBESTOS PROFESSIONAL LICENSE		ENDORSEMENTS	TC EXPIRES
ID NUMBER 100 - 11093	ISSUED 5/9/2018	EXPIRES 05/15/2019			INSPECTOR	2/10/2019
DAVID AVILA 2942 W VAN BUREN ST CHICAGO, IL 60612 Environmental Health					PROJECT MANAGER AIR SAMPLING PROFESSIONAL	9/16/2018
					Alteration of this license shall result in legal action This license issued under authority of the State of Illinois Department of Public Health This license is valid only when accompanied by a valid training course certificate.	

If you have any questions or need further assistance, contact the Asbestos Program at (217)782-3517 or fax (217)785-5897.

Our WEB address is: dph.illinois.gov/topics-services/environmental-health-protection/asbestos
EMAIL Address: dph.asbestos@illinois.gov

PROTECTING HEALTH, IMPROVING LIVES
Nationally Accredited by PHAB

CERTIFICATE OF ACHIEVEMENT ASBESTOS ABATEMENT

Accredited by the Illinois Department of Public Health

This is to certify that DAVID AVILA
has completed the ASBESTOS INSPECTOR'S REFRESHER course and successfully passed the
examination on 02/09/2019 with a minimum score of 70% or better. Training was in accordance
with U.S. E.P.A. 40 CFR 763 Subpart E, Appendix C, Asbestos Containing Materials in Schools:
Model Accreditation Plan, TSCA II, Authorized by both AHERA & ASHARA.

02/09/2019

Course Dates:

02/09/2020

Expires:

1902BIR05

Certificate Number:



Office: 312-491-0181
Fax: 312-421-2901

A handwritten signature in black ink, which appears to read "N Peneff".

Director of Training
Nicholas J. Peneff
Doctor of Public Health

Phone: 312-491-0081

FORM # A-010B



525-535 West Jefferson Street • Springfield, Illinois 62761-0001 • www.dph.illinois.gov

DAVID AVILA
2942 W VAN BUREN ST
CHICAGO, IL 60612

4/19/2019



ASBESTOS PROFESSIONAL LICENSE ID NUMBER: 11093

Enclosed is your Asbestos Professional License. Please note the expiration date on the card and in the image depicted below.

COPY OF THE ASBESTOS PROFESSIONAL LICENSE

Front of License

Back of License

FRONT OF LICENSE		BACK OF LICENSE	
 ILLINOIS DEPARTMENT OF PUBLIC HEALTH IDPH <small>PROTECTING HEALTH. IMPROVING LIVES.</small>	ASBESTOS PROFESSIONAL LICENSE	ENDORSEMENTS	TC EXPIRES
ID NUMBER 100 - 11093	ISSUED 4/19/2019	INSPECTOR	2/9/2020
DAVID AVILA 2942 W VAN BUREN ST CHICAGO, IL 60612 Environmental Health	EXPIRES 05/15/2020 	PROJECT MANAGER AIR SAMPLING PROFESSIONAL	9/15/2019
		Alteration of this license shall result in legal action This license issued under authority of the State of Illinois Department of Public Health This license is valid only when accompanied by a valid training course certificate.	

If you have any questions or need further assistance, contact the Asbestos Program at (217)782-3517 or fax (217)785-5897.

Our WEB address is: dph.illinois.gov/topics-services/environmental-health-protection/asbestos
EMAIL Address: dph.asbestos@illinois.gov

PROTECTING HEALTH, IMPROVING LIVES
Nationally Accredited by PHAB

2019



OCCUPATIONAL TRAINING & SUPPLY, INC.

7233 S. Adams Street ♦ Willowbrook, IL 60527 ♦ (630) 655-3900 ♦ www.otssafety.com

Asbestos Management Planner Refresher

Occupational Training & Supply, Inc. certifies that

Arturo Saenz

has successfully completed the Asbestos Management Planner Refresher course and has passed the competency exam with a minimum score of 70%. The course is accredited by the Illinois Department of Public Health and Indiana Department of Environmental Management for purposes of accreditation in accordance with EPA 40 CFR 763, Asbestos Hazard Emergency response Act (AHERA) and TSCA Title II.

Course Date: 2/28/2019

Exam Date: 2/28/2019

Expiration Date: 2/28/2020

Certificate Number: MPR1902280693

Kathy DeSalvo, Director



**ASBESTOS
PROFESSIONAL
LICENSE**

ID NUMBER	ISSUED	EXPIRES
100 - 04019	4/30/2019	05/15/2020

ARTURO SAENZ
2942 W VAN BUREN ST
CHICAGO, IL 60612
Environmental Health



ENDORSEMENTS	TC EXPIRES
---------------------	-------------------

INSPECTOR	2/28/2020
MANAGEMENT PLANNER	2/28/2020

AIR SAMPLING PROFESSIONAL

Alteration of this license shall result in legal action
This license issued under authority of the State of Illinois
Department of Public Health
This license is valid only when accompanied by a valid
training course certificate.

APPENDIX C

Laboratory Accreditations

APPENDIX D

Laboratory Results

APPENDIX E

Chain of Custody Forms

Three-Year Reinspection Key to Terms

	CODE	KEY
MATERIAL		
	ACBM	Asbestos Containing Building Materials
MATERIAL CATEGORY		
	MISC	Miscellaneous
	SURF	Surfacing
	TSI	Thermal System Insulation
MATERIAL UNITS		
	LF	Linear Feet
	SF	Square Feet
	CF	Cubic Feet
DAMAGE TYPE		
	Loc	Localized
	Dist	Distributed