

## **Facility Assessment Detail**

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About\_CPS/Policies\_and\_guidelines/Pages/facilitystandards.aspx.

## **Condition Rankings and Descriptions**

- Rank 7: The item/system is new or in good condition and no work is required.
- Rank 6: The item/system requires general cleaning and/or routine maintenance.
- Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.1

## **Definitions**

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

**Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

**Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

**Building: Main** 

Category: EXTERIOR

| Group    | Sub Group | Item                                   | Location   | Rank | Quantity | Unit | Cost Reason |
|----------|-----------|--|--|------|----------|------|-------------|
| Canopy   |           | Concrete/ Stucco Canopy                | Underside of Bridge at Boiler Room                   | 6    | 350      | SF   | \$9,910     |
| Chimney  |           | Brick Chimney - Concrete/ Mortar Liner | Boiler Wing- North                                   | 7    | 100      | LF   | \$0         |
| Doors    |           | Exterior FRP Door                      | Entire Building                                      | 7    | 57       | EA   | \$0         |
| Doors    |           | Exterior FRP Door                      | East Elevation at<br>Lunchroom and West<br>Entrances | 5    | 8        | EA   | \$14,701    |
| Doors    |           | Exterior Steel Door                    | Entire Building                                      | 6    | 8        | EA   | \$2,643     |
| Doors    |           | Overhead Rolling / Garage Door         | Boiler House   | 7    | 1        | EA   | \$0         |
| Doors    |           | Side Lite                              | at Greenhouse  | 7    | 2        | EΑ   | \$0         |
| Doors    |           | Transom Lite                           | Entire Building                                      | 7    | 33       | EA   | \$0         |
| Entrance |           | Concrete Exterior Stairs               | SW Entrance at Courtyard                             | 5    | 80       | LF   | \$25,740    |
| Entrance |           | Concrete Exterior Stairs               | Entire Building                                      | 7    | 78       | LF   | \$0         |
| Entrance |           | Concrete Exterior Stairs               | East Access to Basement                              | 5    | 72       | LF   | \$23,166    |
| Entrance |           | Concrete Ramp                          | Entire Building                                      | 7    | 147      | LF   | \$0         |





Building: Main Category: EXTERIOR

| Group          | Sub Group | Item                                      | Location                                       | Rank | Quantity | Unit | Cost      | Reason  |
|----------------|-----------|---|--|------|----------|------|-----------|---|
| Entrance       |           | Entrance Controls - Audio                 | North Entrance at Parking Lot                  | 6    | 1        | EA   | \$429     |   |
| Entrance       |           | Entrance Controls - Audio and Video       | Main and North Entrance                        | 7    | 2        | EA   | \$0       |   |
| Entrance       |           | Power Door Operator and Controls          | Main and North Entrance                        | 7    | 2        | EA   | \$0       |   |
| Entrance       |           | Ramp Handrails                            | SE Entrance at Courtyards                      | 6    | 12       | LF   | \$0       |   |
| Entrance       |           | Ramp Handrails                            | Main and North Entrances                       | 7    | 270      | LF   | \$0       |   |
| Entrance       |           | Stair Handrails                           | East Basement Entrance                         | 4    | 15       | LF   | \$2,407   | Loose handrail  |
| Entrance       |           | Stair Handrails                           | Main and North Entrances                       | 7    | 84       | LF   | \$0       |   |
| Entrance       |           | Stair Handrails                           | Entire Building                                | 6    | 304      | LF   | \$0       | refinish  |
| Entrance       |           | Stone Stairs                              | Entire Building                                | 5    | 1,283    | LF   | \$550,407 | all are being removed and reset                       |
| Entrance       |           | Stone Stairs                              | South and 2 West Entrances                     | 4    | 26       | LF   | \$22,308  | broken pieces   |
| Foundation     |           | Concrete Foundation                       | Entire Building                                | 7    | 3,215    | LF   | \$0       | seepage at numerous locations- currently under repair |
| Lighting       |           | Exterior Lights - Parapet or Roof Mounted | Roof   | 7    | 52       | EA   | \$0       |   |
| Lighting       |           | Exterior Lights - Wall Mounted            | Entire Building                                | 6    | 15       | EA   | \$3,218   |   |
| Lintels        |           | Lintels - Steel                           | Entire Building                                | 7    | 2,945    | LF   | \$0       |   |
| Lintels        |           | Lintels - Terra Cotta                     | Main Entrance                                  | 4    | 20       | LF   | \$15,730  | Cracked terra cotta                                   |
| Lintels        |           | Lintels - Terra Cotta                     | Entire Building                                | 7    | 117      | LF   | \$0       |   |
| Parapet        |           | Coping - Stone                            | Screen wall at East Access to base,emt         | 4    | 52       | LF   | \$13,742  | Displaced and spalled, CIP concrete coping            |
| Parapet        |           | Coping - Stone                            | Top of Light Wells at West and East Elevations | 5    | 50       | LF   | \$4,360   | broken/displaced                                      |
| Parapet        |           | Coping - Stone                            | Main Roof and Ramp Walls                       | 7    | 460      | LF   | \$0       |   |
| Parapet        |           | Coping - Terra Cotta                      | Entire Building                                | 7    | 4,098    | LF   | \$0       | numerous areas currently under repair                 |
| Parapet        |           | Parapet < 16" Height                      | Boiler House Roof                              | 7    | 260      | LF   | \$0       |   |
| Parapet        |           | Parapet > 30" Height                      | Entire Building                                | 7    | 2,996    | LF   | \$0       |   |
| Parapet        |           | Parapet 16" to 30" Height                 | Boiler. Main Roof, lunch<br>Roof               | 7    | 984      | LF   | \$0       |   |
| Roof System    |           | Exterior Downspouts                       | Entire Building                                | 7    | 116,600  | LF   | \$0       |   |
| Roof System    |           | Interior Downspouts                       | Entire Building                                | 7    | 3,650    | LF   | \$0       | all currently under repair                            |
| Roof System    |           | Modified Bitumen Roof                     | Main Roof                                      | 7    | 26,600   | SF   | \$0       |   |
| Roof System    |           | Modified Bitumen Roof                     | Entire Building                                | 7    | 90,000   | SF   | \$0       | currently being replaced                              |
| Roof System    |           | Roof Structure: Concrete                  | Roofs  | 7    | 116,600  | SF   | \$0       |   |
| Superstructure |           | Concrete                                  | Entire Building                                | 7    | 319,900  | SF   | \$0       |   |
| Walls          |           | Brick                                     | Entire Building                                | 7    | 106,600  | SF   | \$0       | 100% tuck pointing and repair/replacement             |





**Building: Main** 

Category: EXTERIOR

| Group   | Sub Group | Item                                    | Location  | Rank   | Quantity | Unit | Cost       | Reason   |
|---------|-----------|---|---|--------|----------|------|------------|--|
| Walls   |           | Brick                                   | Screen Wall at East Access to Basement          | 4      | 104      | SF   | \$7,852    |  |
| Walls   |           | Brick                                   | Cheek Walls at South Main<br>Entrance           | 5      | 20       | SF   | \$453      | step cracks                                    |
| Walls   |           | Prefabricated Metal Panel Wall          | Gym Roof- East Side                             | 7      | 594      | SF   | \$0        |  |
| Walls   |           | Terra Cotta                             | SW Door Base and Arch and Base of Main Entrance | 5      | 120      | SF   | \$30,030   | cracks   |
| Walls   |           | Terra Cotta                             | Entire Building                                 | 7      | 19,860   | SF   | \$0        | numerous areas at South currently under repair |
| Windows |           | Skylite - Glass Single-Pane             | Green House Glass at<br>Courtyard               | 4      | 852      | SF   | \$241,235  | some replacement sections are lexan            |
| Windows |           | Skylite - Glass Single-Pane             | Boiler House                                    | 4      | 144      | SF   | \$40,772   |  |
| Windows |           | Window - Guards wire guard              | Entire Building                                 | 7      | 11,450   | SF   | \$0        |  |
| Windows |           | Windows - Casement Aluminum Double-pane | Entire Building                                 | 7      | 31,400   | SF   | \$0        |  |
| Windows |           | Windows - Casement Steel                | West Elevation at<br>Lunchroom Wing             | 4      | 110      | SF   | \$30,107   | original window at green house connection      |
|         |           |   | EVTERIOR  | Cb. T. | 4-1      |      | ¢4 000 000 |  |

EXTERIOR Sub Total

\$1,039,209

**Building: Main** 

Category: ELECTRICAL

| Group            | Sub Group | Item  | Location                         | Rank | Quantity | Unit | Cost      | Reason                                 |
|------------------|-----------|---|----------------------------------|------|----------|------|-----------|--|
| Emergency System |           | Automatic Transfer switch                             | Central Basement Electrical Room | 4    | 1        | EA   | \$8,866   |  |
| Emergency System |           | Automatic Transfer switch                             | Basement                         | 7    | 1        | EΑ   | \$0       |  |
| Emergency System |           | Automatic Transfer switch                             | Boiler Electrical Room           | 7    | 1        | EΑ   | \$0       |  |
| Emergency System |           | Emergency A/C power - Auditorium and aisle lighting   | 1st Floor                        | 4    | 8,230    | SF   | \$57,079  | T8 installed                           |
| Emergency System |           | Emergency A/C power - Corridors and Stairs            | Entire Building                  | 4    | 41,346   | SF   | \$127,118 | T8 installed                           |
| Emergency System |           | Emergency A/C power - Gym and Lunch rooms             | 2nd Floor                        | 4    | 7,520    | SF   | \$13,442  | T8 installed                           |
| Emergency System |           | Emergency A/C power - Gym and Lunch rooms             | 2nd Floor                        | 4    | 9,585    | SF   | \$17,133  | T8 installed                           |
| Emergency System |           | Emergency A/C power - Gym and Lunch rooms             | 1st Floor                        | 4    | 10,830   | SF   | \$19,359  |  |
| Emergency System |           | Emergency A/C power - Students Toilets                | Entire Building                  | 4    | 3,243    | SF   | \$11,594  | T8 installed                           |
| Emergency System |           | Emergency Battery Packs - Corridors and Stairs        | Entire Building                  | 4    | 2        | EΑ   | \$1,081   |  |
| Emergency System |           | Emergency Battery Packs - Lunchroom and Gym           | Entire Building                  | 3    | 1        | EΑ   | \$541     |  |
| Emergency System |           | Emergency generator 150 KW -200 KW diesel -<br>Indoor | Basement                         | 2    | 1        | EA   | \$100,100 | Non operational. Battery charger shot. |
| Emergency System |           | Exit Signs - Auditorium                               | Entire Building                  | 6    | 15       | EΑ   | \$3,496   |  |
| Emergency System |           | Exit Signs - Corridors and Stairs                     | Entire Building                  | 6    | 82       | EΑ   | \$19,113  |  |
| Emergency System |           | Exit Signs - Lunchroom - Gym - multipurpose room      | s Entire Building                | 6    | 4        | EA   | \$932     |  |
| Emergency System |           | Exit Signs - Lunchroom - Gym - multipurpose room      | s Entire Building                | 6    | 5        | EA   | \$1,165   |  |





**Building: Main** 

Category: ELECTRICAL

| Group              | Sub Group | Item  | Location                         | Rank | Quantity | Unit | Cost        | Reason   |
|--------------------|-----------|---|----------------------------------|------|----------|------|-------------|--|
| Emergency System   |           | Exit Signs - Lunchroom - Gym - multipurpose room                  | s Entire Building                | 6    | 4        | EA   | \$932       |  |
| Emergency System   |           | Public Announcement System  | Entire Building                  | 6    | 319,900  | SF   | \$192,132   |  |
| Emergency System   |           | Security System - CCTV  | Entire Building                  | 3    | 319,900  | SF   | \$2,287,285 | 1st Floor system out. 2nd and 3rd missing cameras. |
| Main Service       |           | Main Electrical service - Live Front - 2000 to 3000 A 120/208/3PH | Boiler Electrical Room           | 5    | 1        | EA   | \$60,060    | and 5rd missing cameras.                           |
| Main Service       |           | Main Electrical service - Live Front - 2000 to 3000 A 120/208/3PH | Southeast Electrical Room        | 5    | 1        | EA   | \$60,060    |  |
| Main Service       |           | Main Electrical service - Live Front - 2000 to 3000 A 120/208/3PH | Central Basement Electrical Room | 5    | 1        | EA   | \$60,060    |  |
| Power Distribution |           | Lighting and power panels   | Basement                         | 7    | 1        | EA   | \$0         |  |
| Power Distribution |           | Lighting and power panels   | Boiler Room                      | 4    | 1        | EA   | \$5,434     |  |
| Power Distribution |           | Lighting and power panels   | Central Basement Electrical Room | 6    | 2        | EA   | \$1,430     |  |
| Power Distribution |           | Lighting and power panels   | Basement                         | 6    | 1        | EA   | \$715       |  |
| Power Distribution |           | Lighting and power panels   | Basement                         | 4    | 1        | EA   | \$5,434     |  |
| Power Distribution |           | Lighting and power panels   | Basement                         | 7    | 1        | EA   | \$0         |  |
| Power Distribution |           | Lighting and power panels   | Basement                         | 7    | 1        | EA   | \$0         |  |
| Power Distribution |           | Lighting and power panels   | Southeast Electrical Room        | 6    | 1        | EA   | \$715       |  |
| Power Distribution |           | Lighting and power panels   | Main Center Roof<br>Penthouse    | 6    | 1        | EA   | \$715       |  |
| Power Distribution |           | Lighting and power panels   | Entire Building                  | 7    | 12       | EA   | \$0         |  |
| Power Distribution |           | Lighting and power panels   | Entire Building                  | 6    | 21       | EA   | \$15,015    |  |
| Power Distribution |           | Lighting and power panels   | Entire Building                  | 4    | 2        | EA   | \$10,868    |  |
| Power Distribution |           | Lighting and power panels   | Boiler Electrical Room           | 6    | 3        | EA   | \$2,145     |  |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Basement                         | 6    | 1        | EA   | \$1,430     |  |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Boiler Electrical Room           | 7    | 1        | EA   | \$0         |  |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Basement                         | 6    | 1        | EA   | \$1,430     |  |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Boiler Room                      | 4    | 1        | EA   | \$12,155    |  |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Southeast Electrical Room        | 7    | 1        | EA   | \$0         |  |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Basement                         | 6    | 1        | EA   | \$1,430     |  |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Basement                         | 7    | 1        | EA   | \$0         |  |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Basement                         | 4    | 1        | EA   | \$12,155    |  |
| Power Distribution |           | Main distribution panels above 600 amp                            | Boiler Room                      | 7    | 1        | EA   | \$0         |  |
| Power Distribution |           | Main distribution panels above 600 amp                            | Basement                         | 6    | 1        | EA   | \$2,145     |  |
| Power Distribution |           | Main distribution panels less than 400 amp                        | Main Center Roof<br>Penthouse    | 4    | 1        | EA   | \$6,578     |  |
| Power Distribution |           | Main distribution panels less than 400 amp                        | Boiler Electrical Room           | 6    | 1        | EA   | \$1,216     |  |
| Power Distribution |           | Main distribution panels less than 400 amp                        | Central Basement Electrical Room | 6    | 1        | EA   | \$1,216     |  |





**Building: Main** 

Category: ELECTRICAL

Group Sub Group Item Location Rank Quantity Unit Cost Reason

ELECTRICAL Sub Total

\$3,123,774

**Building: Main** 

Category: FIRE PROTECTION

| Group      | Sub Group | Item              | Location               | Rank   | Quantity | Unit | Cost | Reason |
|------------|-----------|-------------------|------------------------|--------|----------|------|------|--------|
| Fire Alarm |           | Fire Alarm System | Boiler Electrical Room | 7      | 319,900  | SF   | \$0  |        |
|            |           |                   | FIRE PROTECTION        | Sub To | tal      |      | \$0  |        |

**Building: Main** 

Category: MECHANICAL

| Group                | Sub Group | Item  | Location                                    | Rank | Quantity | Unit | Cost Reason |
|----------------------|-----------|---|---|------|----------|------|-------------|
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit   | Basement- to Well up to central roof        | 5    | 1        | EA   | \$16,016    |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit   | Side Floor North Wall From Well at Basement | 4    | 1        | EA   | \$26,169    |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit   | Basement to Well Up to<br>Lunchroom Roof    | 5    | 1        | EA   | \$16,016    |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit   | Basement up to Central                      | 5    | 1        | EA   | \$16,016    |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit   | Basement Well up to West Wing Roof          | 5    | 1        | EA   | \$16,016    |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit   | Basement up to west wing roof from well     | 5    | 1        | EA   | \$16,016    |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit   | Basement well up to west wing roof          | 5    | 1        | EA   | \$16,016    |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm                | West Wing AHU Air Tunnel                    | 5    | 1        | EA   | \$35,750    |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit - Steam above 35,000 cfm                    | Gymnasium                                   | 5    | 1        | EA   | \$57,200    |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit - Steam above 35,000 cfm                    | Basement                                    | 4    | 1        | EA   | \$164,450   |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit - Steam above 35,000 cfm                    | Basement                                    | 5    | 1        | EA   | \$57,200    |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit Auxiliaries -<br>Steam 15,001 to 25,000 cfm | West Wing AHU Air Tunnel                    | 5    | 1        | EA   | \$12,870    |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit Auxiliaries -<br>Steam above 35,000 cfm     | Basement                                    | 4    | 1        | EA   | \$44,330    |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit Auxiliaries -<br>Steam above 35,000 cfm     | Basement                                    | 4    | 1        | EA   | \$44,330    |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit Auxiliaries -<br>Steam above 35,000 cfm     | Basement                                    | 4    | 1        | EA   | \$44,330    |
| Air Handling Systems |           | Reheat Boxes With Steam Coils   | West Wing AHU Tunnel                        | 4    | 3        | EA   | \$31,317    |





**Building: Main** 

Category: MECHANICAL

| Group                | Sub Group | ltem  | Location                          | Rank | Quantity | Unit | Cost      | Reason |
|----------------------|-----------|---|-----------------------------------|------|----------|------|-----------|--------|
| Air Handling Systems |           | Reheat Boxes With Steam Coils   | Southeast Wing Central Air Tunnel | 5    | 13       | EA   | \$72,501  |        |
| Air Handling Systems |           | Reheat Boxes With Steam Coils   | Southwest Air Tunnel              | 5    | 12       | EA   | \$66,924  |        |
| Air Handling Systems |           | Return Duct Work - Indoor - Vertical Shaft and<br>Ducts                           | Entire Building                   | 5    | 700      | LF   | \$300,300 |        |
| Air Handling Systems |           | Single Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm               | Basement                          | 5    | 1        | EA   | \$28,600  |        |
| Air Handling Systems |           | Single Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm               | Basement                          | 4    | 1        | EA   | \$64,350  |        |
| Air Handling Systems |           | Single Zone Built Up Air Handling Unit - Steam above 35,000 cfm                   | Basement                          | 4    | 1        | EA   | \$107,250 |        |
| Air Handling Systems |           | Single Zone Built Up Air Handling Unit Auxiliaries - Steam above 35,000 cfm       | Basement                          | 5    | 1        | EA   | \$17,160  |        |
| Air Handling Systems |           | Single Zone Built Up Air Handling Unit Auxiliaries-<br>Steam 15,001 to 25,000 cfm | Basement                          | 4    | 1        | EA   | \$18,590  |        |
| Air Handling Systems |           | Single Zone Built Up Air Handling Unit Auxiliaries-<br>Steam 15,001 to 25,000 cfm | Basement                          | 5    | 1        | EA   | \$12,155  |        |
| Boiler Systems       |           | Boiler Assembly - Steam - Low Pressure Scotch<br>Marine Boiler 151 - 200 HP       | Boiler Room                       | 5    | 2        | EA   | \$137,280 |        |
| Boiler Systems       |           | Boiler Assembly - Steam - Low Pressure Scotch<br>Marine Boiler 76-100 HP          | Boiler Room                       | 5    | 1        | EA   | \$57,200  |        |
| Boiler Systems       |           | Boiler Auxiliary - Steam Boiler 151 - 200 HP                                      | Boiler Room                       | 5    | 2        | EA   | \$24,310  |        |
| Boiler Systems       |           | Boiler Auxiliary - Steam Boiler 76-100 HP   | Boiler Room                       | 5    | 1        | EA   | \$10,010  |        |
| Boiler Systems       |           | Combustion Dampers  | Boiler Room                       | 5    | 3        | EA   | \$4,719   |        |
| Boiler Systems       |           | Feed Water Pumps and Tank - Steam Boilers   | Boiler House Basement             | 5    | 1        | EA   | \$19,305  |        |
| Boiler Systems       |           | Gas Boosters  | Boiler Room                       | 5    | 3        | EA   | \$19,520  |        |
| Heating Devices      |           | Fin Tube Electric   | Entire Building                   | 7    | 80       | LF   | \$0       |        |
| Heating Devices      |           | Fin Tube Electric   | Entire Building                   | 6    | 342      | LF   | \$4,891   |        |
| Heating Devices      |           | Fin Tube Hot Water  | Entire Building                   | 6    | 10       | LF   | \$172     |        |
| Heating Devices      |           | Radiators - Steam   | Entire Building                   | 4    | 1        | EA   | \$1,401   |        |
| Heating Devices      |           | Radiators - Steam   | Entire Building                   | 6    | 31       | EA   | \$4,344   |        |
| Heating Devices      |           | Unit Heater - Gas   | Boiler Room                       | 6    | 3        | EA   | \$6,435   |        |
| Heating Devices      |           | Wall Heater - Electric  | Entire Building                   | 6    | 7        | EA   | \$721     |        |
| Heating Devices      |           | Wall Heater - Electric  | Entire Building                   | 5    | 10       | EA   | \$5,148   |        |
| Heating Devices      |           | Wall Heater - Electric  | Entire Building                   | 7    | 3        | EA   | \$0       |        |
| Mechanical Plumbing  |           | Condensate Assembly - Pumps and Tank  | Basement                          | 7    | 1        | EA   | \$0       |        |
| Mechanical Plumbing  |           | Condensate Assembly - Pumps and Tank  | Basement                          | 7    | 1        | EA   | \$0       |        |
| Mechanical Plumbing  |           | Condensate Assembly - Pumps and Tank  | Basement                          | 7    | 1        | EA   | \$0       |        |
| Mechanical Plumbing  |           | Condensate Assembly - Pumps and Tank  | Boiler Room                       | 7    | 1        | EA   | \$0       |        |
| Mechanical Plumbing  |           | Condensate Assembly - Pumps and Tank  | Gymnasium                         | 7    | 1        | EA   | \$0       |        |



**Building: Main** 

Category: MECHANICAL

| Mechanical Plumbing         Piping - Condensate - Steel or Galvanized         Entire Building         5         1,500         LF         \$149,64           Temperature Control         Piping - Steam - Steel or Galvanized         Entire Building         4         1,500         LF         \$179,64           Temperature Control         Phylind Penumatic/Direct Digital Control (DDC) system         Entire Building         6         319,900         SE         \$320,220           Temperature Control         Thermostats - Pneumatic         Entire Building         7         4         \$0.00         \$6,578           Temperature Control         Thermostats - Pneumatic         Entire Building         7         3.0         \$6         \$5,578           Temperature Control         Zone Dampers         Southwest Air Tunnel         6         3.0         \$5,577           Temperature Control         Zone Dampers         Southwest Wing AHU Air Tunnel         6         3.0         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         8         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         8         \$5,577           Temperature Control         Zone Dampers         Basement         5   | Group               | Sub Group | Item   | Location                 | Rank | Quantity | Unit | Cost      | Reason |
|---|---------------------|-----------|--|--------------------------|------|----------|------|-----------|--------|
| Temperature Control         Hybrid Pneumatic/Direct Digital Control (DDC) System         Entire Building         6         319,900         SF         \$320,220           Temperature Control         Thermostats - Pneumatic         Entire Building         4         10         EA         \$5,78           Temperature Control         Thermostats - Pneumatic         Entire Building         7         34         EA         \$6,578           Temperature Control         Zone Dampers         Basement         5         4         EA         \$1,487           Temperature Control         Zone Dampers         Southwest Air Tunnel         6         39         EA         \$5,577           Temperature Control         Zone Dampers         West Wing AHU Air Tunnel         6         4         \$4         \$6,572           Temperature Control         Zone Dampers         West Wing AHU Air Tunnel         6         4         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$5,577           Temperature Control         Zone Dampers         Basement         6         4         8         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$5,577 <td>Mechanical Plumbing</td> <td></td> <td>Piping - Condensate - Steel or Galvanized</td> <td>Entire Building</td> <td>5</td> <td>1,500</td> <td>LF</td> <td>\$48,799</td> <td></td>  | Mechanical Plumbing |           | Piping - Condensate - Steel or Galvanized      | Entire Building          | 5    | 1,500    | LF   | \$48,799  |        |
| Part   | Mechanical Plumbing |           | Piping - Steam - Steel or Galvanized           | Entire Building          | 4    | 1,500    | LF   | \$179,644 |        |
| Temperature Control         Thermostats - Pneumatic         Entire Building         4         10         EA         \$6,578           Temperature Control         Thermostats - Pneumatic         Entire Building         7         34         EA         \$0           Temperature Control         Zone Dampers         Southwest Air Tunnel         6         39         EA         \$5,577           Temperature Control         Zone Dampers         Gymasium         5         11         EA         \$4,090           Temperature Control         Zone Dampers         Gymasium         6         4         EA         \$5,577           Temperature Control         Zone Dampers         Gymasium         6         4         EA         \$5,577           Temperature Control         Zone Dampers         Southeast Wing Central Air Junel         6         4         EA         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$5,577           Unit Ventilation         Unit Ventilations - Steam         Entire Building         6         4         EA         \$6,292           Ventilation         Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm         Roof         5         7         EA         \$1,585  | Temperature Control |           |  | Entire Building          | 6    | 319,900  | SF   | \$320,220 |        |
| Temperature Control         Thermostats - Pneumatic         Entire Building         7         34         EA         \$0           Temperature Control         Zone Dampers         Basement         5         4         EA         \$1,487           Temperature Control         Zone Dampers         Southwest Air Tunnel         6         39         EA         \$5,577           Temperature Control         Zone Dampers         Gymnasium         6         4         EA         \$4,090           Temperature Control         Zone Dampers         West Wing AHU Air Tunnel         6         4         EA         \$5,272           Temperature Control         Zone Dampers         Basement         5         7         EA         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$2,603           Unit Ventilation         Exhaust Fan Indoor         Basement         5         7         EA         \$1,285           Ventilation         Exhaus  | Temperature Control |           | Thermostats - Pneumatic                        | Entire Building          | 6    | 50       | EA   | \$7,150   |        |
| Temperature Control         Zone Dampers         Basement         5         4         EA         \$1,487           Temperature Control         Zone Dampers         Southwest Air Tunnel         6         39         EA         \$5,577           Temperature Control         Zone Dampers         West Wing AHU Air Tunnel         6         4         EA         \$5,272           Temperature Control         Zone Dampers         Southeast Wing Central Air Tunnel         6         4         EA         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$5,677           Temperature Control         Zone Dampers         Basement         5         7         EA         \$2,603           Unit Ventilation         Unit Ventilations Status Fans - Roof Mounted 1,501 to 8,000 cfm         Main Center Roof         5         7         EA         \$1,859           Ventilation         Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm         Roof         5         7         EA         \$1,051           Ventilation         Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm         Roof         7         2  | Temperature Control |           | Thermostats - Pneumatic                        | Entire Building          | 4    | 10       | EA   | \$6,578   |        |
| Temperature Control         Zone Dampers         Southwest Air Tunnel         6         39         EA         \$5,577           Temperature Control         Zone Dampers         Gymnasium         5         11         EA         \$4,090           Temperature Control         Zone Dampers         West Wing AHU Air Tunnel         6         4         EA         \$572           Temperature Control         Zone Dampers         Southeast Wing Central Air Tunnel         6         4         EA         \$5,577           Temperature Control         Zone Dampers         Basement         5         7         EA         \$2,603           Temperature Control         Unit Ventilators - Steam         Entire Building         6         4         EA         \$6,292           Ventilation         Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm         Main Center Roof Penthouse         5         7         EA         \$1,859           Ventilation         Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm         Roof         7         2         EA         \$0           Ventilation         Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm         Roof         7         3         EA         \$429           Ventilation         Exhaust Fans - Roof Mounted 500 to 1,500 cfm         Roof         7   | Temperature Control |           | Thermostats - Pneumatic                        | Entire Building          | 7    | 34       | EA   | \$0       |        |
| Temperature Control Zone Dampers West Wing AHU Air Tunnel 6 4 6 4 EA \$5.72 Temperature Control Zone Dampers West Wing AHU Air Tunnel 6 4 3 9 EA \$5.77 Temperature Control Zone Dampers Southeast Wing Central Air Tunnel 6 3 9 EA \$5.577 Temperature Control Zone Dampers Southeast Wing Central Air Tunnel 5 7 EA \$5.577 Temperature Control Zone Dampers Basement 5 7 EA \$2.603 Unit Ventilation Unit Ventilators - Steam Entire Building 6 4 EA \$6.292 Ventilation Exhaust Fan - Indoor Roof Penthouse Penthouse Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 5 7 EA \$1.0511 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 EA \$4.000 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 EA \$4.000 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 EA \$4.000 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 EA \$4.000 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 EA \$4.000 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 EA \$4.000 Ventilation Lab Exhaust Hood Entire Building 7 EA \$6.578 Ventilation Lab Exhaust Hood Entire Building 7 EA \$6.578 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 EA \$6.578 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 EA \$6.000 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 EA \$6.000 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 EA \$6.000 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 EA \$6.000 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 EA \$6.000 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 EA \$6.000 Ventilation Entire Building 7 EA \$6.000 Ventilation EA \$6.000 Ve | Temperature Control |           | Zone Dampers                                   | Basement                 | 5    | 4        | EA   | \$1,487   |        |
| Temperature ControlZone DampersWest Wing AHU Air Tunnel64EA\$572Temperature ControlZone DampersSoutheast Wing Central Air Tunnel639EA\$5,577Temperature ControlZone DampersBasement57EA\$2,603Unit VentilationUnit Ventilators - SteamEntire Building64EA\$6,292VentilationExhaust Fan - IndoorRoof57EA\$1,859VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfm<br>PenthouseRoof57EA\$10,511VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfm<br>PenthouseRoof61EA\$0VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfm<br>PenthouseRoof72EA\$0VentilationExhaust Fans - Roof Mounted 5,501 to 8,000 cfm<br>PenthouseRoof73EA\$0VentilationExhaust Fans - Roof Mounted 5,500 cfm<br>PenthouseRoof73EA\$0VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfm<br>PenthouseRoof51EA\$1,287VentilationLab Exhaust HoodEntire Building32EA\$6,578VentilationLab Exhaust Hood - Kitchen or Culinary Arts<br>PenthouseEntire Building71EA\$26,684VentilationType I Exhaust Hood - Kitchen or Culinary Arts<br>PenthouseEntire Building71EA\$26,684 <t< td=""><td>Temperature Control</td><td></td><td>Zone Dampers</td><td>Southwest Air Tunnel</td><td>6</td><td>39</td><td>EA</td><td>\$5,577</td><td></td></t<>  | Temperature Control |           | Zone Dampers                                   | Southwest Air Tunnel     | 6    | 39       | EA   | \$5,577   |        |
| Temperature Control Zone Dampers Southeast Wing Central Air Tunnel 6 39 EA \$5,577 Tunnel Control Zone Dampers Basement 5 7 EA \$2,603 Unit Ventilation Unit Ventilators - Steam Entire Building 6 4 EA \$6,292 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 2 EA \$10,511 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 2 EA \$10,511 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 2 EA \$10,511 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 2 EA \$4 \$0 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 2 EA \$4 \$0 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 Exhaust Fans - Roof Mounted 500 to                          | Temperature Control |           | Zone Dampers                                   | Gymnasium                | 5    | 11       | EA   | \$4,090   |        |
| Tunnel Temperature Control Zone Dampers Zone Dampers Basement Solor Solor Unit Ventilation Unit Ventilators - Steam Unit Ventilators Steam Solor                                    | Temperature Control |           | Zone Dampers                                   | West Wing AHU Air Tunnel | 6    | 4        | EA   | \$572     |        |
| Unit Ventilation Unit Ventilators - Steam Entire Building 6 4 EA \$6,292  Ventilation Exhaust Fan - Indoor Roof Penthouse  Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof Roof Roof 7 EA \$10,511  Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 EA \$10,511  Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 EA \$10,511  Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 6 I EA \$429  Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 I EA \$1,287  Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 I EA \$1,287  Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 I EA \$1,287  Ventilation Lab Exhaust Hood Entire Building 8 EA \$65,780  Ventilation Lab Exhaust Hood Entire Building 7 I EA \$2,800  Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 I EA \$2,800  Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts Entire Building 7 I EA \$2,800  Ventilation Type I Exhaust Hood - Warming Kitchen Entire Building 7 I EA \$2,800  Ventilation Type I Exhaust Hood - Warming Kitchen Entire Building 7 I EA \$2,800  Ventilation Type I Exhaust Hood - Warming Kitchen Entire Building 7 I EA \$2,800   | Temperature Control |           | Zone Dampers                                   |                          | 6    | 39       | EA   | \$5,577   |        |
| VentilationExhaust Fan - IndoorMain Center Roof Penthouse51EA\$1,859VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfm<br>Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm<br>VentilationRoof57EA\$10,511VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfm<br>VentilationRoof72EA\$0VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfm<br>VentilationRoof73EA\$429VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfm<br>VentilationRoof73EA\$0VentilationExhaust HoodEntire Building51EA\$1,287VentilationLab Exhaust HoodEntire Building32EA\$6,578VentilationLab Exhaust HoodEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$26,884   | Temperature Control |           | Zone Dampers                                   | Basement                 | 5    | 7        | EA   | \$2,603   |        |
| PenthouseVentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof57EA\$10,511VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof72EA\$0VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof61EA\$429VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof73EA\$0VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof51EA\$1,287VentilationLab Exhaust HoodEntire Building32EA\$65,780VentilationLab Exhaust HoodEntire Building62EA\$6,578VentilationLab Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType I Exhaust Hood - Warming KitchenEntire Building71EA\$0  | Unit Ventilation    |           | Unit Ventilators - Steam                       | Entire Building          | 6    | 4        | EA   | \$6,292   |        |
| VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof72EA\$0VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof61EA\$429VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof73EA\$0VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof51EA\$1,287VentilationLab Exhaust HoodEntire Building32EA\$6,578VentilationLab Exhaust HoodEntire Building62EA\$6,578VentilationLab Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building31EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0  | Ventilation         |           | Exhaust Fan - Indoor                           |                          | 5    | 1        | EA   | \$1,859   |        |
| VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof61EA\$429VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof73EA\$0VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof51EA\$1,287VentilationLab Exhaust HoodEntire Building32EA\$65,780VentilationLab Exhaust HoodEntire Building62EA\$6,578VentilationLab Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0   | Ventilation         |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof                     | 5    | 7        | EA   | \$10,511  |        |
| VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof73EA\$0VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof51EA\$1,287VentilationLab Exhaust HoodEntire Building32EA\$65,780VentilationLab Exhaust HoodEntire Building62EA\$6,578VentilationLab Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building31EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0  | Ventilation         |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof                     | 7    | 2        | EA   | \$0       |        |
| VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof51EA\$1,287VentilationLab Exhaust HoodEntire Building32EA\$65,780VentilationLab Exhaust HoodEntire Building62EA\$6,578VentilationLab Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building31EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0   | Ventilation         |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof                     | 6    | 1        | EA   | \$429     |        |
| VentilationLab Exhaust HoodEntire Building32EA\$65,780VentilationLab Exhaust HoodEntire Building62EA\$6,578VentilationLab Exhaust HoodEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building31EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0  | Ventilation         |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm   | Roof                     | 7    | 3        | EA   | \$0       |        |
| VentilationLab Exhaust HoodEntire Building62EA\$6,578VentilationLab Exhaust HoodEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building31EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0  | Ventilation         |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm   | Roof                     | 5    | 1        | EA   | \$1,287   |        |
| VentilationLab Exhaust HoodEntire Building71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building31EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0   | Ventilation         |           | Lab Exhaust Hood                               | Entire Building          | 3    | 2        | EA   | \$65,780  |        |
| VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building31EA\$26,884VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0  | Ventilation         |           | Lab Exhaust Hood                               | Entire Building          | 6    | 2        | EA   | \$6,578   |        |
| VentilationType I Exhaust Hood - Kitchen or Culinary ArtsEntire Building71EA\$0VentilationType II Exhaust Hood - Warming KitchenEntire Building71EA\$0  | Ventilation         |           | Lab Exhaust Hood                               | Entire Building          | 7    | 1        | EA   | \$0       |        |
| Ventilation Type II Exhaust Hood - Warming Kitchen Entire Building 7 1 EA \$0   | Ventilation         |           | Type I Exhaust Hood - Kitchen or Culinary Arts | Entire Building          | 3    | 1        | EA   | \$26,884  |        |
|   | Ventilation         |           | Type I Exhaust Hood - Kitchen or Culinary Arts | Entire Building          | 7    | 1        | EA   | \$0       |        |
| Ventilation       Type II Exhaust Hood - Warming Kitchen       Entire Building       6       1       EA       \$930   | Ventilation         |           | Type II Exhaust Hood - Warming Kitchen         | Entire Building          | 7    | 1        | EA   | \$0       |        |
|   | Ventilation         |           | Type II Exhaust Hood - Warming Kitchen         | Entire Building          | 6    | 1        | EA   | \$930     |        |

MECHANICAL Sub Total

\$2,300,172

Building: Main Category: PLUMBING

| Group     | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost      | Reason |
|-----------|-----------|--|-----------------|------|----------|------|-----------|--------|
| Hot Water |           | Storage Tank more than 500 gallons                   | Boiler Room     | 6    | 1        | EA   | \$7,436   |        |
| Piping    |           | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 7    | 319,900  | SF   | \$0       |        |
| Piping    |           | Domestic Piping - Cold Water Risers                  | Entire Building | 4    | 319,900  | SF   | \$205,856 |        |





**Building: Main** 

Category: PLUMBING

| Group        | Sub Group | Item   | Location              | Rank   | Quantity | Unit | Cost        | Reason |
|--------------|-----------|--|-----------------------|--------|----------|------|-------------|--------|
| Piping       |           | Domestic Piping - Hot Water from Riser to fixtures | Entire Building       | 7      | 319,900  | SF   | \$0         |        |
| Piping       |           | Domestic Piping - Hot Water Return Risers          | Entire Building       | 4      | 319,900  | SF   | \$146,386   |        |
| Piping       |           | Domestic Piping - Hot Water Risers                 | Entire Building       | 4      | 319,900  | SF   | \$173,834   |        |
| Piping       |           | Domestic Piping Cold Water Horizontal lines        | Entire Building       | 4      | 319,900  | SF   | \$763,953   |        |
| Piping       |           | Domestic Piping Hot Water Horizontal lines         | Entire Building       | 4      | 319,900  | SF   | \$631,291   |        |
| Piping       |           | Domestic Piping Hot Water Return Lines             | Entire Building       | 4      | 319,900  | SF   | \$365,966   |        |
| Piping       |           | Sanitary Piping                                    | Entire Building       | 5      | 319,900  | SF   | \$196,707   |        |
| Piping       |           | Storm Piping                                       | Entire Building       | 4      | 319,900  | SF   | \$228,729   |        |
| Piping       |           | Vent Piping  | Entire Building       | 5      | 319,900  | SF   | \$114,364   |        |
| Pool Systems |           | Pool Drain Piping                                  | Basement              | 5      | 100      | LF   | \$8,580     |        |
| Pool Systems |           | Pool Filtration System                             | Basement              | 6      | 1        | EA   | \$27,885    |        |
| Pool Systems |           | Pool Hot Water Heater - Steam Heat Exchanger       | Basement              | 5      | 1        | EA   | \$6,507     |        |
| Pool Systems |           | Pool Supply and Return Piping                      | Basement              | 4      | 300      | LF   | \$47,190    |        |
| Pumps        |           | Domestic Booster Pump duplex                       | Boiler House Basement | 7      | 1        | EA   | \$0         |        |
| Pumps        |           | Sump Pump  | Basement              | 7      | 2        | EA   | \$0         |        |
| Pumps        |           | Sump Pump  | Gymnasium             | 7      | 2        | EA   | \$0         |        |
| Pumps        |           | Sump Pump  | Basement              | 7      | 2        | EA   | \$0         |        |
| Pumps        |           | Sump Pump  | Basement              | 7      | 2        | EA   | \$0         |        |
|              |           |  | PI LIMRING            | Sub To | tal      |      | \$2 924 682 |        |

PLUMBING Sub Total

\$2,924,682

Building: Main Category: INTERIOR

| Group                 | Sub Group                        | Item             | Location                           | Rank | Quantity | Unit | Cost Reason |
|-----------------------|----------------------------------|------------------|------------------------------------|------|----------|------|-------------|
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In | 144 A - Science Prep Office        | 5    | 150      | SF   | \$849       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In | Office D in Main Office            | 6    | 114      | SF   | \$245       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In | Conference room in Main Office (B) | 6    | 200      | SF   | \$429       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In | Prinicpals Office in Main (A)      | 7    | 224      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In | 210 A - Science Prep Office        | 5    | 150      | SF   | \$849       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In | 208 A - Science Prep Office        | 6    | 90       | SF   | \$193       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In | 242 - ROTC Office                  | 6    | 126      | SF   | \$270       |
| Administrative Suites | Administrative Suites/Offices    | Ceiling - Lay-In | 215 - Program Office               | 6    | 312      | SF   | \$669       |



Building: Main Category: INTERIOR

| Group                 | Sub Group                        | Item                      | Location                                       | Rank | Quantity | Unit | Cost Reason |
|-----------------------|----------------------------------|---------------------------|--|------|----------|------|-------------|
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | Office C in Main Office                        | 6    | 114      | SF   | \$245       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | rm 135A- Assistant<br>Principals Office        | 7    | 340      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 239 C - Gym Office                             | 6    | 160      | SF   | \$343       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 237 - Math Office                              | 6    | 160      | SF   | \$343       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 209 - English Office                           | 6    | 160      | SF   | \$343       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | Main Office                                    | 6    | 1,350    | SF   | \$2,896     |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 137 - Admin Office                             | 6    | 160      | SF   | \$343       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 126 - Administrative Office1                   |      | 350      | SF   | \$751       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | rm 129- counselors office                      | 7    | 705      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | rm 131- counselors office                      | 7    | 705      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | Library Staff office in Library                | / 6  | 250      | SF   | \$536       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | rm 135- discipline office                      | 6    | 760      | SF   | \$1,630     |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 309 - Counselors Office                        | 6    | 160      | SF   | \$343       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 346 -Lab Prep Room                             | 6    | 300      | SF   | \$644       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 337 - History Office                           | 6    | 160      | SF   | \$343       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | 342 - Psychologist Office                      | 6    | 126      | SF   | \$270       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Lay-In          | rm 131A  | 7    | 340      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Plaster/Drywall | 208 A - Science Prep Office                    | e 6  | 60       | SF   | \$170       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Plaster/Drywall | 320 - Administrative Office / Teacher Resource | 7    | 1,332    | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Plaster/Drywall | Pool Office                                    | 6    | 80       | SF   | \$227       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Plaster/Drywall | 239 B - Coach Office                           | 6    | 100      | SF   | \$283       |
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Plaster/Drywall | 140 - School Nurse / Social<br>Work            | 7    | 280      | SF   | \$0         |



Building: Main Category: INTERIOR

| Group                 | Sub Group                        | Item                              | Location                                       | Rank | Quantity | Unit | Cost Reason |
|-----------------------|----------------------------------|-----------------------------------|--|------|----------|------|-------------|
| Administrative Suites | Administrative<br>Suites/Offices | Ceiling - Plaster/Drywall         | 242 - ROTC Office                              | 6    | 200      | SF   | \$566       |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Carpet                 | rm 131A  | 6    | 340      | SF   | \$486       |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile Ceramic/Porcelain | 126 - Administrative Office1                   | 5    | 350      | SF   | \$5,506     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile Ceramic/Porcelain | 140 - School Nurse / Social<br>Work            | 5    | 280      | SF   | \$4,404     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | 320 - Administrative Office / Teacher Resource | 5    | 1,332    | SF   | \$7,543     |
| Administrative Suites | Administrative Suites/Offices    | Flooring - Tile/Sheet             | 242 - ROTC Office                              | 5    | 200      | SF   | \$1,133     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | 346 -Lab Prep Room                             | 6    | 300      | SF   | \$429       |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | rm 135A- Assistant<br>Principals Office        | 6    | 340      | SF   | \$486       |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | rm 131- counselors office                      | 7    | 705      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | rm 129- counselors office                      | 7    | 705      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | Pool Office                                    | 4    | 80       | SF   | \$1,133     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | 239 B - Coach Office                           | 4    | 100      | SF   | \$1,416     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | 208 A - Science Prep Office                    | 4    | 150      | SF   | \$2,124     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | Prinicpals Office in Main (A)                  | 7    | 224      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | Conference room in Main<br>Office (B)          | 7    | 200      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | Office D in Main Office                        | 7    | 114      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | rm 135- discipline office                      | 6    | 760      | SF   | \$1,087     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | Office C in Main Office                        | 7    | 114      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | Main Office                                    | 7    | 1,350    | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | 137 - Admin Office                             | 5    | 160      | SF   | \$906       |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | 210 A - Science Prep Office                    | 4    | 150      | SF   | \$2,124     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Tile/Sheet             | 144 A - Science Prep Office                    | 4    | 150      | SF   | \$2,124     |



Building: Main Category: INTERIOR

| Group                 | Sub Group                        | Item              | Location                           | Rank | Quantity | Unit | Cost Reason |
|-----------------------|----------------------------------|-------------------|------------------------------------|------|----------|------|-------------|
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | 209 - English Office               | 5    | 160      | SF   | \$2,265     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | 342 - Psychologist Office          | 5    | 126      | SF   | \$1,784     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | 337 - History Office               | 5    | 160      | SF   | \$2,265     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | 309 - Counselors Office            | 5    | 160      | SF   | \$2,265     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | Library Staff office in Library    | 7    | 250      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | 237 - Math Office                  | 5    | 160      | SF   | \$2,265     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | 239 C - Gym Office                 | 5    | 160      | SF   | \$2,265     |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | 242 - ROTC Office                  | 6    | 126      | SF   | \$951       |
| Administrative Suites | Administrative<br>Suites/Offices | Flooring - Wood   | 215 - Program Office               | 5    | 312      | SF   | \$4,417     |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | Conference room in Main Office (B) | 7    | 6        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | Library Staff office in Library    | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | 144 A - Science Prep Office        | 7    | 6        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | Main Office                        | 7    | 36       | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | Office C in Main Office            | 7    | 3        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | Office D in Main Office            | 7    | 3        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | Prinicpals Office in Main (A)      | 7    | 6        | SF   | \$0         |
| Administrative Suites | Administrative Suites/Offices    | Lighting - Lay-In | 208 A - Science Prep Office        | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | 209 - English Office               | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | 215 - Program Office               | 7    | 9        | SF   | \$0         |
| Administrative Suites | Administrative Suites/Offices    | Lighting - Lay-In | 242 - ROTC Office                  | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | 126 - Administrative Office1       | 7    | 9        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In | 237 - Math Office                  | 7    | 4        | SF   | \$0         |



Building: Main Category: INTERIOR

| Group                 | Sub Group                        | Item                       | Location                                       | Rank | Quantity | Unit | Cost Reason |
|-----------------------|----------------------------------|----------------------------|--|------|----------|------|-------------|
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | 210 A - Science Prep Office                    | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative Suites/Offices    | Lighting - Lay-In          | rm 129- counselors office                      | 7    | 21       | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | rm 131- counselors office                      | 7    | 21       | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | rm 131A  | 7    | 8        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | rm 135- discipline office                      | 7    | 21       | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | rm 135A- Assistant<br>Principals Office        | 7    | 9        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | 309 - Counselors Office                        | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | 337 - History Office                           | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | 342 - Psychologist Office                      | 7    | 3        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | 346 -Lab Prep Room                             | 7    | 3        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | 239 B - Coach Office                           | 7    | 1        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Lay-In          | 137 - Admin Office                             | 7    | 3        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Pendant/Surface | 140 - School Nurse / Social<br>Work            | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Pendant/Surface | 320 - Administrative Office / Teacher Resource | 7    | 12       | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Pendant/Surface | Pool Office                                    | 7    | 2        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Pendant/Surface | 242 - ROTC Office                              | 7    | 4        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Lighting - Pendant/Surface | 239 C - Gym Office                             | 7    | 3        | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall    | 242 - ROTC Office                              | 6    | 460      | SF   | \$1,085     |
| Administrative Suites | Administrative Suites/Offices    | Walls - Plaster/Drywall    | 239 B - Coach Office                           | 6    | 240      | SF   | \$566       |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall    | rm 131A  | 7    | 634      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall    | 215 - Program Office                           | 6    | 660      | SF   | \$1,557     |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall    | 209 - English Office                           | 6    | 400      | SF   | \$944       |



Building: Main Category: INTERIOR

| Group                 | Sub Group                        | Item                    | Location                                       | Rank | Quantity | Unit | Cost Reason |
|-----------------------|----------------------------------|-------------------------|--|------|----------|------|-------------|
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | 208 A - Science Prep Office                    | 6    | 400      | SF   | \$944       |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | Prinicpals Office in Main (A)                  | 7    | 500      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | 239 C - Gym Office                             | 6    | 400      | SF   | \$944       |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | Office C in Main Office                        | 7    | 200      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | Library Staff office in Library                | 7    | 500      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | Conference room in Main<br>Office (B)          | 7    | 400      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | rm 131- counselors office                      | 7    | 840      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | 237 - Math Office                              | 6    | 400      | SF   | \$944       |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | rm 135- discipline office                      | 7    | 1,150    | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | rm 135A- Assistant<br>Principals Office        | 7    | 634      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | 309 - Counselors Office                        | 6    | 400      | SF   | \$944       |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | 337 - History Office                           | 6    | 400      | SF   | \$944       |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | 320 - Administrative Office / Teacher Resource | 6    | 1,770    | SF   | \$4,176     |
| Administrative Suites | Administrative Suites/Offices    | Walls - Plaster/Drywall | 342 - Psychologist Office                      | 6    | 460      | SF   | \$1,085     |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | rm 129- counselors office                      | 7    | 840      | SF   | \$0         |
| Administrative Suites | Administrative Suites/Offices    | Walls - Plaster/Drywall | 140 - School Nurse / Social<br>Work            | 7    | 611      | SF   | \$0         |
| Administrative Suites | Administrative Suites/Offices    | Walls - Plaster/Drywall | Pool Office                                    | 6    | 360      | SF   | \$849       |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | Office D in Main Office                        | 7    | 200      | SF   | \$0         |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | Main Office                                    | 7    | 1,900    | SF   | \$0         |
| Administrative Suites | Administrative Suites/Offices    | Walls - Plaster/Drywall | 137 - Admin Office                             | 6    | 400      | SF   | \$944       |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | 126 - Administrative Office1                   | 6    | 960      | SF   | \$2,265     |
| Administrative Suites | Administrative<br>Suites/Offices | Walls - Plaster/Drywall | 210 A - Science Prep Office                    | 6    | 400      | SF   | \$944       |



Building: Main Category: INTERIOR

| Group                  | Sub Group                        | Item                                   | Location                             | Rank | Quantity | Unit | Cost Reason |  |
|------------------------|----------------------------------|--|--------------------------------------|------|----------|------|-------------|--|
| Administrative Suites  | Administrative<br>Suites/Offices | Walls - Plaster/Drywall                | 346 -Lab Prep Room                   | 6    | 658      | SF   | \$1,553     |  |
| Administrative Suites  | Administrative<br>Suites/Offices | Walls - Plaster/Drywall                | 242 - ROTC Office                    | 6    | 460      | SF   | \$1,085     |  |
| Administrative Suites  | Administrative<br>Suites/Offices | Walls - Plaster/Drywall                | 144 A - Science Prep Office          | 6    | 400      | SF   | \$944       |  |
| Administrative Suites  | Administrative<br>Suites/Offices | Walls - Structural Glazed Tile         | 239 B - Coach Office                 | 7    | 80       | SF   | \$0         |  |
| Auditorium - Dedicated | Auditorium - Dedicated           | Balcony Seating                        | 1st Floor                            | 6    | 538      | EA   | \$19,803    |  |
| Auditorium - Dedicated | Auditorium - Dedicated           | Main Floor Seating                     | 1st Floor                            | 6    | 1,132    | EA   | \$41,667    |  |
| Auditorium - Dedicated | Auditorium - Dedicated           | Sound System                           | 1st Floor                            | 7    | 1        | EA   | \$0         |  |
| Auditorium - Dedicated | Auditorium - Dedicated           | Stage Curtains                         | 1st Floor                            | 7    | 7        | EA   | \$0         |  |
| Auditorium - Dedicated | Auditorium - Dedicated           | Stage Lighting System                  | 1st Floor                            | 7    | 1        | EA   | \$0         |  |
| Clinic                 |                                  | Health Clinic                          | 166 - Heartland Health Clinic        | 7    | 1,500    | SF   | \$0         |  |
| Doors                  |                                  | Interior Steel Doors incl hw           | Entire Building                      | 7    | 17       | EA   | \$0         |  |
| Doors                  |                                  | Interior Wood Doors incl hw            | Entire Building                      | 4    | 50       | EA   | \$160,446   |  |
| Doors                  |                                  | Interior Wood Doors incl hw            | Entire Building                      | 5    | 98       | EA   | \$46,246    |  |
| Doors                  |                                  | Interior Wood Doors incl hw            | Entire Building                      | 6    | 147      | EA   | \$41,622    |  |
| Doors                  |                                  | Interior Wood Doors incl hw            | Entire Building                      | 7    | 10       | EA   | \$0         |  |
| Doors                  |                                  | Side-lite                              | Entire Building                      | 7    | 40       | SF   | \$0         |  |
| Doors                  |                                  | Store Front Door                       | Entire Building                      | 6    | 19       | EA   | \$4,483     |  |
| Doors                  |                                  | Transom Window                         | Entire Building                      | 6    | 1,450    | SF   | \$26,956    |  |
| Drinking Fountains     | Corridors                        | Single Fountain                        | 3rd Floor                            | 7    | 4        | EA   | \$0         |  |
| Drinking Fountains     | Corridors                        | Single Fountain                        | 169                                  | 7    | 1        | EA   | \$0         |  |
| Drinking Fountains     | Corridors                        | Single Fountain                        | 1st Floor                            | 7    | 4        | EA   | \$0         |  |
| Drinking Fountains     | Corridors                        | Single Fountain                        | 2nd Floor                            | 7    | 4        | EA   | \$0         |  |
| GreenHouse             |                                  | Finishes                               | 110 A - Greenhouse                   | 6    | 600      | SF   | \$0         |  |
| GreenHouse             |                                  | Glazing                                | 110 A - Greenhouse                   | 7    | 900      | SF   | \$0         |  |
| GreenHouse             |                                  | Mechanical                             | 110 A - Greenhouse                   | 7    | 600      | SF   | \$0         |  |
| GreenHouse             |                                  | Plumbing                               | 110 A - Greenhouse                   | 7    | 600      | SF   | \$0         |  |
| Gymnasium / Auditorium | Standard Dedicated<br>Gymnasium  | Bleacher Seating                       | 2nd fl North Gym- under construction |      |          | EA   | \$0         |  |
| Gymnasium / Auditorium | Competition Gymnasiun            | n Bleacher Seating                     | 2nd fl South gym                     | 6    | 176      | EA   | \$4,253     |  |
| Gymnasium / Auditorium | Competition Gymnasiun            | n Ceiling - Plaster/Drywall            | 2nd fl South gym                     | 6    | 9,585    | SF   | \$81,965    |  |
| Gymnasium / Auditorium | Competition Gymnasiun            | n Flooring - Wood                      | 2nd fl South gym                     | 7    | 7,520    | SF   | \$0         |  |
| Gymnasium / Auditorium | Competition Gymnasiun            | n Lighting - Metal Halide/Sodium Vapor | 2nd fl South gym                     | 6    | 24       | EA   | \$4,290     |  |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium     | Scoreboards                            | 2nd fl North Gym- under construction |      |          | EA   | \$0         |  |
| Gymnasium / Auditorium | Competition Gymnasiun            | n Scoreboards                          | 2nd fl South gym                     | 5    | 1        | EA   | \$6,852     |  |
|                        |                                  |  |                                      |      |          |      |             |  |





Building: Main Category: INTERIOR

| Group                  | Sub Group                       | Item                             | Location                             | Rank | Quantity | Unit | Cost     | Reason |
|------------------------|---------------------------------|----------------------------------|--------------------------------------|------|----------|------|----------|--------|
| Gymnasium / Auditorium | Standard Dedicated<br>Gymnasium | Sound System                     | 2nd fl North Gym- under construction |      |          | EA   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium           | n Sound System                   | 2nd fl South gym                     |      |          | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated<br>Gymnasium | Stage Curtain                    | 2nd fl North Gym- under construction |      |          | EA   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium           | n Stage Curtain                  | 2nd fl South gym                     |      |          | EA   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium           | n Walls - Plaster/Drywall        | 2nd fl South gym                     | 6    | 2,705    | SF   | \$23,209 |        |
| Gymnasium / Auditorium | Competition Gymnasium           | n Walls - Structural Glazed Tile | 2nd fl South gym                     | 6    | 3,165    | SF   | \$22,630 |        |
| Kitchen                | Cooking Kitchen                 | Ceiling - Splined                | 1st Floor                            | 7    | 1,680    | SF   | \$0      |        |
| Kitchen                | Cooking Kitchen                 | Flooring - Tile/Sheet            | 1st Floor                            | 7    | 1,680    | SF   | \$0      |        |
| Kitchen                | Cooking Kitchen                 | Lighting - Pendant/Surface       | 1st Floor                            | 7    | 34       | SF   | \$0      |        |
| Kitchen                | Cooking Kitchen                 | Wall - Structural Glazed Tile    | 1st Floor                            | 7    | 2,640    | SF   | \$0      |        |
| Library                | Library                         | Casework                         | 2nd Floor                            | 6    | 180      | LF   | \$5,521  |        |
| Library                | Library                         | Lighting - Lay-In                | 2nd Floor                            | 7    | 66       | SF   | \$0      |        |
| Locker/Shower Room     | Locker/Shower Room              | Benches                          | Boys Locker Room                     | 6    | 110      | LF   | \$629    |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | 2nd FL - Girls West                  |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Staff Restroom                  | Benches                          | Kitchen Office Restroom              |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | 1st FL - Girls                       |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | 1st FL - Boys                        |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Staff Restroom                  | Benches                          | 2nd FL - Men's Faculty               |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Staff Restroom                  | Benches                          | 1st FL - Men's Faculty               |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Locker/Shower Room              | Benches                          | Girls Locker Room                    | 7    | 86       | LF   | \$0      |        |
| Locker/Shower Room     | Staff Restroom                  | Benches                          | 2nd FL - Women's Faculty             |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Staff Restroom                  | Benches                          | 1st FL - Women's Faculty             |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Staff Restroom                  | Benches                          | 144 - Health / Social Work<br>Office |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | 3rd FL - Girls East                  |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | 1st FL - Girls West                  |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | 2nd FL - Boys                        |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | 3rd FL - Boys                        |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | 3rd FL - Girls                       |      |          | LF   | \$0      |        |
| Locker/Shower Room     | Adult Standard Student Restroom | Benches                          | Auditorium- Mens                     |      |          | LF   | \$0      |        |





Building: Main Category: INTERIOR

| Group              | Sub Group                           | Item    | Location                                       | Rank | Quantity | Unit | Cost    | Reason |
|--------------------|-------------------------------------|---------|--|------|----------|------|---------|--------|
| Locker/Shower Room | Adult Standard Student Restroom     | Benches | Auditorium- Womens                             |      |          | LF   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Benches | 155 A - Pool Unisex<br>Restroom                | 7    | 2        | LF   | \$0     |        |
| Locker/Shower Room | Early Childhood<br>Student Restroom | Benches | 169 - Early Childhood<br>Development Classroom |      |          | LF   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Benches | 239 A - Coach Restroom                         | 7    | 2        | LF   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Benches | 226 - Staff Restroom (abandoned)               |      |          | LF   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Lockers | Kitchen Office Restroom                        |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | Auditorium- Mens                               |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Lockers | 2nd FL - Women's Faculty                       |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | 1st FL - Girls                                 |      |          | EA   | \$0     |        |
| Locker/Shower Room | Locker/Shower Room                  | Lockers | Boys Locker Room                               | 7    | 271      | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | 1st FL - Boys                                  |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Lockers | 2nd FL - Men's Faculty                         |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Lockers | 1st FL - Men's Faculty                         |      |          | EA   | \$0     |        |
| Locker/Shower Room | Locker/Shower Room                  | Lockers | Girls Locker Room                              | 6    | 192      | EA   | \$9,423 |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | 1st FL - Girls West                            |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Lockers | 144 - Health / Social Work<br>Office           |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Lockers | 226 - Staff Restroom (abandoned)               |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Lockers | 239 A - Coach Restroom                         | 7    | 4        | EA   | \$0     |        |
| Locker/Shower Room | Early Childhood<br>Student Restroom | Lockers | 169 - Early Childhood<br>Development Classroom |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | Auditorium- Womens                             |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | 3rd FL - Girls                                 |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | 3rd FL - Girls East                            |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | 3rd FL - Boys                                  |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers | 2nd FL - Girls West                            |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Lockers | 1st FL - Women's Faculty                       |      |          | EA   | \$0     |        |





Building: Main Category: INTERIOR

| Group              | Sub Group                           | Item             | Location                                       | Rank | Quantity | Unit | Cost    | Reason |
|--------------------|-------------------------------------|------------------|--|------|----------|------|---------|--------|
| Locker/Shower Room | Staff Restroom                      | Lockers          | 155 A - Pool Unisex<br>Restroom                | 7    | 4        | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Lockers          | 2nd FL - Boys                                  |      |          | EA   | \$0     |        |
| Locker/Shower Room | Locker/Shower Room                  | Showers          | Boys Locker Room                               | 7    | 10       | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | 2nd FL - Girls West                            |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | Kitchen Office Restroom                        |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | 1st FL - Girls                                 |      |          | EA   | \$0     |        |
| Locker/Shower Room | Locker/Shower Room                  | Showers          | Girls Locker Room                              | 6    | 32       | EA   | \$7,779 |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | 1st FL - Boys                                  |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | 2nd FL - Men's Faculty                         |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | 1st FL - Men's Faculty                         |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | 2nd FL - Women's Faculty                       |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | 1st FL - Women's Faculty                       |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | 144 - Health / Social Work<br>Office           | 6    | 1        | EA   | \$243   |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | 2nd FL - Boys                                  |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | 226 - Staff Restroom (abandoned)               |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | 239 A - Coach Restroom                         | 7    | 1        | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | 3rd FL - Girls East                            |      |          | EA   | \$0     |        |
| Locker/Shower Room | Staff Restroom                      | Showers          | 155 A - Pool Unisex<br>Restroom                | 7    | 1        | EA   | \$0     |        |
| Locker/Shower Room | Early Childhood<br>Student Restroom | Showers          | 169 - Early Childhood<br>Development Classroom |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | Auditorium- Mens                               |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | 3rd FL - Girls                                 |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | 3rd FL - Boys                                  |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | Auditorium- Womens                             |      |          | EA   | \$0     |        |
| Locker/Shower Room | Adult Standard Student Restroom     | Showers          | 1st FL - Girls West                            |      |          | EA   | \$0     |        |
| Lunchroom          | Lunchroom                           | Ceiling - Lay-In | 1st Floor                                      | 7    | 9,030    | SF   | \$0     |        |



Building: Main Category: INTERIOR

| Group                    | Sub Group                           | Item                          | Location  | Rank | Quantity | Unit | Cost Reason |
|--------------------------|-------------------------------------|-------------------------------|---|------|----------|------|-------------|
| _unchroom                | Multipurpose Room                   | Ceiling - Plaster/Drywall     | Weight Room between Boys and Girls Locker Rooms | 7    | 2,065    | SF   | \$0         |
| unchroom                 | Lunchroom                           | Ceiling - Splined             | 1st Floor                                       | 7    | 1,800    | SF   | \$0         |
| unchroom                 | Lunchroom                           | Flooring - Tile/Sheet         | 1st Floor                                       | 7    | 10,830   | SF   | \$0         |
| unchroom                 | Multipurpose Room                   | Lighting - Pendant/Surface    | Weight Room between Boys and Girls Locker Rooms | 7    | 49       | SF   | \$0         |
| unchroom                 | Lunchroom                           | Lighting - Pendant/Surface    | 1st Floor                                       | 6    | 113      | SF   | \$81        |
| unchroom                 | Lunchroom                           | Serving Line                  | 1st Floor                                       | 7    | 115      | LF   | \$0         |
| unchroom                 | Cooking Kitchen                     | Serving Line                  | 1st Floor                                       |      |          | LF   | \$0         |
| Lunchroom                | Multipurpose Room                   | Serving Line                  | Weight Room between Boys and Girls Locker Rooms |      |          | LF   | \$0         |
| Lunchroom                | Multipurpose Room                   | Wall - Plaster/Drywall        | Weight Room between Boys and Girls Locker Rooms | 7    | 1,455    | SF   | \$0         |
| unchroom                 | Lunchroom                           | Wall - Plaster/Drywall        | 1st Floor                                       | 7    | 3,565    | SF   | \$0         |
| Lunchroom                | Multipurpose Room                   | Wall - Structural Glazed Tile | Weight Room between Boys and Girls Locker Rooms | 6    | 1,600    | SF   | \$11,440    |
| unchroom                 | Lunchroom                           | Wall - Structural Glazed Tile | 1st Floor                                       | 7    | 7,529    | SF   | \$0         |
| Mechanical/Service Rooms |                                     | Boiler Room                   | Boiler Room                                     | 7    | 5,500    | SF   | \$0         |
| Mechanical/Service Rooms |                                     | Janitor's Closet              | Entire Building                                 | 7    | 4        | SF   | \$0         |
| Mechanical/Service Rooms |                                     | Mechanical/Service Rooms      | Entire Building                                 | 7    | 76,000   | SF   | \$0         |
| Mechanical/Service Rooms |                                     | Storage Room                  | Entire Building                                 | 6    | 2,925    | SF   | \$13,803    |
| Mechanical/Service Rooms |                                     | Storage Room                  | in Main Office                                  | 7    | 90       | SF   | \$0         |
| Mechanical/Service Rooms |                                     | Storage Room                  | Entire Building                                 | 7    | 1,820    | SF   | \$0         |
| Staff Restroom           | Staff Restroom                      | Accessories                   | 144 - Health / Social Work<br>Office            | 6    | 160      | SF   | \$1,236     |
| Staff Restroom           | Staff Restroom                      | Accessories                   | 2nd FL - Women's Faculty                        | 6    | 200      | SF   | \$1,544     |
| Staff Restroom           | Adult Standard Student Restroom     | Accessories                   | 2nd FL - Girls West                             | 6    | 243      | SF   | \$1,876     |
| Staff Restroom           | Adult Standard Student Restroom     | Accessories                   | 2nd FL - Boys                                   | 6    | 400      | SF   | \$3,089     |
| Staff Restroom           | Staff Restroom                      | Accessories                   | 226 - Staff Restroom (abandoned)                |      |          | SF   | \$0         |
| taff Restroom            | Staff Restroom                      | Accessories                   | 239 A - Coach Restroom                          | 7    | 100      | SF   | \$0         |
| taff Restroom            | Early Childhood<br>Student Restroom | Accessories                   | 169 - Early Childhood<br>Development Classroom  | 7    | 60       | SF   | \$0         |
| staff Restroom           | Staff Restroom                      | Accessories                   | 155 A - Pool Unisex<br>Restroom                 | 7    | 100      | SF   | \$0         |
| taff Restroom            | Locker/Shower Room                  | Accessories                   | Girls Locker Room                               | 6    | 4,272    | SF   | \$32,988    |
| Staff Restroom           | Adult Standard Student Restroom     | Accessories                   | Auditorium- Womens                              | 7    | 190      | SF   | \$0         |



Building: Main Category: INTERIOR

| Group          | Sub Group                           | Item                      | Location                                       | Rank | Quantity | Unit | Cost    | Reason |
|----------------|-------------------------------------|---------------------------|--|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom     | Accessories               | Auditorium- Mens                               | 7    | 324      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Accessories               | 1st FL - Girls West                            | 6    | 243      | SF   | \$1,876 |        |
| Staff Restroom | Adult Standard Student Restroom     | Accessories               | 3rd FL - Girls                                 | 6    | 400      | SF   | \$3,089 |        |
| Staff Restroom | Staff Restroom                      | Accessories               | Kitchen Office Restroom                        | 6    | 42       | SF   | \$324   |        |
| Staff Restroom | Adult Standard Student Restroom     | Accessories               | 1st FL - Girls                                 | 6    | 400      | SF   | \$3,089 |        |
| Staff Restroom | Locker/Shower Room                  | Accessories               | Boys Locker Room                               | 7    | 1,835    | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Accessories               | 1st FL - Boys                                  | 6    | 400      | SF   | \$3,089 |        |
| Staff Restroom | Adult Standard Student Restroom     | Accessories               | 3rd FL - Girls East                            | 6    | 243      | SF   | \$1,876 |        |
| Staff Restroom | Staff Restroom                      | Accessories               | 1st FL - Men's Faculty                         | 6    | 200      | SF   | \$1,544 |        |
| Staff Restroom | Staff Restroom                      | Accessories               | 1st FL - Women's Faculty                       | 6    | 200      | SF   | \$1,544 |        |
| Staff Restroom | Adult Standard Student Restroom     | Accessories               | 3rd FL - Boys                                  | 6    | 400      | SF   | \$3,089 |        |
| Staff Restroom | Staff Restroom                      | Accessories               | 2nd FL - Men's Faculty                         | 6    | 200      | SF   | \$1,544 |        |
| Staff Restroom | Early Childhood<br>Student Restroom | Ceiling - Lay-In          | 169 - Early Childhood<br>Development Classroom | 7    | 60       | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | 2nd FL - Women's Faculty                       | 7    | 200      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | 1st FL - Men's Faculty                         | 7    | 200      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | 2nd FL - Men's Faculty                         | 7    | 200      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | 1st FL - Boys                                  | 6    | 400      | SF   | \$1,133 |        |
| Staff Restroom | Locker/Shower Room                  | Ceiling - Plaster/Drywall | Boys Locker Room                               | 7    | 4,835    | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | 1st FL - Girls West                            | 6    | 243      | SF   | \$688   |        |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | 1st FL - Women's Faculty                       | 7    | 200      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | Auditorium- Womens                             | 7    | 190      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | Kitchen Office Restroom                        | 6    | 42       | SF   | \$119   |        |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | 1st FL - Girls                                 | 6    | 400      | SF   | \$1,133 |        |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | 144 - Health / Social Work<br>Office           | 7    | 160      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | 2nd FL - Boys                                  | 6    | 400      | SF   | \$1,133 |        |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | 226 - Staff Restroom (abandoned)               | 6    | 40       | SF   | \$113   |        |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | 239 A - Coach Restroom                         | 7    | 100      | SF   | \$0     |        |



Building: Main Category: INTERIOR

| Group          | Sub Group                           | Item                      | Location                                       | Rank | Quantity | Unit | Cost Reason |
|----------------|-------------------------------------|---------------------------|--|------|----------|------|-------------|
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | Auditorium- Mens                               | 7    | 324      | SF   | \$0         |
| Staff Restroom | Locker/Shower Room                  | Ceiling - Plaster/Drywall | Girls Locker Room                              | 7    | 4,272    | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | 3rd FL - Girls                                 | 6    | 400      | SF   | \$1,133     |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | 3rd FL - Boys                                  | 6    | 400      | SF   | \$1,133     |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | 2nd FL - Girls West                            | 6    | 243      | SF   | \$688       |
| Staff Restroom | Staff Restroom                      | Ceiling - Plaster/Drywall | 155 A - Pool Unisex<br>Restroom                | 7    | 100      | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Ceiling - Plaster/Drywall | 3rd FL - Girls East                            | 6    | 243      | SF   | \$688       |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain               | Auditorium- Womens                             | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain               | 1st FL - Boys                                  | 7    | 1        | EA   | \$0         |
| Staff Restroom | Locker/Shower Room                  | Floor Drain               | Boys Locker Room                               | 5    | 2        | EA   | \$3,003     |
| Staff Restroom | Staff Restroom                      | Floor Drain               | 144 - Health / Social Work<br>Office           | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain               | 1st FL - Girls                                 | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain               | 1st FL - Girls West                            | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Floor Drain               | Kitchen Office Restroom                        |      |          | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain               | 2nd FL - Girls West                            | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain               | 3rd FL - Boys                                  | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain               | 3rd FL - Girls East                            | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain               | Auditorium- Mens                               | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Floor Drain               | 155 A - Pool Unisex<br>Restroom                | 7    | 1        | EA   | \$0         |
| Staff Restroom | Early Childhood<br>Student Restroom | Floor Drain               | 169 - Early Childhood<br>Development Classroom | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Floor Drain               | 239 A - Coach Restroom                         | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Floor Drain               | 226 - Staff Restroom (abandoned)               |      |          | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Floor Drain               | 1st FL - Women's Faculty                       | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Floor Drain               | 2nd FL - Women's Faculty                       | 7    | 1        | EA   | \$0         |



Building: Main Category: INTERIOR

| Group          | Sub Group                           | Item                              | Location                                       | Rank | Quantity | Unit | Cost     | Reason |
|----------------|-------------------------------------|-----------------------------------|--|------|----------|------|----------|--------|
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain                       | 2nd FL - Boys                                  | 7    | 1        | EA   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom     | Floor Drain                       | 3rd FL - Girls                                 | 7    | 1        | EA   | \$0      |        |
| Staff Restroom | Locker/Shower Room                  | Floor Drain                       | Girls Locker Room                              | 6    | 23       | EA   | \$6,907  |        |
| Staff Restroom | Staff Restroom                      | Floor Drain                       | 1st FL - Men's Faculty                         | 7    | 1        | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                      | Floor Drain                       | 2nd FL - Men's Faculty                         | 7    | 1        | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                      | Flooring - Tile Ceramic/Porcelain | 144 - Health / Social Work<br>Office           | 5    | 160      | SF   | \$2,517  |        |
| Staff Restroom | Staff Restroom                      | Flooring - Tile Ceramic/Porcelain | 2nd FL - Men's Faculty                         | 5    | 200      | SF   | \$3,146  |        |
| Staff Restroom | Locker/Shower Room                  | Flooring - Tile Ceramic/Porcelain | Girls Locker Room                              | 6    | 4,272    | SF   | \$10,874 |        |
| Staff Restroom | Adult Standard Student Restroom     | Flooring - Tile Ceramic/Porcelain | 3rd FL - Girls East                            | 5    | 243      | SF   | \$3,822  |        |
| Staff Restroom | Staff Restroom                      | Flooring - Tile Ceramic/Porcelain | 155 A - Pool Unisex<br>Restroom                | 7    | 100      | SF   | \$0      |        |
| Staff Restroom | Early Childhood<br>Student Restroom | Flooring - Tile Ceramic/Porcelain | 169 - Early Childhood<br>Development Classroom | 7    | 60       | SF   | \$0      |        |
| Staff Restroom | Staff Restroom                      | Flooring - Tile Ceramic/Porcelain | 2nd FL - Women's Faculty                       | 5    | 200      | SF   | \$3,146  |        |
| Staff Restroom | Staff Restroom                      | Flooring - Tile Ceramic/Porcelain | 226 - Staff Restroom (abandoned)               | 5    | 40       | SF   | \$629    |        |
| Staff Restroom | Adult Standard Student Restroom     | Flooring - Tile Ceramic/Porcelain | 2nd FL - Girls West                            | 5    | 243      | SF   | \$3,822  |        |
| Staff Restroom | Staff Restroom                      | Flooring - Tile Ceramic/Porcelain | 1st FL - Women's Faculty                       | 5    | 200      | SF   | \$3,146  |        |
| Staff Restroom | Locker/Shower Room                  | Flooring - Tile Ceramic/Porcelain | Boys Locker Room                               | 6    | 4,835    | SF   | \$12,307 |        |
| Staff Restroom | Adult Standard Student Restroom     | Flooring - Tile Ceramic/Porcelain | Auditorium- Mens                               | 7    | 324      | SF   | \$0      |        |
| Staff Restroom | Staff Restroom                      | Flooring - Tile Ceramic/Porcelain | 1st FL - Men's Faculty                         | 5    | 200      | SF   | \$3,146  |        |
| Staff Restroom | Adult Standard Student Restroom     | Flooring - Tile Ceramic/Porcelain | 1st FL - Girls                                 | 5    | 400      | SF   | \$6,292  |        |
| Staff Restroom | Adult Standard Student Restroom     | Flooring - Tile Ceramic/Porcelain | 1st FL - Girls West                            | 5    | 243      | SF   | \$3,822  |        |
| Staff Restroom | Staff Restroom                      | Flooring - Tile Ceramic/Porcelain | 239 A - Coach Restroom                         | 7    | 100      | SF   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom     | Flooring - Tile Ceramic/Porcelain | Auditorium- Womens                             | 7    | 190      | SF   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer                        | 3rd FL - Girls East                            | 7    | 1        | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                      | Hand Dryer                        | Kitchen Office Restroom                        |      |          | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                      | Hand Dryer                        | 144 - Health / Social Work<br>Office           | 7    | 1        | EA   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer                        | 2nd FL - Boys                                  | 7    | 1        | EA   | \$0      |        |



Building: Main Category: INTERIOR

| Group          | Sub Group                           | Item       | Locati            | on                               | Rank | Quantity | Unit | Cost    | Reason |
|----------------|-------------------------------------|------------|-------------------|----------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom                      | Hand Dryer | 226 - S<br>(aband | Staff Restroom<br>loned)         |      |          | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Hand Dryer | 239 A             | - Coach Restroom                 |      |          | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Hand Dryer | 155 A<br>Restro   | - Pool Unisex<br>om              |      |          | EA   | \$0     |        |
| Staff Restroom | Early Childhood<br>Student Restroom | Hand Dryer |                   | Early Childhood ppment Classroom | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Hand Dryer | 1st FL            | - Women's Faculty                |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer | Audito            | rium- Womens                     | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer | 3rd FL            | - Girls                          | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer | 2nd FL            | - Girls West                     | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer | 3rd FL            | - Boys                           | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer | 1st FL            | - Girls West                     | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer | 1st FL            | - Girls                          | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer | 1st FL            | - Boys                           | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Hand Dryer | 2nd FL            | - Men's Faculty                  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Hand Dryer | 1st FL            | - Men's Faculty                  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room                  | Hand Dryer | Girls L           | ocker Room                       | 6    | 3        | EA   | \$651   |        |
| Staff Restroom | Staff Restroom                      | Hand Dryer | 2nd FL            | - Women's Faculty                |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Hand Dryer | Audito            | rium- Mens                       | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room                  | Lavatory   | Boys L            | ocker Room                       | 6    | 2        | EA   | \$744   |        |
| Staff Restroom | Staff Restroom                      | Lavatory   | 239 A             | - Coach Restroom                 | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Lavatory   | 2nd FL            | - Men's Faculty                  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Lavatory   | 1st FL            | - Men's Faculty                  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room                  | Lavatory   | Girls L           | ocker Room                       | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Lavatory   | 2nd FL            | - Women's Faculty                | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Lavatory   | 1st FL            | - Women's Faculty                | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Lavatory   | 144 - H<br>Office | Health / Social Work             | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory   | 3rd FL            | - Boys                           | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Lavatory   | 226 - S<br>(aband | Staff Restroom<br>loned)         | 4    | 1        | EA   | \$3,718 |        |



Building: Main Category: INTERIOR

| Group          | Sub Group                           | Item                        | Location                                       | Rank | Quantity | Unit | Cost Reason |
|----------------|-------------------------------------|-----------------------------|--|------|----------|------|-------------|
| Staff Restroom | Adult Standard Student<br>Restroom  | Lavatory                    | 3rd FL - Girls East                            | 7    | 2        | EA   | \$0         |
| Staff Restroom | Early Childhood<br>Student Restroom | Lavatory                    | 169 - Early Childhood<br>Development Classroom | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Lavatory                    | 155 A - Pool Unisex<br>Restroom                | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory                    | Auditorium- Womens                             | 7    | 2        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory                    | Auditorium- Mens                               | 7    | 2        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory                    | 3rd FL - Girls                                 | 7    | 2        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory                    | 1st FL - Girls                                 | 7    | 2        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory                    | 2nd FL - Boys                                  | 7    | 2        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Lavatory                    | Kitchen Office Restroom                        | 7    | 1        | EA   | <b>\$</b> 0 |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory                    | 2nd FL - Girls West                            | 7    | 2        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory                    | 1st FL - Boys                                  | 7    | 2        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lavatory                    | 1st FL - Girls West                            | 7    | 2        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Lighting - Lay-In           | 155 A - Pool Unisex<br>Restroom                | 7    | 2        | SF   | \$0         |
| Staff Restroom | Early Childhood<br>Student Restroom | Lighting - Lay-In           | 169 - Early Childhood<br>Development Classroom | 7    | 1        | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Lighting - Lay-In           | 239 A - Coach Restroom                         | 7    | 2        | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Lighting - Pendant/ Surface | 1st FL - Women's Faculty                       | 7    | 5        | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lighting - Pendant/ Surface | 1st FL - Girls                                 | 7    | 7        | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Lighting - Pendant/ Surface | Kitchen Office Restroom                        | 7    | 1        | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lighting - Pendant/ Surface | 2nd FL - Girls West                            | 7    | 5        | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lighting - Pendant/ Surface | 1st FL - Boys                                  | 7    | 7        | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Lighting - Pendant/ Surface | 2nd FL - Men's Faculty                         | 7    | 5        | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Lighting - Pendant/ Surface | 1st FL - Girls West                            | 7    | 5        | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Lighting - Pendant/ Surface | 2nd FL - Women's Faculty                       | 7    | 5        | SF   | \$0         |
| Staff Restroom | Locker/Shower Room                  | Lighting - Pendant/ Surface | Boys Locker Room                               | 7    | 70       | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Lighting - Pendant/ Surface | 144 - Health / Social Work<br>Office           | 7    | 3        | SF   | \$0         |



Building: Main Category: INTERIOR

| Group          | Sub Group                       | Item                        | Location                             | Rank | Quantity | Unit | Cost Reason |
|----------------|---------------------------------|-----------------------------|--------------------------------------|------|----------|------|-------------|
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd FL - Boys                        | 7    | 7        | SF   | \$0         |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface | Girls Locker Room                    | 7    | 91       | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | Auditorium- Womens                   | 7    | 4        | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | Auditorium- Mens                     | 7    | 4        | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 3rd FL - Girls                       | 7    | 7        | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 3rd FL - Girls East                  | 7    | 5        | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 3rd FL - Boys                        | 7    | 7        | SF   | \$0         |
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | 1st FL - Men's Faculty               | 7    | 5        | SF   | \$0         |
| Staff Restroom | Staff Restroom                  | Lighting - Wall Mounted     | 226 - Staff Restroom (abandoned)     | 5    | 1        | EA   | \$157       |
| Staff Restroom | Staff Restroom                  | Partitions                  | 226 - Staff Restroom (abandoned)     |      |          | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd FL - Boys                        | 6    | 5        | EA   | \$897       |
| Staff Restroom | Staff Restroom                  | Partitions                  | 144 - Health / Social Work<br>Office | 5    | 2        | EA   | \$1,144     |
| Staff Restroom | Staff Restroom                  | Partitions                  | 1st FL - Women's Faculty             | 6    | 3        | EA   | \$538       |
| Staff Restroom | Staff Restroom                  | Partitions                  | 2nd FL - Women's Faculty             | 6    | 3        | EA   | \$538       |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd FL - Girls West                  | 6    | 6        | EA   | \$1,076     |
| Staff Restroom | Staff Restroom                  | Partitions                  | Kitchen Office Restroom              |      |          | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st FL - Girls West                  | 6    | 6        | EA   | \$1,076     |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st FL - Girls                       | 6    | 11       | EA   | \$1,973     |
| Staff Restroom | Locker/Shower Room              | Partitions                  | Boys Locker Room                     | 5    | 2        | EA   | \$1,144     |
| Staff Restroom | Locker/Shower Room              | Partitions                  | Girls Locker Room                    | 6    | 40       | EA   | \$7,173     |
| Staff Restroom | Staff Restroom                  | Partitions                  | 239 A - Coach Restroom               |      |          | EA   | \$0         |
| Staff Restroom | Staff Restroom                  | Partitions                  | 2nd FL - Men's Faculty               | 6    | 1        | EA   | \$179       |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 3rd FL - Girls East                  | 6    | 6        | EA   | \$1,076     |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st FL - Boys                        | 6    | 5        | EA   | \$897       |
| Staff Restroom | Staff Restroom                  | Partitions                  | 155 A - Pool Unisex<br>Restroom      |      |          | EA   | \$0         |



Building: Main Category: INTERIOR

| Group          | Sub Group                           | Item       | Location                                       | Rank | Quantity | Unit | Cost    | Reason |
|----------------|-------------------------------------|------------|--|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom     | Partitions | Auditorium- Womens                             | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Partitions | 1st FL - Men's Faculty                         | 6    | 1        | EA   | \$179   |        |
| Staff Restroom | Adult Standard Student Restroom     | Partitions | 3rd FL - Girls                                 | 6    | 11       | EA   | \$1,973 |        |
| Staff Restroom | Adult Standard Student Restroom     | Partitions | Auditorium- Mens                               | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Partitions | 3rd FL - Boys                                  | 6    | 5        | EA   | \$897   |        |
| Staff Restroom | Early Childhood<br>Student Restroom | Partitions | 169 - Early Childhood<br>Development Classroom |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | 1st FL - Girls West                            |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | 3rd FL - Boys                                  | 6    | 7        | EA   | \$2,603 |        |
| Staff Restroom | Staff Restroom                      | Urinals    | 2nd FL - Men's Faculty                         | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | 1st FL - Boys                                  | 6    | 7        | EA   | \$2,603 |        |
| Staff Restroom | Locker/Shower Room                  | Urinals    | Girls Locker Room                              |      |          | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Urinals    | 1st FL - Men's Faculty                         | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | 1st FL - Girls                                 |      |          | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Urinals    | 155 A - Pool Unisex<br>Restroom                |      |          | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Urinals    | Kitchen Office Restroom                        |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | 2nd FL - Girls West                            |      |          | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room                  | Urinals    | Boys Locker Room                               | 7    | 3        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | 3rd FL - Girls East                            |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | 3rd FL - Girls                                 |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | Auditorium- Womens                             |      |          | EA   | \$0     |        |
| Staff Restroom | Early Childhood<br>Student Restroom | Urinals    | 169 - Early Childhood<br>Development Classroom |      |          | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Urinals    | 239 A - Coach Restroom                         |      |          | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                      | Urinals    | 226 - Staff Restroom (abandoned)               |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom     | Urinals    | 2nd FL - Boys                                  | 6    | 7        | EA   | \$2,603 |        |
| Staff Restroom | Staff Restroom                      | Urinals    | 144 - Health / Social Work<br>Office           | 6    | 1        | EA   | \$372   |        |



Building: Main Category: INTERIOR

| Group          | Sub Group                           | Item                          | Location                                       | Rank | Quantity | Unit | Cost Reason |
|----------------|-------------------------------------|-------------------------------|--|------|----------|------|-------------|
| Staff Restroom | Staff Restroom                      | Urinals                       | 1st FL - Women's Faculty                       |      |          | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Urinals                       | 2nd FL - Women's Faculty                       |      |          | EA   | \$0         |
| Staff Restroom | Adult Standard Student<br>Restroom  | Urinals                       | Auditorium- Mens                               | 7    | 3        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Wall - Plaster/Drywall        | 155 A - Pool Unisex<br>Restroom                | 7    | 180      | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Wall - Plaster/Drywall        | 1st FL - Women's Faculty                       | 7    | 390      | SF   | \$0         |
| Staff Restroom | Adult Standard Student<br>Restroom  | Wall - Plaster/Drywall        | 2nd FL - Girls West                            | 6    | 720      | SF   | \$1,699     |
| Staff Restroom | Adult Standard Student Restroom     | Wall - Plaster/Drywall        | 1st FL - Girls West                            | 6    | 720      | SF   | \$1,699     |
| Staff Restroom | Adult Standard Student<br>Restroom  | Wall - Plaster/Drywall        | 1st FL - Girls                                 | 5    | 810      | SF   | \$3,822     |
| Staff Restroom | Locker/Shower Room                  | Wall - Plaster/Drywall        | Girls Locker Room                              | 7    | 1,075    | SF   | \$0         |
| Staff Restroom | Adult Standard Student<br>Restroom  | Wall - Plaster/Drywall        | 1st FL - Boys                                  | 6    | 810      | SF   | \$1,911     |
| Staff Restroom | Staff Restroom                      | Wall - Plaster/Drywall        | 2nd FL - Men's Faculty                         | 7    | 390      | SF   | \$0         |
| Staff Restroom | Adult Standard Student<br>Restroom  | Wall - Plaster/Drywall        | Auditorium- Mens                               | 7    | 432      | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Wall - Plaster/Drywall        | 2nd FL - Women's Faculty                       | 7    | 390      | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Wall - Plaster/Drywall        | 3rd FL - Boys                                  | 6    | 810      | SF   | \$1,911     |
| Staff Restroom | Staff Restroom                      | Wall - Plaster/Drywall        | 144 - Health / Social Work<br>Office           | 7    | 338      | SF   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Wall - Plaster/Drywall        | 2nd FL - Boys                                  | 6    | 810      | SF   | \$1,911     |
| Staff Restroom | Staff Restroom                      | Wall - Plaster/Drywall        | 226 - Staff Restroom (abandoned)               | 6    | 368      | SF   | \$868       |
| Staff Restroom | Early Childhood<br>Student Restroom | Wall - Plaster/Drywall        | 169 - Early Childhood<br>Development Classroom | 7    | 224      | SF   | \$0         |
| Staff Restroom | Adult Standard Student<br>Restroom  | Wall - Plaster/Drywall        | Auditorium- Womens                             | 7    | 348      | SF   | \$0         |
| Staff Restroom | Adult Standard Student<br>Restroom  | Wall - Plaster/Drywall        | 3rd FL - Girls                                 | 6    | 810      | SF   | \$1,911     |
| Staff Restroom | Adult Standard Student<br>Restroom  | Wall - Plaster/Drywall        | 3rd FL - Girls East                            | 6    | 720      | SF   | \$1,699     |
| Staff Restroom | Staff Restroom                      | Wall - Plaster/Drywall        | 1st FL - Men's Faculty                         | 7    | 390      | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Wall - Structural Glazed Tile | 155 A - Pool Unisex<br>Restroom                | 7    | 220      | SF   | \$0         |
| Staff Restroom | Staff Restroom                      | Wall - Structural Glazed Tile | 239 A - Coach Restroom                         | 7    | 400      | SF   | \$0         |
| Staff Restroom | Locker/Shower Room                  | Wall - Structural Glazed Tile | Boys Locker Room                               | 6    | 5,327    | SF   | \$38,088    |
| Staff Restroom | Locker/Shower Room                  | Wall - Structural Glazed Tile | Girls Locker Room                              | 7    | 4,790    | SF   | \$0         |



Building: Main Category: INTERIOR

| Group          | Sub Group                           | Item                           | Location                                       | Rank | Quantity | Unit | Cost Reason |
|----------------|-------------------------------------|--------------------------------|--|------|----------|------|-------------|
| Staff Restroom | Early Childhood<br>Student Restroom | Wall - Tile Ceramic/ Porcelain | 169 - Early Childhood<br>Development Classroom | 7    | 96       | SF   | \$0         |
| Staff Restroom | Adult Standard Student<br>Restroom  | Water Closet                   | 1st FL - Boys                                  | 7    | 5        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | 226 - Staff Restroom (abandoned)               | 4    | 1        | EA   | \$3,718     |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | 3rd FL - Boys                                  | 7    | 5        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | 3rd FL - Girls East                            | 7    | 6        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | 3rd FL - Girls                                 | 7    | 11       | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | Auditorium- Mens                               | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | Auditorium- Womens                             | 7    | 2        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | 155 A - Pool Unisex<br>Restroom                | 7    | 1        | EA   | \$0         |
| Staff Restroom | Early Childhood<br>Student Restroom | Water Closet                   | 169 - Early Childhood<br>Development Classroom | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | 239 A - Coach Restroom                         | 7    | 1        | EA   | \$0         |
| Staff Restroom | Locker/Shower Room                  | Water Closet                   | Boys Locker Room                               | 7    | 2        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | 2nd FL - Boys                                  | 7    | 5        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | 144 - Health / Social Work<br>Office           | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | 1st FL - Women's Faculty                       | 7    | 3        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | 2nd FL - Women's Faculty                       | 7    | 3        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | 2nd FL - Men's Faculty                         | 7    | 1        | EA   | \$0         |
| Staff Restroom | Locker/Shower Room                  | Water Closet                   | Girls Locker Room                              | 7    | 7        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | 1st FL - Girls                                 | 7    | 11       | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | 1st FL - Girls West                            | 7    | 6        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | 1st FL - Men's Faculty                         | 7    | 1        | EA   | \$0         |
| Staff Restroom | Staff Restroom                      | Water Closet                   | Kitchen Office Restroom                        | 7    | 1        | EA   | \$0         |
| Staff Restroom | Adult Standard Student Restroom     | Water Closet                   | 2nd FL - Girls West                            | 7    | 6        | EA   | \$0         |
| Theater        | Auditorium - Dedicated              | Ceiling - Plaster/Drywall      | 1st Floor                                      | 7    | 8,730    | SF   | \$0         |
| Theater        | Auditorium - Dedicated              | Flooring - Carpet              | 1st Floor                                      | 6    | 8,308    | SF   | \$11,880    |
| Theater        | Auditorium - Dedicated              | Flooring - Wood                | 1st Floor                                      | 7    | 4,656    | SF   | \$0         |
| Theater        | Auditorium - Dedicated              | Lighting - Lay-In              | 1st Floor                                      | 7    | 32       | SF   | \$0         |



Building: Main Category: INTERIOR

| Theater  | Group               | Sub Group              | Item                                | Location        | Rank | Quantity | Unit | Cost     | Reason                          |
|--|---------------------|------------------------|-------------------------------------|-----------------|------|----------|------|----------|---------------------------------|
| Theater         Auditorium - Dedicated         Stage         1st Floor         7         1         SF         \$0           Theater         Auditorium - Dedicated         Wall - Plaster/Drywall         1st Floor         7         15,372         SF         \$0         includes wood accompanels           Vertical Conveyance         Elevator - Roped Holeless Hydraulic         Entire Building         6         1         EA         \$17,160           Vocational Shop         Classroom         Work Sink         4         1         EA         \$3,861           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         4         5         EA         \$19,305           Vocational Shop         Classroom         Work Sink         4         5         EA         \$19,305           Vocational Shop         Classroom         Work Sink         5         3         EA         \$19,305           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0  | Theater             | Auditorium - Dedicated | Lighting - Pendant/ Surface         | 1st Floor       | 7    | 20       | SF   | \$0      |                                 |
| Theater         Auditorium - Dedicated         Wall - Plaster/Drywall         1st Floor         7         15,372         SF         \$0         includes wood acous panels           Vertical Conveyance         Elevator - Roped Holeless Hydraulic         Entire Building         6         1         EA         \$17,160           Vocational Shop         Classroom         Work Sink         7         1         EA         \$3,861           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         4         3         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         7         1         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$6           Vocational Shop   | Theater             | Auditorium - Dedicated | Lighting - Wall Mounted             | 1st Floor       | 7    | 23       | EA   | \$0      |                                 |
| Vertical Conveyance         Elevator - Roped Holeless Hydraulic         Entire Building         6         1         EA         \$17,160           Vocational Shop         Classroom         Work Sink         7         1         EA         \$3,861           Vocational Shop         Classroom         Work Sink         7         1         EA         \$5,792           Vocational Shop         Classroom         Work Sink         4         5         EA         \$11,583           Vocational Shop         Classroom         Work Sink         4         5         EA         \$19,305           Vocational Shop         Classroom         Work Sink         4         5         EA         \$19,305           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         1         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         <  | Theater             | Auditorium - Dedicated | Stage                               | 1st Floor       | 7    | 1        | SF   | \$0      |                                 |
| Vocational Shop         Classroom         Work Sink         4         1         EA         \$3,861           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         4         5         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         3         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         5         EA         \$3,861           Vocational Shop         Classroom         Work Sink         7         1         EA         \$3,86   | Theater             | Auditorium - Dedicated | Wall - Plaster/Drywall              | 1st Floor       | 7    | 15,372   | SF   | \$0      | includes wood acoustical panels |
| Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         4         5         EA         \$19,305           Vocational Shop         Classroom         Work Sink         4         3         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$3,861           Vocational Shop         Classroom         Work Sink         4         3         EA         \$11,   | Vertical Conveyance |                        | Elevator - Roped Holeless Hydraulic | Entire Building | 6    | 1        | EA   | \$17,160 |                                 |
| Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         4         5         EA         \$19,305           Vocational Shop         Classroom         Work Sink         4         3         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         5         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$1,583           Vocational Shop         Classroom         Work Sink         5         23         EA         \$44,402   | Vocational Shop     | Classroom              | Work Sink                           |                 | 4    | 1        | EA   | \$3,861  |                                 |
| Vocational Shop         Classroom         Work Sink         4         5         EA         \$19,305           Vocational Shop         Classroom         Work Sink         4         3         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         5         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$3,861           Vocational Shop         Classroom         Work Sink         7         1         EA         \$11,583           Vocational Shop         Classroom         Work Sink         3         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         23         EA         \$44,402 <td>Vocational Shop</td> <td>Classroom</td> <td>Work Sink</td> <td></td> <td>7</td> <td>1</td> <td>EA</td> <td>\$0</td> <td></td>     | Vocational Shop     | Classroom              | Work Sink                           |                 | 7    | 1        | EA   | \$0      |                                 |
| Vocational Shop         Classroom         Work Sink         4         3         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         5         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$3,861           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         4         3         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         23         EA         \$44,402           Vocational Shop         Classroom         Work Sink         5         2         EA         \$3,861 <td>Vocational Shop</td> <td>Classroom</td> <td>Work Sink</td> <td></td> <td>5</td> <td>3</td> <td>EA</td> <td>\$5,792</td> <td></td> | Vocational Shop     | Classroom              | Work Sink                           |                 | 5    | 3        | EA   | \$5,792  |                                 |
| Vocational Shop         Classroom         Work Sink         5         1         EA         \$1,931           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         5         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         23         EA         \$44,402           Vocational Shop         Classroom         Work Sink         6         2         EA         \$772           Vocational Shop         Classroom         Work Sink         5         2         EA         \$3,861  | Vocational Shop     | Classroom              | Work Sink                           |                 | 4    | 5        | EA   | \$19,305 |                                 |
| Vocational ShopClassroomWork Sink53EA\$5,792Vocational ShopClassroomWork Sink53EA\$5,792Vocational ShopClassroomWork Sink71EA\$0Vocational ShopClassroomWork Sink75EA\$0Vocational ShopClassroomWork Sink610EA\$3,861Vocational ShopClassroomWork Sink71EA\$0Vocational ShopClassroomWork Sink43EA\$11,583Vocational ShopClassroomWork Sink523EA\$44,402Vocational ShopClassroomWork Sink62EA\$772Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 4    | 3        | EA   | \$11,583 |                                 |
| Vocational Shop         Classroom         Work Sink         5         3         EA         \$5,792           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         5         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         7         1         EA         \$0           Vocational Shop         Classroom         Work Sink         4         3         EA         \$11,583           Vocational Shop         Classroom         Work Sink         5         23         EA         \$44,402           Vocational Shop         Classroom         Work Sink         6         2         EA         \$772           Vocational Shop         Classroom         Work Sink         5         2         EA         \$3,861           Vocational Shop         Classroom         Work Sink         5         2         EA         \$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 5    | 1        | EA   | \$1,931  |                                 |
| Vocational ShopClassroomWork Sink71EA\$0Vocational ShopClassroomWork Sink75EA\$0Vocational ShopClassroomWork Sink610EA\$3,861Vocational ShopClassroomWork Sink71EA\$0Vocational ShopClassroomWork Sink43EA\$11,583Vocational ShopClassroomWork Sink523EA\$44,402Vocational ShopClassroomWork Sink62EA\$772Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 5    | 3        | EA   | \$5,792  |                                 |
| Vocational ShopClassroomWork Sink75EA\$0Vocational ShopClassroomWork Sink610EA\$3,861Vocational ShopClassroomWork Sink71EA\$0Vocational ShopClassroomWork Sink43EA\$11,583Vocational ShopClassroomWork Sink523EA\$44,402Vocational ShopClassroomWork Sink62EA\$772Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 5    | 3        | EΑ   | \$5,792  |                                 |
| Vocational ShopClassroomWork Sink610EA\$3,861Vocational ShopClassroomWork Sink71EA\$0Vocational ShopClassroomWork Sink43EA\$11,583Vocational ShopClassroomWork Sink523EA\$44,402Vocational ShopClassroomWork Sink62EA\$772Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 7    | 1        | EA   | \$0      |                                 |
| Vocational ShopClassroomWork Sink71EA\$0Vocational ShopClassroomWork Sink43EA\$11,583Vocational ShopClassroomWork Sink523EA\$44,402Vocational ShopClassroomWork Sink62EA\$772Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861  | Vocational Shop     | Classroom              | Work Sink                           |                 | 7    | 5        | EA   | \$0      |                                 |
| Vocational ShopClassroomWork Sink43EA\$11,583Vocational ShopClassroomWork Sink523EA\$44,402Vocational ShopClassroomWork Sink62EA\$772Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861  | Vocational Shop     | Classroom              | Work Sink                           |                 | 6    | 10       | EΑ   | \$3,861  |                                 |
| Vocational ShopClassroomWork Sink523EA\$44,402Vocational ShopClassroomWork Sink62EA\$772Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 7    | 1        | EA   | \$0      |                                 |
| Vocational ShopClassroomWork Sink62EA\$772Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 4    | 3        | EA   | \$11,583 |                                 |
| Vocational ShopClassroomWork Sink52EA\$3,861Vocational ShopClassroomWork Sink52EA\$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 5    | 23       | EA   | \$44,402 |                                 |
| Vocational Shop Classroom Work Sink 5 2 EA \$3,861   | Vocational Shop     | Classroom              | Work Sink                           |                 | 6    | 2        | EA   | \$772    |                                 |
|  | Vocational Shop     | Classroom              | Work Sink                           |                 | 5    | 2        | EA   | \$3,861  |                                 |
| Vocational Shop Classroom Work Sink 7 10 EA \$0  | Vocational Shop     | Classroom              | Work Sink                           |                 | 5    | 2        | EA   | \$3,861  |                                 |
|  | Vocational Shop     | Classroom              | Work Sink                           |                 | 7    | 10       | EA   | \$0      |                                 |
| Vocational ShopClassroomWork Sink61EA\$386   | Vocational Shop     | Classroom              | Work Sink                           |                 | 6    | 1        | EA   | \$386    |                                 |

INTERIOR Sub Total

\$1,000,820

Building: Main Category: ROOM

| Group      | Sub Group                        | Item                        | Location                            | Rank | Quantity | Unit | Cost F   | Reason |
|------------|----------------------------------|-----------------------------|-------------------------------------|------|----------|------|----------|--------|
| ADMIN_WALL | Administrative<br>Suites/Offices | Administrative Office Walls | 140 - School Nurse / Social<br>Work | 6    | 611      | SF   | \$1,442  |        |
| Casework   | Classroom                        | Casework                    |                                     | 5    | 13       | LF   | \$2,324  |        |
| Casework   | Classroom                        | Casework                    |                                     |      |          | LF   | \$0      |        |
| Casework   | Classroom                        | Casework                    |                                     | 5    | 13       | LF   | \$2,324  |        |
| Casework   | Classroom                        | Casework                    |                                     | 5    | 9        | LF   | \$1,609  |        |
| Casework   | Classroom                        | Casework                    |                                     | 5    | 185      | LF   | \$33,069 |        |
| Casework   | Classroom                        | Casework                    |                                     | 5    | 13       | LF   | \$2,324  |        |





Building: Main Category: ROOM

| Group    | Sub Group | Item     | Location R | Rank | Quantity | Unit | Cost Reason |
|----------|-----------|----------|------------|------|----------|------|-------------|
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 30       | LF   | \$5,363     |
| Casework | Classroom | Casework |            | 5    | 60       | LF   | \$10,725    |
| Casework | Classroom | Casework |            |      |          | LF   | \$0         |
| Casework | Classroom | Casework |            |      |          | LF   | \$0         |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            |      |          | LF   | \$0         |
| Casework | Classroom | Casework |            | 6    | 27       | LF   | \$965       |
| Casework | Classroom | Casework |            | 5    | 35       | LF   | \$6,256     |
| Casework | Classroom | Casework |            | 5    | 185      | LF   | \$33,069    |
| Casework | Classroom | Casework |            | 5    | 29       | LF   | \$5,184     |
| Casework | Classroom | Casework |            | 5    | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework |            | 5    | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework |            | 5    | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework |            | 5    | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            |      |          | LF   | \$0         |
| Casework | Classroom | Casework |            |      |          | LF   | \$0         |
| Casework | Classroom | Casework |            |      |          | LF   | \$0         |
| Casework | Classroom | Casework |            | 5    | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework |            | 5    | 185      | LF   | \$33,069    |
| Casework | Classroom | Casework |            | 6    | 78       | LF   | \$2,789     |
| Casework | Classroom | Casework |            | 5    | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 27       | LF   | \$4,826     |
| Casework | Classroom | Casework |            | 5    | 60       | LF   | \$10,725    |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework |            | 5    | 37       | LF   | \$6,614     |
| Casework | Classroom | Casework |            | 5    | 32       | LF   | \$5,720     |



Building: Main Category: ROOM

| Group    | Sub Group | Item        | Location F | Rank ( | Quantity | Unit | Cost Reason |
|----------|-----------|-------------|------------|--------|----------|------|-------------|
| Casework | Classroom | Casework    |            | 5      | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework    |            | 5      | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework    |            | 5      | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework    |            | 5      | 9        | LF   | \$1,609     |
| Casework | Classroom | Casework    |            | 5      | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework    |            | 5      | 13       | LF   | \$2,324     |
| Casework | Classroom | Casework    |            | 6      | 130      | LF   | \$4,648     |
| Casework | Classroom | Casework    |            | 5      | 110      | LF   | \$19,663    |
| Casework | Classroom | Casework    |            | 5      | 145      | LF   | \$25,919    |
| Casework | Classroom | Casework    |            | 5      | 208      | LF   | \$37,180    |
| Casework | Classroom | Casework    |            | 5      | 72       | LF   | \$12,870    |
| Casework | Classroom | Casework    |            | 5      | 44       | LF   | \$7,865     |
| Casework | Classroom | Casework    |            | 7      | 9        | LF   | \$0         |
| Casework | Classroom | Casework    |            | 5      | 45       | LF   | \$8,044     |
| Casework | Classroom | Casework    |            | 5      | 13       | LF   | \$2,324     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 1,032    | SF   | \$2,214     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 916      | SF   | \$1,965     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 916      | SF   | \$1,965     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 984      | SF   | \$2,111     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 1,032    | SF   | \$2,214     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 1,032    | SF   | \$2,214     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 984      | SF   | \$2,111     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 984      | SF   | \$2,111     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 984      | SF   | \$2,111     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 984      | SF   | \$2,111     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |
| Ceiling  | Classroom | Lay-In/Drop |            | 6      | 720      | SF   | \$1,544     |



Building: Main Category: ROOM

| Group   | Sub Group | Item        | Location | Rank | Quantity | Unit | Cost Reason |
|---------|-----------|-------------|----------|------|----------|------|-------------|
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,032    | SF   | \$2,214     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,032    | SF   | \$2,214     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 624      | SF   | \$1,338     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,032    | SF   | \$2,214     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,032    | SF   | \$2,214     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,472    | SF   | \$3,157     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,420    | SF   | \$3,046     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,260    | SF   | \$2,703     |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 1,180    | SF   | \$0         |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 1,600    | SF   | \$0         |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,265    | SF   | \$2,713     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,032    | SF   | \$2,214     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,032    | SF   | \$2,214     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,128    | SF   | \$2,420     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 984      | SF   | \$2,111     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 408      | SF   | \$875       |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,258    | SF   | \$2,698     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 490      | SF   | \$1,051     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 510      | SF   | \$1,094     |
| Ceiling | Classroom | Lay-In/Drop |          | 4    | 720      | SF   | \$6,795     |
| Ceiling | Classroom | Lay-In/Drop |          | 5    | 1,128    | SF   | \$6,388     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 720      | SF   | \$1,544     |





Building: Main Category: ROOM

| Group       | Sub Group         | Item            | Location  | Rank | Quantity | Unit | Cost Reason |
|-------------|-------------------|-----------------|---|------|----------|------|-------------|
| Ceiling     | Classroom         | Plaster/Drywall |   | 7    | 336      | SF   | \$0         |
| Ceiling     | Classroom         | Plaster/Drywall |   | 7    | 1,600    | SF   | \$0         |
| Ceiling     | Classroom         | Plaster/Drywall |   | 6    | 1,258    | SF   | \$3,562     |
| Ceiling     | Classroom         | Plaster/Drywall |   | 7    | 365      | SF   | \$0         |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 20       | LF   | \$2,431     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 20       | LF   | \$2,431     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 19       | LF   | \$2,309     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 48       | LF   | \$5,834     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 48       | LF   | \$5,834     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 14       | LF   | \$1,702     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    |          | LF   |             |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 8        | LF   | \$972       |
| Chalk Board | Classroom         | Chalk Board     |   | 4    |          | LF   |             |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 6        | LF   | \$729       |
| Chalk Board | Lunchroom         | Chalk Board     | 1st Floor                                       | 4    |          | LF   |             |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 42       | LF   | \$5,105     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 5        | LF   | \$608       |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 48       | LF   | \$5,834     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 28       | LF   | \$3,403     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 48       | LF   | \$5,834     |
| Chalk Board | Multipurpose Room | Chalk Board     | Weight Room between Boys and Girls Locker Rooms | 4    |          | LF   |             |
| Chalk Board | Classroom         | Chalk Board     |   | 4    |          | LF   |             |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 6        | LF   | \$729       |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 31       | LF   | \$3,768     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 31       | LF   | \$3,768     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 31       | LF   | \$3,768     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 20       | LF   | \$2,431     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    |          | LF   |             |
| Chalk Board | Classroom         | Chalk Board     |   | 4    |          | LF   |             |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 18       | LF   | \$2,188     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 27       | LF   | \$3,282     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 8        | LF   | \$972       |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 20       | LF   | \$2,431     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 48       | LF   | \$5,834     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 28       | LF   | \$3,403     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 48       | LF   | \$5,834     |
| Chalk Board | Classroom         | Chalk Board     |   | 4    | 31       | LF   | \$3,768     |





Building: Main Category: ROOM

| Group       | Sub Group | Item                   | Location   | Rank | Quantity | Unit | Cost Reason |  |
|-------------|-----------|------------------------|--|------|----------|------|-------------|--|
| Chalk Board | Classroom | Chalk Board            |  | 4    | 15       | LF   | \$1,823     |  |
| Chalk Board | Classroom | Chalk Board            |  | 4    |          | LF   |             |  |
| Chalk Board | Classroom | Chalk Board            |  | 4    | 8        | LF   | \$972       |  |
| Chalk Board | Classroom | Chalk Board            |  | 4    | 48       | LF   | \$5,834     |  |
| Chalk Board | Classroom | Chalk Board            |  | 4    | 58       | LF   | \$7,050     |  |
| Chalk Board | Classroom | Chalk Board            |  | 4    | 47       | LF   | \$5,713     |  |
| Chalk Board | Classroom | Chalk Board            |  | 4    | 27       | LF   | \$3,282     |  |
| Chalk Board | Classroom | Chalk Board            |  | 4    | 28       | LF   | \$3,403     |  |
| Chalk Board | Classroom | Chalk Board            |  | 4    | 5        | LF   | \$608       |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 7    | 1        | EA   | \$0         |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 4    | 1        | EA   | \$10,725    |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 4    | 1        | EA   | \$10,725    |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 4    | 1        | EA   | \$10,725    |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 6    | 1        | EA   | \$2,681     |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 7    | 1        | EA   | \$0         |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 7    | 1        | EA   | \$0         |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 7    | 1        | EA   | \$0         |  |
| CLASSROOM   | Classroom | Eye Wash Station       |  | 7    | 1        | EA   | \$0         |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 6    | 8        | SF   | \$183       |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 6    | 12       | SF   | \$275       |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 7    | 1        | SF   | \$0         |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 7    | 32       | SF   | \$0         |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 7    | 1        | SF   | \$0         |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 7    | 34       | SF   | \$0         |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 6    | 8        | SF   | \$183       |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 6    | 10       | SF   | \$229       |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 7    | 2        | SF   | \$0         |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 6    | 8        | SF   | \$183       |  |
| CLASSROOM   | Classroom | Science Lab Elements   |  | 6    | 8        | SF   | \$183       |  |
| Corridors   | Corridors | Ceiling                | 169  |      |          | SF   | \$0         |  |
| Corridors   | Corridors | Concrete Epoxy/Painted | stairs at boys gym   | 6    | 54       | SF   | \$255       |  |
| Corridors   | Corridors | Drinking Fountains     | North West Stairs  |      |          | EA   | \$0         |  |
| Corridors   | Corridors | Drinking Fountains     | Auditorium Stair (Southeast                                  | )    |          | EA   | \$0         |  |
| Corridors   | Corridors | Drinking Fountains     | West Stairs  |      |          | EA   | \$0         |  |
| Corridors   | Corridors | Drinking Fountains     | South East Stairs  |      |          | EA   | \$0         |  |
| Corridors   | Corridors | Drinking Fountains     | balcony behind music<br>rooms (used as a teachers<br>lounge) |      |          | EA   | \$0         |  |





Building: Main Category: ROOM

| Group     | Sub Group | Item               | Location   | Rank | Quantity | Unit | Cost  | Reason |
|-----------|-----------|--------------------|--|------|----------|------|-------|--------|
| Corridors | Corridors | Drinking Fountains | stairs from behind music rooms                               |      |          | EA   | \$0   |        |
| Corridors | Corridors | Drinking Fountains | stairs at boys gym   |      |          | EA   | \$0   |        |
| Corridors | Corridors | Drinking Fountains | South West Stairs  |      |          | EA   | \$0   |        |
| Corridors | Corridors | Drinking Fountains | Auditorium Stair (Southwest)                                 |      |          | EA   | \$0   |        |
| Corridors | Corridors | Drinking Fountains | Center South Stairs  |      |          | EA   | \$0   |        |
| Corridors | Corridors | Drinking Fountains | Center North Stairs  |      |          | EA   | \$0   |        |
| Corridors | Corridors | Drinking Fountains | Auditorium Lobby and<br>Vestibule                            |      |          | EA   | \$0   |        |
| Corridors | Corridors | Drinking Fountains | Stairs between the gyms                                      |      |          | EA   | \$0   |        |
| Corridors | Corridors | Drop/Lay-In        | 3rd Floor  | 7    | 11,820   | SF   | \$0   |        |
| Corridors | Corridors | Drop/Lay-In        | 2nd Floor  | 7    | 11,820   | SF   | \$0   |        |
| Corridors | Corridors | Drop/Lay-In        | North West Stairs  | 6    | 290      | SF   | \$622 |        |
| Corridors | Corridors | Drop/Lay-In        | Center North Stairs  | 7    | 207      | SF   | \$0   |        |
| Corridors | Corridors | Drop/Lay-In        | 1st Floor  | 7    | 14,500   | SF   | \$0   |        |
| Corridors | Corridors | Drop/Lay-In        | Center South Stairs  | 7    | 207      | SF   | \$0   |        |
| Corridors | Corridors | Drop/Lay-In        | South West Stairs  | 7    | 207      | SF   | \$0   |        |
| Corridors | Corridors | Drop/Lay-In        | West Stairs  | 6    | 290      | SF   | \$622 |        |
| Corridors | Corridors | Drop/Lay-In        | South East Stairs  | 6    | 99       | SF   | \$212 |        |
| Corridors | Corridors | Floors             | 169  |      |          | SF   | \$0   |        |
| Corridors | Corridors | Floors             | Auditorium Lobby and<br>Vestibule                            | 7    | 500      | SF   | \$0   |        |
| Corridors | Corridors | Lay-In             | 2nd Floor  | 7    | 11,820   | EA   | \$0   |        |
| Corridors | Corridors | Lay-In             | 3rd Floor  | 7    | 11,820   | EA   | \$0   |        |
| Corridors | Corridors | Lay-In             | 1st Floor  | 7    | 14,500   | EA   | \$0   |        |
| Corridors | Corridors | Lighting           | 169  |      |          | EA   | \$0   |        |
| Corridors | Corridors | Pendant/Surface    | balcony behind music<br>rooms (used as a teachers<br>lounge) | 7    | 755      | EA   | \$0   |        |
| Corridors | Corridors | Pendant/Surface    | North West Stairs  | 7    | 387      | EA   | \$0   |        |
| Corridors | Corridors | Pendant/Surface    | Auditorium Stair (Southwest)                                 | 7    | 2        | EA   | \$0   |        |
| Corridors | Corridors | Pendant/Surface    | Auditorium Stair (Southeast)                                 | 7    | 2        | EA   | \$0   |        |
| Corridors | Corridors | Pendant/Surface    | stairs at boys gym   | 6    | 168      | EA   | \$120 |        |
| Corridors | Corridors | Pendant/Surface    | stairs from behind music rooms                               | 6    | 275      | EA   | \$197 |        |
| Corridors | Corridors | Pendant/Surface    | South East Stairs  | 7    | 452      | EA   | \$0   |        |
| Corridors | Corridors | Pendant/Surface    | West Stairs  | 7    | 387      | EA   | \$0   |        |
| Corridors | Corridors | Pendant/Surface    | South West Stairs  | 6    | 733      | EA   | \$524 |        |
| Corridors | Corridors | Pendant/Surface    | Center North Stairs  | 6    | 733      | EA   | \$524 |        |



Building: Main Category: ROOM

| Group     | Sub Group | Item            | Location   | Rank | Quantity | Unit | Cost R   | leason |
|-----------|-----------|-----------------|--|------|----------|------|----------|--------|
| Corridors | Corridors | Pendant/Surface | Auditorium Lobby and<br>Vestibule                            | 7    | 26       | EA   | \$0      |        |
| Corridors | Corridors | Pendant/Surface | Stairs between the gyms                                      | 6    | 757      | EA   | \$541    |        |
| Corridors | Corridors | Pendant/Surface | Center South Stairs  | 6    | 733      | EA   | \$524    |        |
| Corridors | Corridors | Plaster/Drywall | Center South Stairs  | 6    | 1,295    | SF   | \$3,056  |        |
| Corridors | Corridors | Plaster/Drywall | Center North Stairs  | 6    | 1,295    | SF   | \$3,056  |        |
| Corridors | Corridors | Plaster/Drywall | South West Stairs  | 6    | 1,295    | SF   | \$3,056  |        |
| Corridors | Corridors | Plaster/Drywall | North West Stairs  | 6    | 1,025    | SF   | \$2,418  |        |
| Corridors | Corridors | Plaster/Drywall | West Stairs  | 6    | 1,025    | SF   | \$2,418  |        |
| Corridors | Corridors | Plaster/Drywall | South East Stairs  | 6    | 1,230    | SF   | \$2,902  |        |
| Corridors | Corridors | Plaster/Drywall | 1st Floor  | 6    | 15,000   | SF   | \$35,393 |        |
| Corridors | Corridors | Plaster/Drywall | 2nd Floor  | 6    | 11,820   | SF   | \$27,889 |        |
| Corridors | Corridors | Plaster/Drywall | balcony behind music<br>rooms (used as a teachers<br>lounge) | 6    | 285      | SF   | \$672    |        |
| Corridors | Corridors | Plaster/Drywall | stairs from behind music rooms                               | 6    | 690      | SF   | \$1,628  |        |
| Corridors | Corridors | Plaster/Drywall | Stairs between the gyms                                      | 6    | 960      | SF   | \$2,265  |        |
| Corridors | Corridors | Plaster/Drywall | stairs at boys gym   | 6    | 1,860    | SF   | \$4,389  |        |
| Corridors | Corridors | Plaster/Drywall | Auditorium Stair (Southeast)                                 | 6    | 1,800    | SF   | \$4,247  |        |
| Corridors | Corridors | Plaster/Drywall | Auditorium Stair (Southwest)                                 | 6    | 1,800    | SF   | \$4,247  |        |
| Corridors | Corridors | Plaster/Drywall | Auditorium Lobby and Vestibule                               | 6    | 4,840    | SF   | \$11,420 |        |
| Corridors | Corridors | Plaster/Drywall | 3rd Floor  | 6    | 11,820   | SF   | \$27,889 |        |
| Corridors | Corridors | Splined         | balcony behind music<br>rooms (used as a teachers<br>lounge) | 6    | 755      | SF   | \$1,619  |        |
| Corridors | Corridors | Splined         | stairs from behind music rooms                               | 6    | 190      | SF   | \$408    |        |
| Corridors | Corridors | Stair Handrails | 3rd Floor  |      |          | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | stairs from behind music rooms                               | 6    | 60       | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | Stairs between the gyms                                      | 6    | 82       | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | South East Stairs  | 6    | 123      | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | Auditorium Stair (Southeast)                                 | 7    | 60       | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | Center North Stairs  | 6    | 110      | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | stairs at boys gym   | 6    | 146      | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | 1st Floor  |      |          | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | West Stairs  | 6    | 101      | LF   | \$0      |        |
| Corridors | Corridors | Stair Handrails | North West Stairs  | 6    | 101      | LF   | \$0      |        |



Building: Main Category: ROOM

| Group     | Sub Group | Item                   | Location   | Rank | Quantity | Unit | Cost Reason |
|-----------|-----------|------------------------|--|------|----------|------|-------------|
| Corridors | Corridors | Stair Handrails        | Center South Stairs  | 6    | 110      | LF   | \$0         |
| Corridors | Corridors | Stair Handrails        | 169  |      |          | LF   | \$0         |
| Corridors | Corridors | Stair Handrails        | Auditorium Lobby and<br>Vestibule                            |      |          | LF   | \$0         |
| Corridors | Corridors | Stair Handrails        | Auditorium Stair (Southwest)                                 | 7    | 60       | LF   | \$0         |
| Corridors | Corridors | Stair Handrails        | balcony behind music<br>rooms (used as a teachers<br>lounge) |      |          | LF   | \$0         |
| Corridors | Corridors | Stair Handrails        | South West Stairs  | 6    | 110      | LF   | \$0         |
| Corridors | Corridors | Stair Handrails        | 2nd Floor  |      |          | LF   | \$0         |
| Corridors | Corridors | Stairs                 | Auditorium Lobby and Vestibule                               |      |          | EA   | \$0         |
| Corridors | Corridors | Stairs                 | 3rd Floor  |      |          | EA   | \$0         |
| Corridors | Corridors | Stairs                 | 2nd Floor  |      |          | EA   | \$0         |
| Corridors | Corridors | Stairs                 | 1st Floor  |      |          | EA   | \$0         |
| Corridors | Corridors | Stairs                 | 169  |      |          | EA   | \$0         |
| Corridors | Corridors | Stairs                 | balcony behind music<br>rooms (used as a teachers<br>lounge) |      |          | EA   | \$0         |
| Corridors | Corridors | Structural Glazed Tile | 1st Floor  | 7    | 15,000   | SF   | \$0         |
| Corridors | Corridors | Structural Glazed Tile | South East Stairs  | 6    | 1,115    | SF   | \$7,972     |
| Corridors | Corridors | Structural Glazed Tile | 2nd Floor  | 7    | 11,820   | SF   | \$0         |
| Corridors | Corridors | Structural Glazed Tile | 3rd Floor  | 7    | 11,820   | SF   | \$0         |
| Corridors | Corridors | Structural Glazed Tile | balcony behind music<br>rooms (used as a teachers<br>lounge) | 6    | 555      | SF   | \$3,968     |
| Corridors | Corridors | Structural Glazed Tile | stairs from behind music rooms                               | 6    | 690      | SF   | \$4,934     |
| Corridors | Corridors | Structural Glazed Tile | Center North Stairs  | 6    | 1,280    | SF   | \$9,152     |
| Corridors | Corridors | Structural Glazed Tile | South West Stairs  | 6    | 1,280    | SF   | \$9,152     |
| Corridors | Corridors | Structural Glazed Tile | stairs at boys gym   | 6    | 1,665    | SF   | \$11,905    |
| Corridors | Corridors | Structural Glazed Tile | West Stairs  | 6    | 1,010    | SF   | \$7,222     |
| Corridors | Corridors | Structural Glazed Tile | Center South Stairs  | 6    | 1,280    | SF   | \$9,152     |
| Corridors | Corridors | Structural Glazed Tile | North West Stairs  | 6    | 1,010    | SF   | \$7,222     |
| Corridors | Corridors | Structural Glazed Tile | Stairs between the gyms                                      | 6    | 950      | SF   | \$6,793     |
| Corridors | Corridors | Student Lockers        | Center South Stairs  |      |          | EA   | \$0         |
| Corridors | Corridors | Student Lockers        | 2nd Floor  | 6    | 458      | EA   | \$65,494    |
| Corridors | Corridors | Student Lockers        | Auditorium Stair (Southwest)                                 |      |          | EA   | \$0         |
| Corridors | Corridors | Student Lockers        | Auditorium Stair (Southeast)                                 |      |          | EA   | \$0         |
| Corridors | Corridors | Student Lockers        | stairs at boys gym   |      |          | EA   | \$0         |



Building: Main Category: ROOM

| Group     | Sub Group | Item                   | Location   | Rank | Quantity | Unit | Cost     | Reason |
|-----------|-----------|------------------------|--|------|----------|------|----------|--------|
| Corridors | Corridors | Student Lockers        | Stairs between the gyms                                      |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | stairs from behind music rooms                               |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | 169  |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | 3rd Floor  | 6    | 458      | EA   | \$65,494 |        |
| Corridors | Corridors | Student Lockers        | Auditorium Lobby and<br>Vestibule                            |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | South East Stairs  |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | 1st Floor  | 6    | 340      | EA   | \$48,620 |        |
| Corridors | Corridors | Student Lockers        | West Stairs  |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | North West Stairs  |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | South West Stairs  |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | Center North Stairs  |      |          | EA   | \$0      |        |
| Corridors | Corridors | Student Lockers        | balcony behind music<br>rooms (used as a teachers<br>lounge) |      |          | EA   | \$0      |        |
| Corridors | Corridors | Terrazzo               | 3rd Floor  | 7    | 1,773    | SF   | \$0      |        |
| Corridors | Corridors | Terrazzo               | Center South Stairs  | 6    | 377      | SF   | \$2,135  |        |
| Corridors | Corridors | Terrazzo               | 2nd Floor  | 7    | 1,773    | SF   | \$0      |        |
| Corridors | Corridors | Terrazzo               | 1st Floor  | 7    | 1,990    | SF   | \$0      |        |
| Corridors | Corridors | Terrazzo               | South East Stairs  | 6    | 278      | SF   | \$1,574  |        |
| Corridors | Corridors | Terrazzo               | West Stairs  | 6    | 210      | SF   | \$1,189  |        |
| Corridors | Corridors | Terrazzo               | stairs from behind music rooms                               | 6    | 60       | SF   | \$340    |        |
| Corridors | Corridors | Terrazzo               | Stairs between the gyms                                      | 6    | 682      | SF   | \$3,862  |        |
| Corridors | Corridors | Terrazzo               | stairs at boys gym   | 6    | 962      | SF   | \$5,448  |        |
| Corridors | Corridors | Terrazzo               | Auditorium Stair (Southeast)                                 | 7    | 456      | SF   | \$0      |        |
| Corridors | Corridors | Terrazzo               | South West Stairs  | 6    | 377      | SF   | \$2,135  |        |
| Corridors | Corridors | Terrazzo               | Auditorium Lobby and<br>Vestibule                            | 7    | 796      | SF   | \$0      |        |
| Corridors | Corridors | Terrazzo               | Center North Stairs  | 6    | 377      | SF   | \$2,135  |        |
| Corridors | Corridors | Terrazzo               | Auditorium Stair (Southwest)                                 | 7    | 456      | SF   | \$0      |        |
| Corridors | Corridors | Terrazzo               | North West Stairs  | 6    | 210      | SF   | \$1,189  |        |
| Corridors | Corridors | Tile Ceramic/Porcelain | 1st Floor  | 7    | 1,260    | SF   | \$0      |        |
| Corridors | Corridors | Tile/Sheet Flooring    | Auditorium Lobby and<br>Vestibule                            | 6    | 1,360    | SF   | \$1,945  |        |
| Corridors | Corridors | Tile/Sheet Flooring    | South East Stairs  | 6    | 45       | SF   | \$64     |        |
| Corridors | Corridors | Tile/Sheet Flooring    | 1st Floor  | 6    | 11,250   | SF   | \$16,088 |        |
| Corridors | Corridors | Tile/Sheet Flooring    | 2nd Floor  | 6    | 10,050   | SF   | \$14,372 |        |



Building: Main Category: ROOM

| Group Group       | Sub Group | Item                | Location   | Rank | Quantity | Unit | Cost     | Reason |
|-------------------|-----------|---------------------|--|------|----------|------|----------|--------|
| Corridors         | Corridors | Tile/Sheet Flooring | 3rd Floor  | 6    | 10,050   | SF   | \$14,372 |        |
| Corridors         | Corridors | Tile/Sheet Flooring | balcony behind music<br>rooms (used as a teachers<br>lounge) | 6    | 755      | SF   | \$1,080  |        |
| Corridors         | Corridors | Tile/Sheet Flooring | stairs from behind music rooms                               | 6    | 170      | SF   | \$243    |        |
| Corridors         | Corridors | Tile/Sheet Flooring | West Stairs  | 6    | 60       | SF   | \$86     |        |
| Corridors         | Corridors | Tile/Sheet Flooring | North West Stairs  | 6    | 60       | SF   | \$86     |        |
| Corridors         | Corridors | Tile/Sheet Flooring | South West Stairs  | 6    | 175      | SF   | \$250    |        |
| Corridors         | Corridors | Tile/Sheet Flooring | Center South Stairs  | 6    | 175      | SF   | \$250    |        |
| Corridors         | Corridors | Tile/Sheet Flooring | Center North Stairs  | 6    | 175      | SF   | \$250    |        |
| Corridors         | Corridors | Walls               | Auditorium Lobby and Vestibule                               | 7    | 500      | SF   | \$0      |        |
| Corridors         | Corridors | Walls               | Auditorium Lobby and Vestibule                               | 7    | 400      | SF   | \$0      |        |
| Corridors         | Corridors | Walls               | 169  |      |          | SF   | \$0      |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | North West Stairs  | 6    | 97       | SF   | \$275    |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | Auditorium Lobby and Vestibule                               | 7    | 2,652    | SF   | \$0      |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | Center North Stairs  | 7    | 526      | SF   | \$0      |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | Center South Stairs  | 7    | 526      | SF   | \$0      |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | stairs from behind music rooms                               | 6    | 85       | SF   | \$241    |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | South West Stairs  | 7    | 526      | SF   | \$0      |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | South East Stairs  | 6    | 353      | SF   | \$999    |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | Auditorium Stair (Southwest)                                 | 7    | 288      | SF   | \$0      |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | Auditorium Stair (Southeast)                                 | 7    | 288      | SF   | \$0      |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | Stairs between the gyms                                      | 6    | 757      | SF   | \$2,143  |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | West Stairs  | 6    | 97       | SF   | \$275    |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | stairs at boys gym   | 6    | 1,068    | SF   | \$3,024  |        |
| Stairs            | Corridors | Terrazzo            | stairs from behind music rooms                               | 6    | 26       | SF   | \$294    |        |
| Stairs            | Corridors | Terrazzo            | Auditorium Stair (Southwest)                                 | 7    | 52       | SF   | \$0      |        |
| Stairs            | Corridors | Terrazzo            | South East Stairs  | 6    | 62       | SF   | \$702    |        |
| Stairs            | Corridors | Terrazzo            | Stairs between the gyms                                      | 6    | 46       | SF   | \$521    |        |
| Stairs            | Corridors | Terrazzo            | stairs at boys gym   | 6    | 73       | SF   | \$827    |        |
| Stairs            | Corridors | Terrazzo            | North West Stairs  | 6    | 56       | SF   | \$634    |        |
| Stairs            | Corridors | Terrazzo            | South West Stairs  | 6    | 58       | SF   | \$657    |        |
| Stairs            | Corridors | Terrazzo            | Center South Stairs  | 6    | 58       | SF   | \$657    |        |
| Stairs            | Corridors | Terrazzo            | Auditorium Stair (Southeast)                                 | 7    | 52       | SF   | \$0      |        |



Building: Main Category: ROOM

| Group  | Sub Group | Item       | Location            | Rank | Quantity | Unit | Cost     | Reason |
|--------|-----------|------------|---------------------|------|----------|------|----------|--------|
| Stairs | Corridors | Terrazzo   | West Stairs         | 6    | 56       | SF   | \$634    |        |
| Stairs | Corridors | Terrazzo   | Center North Stairs | 6    | 58       | SF   | \$657    |        |
| Floor  | Classroom | Tile/Sheet |                     | 5    | 1,420    | SF   | \$8,041  |        |
| Floor  | Classroom | Tile/Sheet |                     | 5    | 720      | SF   | \$4,077  |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 984      | SF   | \$1,407  |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 916      | SF   | \$12,968 |        |
| Floor  | Classroom | Tile/Sheet |                     | 5    | 720      | SF   | \$4,077  |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 1,128    | SF   | \$15,969 |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 720      | SF   | \$10,193 |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 510      | SF   | \$729    |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 1,258    | SF   | \$1,799  |        |
| Floor  | Classroom | Tile/Sheet |                     | 5    | 408      | SF   | \$2,310  |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 984      | SF   | \$13,930 |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 1,128    | SF   | \$15,969 |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 1,032    | SF   | \$14,610 |        |
| Floor  | Classroom | Tile/Sheet |                     | 5    | 1,032    | SF   | \$5,844  |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 720      | SF   | \$1,030  |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 720      | SF   | \$10,193 |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 490      | SF   | \$6,937  |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 720      | SF   | \$10,193 |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 720      | SF   | \$1,030  |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 984      | SF   | \$1,407  |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 916      | SF   | \$12,968 |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 1,472    | SF   | \$20,839 |        |
| Floor  | Classroom | Tile/Sheet |                     | 5    | 1,260    | SF   | \$7,135  |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 1,180    | SF   | \$1,687  |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 1,600    | SF   | \$2,288  |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 1,265    | SF   | \$17,909 |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 1,032    | SF   | \$14,610 |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 336      | SF   | \$4,757  |        |
| Floor  | Classroom | Tile/Sheet |                     | 4    | 1,258    | SF   | \$17,810 |        |
| Floor  | Classroom | Tile/Sheet |                     | 6    | 1,600    | SF   | \$2,288  |        |
| Floor  | Classroom | Wood       |                     | 5    | 720      | SF   | \$10,193 |        |
| Floor  | Classroom | Wood       |                     | 5    | 720      | SF   | \$10,193 |        |
| Floor  | Classroom | Wood       |                     | 7    | 720      | SF   | \$0      |        |
| Floor  | Classroom | Wood       |                     | 5    | 720      | SF   | \$10,193 |        |
| Floor  | Classroom | Wood       |                     | 5    | 720      | SF   | \$10,193 |        |



Building: Main Category: ROOM

| Group           | Sub Group                       | Item              | Location                             | Rank | Quantity | Unit | Cost     | Reason |
|-----------------|---------------------------------|-------------------|--------------------------------------|------|----------|------|----------|--------|
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 984      | SF   | \$13,930 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 1,032    | SF   | \$14,610 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 7    | 1,032    | SF   | \$0      |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 4    | 624      | SF   | \$16,490 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 1,032    | SF   | \$14,610 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 1,032    | SF   | \$14,610 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 1,032    | SF   | \$14,610 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 1,032    | SF   | \$14,610 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 984      | SF   | \$13,930 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 984      | SF   | \$13,930 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 365      | SF   | \$5,167  |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| Floor           | Classroom                       | Wood              |                                      | 5    | 720      | SF   | \$10,193 |        |
| GYM_CEILING     | Standard Dedicated<br>Gymnasium | Gymnasia Ceiling  | 2nd fl North Gym- under construction |      | 7,520    | SF   | \$0      |        |
| GYM_FLOOR       | Standard Dedicated<br>Gymnasium | Gymnasia Floor    | 2nd fl North Gym- under construction |      | 7,520    | SF   | \$0      |        |
| GYM_FLOOR       | Competition Gymnasiu            | m Gymnasia Floor  | 2nd fl South gym                     | 6    | 2,065    | SF   | \$15,592 |        |
| GYM_LIGHT       | Standard Dedicated<br>Gymnasium | Gymnasia Lighting | 2nd fl North Gym- under construction |      |          | EA   | \$0      |        |
| GYM_WALL        | Standard Dedicated<br>Gymnasium | Gymnasia Walls    | 2nd fl North Gym- under construction |      |          | SF   | \$0      |        |
| LIBRARY_CEILING | Library                         | Drop/Lay-In       | 2nd Floor                            | 6    | 2,300    | SF   | \$4,934  |        |





Building: Main Category: ROOM

| Group         | Sub Group | Item            | Location  | Rank | Quantity | Unit | Cost Reason |
|---------------|-----------|-----------------|-----------|------|----------|------|-------------|
| LIBRARY_FLOOR | Library   | Library Floor   | 2nd Floor | 6    | 2,300    | SF   | \$3,289     |
| LIBRARY_WALL  | Library   | Plaster/Drywall | 2nd Floor | 6    | 2,015    |      | \$4,754     |
| Lighting      | Classroom | Lay-In          |           | 7    | 27       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 18       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 33       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 30       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 40       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 42       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 33       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 24       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 15       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 11       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 8        | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 27       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 33       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 6    | 30       | EA   | \$2,145     |
| Lighting      | Classroom | Lay-In          |           | 6    | 30       | EA   | \$2,145     |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 32       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 36       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 30       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |
| Lighting      | Classroom | Lay-In          |           | 7    | 21       | EA   | \$0         |



Building: Main Category: ROOM

| Group        | Sub Group         | Item            | Location  | Rank | Quantity | Unit | Cost Reason |
|--------------|-------------------|-----------------|---|------|----------|------|-------------|
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EA   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 17       | EA   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 27       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 30       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 30       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 15       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 27       | EA   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 27       | EA   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 30       | EA   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EA   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 30       | EA   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 30       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 27       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 30       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EΑ   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 27       | EA   | \$0         |
| Lighting     | Classroom         | Lay-In          |   | 7    | 21       | EA   | \$0         |
| Lighting     | Classroom         | Pendant/Surface |   | 7    | 21       | EA   | \$0         |
| Lighting     | Classroom         | Pendant/Surface |   | 7    | 5        | EA   | \$0         |
| Lighting     | Classroom         | Pendant/Surface |   | 7    | 24       | EA   | \$0         |
| Lighting     | Classroom         | Pendant/Surface |   | 7    | 5        | EA   | \$0         |
| LUNCH_FLOOR  | Multipurpose Room | Lunchroom Floor | Weight Room between Boys and Girls Locker Rooms | 6    | 2,065    | SF   | \$2,953     |
| Marker Board | Classroom         | Marker Board    |   | 7    | 23       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board    |   | 7    | 20       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board    |   | 7    | 20       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board    |   | 7    | 20       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board    |   | 7    | 24       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board    |   | 7    | 8        | LF   | \$0         |
| Marker Board | Classroom         | Marker Board    |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board    |   |      |          | LF   | \$0         |





Building: Main Category: ROOM

| Group        | Sub Group         | Item         | Location  | Rank | Quantity | Unit | Cost Reason |
|--------------|-------------------|--------------|---|------|----------|------|-------------|
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 26       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 40       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 20       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 43       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 40       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 26       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 15       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 24       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 16       | LF   | \$0         |
| Marker Board | Multipurpose Room | Marker Board | Weight Room between Boys and Girls Locker Rooms |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 24       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 28       | LF   | \$0         |
| Marker Board | Lunchroom         | Marker Board | 1st Floor                                       |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 20       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 16       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 16       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 42       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 37       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 45       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 6    | 35       | LF   | \$1,001     |
| Marker Board | Classroom         | Marker Board |   | 6    | 16       | LF   | \$458       |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 12       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 6    | 24       | LF   | \$686       |
| Marker Board | Classroom         | Marker Board |   | 7    | 16       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 48       | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   |      |          | LF   | \$0         |
| Marker Board | Classroom         | Marker Board |   | 7    | 30       | LF   | \$0         |



Building: Main Category: ROOM

| Group          | Sub Group                       | Item                | Location                             | Rank | Quantity | Unit | Cost Reason |
|----------------|---------------------------------|---------------------|--------------------------------------|------|----------|------|-------------|
| Marker Board   | Classroom                       | Marker Board        |                                      | 7    | 16       | LF   | \$0         |
| Marker Board   | Classroom                       | Marker Board        |                                      | 7    | 16       | LF   | \$0         |
| Marker Board   | Classroom                       | Marker Board        |                                      | 7    | 28       | LF   | \$0         |
| Marker Board   | Classroom                       | Marker Board        |                                      | 6    | 28       | LF   | \$801       |
| Marker Board   | Classroom                       | Marker Board        |                                      | 7    | 48       | LF   | \$0         |
| Marker Board   | Classroom                       | Marker Board        |                                      | 7    | 48       | LF   | \$0         |
| Marker Board   | Classroom                       | Marker Board        |                                      | 6    | 20       | LF   | \$572       |
| Marker Board   | Classroom                       | Marker Board        |                                      | 7    | 8        | LF   | \$0         |
| Marker Board   | Classroom                       | Marker Board        |                                      |      |          | LF   | \$0         |
| Marker Board   | Classroom                       | Marker Board        |                                      | 7    | 48       | LF   | \$0         |
| RESTROOM_FLOOR | Adult Standard Student Restroom | Restroom Floor      | 2nd FL - Boys                        |      | 400      | SF   | \$0         |
| RESTROOM_FLOOR | Adult Standard Student Restroom | Restroom Floor      | 3rd FL - Boys                        |      | 400      | SF   | \$0         |
| RESTROOM_FLOOR | Adult Standard Student Restroom | Restroom Floor      | 3rd FL - Girls                       |      | 400      | SF   | \$0         |
| RESTROOM_FLOOR | Adult Standard Student Restroom | Restroom Floor      | 1st FL - Boys                        |      | 400      | SF   | \$0         |
| RESTROOM_FLOOR | Staff Restroom                  | Restroom Floor      | Kitchen Office Restroom              |      | 42       | SF   | \$0         |
| RESTROOM_WALL  | Locker/Shower Room              | Restroom Walls      | Boys Locker Room                     | 7    | 700      | SF   | \$0         |
| RESTROOM_WALL  | Staff Restroom                  | Restroom Walls      | Kitchen Office Restroom              | 6    | 416      | SF   | \$1,059     |
| RESTROOM_WALL  | Staff Restroom                  | Restroom Walls      | 2nd FL - Men's Faculty               | 7    | 390      | SF   | \$0         |
| RESTROOM_WALL  | Staff Restroom                  | Restroom Walls      | 1st FL - Men's Faculty               | 7    | 390      | SF   | \$0         |
| RESTROOM_WALL  | Staff Restroom                  | Restroom Walls      | 2nd FL - Women's Faculty             | 7    | 390      | SF   | \$0         |
| RESTROOM_WALL  | Staff Restroom                  | Restroom Walls      | 1st FL - Women's Faculty             | 7    | 390      | SF   | \$0         |
| RESTROOM_WALL  | Adult Standard Student Restroom | Restroom Walls      | Auditorium- Womens                   | 7    | 348      | SF   | \$0         |
| RESTROOM_WALL  | Adult Standard Student Restroom | Restroom Walls      | Auditorium- Mens                     | 7    | 432      | SF   | \$0         |
| RESTROOM_WALL  | Staff Restroom                  | Restroom Walls      | 144 - Health / Social Work<br>Office | 5    | 338      | SF   | \$5,317     |
| RESTROOM_WALL  | Locker/Shower Room              | Restroom Walls      | Girls Locker Room                    | 6    | 245      | SF   | \$624       |
| THEATER_FLOOR  | Auditorium - Dedicated          | Auditorium Floor    | 1st Floor                            | 7    | 5,560    | SF   | \$0         |
| THEATER_LIGHT  | Auditorium - Dedicated          | Auditorium Lighting | 1st Floor                            | 7    | 120      | EA   | \$0         |
| Vall           | Classroom                       | Plaster/Drywall     |                                      | 6    | 880      | SF   | \$2,076     |
| Vall           | Classroom                       | Plaster/Drywall     |                                      | 6    | 740      | SF   | \$1,746     |
| Vall           | Classroom                       | Plaster/Drywall     |                                      | 6    | 1,080    | SF   | \$2,548     |
| Wall           | Classroom                       | Plaster/Drywall     |                                      | 5    | 1,726    | SF   | \$8,145     |
| Wall           | Classroom                       | Plaster/Drywall     |                                      | 5    | 1,140    | SF   | \$5,380     |



Building: Main Category: ROOM

| Group | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost Reason |
|-------|-----------|-----------------|----------|------|----------|------|-------------|
| Wall  | Classroom | Plaster/Drywall |          | 5    | 1,140    | SF   | \$5,380     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,005    | SF   | \$0         |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 908      | SF   | \$2,142     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,080    | SF   | \$2,548     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,690    | SF   | \$3,988     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,140    | SF   | \$2,690     |
| Wall  | Classroom | Plaster/Drywall |          | 5    | 1,726    | SF   | \$8,145     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,140    | SF   | \$2,690     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 5    | 880      | SF   | \$4,153     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,340    | SF   | \$3,162     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 790      | SF   | \$1,864     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,000    | SF   | \$2,360     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,690    | SF   | \$3,988     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 2,010    | SF   | \$0         |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,140    | SF   | \$2,690     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,140    | SF   | \$2,690     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,140    | SF   | \$2,690     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 880      | SF   | \$2,076     |



Building: Main Category: ROOM

| Group | Sub Group | Item            | Location | Rank       | Quantity | Unit | Cost        | Reason |
|-------|-----------|-----------------|----------|------------|----------|------|-------------|--------|
| Wall  | Classroom | Plaster/Drywall |          | 6          | 880      | SF   | \$2,076     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 880      | SF   | \$2,076     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 1,080    | SF   | \$2,548     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 1,080    | SF   | \$2,548     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 880      | SF   | \$2,076     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 1,080    | SF   | \$2,548     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7          | 1,700    | SF   | \$0         |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 738      | SF   | \$1,741     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 1,740    | SF   | \$4,106     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 2,010    | SF   | \$4,743     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7          | 580      | SF   | \$0         |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 1,469    | SF   | \$3,466     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 880      | SF   | \$2,076     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 880      | SF   | \$2,076     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7          | 1,140    | SF   | \$0         |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 1,140    | SF   | \$2,690     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 880      | SF   | \$2,076     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 880      | SF   | \$2,076     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 1,080    | SF   | \$2,548     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6          | 1,469    | SF   | \$3,466     |        |
| Wall  | Classroom | Wall            |          | 7          | 1,108    | SF   | \$0         |        |
| Wall  | Classroom | Wall            |          |            |          | SF   | \$0         |        |
| Wall  | Classroom | Wall            |          | 7          | 1,005    | SF   | \$0         |        |
|       |           |                 | ROC      | OM Sub Tot | al       |      | \$1,886,683 |        |

Building Main Sub Total \$12,275,340

**Building: SITE Category: SITE** 

| Group          | Sub Group | Item               | Location                | Rank | Quantity | Unit | Cost     | Reason        |
|----------------|-----------|--------------------|-------------------------|------|----------|------|----------|---------------|
| Athletic       |           | Baseball - Natural | North East              | 6    | 56,900   | SF   | \$32,547 |               |
| Civil/Drainage |           | Catch Basin        | NW Lot                  | 7    | 4        | EA   | \$0      |               |
| Civil/Drainage |           | Catch Basin        | Light Wells             | 6    | 7        | EA   | \$3,804  | rod and clean |
| Civil/Drainage |           | Site Manhole       | Entire Site             | 7    | 24       | EA   | \$0      |               |
| Fencing        |           | Chain Link         | Site North- Driver's Ed | 6    | 145      | LF   | \$2,080  |               |
| Fencing        |           | Chain Link         | Backstop at NE          | 5    | 40       | LF   | \$1,430  |               |



**Building: SITE** Category: SITE

| Group       | Sub Group | Item                                 | Location   | Rank   | Quantity | Unit | Cost      | Reason                               |
|-------------|-----------|--------------------------------------|--|--------|----------|------|-----------|--------------------------------------|
| Fencing     |           | Ornamental Iron                      | Entire Site  | 7      | 1,200    | LF   | \$0       |                                      |
| Fencing     |           | Ornamental Iron                      | Site NE  | 5      | 13       | LF   | \$810     | bent                                 |
| Landscape   |           | Asphalt Play Area/Hardscape          | Courtyard  | 7      | 6,292    | SF   | \$0       | paths                                |
| Landscape   |           | Benches                              | Courtyard  | 6      | 1        | EA   | \$236     |                                      |
| Landscape   |           | Benches                              | Courtyard  | 7      | 8        | EA   | \$0       |                                      |
| Landscape   |           | Grass                                | Site East and West   | 4      | 5,730    | SF   | \$22,697  |                                      |
| Landscape   |           | Grass                                | Entire Site  | 7      | 70,700   | SF   | \$0       |                                      |
| Landscape   |           | Hardscape - Concrete                 | East Side of Boiler House<br>and East Site at NE<br>Entrance | 4      | 1,750    | SF   | \$33,033  |                                      |
| Landscape   |           | Hardscape - Concrete                 | Entire Site  | 7      | 11,820   | SF   | \$0       |                                      |
| Landscape   |           | Hardscape - Pavers                   | Courtyard  | 7      | 1,380    | SF   | \$0       |                                      |
| Landscape   |           | Parkway trees                        | Entire Site  | 7      | 62       | EA   | \$0       |                                      |
| Landscape   |           | Planting Beds/ Areas                 | Entire Site  | 5      | 4,848    | SF   | \$0       | staging areas for construction       |
| Landscape   |           | Retaining Wall - Concrete            | Top of Light Wells in Courtyard                              | 5      | 74       | SF   | \$5,762   | wall/curb cracked                    |
| Landscape   |           | Retaining Wall - Concrete            | East Access to Basement at<br>Light Wells                    | 6      | 2,509    | SF   | \$59,200  |                                      |
| Landscape   |           | Trash Receptacles                    | Entire Site  | 7      | 2        | EA   | \$0       |                                      |
| Parking Lot |           | Asphalt                              | Site NW  | 5      | 1,600    | SF   | \$4,530   | potholes and cracked/displaced areas |
| Parking Lot |           | Asphalt                              | North West   | 7      | 76,190   | SF   | \$0       |                                      |
| Sidewalks   |           | Internal Walks                       | Courtyard and Site North                                     | 7      | 150      | LF   | \$0       |                                      |
| Sidewalks   |           | Perimeter Sidewalks                  | Entire Site  | 7      | 29,880   | SF   | \$0       |                                      |
| Sidewalks   |           | Perimeter Sidewalks                  | Site - East  | 4      | 320      | SF   | \$6,040   |                                      |
| Signage     |           | Flag Pole                            | Site ¿ South   | 7      | 1        | EA   | \$0       |                                      |
| Signage     |           | Marquee - Free Standing Back Lighted | South East Site  | 6      | 1        | EA   | \$0       |                                      |
|             |           |                                      | SITE S   | Sub To | tal      |      | \$172,168 |                                      |

SITE Sub Total \$172,168



3436 W Wilson Ave Chicago, IL 60625

**Building: SITE Category: SITE** 

Group Sub Group Item Location Rank Quantity Unit Cost Reason

Total Campus Need <sup>2 3</sup> \$12,447,509

<sup>&</sup>lt;sup>1</sup> It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

<sup>&</sup>lt;sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>&</sup>lt;sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.



3436 W Wilson Ave Chicago, IL 60625

| Room Su        | oom Summary  |       |                |                 |    |                         |                            |                        |                |                |                |           |               |          |
|----------------|--------------|-------|----------------|-----------------|----|-------------------------|----------------------------|------------------------|----------------|----------------|----------------|-----------|---------------|----------|
| Room<br>Number | Room<br>Size | Voice | Data<br>Outlet | Elect<br>Outlet |    | Glaze<br>Window<br>Area | Operable<br>Window<br>Area | No. of<br>Window<br>AC | Window<br>Stop | Smart<br>Board | Power<br>Strip | Room Type | Room Sub Type | Location |
| Building:      | Main         |       |                |                 |    |                         |                            |                        |                |                |                |           |               | •        |
| 06             | 408          |       |                | 8               | 40 | 60                      | 8                          |                        | Υ              | N              | N              | Classroom |               |          |
| 08             | 720          | 1     | 2              | 22              | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 10             | 1128         | 1     | 2              | 22              | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 11             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 12             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 13             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 14             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 16             | 490          |       |                | 6               | 40 | 54                      | 9                          |                        | N              | N              | N              | Classroom |               |          |
| 17             | 1258         |       | 8              | 16              | 40 | 108                     | 14                         |                        | Υ              | Υ              | Υ              | Classroom |               |          |
| 30             | 984          | 1     | 2              | 60              | 40 | 102                     | 18                         |                        | Υ              | N              | Υ              | Classroom |               |          |
| 32             | 1128         | 1     | 2              | 22              | 40 | 102                     | 25                         |                        | Υ              | N              | N              | Classroom |               |          |
| 44             | 1032         | 1     | 2              | 22              | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 48             | 1032         | 1     | 2              | 22              | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 50             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | Υ              | Classroom |               |          |
| 67             | 1600         | 1     | 2              | 22              | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 68             | 1600         | 1     | 2              | 22              | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 69             | 1180         | 1     | 2              | 22              | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 204            | 1420         |       |                | 14              | 40 | 108                     | 18                         |                        | Υ              | N              | N              | Classroom |               |          |
| 205            | 365          |       |                | 6               | 40 | 18                      | 6                          |                        | Υ              | N              | N              | Classroom |               |          |
| :05            | 1260         |       |                | 14              | 40 | 108                     | 18                         |                        | Υ              | N              | N              | Classroom |               |          |
| 208            | 916          |       | 2              | 24              | 40 | 108                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 10             | 1472         |       | 2              | 24              | 40 | 240                     | 32                         |                        | Υ              | N              | N              | Classroom |               |          |
| 11             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 13             | 720          | 1     | 2              |                 | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 14             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 16             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 17             | 720          | 1     | 6              | 18              | 40 | 108                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 21             | 1258         |       | 8              | 16              | 40 | 108                     | 14                         |                        | Υ              | Υ              | Υ              | Classroom |               |          |
| 26             | 336          |       | 2              | 8               | 40 | 36                      | 6                          |                        | Υ              | N              | N              | Classroom |               |          |
| 28             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | Υ              | Classroom |               |          |
| 29             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | Υ              | Classroom |               |          |
| 30             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | Υ              | Classroom |               |          |
| 31             | 1032         | 1     | 6              | 18              | 40 | 108                     | 17                         |                        | Υ              | N              | N              | Classroom |               |          |
| 32             | 720          | 1     | 2              | 6               | 40 | 102                     | 17                         |                        | Υ              | N              | Υ              | Classroom |               |          |
| 33             | 720          | 1     | 2              |                 | 40 | 102                     | 17                         |                        | Υ              | N              | Υ              | Classroom |               |          |
| 235            | 720          | 1     | 2              | 6               | 40 |                         | 17                         |                        | Υ              | N              | Υ              | Classroom |               |          |



3436 W Wilson Ave Chicago, IL 60625

| Room Su | Room | Voice | Data | Floct | Noise | Glaze          | Operable       | No. of | Window | Smart | Power | Room Type                     | Room Sub Type                   | Location                         |
|---------|------|-------|------|-------|-------|----------------|----------------|--------|--------|-------|-------|-------------------------------|---------------------------------|----------------------------------|
| Number  | Size |       |      |       |       | Window<br>Area | Window<br>Area | Window | Stop   | Board |       | Room Type                     | Room Sub Type                   | Location                         |
| 244     | 1265 | 1     | 2    | 6     | 40    | 102            | 17             |        | Y      | N     | Υ     | Classroom                     |                                 |                                  |
| 246/248 | 1032 | 1     | 6    |       |       | 108            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 250     | 984  | 1     | 2    |       |       | 102            | 18             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 306     | 916  |       | 2    |       |       | 108            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 808     | 510  | 1     | 2    |       | 40    | 84             | 12             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 10      | 984  | 1     | 2    |       | 40    | 102            | 18             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 311     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 312     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 313     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 314     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 315     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 316     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 317     | 1032 | 1     | 6    | 18    | 40    | 108            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 318     | 624  | 1     | 12   | 12    | 40    | 72             | 12             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 19      | 1032 | 1     | 6    | 18    | 40    | 108            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 323     | 1032 | 1     | 6    | 18    | 40    | 108            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 326     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 328     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 329     | 1032 | 1     | 6    | 24    | 40    | 108            | 17             |        | Υ      | Υ     | N     | Classroom                     |                                 |                                  |
| 330     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 331     | 1032 | 1     | 6    | 18    | 40    | 108            | 17             |        | Υ      | N     | N     | Classroom                     |                                 |                                  |
| 332     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 333     | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 35      | 720  | 1     | 2    | 6     | 40    | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 344     | 984  | 1     | 2    |       |       | 102            | 17             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 48      | 984  | 1     | 2    | 38    |       | 102            | 18             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| 350     | 984  | 1     | 2    | 6     | 40    | 102            | 18             |        | Υ      | N     | Υ     | Classroom                     |                                 |                                  |
| Other   | 400  |       |      |       |       |                |                |        | N      | N     | N     | Restroom                      | Adult Standard Student Restroom | 2nd FL - Boys                    |
| Other   | 40   |       |      |       |       |                |                |        | N      | N     | N     | Restroom                      | Staff Restroom                  | 226 - Staff Restroom (abandoned) |
| Other   | 312  |       |      | 8     |       |                |                |        | N      | N     | Υ     | Administrative Suites/Offices |                                 | 215 - Program Office             |
| Other   | 243  |       |      |       |       |                |                |        | N      | N     | N     | Restroom                      | Adult Standard Student Restroom | 2nd FL - Girls West              |
| Other   | 126  |       |      | 4     |       |                |                |        | N      | N     | N     | Administrative Suites/Offices |                                 | 242 - ROTC Office                |
| Other   | 100  |       |      |       |       |                |                |        | N      | N     | N     | Restroom                      | Staff Restroom                  | 239 A - Coach Restroom           |
| Other   | 100  |       |      | 4     |       |                |                |        | N      | N     | N     | Administrative Suites/Offices |                                 | 239 B - Coach Office             |
| Other   | 160  |       |      | 4     |       |                |                |        | N      | N     | N     | Administrative Suites/Offices |                                 | 209 - English Office             |
| Other   | 160  |       |      | 4     |       |                |                |        | N      | N     | N     | Administrative Suites/Offices |                                 | 237 - Math Office                |
| Other   | 400  |       |      |       |       |                |                |        | N      | N     | N     | Restroom                      | Adult Standard Student Restroom | 1st FL - Girls                   |



3436 W Wilson Ave Chicago, IL 60625

| Room<br>Number | Room<br>Size | Voice<br>Outlet | Data<br>Outlet | Elect<br>Outlet |       | Glaze<br>Window | Operable Window | No. of<br>Window | Window<br>Stop | Smart<br>Board | Power<br>Strip |                               | Room Sub Type                   | Location   |
|----------------|--------------|-----------------|----------------|-----------------|-------|-----------------|-----------------|------------------|----------------|----------------|----------------|-------------------------------|---------------------------------|--|
| rambor         | O IZC        | Odilot          | Outlot         | Outlot          | LOVOI | Area            | Area            | AC               | Оюр            | Dould          | Ottip          |                               |                                 |  |
| Other          | 160          |                 |                | 4               |       |                 |                 |                  | N              | N              | N              | Administrative Suites/Offices |                                 | 309 - Counselors Office                                |
| Other          | 243          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Adult Standard Student Restroom | 3rd FL - Girls East                                    |
| Other          | 400          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Adult Standard Student Restroom | 3rd FL - Boys  |
| Other          | 1332         |                 |                | 14              |       |                 |                 |                  | N              | N              | Υ              | Administrative Suites/Offices |                                 | 320 - Administrative Office / Teacher Resource         |
| Other          | 400          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Adult Standard Student Restroom | 3rd FL - Girls   |
| Other          | 126          |                 |                | 4               |       |                 |                 |                  | N              | N              | N              | Administrative Suites/Offices |                                 | 342 - Psychologist Office                              |
| Other          | 300          |                 |                | 8               |       |                 |                 |                  | N              | N              | N              | Administrative Suites/Offices |                                 | 346 -Lab Prep Room                                     |
| Other          | 160          |                 |                | 4               |       |                 |                 |                  | N              | N              | N              | Administrative Suites/Offices |                                 | 239 C - Gym Office                                     |
| Other          | 11820        |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | 2nd Floor  |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | Center North Stairs                                    |
| Other          | 200          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Staff Restroom                  | 1st FL - Women's Faculty                               |
| Other          | 2065         |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Lunch & Multipurpose Room     | Multipurpose Room               | Weight Room between Boys and Girls Locker Rooms        |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | Center South Stairs                                    |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | South West Stairs                                      |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | North West Stairs                                      |
| Other          | 200          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Staff Restroom                  | 2nd FL - Women's Faculty                               |
| Other          | 350          |                 |                | 8               |       |                 |                 |                  | N              | N              | N              | Administrative Suites/Offices |                                 | 126 - Administrative Office1                           |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | West Stairs  |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | South East Stairs                                      |
| Other          | 200          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Staff Restroom                  | 1st FL - Men's Faculty                                 |
| Other          | 200          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Staff Restroom                  | 2nd FL - Men's Faculty                                 |
| Other          | 4272         |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Locker/Shower Room              | Girls Locker Room                                      |
| Other          | 400          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Adult Standard Student Restroom | 1st FL - Boys  |
| Other          | 280          |                 |                | 6               |       |                 |                 |                  | N              | N              | N              | Administrative Suites/Offices |                                 | 140 - School Nurse / Social Work                       |
| Other          | 11820        |                 |                |                 |       |                 |                 |                  | N              | Ν              | N              | Corridors                     |                                 | 3rd Floor  |
| Other          | 42           |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Restroom                      | Staff Restroom                  | Kitchen Office Restroom                                |
| Other          | 7910         |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Pool & Natatorium             |                                 | 1st fl- under construction                             |
| Other          | 755          |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | balcony behind music rooms (used as a teachers lounge) |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | stairs from behind music rooms                         |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | Stairs between the gyms                                |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | stairs at boys gym                                     |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | Auditorium Stair (Southeast)                           |
| Other          |              |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Corridors                     |                                 | Auditorium Stair (Southwest)                           |
| Other          | 9585         |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Gymnasia                      | Competition Gymnasium           | 2nd fl South gym                                       |
| Other          | 7520         |                 |                |                 |       |                 |                 |                  | N              | N              | N              | Gymnasia                      | Standard Dedicated Gymnasium    | 2nd fl North Gym- under                                |



3436 W Wilson Ave Chicago, IL 60625

| Room     | Room  | Voice  | Data   | Elect  | Noise | Glaze | Operable       | No. of       | Window | Smart | Power | Room Type                     | Room Sub Type  | Location                             |
|----------|-------|--------|--------|--------|-------|-------|----------------|--------------|--------|-------|-------|-------------------------------|--|--------------------------------------|
| Number   | Size  | Outlet | Outlet | Outlet |       |       | Window<br>Area | Window<br>AC | Stop   | Board |       | Koom Type                     | TROOM Gub Type   | Location                             |
| Other    | 1680  |        |        |        |       |       |                |              | N      | N     | N     | Kitchen                       | Cooking Kitchen  | 1st Floor                            |
| Other    | 14500 |        |        |        |       |       |                |              | N      | N     | N     | Corridors                     |  | 1st Floor                            |
| Other    | 705   |        |        | 10     |       |       |                |              | N      | N     | Υ     | Administrative Suites/Offices |  | rm 131- counselors office            |
| Other    | 150   |        |        | 4      |       |       |                |              | N      | N     | N     | Administrative Suites/Offices |  | 210 A - Science Prep Office          |
| Other    | 8730  |        |        |        |       |       |                |              | N      | N     | N     | Auditorium & Theater          | Auditorium - Dedicated   | 1st Floor                            |
| Other    | 2652  |        |        |        |       |       |                |              | N      | N     | N     | Corridors                     |  | Auditorium Lobby and Vestibule       |
| Other    | 324   |        |        |        |       |       |                |              | N      | N     | N     | Restroom                      | Adult Standard Student Restroom  | Auditorium- Mens                     |
| Other    | 190   |        |        |        |       |       |                |              | N      | N     | N     | Restroom                      | Adult Standard Student Restroom  | Auditorium- Womens                   |
| Other    | 160   |        |        | 4      |       |       |                |              | N      | N     | N     | Administrative Suites/Offices |  | 337 - History Office                 |
| Other    | 4835  |        |        |        |       |       |                |              | N      | N     | N     | Restroom                      | Locker/Shower Room   | Boys Locker Room                     |
| Other    | 10830 |        |        |        |       |       |                |              | N      | N     | N     | Lunch & Multipurpose Room     | Lunchroom  | 1st Floor                            |
| Other    | 243   |        |        |        |       |       |                |              | N      | N     | N     | Restroom                      | Adult Standard Student Restroom  | 1st FL - Girls West                  |
| Other    | 340   |        |        | 12     |       |       |                |              | N      | N     | Υ     | Administrative Suites/Offices |  | rm 135A- Assistant Principals Office |
| Other    | 80    |        |        | 2      |       |       |                |              | N      | N     | N     | Administrative Suites/Offices | 1  | Pool Office                          |
| Other    | 760   |        |        | 10     |       |       |                |              | N      | N     | Y     | Administrative Suites/Offices |  | rm 135- discipline office            |
| Other    | 160   |        |        | 4      |       |       |                |              | N      | N     | N     | Administrative Suites/Offices |  | 137 - Admin Office                   |
| Other    | 100   |        |        |        |       |       |                |              | N      | N     | N     | Restroom                      | Staff Restroom   | 155 A - Pool Unisex Restroom         |
| Other    | 160   |        |        |        |       |       |                |              | N      | N     | N     | Restroom                      | Staff Restroom   | 144 - Health / Social Work Office    |
| Other    | 705   |        |        | 10     |       |       |                |              | N      | N     | Y     | Administrative Suites/Offices | Ctail 1 tool oo  | rm 129- counselors office            |
| Other    |       |        |        |        |       |       |                |              | N      | N     | N     | Corridors                     |  | 169                                  |
| Other    | 60    |        |        |        |       |       |                |              | N      | N     |       | Restroom                      | Early Childhood Student Restroom   | 169 - Early Childhood                |
| <u> </u> |       |        |        |        |       |       |                |              |        |       |       |                               | Tany communication of the control of | Development Classroom                |
| Other    | 250   |        |        | 4      |       |       |                |              | N      | N     | Υ     | Administrative Suites/Offices |  | Library Staff office in Library      |
| Other    | 2300  |        |        |        |       |       |                |              | N      | N     | N     | Library                       |  | 2nd Floor                            |
| Other    | 224   |        |        | 6      |       |       |                |              | N      | N     | Υ     | Administrative Suites/Offices |  | Prinicpals Office in Main (A)        |
| Other    | 200   |        |        | 6      |       |       |                |              | N      | N     | Υ     | Administrative Suites/Offices |  | Conference room in Main Office (B)   |
| Other    | 150   |        |        | 4      |       |       |                |              | N      | N     | N     | Administrative Suites/Offices |  | 144 A - Science Prep Office          |
| Other    | 114   |        |        | 4      |       |       |                |              | N      | N     | Υ     | Administrative Suites/Offices |  | Office C in Main Office              |
| Other    | 114   |        |        | 4      |       |       |                |              | N      | N     | Υ     | Administrative Suites/Offices |  | Office D in Main Office              |
| Other    | 1350  |        |        | 10     |       |       |                |              | N      | N     | Υ     | Administrative Suites/Offices |  | Main Office                          |
| Other    | 200   |        |        | 4      |       |       |                |              | N      | N     | N     | Administrative Suites/Offices |  | 242 - ROTC Office                    |
| Other    | 150   |        |        | 4      |       |       |                |              | N      | N     | N     | Administrative Suites/Offices |  | 208 A - Science Prep Office          |
| Other    | 340   |        |        | 6      |       |       |                |              | N      | N     | Y     | Administrative Suites/Offices | <del> </del>   | rm 131A                              |