

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

Rank 7: The item/system is new or in good condition and no work is required.

Rank 6: The item/system requires general cleaning and/or routine maintenance.

Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.

Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.

Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.

Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.

Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main

Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|-----------|--|--|------|----------|------|----------|----------------------------|
| Chimney | | Brick Chimney - Concrete/ Mortar Liner | top of chimney | 5 | 15 | LF | \$26,813 | bulging brick |
| Chimney | | Brick Chimney - Concrete/ Mortar Liner | Chimney | 6 | 20 | LF | \$10,010 | strapped, cracks at ladder |
| Chimney | | Brick Chimney - Concrete/ Mortar Liner | Chimney | 6 | 49 | LF | \$24,525 | cracks |
| Doors | | Exterior FRP Door | Entire Building | 6 | 25 | EA | \$13,921 | |
| Doors | | Exterior Steel Door | Upper Roof Access and Courtyard basement | 5 | 2 | EA | \$2,180 | |
| Doors | | Exterior Steel Door | Entire Building | 6 | 5 | EA | \$1,652 | |
| Doors | | Overhead Rolling / Garage Door | Entire Building | 6 | 17 | EA | \$17,457 | |
| Entrance | | Concrete Exterior Stairs | Entire Building | 6 | 722 | LF | \$77,435 | |
| Entrance | | Concrete Ramp | Entry 9 | 6 | 64 | LF | \$8,923 | |
| Entrance | | Ramp Handrails | Entry 9 | 6 | 130 | LF | \$0 | |
| Entrance | | Stair Handrails | Entry 8 and S. gym | 5 | 38 | LF | \$305 | |
| Entrance | | Stair Handrails | Entire Building | 6 | 108 | LF | \$0 | |
| Entrance | | Stone Stairs | Entry North of gym | 6 | 8 | LF | \$1,430 | |

Building: Main
Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|-----------|---|--|------|----------|------|-----------|--|
| Entrance | | Stone Stairs | Threshold and courtyard entry | 5 | 68 | LF | \$29,172 | stairs cracked and worn |
| Foundation | | Concrete Foundation | Pool, Boiler Room, and Courtyard | 5 | 330 | LF | \$147,318 | cracks and seepage |
| Foundation | | Concrete Foundation | Entire Building | 7 | 1,500 | LF | \$0 | |
| Lighting | | Exterior Lights - Parapet or Roof Mounted | Entire Building | 6 | 7 | EA | \$3,504 | |
| Lighting | | Exterior Lights - Wall Mounted | Entire Building | 6 | 18 | EA | \$3,861 | |
| Lintels | | Lintels - Concrete | Courtyard Basement | 6 | 1 | LF | \$0 | |
| Lintels | | Lintels - Steel | South over gym roof | 4 | 35 | LF | \$15,265 | brick core visible |
| Lintels | | Lintels - Steel | Entire Building | 6 | 2,122 | LF | \$80,110 | |
| Lintels | | Lintels - Terra Cotta | Entry 9 | 5 | 10 | LF | \$3,933 | open joints |
| Lintels | | Lintels - Terra Cotta | Lower windows and doors | 6 | 635 | LF | \$0 | |
| Parapet | | Coping - Terra Cotta | 1958 bldg, multiple locations | 5 | 30 | LF | \$5,363 | |
| Parapet | | Coping - Terra Cotta | Roofs | 6 | 2,742 | LF | \$0 | seal joints |
| Parapet | | Coping - Terra Cotta | south 1 story roof P | 4 | 16 | LF | \$4,228 | |
| Parapet | | Parapet > 30" Height | 1939 building | 5 | 654 | LF | \$262,329 | cracked, spalled |
| Parapet | | Parapet > 30" Height | 1958 building | 6 | 517 | LF | \$134,185 | |
| Parapet | | Parapet 16" to 30" Height | 1939 building | 5 | 927 | LF | \$297,467 | cracked, spalled |
| Parapet | | Parapet 16" to 30" Height | 1958 building | 6 | 690 | LF | \$143,269 | |
| Roof System | | Exterior Downspouts | 1 story roof sw of gym | 6 | 4 | LF | \$74 | |
| Roof System | | Interior Downspouts | Entire Building | 6 | 600 | LF | \$0 | |
| Roof System | | Interior Downspouts | 1939 building and gym | 5 | 130 | LF | \$13,943 | frozen at drain, 1 blocked per engineer |
| Roof System | | Metal Roof | North Shed | 5 | 190 | SF | \$3,396 | rusty |
| Roof System | | Modified Bitumen Roof | 1 story roofs at courtyard, north, west and south of gym | 5 | 2,360 | SF | \$27,842 | courtyard and north roofs are mossy; west and south roofs of gym are ponding |
| Roof System | | Modified Bitumen Roof | Roofs | 6 | 75,890 | SF | \$537,187 | |
| Roof System | | Roof Structure: Steel with Clay Tile Arch | Roofs | 7 | 78,250 | SF | \$0 | |
| Superstructure | | Concrete | First Floor and Basement | 7 | 129,000 | SF | \$0 | |
| Superstructure | | Steel with Clay Tile Arch | Upper Floors | 7 | 121,000 | SF | \$0 | |
| Walls | | Brick | West above Auditorium Entry | 5 | 100 | SF | \$2,265 | shelf angle |
| Walls | | Brick | Courtyard and West Entry Towers and West of Gym | 5 | 1,500 | SF | \$33,977 | cracks and piers |
| Walls | | Brick | Entire Building | 7 | 37,375 | SF | \$0 | |
| Walls | | Brick | North Shed | 4 | 275 | SF | \$20,764 | crumbling |
| Walls | | Brick | East above Roof P and South about Gym | 5 | 625 | SF | \$14,157 | repoint, cracks |

Building: Main
Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------------------|-----------|---|--|------|----------|------|--------------------|-------------------------------|
| Walls | | Brick | Courtyard- all walls | 5 | 30,975 | SF | \$701,621 | remove ivy, repoint NW corner |
| Walls | | Brick | Penthouse | 5 | 3,185 | SF | \$72,144 | cracks at corners |
| Walls | | Stone - Cut | base of building | 6 | 2,932 | SF | \$41,928 | |
| Walls | | Terra Cotta | West Main Entry | 5 | 700 | SF | \$175,175 | open joints |
| Walls | | Terra Cotta | Decorative bands at penthouses and west door surrounds | 6 | 790 | SF | \$22,594 | |
| Windows | | Windows - Casement Aluminum Double-pane | 1st and 2nd floor | 5 | 7,185 | SF | \$165,420 | |
| Windows | | Windows - Casement Lexan | top floor | 4 | 17,723 | SF | \$2,040,690 | |
| Windows | | Windows - Casement Steel | Rooftop Penthouses | 4 | 54 | SF | \$14,780 | cracked glass, gaps at AC |
| Windows | | Windows - Decorative | Courtyard and South over roof P | 6 | 736 | SF | \$4,210 | glass block |
| Windows | | Windows - Sash Aluminum | Courtyard basement stairwell | 4 | 88 | SF | \$11,711 | wood |
| EXTERIOR Sub Total | | | | | | | \$5,218,529 | |

Building: Main
Category: ELECTRICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------|-----------|---|-----------------|------|----------|------|-----------|--------|
| Emergency System | | Automatic Transfer switch | Basement | 6 | 1 | EA | \$1,430 | |
| Emergency System | | Automatic Transfer switch | Mechanical Room | 6 | 1 | EA | \$1,430 | |
| Emergency System | | Emergency A/C power - Auditorium and aisle lighting | 1st Floor | 6 | 8,123 | SF | \$11,035 | |
| Emergency System | | Emergency A/C power - Corridors and Stairs | Entire Building | 6 | 38,041 | SF | \$16,320 | |
| Emergency System | | Emergency A/C power - Gym and Lunch rooms | 2nd Floor | 6 | 11,631 | SF | \$6,154 | |
| Emergency System | | Emergency A/C power - Gym and Lunch rooms | 1st Floor | 6 | 8,200 | SF | \$4,339 | |
| Emergency System | | Emergency A/C power - Students Toilets | Entire Building | 6 | 8,855 | SF | \$3,799 | |
| Emergency System | | Emergency generator 60 to 100 KW diesel - Outdoor | North Courtyard | 6 | 1 | EA | \$8,151 | |
| Emergency System | | Exit Signs - Auditorium | 1st Floor | 6 | 7 | EA | \$1,632 | |
| Emergency System | | Exit Signs - Corridors and Stairs | Entire Building | 6 | 38 | EA | \$8,857 | |
| Emergency System | | Exit Signs - Lunchroom - Gym - multipurpose rooms | 2nd Floor | 6 | 5 | EA | \$1,165 | |
| Emergency System | | Exit Signs - Lunchroom - Gym - multipurpose rooms | 1st Floor | 6 | 4 | EA | \$932 | |
| Emergency System | | Independent Electrical Service for emergency power | Electrical Room | 6 | 1 | EA | \$1,430 | |
| Emergency System | | Public Announcement System | Main Office | 5 | 383,000 | SF | \$547,690 | |
| Emergency System | | Security System - Intrusion detection | Basement | 6 | 383,000 | SF | \$355,999 | |
| Main Service | | Main Electrical service - Live Front - 2000 to 3000 A 120/208/3PH | Electrical Room | 6 | 1 | EA | \$24,310 | |

Building: Main
Category: ELECTRICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------------|-----------|---|---------------------------|------|----------|------|--------------------|--------|
| Main Service | | Main Electrical service - Live Front - 2000 to 3000 A 277/480/3PH | Electrical Room | 6 | 1 | EA | \$30,388 | |
| Power Distribution | | Lighting and power panels | Basement | 4 | 1 | EA | \$5,434 | |
| Power Distribution | | Lighting and power panels | 1st Floor | 4 | 2 | EA | \$10,868 | |
| Power Distribution | | Lighting and power panels | Entire Building | 6 | 25 | EA | \$17,875 | |
| Power Distribution | | Main distribution panels 400-600 amp | Basement | 6 | 4 | EA | \$5,720 | |
| Power Distribution | | Main distribution panels 400-600 amp | 3rd Floor Electrical room | 6 | 1 | EA | \$1,430 | |
| Power Distribution | | Main distribution panels above 600 amp | Basement | 6 | 2 | EA | \$4,290 | |
| Power Distribution | | Main distribution panels above 600 amp | Mechanical Room | 6 | 2 | EA | \$4,290 | |
| Power Distribution | | Main distribution panels less than 400 amp | 3rd Floor Electrical room | 6 | 3 | EA | \$3,647 | |
| Power Distribution | | Main distribution panels less than 400 amp | Basement | 6 | 2 | EA | \$2,431 | |
| Power Distribution | | Transformers 277/480-120/208 | Electrical Room | 6 | 1 | EA | \$1,144 | |
| Power Distribution | | Transformers 277/480-120/208 | Elev. Machine room | 6 | 1 | EA | \$1,144 | |
| ELECTRICAL Sub Total | | | | | | | \$1,083,332 | |

Building: Main
Category: FIRE PROTECTION

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------------------------|-----------|--------------------------|-----------------|------|----------|------|-----------------|--------|
| Fire Alarm | | Fire Alarm Strobe Lights | Entire Building | 6 | 250,000 | SF | \$89,375 | |
| FIRE PROTECTION Sub Total | | | | | | | \$89,375 | |

Building: Main
Category: MECHANICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------------|-----------|---|-----------------|------|----------|------|-----------|--------|
| Air Conditioning | | Chillers - Water Cooled - Centrifugal 201-300 tons | Mechanical Room | 4 | 1 | EA | \$233,090 | |
| Air Conditioning | | Chillers - Water Cooled - Centrifugal greater than 400 tons | Mechanical Room | 6 | 1 | EA | \$35,750 | |
| Air Conditioning | | Condensing Unit - Ground Mounted less than 5 tons | Basement | 6 | 1 | EA | \$715 | |
| Air Conditioning | | Cooling Tower - Spray Type - greater than 300 tons | Roof | 4 | 1 | EA | \$55,770 | |
| Air Conditioning | | Window A/C Unit | Gym Office | 6 | 1 | EA | \$215 | |
| Air Handling Systems | | Air Handling Unit Package - Single Zone - Steam 4,000 to 8,000 cfm | Basement | 5 | 1 | EA | \$15,730 | |
| Air Handling Systems | | Air Handling Unit Package - Single Zone - Steam 8,001 to 12,000 cfm | Basement | 5 | 1 | EA | \$21,450 | |
| Air Handling Systems | | Air Intake - Built Up Air Handling Unit | Roof | 5 | 5 | EA | \$80,080 | |
| Air Handling Systems | | Air intake for all Air Handling Units except built up AHU | East Façade | 6 | 1 | EA | \$1,430 | |

Building: Main
Category: MECHANICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------------|-----------|---|-----------------|------|----------|------|-----------|--------|
| Air Handling Systems | | Air intake for all Air Handling Units except built up AHU | Roof | 6 | 1 | EA | \$1,430 | |
| Air Handling Systems | | Fan Coil Unit - Electric | Basement | 6 | 1 | EA | \$1,187 | |
| Air Handling Systems | | Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm | Basement | 5 | 2 | EA | \$71,500 | |
| Air Handling Systems | | Multi Zone Built Up Air Handling Unit - Steam above 35,000 cfm | Basement | 5 | 3 | EA | \$171,600 | |
| Air Handling Systems | | Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm | Basement | 5 | 2 | EA | \$25,740 | |
| Air Handling Systems | | Multi Zone Built Up Air Handling Unit Auxiliaries - Steam above 35,000 cfm | Basement | 5 | 3 | EA | \$64,350 | |
| Air Handling Systems | | Reheat Boxes With Hot Water Coils | Basement | 6 | 125 | EA | \$123,338 | |
| Air Handling Systems | | Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft | Entire Building | 6 | 500 | LF | \$31,460 | |
| Air Handling Systems | | Return Fans - Indoor 10,001 to 20,000 CFM | Attic | 6 | 1 | EA | \$2,431 | |
| Air Handling Systems | | Return Fans - Indoor 5,000 to 10,000 CFM | Basement | 4 | 1 | EA | \$9,295 | |
| Air Handling Systems | | Return Fans - Indoor 5,000 to 10,000 CFM | Basement | 6 | 1 | EA | \$1,716 | |
| Air Handling Systems | | Return Fans - Indoor greater than 20,000 CFM | Attic | 4 | 4 | EA | \$131,560 | |
| Air Handling Systems | | Roof Top Unit - Single Zone - Gas-Heating 21 to 30 tons | Roof | 6 | 2 | EA | \$12,870 | |
| Air Handling Systems | | Single Zone Built Up Air Handling Unit - Steam above 35,000 cfm | Basement | 5 | 1 | EA | \$57,200 | |
| Air Handling Systems | | Single Zone Built Up Air Handling Unit Auxiliaries - Steam above 35,000 cfm | Basement | 5 | 1 | EA | \$17,160 | |
| Boiler Systems | | Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler greater than 200 HP | Boiler Room | 6 | 3 | EA | \$89,661 | |
| Boiler Systems | | Boiler Auxiliary - Steam Boiler greater than 200 HP | Boiler Room | 6 | 3 | EA | \$9,867 | |
| Boiler Systems | | Chemical Feed System (Steam Boilers) | Boiler Room | 6 | 2 | EA | \$4,290 | |
| Boiler Systems | | Chemical Pot Feeder - Hot Water | Basement | 6 | 1 | EA | \$300 | |
| Boiler Systems | | Chemical Pot Feeder - Hot Water | Basement | 4 | 1 | EA | \$3,003 | |
| Boiler Systems | | Combustion Dampers | Boiler Room | 6 | 3 | EA | \$858 | |
| Boiler Systems | | Feed Water Pumps and Tank - Steam Boilers | Boiler Room | 6 | 1 | EA | \$8,437 | |
| Boiler Systems | | Feed Water Pumps and Tank - Steam Boilers | Mechanical Room | 6 | 1 | EA | \$8,437 | |
| Boiler Systems | | Glycol Feed System | Mechanical Room | 6 | 1 | EA | \$1,087 | |
| Heat Exchangers | | Heat Exchanger - Steam to Hot Water Shell Type | Basement | 4 | 1 | EA | \$21,164 | |
| Heat Exchangers | | Heat Exchanger - Steam to Hot Water Shell Type | Mechanical Room | 6 | 1 | EA | \$4,719 | |
| Heating Devices | | Fin Tube Hot Water | 1st Floor | 5 | 9 | LF | \$772 | |
| Heating Devices | | Radiators - Steam | Entire Building | 5 | 12 | EA | \$7,894 | |
| Heating Devices | | Unit Heater - Electric | Basement | 6 | 1 | EA | \$1,430 | |
| Heating Devices | | Unit Heater - Gas | Boiler Room | 6 | 1 | EA | \$2,145 | |

Building: Main
Category: MECHANICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------------|-----------|---|-----------------|------|----------|------|--------------------|--------|
| Heating Devices | | Wall Heater - Electric | Entire Building | 5 | 22 | EA | \$11,326 | |
| Heating Devices | | Wall Heater - Electric | 1st Floor | 4 | 2 | EA | \$2,059 | |
| Mechanical Plumbing | | Condensate Assembly - Pumps and Tank | Basement | 4 | 4 | EA | \$114,400 | |
| Mechanical Plumbing | | Piping - Condensate - Steel or Galvanized | Basement | 5 | 1,000 | LF | \$32,533 | |
| Mechanical Plumbing | | Piping - Hydronic Supply and Return - Steel or Galvanized | Basement | 5 | 2,000 | LF | \$98,956 | |
| Mechanical Plumbing | | Piping - Steam - Steel or Galvanized | Basement | 5 | 1,000 | LF | \$49,478 | |
| Mechanical Plumbing | | Pumps - Chilled Water 10 to 20 HP | Mechanical Room | 4 | 2 | EA | \$53,625 | |
| Mechanical Plumbing | | Pumps - Condenser Water 10 to 20 HP | Mechanical Room | 4 | 1 | EA | \$26,813 | |
| Mechanical Plumbing | | Pumps - Condenser Water 21-50 HP | Mechanical Room | 6 | 1 | EA | \$5,720 | |
| Mechanical Plumbing | | Pumps - Hot Water 21 - 50 HP | Mechanical Room | 4 | 2 | EA | \$96,525 | |
| Mechanical Plumbing | | Pumps - Hot Water less than 5 HP | Basement | 4 | 1 | EA | \$10,725 | |
| Temperature Control | | Pneumatic System | Entire Building | 5 | 250,000 | SF | \$1,072,500 | |
| Temperature Control | | Thermostats - Pneumatic | Entire Building | 4 | 125 | EA | \$82,225 | |
| Unit Ventilation | | Unit Ventilators - Steam | 2nd Floor | 4 | 2 | EA | \$31,460 | |
| Ventilation | | Exhaust Fan - Indoor | Mechanical Room | 6 | 1 | EA | \$501 | |
| Ventilation | | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof | 6 | 5 | EA | \$2,145 | |
| Ventilation | | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof | 5 | 8 | EA | \$12,012 | |
| Ventilation | | Exhaust Fans - Roof Mounted 500 to 1,500 cfm | Roof | 5 | 2 | EA | \$2,574 | |
| Ventilation | | Exhaust Fans - Roof Mounted 500 to 1,500 cfm | Lower Roof | 4 | 1 | EA | \$2,288 | |
| Ventilation | | Exhaust Fans - Roof Mounted above 8,000 cfm | South Façade | 6 | 3 | EA | \$6,435 | |
| Ventilation | | Exhaust Fans - Roof Mounted above 8,000 cfm | Roof | 5 | 2 | EA | \$12,870 | |
| Ventilation | | Lab Exhaust Hood | 3rd Floor | 4 | 3 | EA | \$98,670 | |
| Ventilation | | Lab Exhaust Hood | 2nd Floor | 6 | 1 | EA | \$3,289 | |
| MECHANICAL Sub Total | | | | | | | \$3,160,257 | |

Building: Main
Category: PLUMBING

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|--|-----------------|------|----------|------|-----------|--------|
| Hot Water | | Hot Water Heater - Gas more than 300,000 BTU/HR | Boiler Room | 6 | 1 | EA | \$6,721 | |
| Hot Water | | Hot Water Heater - Gas more than 300,000 BTU/HR | Boiler Room | 4 | 1 | EA | \$32,032 | |
| Hot Water | | Storage Tank more than 500 gallons | Basement | 5 | 1 | EA | \$11,440 | |
| Piping | | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 4 | 250,000 | SF | \$82,225 | |
| Piping | | Domestic Piping - Cold Water Risers | Entire Building | 4 | 250,000 | SF | \$160,875 | |
| Piping | | Domestic Piping - Hot Water from Riser to fixtures | Entire Building | 4 | 250,000 | SF | \$53,625 | |

Building: Main
Category: PLUMBING

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------------------|-----------|--|-----------------|------|----------|------|--------------------|-----------|
| Piping | | Domestic Piping - Hot Water Return Risers | Entire Building | 4 | 250,000 | SF | \$114,400 | |
| Piping | | Domestic Piping - Hot Water Risers | Entire Building | 4 | 250,000 | SF | \$135,850 | |
| Piping | | Domestic Piping Cold Water Horizontal lines | Entire Building | 4 | 250,000 | SF | \$597,025 | |
| Piping | | Domestic Piping Hot Water Horizontal lines | Entire Building | 4 | 250,000 | SF | \$493,350 | |
| Piping | | Domestic Piping Hot Water Return Lines | Entire Building | 4 | 250,000 | SF | \$286,000 | |
| Piping | | Sanitary Piping | Entire Building | 5 | 250,000 | SF | \$153,725 | |
| Piping | | Storm Piping | Entire Building | 5 | 250,000 | SF | \$117,975 | |
| Piping | | Vent Piping | Entire Building | 5 | 250,000 | SF | \$89,375 | |
| Pool Systems | | Pool Drain Piping | Basement | 6 | 150 | LF | \$2,574 | |
| Pool Systems | | Pool Filtration System | Basement | 4 | 2 | EA | \$434,720 | |
| Pool Systems | | Pool Hot Water Heater - Electric | Basement | 6 | 1 | EA | \$4,004 | |
| Pool Systems | | Pool Hot Water Heater - Steam Heat Exchanger | Basement | 6 | 1 | EA | \$1,301 | |
| Pool Systems | | Pool Supply and Return Piping | Basement | 6 | 200 | LF | \$3,146 | |
| Pumps | | Domestic Booster Pump duplex | Basement | 4 | 2 | EA | \$62,920 | |
| Pumps | | Domestic Booster Pump simplex | Basement | 6 | 1 | EA | \$1,716 | |
| Pumps | | Domestic Booster Pump simplex | Basement | 4 | 1 | EA | \$17,160 | Undersize |
| Pumps | | Sump Pump | Basement | 6 | 2 | EA | \$2,717 | |
| Pumps | | Sump Pump | Basement | 4 | 2 | EA | \$23,738 | |
| PLUMBING Sub Total | | | | | | | \$2,888,614 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|------------------|-----------------------------|------|----------|------|-------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | In Roo 206 | 6 | 140 | SF | \$300 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | RM 304B | 7 | 254 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | prep rm/office btwn 313-311 | 7 | 265 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 101A | 7 | 188 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 112 | 7 | 514 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 112A Conference Room | 7 | 180 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 2nd Floor Nurse's Office | 6 | 336 | SF | \$721 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | in between 312-316 | 6 | 251 | SF | \$538 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|-----------------------------------|--------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 300A | 6 | 170 | SF | \$365 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 208 | 6 | 140 | SF | \$300 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 220 between gyms | 6 | 606 | SF | \$1,300 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 109- FP Library | 7 | 345 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 300 | 6 | 310 | SF | \$665 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Weight Room Office 228C | 7 | 130 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Pool Office | 7 | 78 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 128 | 6 | 172 | SF | \$487 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 112B Conference Room | 7 | 128 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Gym Office 275 | 6 | 275 | SF | \$779 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Weight Room Office 228A | 7 | 130 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Weight Room Office 228D | 7 | 130 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Weight Room Office 228B | 7 | 130 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 2nd Floor Nurse's Office | 5 | 336 | SF | \$1,201 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | rm 300 | 5 | 310 | SF | \$1,108 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 208 | 7 | 140 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | In Roo 206 | 7 | 140 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile Ceramic/Porcelain | Pool Office | 6 | 78 | SF | \$199 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Gym Office 275 | 6 | 275 | SF | \$393 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | rm 109- FP Library | 6 | 345 | SF | \$493 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | rm 220 between gyms | 5 | 100 | SF | \$566 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | rm 220 between gyms | 6 | 506 | SF | \$724 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|-----------------------|-----------------------------|------|----------|------|-------|--------|
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | in between 312-316 | 7 | 251 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Weight Room Office 228D | 6 | 130 | SF | \$186 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Weight Room Office 228B | 6 | 130 | SF | \$186 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Weight Room Office 228C | 6 | 130 | SF | \$186 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 112A Conference Room | 6 | 180 | SF | \$257 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 112 | 7 | 514 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 128 | 7 | 172 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 101A | 7 | 188 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | prep rm/office btwn 313-311 | 6 | 265 | SF | \$379 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | RM 304B | 7 | 254 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 300A | 6 | 170 | SF | \$243 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Weight Room Office 228A | 6 | 130 | SF | \$186 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood | 112B Conference Room | 6 | 128 | SF | \$966 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | RM 304B | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | In Roo 206 | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | rm 300 | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 2nd Floor Nurse's Office | 6 | 4 | SF | \$3 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 112 | 7 | 11 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Pool Office | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | rm 220 between gyms | 6 | 10 | SF | \$7 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | prep rm/office btwn 313-311 | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 300A | 7 | 3 | SF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|----------------------------|-------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | rm 109- FP Library | 7 | 7 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 208 | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 101A | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Weight Room Office 228B | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 128 | 6 | 2 | SF | \$1 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 112B Conference Room | 6 | 2 | SF | \$1 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 112A Conference Room | 6 | 4 | SF | \$3 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Gym Office 275 | 5 | 4 | SF | \$10 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Weight Room Office 228D | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | in between 312-316 | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Weight Room Office 228A | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Weight Room Office 228C | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | Gym Office 275 | 6 | 788 | SF | \$2,254 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 128 | 6 | 447 | SF | \$1,278 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 300A | 6 | 429 | SF | \$1,227 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Weight Room Office 228A | 6 | 475 | SF | \$1,121 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 109- FP Library | 6 | 724 | SF | \$1,708 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 220 between gyms | 6 | 775 | SF | \$1,829 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | In Roo 206 | 6 | 443 | SF | \$1,045 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 208 | 6 | 443 | SF | \$1,045 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 300 | 6 | 715 | SF | \$1,687 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | in between 312-316 | 6 | 550 | SF | \$1,298 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------------|-------------------------------|--------------------------------|-----------------------------|------|----------|------|----------|--------|
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 2nd Floor Nurse's Office | 6 | 730 | SF | \$1,722 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Weight Room Office 228B | 6 | 475 | SF | \$1,121 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Weight Room Office 228C | 6 | 475 | SF | \$1,121 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 112A Conference Room | 7 | 456 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 112 | 7 | 806 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 112B Conference Room | 7 | 338 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | prep rm/office btwn 313-311 | 6 | 450 | SF | \$1,062 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | RM 304B | 6 | 345 | SF | \$814 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Weight Room Office 228D | 6 | 475 | SF | \$1,121 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Structural Glazed Tile | 101A | 7 | 421 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Structural Glazed Tile | Pool Office | 7 | 409 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Structural Glazed Tile | rm 220 between gyms | 6 | 200 | SF | \$1,430 | |
| Auditorium - Dedicated | Auditorium - Dedicated | Balcony Seating | 1st Floor | 7 | 213 | EA | \$0 | |
| Auditorium - Dedicated | Auditorium - Dedicated | Main Floor Seating | 1st Floor | 6 | 498 | EA | \$18,330 | |
| Auditorium - Dedicated | Auditorium - Dedicated | Sound System | 1st Floor | 5 | 1 | EA | \$92,950 | |
| Auditorium - Dedicated | Auditorium - Dedicated | Stage Curtains | 1st Floor | 7 | 8 | EA | \$0 | |
| Auditorium - Dedicated | Auditorium - Dedicated | Stage Lighting System | 1st Floor | 7 | 1 | EA | \$0 | |
| Corridor | | Stairs - Terrazzo | 1st Floor Auditorium | 6 | 26 | LF | \$294 | |
| Doors | | Interior Steel Doors incl hw | Entire Building | 7 | 8 | EA | \$0 | |
| Doors | | Interior Steel Doors incl hw | Entire Building | 6 | 17 | EA | \$4,813 | |
| Doors | | Interior Wood Doors incl hw | Entire Building | 7 | 60 | EA | \$0 | |
| Doors | | Interior Wood Doors incl hw | Entire Building | 6 | 174 | EA | \$49,266 | |
| Doors | | Interior Wood Doors incl hw | Entire Building | 5 | 25 | EA | \$11,798 | |
| Doors | | Interior Wood Doors incl hw | Entire Building | 4 | 7 | EA | \$22,462 | |
| Doors | | Transom Window | Entire Building | 6 | 936 | SF | \$17,400 | |
| Drinking Fountains | Corridors | Single Fountain | 3rd Floor | 6 | 2 | EA | \$772 | |
| Drinking Fountains | Corridors | Single Fountain | 1st Floor | 5 | 2 | EA | \$3,861 | |
| Drinking Fountains | Corridors | Single Fountain | 1st Floor | 6 | 3 | EA | \$1,158 | |
| Drinking Fountains | Corridors | Single Fountain | 1st Floor | 7 | 4 | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------------|------------------------------|----------------------------|-------------------------|------|----------|------|----------|--------|
| Drinking Fountains | Corridors | Single Fountain | 2nd Floor | 6 | 5 | EA | \$1,931 | |
| Drinking Fountains | Corridors | Single Fountain | 2nd Floor | 5 | 2 | EA | \$3,861 | |
| Drinking Fountains | | Single Fountain | 1st Floor Auditorium | 7 | 2 | EA | \$0 | |
| Drinking Fountains | Corridors | Single Fountain | 3rd Floor | 7 | 7 | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating | Basement Wrestling Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating | 126 | 7 | 1,008 | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating | 220 | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating | 2nd Floor Weight Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating | 2nd Floor Weight Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating | 218 | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Exposed | Basement Wrestling Room | 5 | 1,896 | SF | \$14,424 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Exposed | 126 | 7 | 8,200 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Plaster/Drywall | 218 | 6 | 4,565 | SF | \$39,037 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Plaster/Drywall | 220 | 6 | 2,682 | SF | \$22,935 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Plaster/Drywall | 2nd Floor Weight Room | 6 | 728 | SF | \$6,225 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Plaster/Drywall | 2nd Floor Weight Room | 7 | 1,760 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Sports Flooring | 2nd Floor Weight Room | 7 | 728 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Sports Flooring | 2nd Floor Weight Room | 7 | 1,760 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Sports Flooring | Basement Wrestling Room | 5 | 1,896 | SF | \$18,979 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Wood | 126 | 7 | 8,200 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Wood | 220 | 6 | 2,682 | SF | \$20,250 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Wood | 218 | 6 | 4,565 | SF | \$34,468 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Lay-In | 218 | 7 | 15 | SF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------------|------------------------------|--------------------------------------|-------------------------|------|----------|------|---------|--------|
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Lay-In | 220 | 7 | 15 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Lay-In | 220 | 4 | 1 | SF | \$5 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Lay-In | 218 | 4 | 1 | SF | \$5 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Metal Halide/Sodium Vapor | 126 | 7 | 32 | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Pendant/Surface | Basement Wrestling Room | 5 | 8 | EA | \$4,347 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Pendant/Surface | 2nd Floor Weight Room | 6 | 24 | EA | \$2,917 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Pendant/Surface | 2nd Floor Weight Room | 7 | 54 | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards | 126 | 6 | 1 | EA | \$2,076 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards | 2nd Floor Weight Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards | Basement Wrestling Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards | 2nd Floor Weight Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards | 218 | 5 | 1 | EA | \$6,852 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards | 220 | 5 | 1 | EA | \$6,852 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System | 2nd Floor Weight Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System | Basement Wrestling Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System | 2nd Floor Weight Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System | 218 | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System | 220 | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System | 126 | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Stage Curtain | 2nd Floor Weight Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Stage Curtain | 126 | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Stage Curtain | 218 | | | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------------|---------------------------------|--------------------------------|---------------------------------|------|----------|------|----------|--------|
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Stage Curtain | Basement Wrestling Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Stage Curtain | 2nd Floor Weight Room | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Stage Curtain | 220 | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Concrete Block | 2nd Floor Weight Room | 7 | 1,671 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Plaster/Drywall | 2nd Floor Weight Room | 5 | 1,753 | SF | \$25,068 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Plaster/Drywall | Basement Wrestling Room | 5 | 2,105 | SF | \$30,102 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Plaster/Drywall | 126 | 6 | 4,732 | SF | \$40,601 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Structural Glazed Tile | 126 | 7 | 3,355 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Structural Glazed Tile | 220 | 7 | 1,254 | SF | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Structural Glazed Tile | 218 | 7 | 1,632 | SF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 3rd fl staff FP girls west | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | 2nd Floor | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | girls locker rm 118 | 7 | 34 | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | mens- first fl service corridor | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | girls rm 122 | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | in girls locker rm 122 | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 3rd Floor womens Staff east | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | in office 300 | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | In Nurse's Office | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Women's Auditorium Restroom | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Men's Auditorium Restroom | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Gym Office 128 Shower | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Gym Office 128 | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | in office 220 | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 2nd Floor Mens Staff | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Basement Boys Locker Room | 6 | 18 | LF | \$103 | |
| Locker/Shower Room | Staff Restroom | Benches | In Office 112 | | | LF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------|---------------------------------|---------|---------------------------------|------|----------|------|----------|--------|
| Locker/Shower Room | Staff Restroom | Benches | 3rd Floor Mens Staff | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | 2nd Floor | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 3rd fl staff FP girls west | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 3rd Floor Mens Staff | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 2nd Floor Mens Staff | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | In Office 112 | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Gym Office 128 Shower | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Men's Auditorium Restroom | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | In Nurse's Office | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Basement Boys Locker Room | 7 | 152 | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | in office 300 | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 3rd Floor womens Staff east | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | in office 220 | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | girls locker rm 118 | 7 | 182 | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | mens- first fl service corridor | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | girls rm 122 | 6 | 1,300 | EA | \$63,801 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | in girls locker rm 122 | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Women's Auditorium Restroom | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Gym Office 128 | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Showers | girls locker rm 118 | 7 | 14 | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 3rd fl staff FP girls west | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 3rd Floor Mens Staff | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Gym Office 128 Shower | 6 | 1 | EA | \$243 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Men's Auditorium Restroom | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 2nd Floor Mens Staff | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Basement Boys Locker Room | 6 | 16 | EA | \$3,890 | |
| Locker/Shower Room | Staff Restroom | Showers | In Office 112 | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Women's Auditorium Restroom | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | In Nurse's Office | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | 2nd Floor | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | in office 220 | 6 | 1 | EA | \$243 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------------|---------------------------------|-------------------------------|-----------------------------------|------|----------|------|-----------|---------|
| Locker/Shower Room | Locker/Shower Room | Showers | girls rm 122 | 5 | 2 | EA | \$2,431 | running |
| Locker/Shower Room | Staff Restroom | Showers | in office 300 | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | in girls locker rm 122 | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 3rd Floor womens Staff east | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Gym Office 128 | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | mens- first fl service corridor | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Showers | girls rm 122 | 6 | 14 | EA | \$3,403 | |
| Lunchroom | Multipurpose Room | Ceiling - Lay-In | rm 320 | 6 | 1,315 | SF | \$2,821 | |
| Lunchroom | Multipurpose Room | Ceiling - Splined | rm 320 | 6 | 115 | SF | \$247 | |
| Lunchroom | Multipurpose Room | Flooring - Wood | rm 320 | 6 | 1,430 | SF | \$10,797 | |
| Lunchroom | Multipurpose Room | Lighting - Pendant/Surface | rm 320 | 6 | 20 | SF | \$14 | |
| Lunchroom | Multipurpose Room | Serving Line | rm 320 | | | LF | \$0 | |
| Lunchroom | Multipurpose Room | Wall - Plaster/Drywall | rm 320 | 6 | 154 | SF | \$363 | |
| Lunchroom | Multipurpose Room | Wall - Structural Glazed Tile | rm 320 | 7 | 1,973 | SF | \$0 | |
| Mechanical/Service Rooms | | Janitor's Closet | Entire Building | 7 | 6 | SF | \$0 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | Basement | 6 | 34,762 | SF | \$164,042 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | Mezzanine in Boiler Room | 6 | 1,350 | SF | \$6,371 | |
| Mechanical/Service Rooms | | Storage Room | 2nd Floor Off Gym | 7 | 268 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | In Office 208 | 7 | 92 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | Gym Storage | 6 | 32 | SF | \$151 | |
| Mechanical/Service Rooms | | Storage Room | Basement Boys Locker Room Storage | 6 | 771 | SF | \$3,638 | |
| Mechanical/Service Rooms | | Storage Room | Basement Wrestling Room Storage | 6 | 118 | SF | \$557 | |
| Mechanical/Service Rooms | | Storage Room | 112 Storage | 7 | 200 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | In Room 101 | 7 | 50 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | In Room 101 | 7 | 58 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | In Office 101A | 7 | 44 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | 342A Computer Storage | 7 | 360 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | Basement Wrestling Room Storage | 6 | 370 | SF | \$1,746 | |
| Staff Restroom | Staff Restroom | Accessories | In Nurse's Office | 7 | 46 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | 3rd fl staff FP girls west | 6 | 464 | SF | \$3,583 | |
| Staff Restroom | Staff Restroom | Accessories | 3rd Floor Mens Staff | 6 | 288 | SF | \$2,224 | |
| Staff Restroom | Staff Restroom | Accessories | 2nd Floor Mens Staff | 6 | 288 | SF | \$2,224 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Basement Boys Locker Room | | | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | In Office 112 | 7 | 28 | SF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|---------------------------|---------------------------------|------|----------|------|----------|--------|
| Staff Restroom | Staff Restroom | Accessories | Gym Office 128 | 6 | 19 | SF | \$147 | |
| Staff Restroom | Staff Restroom | Accessories | Gym Office 128 Shower | 6 | 19 | SF | \$147 | |
| Staff Restroom | Staff Restroom | Accessories | in office 220 | 6 | 60 | SF | \$463 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Women's Auditorium Restroom | 5 | 68 | SF | \$1,733 | |
| Staff Restroom | Locker/Shower Room | Accessories | girls locker rm 118 | 6 | 1,314 | SF | \$10,147 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | 2nd Floor | 6 | 225 | SF | \$1,737 | |
| Staff Restroom | Staff Restroom | Accessories | in office 300 | 5 | 46 | SF | \$1,172 | |
| Staff Restroom | Staff Restroom | Accessories | 3rd Floor womens Staff east | 6 | 288 | SF | \$2,224 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | in girls locker rm 122 | 6 | 183 | SF | \$1,413 | |
| Staff Restroom | Locker/Shower Room | Accessories | girls rm 122 | | | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | mens- first fl service corridor | 6 | 22 | SF | \$170 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Men's Auditorium Restroom | 6 | 96 | SF | \$741 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Gym Office 128 Shower | 6 | 19 | SF | \$54 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | In Office 112 | 7 | 28 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | in office 220 | 7 | 60 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | in girls locker rm 122 | 6 | 183 | SF | \$518 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | in office 300 | 7 | 46 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 2nd Floor Mens Staff | 7 | 288 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Basement Boys Locker Room | 5 | 4,052 | SF | \$22,946 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Men's Auditorium Restroom | 7 | 96 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | girls rm 122 | 7 | 1,342 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 3rd Floor womens Staff east | 7 | 295 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | girls locker rm 118 | 7 | 1,314 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 3rd fl staff FP girls west | 6 | 464 | SF | \$1,314 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 3rd Floor Mens Staff | 7 | 288 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Women's Auditorium Restroom | 7 | 68 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | In Nurse's Office | 7 | 46 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor | 6 | 225 | SF | \$637 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Gym Office 128 | 6 | 19 | SF | \$54 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | mens- first fl service corridor | 7 | 22 | SF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|-----------------------------------|---------------------------------|------|----------|------|----------|--------|
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Women's Auditorium Restroom | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | mens- first fl service corridor | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | 3rd fl staff FP girls west | 6 | 1 | EA | \$300 | |
| Staff Restroom | Staff Restroom | Floor Drain | 3rd Floor Mens Staff | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | 2nd Floor Mens Staff | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Basement Boys Locker Room | 6 | 13 | EA | \$3,904 | |
| Staff Restroom | Staff Restroom | Floor Drain | In Office 112 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Gym Office 128 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Gym Office 128 Shower | 6 | 1 | EA | \$300 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Men's Auditorium Restroom | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | In Nurse's Office | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | in office 300 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | 3rd Floor womens Staff east | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | 2nd Floor | 6 | 1 | EA | \$300 | |
| Staff Restroom | Locker/Shower Room | Floor Drain | girls rm 122 | 6 | 4 | EA | \$1,201 | |
| Staff Restroom | Staff Restroom | Floor Drain | in office 220 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Floor Drain | girls locker rm 118 | 7 | 9 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | in girls locker rm 122 | 6 | 1 | EA | \$300 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Concrete | Basement Boys Locker Room | 6 | 3,372 | SF | \$15,912 | |
| Staff Restroom | Staff Restroom | Flooring - Terrazzo | in office 220 | 7 | 14 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | In Office 112 | 7 | 28 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile Ceramic/Porcelain | girls rm 122 | 6 | 1,342 | SF | \$3,416 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | in girls locker rm 122 | 7 | 133 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | mens- first fl service corridor | 6 | 22 | SF | \$56 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 3rd Floor womens Staff east | 6 | 295 | SF | \$751 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor | 7 | 225 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Men's Auditorium Restroom | 6 | 96 | SF | \$244 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile Ceramic/Porcelain | girls locker rm 118 | 7 | 1,314 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Basement Boys Locker Room | 6 | 680 | SF | \$1,731 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor Mens Staff | 6 | 288 | SF | \$733 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|-----------------------------------|---------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 3rd Floor Mens Staff | 6 | 288 | SF | \$733 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 3rd fl staff FP girls west | 7 | 464 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Women's Auditorium Restroom | 6 | 68 | SF | \$173 | |
| Staff Restroom | Staff Restroom | Flooring - Tile/Sheet | in office 300 | 6 | 46 | SF | \$66 | |
| Staff Restroom | Staff Restroom | Flooring - Tile/Sheet | In Nurse's Office | 6 | 46 | SF | \$66 | |
| Staff Restroom | Staff Restroom | Flooring - Tile/Sheet | Gym Office 128 Shower | 7 | 19 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile/Sheet | Gym Office 128 | 7 | 19 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile/Sheet | in office 220 | 7 | 46 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | In Nurse's Office | 7 | 1 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Hand Dryer | girls rm 122 | 6 | 12 | EA | \$2,605 | |
| Staff Restroom | Staff Restroom | Hand Dryer | in office 220 | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Hand Dryer | girls locker rm 118 | 7 | 13 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | mens- first fl service corridor | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | in girls locker rm 122 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 3rd Floor womens Staff east | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 2nd Floor | 6 | 1 | EA | \$217 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Women's Auditorium Restroom | 4 | 1 | EA | \$2,171 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Men's Auditorium Restroom | 4 | 1 | EA | \$2,171 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Gym Office 128 Shower | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Gym Office 128 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | In Office 112 | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Basement Boys Locker Room | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 2nd Floor Mens Staff | 6 | 1 | EA | \$217 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 3rd Floor Mens Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 3rd fl staff FP girls west | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | in office 300 | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Basement Boys Locker Room | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | 2nd Floor Mens Staff | 6 | 5 | EA | \$1,859 | |
| Staff Restroom | Staff Restroom | Lavatory | 3rd fl staff FP girls west | 6 | 2 | EA | \$744 | |
| Staff Restroom | Staff Restroom | Lavatory | 3rd fl staff FP girls west | 5 | 1 | EA | \$1,859 | |
| Staff Restroom | Staff Restroom | Lavatory | 3rd Floor womens Staff east | 6 | 2 | EA | \$744 | |
| Staff Restroom | Staff Restroom | Lavatory | in office 220 | 6 | 1 | EA | \$372 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|-----------------------------|---------------------------------|------|----------|------|---------|---------|
| Staff Restroom | Locker/Shower Room | Lavatory | girls locker rm 118 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Lavatory | girls locker rm 118 | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Lavatory | mens- first fl service corridor | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Lavatory | 3rd Floor Mens Staff | 6 | 5 | EA | \$1,859 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | in girls locker rm 122 | 5 | 2 | EA | \$3,718 | leaking |
| Staff Restroom | Staff Restroom | Lavatory | in office 300 | 6 | 1 | EA | \$372 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | 2nd Floor | 6 | 2 | EA | \$744 | |
| Staff Restroom | Staff Restroom | Lavatory | In Nurse's Office | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Women's Auditorium Restroom | 6 | 2 | EA | \$744 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Men's Auditorium Restroom | 6 | 2 | EA | \$744 | |
| Staff Restroom | Staff Restroom | Lavatory | Gym Office 128 Shower | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Gym Office 128 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | In Office 112 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Lavatory | girls rm 122 | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | 2nd Floor | 6 | 7 | SF | \$5 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 3rd fl staff FP girls west | 7 | 16 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 3rd Floor Mens Staff | 7 | 11 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 2nd Floor Mens Staff | 7 | 11 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | In Nurse's Office | 6 | 1 | SF | \$1 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 3rd Floor womens Staff east | 7 | 11 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Pendant/ Surface | mens- first fl service corridor | 4 | 1 | SF | \$4 | |
| Staff Restroom | Locker/Shower Room | Lighting - Pendant/ Surface | girls rm 122 | 7 | 50 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Pendant/ Surface | in office 220 | 7 | 1 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Lighting - Pendant/ Surface | girls locker rm 118 | 7 | 52 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | in girls locker rm 122 | 7 | 4 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Pendant/ Surface | in office 300 | 7 | 1 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | Women's Auditorium Restroom | 6 | 2 | SF | \$1 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | Men's Auditorium Restroom | 6 | 2 | SF | \$1 | |
| Staff Restroom | Staff Restroom | Lighting - Pendant/ Surface | Gym Office 128 Shower | 4 | 1 | SF | \$4 | |
| Staff Restroom | Staff Restroom | Lighting - Pendant/ Surface | Gym Office 128 | 4 | 1 | SF | \$4 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | Basement Boys Locker Room | 4 | 6 | SF | \$26 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|-----------------------------|---------------------------------|------|----------|------|---------|-------------|
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | Basement Boys Locker Room | 5 | 59 | SF | \$84 | |
| Staff Restroom | Staff Restroom | Lighting - Wall Mounted | in office 300 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Wall Mounted | In Office 112 | 6 | 1 | EA | \$29 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Basement Boys Locker Room | 5 | 2 | EA | \$1,144 | |
| Staff Restroom | Staff Restroom | Partitions | In Nurse's Office | 7 | 1 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | girls locker rm 118 | 7 | 5 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | mens- first fl service corridor | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | girls rm 122 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 3rd Floor womens Staff east | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | in office 300 | 6 | 1 | EA | \$179 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | 2nd Floor | 6 | 2 | EA | \$359 | |
| Staff Restroom | Staff Restroom | Partitions | in office 220 | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Women's Auditorium Restroom | 6 | 2 | EA | \$359 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Men's Auditorium Restroom | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Gym Office 128 Shower | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | In Office 112 | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | in girls locker rm 122 | 5 | 4 | EA | \$2,288 | do not lock |
| Staff Restroom | Staff Restroom | Partitions | 2nd Floor Mens Staff | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 3rd Floor Mens Staff | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 3rd fl staff FP girls west | 6 | 9 | EA | \$1,614 | |
| Staff Restroom | Staff Restroom | Partitions | Gym Office 128 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 3rd fl staff FP girls west | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 2nd Floor Mens Staff | 7 | 8 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Women's Auditorium Restroom | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Urinals | girls locker rm 118 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | mens- first fl service corridor | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | in girls locker rm 122 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | in office 300 | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | 2nd Floor | 6 | 3 | EA | \$1,115 | |
| Staff Restroom | Staff Restroom | Urinals | in office 220 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 3rd Floor Mens Staff | 7 | 8 | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|-------------------------------|---------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Locker/Shower Room | Urinals | girls rm 122 | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Men's Auditorium Restroom | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | Gym Office 128 Shower | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | Gym Office 128 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | In Office 112 | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Basement Boys Locker Room | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | In Nurse's Office | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | Basement Boys Locker Room | 5 | 250 | SF | \$1,888 | |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | Gym Office 128 Shower | 6 | 147 | SF | \$420 | |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | Gym Office 128 | 6 | 147 | SF | \$420 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | Basement Boys Locker Room | 6 | 150 | SF | \$429 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | Basement Boys Locker Room | 7 | 2,236 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | In Office 112 | 7 | 195 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | In Nurse's Office | 5 | 246 | SF | \$1,161 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | in office 300 | 6 | 190 | SF | \$448 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Plaster/Drywall | Women's Auditorium Restroom | 7 | 70 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Plaster/Drywall | Men's Auditorium Restroom | 6 | 80 | SF | \$189 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | 3rd Floor womens Staff east | 6 | 120 | SF | \$283 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Plaster/Drywall | 2nd Floor | 6 | 204 | SF | \$481 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | mens- first fl service corridor | 6 | 208 | SF | \$491 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | in office 220 | 6 | 291 | SF | \$687 | |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 3rd fl staff FP girls west | 7 | 476 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 3rd Floor Mens Staff | 7 | 835 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 2nd Floor Mens Staff | 7 | 835 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Wall - Structural Glazed Tile | girls locker rm 118 | 7 | 3,654 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | in office 220 | 7 | 90 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | Basement Boys Locker Room | 7 | 1,474 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | Basement Boys Locker Room | 7 | 384 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 2nd Floor | 6 | 492 | SF | \$3,518 | |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 3rd Floor womens Staff east | 7 | 715 | SF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|----------------------------------|---------------------------------|------|----------|------|----------|--------|
| Staff Restroom | Locker/Shower Room | Wall - Structural Glazed Tile | girls rm 122 | 7 | 519 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Wall - Structural Glazed Tile | girls locker rm 118 | 7 | 1,000 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | Men's Auditorium Restroom | 6 | 240 | SF | \$611 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | Women's Auditorium Restroom | 5 | 204 | SF | \$3,209 | |
| Staff Restroom | Staff Restroom | Water Closet | in office 220 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | in office 300 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | in girls locker rm 122 | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | mens- first fl service corridor | 7 | 1 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Water Closet | girls locker rm 118 | 7 | 5 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | 3rd Floor Mens Staff | 7 | 4 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | 2nd Floor | 6 | 2 | EA | \$744 | |
| Staff Restroom | Staff Restroom | Water Closet | In Nurse's Office | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Women's Auditorium Restroom | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Men's Auditorium Restroom | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Gym Office 128 | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Water Closet | 3rd Floor womens Staff east | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | In Office 112 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Basement Boys Locker Room | 6 | 2 | EA | \$744 | |
| Staff Restroom | Staff Restroom | Water Closet | 2nd Floor Mens Staff | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | 3rd fl staff FP girls west | 7 | 8 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | 3rd fl staff FP girls west | 5 | 1 | EA | \$1,859 | |
| Staff Restroom | Locker/Shower Room | Water Closet | girls rm 122 | | | EA | \$0 | |
| Swimming Pool | | Lighting - Pendant/ Surface | Pool | 5 | 2 | SF | \$6 | |
| Swimming Pool | | Lighting - Pendant/ Surface | Pool | 6 | 72 | SF | \$77 | |
| Swimming Pool | | Pool Basin | Pool | 7 | 1,440 | SF | \$0 | |
| Swimming Pool | | Pool Deck | Pool | 7 | 1,600 | SF | \$0 | |
| Swimming Pool | | Pool deck drains | Pool | 7 | 4 | EA | \$0 | |
| Swimming Pool | | Pool deck drains | Pool | 7 | 8 | EA | \$0 | |
| Swimming Pool | | Splined Ceiling including access | Pool | 7 | 3,040 | SF | \$0 | |
| Swimming Pool | | Wall Tile | Pool | 7 | 1,981 | SF | \$0 | |
| Theater | Auditorium - Dedicated | Ceiling - Plaster/Drywall | 1st Floor | 6 | 8,217 | SF | \$70,267 | |
| Theater | Auditorium - Dedicated | Flooring - Carpet | 1st Floor | 6 | 1,481 | SF | \$2,118 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------|------------------------|-------------------------------------|-----------|------|----------|------|-----------|--------|
| Theater | Auditorium - Dedicated | Flooring - Concrete | 1st Floor | 6 | 4,202 | SF | \$19,829 | |
| Theater | Auditorium - Dedicated | Flooring - Tile/Sheet | 1st Floor | 6 | 125 | SF | \$179 | |
| Theater | Auditorium - Dedicated | Lighting - Chandelier, Incandescent | 1st Floor | 4 | 11 | EA | \$20,449 | |
| Theater | Auditorium - Dedicated | Lighting - Pendant/ Surface | 1st Floor | 6 | 48 | SF | \$79 | |
| Theater | Auditorium - Dedicated | Lighting - Pendant/ Surface | 1st Floor | 7 | 7 | SF | \$0 | |
| Theater | Auditorium - Dedicated | Lighting - Pendant/ Surface | 1st Floor | 7 | 4 | SF | \$0 | |
| Theater | Auditorium - Dedicated | Lighting - Wall Mounted | 1st Floor | 4 | 18 | EA | \$1,287 | |
| Theater | Auditorium - Dedicated | Stage | 1st Floor | 5 | 1,290 | SF | \$36,156 | |
| Theater | Auditorium - Dedicated | Wall - Plaster/Drywall | 1st Floor | 5 | 12,288 | SF | \$175,718 | |
| Theater | Auditorium - Dedicated | Wall - Structural Glazed Tile | 1st Floor | 6 | 130 | SF | \$930 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 7 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 1 | EA | \$1,931 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 9 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 2 | EA | \$3,861 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 3 | EA | \$1,158 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 2 | EA | \$3,861 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 1 | EA | \$386 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 2 | EA | \$3,861 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 1 | EA | \$386 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 1 | EA | \$386 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 10 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 1 | EA | \$386 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 4 | EA | \$7,722 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 4 | EA | \$7,722 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 1 | EA | \$386 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 1 | EA | \$1,931 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 1 | EA | \$386 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 1 | EA | \$386 | |

INTERIOR Sub Total \$1,297,277

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------|-------------------------------|-----------------------------|----------|------|----------|------|---------|--------|
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | RM 304B | 7 | 200 | SF | \$0 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 300A | 6 | 100 | SF | \$236 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | RM 304B | 7 | 85 | SF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 37 | LF | \$1,323 | |
| Casework | Classroom | Casework | | 6 | 140 | LF | \$5,005 | |
| Casework | Classroom | Casework | | 6 | 25 | LF | \$894 | |
| Casework | Classroom | Casework | | 6 | 141 | LF | \$5,041 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 26 | LF | \$930 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 141 | LF | \$5,041 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 26 | LF | \$930 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 16 | LF | \$572 | |
| Casework | Classroom | Casework | | 6 | 153 | LF | \$5,470 | |
| Casework | Classroom | Casework | | 6 | 153 | LF | \$5,470 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 8 | LF | \$286 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|-----------|----------|----------|------|----------|------|---------|--------|
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 5 | 36 | LF | \$6,435 | |
| Casework | Classroom | Casework | | 6 | 94 | LF | \$3,361 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 12 | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 43 | LF | \$1,537 | |
| Casework | Classroom | Casework | | 6 | 43 | LF | \$1,537 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 29 | LF | \$1,037 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 29 | LF | \$1,037 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 29 | LF | \$1,037 | |
| Casework | Classroom | Casework | | 6 | 9 | LF | \$322 | |
| Casework | Classroom | Casework | | 6 | 16 | LF | \$572 | |
| Casework | Classroom | Casework | | 6 | 14 | LF | \$501 | |
| Casework | Classroom | Casework | | 6 | 46 | LF | \$1,645 | |
| Casework | Classroom | Casework | | 7 | 85 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 9 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 9 | LF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|-----------|-------------|----------|------|----------|------|---------|--------|
| Casework | Classroom | Casework | | 6 | 29 | LF | \$1,037 | |
| Ceiling | Classroom | Ceiling | | | 706 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 965 | SF | \$2,070 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 965 | SF | \$2,070 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 2,284 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,286 | SF | \$2,758 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 750 | SF | \$1,609 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 927 | SF | \$1,988 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 638 | SF | \$1,369 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,470 | SF | \$3,153 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,750 | SF | \$3,754 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,112 | SF | \$2,385 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 386 | SF | \$828 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 412 | SF | \$884 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 476 | SF | \$1,021 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 2,848 | SF | \$6,109 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 965 | SF | \$2,070 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 678 | SF | \$1,454 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,080 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 965 | SF | \$2,070 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,080 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 584 | SF | \$1,253 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,286 | SF | \$2,758 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,830 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,470 | SF | \$3,153 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 538 | SF | \$1,154 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 438 | SF | \$940 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,090 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,036 | SF | \$2,222 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 364 | SF | \$781 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 628 | SF | \$1,347 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 778 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 965 | SF | \$2,070 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 965 | SF | \$2,070 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 628 | SF | \$1,347 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 556 | SF | \$1,193 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 946 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 912 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 748 | SF | \$1,604 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 864 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,396 | SF | \$2,994 | |
| Ceiling | Classroom | Plaster/Drywall | | 7 | 100 | SF | \$0 | |
| Ceiling | Classroom | Plaster/Drywall | | 7 | 480 | SF | \$0 | |
| Ceiling | Classroom | Plaster/Drywall | | 7 | 200 | SF | \$0 | |
| Ceiling | Classroom | Plaster/Drywall | | 7 | 100 | SF | \$0 | |
| Ceiling | Classroom | Plaster/Drywall | | 7 | 100 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------|-------------------|-------------|----------|------|----------|------|---------|--------|
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Multipurpose Room | Chalk Board | rm 320 | 4 | 10 | LF | \$1,216 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 28 | LF | \$3,403 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 6 | LF | \$729 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 6 | LF | \$729 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 28 | LF | \$3,403 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 26 | LF | \$3,160 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 28 | LF | \$3,403 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 32 | LF | \$3,890 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 26 | LF | \$3,160 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 32 | LF | \$3,890 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 28 | LF | \$3,403 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 26 | LF | \$3,160 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 26 | LF | \$3,160 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 18 | LF | \$2,188 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 26 | LF | \$3,160 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 42 | LF | \$5,105 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 26 | LF | \$3,160 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 6 | LF | \$729 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 26 | LF | \$3,160 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 46 | LF | \$5,591 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 46 | LF | \$5,591 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 46 | LF | \$5,591 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 8 | LF | \$972 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------|-----------|----------------------|---------------------------------|------|----------|------|---------|--------|
| Chalk Board | Classroom | Chalk Board | | 4 | 26 | LF | \$3,160 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 7 | LF | \$851 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 8 | LF | \$972 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 8 | LF | \$972 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 6 | LF | \$729 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 28 | LF | \$3,403 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 28 | LF | \$3,403 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 6 | LF | \$729 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 20 | LF | \$2,431 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| CLASSROOM | Classroom | Eye Wash Station | | 7 | 1 | EA | \$0 | |
| CLASSROOM | Classroom | Eye Wash Station | | 6 | 1 | EA | \$2,681 | |
| CLASSROOM | Classroom | Eye Wash Station | | 7 | 1 | EA | \$0 | |
| CLASSROOM | Classroom | Eye Wash Station | | 6 | 1 | EA | \$2,681 | |
| CLASSROOM | Classroom | Eye Wash Station | | 7 | 1 | EA | \$0 | |
| CLASSROOM | Classroom | Eye Wash Station | | 7 | 1 | EA | \$0 | |
| CLASSROOM | Classroom | Eye Wash Station | | 7 | 1 | EA | \$0 | |
| CLASSROOM | Classroom | Eye Wash Station | | 7 | 1 | EA | \$0 | |
| CLASSROOM | Classroom | Science Lab Elements | | 7 | 1 | SF | \$0 | |
| CLASSROOM | Classroom | Science Lab Elements | | 7 | 1 | SF | \$0 | |
| Corridors | Corridors | Concrete Block | Boys Locker Stair to Gym | 7 | 407 | SF | \$0 | |
| Corridors | Corridors | Concrete Block | Vestibule from Gym to Hallway 1 | 6 | 120 | SF | \$343 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|------------------------|---|------|----------|------|----------|--------|
| Corridors | Corridors | Concrete Block | Basement Wrestling Room Stair | 6 | 280 | SF | \$801 | |
| Corridors | Corridors | Concrete Block | Basement Boys Locker Stairs to Hallway | 7 | 414 | SF | \$0 | |
| Corridors | Corridors | Concrete Block | Vestibule from Gym to Hallway 2 | 6 | 120 | SF | \$343 | |
| Corridors | Corridors | Concrete Epoxy/Painted | 3rd fl service corridor and stairs to roof and down to lower floors | 6 | 603 | SF | \$2,846 | |
| Corridors | Corridors | Concrete Epoxy/Painted | 2nd fl service corridor | 6 | 241 | SF | \$1,137 | |
| Corridors | Corridors | Concrete Epoxy/Painted | Basement Wrestling Room Stair | 6 | 72 | SF | \$340 | |
| Corridors | Corridors | Concrete Epoxy/Painted | Basement Boys Locker Stairs to Hallway | 6 | 59 | SF | \$278 | |
| Corridors | Corridors | Concrete Epoxy/Painted | Boys Locker Stair to Gym | 6 | 82 | SF | \$387 | |
| Corridors | Corridors | Concrete Epoxy/Painted | 1st fl service corridor | 6 | 264 | SF | \$1,246 | |
| Corridors | Corridors | Drinking Fountains | SW Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | 3rd fl service corridor and stairs to roof and down to lower floors | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Vestibule from Gym to Hallway 1 | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | to 300, 302, 399 | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | SE Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Vestibule from Gym to Hallway 2 | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | NW Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Gym Vestibule 2 | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Basement Wrestling Room Stair | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Boys Locker Stair to Gym | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Center Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Gym Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | 2nd fl service corridor | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | 1st fl service corridor | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | 1st vestibule to courtyard | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Gym Vestibule | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Basement Boys Locker Stairs to Hallway | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | NE Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drop/Lay-In | 2nd Floor | 6 | 12,312 | SF | \$26,409 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|-----------------|---|------|----------|------|----------|--------|
| Corridors | Corridors | Drop/Lay-In | 3rd Floor | 6 | 6,654 | SF | \$14,273 | |
| Corridors | Corridors | Drop/Lay-In | to 300, 302, 399 | 6 | 217 | SF | \$465 | |
| Corridors | Corridors | Drop/Lay-In | SE Stairs | 7 | 134 | SF | \$0 | |
| Corridors | Corridors | Drop/Lay-In | Center Stairs | 7 | 452 | SF | \$0 | |
| Corridors | Corridors | Drop/Lay-In | 1st Floor | 6 | 12,843 | SF | \$27,548 | |
| Corridors | Corridors | Exposed | Gym Stairs | 7 | 82 | SF | \$0 | |
| Corridors | Corridors | Lay-In | Center Stairs | 7 | 452 | EA | \$0 | |
| Corridors | Corridors | Lay-In | 3rd Floor | 7 | 6,654 | EA | \$0 | |
| Corridors | Corridors | Lay-In | 1st Floor | 7 | 12,723 | EA | \$0 | |
| Corridors | Corridors | Lay-In | SE Stairs | 7 | 134 | EA | \$0 | |
| Corridors | Corridors | Lay-In | 2nd Floor | 7 | 12,312 | EA | \$0 | |
| Corridors | Corridors | Lay-In | to 300, 302, 399 | 7 | 217 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | 2nd fl service corridor | 7 | 241 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | SW Stairs | 7 | 756 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | NW Stairs | 7 | 756 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | SE Stairs | 7 | 596 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | Vestibule from Gym to Hallway 1 | 6 | 2 | EA | \$1 | |
| Corridors | Corridors | Pendant/Surface | Vestibule from Gym to Hallway 2 | 6 | 2 | EA | \$1 | |
| Corridors | Corridors | Pendant/Surface | Gym Vestibule 2 | 6 | 1 | EA | \$1 | |
| Corridors | Corridors | Pendant/Surface | Basement Wrestling Room Stair | 4 | 1 | EA | \$10 | |
| Corridors | Corridors | Pendant/Surface | Boys Locker Stair to Gym | 6 | 82 | EA | \$59 | |
| Corridors | Corridors | Pendant/Surface | Gym Stairs | 7 | 732 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | 3rd fl service corridor and stairs to roof and down to lower floors | 7 | 580 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | 1st fl service corridor | 7 | 305 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | 1st Floor | 7 | 1,471 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | 1st vestibule to courtyard | 7 | 2 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | Gym Vestibule | 6 | 1 | EA | \$1 | |
| Corridors | Corridors | Pendant/Surface | Basement Boys Locker Stairs to Hallway | 6 | 59 | EA | \$42 | |
| Corridors | Corridors | Pendant/Surface | Center Stairs | 7 | 1,225 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | NE Stairs | 7 | 756 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | 3rd Floor | 7 | 4,728 | EA | \$0 | |
| Corridors | Corridors | Plaster/Drywall | Basement Wrestling Room Stair | 6 | 510 | SF | \$1,203 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|---------------------|---|------|----------|------|----------|--------|
| Corridors | Corridors | Plaster/Drywall | Gym Stairs | 6 | 2,262 | SF | \$5,337 | |
| Corridors | Corridors | Plaster/Drywall | 3rd Floor | 6 | 5,667 | SF | \$13,371 | |
| Corridors | Corridors | Plaster/Drywall | 3rd fl service corridor and stairs to roof and down to lower floors | 6 | 3,083 | SF | \$7,274 | |
| Corridors | Corridors | Plaster/Drywall | 2nd fl service corridor | 6 | 1,278 | SF | \$3,015 | |
| Corridors | Corridors | Plaster/Drywall | 1st vestibule to courtyard | 6 | 42 | SF | \$99 | |
| Corridors | Corridors | Plaster/Drywall | 2nd Floor | 6 | 8,746 | SF | \$20,636 | |
| Corridors | Corridors | Plaster/Drywall | to 300, 302, 399 | 6 | 820 | SF | \$1,935 | |
| Corridors | Corridors | Plaster/Drywall | 1st Floor | 6 | 8,716 | SF | \$20,565 | |
| Corridors | Corridors | Plaster/Drywall | 1st fl service corridor | 6 | 1,644 | SF | \$3,879 | |
| Corridors | Corridors | Plaster/Drywall | SE Stairs | 6 | 1,576 | SF | \$3,719 | |
| Corridors | Corridors | Plaster/Drywall | NW Stairs | 6 | 1,650 | SF | \$3,893 | |
| Corridors | Corridors | Plaster/Drywall | SW Stairs | 6 | 1,650 | SF | \$3,893 | |
| Corridors | Corridors | Plaster/Drywall | NE Stairs | 6 | 1,650 | SF | \$3,893 | |
| Corridors | Corridors | Plaster/Drywall | Center Stairs | 6 | 2,287 | SF | \$5,396 | |
| Corridors | Corridors | Single Water Cooler | 2nd Floor | 6 | 1 | EA | \$615 | |
| Corridors | Corridors | Single Water Cooler | 2nd Floor | 7 | 1 | EA | \$0 | |
| Corridors | Corridors | Single Water Cooler | 3rd Floor | 7 | 2 | EA | \$0 | |
| Corridors | Corridors | Single Water Cooler | 1st Floor | 7 | 2 | EA | \$0 | |
| Corridors | Corridors | Splined | 1st Floor | 6 | 1,471 | SF | \$3,155 | |
| Corridors | Corridors | Stair Handrails | Basement Boys Locker Stairs to Hallway | 7 | 34 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Basement Wrestling Room Stair | 7 | 36 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Gym Vestibule | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 1st Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 2nd Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 1st fl service corridor | 6 | 8 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 2nd fl service corridor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 3rd fl service corridor and stairs to roof and down to lower floors | 6 | 132 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 3rd Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 1st vestibule to courtyard | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Boys Locker Stair to Gym | 7 | 30 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Center Stairs | 6 | 208 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Gym Vestibule 2 | | | LF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|------------------------|---|------|----------|------|---------|--------|
| Corridors | Corridors | Stair Handrails | Vestibule from Gym to Hallway 2 | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Vestibule from Gym to Hallway 1 | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | to 300, 302, 399 | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | SE Stairs | 6 | 108 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | NW Stairs | 6 | 107 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | SW Stairs | 6 | 107 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | NE Stairs | 6 | 107 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Gym Stairs | 6 | 84 | LF | \$0 | |
| Corridors | Corridors | Stairs | Basement Wrestling Room Stair | 6 | 19 | EA | \$136 | |
| Corridors | Corridors | Stairs | Boys Locker Stair to Gym | 6 | 18 | EA | \$129 | |
| Corridors | Corridors | Stairs | Basement Boys Locker Stairs to Hallway | 6 | 18 | EA | \$129 | |
| Corridors | Corridors | Stairs | Gym Vestibule | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 1st vestibule to courtyard | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 1st Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 2nd Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 1st fl service corridor | 4 | 4 | EA | \$400 | |
| Corridors | Corridors | Stairs | 2nd fl service corridor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | Vestibule from Gym to Hallway 2 | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 3rd Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | Gym Vestibule 2 | | | EA | \$0 | |
| Corridors | Corridors | Stairs | Vestibule from Gym to Hallway 1 | | | EA | \$0 | |
| Corridors | Corridors | Stairs | to 300, 302, 399 | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 3rd fl service corridor and stairs to roof and down to lower floors | 6 | 55 | EA | \$393 | |
| Corridors | Corridors | Structural Glazed Tile | Boys Locker Stair to Gym | 7 | 250 | SF | \$0 | |
| Corridors | Corridors | Structural Glazed Tile | Basement Boys Locker Stairs to Hallway | 7 | 505 | SF | \$0 | |
| Corridors | Corridors | Structural Glazed Tile | Center Stairs | 6 | 1,302 | SF | \$9,309 | |
| Corridors | Corridors | Structural Glazed Tile | NE Stairs | 7 | 1,234 | SF | \$0 | |
| Corridors | Corridors | Structural Glazed Tile | Vestibule from Gym to Hallway 2 | 7 | 240 | SF | \$0 | |
| Corridors | Corridors | Structural Glazed Tile | Gym Stairs | 7 | 2,262 | SF | \$0 | |
| Corridors | Corridors | Structural Glazed Tile | 3rd Floor | 7 | 3,542 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|------------------------|---|------|----------|------|----------|--------|
| Corridors | Corridors | Structural Glazed Tile | 2nd Floor | 7 | 3,762 | SF | \$0 | |
| Corridors | Corridors | Structural Glazed Tile | 1st Floor | 6 | 5,819 | SF | \$41,606 | |
| Corridors | Corridors | Structural Glazed Tile | SW Stairs | 6 | 1,234 | SF | \$8,823 | |
| Corridors | Corridors | Structural Glazed Tile | NW Stairs | 6 | 1,234 | SF | \$8,823 | |
| Corridors | Corridors | Structural Glazed Tile | Vestibule from Gym to Hallway 1 | 7 | 240 | SF | \$0 | |
| Corridors | Corridors | Structural Glazed Tile | SE Stairs | 6 | 1,234 | SF | \$8,823 | |
| Corridors | Corridors | Student Lockers | SW Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Center Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | NW Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Gym Vestibule | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | NE Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Gym Vestibule 2 | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Boys Locker Stair to Gym | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Gym Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 3rd Floor | 6 | 54 | EA | \$7,722 | |
| Corridors | Corridors | Student Lockers | 3rd fl service corridor and stairs to roof and down to lower floors | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 3rd Floor | 5 | 500 | EA | \$89,375 | |
| Corridors | Corridors | Student Lockers | Basement Wrestling Room Stair | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 1st fl service corridor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 1st Floor | 5 | 523 | EA | \$93,486 | |
| Corridors | Corridors | Student Lockers | Vestibule from Gym to Hallway 2 | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Vestibule from Gym to Hallway 1 | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | to 300, 302, 399 | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | SE Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 2nd Floor | 6 | 30 | EA | \$4,290 | |
| Corridors | Corridors | Student Lockers | 2nd Floor | 5 | 525 | EA | \$93,844 | |
| Corridors | Corridors | Student Lockers | 1st vestibule to courtyard | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Basement Boys Locker Stairs to Hallway | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 2nd fl service corridor | | | EA | \$0 | |
| Corridors | Corridors | Terrazzo | 1st Floor | 7 | 2,331 | SF | \$0 | |
| Corridors | Corridors | Terrazzo | 2nd Floor | 7 | 2,332 | SF | \$0 | |
| Corridors | Corridors | Terrazzo | 3rd Floor | 7 | 1,863 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------------|-----------|------------------------|--|------|----------|------|----------|--------|
| Corridors | Corridors | Terrazzo | Gym Stairs | 6 | 632 | SF | \$3,579 | |
| Corridors | Corridors | Terrazzo | SE Stairs | 7 | 690 | SF | \$0 | |
| Corridors | Corridors | Terrazzo | NW Stairs | 7 | 512 | SF | \$0 | |
| Corridors | Corridors | Terrazzo | Center Stairs | 7 | 1,282 | SF | \$0 | |
| Corridors | Corridors | Terrazzo | SW Stairs | 7 | 512 | SF | \$0 | |
| Corridors | Corridors | Terrazzo | NE Stairs | 7 | 512 | SF | \$0 | |
| Corridors | Corridors | Terrazzo | 1st vestibule to courtyard | 7 | 100 | SF | \$0 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | NE Stairs | 7 | 93 | SF | \$0 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | SW Stairs | 7 | 93 | SF | \$0 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | NW Stairs | 7 | 93 | SF | \$0 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | SE Stairs | 7 | 93 | SF | \$0 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | Gym Vestibule 2 | 6 | 64 | SF | \$163 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | Gym Vestibule | 6 | 64 | SF | \$163 | |
| Corridors | Corridors | Tile/Sheet Flooring | 1st fl service corridor | 6 | 41 | SF | \$59 | |
| Corridors | Corridors | Tile/Sheet Flooring | to 300, 302, 399 | 7 | 217 | SF | \$0 | |
| Corridors | Corridors | Tile/Sheet Flooring | Vestibule from Gym to Hallway 1 | 6 | 86 | SF | \$123 | |
| Corridors | Corridors | Tile/Sheet Flooring | 3rd Floor | 6 | 9,226 | SF | \$13,193 | |
| Corridors | Corridors | Tile/Sheet Flooring | 2nd Floor | 6 | 9,980 | SF | \$14,271 | |
| Corridors | Corridors | Tile/Sheet Flooring | 1st Floor | 6 | 10,512 | SF | \$15,032 | |
| Corridors | Corridors | Tile/Sheet Flooring | Vestibule from Gym to Hallway 2 | 6 | 86 | SF | \$123 | |
| Corridors | Corridors | Walls | 2nd Floor | 7 | 112 | SF | \$0 | |
| Corridors | Corridors | Walls | Gym Vestibule 2 | | | SF | \$0 | |
| Corridors | Corridors | Walls | Gym Vestibule | | | SF | \$0 | |
| Corridors | Corridors | Walls | 1st vestibule to courtyard | 7 | 189 | SF | \$0 | |
| Corridors | Corridors | Walls | 3rd Floor | 6 | 6,474 | SF | \$15,275 | |
| Corridors | Corridors | Walls | 2nd Floor | 6 | 7,022 | SF | \$16,568 | |
| Corridors | Corridors | Walls | 1st Floor | 6 | 6,254 | SF | \$14,756 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | 1st fl service corridor | 7 | 305 | SF | \$0 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Gym Vestibule | 5 | 64 | SF | \$362 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Basement Boys Locker Stairs to Hallway | 6 | 115 | SF | \$326 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Center Stairs | 6 | 1,225 | SF | \$3,468 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | 2nd fl service corridor | 6 | 241 | SF | \$682 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | SW Stairs | 6 | 756 | SF | \$2,141 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | 1st vestibule to courtyard | 7 | 100 | SF | \$0 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | 3rd Floor | 7 | 4,728 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------------|-----------|-----------------|---|------|----------|------|---------|--------|
| Corridors Ceiling | Corridors | Plaster/Drywall | Boys Locker Stair to Gym | 6 | 150 | SF | \$425 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Gym Stairs | 6 | 650 | SF | \$1,840 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | NE Stairs | 7 | 756 | SF | \$0 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Basement Wrestling Room Stair | 6 | 108 | SF | \$306 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Gym Vestibule 2 | 5 | 64 | SF | \$362 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Vestibule from Gym to Hallway 2 | 6 | 86 | SF | \$244 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Vestibule from Gym to Hallway 1 | 6 | 86 | SF | \$244 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | SE Stairs | 6 | 596 | SF | \$1,688 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | NW Stairs | 6 | 756 | SF | \$2,141 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | 3rd fl service corridor and stairs to roof and down to lower floors | 7 | 580 | SF | \$0 | |
| Stairs | Corridors | Terrazzo | SE Stairs | 6 | 57 | SF | \$646 | |
| Stairs | Corridors | Terrazzo | Center Stairs | 6 | 101 | SF | \$1,144 | |
| Stairs | Corridors | Terrazzo | NE Stairs | 6 | 51 | SF | \$578 | |
| Stairs | Corridors | Terrazzo | NW Stairs | 6 | 51 | SF | \$578 | |
| Stairs | Corridors | Terrazzo | Gym Stairs | 6 | 78 | SF | \$883 | |
| Stairs | Corridors | Terrazzo | SW Stairs | 6 | 51 | SF | \$578 | |
| Floor | Classroom | Carpet | | 6 | 946 | SF | \$1,353 | |
| Floor | Classroom | Carpet | | 6 | 912 | SF | \$1,304 | |
| Floor | Classroom | Floor | | 7 | 1,150 | SF | \$0 | |
| Floor | Classroom | Floor | | | 706 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 638 | SF | \$912 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 1,470 | SF | \$2,102 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,112 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 1,470 | SF | \$2,102 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------------|----------|------|----------|------|---------|--------|
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,090 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 7 | 386 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 638 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 7 | 864 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,396 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 7 | 965 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 364 | SF | \$521 | |
| Floor | Classroom | Tile/Sheet | | 6 | 728 | SF | \$1,041 | |
| Floor | Classroom | Tile/Sheet | | 6 | 728 | SF | \$1,041 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,036 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 674 | SF | \$964 | |
| Floor | Classroom | Tile/Sheet | | 7 | 778 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 2,848 | SF | \$4,073 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 1,750 | SF | \$2,503 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 927 | SF | \$1,326 | |
| Floor | Classroom | Tile/Sheet | | 6 | 1,830 | SF | \$2,617 | |
| Floor | Classroom | Tile/Sheet | | 7 | 476 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,080 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 678 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 584 | SF | \$835 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 7 | 965 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 965 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 965 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|------------------------------|----------------|----------|------|----------|------|----------|--------|
| Floor | Classroom | Tile/Sheet | | 7 | 1,080 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| Floor | Classroom | Tile/Sheet | | 7 | 750 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,286 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 2,284 | SF | \$3,266 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,286 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 965 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 965 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 5 | 412 | SF | \$2,333 | |
| Floor | Classroom | Tile/Sheet | | 6 | 748 | SF | \$1,070 | |
| GYM_WALL | Standard Dedicated Gymnasium | Gymnasia Walls | 218 | 5 | 4,352 | SF | \$93,350 | |
| GYM_WALL | Standard Dedicated Gymnasium | Gymnasia Walls | 220 | 5 | 3,344 | SF | \$71,729 | |
| Lighting | Classroom | Lay-In | | 6 | 12 | EA | \$858 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 22 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 22 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 6 | 14 | EA | \$1,001 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 6 | 42 | EA | \$3,003 | |
| Lighting | Classroom | Lay-In | | 6 | 22 | EA | \$1,573 | |
| Lighting | Classroom | Lay-In | | 6 | 42 | EA | \$3,003 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 4 | 9 | EA | \$3,346 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 15 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 10 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|-----------|--------|----------|------|----------|------|---------|--------|
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 18 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 20 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 15 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 22 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 6 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 6 | 12 | EA | \$858 | |
| Lighting | Classroom | Lay-In | | 6 | 12 | EA | \$858 | |
| Lighting | Classroom | Lay-In | | 4 | 10 | EA | \$3,718 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 20 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 6 | 9 | EA | \$644 | |
| Lighting | Classroom | Lay-In | | 7 | 36 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 20 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 50 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 11 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 20 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 22 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 18 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 6 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 34 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 8 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 39 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Lighting | Classroom | Lay-In | | 6 | 14 | EA | \$1,001 | |
| Lighting | Classroom | Lay-In | | 6 | 14 | EA | \$1,001 | |
| Lighting | Classroom | Lay-In | | 6 | 14 | EA | \$1,001 | |
| Lighting | Classroom | Lay-In | | 6 | 14 | EA | \$1,001 | |
| Lighting | Classroom | Lay-In | | 6 | 14 | EA | \$1,001 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 14 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 6 | 14 | EA | \$1,001 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 20 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 20 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 25 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 25 | EA | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 14 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 32 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 14 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 6 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 15 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 36 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------|---------------------------------|------------------|----------------------------|------|----------|------|---------|--------|
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 6 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 8 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Multipurpose Room | Marker Board | rm 320 | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 11 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 12 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 22 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 32 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 20 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| RESTROOM_WALL | Adult Standard Student Restroom | Restroom Walls | in girls locker rm 122 | 6 | 577 | SF | \$1,469 | |
| RESTROOM_WALL | Locker/Shower Room | Restroom Walls | girls rm 122 | 7 | 1,717 | SF | \$0 | |
| RESTROOM_WALL | Staff Restroom | Restroom Walls | 3rd fl staff FP girls west | 6 | 544 | SF | \$1,385 | |
| THEATER_FLOOR | Auditorium - Dedicated | Auditorium Floor | 1st Floor | 6 | 1,025 | SF | \$4,837 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|---------------------|----------|------|----------|------|---------|--------|
| Wall | Classroom | Concrete Block | | 7 | 220 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 1,525 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 1,113 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 1,113 | SF | \$0 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 82 | SF | \$193 | |
| Wall | Classroom | Metal/Folding Panel | | 7 | 151 | SF | \$0 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 82 | SF | \$193 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 653 | SF | \$1,541 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 862 | SF | \$2,034 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 759 | SF | \$1,791 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,009 | SF | \$2,381 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,009 | SF | \$2,381 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 749 | SF | \$1,767 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 728 | SF | \$1,718 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,327 | SF | \$3,131 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 960 | SF | \$2,265 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------------------------|----------|------|----------|------|---------|--------|
| Wall | Classroom | Plaster/Drywall | | 6 | 432 | SF | \$1,019 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,746 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,009 | SF | \$2,381 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 958 | SF | \$2,260 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 980 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 998 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 968 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 4 | 40 | SF | \$378 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 942 | SF | \$2,223 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 942 | SF | \$2,223 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,083 | SF | \$2,555 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,033 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 862 | SF | \$2,034 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,009 | SF | \$2,381 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 927 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,314 | SF | \$3,100 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,098 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 456 | SF | \$1,076 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,838 | SF | \$4,337 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,327 | SF | \$3,131 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,009 | SF | \$2,381 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,009 | SF | \$2,381 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,505 | SF | \$3,551 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 892 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 716 | SF | \$1,689 | |
| Wall | Classroom | Structural Glazed Tile | | 7 | 48 | SF | \$0 | |
| Wall | Classroom | Wall | | 7 | 260 | SF | \$0 | glass |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|---------|--------------|
| Wall | Classroom | Wall | | 7 | 164 | SF | \$0 | |
| Wall | Classroom | Wall | | 7 | 472 | SF | \$0 | |
| Wall | Classroom | Wall | | 7 | 70 | SF | \$0 | |
| Wall | Classroom | Wall | | 6 | 1,068 | SF | \$2,520 | |
| Wall | Classroom | Wall | | 6 | 145 | SF | \$342 | |
| Wall | Classroom | Wall | | 7 | 236 | SF | \$0 | |
| Wall | Classroom | Wall | | 6 | 312 | SF | \$736 | glazed brick |

ROOM Sub Total \$1,259,142

Building Main Sub Total \$14,996,526

Building: Addition(1959/1974)
Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|-----------|---|-----------------------|------|----------|------|-----------|---|
| Canopy | | Metal Canopy | south main entry | 6 | 377 | SF | \$9,073 | |
| Doors | | Exterior Steel Door | West Entrances | 5 | 4 | EA | \$4,360 | |
| Doors | | Overhead Rolling / Garage Door | Northwest | 7 | 3 | EA | \$0 | |
| Doors | | Side Lite | north classroom doors | 5 | 6 | EA | \$4,485 | |
| Doors | | Store Front Door | Entire Building | 5 | 21 | EA | \$54,504 | |
| Doors | | Store Front Door | south main entry | 6 | 4 | EA | \$2,076 | |
| Doors | | Transom Lite | Entire Building | 5 | 23 | EA | \$21,490 | |
| Doors | | Transom Lite | south main entry | 6 | 4 | EA | \$1,133 | |
| Entrance | | Power Door Operator and Controls | south main entry | 7 | 1 | EA | \$0 | |
| Foundation | | Concrete Foundation | Entire Building | 7 | 1,420 | LF | \$0 | |
| Parapet | | Parapet 16" to 30" Height | Entire Building | 6 | 1,400 | LF | \$290,690 | failing and open joints between panels, no copings- top of precast panel is exposed |
| Parapet | | Parapet 16" to 30" Height | Entire Building | 5 | 15 | LF | \$4,813 | spalling at various locations |
| Roof System | | Interior Downspouts | Entire Building | 6 | 545 | LF | \$0 | |
| Roof System | | Interior Downspouts | Entire Building | 5 | 35 | LF | \$3,754 | blocked per engineer |
| Roof System | | Modified Bitumen Roof | Roof | 6 | 70,200 | SF | \$496,911 | snow covered, leaks per engineer |
| Roof System | | Roof Structure: Steel/Metal Deck/Concrete Topping | Roof | 7 | 69,820 | SF | \$0 | |
| Superstructure | | Concrete | Entire Building | 7 | 133,500 | SF | \$0 | |
| Walls | | Precast Panel Wall | Entire Building | 6 | 27,180 | SF | \$179,567 | joints failing |
| Windows | | Storefront Windows | south main entry | 6 | 285 | SF | \$1,630 | |

Building: Addition(1959/1974)

Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------------------|-----------|---|--------------------|------|----------|------|--------------------|--|
| Windows | | Storefront Windows | North Entrances | 5 | 600 | SF | \$29,155 | |
| Windows | | Window - Guards perforated | west of main entry | 6 | 450 | SF | \$0 | |
| Windows | | Windows - Casement Aluminum Double-pane | 1st Floor | 5 | 8,000 | SF | \$184,184 | do not operate, paint peeling between glass blinds |
| Windows | | Windows - Casement Lexan | 2nd Floor | 4 | 12,250 | SF | \$1,410,509 | |
| EXTERIOR Sub Total | | | | | | | \$2,698,336 | |

Building: Addition(1959/1974)

Category: ELECTRICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------------|-----------|--|-----------------------------|------|----------|------|------------------|--------|
| Emergency System | | Automatic Transfer switch | Electrical Room | 7 | 4 | EA | \$0 | |
| Emergency System | | Automatic Transfer switch | 1st Floor Electrical Closet | 6 | 2 | EA | \$2,860 | |
| Emergency System | | Emergency A/C power - Corridors and Stairs | Entire Building | 6 | 20,177 | SF | \$8,656 | |
| Emergency System | | Emergency A/C power - Gym and Lunch rooms | 2nd Floor | 6 | 17,130 | SF | \$9,063 | |
| Emergency System | | Emergency A/C power - Students Toilets | Entire Building | 6 | 2,916 | SF | \$1,251 | |
| Emergency System | | Exit Signs - Corridors and Stairs | Entire Building | 6 | 25 | EA | \$5,827 | |
| Emergency System | | Exit Signs - Lunchroom - Gym - multipurpose rooms | 2nd Floor | 6 | 9 | EA | \$2,098 | |
| Emergency System | | Independent Electrical Service for emergency power | Electrical Room | 6 | 1 | EA | \$1,430 | |
| Main Service | | Main Electrical service 2000 to 3000 A 277/480/3PH | Electrical Room | 6 | 1 | EA | \$30,388 | |
| Power Distribution | | Lighting and power panels | Entire Building | 6 | 23 | EA | \$16,445 | |
| Power Distribution | | Lighting and power panels | Electrical Room | 6 | 8 | EA | \$5,720 | |
| Power Distribution | | Main distribution panels 400-600 amp | Bsmt Electrical Room | 6 | 6 | EA | \$8,580 | |
| Power Distribution | | Main distribution panels above 600 amp | Electrical Closet | 6 | 3 | EA | \$6,435 | |
| Power Distribution | | Transformers 277/480-120/208 | Electrical Room | 6 | 7 | EA | \$8,008 | |
| ELECTRICAL Sub Total | | | | | | | \$106,761 | |

Building: Addition(1959/1974)

Category: FIRE PROTECTION

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------|-----------|--------------------------|-----------------|------|----------|------|-----------|--------|
| Fire Alarm | | Fire Alarm Strobe Lights | Entire Building | 6 | 133,500 | SF | \$47,726 | |
| Fire Alarm | | Fire Alarm System | Electrical Room | 6 | 133,500 | SF | \$162,269 | |
| Fire Alarm | | Fire Pump Controller | Fire pump room | 6 | 1 | EA | \$2,145 | |
| Pump Room Assembly | | Fire Pump 25-50hp | Fire pump room | 6 | 1 | EA | \$3,718 | |
| Pump Room Assembly | | Jockey Pump | Fire pump room | 6 | 1 | EA | \$744 | |
| Sprinkler System | | Sprinkler Heads | Entire Building | 6 | 133,500 | SF | \$7,636 | |

Building: Addition(1959/1974)

Category: FIRE

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------------------------|-----------|----------------------|-----------------|------|----------|------|------------------|--------|
| Sprinkler System | | Wet Sprinkler System | Entire Building | 6 | 133,500 | SF | \$76,362 | |
| FIRE PROTECTION Sub Total | | | | | | | \$300,600 | |

Building: Addition(1959/1974)

Category: MECHANICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------------|-----------|---|-----------------|------|----------|------|--------------------|--------|
| Air Conditioning | | Heat Pump - Self Contained | MDF Room | 6 | 1 | EA | \$844 | |
| Air Handling Systems | | Roof Top Unit - Multi Zone - Gas-Heating 10 to 20 tons | Roof | 4 | 1 | EA | \$50,050 | |
| Air Handling Systems | | Roof Top Unit - Multi Zone - Gas-Heating greater than 45 tons | Roof | 5 | 9 | EA | \$579,150 | |
| Heating Devices | | Cabinet Heaters With Electric Coils | 1st Floor | 6 | 8 | EA | \$4,004 | |
| Heating Devices | | Cabinet Heaters With Electric Coils | 2nd Floor | 6 | 1 | EA | \$501 | |
| Heating Devices | | Fin Tube Electric | 1st Floor | 5 | 12 | LF | \$858 | |
| Heating Devices | | Unit Heater - Electric | Basement | 6 | 2 | EA | \$2,860 | |
| Heating Devices | | Unit Heater - Electric | 2nd Floor | 6 | 1 | EA | \$1,430 | |
| Temperature Control | | Pneumatic System | Entire Building | 5 | 133,500 | SF | \$572,715 | |
| Temperature Control | | Thermostats - Pneumatic | Entire Building | 6 | 106 | EA | \$15,158 | |
| Temperature Control | | Zone Dampers | Entire Building | 6 | 106 | EA | \$15,158 | |
| Ventilation | | Exhaust Fan - Indoor | Basement | 6 | 2 | EA | \$1,001 | |
| Ventilation | | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof | 4 | 2 | EA | \$8,580 | |
| Ventilation | | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof | 6 | 2 | EA | \$858 | |
| Ventilation | | Exhaust Fans - Roof Mounted 500 to 1,500 cfm | Roof | 4 | 1 | EA | \$2,288 | |
| Ventilation | | Exhaust Fans - Roof Mounted 500 to 1,500 cfm | Roof | 5 | 4 | EA | \$5,148 | |
| Ventilation | | Exhaust Fans - Roof mounted less than 500 CFM | Roof | 5 | 1 | EA | \$1,030 | |
| Ventilation | | Type I Exhaust Hood - Kitchen or Culinary Arts | 2nd Floor | 7 | 1 | EA | \$0 | |
| Ventilation | | Type I Exhaust Hood - Kitchen or Culinary Arts | 1st Floor | 6 | 1 | EA | \$1,716 | |
| Ventilation | | Type II Exhaust Hood - Warming Kitchen | 2nd Floor | 7 | 3 | EA | \$0 | |
| MECHANICAL Sub Total | | | | | | | \$1,263,348 | |

Building: Addition(1959/1974)

Category: PLUMBING

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|---|---------------------------|------|----------|------|----------|--------|
| Hot Water | | Hot Water Heater - Gas more than 300,000 BTU/HR | 2nd Floor Mechanical room | 5 | 1 | EA | \$17,160 | |
| Hot Water | | Hot Water Heater - Gas more than 300,000 BTU/HR | 2nd Floor Mechanical room | 6 | 2 | EA | \$13,442 | |

Building: Addition(1959/1974)

Category: PLUMBING

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------------------|-----------|--|-----------------|------|----------|------|------------------|--------|
| Piping | | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 5 | 133,500 | SF | \$22,909 | |
| Piping | | Domestic Piping - Cold Water Risers | Entire Building | 5 | 133,500 | SF | \$43,908 | |
| Piping | | Domestic Piping - Hot Water from Riser to fixtures | Entire Building | 5 | 133,500 | SF | \$152,724 | |
| Piping | | Domestic Piping - Hot Water Return Risers | Entire Building | 5 | 133,500 | SF | \$28,636 | |
| Piping | | Domestic Piping - Hot Water Risers | Entire Building | 5 | 133,500 | SF | \$34,363 | |
| Piping | | Domestic Piping Cold Water Horizontal lines | Entire Building | 5 | 133,500 | SF | \$118,361 | |
| Piping | | Domestic Piping Hot Water Horizontal lines | Entire Building | 5 | 133,500 | SF | \$70,635 | |
| Piping | | Domestic Piping Hot Water Return Lines | Entire Building | 5 | 133,500 | SF | \$72,544 | |
| Piping | | Sanitary Piping | Entire Building | 5 | 133,500 | SF | \$82,089 | |
| Piping | | Storm Piping | Entire Building | 5 | 133,500 | SF | \$62,999 | |
| Piping | | Vent Piping | Entire Building | 5 | 133,500 | SF | \$47,726 | |
| Pumps | | Domestic Booster Pump duplex | Fire pump room | 6 | 1 | EA | \$3,146 | |
| Pumps | | Sump Pump | Fire pump room | 6 | 1 | EA | \$1,359 | |
| PLUMBING Sub Total | | | | | | | \$772,000 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|------------------|----------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 253 | 6 | 255 | SF | \$547 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 164 | 6 | 300 | SF | \$644 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 163 | 6 | 300 | SF | \$644 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 157 | 6 | 375 | SF | \$804 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 180D | 6 | 150 | SF | \$322 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 171 | 6 | 400 | SF | \$858 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 158 | 6 | 450 | SF | \$965 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 168 | 6 | 390 | SF | \$837 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 270D,E,F,G,H,J | 6 | 300 | SF | \$644 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 270B & C | 6 | 360 | SF | \$772 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 270 Main Counselors Office | 6 | 880 | SF | \$1,888 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|------------------|------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 270L | 6 | 200 | SF | \$429 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 166B | 6 | 220 | SF | \$472 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 166 | 6 | 1,755 | SF | \$3,764 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 163a | 6 | 195 | SF | \$418 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 166A | 6 | 225 | SF | \$483 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 271A & B Faculty Lounge | 6 | 1,500 | SF | \$3,218 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | rm 155 | 7 | 375 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 180G | 6 | 300 | SF | \$644 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Student Lounge | 6 | 948 | SF | \$2,033 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 180E | 6 | 150 | SF | \$322 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 270A Counselors Waiting Area | 6 | 300 | SF | \$644 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 180F | 6 | 131 | SF | \$281 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 166C | 6 | 100 | SF | \$215 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 273 Office in Faculty Dining | 6 | 100 | SF | \$215 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 270G, H, J | 6 | 300 | SF | \$644 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 264 Attendance Office | 6 | 428 | SF | \$918 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 166D | 6 | 100 | SF | \$215 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 256 | 6 | 485 | SF | \$1,040 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 256A | 6 | 174 | SF | \$373 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 256B | 6 | 174 | SF | \$373 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 256C | 6 | 205 | SF | \$440 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 272 Office in Faculty Dining | 6 | 100 | SF | \$215 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|---------------------------|------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 274 Office in Faculty Dining | 6 | 100 | SF | \$215 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 275 Office in Faculty Dining | 6 | 100 | SF | \$215 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Box Office in Student Dining | 5 | 575 | SF | \$3,256 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 271 Faculty Dining | 7 | 2,165 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 166A | 7 | 35 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 185A | 7 | 165 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 180H | 6 | 575 | SF | \$1,628 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 166R Break Room | 7 | 240 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined | Kitchen Office | 7 | 108 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 180E | 6 | 150 | SF | \$215 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | Student Lounge | 7 | 948 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 180G | 6 | 300 | SF | \$429 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 168 | 7 | 390 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 180D | 6 | 150 | SF | \$215 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 166A | 7 | 225 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 270D,E,F,G,H,J | 6 | 300 | SF | \$429 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 166C | 6 | 100 | SF | \$143 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 166B | 7 | 220 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 166 | 6 | 1,755 | SF | \$2,510 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 270G, H, J | 6 | 300 | SF | \$429 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 180F | 6 | 131 | SF | \$187 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | rm 163a | 7 | 195 | SF | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|-----------------------|------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | rm 163 | 6 | 300 | SF | \$429 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | rm 164 | 6 | 300 | SF | \$429 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 274 Office in Faculty Dining | 6 | 100 | SF | \$143 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 166D | 6 | 100 | SF | \$143 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 272 Office in Faculty Dining | 6 | 100 | SF | \$143 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 275 Office in Faculty Dining | 6 | 100 | SF | \$143 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 273 Office in Faculty Dining | 6 | 100 | SF | \$143 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 185A | 5 | 165 | SF | \$934 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 270B & C | 7 | 360 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 270A Counselors Waiting Area | 7 | 300 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | rm 158 | 7 | 450 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 271 Faculty Dining | 7 | 2,165 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | rm 157 | 7 | 375 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 270 Main Counselors Office | 7 | 880 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 166R Break Room | 5 | 240 | SF | \$1,359 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 166A | 7 | 35 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 270L | 7 | 200 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Box Office in Student Dining | 7 | 575 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | rm 155 | 7 | 375 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 180H | 7 | 575 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 256A | 7 | 174 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 271A & B Faculty Lounge | 7 | 1,500 | SF | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|----------------------------|------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Kitchen Office | 6 | 108 | SF | \$154 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 256C | 7 | 205 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 256 | 7 | 485 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 171 | 5 | 400 | SF | \$2,265 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 253 | 7 | 255 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 256B | 7 | 174 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 264 Attendance Office | 7 | 428 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 166R Break Room | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Kitchen Office | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 185A | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 180H | 6 | 12 | SF | \$9 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 270B & C | 7 | 6 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Student Lounge | 7 | 17 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 166A | 7 | 3 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 180G | 7 | 6 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | rm 155 | 7 | 7 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 168 | 7 | 8 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 166C | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 166 | 7 | 31 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 166B | 7 | 5 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 270L | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 270A Counselors Waiting Area | 7 | 6 | SF | \$0 | |

Building: Addition(1959/1974)
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|----------------------------|------------------------------|------|----------|------|------|--------|
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 270G, H, J | 7 | 6 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 270D,E,F,G,H,J | 7 | 6 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 253 | 7 | 5 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 180E | 7 | 3 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 270 Main Counselors Office | 7 | 20 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 271 Faculty Dining | 7 | 36 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | rm 158 | 7 | 10 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 256B | 7 | 3 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 256A | 7 | 3 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 256 | 7 | 10 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 180D | 7 | 3 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 256C | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 272 Office in Faculty Dining | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 273 Office in Faculty Dining | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 274 Office in Faculty Dining | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | rm 163a | 7 | 3 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Box Office in Student Dining | 7 | 11 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 264 Attendance Office | 7 | 5 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 271A & B Faculty Lounge | 7 | 27 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 171 | 7 | 7 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | rm 157 | 7 | 7 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | rm 164 | 7 | 4 | SF | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|----------------------------|------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | rm 163 | 6 | 4 | SF | \$3 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 275 Office in Faculty Dining | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 180F | 6 | 2 | SF | \$1 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 166D | 7 | 2 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 180F | 7 | 312 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 270L | 7 | 300 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 271A & B Faculty Lounge | 7 | 450 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 264 Attendance Office | 7 | 370 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | Box Office in Student Dining | 7 | 110 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 271 Faculty Dining | 7 | 1,140 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | Kitchen Office | 7 | 315 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 256 | 7 | 190 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | Student Lounge | 7 | 300 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 166R Break Room | 7 | 496 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 270 Main Counselors Office | 7 | 370 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 180F | 7 | 156 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 180H | 6 | 1,200 | SF | \$3,432 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 270G, H, J | 7 | 300 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 270L | 6 | 250 | SF | \$715 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 166B | 7 | 138 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 166 | 7 | 888 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 166A | 7 | 112 | SF | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|-------------------------|------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 168 | 7 | 312 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 185A | 7 | 432 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 171 | 6 | 50 | SF | \$118 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 155 | 6 | 812 | SF | \$1,916 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 158 | 6 | 225 | SF | \$531 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 166A | 7 | 535 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 166B | 7 | 578 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 155 | 7 | 75 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 166 | 6 | 250 | SF | \$590 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 166D | 6 | 50 | SF | \$118 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 163a | 6 | 150 | SF | \$354 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 163 | 7 | 150 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 166C | 6 | 50 | SF | \$118 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 256 | 6 | 360 | SF | \$849 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 256A | 6 | 265 | SF | \$625 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 256B | 6 | 410 | SF | \$967 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 253 | 7 | 130 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 271A & B Faculty Lounge | 6 | 740 | SF | \$1,746 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Box Office in Student Dining | 6 | 490 | SF | \$1,156 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 275 Office in Faculty Dining | 6 | 50 | SF | \$118 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 256C | 7 | 100 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 273 Office in Faculty Dining | 6 | 50 | SF | \$118 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|------------------------------|-------------------------------------|------|----------|------|----------|--------|
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 271 Faculty Dining | 7 | 520 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | rm 157 | 6 | 75 | SF | \$177 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 270 Main Counselors Office | 7 | 290 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 270A Counselors Waiting Area | 5 | 150 | SF | \$708 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 270B & C | 7 | 960 | SF | \$0 | |
| Doors | | Interior Steel Doors incl hw | Entire Building | 6 | 38 | EA | \$10,759 | |
| Doors | | Interior Steel Doors incl hw | Entire Building | 7 | 51 | EA | \$0 | |
| Doors | | Interior Wood Doors incl hw | Entire Building | 6 | 125 | EA | \$35,393 | |
| Doors | | Interior Wood Doors incl hw | Entire Building | 5 | 3 | EA | \$1,416 | |
| Doors | | Side-lite | Entire Building | 6 | 975 | SF | \$18,125 | |
| Doors | | Store Front Door | Entire Building | 6 | 8 | EA | \$1,888 | |
| Doors | | Store Front Door | Entire Building | 7 | 15 | EA | \$0 | |
| Doors | | Transom Window | Entire Building | 6 | 220 | SF | \$4,090 | |
| Drinking Fountains | Corridors | Single Fountain | 2nd Floor | 5 | 2 | EA | \$3,861 | |
| Kitchen | Cooking Kitchen | Ceiling - Splined | 2nd Floor | 6 | 3,060 | SF | \$8,752 | |
| Kitchen | Warming Kitchen | Ceiling - Splined | Servery 2 in Lunchroom on 2nd Floor | 7 | 460 | SF | \$0 | |
| Kitchen | Warming Kitchen | Ceiling - Splined | Servery 1 in Lunchroom on 2nd Floor | 5 | 890 | SF | \$6,313 | |
| Kitchen | Cooking Kitchen | Flooring - Concrete | 2nd Floor | 5 | 3,060 | SF | \$14,440 | |
| Kitchen | Warming Kitchen | Flooring - Concrete | Servery 1 in Lunchroom on 2nd Floor | 5 | 890 | SF | \$4,200 | |
| Kitchen | Warming Kitchen | Flooring - Concrete | Servery 2 in Lunchroom on 2nd Floor | 5 | 460 | SF | \$2,171 | |
| Kitchen | Warming Kitchen | Lighting - Lay-In | Servery 1 in Lunchroom on 2nd Floor | 7 | 18 | SF | \$0 | |
| Kitchen | Cooking Kitchen | Lighting - Lay-In | 2nd Floor | 7 | 46 | SF | \$0 | |
| Kitchen | Warming Kitchen | Lighting - Lay-In | Servery 2 in Lunchroom on 2nd Floor | 7 | 11 | SF | \$0 | |
| Kitchen | Cooking Kitchen | Wall - Concrete Block | 2nd Floor | 6 | 3,300 | SF | \$9,438 | |
| Kitchen | Warming Kitchen | Wall - Concrete Block | Servery 2 in Lunchroom on 2nd Floor | 7 | 970 | SF | \$0 | |
| Kitchen | Warming Kitchen | Wall - Concrete Block | Servery 1 in Lunchroom on 2nd Floor | 7 | 1,150 | SF | \$0 | |
| Library | Library | Casework | 180 | | | LF | \$0 | |
| Library | Library | Flooring Carpet | 180 | 6 | 6,370 | SF | \$9,109 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------|---------------------------------|-----------------------------|--|------|----------|------|------|--------|
| Library | Library | Lighting - Pendant/ Surface | 180 | 7 | 126 | SF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Women's Staff Restroom in Kitchen | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Staff Restroom in Kitchen | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Womens 1st flr SE | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Mens 1st flr SE | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Mens 1st flr SW | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Womens 1st flr SW | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Mens 1st flr NW | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Womens 1st flr NW | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Womens 1st flr NE | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Mens 1st flr NE | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Mens 2nd Flr NW | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Mens 2nd Flr NE in Faculty Dining | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | Womens 2nd Flr NE in Faculty Dining | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Womens 2nd flr NW in Student Dining Room | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Womens 2nd Flr SE | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Womens 2nd Flr SW | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | In Conference Room 166B | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Mens 2nd Flr SW | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Benches | Mens 2nd Flr SE | | | LF | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Mens 2nd Flr SE | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Womens 1st flr NE | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Womens 1st flr NW | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Womens 2nd Flr SW | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Mens 2nd Flr SW | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Womens 2nd Flr SE | | | EA | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------|---------------------------------|---------|--|------|----------|------|-------|--------|
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Womens 2nd flr NW in Student Dining Room | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Mens 2nd Flr NE in Faculty Dining | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Mens 2nd Flr NW | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | In Conference Room 166B | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Womens 1st flr SW | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Staff Restroom in Kitchen | 6 | 12 | EA | \$589 | |
| Locker/Shower Room | Staff Restroom | Lockers | Women's Staff Restroom in Kitchen | 6 | 15 | EA | \$736 | |
| Locker/Shower Room | Staff Restroom | Lockers | Mens 1st flr SE | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Womens 1st flr SE | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Mens 1st flr SW | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Mens 1st flr NE | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | Womens 2nd Flr NE in Faculty Dining | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Lockers | Mens 1st flr NW | | | EA | \$0 | |
| Locker/Shower Room | | Lockers | 2nd Floor Student Dining | 6 | 19 | EA | \$932 | |
| Locker/Shower Room | Staff Restroom | Showers | Womens 1st flr NW | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Mens 1st flr NW | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Womens 1st flr SW | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Womens 1st flr SE | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Staff Restroom in Kitchen | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Womens 1st flr NE | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Mens 1st flr SW | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Women's Staff Restroom in Kitchen | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Womens 2nd flr NW in Student Dining Room | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Womens 2nd Flr SW | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Mens 1st flr SE | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Womens 2nd Flr SE | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Womens 2nd Flr NE in Faculty Dining | | | EA | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------------|---------------------------------|----------------------------|-------------------------------------|------|----------|------|-----------|--------|
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Mens 2nd Flr SE | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Mens 2nd Flr NE in Faculty Dining | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Mens 2nd Flr NW | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | In Conference Room 166B | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | Mens 1st flr NE | | | EA | \$0 | |
| Locker/Shower Room | Adult Standard Student Restroom | Showers | Mens 2nd Flr SW | | | EA | \$0 | |
| Lunchroom | Lunchroom | Ceiling - Lay-In | 2nd Floor | 6 | 15,330 | SF | \$32,883 | |
| Lunchroom | Multipurpose Room | Ceiling - Lay-In | Forum rm 162 | 6 | 1,800 | SF | \$3,861 | |
| Lunchroom | Multipurpose Room | Flooring - Carpet | Forum rm 162 | 6 | 1,605 | SF | \$2,295 | |
| Lunchroom | Multipurpose Room | Flooring - Tile/Sheet | Forum rm 162 | 7 | 195 | SF | \$0 | |
| Lunchroom | Lunchroom | Flooring - Tile/Sheet | 2nd Floor | 6 | 15,330 | SF | \$21,922 | |
| Lunchroom | Lunchroom | Lighting - Pendant/Surface | 2nd Floor | 6 | 315 | SF | \$225 | |
| Lunchroom | Multipurpose Room | Lighting - Pendant/Surface | Forum rm 162 | 7 | 35 | SF | \$0 | |
| Lunchroom | Cooking Kitchen | Serving Line | 2nd Floor | | | LF | \$0 | |
| Lunchroom | Lunchroom | Serving Line | 2nd Floor | | | LF | \$0 | |
| Lunchroom | Multipurpose Room | Serving Line | Forum rm 162 | | | LF | \$0 | |
| Lunchroom | Warming Kitchen | Serving Line | Servery 2 in Lunchroom on 2nd Floor | 7 | 36 | LF | \$0 | |
| Lunchroom | Warming Kitchen | Serving Line | Servery 1 in Lunchroom on 2nd Floor | 7 | 72 | LF | \$0 | |
| Lunchroom | Lunchroom | Wall - Concrete Block | 2nd Floor | 6 | 1,200 | SF | \$3,432 | |
| Lunchroom | Multipurpose Room | Wall - Plaster/Drywall | Forum rm 162 | 7 | 562 | SF | \$0 | |
| MDF/IDF | | Finishes | 249A | 7 | 450 | SF | \$0 | |
| MDF/IDF | | Ventilation and Cooling | 249A | 6 | 450 | EA | \$630,630 | |
| Mechanical/Service Rooms | | Janitor's Closet | Entire Building | 6 | 2 | SF | \$9 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | Entire Building | 6 | 7,708 | SF | \$36,374 | |
| Mechanical/Service Rooms | | Storage Room | Kitchen Storage | 7 | 760 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | In Music Room 174 | 6 | 288 | SF | \$1,359 | |
| Mechanical/Service Rooms | | Storage Room | Box Office Storage | 7 | 280 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | In Main Office | 7 | 360 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | In Room 181 | 7 | 454 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | Dark Room Storage | 7 | 100 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | Drama Storage | 7 | 280 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | In Resource Room | 7 | 433 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | In Conference Room 166B | 7 | 20 | SF | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|---------------------------|--|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom | Accessories | Mens 2nd Flr NE in Faculty Dining | 7 | 140 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Mens 2nd Flr SE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | Mens 2nd Flr NW | 6 | 180 | SF | \$1,390 | |
| Staff Restroom | Staff Restroom | Accessories | Mens 1st flr NE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | Womens 1st flr NE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | Mens 1st flr SE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Mens 1st flr NW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Womens 1st flr SW | 6 | 180 | SF | \$1,390 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Mens 1st flr SW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | Staff Restroom in Kitchen | 7 | 104 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | Women's Staff Restroom in Kitchen | 6 | 132 | SF | \$1,019 | |
| Staff Restroom | Staff Restroom | Accessories | Womens 1st flr NW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Womens 2nd Flr SE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Womens 2nd flr NW in Student Dining Room | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Womens 2nd Flr SW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Accessories | Mens 2nd Flr SW | 5 | 180 | SF | \$4,587 | |
| Staff Restroom | Staff Restroom | Accessories | Womens 1st flr SE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | Womens 2nd Flr NE in Faculty Dining | 7 | 140 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Womens 1st flr SE | 6 | 180 | SF | \$510 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Mens 2nd Flr NE in Faculty Dining | 6 | 140 | SF | \$396 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Mens 2nd Flr NW | 6 | 180 | SF | \$510 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | In Conference Room 166B | 7 | 20 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Mens 1st flr NE | 6 | 180 | SF | \$510 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Womens 1st flr NE | 6 | 180 | SF | \$510 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Mens 1st flr NW | 5 | 180 | SF | \$1,019 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Mens 1st flr SW | 6 | 180 | SF | \$510 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Mens 1st flr SE | 6 | 180 | SF | \$510 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|---------------------------|--|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | Womens 2nd Flr NE in Faculty Dining | 6 | 140 | SF | \$396 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Womens 2nd flr NW in Student Dining Room | 6 | 180 | SF | \$510 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Womens 2nd Flr SE | 6 | 180 | SF | \$510 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Mens 2nd Flr SW | 5 | 180 | SF | \$1,019 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Womens 2nd Flr SW | 6 | 180 | SF | \$510 | |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | Womens 1st flr SW | 6 | 180 | SF | \$510 | |
| Staff Restroom | Staff Restroom | Ceiling - Splined | Staff Restroom in Kitchen | 6 | 104 | SF | \$223 | |
| Staff Restroom | Staff Restroom | Ceiling - Splined | Women's Staff Restroom in Kitchen | 7 | 132 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Womens 2nd Flr SE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Mens 1st flr NW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Womens 1st flr NW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Womens 1st flr NE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Mens 1st flr NE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | In Conference Room 166B | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Mens 2nd Flr NW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Mens 2nd Flr NE in Faculty Dining | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Womens 1st flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Womens 2nd flr NW in Student Dining Room | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Mens 2nd Flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Womens 2nd Flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Womens 2nd Flr NE in Faculty Dining | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Womens 1st flr SE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Mens 1st flr SE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Women's Staff Restroom in Kitchen | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Floor Drain | Staff Restroom in Kitchen | 7 | 1 | EA | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|-----------------------------------|--|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Mens 2nd Flr SE | 6 | 1 | EA | \$300 | |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain | Mens 1st flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | Womens 1st flr NE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Womens 2nd Flr SW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Mens 1st flr SW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | In Conference Room 166B | 7 | 20 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Womens 2nd Flr SE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | Mens 2nd Flr NE in Faculty Dining | 7 | 140 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | Staff Restroom in Kitchen | 7 | 104 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Mens 2nd Flr SW | 5 | 180 | SF | \$2,831 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Mens 2nd Flr SE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | Mens 1st flr NE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | Womens 1st flr SE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Womens 2nd flr NW in Student Dining Room | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | Womens 2nd Flr NE in Faculty Dining | 7 | 140 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Womens 1st flr SW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | Mens 1st flr SE | 7 | 180 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | Mens 1st flr NW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | Womens 1st flr NW | 7 | 180 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Womens 1st flr SE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Mens 1st flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Womens 1st flr SW | 6 | 1 | EA | \$217 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Mens 1st flr SE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Womens 2nd flr NW in Student Dining Room | 5 | 1 | EA | \$716 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Womens 2nd Flr SE | 7 | 1 | EA | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|------------|--|------|----------|------|-------|--------|
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Mens 1st flr NW | 5 | 1 | EA | \$716 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Womens 1st flr NW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Mens 1st flr NE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | In Conference Room 166B | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Mens 2nd Flr NW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Mens 2nd Flr SE | 6 | 1 | EA | \$217 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Mens 2nd Flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Staff Restroom in Kitchen | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Mens 2nd Flr NE in Faculty Dining | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Womens 1st flr NE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | Womens 2nd Flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Womens 2nd Flr NE in Faculty Dining | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | Women's Staff Restroom in Kitchen | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Mens 1st flr NW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Women's Staff Restroom in Kitchen | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Womens 1st flr SE | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Womens 2nd flr NW in Student Dining Room | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Mens 1st flr SE | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Womens 2nd Flr NE in Faculty Dining | 6 | 2 | EA | \$744 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Mens 1st flr SW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Mens 2nd Flr SW | 6 | 2 | EA | \$744 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Womens 2nd Flr SW | 6 | 2 | EA | \$744 | |
| Staff Restroom | Staff Restroom | Lavatory | Mens 2nd Flr NE in Faculty Dining | 6 | 2 | EA | \$744 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Womens 1st flr SW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Womens 2nd Flr SE | 7 | 2 | EA | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|-----------------------------|--|------|----------|------|-------|--------|
| Staff Restroom | Staff Restroom | Lavatory | Womens 1st flr NW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Womens 1st flr NE | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Mens 1st flr NE | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Staff Restroom in Kitchen | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Lavatory | In Conference Room 166B | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | Mens 2nd Flr NW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lavatory | Mens 2nd Flr SE | 6 | 2 | EA | \$744 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | Womens 2nd Flr SW | 6 | 5 | SF | \$4 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Staff Restroom in Kitchen | 7 | 3 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Womens 1st flr SE | 6 | 5 | SF | \$4 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | Mens 1st flr SW | 6 | 5 | SF | \$4 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | Womens 1st flr SW | 6 | 5 | SF | \$4 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | Mens 1st flr NW | 7 | 5 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Womens 1st flr NW | 7 | 5 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | Womens 2nd flr NW in Student Dining Room | 6 | 5 | SF | \$4 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Womens 1st flr NE | 6 | 5 | SF | \$4 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | Mens 2nd Flr SW | 7 | 1 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Mens 1st flr NE | 6 | 5 | SF | \$4 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Mens 2nd Flr NW | 6 | 5 | SF | \$4 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Mens 2nd Flr NE in Faculty Dining | 6 | 4 | SF | \$3 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Mens 1st flr SE | 6 | 5 | SF | \$4 | |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | Mens 2nd Flr SE | 6 | 5 | SF | \$4 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | Women's Staff Restroom in Kitchen | 7 | 3 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Pendant/ Surface | In Conference Room 166B | 4 | 1 | SF | \$4 | |
| Staff Restroom | Staff Restroom | Lighting - Wall Mounted | In Conference Room 166B | 4 | 1 | EA | \$322 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Womens 1st flr SW | 7 | 5 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Mens 1st flr SW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Staff Restroom in Kitchen | 7 | 1 | EA | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|------------|--|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Partitions | Womens 2nd Flr SE | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Mens 1st flr SE | 6 | 2 | EA | \$359 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Mens 1st flr NW | 6 | 1 | EA | \$179 | |
| Staff Restroom | Staff Restroom | Partitions | Womens 1st flr NW | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Womens 1st flr NE | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Mens 1st flr NE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | In Conference Room 166B | | | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Mens 2nd Flr SE | 6 | 1 | EA | \$179 | |
| Staff Restroom | Staff Restroom | Partitions | Women's Staff Restroom in Kitchen | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Mens 2nd Flr NW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Womens 2nd flr NW in Student Dining Room | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Womens 1st flr SE | 7 | 5 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Womens 2nd Flr NE in Faculty Dining | 7 | 3 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Mens 2nd Flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Partitions | Womens 2nd Flr SW | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | Mens 2nd Flr NE in Faculty Dining | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | Mens 2nd Flr NE in Faculty Dining | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Mens 1st flr SW | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | Mens 1st flr NE | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Mens 2nd Flr SE | 7 | 3 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Mens 2nd Flr SE | 5 | 1 | EA | \$1,859 | |
| Staff Restroom | Staff Restroom | Urinals | In Conference Room 166B | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | Mens 2nd Flr NW | 7 | 4 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Mens 1st flr NW | 7 | 4 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Mens 2nd Flr SW | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | Mens 1st flr SE | 7 | 4 | EA | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|--------------------------------|--|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom | Urinals | Women's Staff Restroom in Kitchen | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | Staff Restroom in Kitchen | 6 | 1 | EA | \$372 | |
| Staff Restroom | Adult Standard Student Restroom | Urinals | Womens 2nd flr NW in Student Dining Room | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Mens 1st flr NE | 7 | 576 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Staff Restroom in Kitchen | 7 | 400 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Women's Staff Restroom in Kitchen | 7 | 480 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Mens 1st flr SE | 7 | 576 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Womens 1st flr SE | 7 | 576 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | Mens 2nd Flr SW | 5 | 576 | SF | \$9,060 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Womens 1st flr NW | 7 | 576 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | Womens 1st flr SW | 7 | 576 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | Womens 2nd Flr SW | 7 | 576 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | Womens 2nd Flr SE | 7 | 576 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | Womens 2nd flr NW in Student Dining Room | 7 | 576 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Womens 2nd Flr NE in Faculty Dining | 7 | 576 | SF | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | Mens 2nd Flr SE | 7 | 576 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Mens 2nd Flr NE in Faculty Dining | 7 | 576 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Mens 2nd Flr NW | 6 | 576 | SF | \$1,466 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | In Conference Room 166B | 7 | 144 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Tile Ceramic/ Porcelain | Womens 1st flr NE | 7 | 576 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Womens 1st flr SE | 7 | 5 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | In Conference Room 166B | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Womens 2nd Flr SE | 7 | 4 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Womens 2nd flr NW in Student Dining Room | 7 | 4 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Womens 2nd Flr SW | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Womens 2nd Flr NE in Faculty Dining | 7 | 3 | EA | \$0 | |

Building: Addition(1959/1974)

Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------------------|---------------------------------|--------------|-----------------------------------|------|----------|------|------------------|--------|
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Mens 2nd Flr SE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Mens 2nd Flr NE in Faculty Dining | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Mens 2nd Flr NW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Mens 2nd Flr SW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Mens 1st flr NE | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Womens 1st flr NE | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Womens 1st flr NW | 7 | 4 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Mens 1st flr NW | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Mens 1st flr SW | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Mens 1st flr SE | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Women's Staff Restroom in Kitchen | 7 | 2 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | Staff Restroom in Kitchen | 7 | 1 | EA | \$0 | |
| Staff Restroom | Adult Standard Student Restroom | Water Closet | Womens 1st flr SW | 7 | 5 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 1 | EA | \$386 | |
| Vocational Shop | Classroom | Work Sink | | 4 | 1 | EA | \$3,861 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 1 | EA | \$1,931 | |
| Vocational Shop | Classroom | Work Sink | | 5 | 1 | EA | \$1,931 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 12 | EA | \$4,633 | |
| INTERIOR Sub Total | | | | | | | \$974,208 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------|-------------------------------|-----------------------------|------------------------------|------|----------|------|---------|--------|
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 270A Counselors Waiting Area | 6 | 600 | SF | \$1,416 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 271 Faculty Dining | 6 | 1,242 | SF | \$2,930 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 256B | 6 | 120 | SF | \$283 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 180D | 6 | 625 | SF | \$1,475 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | rm 163 | 6 | 688 | SF | \$1,623 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------|-------------------------------|-----------------------------|------------------------------|------|----------|------|---------|-------------|
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 256 | 6 | 445 | SF | \$1,050 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | rm 164 | 6 | 663 | SF | \$1,564 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | rm 164 | 7 | 212 | SF | \$0 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | rm 158 | 6 | 812 | SF | \$1,916 | metal panel |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 256A | 6 | 265 | SF | \$625 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 180E | 6 | 625 | SF | \$1,475 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 171 | 6 | 875 | SF | \$2,065 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | rm 157 | 6 | 750 | SF | \$1,770 | metal panel |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | rm 163a | 6 | 562 | SF | \$1,326 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 271A & B Faculty Lounge | 6 | 400 | SF | \$944 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 256C | 6 | 305 | SF | \$720 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 264 Attendance Office | 7 | 510 | SF | \$0 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 275 Office in Faculty Dining | 6 | 270 | SF | \$637 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 274 Office in Faculty Dining | 6 | 370 | SF | \$873 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 273 Office in Faculty Dining | 6 | 270 | SF | \$637 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 272 Office in Faculty Dining | 6 | 370 | SF | \$873 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 270D,E,F,G,H,J | 6 | 1,125 | SF | \$2,654 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 270 Main Counselors Office | 7 | 370 | SF | \$0 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 180G | 6 | 875 | SF | \$2,065 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 166D | 6 | 355 | SF | \$838 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 168 | 6 | 680 | SF | \$1,604 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 166C | 6 | 355 | SF | \$838 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------|-------------------------------|-----------------------------|----------------------------|------|----------|------|---------|--------|
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | rm 157 | 7 | 63 | SF | \$0 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 166 | 6 | 1,562 | SF | \$3,686 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | Student Lounge | 7 | 494 | SF | \$0 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 270G, H, J | 6 | 825 | SF | \$1,947 | |
| ADMIN_WALL | Administrative Suites/Offices | Administrative Office Walls | 270 Main Counselors Office | 7 | 305 | SF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|-----------|-------------|----------|------|----------|------|---------|--------|
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | | | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 5 | LF | \$0 | |
| Ceiling | Classroom | Ceiling | | | 600 | SF | \$0 | |
| Ceiling | Classroom | Ceiling | | | 600 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,201 | SF | \$2,576 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,853 | SF | \$3,975 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,208 | SF | \$2,591 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 750 | SF | \$1,609 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 600 | SF | \$1,287 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 330 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 638 | SF | \$1,369 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,087 | SF | \$2,332 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,120 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 368 | SF | \$789 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 960 | SF | \$2,059 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 484 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 800 | SF | \$1,716 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 750 | SF | \$1,609 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 790 | SF | \$1,695 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------|-------------------|-----------------|--------------|------|----------|------|----------|--------|
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 784 | SF | \$1,682 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,298 | SF | \$2,784 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 4,800 | SF | \$10,296 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 900 | SF | \$1,931 | |
| Ceiling | Classroom | Plaster/Drywall | | 6 | 2,157 | SF | \$6,107 | |
| Ceiling | Classroom | Plaster/Drywall | | 6 | 480 | SF | \$1,359 | |
| Ceiling | Classroom | Plaster/Drywall | | 5 | 435 | SF | \$2,463 | |
| Ceiling | Classroom | Plaster/Drywall | | 6 | 1,377 | SF | \$3,899 | |
| Ceiling | Classroom | Splined Ceiling | | 6 | 3,295 | SF | \$7,068 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 10 | LF | \$1,216 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 34 | LF | \$4,133 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 10 | LF | \$1,216 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Multipurpose Room | Chalk Board | Forum rm 162 | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 10 | LF | \$1,216 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 10 | LF | \$1,216 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 4 | LF | \$486 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 8 | LF | \$972 | |
| Chalk Board | Lunchroom | Chalk Board | 2nd Floor | 4 | | LF | | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------|-----------|--------------------|---|------|----------|------|-----------|--------|
| Chalk Board | Classroom | Chalk Board | | 4 | 16 | LF | \$1,945 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 25 | LF | \$3,039 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 16 | LF | \$1,945 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 8 | LF | \$972 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Corridors | Corridors | Concrete Block | Connecting Corridor 1st and 2nd Floor | 6 | 1,170 | SF | \$3,346 | |
| Corridors | Corridors | Concrete Block | Entire Building Stairs, Entrance 2,3,5 & 12 | 7 | 3,102 | SF | \$0 | |
| Corridors | Corridors | Concrete Block | 2nd Floor | 7 | 1,328 | SF | \$0 | |
| Corridors | Corridors | Concrete Block | 2nd Floor | 6 | 264 | SF | \$755 | |
| Corridors | Corridors | Concrete Block | 1st Floor | 6 | 2,166 | SF | \$6,195 | |
| Corridors | Corridors | Concrete Block | Entire Building Stairs, Entrance 2,3,5 & 12 | 6 | 1,034 | SF | \$2,957 | |
| Corridors | Corridors | Drinking Fountains | Entire Building Stairs, Entrance 2,3,5 & 12 | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | 1st Floor | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Connecting Corridor 1st and 2nd Floor | | | EA | \$0 | |
| Corridors | Corridors | Drop/Lay-In | 1st Floor | 6 | 14,147 | SF | \$30,345 | |
| Corridors | Corridors | Drop/Lay-In | Connecting Corridor 1st and 2nd Floor | 6 | 365 | SF | \$783 | |
| Corridors | Corridors | Drop/Lay-In | Entire Building Stairs, Entrance 2,3,5 & 12 | 6 | 2,260 | SF | \$4,848 | |
| Corridors | Corridors | Drop/Lay-In | 2nd Floor | 6 | 5,300 | SF | \$11,369 | |
| Corridors | Corridors | Lay-In | 1st Floor | 6 | 2,213 | EA | \$1,582 | |
| Corridors | Corridors | Lay-In | Connecting Corridor 1st and 2nd Floor | 6 | 730 | EA | \$522 | |
| Corridors | Corridors | Lay-In | Entire Building Stairs, Entrance 2,3,5 & 12 | 7 | 1,332 | EA | \$0 | |
| Corridors | Corridors | Metal Panel | 1st Floor | 6 | 8,475 | SF | \$71,988 | |
| Corridors | Corridors | Metal Panel | 2nd Floor | 5 | 8,482 | SF | \$242,585 | |
| Corridors | Corridors | Pendant/Surface | 2nd Floor | 6 | 5,300 | EA | \$3,790 | |
| Corridors | Corridors | Pendant/Surface | 1st Floor | 6 | 11,934 | EA | \$8,533 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------------|-----------|---------------------|---|------|----------|------|----------|--------|
| Corridors | Corridors | Pendant/Surface | Entire Building Stairs, Entrance 2,3,5 & 12 | 6 | 2,260 | EA | \$1,616 | |
| Corridors | Corridors | Plaster/Drywall | Entire Building Stairs, Entrance 2,3,5 & 12 | 6 | 1,980 | SF | \$4,672 | |
| Corridors | Corridors | Single Water Cooler | 2nd Floor | 7 | 4 | EA | \$0 | |
| Corridors | Corridors | Single Water Cooler | 2nd Floor | 6 | 2 | EA | \$1,230 | |
| Corridors | Corridors | Stair Handrails | 2nd Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Entire Building Stairs, Entrance 2,3,5 & 12 | 7 | 400 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 1st Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Connecting Corridor 1st and 2nd Floor | | | LF | \$0 | |
| Corridors | Corridors | Stairs | Connecting Corridor 1st and 2nd Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 1st Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 2nd Floor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Entire Building Stairs, Entrance 2,3,5 & 12 | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Connecting Corridor 1st and 2nd Floor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 1st Floor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 2nd Floor | 5 | 118 | EA | \$21,093 | |
| Corridors | Corridors | Terrazzo | 1st Floor | 6 | 3,112 | SF | \$17,623 | |
| Corridors | Corridors | Terrazzo | Entire Building Stairs, Entrance 2,3,5 & 12 | 7 | 3,588 | SF | \$0 | |
| Corridors | Corridors | Tile/Sheet Flooring | 2nd Floor | 6 | 5,300 | SF | \$7,579 | |
| Corridors | Corridors | Tile/Sheet Flooring | Connecting Corridor 1st and 2nd Floor | 7 | 730 | SF | \$0 | |
| Corridors | Corridors | Tile/Sheet Flooring | 1st Floor | 6 | 11,035 | SF | \$15,780 | |
| Corridors | Corridors | Walls | 1st Floor | 7 | 3,775 | SF | \$0 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Entire Building Stairs, Entrance 2,3,5 & 12 | 5 | 1,332 | SF | \$7,543 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Connecting Corridor 1st and 2nd Floor | 5 | 365 | SF | \$2,067 | |
| Stairs | Corridors | Terrazzo | Entire Building Stairs, Entrance 2,3,5 & 12 | 7 | 92 | SF | \$0 | |
| Floor | Classroom | Carpet | | 5 | 790 | SF | \$2,824 | |
| Floor | Classroom | Carpet | | 4 | 2,067 | SF | \$21,459 | |
| Floor | Classroom | Carpet | | 7 | 1,853 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 960 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------|-----------------|----------------|-----------|------|----------|------|----------|--------|
| Floor | Classroom | Tile/Sheet | | 5 | 4,800 | SF | \$27,181 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 600 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 915 | SF | \$1,308 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 484 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 330 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,087 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 638 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 750 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 368 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 5 | 435 | SF | \$2,463 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,377 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 600 | SF | \$858 | |
| Floor | Classroom | Tile/Sheet | | 7 | 600 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 800 | SF | \$1,144 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,201 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,298 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 750 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,208 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 90 | SF | \$129 | |
| Floor | Classroom | Tile/Sheet | | 7 | 900 | SF | \$0 | |
| Floor | Classroom | Wood | | 5 | 2,860 | SF | \$40,489 | |
| KITCHEN_WALL | Cooking Kitchen | Kitchen Walls | 2nd Floor | 7 | 470 | SF | \$0 | |
| LIBRARY_CEILING | Library | Drop/Lay-In | 180 | 6 | 6,370 | SF | \$13,664 | |
| LIBRARY_WALL | Library | Concrete Block | 180 | 7 | 625 | SF | \$0 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------|-----------|-----------------|----------|------|----------|------|----------|--------|
| LIBRARY_WALL | Library | Library Walls | 180 | 6 | 2,242 | SF | \$6,412 | |
| Lighting | Classroom | Lay-In | | 6 | 37 | EA | \$2,646 | |
| Lighting | Classroom | Lay-In | | 6 | 27 | EA | \$1,931 | |
| Lighting | Classroom | Lay-In | | 6 | 6 | EA | \$429 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 26 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 16 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 30 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 11 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 8 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 4 | 30 | EA | \$11,798 | |
| Lighting | Classroom | Pendant/Surface | | 6 | 19 | EA | \$1,359 | |
| Lighting | Classroom | Pendant/Surface | | 6 | 1 | EA | \$72 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 13 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 23 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 18 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 37 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 18 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 8 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 11 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 23 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 4 | 1 | EA | \$393 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 18 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 6 | 150 | EA | \$10,725 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 21 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 16 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 11 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 18 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 18 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 6 | 5 | EA | \$358 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------|-------------------|-----------------|--------------|------|----------|------|----------|--------|
| Lighting | Classroom | Pendant/Surface | | 6 | 14 | EA | \$1,001 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 13 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 5 | 11 | EA | \$1,573 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 17 | EA | \$0 | |
| LUNCH_WALL | Multipurpose Room | Lunchroom Walls | Forum rm 162 | 6 | 1,062 | SF | \$3,037 | |
| LUNCH_WALL | Lunchroom | Lunchroom Walls | 2nd Floor | 6 | 4,800 | SF | \$13,728 | |
| LUNCH_WALL | Multipurpose Room | Lunchroom Walls | Forum rm 162 | 7 | 250 | SF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Multipurpose Room | Marker Board | Forum rm 162 | 5 | 12 | LF | \$686 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 14 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 20 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 8 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 20 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 6 | 12 | LF | \$343 | |
| Marker Board | Classroom | Marker Board | | 7 | 20 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 15 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 6 | 12 | LF | \$343 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 20 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 10 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 12 | LF | \$0 | |
| Marker Board | Lunchroom | Marker Board | 2nd Floor | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------|---------------------------------|---------------------|-------------------------------------|------|----------|------|---------|--------|
| Marker Board | Classroom | Marker Board | | 4 | 5 | LF | \$608 | |
| Marker Board | Classroom | Marker Board | | 5 | 9 | LF | \$515 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 5 | 6 | LF | \$343 | |
| RESTROOM_CEILING | Adult Standard Student Restroom | Restroom Ceiling | Mens 2nd Flr SE | 5 | 180 | SF | \$1,019 | |
| RESTROOM_CEILING | Staff Restroom | Restroom Ceiling | Womens 1st flr NW | 7 | 180 | SF | \$0 | |
| RESTROOM_FLOOR | Staff Restroom | Restroom Floor | Mens 2nd Flr NW | 6 | 180 | SF | \$458 | |
| RESTROOM_FLOOR | Staff Restroom | Restroom Floor | Women's Staff Restroom in Kitchen | | 132 | SF | \$0 | |
| RESTROOM_LIGHT | Staff Restroom | Restroom Lighting | Womens 2nd Flr NE in Faculty Dining | 7 | 4 | EA | \$0 | |
| RESTROOM_LIGHT | Adult Standard Student Restroom | Restroom Lighting | Womens 2nd Flr SE | 7 | 5 | EA | \$0 | |
| RESTROOM_WALL | Adult Standard Student Restroom | Restroom Walls | Mens 1st flr SW | 6 | 576 | SF | \$1,466 | |
| RESTROOM_WALL | Adult Standard Student Restroom | Restroom Walls | Mens 1st flr NW | 6 | 576 | SF | \$1,466 | |
| Wall | Classroom | Concrete Block | | 7 | 138 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 375 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 6,188 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 750 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 6 | 500 | SF | \$1,430 | |
| Wall | Classroom | Concrete Block | | 7 | 290 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 6 | 1,206 | SF | \$3,449 | |
| Wall | Classroom | Concrete Block | | 6 | 250 | SF | \$715 | |
| Wall | Classroom | Concrete Block | | 7 | 188 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 100 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 150 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 120 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 150 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 1,586 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 375 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 6 | 1,096 | SF | \$3,135 | |
| Wall | Classroom | Concrete Block | | 7 | 1,855 | SF | \$0 | |
| Wall | Classroom | Concrete Block | | 7 | 60 | SF | \$0 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 900 | SF | \$2,124 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 600 | SF | \$1,416 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 750 | SF | \$1,770 | |

Building: Addition(1959/1974)

Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|---------------------|----------|------|----------|------|----------|--------|
| Wall | Classroom | Metal/Folding Panel | | 6 | 550 | SF | \$1,298 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,125 | SF | \$2,654 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 650 | SF | \$1,534 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 462 | SF | \$1,090 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,125 | SF | \$2,654 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,125 | SF | \$2,654 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 750 | SF | \$1,770 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,125 | SF | \$2,654 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,125 | SF | \$2,654 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 750 | SF | \$1,770 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 894 | SF | \$2,109 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 900 | SF | \$2,124 | |
| Wall | Classroom | Metal/Folding Panel | | 7 | 1,063 | SF | \$0 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,100 | SF | \$2,595 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,125 | SF | \$2,654 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 625 | SF | \$1,475 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 500 | SF | \$1,180 | |
| Wall | Classroom | Metal/Folding Panel | | 4 | 744 | SF | \$37,237 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 735 | SF | \$1,734 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,250 | SF | \$2,949 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,160 | SF | \$2,737 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 750 | SF | \$1,770 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 600 | SF | \$1,416 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 600 | SF | \$1,416 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 730 | SF | \$1,722 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 312 | SF | \$736 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 312 | SF | \$736 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 1,100 | SF | \$2,595 | |
| Wall | Classroom | Metal/Folding Panel | | 6 | 500 | SF | \$1,180 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 275 | SF | \$649 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 300 | SF | \$708 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 150 | SF | \$354 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 150 | SF | \$354 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 300 | SF | \$708 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,025 | SF | \$2,418 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 468 | SF | \$1,104 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 462 | SF | \$1,090 | |

Building: Addition(1959/1974)
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---|-----------|-----------------|----------|------|----------|------|--------------------|--------|
| Wall | Classroom | Plaster/Drywall | | 6 | 150 | SF | \$354 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 150 | SF | \$354 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 550 | SF | \$1,298 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 300 | SF | \$708 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 75 | SF | \$177 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 150 | SF | \$354 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 360 | SF | \$849 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 125 | SF | \$295 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 275 | SF | \$649 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 300 | SF | \$708 | |
| Wall | Classroom | Plaster/Drywall | | 5 | 300 | SF | \$1,416 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 150 | SF | \$354 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 150 | SF | \$354 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 300 | SF | \$708 | |
| Wall | Classroom | Plaster/Drywall | | 5 | 2,420 | SF | \$11,420 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 150 | SF | \$354 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 198 | SF | \$467 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 250 | SF | \$590 | |
| Wall | Classroom | Plaster/Drywall | | 5 | 2,152 | SF | \$10,155 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 460 | SF | \$1,085 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 1,060 | SF | \$2,501 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 550 | SF | \$1,298 | |
| Wall | Classroom | Plaster/Drywall | | 4 | 700 | SF | \$6,607 | |
| Wall | Classroom | Wall | | 7 | 188 | SF | \$0 | |
| ROOM Sub Total | | | | | | | \$942,469 | |
| Building Addition(1959/1974) Sub Total | | | | | | | \$7,057,722 | |

Building: SITE
Category: SITE

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|-----------|----------------------|----------------|------|----------|------|------|--------|
| Athletic | | Baseball - Natural | Site - East | 7 | 78,600 | SF | \$0 | |
| Athletic | | Basketball - Asphalt | Site - East | 7 | 6,400 | SF | \$0 | |
| Athletic | | Metal Bleachers | Baseball field | 7 | 90 | LF | \$0 | |
| Athletic | | Tennis - Asphalt | Site 2 South | 7 | 13,600 | SF | \$0 | |
| Civil/Drainage | | Catch Basin | Entire Site | 7 | 15 | EA | \$0 | |

Building: SITE
Category: SITE

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-----------|---|--|------|----------|------|------------------|--|
| Civil/Drainage | | Catch Basin | Courtyard | 5 | 1 | EA | \$1,216 | |
| Civil/Drainage | | Site Drain | Entire Site | 7 | 2 | EA | \$0 | |
| Civil/Drainage | | Site Drain | Courtyard | 5 | 2 | EA | \$2,002 | slow drainage- possible pipe collapse reported |
| Civil/Drainage | | Site Manhole | Entire Site | 7 | 20 | EA | \$0 | |
| Fencing | | Chain Link | Driver's Building, Baseball, and West Site | 4 | 510 | LF | \$54,698 | leaning and missing fence |
| Fencing | | Chain Link | Entire Site | 7 | 1,475 | LF | \$0 | |
| Fencing | | Ornamental Iron | Entire Site | 7 | 985 | LF | \$0 | |
| Landscape | | Asphalt Play Area/Hardscape | Entire Site | 7 | 68 | SF | \$0 | |
| Landscape | | Benches | Site ζ North | 7 | 6 | EA | \$0 | |
| Landscape | | Grass | Entire Site | 7 | 376,000 | SF | \$0 | |
| Landscape | | Hardscape - Concrete | North Entrances | 4 | 500 | SF | \$9,438 | cracks |
| Landscape | | Hardscape - Concrete | Entire Site | 7 | 55,000 | SF | \$0 | |
| Landscape | | Planting Beds/ Areas | Entire Site | 7 | 16,800 | SF | \$0 | |
| Landscape | | Retaining Wall - Concrete | Garage | 6 | 1,400 | SF | \$33,033 | cracks |
| Landscape | | Retaining Wall - Concrete | Entire Site | 7 | 1,460 | SF | \$0 | |
| Landscape | | Retaining Wall - Concrete | East Parking Lot | 5 | 20 | SF | \$1,557 | |
| Landscape | | Retaining Wall - Masonry | West Entrances | 5 | 96 | SF | \$4,485 | displaced masonry |
| Landscape | | Trash Receptacles | Entire Site | 7 | 8 | EA | \$0 | |
| Parking Lot | | Asphalt | Entire Site | 6 | 64,500 | SF | \$55,341 | cracks |
| Parking Lot | | Concrete | Entire Site | 6 | 11,600 | SF | \$0 | cracks |
| Parking Lot | | Concrete Curbs | Entire Site | 7 | 923 | LF | \$0 | snow covered |
| Parking Lot | | Lights, Pole Mounted | Parking Lot | 6 | 20 | EA | \$22,880 | |
| Parking Lot | | Parking lot interior plantings | Site - East | 7 | 4 | LF | \$0 | |
| Parking Lot | | Trash Compactor | Site ζ North | 7 | 1 | EA | \$0 | |
| Parking Lot | | Trash Enclosure | Site ζ North | 7 | 900 | SF | \$0 | |
| Parking Lot | | Vehicular Screening | North Parking | 7 | 2,800 | LF | \$0 | |
| Service Garage | | Garage - Underground | Site ζ North | 7 | 1 | SF | \$0 | |
| Sidewalks | | Perimeter Sidewalks | Entire Site | 7 | 30,380 | SF | \$0 | |
| Signage | | Flag Pole | Site ζ North | 7 | 3 | EA | \$0 | |
| Signage | | Flag Pole | North and West | 6 | 2 | EA | \$0 | |
| Signage | | Marquee - Free Standing Back Lighted w/ LED | Site ζ South | 7 | 1 | EA | \$0 | |
| Signage | | Monument Sign | Site ζ North | 5 | 1 | EA | \$28,600 | corrosion |
| SITE Sub Total | | | | | | | \$213,249 | |

Building: SITE

Category: SITE

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---|-----------|------|----------|------|----------|------|---------------------|--------|
| SITE Sub Total | | | | | | | \$213,249 | |
| Total Campus Need ^{2 3} | | | | | | | \$22,267,498 | |

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-----------------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-----------|---------------|----------|
| Building: Main | | | | | | | | | | | | | | |
| 101 | 1112 | 1 | 1 | 10 | 40 | 180 | | | N | N | N | Classroom | | |
| 105 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 106 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 107 | 1470 | 36 | 36 | 160 | 40 | 240 | | | N | N | N | Classroom | | |
| 108 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 110 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 113 | 1470 | 36 | 36 | 160 | 40 | 240 | | | N | N | N | Classroom | | |
| 114 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 116 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 117 | 412 | 1 | 2 | 12 | 40 | 60 | | | N | N | N | Classroom | | |
| 121 | 1830 | 1 | 1 | 16 | 40 | 300 | | | N | N | N | Classroom | | |
| 134 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 136 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 138 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 139 | 1750 | | 62 | 244 | 40 | 300 | | | N | N | N | Classroom | | |
| 140 | 1080 | 1 | 2 | 10 | 40 | 240 | | | N | N | Y | Classroom | | |
| 142 | 1080 | 1 | 2 | 10 | 40 | 240 | | | N | N | Y | Classroom | | |
| 203 | 1150 | 2 | 2 | 12 | 40 | 180 | | | N | N | Y | Classroom | | |
| 205 | 778 | 1 | 2 | 10 | 40 | 240 | | | N | N | N | Classroom | | |
| 206 | 946 | 1 | 2 | 10 | 40 | 180 | | | N | N | N | Classroom | | |
| 207 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 209 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 210 | 912 | 1 | 2 | 10 | 40 | 180 | | | N | N | N | Classroom | | |
| 211 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 212 | 864 | 1 | 2 | 10 | 40 | 140 | | | N | N | N | Classroom | | |
| 213 | 1090 | | 30 | 52 | 40 | 180 | | | N | N | N | Classroom | | |
| 214 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 216 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 217 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | N | N | Classroom | | |
| 219 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 221 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 232 | 638 | | 2 | 24 | 40 | 120 | | | N | N | Y | Classroom | | |
| 234 | 674 | | 2 | 24 | 40 | 120 | | | N | N | Y | Classroom | | |
| 236 | 1036 | 1 | 2 | 28 | 40 | 180 | | | N | N | Y | Classroom | | |
| 237 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 238 | 728 | | 2 | 24 | 40 | 120 | | | N | N | Y | Classroom | | |

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|-----------------------------|
| 239 | 1396 | 1 | 33 | 114 | 40 | 240 | | | N | N | N | Classroom | | |
| 240 | 728 | | 2 | 24 | 40 | 120 | | | N | N | Y | Classroom | | |
| 242 | 364 | 1 | 2 | 8 | 40 | 60 | | | N | N | N | Classroom | | |
| 300 | 584 | 1 | 3 | 8 | 40 | 60 | | | N | N | Y | Classroom | | |
| 301 | 386 | 2 | 3 | 14 | | 40 | | | N | N | Y | Classroom | | |
| 302 | 927 | 1 | 2 | 20 | 40 | 120 | | | N | N | Y | Classroom | | |
| 303 | 965 | 1 | 3 | 18 | | 180 | | 40 | N | N | Y | Classroom | | |
| 304 | 2848 | 1 | 1 | 8 | 40 | | | | N | N | Y | Classroom | | |
| 304A | 476 | 1 | 26 | 62 | 40 | 60 | | | N | N | Y | Classroom | | |
| 305 | 965 | 1 | 3 | 18 | | 180 | | 40 | N | N | Y | Classroom | | |
| 306 | 2284 | 1 | 40 | 80 | 40 | 200 | | | N | N | Y | Classroom | | |
| 307 | 750 | 1 | 3 | 8 | 40 | 240 | | | N | N | N | Classroom | | |
| 308 | 1286 | 1 | 2 | 12 | 40 | 220 | | | N | Y | Y | Classroom | | |
| 310 | 1286 | 1 | 2 | 34 | 40 | 220 | | | N | Y | Y | Classroom | | |
| 311 | 965 | 1 | 3 | 36 | 40 | 180 | | | N | N | Y | Classroom | | |
| 312 | 965 | 1 | 3 | 78 | 40 | 180 | | | N | N | Y | Classroom | | |
| 313 | 965 | 1 | 3 | 36 | 40 | 180 | | | N | N | Y | Classroom | | |
| 316 | 965 | 1 | 3 | 78 | 40 | 180 | | | N | N | Y | Classroom | | |
| 317 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 319 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 321 | 748 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 324 | 638 | 1 | 2 | 10 | 40 | 180 | | | N | Y | Y | Classroom | | |
| 332 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 334 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 336 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 337 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 338 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 339 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 340 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 341 | 688 | 1 | 2 | 10 | 40 | 120 | | | N | Y | N | Classroom | | |
| 342 | 706 | 42 | 84 | 168 | 40 | 240 | | | N | N | N | Classroom | | |
| 399 | 678 | 1 | 3 | 14 | 40 | | | | N | N | Y | Classroom | | |
| Other | | | | | | | | | N | N | N | Corridors | | SE Stairs |
| Other | 265 | | | 6 | | | | | N | N | N | Administrative Suites/Offices | | prep rm/office btwn 313-311 |
| Other | 288 | | | | | | | | N | N | N | Restroom | Staff Restroom | 2nd Floor Mens Staff |
| Other | | | | | | | | | N | N | N | Corridors | | Gym Stairs |
| Other | 96 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Men's Auditorium Restroom |

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|--|
| Other | 12843 | | | | | | | | N | N | N | Corridors | | 1st Floor |
| Other | 1760 | | | | | | | | N | N | N | Gymnasia | Standard Dedicated Gymnasium | 2nd Floor Weight Room |
| Other | 288 | | | | | | | | N | N | N | Restroom | Staff Restroom | 3rd Floor Mens Staff |
| Other | 68 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Women's Auditorium Restroom |
| Other | 217 | | | | | | | | N | N | N | Corridors | | to 300, 302, 399 |
| Other | 100 | | | | | | | | N | N | N | Corridors | | 1st vestibule to courtyard |
| Other | 170 | | | 8 | | | | | N | N | N | Administrative Suites/Offices | | 300A |
| Other | 1342 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | girls rm 122 |
| Other | 464 | | | | | | | | N | N | N | Restroom | Staff Restroom | 3rd fl staff FP girls west |
| Other | 254 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | RM 304B |
| Other | 1314 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | girls locker rm 118 |
| Other | | | | | | | | | N | N | N | Corridors | | Center Stairs |
| Other | 188 | | | 4 | | | | | N | N | Y | Administrative Suites/Offices | | 101A |
| Other | 728 | | | | | | | | N | N | N | Gymnasia | Standard Dedicated Gymnasium | 2nd Floor Weight Room |
| Other | 8123 | | | | | | | | N | N | N | Auditorium & Theater | Auditorium - Dedicated | 1st Floor |
| Other | 183 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | in girls locker rm 122 |
| Other | | | | | | | | | N | N | N | Corridors | | NE Stairs |
| Other | | | | | | | | | N | N | N | Corridors | | NW Stairs |
| Other | | | | | | | | | N | N | N | Corridors | | SW Stairs |
| Other | 295 | | | | | | | | N | N | N | Restroom | Staff Restroom | 3rd Floor womens Staff east |
| Other | 172 | | | 4 | | | | | N | N | N | Administrative Suites/Offices | | 128 |
| Other | 251 | | | 6 | | | | | N | N | N | Administrative Suites/Offices | | in between 312-316 |
| Other | 1430 | | | | | | | | N | N | N | Lunch & Multipurpose Room | Multipurpose Room | rm 320 |
| Other | 86 | | | | | | | | N | N | N | Corridors | | Vestibule from Gym to Hallway 2 |
| Other | 310 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | rm 300 |
| Other | 86 | | | | | | | | N | N | N | Corridors | | Vestibule from Gym to Hallway 1 |
| Other | 46 | | | | | | | | N | N | N | Restroom | Staff Restroom | in office 300 |
| Other | | | | | | | | | N | N | N | Corridors | | Basement Boys Locker Stairs to Hallway |
| Other | 128 | | | 8 | | | | | N | N | N | Administrative Suites/Offices | | 112B Conference Room |
| Other | 4052 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Basement Boys Locker Room |
| Other | 64 | | | | | | | | N | N | N | Corridors | | Gym Vestibule 2 |
| Other | 345 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | rm 109- FP Library |
| Other | 60 | | | | | | | | N | N | N | Restroom | Staff Restroom | in office 220 |
| Other | 606 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | rm 220 between gyms |
| Other | | | | | | | | | N | N | N | Corridors | | Basement Wrestling Room Stair |
| Other | 1896 | | | | | | | | N | N | N | Gymnasia | Standard Dedicated Gymnasium | Basement Wrestling Room |
| Other | 78 | | | 2 | | | | | N | N | N | Administrative Suites/Offices | | Pool Office |

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|---|
| Other | 64 | | | | | | | | N | N | N | Corridors | | Gym Vestibule |
| Other | 8200 | | | | | | | | N | N | N | Gymnasia | Standard Dedicated Gymnasium | 126 |
| Other | 130 | | | 4 | | | | | N | N | Y | Administrative Suites/Offices | | Weight Room Office 228C |
| Other | | | | | | | | | N | N | N | Corridors | | Boys Locker Stair to Gym |
| Other | 140 | | | 4 | | | | | N | N | N | Administrative Suites/Offices | | In Roo 206 |
| Other | 130 | | | 4 | | | | | N | N | Y | Administrative Suites/Offices | | Weight Room Office 228B |
| Other | 514 | | | 20 | | | | | N | N | N | Administrative Suites/Offices | | 112 |
| Other | 130 | | | 4 | | | | | N | N | Y | Administrative Suites/Offices | | Weight Room Office 228D |
| Other | 336 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 2nd Floor Nurse's Office |
| Other | 46 | | | | | | | | N | N | N | Restroom | Staff Restroom | In Nurse's Office |
| Other | 12312 | | | | | | | | N | N | N | Corridors | | 2nd Floor |
| Other | 225 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | 2nd Floor |
| Other | 22 | | | | | | | | N | N | N | Restroom | Staff Restroom | mens- first fl service corridor |
| Other | 140 | | | 4 | | | | | N | N | N | Administrative Suites/Offices | | 208 |
| Other | 130 | | | 4 | | | | | N | N | Y | Administrative Suites/Offices | | Weight Room Office 228A |
| Other | 19 | | | | | | | | N | N | N | Restroom | Staff Restroom | Gym Office 128 |
| Other | 2682 | | | | | | | | N | N | N | Gymnasia | Standard Dedicated Gymnasium | 220 |
| Other | 4565 | | | | | | | | N | N | N | Gymnasia | Standard Dedicated Gymnasium | 218 |
| Other | 305 | | | | | | | | N | N | N | Corridors | | 1st fl service corridor |
| Other | 28 | | | | | | | | N | N | N | Restroom | Staff Restroom | In Office 112 |
| Other | 241 | | | | | | | | N | N | N | Corridors | | 2nd fl service corridor |
| Other | 19 | | | | | | | | N | N | N | Restroom | Staff Restroom | Gym Office 128 Shower |
| Other | 275 | | | 6 | | | | | N | N | N | Administrative Suites/Offices | | Gym Office 275 |
| Other | 11382 | | | | | | | | N | N | N | Corridors | | 3rd Floor |
| Other | 341 | | | | | | | | N | N | N | Corridors | | 3rd fl service corridor and stairs to roof and down to lower floors |
| Other | 180 | | | 4 | | | | | N | N | N | Administrative Suites/Offices | | 112A Conference Room |

Building: Addition(1959/1974)

| | | | | | | | | | | | | | | |
|-----|-----|---|---|----|----|-----|--|--|---|---|---|-----------|--|--|
| 145 | 750 | 1 | 2 | 12 | 40 | 324 | | | N | N | Y | Classroom | | |
| 149 | 900 | 1 | 2 | 46 | 40 | 178 | | | N | N | Y | Classroom | | |
| 150 | 330 | 1 | 1 | 8 | 40 | | | | N | N | Y | Classroom | | |
| 151 | 484 | 1 | 4 | 12 | 40 | | | | N | N | Y | Classroom | | |
| 152 | 638 | 1 | 2 | 8 | 40 | | | | N | N | Y | Classroom | | |
| 153 | 900 | 1 | 2 | 8 | 40 | 178 | | | N | N | Y | Classroom | | |
| 154 | 900 | 1 | 2 | 8 | 40 | 356 | | | N | N | Y | Classroom | | |
| 156 | 900 | 2 | 7 | 16 | 40 | 96 | | | N | N | Y | Classroom | | |
| 159 | 900 | 1 | 2 | 10 | 40 | 178 | | | N | N | Y | Classroom | | |

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|-------------------------|
| 160 | 900 | 1 | 2 | 10 | 40 | 356 | | | N | N | Y | Classroom | | |
| 161 | 900 | 1 | 2 | 42 | 40 | 178 | | | N | N | Y | Classroom | | |
| 172 | 790 | 1 | 9 | 44 | 40 | 242 | | | N | N | N | Classroom | | |
| 173 | 1377 | 1 | 3 | 12 | 40 | 113 | | | N | N | N | Classroom | | |
| 174 | 2157 | 1 | 1 | 17 | 40 | 566 | | | N | N | Y | Classroom | | |
| 175 | 600 | | 1 | 16 | 40 | 146 | | | N | N | N | Classroom | | |
| 176 | 600 | | | 18 | 40 | 324 | | | N | N | N | Classroom | | |
| 180A | 1853 | | | 8 | | 1138 | | | N | N | Y | Classroom | | |
| 181 | 4800 | 2 | 6 | 32 | 40 | 9 | | | N | N | N | Classroom | | |
| 184 | 600 | 1 | 6 | 12 | 40 | | | | N | N | N | Classroom | | |
| 185 | 435 | | | 44 | 40 | | | | N | N | N | Classroom | | |
| 187 | 3775 | 1 | 2 | 24 | 40 | | | | N | N | Y | Classroom | | |
| 245 | 750 | 1 | 2 | 12 | 40 | 324 | | | N | N | Y | Classroom | | |
| 247 | 1298 | 1 | 35 | 92 | 40 | 82 | | | N | N | Y | Classroom | | |
| 249 | 900 | 1 | 10 | 20 | 40 | 356 | | | N | N | Y | Classroom | | |
| 250 | 960 | 1 | 30 | 70 | 40 | | | | N | N | Y | Classroom | | |
| 251 | 800 | 1 | 33 | 68 | 40 | | | | N | N | Y | Classroom | | |
| 252 | 1087 | 1 | 35 | 78 | 40 | 267 | | | N | N | Y | Classroom | | |
| 254 | 1201 | 1 | 36 | 76 | 40 | 445 | | | N | N | Y | Classroom | | |
| 255 | 900 | 4 | 7 | 26 | 40 | 178 | | | N | N | Y | Classroom | | |
| 257 | 900 | 1 | 3 | 12 | 40 | 356 | | | N | N | Y | Classroom | | |
| 258 | 900 | 1 | 3 | 16 | 40 | 178 | | | N | N | Y | Classroom | | |
| 259 | 900 | 1 | 3 | 70 | 40 | 356 | | | N | N | Y | Classroom | | |
| 260 | 900 | 1 | 2 | 42 | 40 | 178 | | | N | N | Y | Classroom | | |
| 261 | 900 | 1 | 3 | 14 | 40 | 356 | | | N | Y | Y | Classroom | | |
| 262 | 900 | 1 | 3 | 12 | 40 | 178 | | | N | N | Y | Classroom | | |
| 263 | 368 | 2 | 2 | 10 | 40 | | | | N | N | Y | Classroom | | |
| Other | 255 | | | 14 | | | | | N | N | Y | Administrative Suites/Offices | | 253 |
| Other | 225 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | 166A |
| Other | 390 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | 168 |
| Other | 20 | | | | | | | | N | N | N | Restroom | Staff Restroom | In Conference Room 166B |
| Other | 180 | | | | | | | | N | N | N | Restroom | Staff Restroom | Womens 1st flr SE |
| Other | 360 | | | 30 | | | | | N | N | N | Administrative Suites/Offices | | 270B & C |
| Other | 100 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 166C |
| Other | 180 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Mens 1st flr SW |
| Other | 180 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Womens 1st flr SW |
| Other | 180 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Mens 1st flr NW |

| Room Summary | | | | | | | | | | | | | | |
|--------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|--|
| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
| Other | 180 | | | | | | | | N | N | N | Restroom | Staff Restroom | Womens 1st flr NW |
| Other | 180 | | | | | | | | N | N | N | Restroom | Staff Restroom | Womens 1st flr NE |
| Other | 180 | | | | | | | | N | N | N | Restroom | Staff Restroom | Mens 1st flr NE |
| Other | 1800 | | | | | | | | N | N | N | Lunch & Multipurpose Room | Multipurpose Room | Forum rm 162 |
| Other | 300 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | rm 164 |
| Other | 450 | | | 12 | | | | | N | N | Y | Administrative Suites/Offices | | rm 158 |
| Other | 400 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | 171 |
| Other | 300 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | rm 163 |
| Other | 195 | | | 4 | | | | | N | N | Y | Administrative Suites/Offices | | rm 163a |
| Other | 6370 | | | | | | | | N | N | N | Library | | 180 |
| Other | 131 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 180F |
| Other | 150 | | | 4 | | | | | N | N | N | Administrative Suites/Offices | | 180D |
| Other | 150 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 180E |
| Other | 948 | | | | | | | | N | N | N | Administrative Suites/Offices | | Student Lounge |
| Other | 575 | | | 36 | | | | | N | N | N | Administrative Suites/Offices | | 180H |
| Other | 300 | | | 4 | | | | | N | N | N | Administrative Suites/Offices | | 180G |
| Other | 165 | | | | | | | | N | N | N | Administrative Suites/Offices | | 185A |
| Other | 375 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | rm 157 |
| Other | 300 | | | 2 | | | | | N | N | N | Administrative Suites/Offices | | 270A Counselors Waiting Area |
| Other | 880 | | | 26 | | | | | N | N | Y | Administrative Suites/Offices | | 270 Main Counselors Office |
| Other | 200 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | 270L |
| Other | 140 | | | | | | | | N | N | N | Restroom | Staff Restroom | Mens 2nd Flr NE in Faculty Dining |
| Other | 180 | | | | | | | | N | N | N | Restroom | Staff Restroom | Mens 2nd Flr NW |
| Other | 180 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Mens 2nd Flr SE |
| Other | 140 | | | | | | | | N | N | N | Restroom | Staff Restroom | Womens 2nd Flr NE in Faculty Dining |
| Other | 180 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Womens 2nd flr NW in Student Dining Room |
| Other | 180 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Womens 2nd Flr SE |
| Other | 428 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | 264 Attendance Office |
| Other | 180 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Womens 2nd Flr SW |
| Other | 575 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | Box Office in Student Dining |
| Other | 300 | | | 24 | | | | | N | N | Y | Administrative Suites/Offices | | 270G, H, J |
| Other | 300 | | | 24 | | | | | N | N | Y | Administrative Suites/Offices | | 270D,E,F,G,H,J |
| Other | 15330 | | | | | | | | N | N | N | Lunch & Multipurpose Room | Lunchroom | 2nd Floor |
| Other | 5300 | | | | | | | | N | N | N | Corridors | | 2nd Floor |
| Other | 14147 | | | | | | | | N | N | N | Corridors | | 1st Floor |

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|---|
| Other | 730 | | | | | | | | N | N | N | Corridors | | Connecting Corridor 1st and 2nd Floor |
| Other | | | | | | | | | N | N | N | Corridors | | Entire Building Stairs, Entrance 2,3,5 & 12 |
| Other | 180 | | | | | | | | N | N | N | Restroom | Staff Restroom | Mens 1st flr SE |
| Other | 180 | | | | | | | | N | N | N | Restroom | Adult Standard Student Restroom | Mens 2nd Flr SW |
| Other | 3060 | | | | | | | | N | N | N | Kitchen | Cooking Kitchen | 2nd Floor |
| Other | 220 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | 166B |
| Other | 375 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | rm 155 |
| Other | 100 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 166D |
| Other | 485 | | | 46 | | | | | N | N | N | Administrative Suites/Offices | | 256 |
| Other | 240 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 166R Break Room |
| Other | 174 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 256A |
| Other | 174 | | | 16 | | | | | N | N | Y | Administrative Suites/Offices | | 256B |
| Other | 890 | | | | | | | | N | N | N | Kitchen | Warming Kitchen | Servery 1 in Lunchroom on 2nd Floor |
| Other | 1500 | | | 70 | | | | | N | N | N | Administrative Suites/Offices | | 271A & B Faculty Lounge |
| Other | 205 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | 256C |
| Other | 1755 | | | 34 | | | | | N | N | Y | Administrative Suites/Offices | | 166 |
| Other | 132 | | | | | | | | N | N | N | Restroom | Staff Restroom | Women's Staff Restroom in Kitchen |
| Other | 460 | | | | | | | | N | N | N | Kitchen | Warming Kitchen | Servery 2 in Lunchroom on 2nd Floor |
| Other | 108 | | | 8 | | | | | N | N | N | Administrative Suites/Offices | | Kitchen Office |
| Other | 2165 | | | 14 | | | | | N | N | N | Administrative Suites/Offices | | 271 Faculty Dining |
| Other | 100 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 272 Office in Faculty Dining |
| Other | 100 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 273 Office in Faculty Dining |
| Other | 100 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 274 Office in Faculty Dining |
| Other | 100 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 275 Office in Faculty Dining |
| Other | 104 | | | | | | | | N | N | N | Restroom | Staff Restroom | Staff Restroom in Kitchen |
| Work Room | 1208 | 1 | 28 | 68 | 40 | | | | N | N | Y | Classroom | | |