Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

Rank 7: The item/system is new or in good condition and no work is required.

- Rank 6: The item/system requires general cleaning and/or routine maintenance.
- Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.1

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Canopy		Concrete/ Stucco Canopy	S and E facade	7	660	SF	\$0
Chimney		Metal Flue	main roof- SE corner	7	8	LF	\$0
Doors		Exterior Steel Door	N, E, S facades	7	4	EA	\$0
Doors		Overhead Rolling / Garage Door	N and S facades	7	3	EA	\$0
Doors		Side Lite	doors 16 - 18	7	5	EA	\$0
Doors		Store Front Door	doors 15 - 18	7	8	EA	\$0
Doors		Transom Lite	doors 16- 18, E service door	7	6	EA	\$0
Entrance		Concrete Exterior Stairs	door 18	7	36	LF	\$0
Entrance		Entrance Controls - Audio and Video	door 15	7	1	EA	\$0
Entrance		Power Door Operator and Controls	door 15	7	1	EA	\$0
Entrance		Stair Handrails	door 18	7	12	LF	\$0
Foundation		Concrete Foundation	Entire Building	7	823	LF	\$0
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	19	EA	\$4,076
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	16	EA	\$0

Building: Building A/B Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lintels		Lintels - Steel	Entire Building	7	529	LF	\$0	
Parapet		Coping - Metal	Entire Building	7	2,052	LF	\$0	
Parapet		Parapet > 30" Height	auditorium roof	7	242	LF	\$0	
Parapet		Parapet 16" to 30" Height	low roof at NE and auditorium roof	7	381	LF	\$0	
Roof System		EPDM/ Synthetic Rubber Roof	Roof	7	42,100	SF	\$0	8090 SF is green roof
Roof System		Interior Downspouts	Entire Building	7	786	LF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Top	ping Roof	7	42,100	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	58,600	SF	\$0	
Walls		Brick	Entire Building	7	34,200	SF	\$0	
Walls		Precast Panel Wall	Entire Building	7	3,150	SF	\$0	
Walls		Prefabricated Metal Panel Wall	bridge	7	4,190	SF	\$0	
Windows		Curtain wall - Glazed Double Pane	Entire Building	7	8,980	SF	\$0	
Windows		Curtain wall - Insulated panel	Entire Building	7	303	SF	\$0	
Windows		Curtain wall - Windows	Entire Building	7	322	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	South Façade	7	130	SF	\$0	
			EVTEDI		kol		\$4.076	

EXTERIOR Sub Total

\$4,076

Building: Building A/B Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reas	son
Emergency System		Automatic Transfer switch	Entire Building	7	1	EA	\$0	
Emergency System		Emergency A/C power - Auditorium and aisle lighting	1st Floor	7	8,720	SF	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	15,343	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	1,124	SF	\$0	
Emergency System		Emergency generator 200 -250 KW natural gas - Indoor	Generator room	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	9	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	19	EA	\$0	
Emergency System		Independent Electrical Service for emergency power	1st Floor	7	1	EA	\$0	
Emergency System		Security System - Intrusion detection	1st Floor	7	58,600	SF	\$0	
Main Service		Main Electrical service 1600 A 277/480/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	7	18	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	2	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	1	EA	\$0	

Building: Building A/B Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank G	Quantity	Unit	Cost Reason
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	3	EA	\$0
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	2	EA	\$0
					1		¢0

ELECTRICAL Sub Total

\$0

Building: Building A/B Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost F	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	58,600	SF	\$0	
Fire Alarm		Fire Alarm System	Electrical Room	7	58,600	SF	\$0	
Fire Alarm		Fire Pump Controller	PUMP ROOM	7	1	EA	\$0	
Pump Room Assembly		Fire Pump 50-75hp	PUMP ROOM	7	1	EA	\$0	
Pump Room Assembly		Jockey Pump	PUMP ROOM	7	1	EA	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	7	58,600	SF	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	7	58,600	SF	\$0	
					al		¢0	

FIRE PROTECTION Sub Total

\$0

Building: Building A/B Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Air Conditioning		Condensing Unit - Roof Mounted 11 to 20 tons	Roof	7	2	EA	\$0
Air Conditioning		Condensing Unit - Roof Mounted 5 to 10 tons	Roof	7	1	EA	\$0
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm	Mechanical Room	7	1	EA	\$0
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 12,001 to 20,000 cfm	Mechanical Room	7	1	EA	\$0
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	Mechanical Room	7	1	EA	\$0
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	2ND FLOOR MECHANICAL ROOM, SOUTH EXTERIOR WALL	7	1	EA	\$0
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	2ND FLOOR MECHANICAL ROOM, EAST EXTERIOR WALL	7	1	EA	\$0
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	2ND FLOOR MECHANICAL ROOM, EAST EXTERIOR WALL	7	1	EA	\$0
Air Handling Systems		Fan Coil Unit - Hot Water and Chilled Water	Entire Building	7	12	EA	\$0

Building: Building A/B Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Air Handling Systems		Return Fans - Indoor greater than 20,000 CFM	Mechanical Room	7	1	EA	\$O
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	Entire Building	7	22	EA	\$O
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	7	6	EA	\$O
Heating Devices		Fin Tube Hot Water	Entire Building	7	174	LF	\$0
Heating Devices		Fin Tube Hot Water	Entire Building	7	174	LF	\$O
Heating Devices		Unit Heater - Electric	1st Floor	7	1	EA	\$O
Heating Devices		Unit Heater - Hot Water	Entire Building	7	9	EA	\$ 0
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	37	EA	\$O
Ventilation		Exhaust Fan - Indoor	Electrical Room	7	1	EA	\$0
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	7	EA	\$O
			MECHANIC	CAL Sub To	tal		\$0
Building: Building Category: PLUMBI							
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Hot Water		Hot Water Heater - Electric less than 50 KW	PUMP ROOM	7	2	EA	\$0
Piping		Domestic Piping - Cold Water from Risers to	Entire Building	7	58,600	SF	\$0
		Fixtures					
Piping		Fixtures Domestic Piping - Cold Water Risers	Entire Building	7	58,600	SF	\$0

T IXtures		
Domestic Piping - Cold Water Risers	Entire Building	7
Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7
Domestic Piping - Hot Water Return Risers	Entire Building	7
Domestic Piping - Hot Water Risers	Entire Building	7
Domestic Piping Cold Water Horizontal lines	Entire Building	7
Domestic Piping Hot Water Horizontal lines	Entire Building	7
Domestic Piping Hot Water Return Lines	Entire Building	7
Sanitary Piping	Entire Building	7
Storm Piping	Entire Building	7

Domestic Booster Pump duplex

Vent Piping

PLUMBING Sub Total

7

7

\$0

SF

SF

SF

SF

SF

SF

SF

SF

\$0

\$0

\$0

\$0

\$0

\$0

\$0

\$0

\$0

58,600

58,600

58,600

58,600

58,600

58,600

58,600

58,600

1 ΕA

Building: Building A/B Category: INTERIOR

Piping

Piping

Piping

Piping Piping

Piping

Piping

Piping

Pumps

Group	Sub Group	Item	Location	Rank Qu	antity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 0115- office	7	586	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Ticket Office 0146	7	149	SF	\$0	

Entire Building

PUMP ROOM

Benito Juarez Community Academy High School

2150 S Laflin St Chicago, IL 60608

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Control and Sound Rooms	7	606	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 2213	7	110	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	rm 2213	7	110	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Control and Sound Rooms	7	606	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	rm 0115- office	7	586	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Ticket Office 0146	7	149	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Ticket Office 0146	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 0115- office	7	7	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 2213	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Control and Sound Rooms	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Control and Sound Rooms	7	12	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Control and Sound Rooms	7	1,185	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Ticket Office 0146	7	275	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 2213	7	400	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 0115- office	7	724	SF	\$0
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor			EA	\$O
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	7	517	EA	\$O
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor	7	1	EA	\$O
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	7	11	EA	\$0
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	7	1	EA	\$O
Doors		Interior Steel Doors incl hw	Entire Building	6	8	EA	\$2,265
Doors		Interior Steel Doors incl hw	Entire Building	7	53	EA	\$0
Doors		Interior Steel Doors incl hw	Stage Doors	6	2	EA	\$566
Doors		Interior Wood Doors incl hw	Entire Building	7	17	EA	\$0
Doors		Interior Wood Doors incl hw	Entire Building	6	22	EA	\$6,229
Doors		Side-lite	Entire Building	7	30	SF	\$0
Doors		Store Front Door	Entire Building	7	4	EA	\$0

Benito Juarez Community Academy High School

2150 S Laflin St Chicago, IL 60608

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Locker/Shower Room	Benches	Girls Dressing Room 1st fl			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl womens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl mens			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	Boys Dressing Room 1st fl			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd floor girls			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	1st floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl mens			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	Boys Dressing Room 1st fl	7	54	EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	Girls Dressing Room 1st fl	7	54	EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd floor girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	1st floor girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl womens			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	1st floor girls			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	Girls Dressing Room 1st fl			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	1st floor boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd floor boys			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	Boys Dressing Room 1st fl			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl womens			EA	\$0	
Lunchroom	Multipurpose Room	Ceiling - Exposed	Scene Shop Rm 1131	7	1,406	SF	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	Green Room 0126	7	516	SF	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	0114 Small Practice Room	7	114	SF	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	0116 Small Practice Room	7	114	SF	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	0112 Small Practice	7	114	SF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	0114 Small Practice Room	7	114	SF	\$0
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	0112 Small Practice	7	114	SF	\$0
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	Green Room 0126	7	516	SF	\$O
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	0116 Small Practice Room	7	114	SF	\$O
Lunchroom	Multipurpose Room	Lighting - Lay-In	Green Room 0126	7	5	SF	\$0
Lunchroom	Multipurpose Room	Lighting - Lay-In	0114 Small Practice Room	7	2	SF	\$0
Lunchroom	Multipurpose Room	Lighting - Lay-In	0116 Small Practice Room	7	2	SF	\$0
Lunchroom	Multipurpose Room	Lighting - Lay-In	0112 Small Practice	7	2	SF	\$0
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	Scene Shop Rm 1131	7	8	SF	\$0
Lunchroom	Multipurpose Room	Serving Line	0116 Small Practice Room			LF	\$0
Lunchroom	Multipurpose Room	Serving Line	0114 Small Practice Room			LF	\$0
Lunchroom	Multipurpose Room	Serving Line	0112 Small Practice			LF	\$0
Lunchroom	Multipurpose Room	Serving Line	Scene Shop Rm 1131			LF	\$0
Lunchroom	Multipurpose Room	Serving Line	Green Room 0126			LF	\$0
Lunchroom	Multipurpose Room	Wall - Concrete Block	Green Room 0126	7	1,080	SF	\$0
Lunchroom	Multipurpose Room	Wall - Concrete Block	Scene Shop Rm 1131	7	1,865	SF	\$0
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	0116 Small Practice Room	7	402	SF	\$0
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	0112 Small Practice	7	402	SF	\$0
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	0114 Small Practice Room	7	402	SF	\$0
MDF/IDF		Finishes	2nd Floor	7	216	SF	\$0
MDF/IDF		Ventilation and Cooling	2nd Floor	7	1	EA	\$0
Mechanical/Service Rooms		Mechanical/Service Rooms	Entire Building	7	5,313	SF	\$0
Mechanical/Service Rooms		Storage Room	Entire Building	7	3,200	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd floor girls	7	312	SF	\$0
Staff Restroom	Staff Restroom	Accessories	1st fl womens	7	100	SF	\$0
Staff Restroom	Staff Restroom	Accessories	1st fl mens	7	82	SF	\$0
Staff Restroom	Locker/Shower Room	Accessories	Boys Dressing Room 1st fl	7	577	SF	\$0
Staff Restroom	Locker/Shower Room	Accessories	Girls Dressing Room 1st fl	7	577	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Accessories	1st floor boys	7	312	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd floor boys	7	312	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Accessories	1st floor girls	7	312	SF	\$0
Staff Restroom	Locker/Shower Room	Ceiling - Lay-In	Boys Dressing Room 1st fl	7	530	SF	\$O
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl mens	7	82	SF	\$0
Staff Restroom	Locker/Shower Room	Ceiling - Lay-In	Girls Dressing Room 1st fl	7	530	SF	\$0

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl womens	7	100	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	7	312	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	7	312	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	7	250	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	7	250	SF	\$0	
Staff Restroom	Locker/Shower Room	Floor Drain	Girls Dressing Room 1st fl	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl womens	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Floor Drain	Boys Dressing Room 1st fl	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	1st floor girls	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	1st floor boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd floor boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd floor girls	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls	7	312	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st fl womens	7	100	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st fl mens	7	82	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	Boys Dressing Room 1st fl	7	54	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	Girls Dressing Room 1st fl	7	54	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys	7	250	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys	7	250	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls	7	312	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile/Sheet	Girls Dressing Room 1st fl	7	530	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile/Sheet	Boys Dressing Room 1st fl	7	530	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl womens			EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	Boys Dressing Room 1st fl			EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	Girls Dressing Room 1st fl			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd floor girls			EA	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	1st floor girls			EA	\$0
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	1st floor boys			EA	\$0
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd floor boys			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	1st fl mens			EA	\$0
Staff Restroom	Adult Standard Student Restroom	Lavatory	1st floor girls	7	5	EA	\$0
Staff Restroom	Adult Standard Student Restroom		2nd floor boys	7	4	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Lavatory	1st floor boys	7	4	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Lavatory	2nd floor girls	7	5	EA	\$0
Staff Restroom	Locker/Shower Room	Lavatory	Boys Dressing Room 1st fl	7	3	EA	\$O
Staff Restroom	Staff Restroom	Lavatory	1st fl mens	7	1	EA	\$O
Staff Restroom	Staff Restroom	Lavatory	1st fl womens	7	1	EA	\$O
Staff Restroom	Locker/Shower Room	Lavatory	Girls Dressing Room 1st fl	7	3	EA	\$0
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	Girls Dressing Room 1st fl	7	5	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Lighting - Lay-In	2nd floor boys	7	11	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Lighting - Lay-In	1st floor boys	7	11	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Lighting - Lay-In	2nd floor girls	7	14	SF	\$0
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	Boys Dressing Room 1st fl	7	5	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl mens	7	1	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl womens	7	1	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Lighting - Lay-In	1st floor girls	7	14	SF	\$0
Staff Restroom	Locker/Shower Room	Lighting - Wall Mounted	Boys Dressing Room 1st fl	7	20	EA	\$0
Staff Restroom	Locker/Shower Room	Lighting - Wall Mounted	Girls Dressing Room 1st fl	7	20	EA	\$0
Staff Restroom	Staff Restroom	Partitions	1st fl mens			EA	\$0
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd floor boys	7	2	EA	\$0
Staff Restroom	Staff Restroom	Partitions	1st fl womens			EA	\$0
Staff Restroom	Locker/Shower Room	Partitions	Boys Dressing Room 1st fl			EA	\$0
Staff Restroom	Locker/Shower Room	Partitions	Girls Dressing Room 1st fl			EA	\$0
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd floor girls	7	8	EA	\$0

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Partitions	1st floor girls	7	8	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	1st floor boys	7	2	EA	\$0	
Staff Restroom	Locker/Shower Room	Urinals	Boys Dressing Room 1st fl			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	1st floor boys	7	3	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	1st floor girls			EA	\$0	
Staff Restroom	Locker/Shower Room	Urinals	Girls Dressing Room 1st fl			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl womens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl mens			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st fl womens	7	280	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	Girls Dressing Room 1st fl	7	1,048	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	Boys Dressing Room 1st fl	7	1,048	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st fl mens	7	240	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Structural Glazed Tile	Girls Dressing Room 1st fl	7	80	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls	7	725	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl womens	7	120	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girls	7	725	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl mens	7	100	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Structural Glazed Tile	Boys Dressing Room 1st fl	7	80	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys	7	725	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys	7	725	SF	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	Girls Dressing Room 1st fl	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl womens	6	1	EA	\$372	
Staff Restroom	Locker/Shower Room	Water Closet	Boys Dressing Room 1st fl	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd floor girls	7	8	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl mens	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	1st floor girls	7	8	EA	\$0	

Building: Building A/B Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Adult Standard Student Restroom	Water Closet	1st floor boys	7	2	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd floor boys	7	2	EA	\$0
Theater	Auditorium - Dedicated	Ceiling - Exposed	1st Floor	7	8,720	SF	\$0
Theater	Auditorium - Dedicated	Flooring - Carpet	1st Floor	7	1,600	SF	\$0
Theater	Auditorium - Dedicated	Flooring - Concrete	1st Floor	6	7,120	SF	\$33,599
Theater	Auditorium - Dedicated	Lighting - Lay-In	1st Floor	7	4	SF	\$0
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	7	45	SF	\$0
Theater	Auditorium - Dedicated	Stage	1st Floor	7	4,502	SF	\$0
Theater	Auditorium - Dedicated	Wall - Concrete Block	1st Floor	7	13,378	SF	\$0
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0
Vertical Conveyance		Stage Lift	Auditorium	7	1	EA	\$O
							A / A A A A

INTERIOR Sub Total

\$43,032

Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Classroom	Casework				LF	\$0
Classroom	Casework				LF	\$0
Classroom	Casework		7	45	LF	\$0
Classroom	Casework		7	21	LF	\$0
Classroom	Casework				LF	\$0
Classroom	Casework				LF	\$0
Classroom	Casework		7	21	LF	\$0
Classroom	Casework		7	21	LF	\$O
Classroom	Casework		7	21	LF	\$O
Classroom	Casework		7	21	LF	\$O
Classroom	Casework		7	21	LF	\$O
Classroom	Lay-In/Drop		7	705	SF	\$O
Classroom	Lay-In/Drop		7	705	SF	\$0
Classroom	Lay-In/Drop		7	705	SF	\$0
Classroom	Lay-In/Drop		7	705	SF	\$O
Classroom	Lay-In/Drop		7	705	SF	\$O
Classroom	Lay-In/Drop		7	705	SF	\$O
Classroom	Lay-In/Drop		6	600	SF	\$1,287
Classroom	Lay-In/Drop		6	1,452	SF	\$3,115
Classroom	Lay-In/Drop		7	1,360	SF	\$0
	Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom Classroom	ClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassro	ClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/Drop	ClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomL	ClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomCaseworkClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/DropClassroomLay-In/Drop <td>Classroom Casework LF Classroom Casework LF Classroom Casework 7 45 LF Classroom Casework 7 21 LF Classroom Lay-In/Drop 7 705 SF Classroom Lay-In/Drop 7 705 SF <</td>	Classroom Casework LF Classroom Casework LF Classroom Casework 7 45 LF Classroom Casework 7 21 LF Classroom Lay-In/Drop 7 705 SF Classroom Lay-In/Drop 7 705 SF <

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Ceiling	Classroom	Lay-In/Drop		7	1,469	SF	\$O
Ceiling	Classroom	Lay-In/Drop		7	727	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	355	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	70	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	300	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	70	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	70	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	70	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	70	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	70	SF	\$0
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376
Chalk Board	Multipurpose Room	Chalk Board	0114 Small Practice Room	4		LF	
Chalk Board	Multipurpose Room	Chalk Board	0112 Small Practice	4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Multipurpose Room	Chalk Board	Green Room 0126	4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4	15	LF	\$1,823
Chalk Board	Multipurpose Room	Chalk Board	Scene Shop Rm 1131	4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Multipurpose Room	Chalk Board	0116 Small Practice Room	4		LF	
Corridors	Corridors	Carpet	Vestibule 0143	7	240	SF	\$O
Corridors	Corridors	Carpet	Auditorium Vestibules	7	312	SF	\$0
Corridors	Corridors	Carpet	Stair 0149	7	104	SF	\$0
Corridors	Corridors	Concrete Block	Vestibule 0221	7	405	SF	\$0
Corridors	Corridors	Concrete Block	2nd Floor	7	3,865	SF	\$0
Corridors	Corridors	Concrete Block	Catwalk Access 1	7	3,713	SF	\$0
Corridors	Corridors	Concrete Block	1st Floor	7	3,700	SF	\$0
Corridors	Corridors	Concrete Block	Catwalk Access 2	7	4,668	SF	\$0
Corridors	Corridors	Concrete Epoxy/Painted	Catwalk Access 2	7	507	SF	\$0
Corridors	Corridors	Concrete Epoxy/Painted	1st Floor	7	300	SF	\$0
Corridors	Corridors	Concrete Epoxy/Painted	Vestibule 0109	6	74	SF	\$349

CarridorsConridorsConcrete EpoxylPaintedCatwaik Access 17451F90CorridorsOrridorsDirking FourtainsStair 1EA\$0CorridorsCorridorsDirking FourtainsCatwaik Access 1EA\$0CorridorsOrridorsDirking FourtainsCatwaik Access 1EA\$0CorridorsDirking FourtainsCatwaik Access 2EA\$0CorridorsDirking FourtainsCatwaik Access 2EA\$0CorridorsOrridorsDirking FourtainsVestbule 013EA\$0CorridorsCorridorsDirking FourtainsVestbule 021EA\$0CorridorsDirking FourtainsVestbule 0101EA\$0CorridorsDirking FourtainsAudiorium Vestbule 011EA\$0CorridorsDirking FourtainsStair 14EA\$0CorridorsDirking FourtainsStair 14EA\$0CorridorsDirking FourtainsStair 14EA\$0CorridorsCorridorsDirking FourtainsStair 14EA\$0CorridorsCorridorsDirking FourtainsStair 14EA\$0CorridorsCorridorsDirking FourtainsStair 145\$0CorridorsCorridorsDirking FourtainsStair 147\$18\$0CorridorsCorridorsDirking FourtainsStair 147\$18\$1\$1CorridorsCorridorsDirking Fourtains </th <th>Group</th> <th>Sub Group</th> <th>Item</th> <th>Location</th> <th>Rank</th> <th>Quantity</th> <th>Unit</th> <th>Cost</th> <th>Reason</th>	Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
CarridorsCarridorsDinking FourtainsVestibue 0109EAS0CorridorsCarridorsDinking FourtainsCatwaik Access 1EAS0CorridorsOrnidorsDinking FourtainsCatwaik Access 2EAS0CorridorsDinking FourtainsCatwaik Access 2EAS0CorridorsDinking FourtainsCatwaik Access 2EAS0CorridorsDinking FourtainsVestibue 021EAS0CorridorsDinking FourtainsVestibue 021EAS0CorridorsDinking FourtainsVestibue 021EAS0CorridorsDinking FourtainsVestibue 021EAS0CorridorsDinking FourtainsVestibue 021EAS0CorridorsDinking FourtainsStai 124EAS0CorridorsDinking FourtainsStai 2EAS0CorridorsDinking FourtainsStai 2S0S0CorridorsDinking FourtainsStai 12FS0CorridorsDinking FourtainsStai 12FS0Corridor	Corridors	Corridors	Concrete Epoxy/Painted	Catwalk Access 1	7	451	SF	\$0	
CorridorsCorridorsCorridorsCorridorsCorridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsContridorsCo	Corridors	Corridors	Drinking Fountains	Stair 1			EA	\$0	
CorridorsCorridorsOrniking FountainsCatwalk 0119EA\$0CorridorsDinking FountainsCatwalk Access 2EA\$0CorridorsOrniking FountainsVatble 013EA\$0CorridorsDinking FountainsVestibule 013EA\$0CorridorsDinking FountainsVestibule 0101EA\$0CorridorsOrnidorsDinking FountainsVestibule 0101EA\$0CorridorsOrnidorsDinking FountainsAuditorium LobbyEA\$0CorridorsOrnidorsDinking FountainsAuditorium VestibulesEA\$0CorridorsOrnidorsDinking FountainsStai 2EA\$0CorridorsOrnidorsOrnidorsDinking FountainsStai 2EA\$0CorridorsOrnidorsOrnidorsOrnidorsOrnidorsStai 2\$0\$0CorridorsOrnidorsOrnidorsOrnidorsOrnidors\$0\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1\$1	Corridors	Corridors	Drinking Fountains	Vestibule 0109			EA	\$0	
CorridorsCorridorsCondidorsCondidorsCondidorsCondidorsDinking FountainsCavelbule 0143EAS0CorridorsCorridorsDinking FountainsVestbule 0143EAS0CorridorsOrridorsDinking FountainsVestbule 0101EAS0CorridorsDinking FountainsAuditorium VestbulesEAS0CorridorsOrridorsDinking FountainsAuditorium VestbulesEAS0CorridorsOrridorsDinking FountainsStair 0149EAS0CorridorsOrridorsDinking FountainsStair 0149EAS0CorridorsOrridorsDinking FountainsStair 0149EAS0CorridorsOrridorsDinking FountainsStair 0149Z.938SFS0CorridorsOrridorsDinking FountainsStair 014977.8SPS0CorridorsOrridorsDinking FountainsStair 014977.8SFS0CorridorsOrridorsDinking FountainsStair 014977.8SFS0CorridorsDinking FountainsStair 014977.8SFS0CorridorsDinking FountainsStair 014977.8SFS0CorridorsDinking FountainsStair 014973.81SFS0CorridorsDing Lay-InStair 273.61SFS0CorridorsDing Lay-InStair 273.61<	Corridors	Corridors	Drinking Fountains	Catwalk Access 1			EA	\$0	
CorridorsCorridorsDinking FountainsVestbule 0143EAS0CorridorsCorridorsDinking FountainsVestbule 021EAS0CorridorsCorridorsDinking FountainsVestbule 021EAS0CorridorsCorridorsDinking FountainsAudtorium LobbyEAS0CorridorsCorridorsDinking FountainsAudtorium VestbulesEAS0CorridorsCorridorsDinking FountainsStair 0149EAS0CorridorsCorridorsDinking FountainsStair 014972,938SFS0CorridorsCorridorsDropLay-InStair 014972,938SFS0CorridorsCorridorsDropLay-InStair 0149772,938SFS0CorridorsCorridorsDropLay-InStair 0149774,93SFS0CorridorsCorridorsDropLay-InStair 021774,93SFS0CorridorsCorridorsDropLay-InStair 02173,143SFS0CorridorsCorridorsDropLay-InStair 02173,143SFS0CorridorsCorridorsDropLay-InStair 02173,143SFS0CorridorsCorridorsDropLay-InCatalk Access 173,143SFS0CorridorsCorridorsExposedCatalk Access 173,143SFS0Corridors	Corridors	Corridors	Drinking Fountains	Vestibule 0119			EA	\$0	
CorridorsCorridorsDinking FountainsVestibule 043EA\$0CorridorsCorridorsDinking FountainsVestibule 021EA\$0CorridorsCorridorsDinking FountainsVestibule 021EA\$0CorridorsCorridorsDinking FountainsAuditorium LobbyEA\$0CorridorsCorridorsDinking FountainsStair 0149EA\$0CorridorsCorridorsDinking FountainsStair 0149F\$0\$0CorridorsCorridorsDropLay-InAuditorium Lobby7\$2,08\$F\$0CorridorsCorridorsDropLay-InStair 01497\$0\$5\$0CorridorsCorridorsDropLay-InVestibule 0217\$1\$1\$0\$0CorridorsCorridorsDropLay-InStair 17\$35\$5\$0\$0CorridorsCorridorsDropLay-InStair 17\$43\$F\$0\$0CorridorsCorridorsDropLay-InStair 27\$43\$F\$0\$0CorridorsCorridorsDropLay-InStair 27\$43\$F\$0\$0CorridorsCorridorsDropLay-InStair 27\$43\$F\$0\$0CorridorsCorridorsDropLay-InStair 27\$43\$F\$0\$0CorridorsCorridorsCorridorsExposedCarl 4\$F\$0\$0\$0 </td <td>Corridors</td> <td>Corridors</td> <td>Drinking Fountains</td> <td>Catwalk Access 2</td> <td></td> <td></td> <td>EA</td> <td>\$0</td> <td></td>	Corridors	Corridors	Drinking Fountains	Catwalk Access 2			EA	\$0	
CorridorsCorridorsDinking FountainsVestibule 0221EA\$0CorridorsCorridorsDinking FountainsAuditorium LobbyEA\$0CorridorsCorridorsDinking FountainsAuditorium VestibulesEA\$0CorridorsCorridorsDinking FountainsAuditorium VestibulesEA\$0CorridorsCorridorsDinking FountainsStair 01497\$2,936\$F\$0CorridorsCorridorsDrop/Lay-InNutliforium Lobby7\$2,936\$F\$0CorridorsCorridorsDrop/Lay-InNutliforium Lobby7\$2,936\$F\$0CorridorsCorridorsDrop/Lay-InNutliforium Lobby7\$2,936\$F\$0CorridorsCorridorsDrop/Lay-InVestibule 010977\$4\$F\$0CorridorsCorridorsDrop/Lay-InStair 147\$45\$F\$0CorridorsCorridorsDrop/Lay-InStair 147\$43\$F\$0CorridorsCorridorsDrop/Lay-InStair 27\$44\$F\$0CorridorsCorridorsExposedIst Floor7\$300\$F\$0CorridorsCorridorsExposedCalwalk Access 27\$447\$F\$0CorridorsCorridorsExposedCalwalk Access 27\$46\$F\$0CorridorsCorridorsLay-InAuditorium Vesibule 01017\$1	Corridors	Corridors	Drinking Fountains	2nd Floor			EA	\$0	
CorridorsCorridorsDrinking FountainsVestibule 0101EA\$0CorridorsCorridorsDrinking FountainsAuditorium LobbyEA\$0CorridorsCorridorsDrinking FountainsStair 0149EA\$0CorridorsCorridorsDrinking FountainsStair 2EA\$0CorridorsCorridorsDrinking FountainsStair 2EA\$0CorridorsCorridorsDropLay-InStair 2EA\$0CorridorsCorridorsDropLay-InStair 2F\$0CorridorsCorridorsDropLay-InStair 2F\$0CorridorsCorridorsDropLay-InStair 177.8\$F\$0CorridorsCorridorsDropLay-InStair 174.35\$F\$0CorridorsCorridorsDropLay-InStair 274.35\$F\$0CorridorsCorridorsDropLay-InStair 274.35\$F\$0CorridorsCorridorsDropLay-InStair 274.35\$F\$0CorridorsCorridorsDropLay-InStair 274.35\$F\$0CorridorsCorridorsExposedCatwalk Access 274.35\$F\$0CorridorsCorridorsExposedCatwalk Access 274.45\$F\$0CorridorsCorridorsLay-InStair 274.35\$F\$0CorridorsCorrido	Corridors	Corridors	Drinking Fountains	Vestibule 0143			EA	\$0	
CorridorsCorridorsDrinking FountainsAuditorium LobbyEA\$0CorridorsOrnidorsDrinking FountainsStair 21EA\$0CorridorsCorridorsDrinking FountainsStair 2EA\$0CorridorsCorridorsDropLay-InStair 2EA\$0CorridorsCorridorsDropLay-InStair 2EA\$0CorridorsCorridorsDropLay-InStair 2Z\$6\$0CorridorsCorridorsDropLay-InStair 17\$2,08\$6\$0CorridorsCorridorsDropLay-InVestibule 02217\$7\$2,08\$6\$0CorridorsCorridorsDropLay-InStair 27\$436\$6\$0CorridorsDropLay-InStair 27\$3,810\$F\$0CorridorsDropLay-InAudtorium Vestibules7\$128\$F\$0CorridorsDropLay-InAudtorium Vestibules7\$128\$F\$0CorridorsCorridorsDropLay-InAudtorium Vestibules7\$128\$F\$0CorridorsCorridorsDropLay-InAudtorium Vestibules7\$128\$F\$0CorridorsCorridorsExposedCarwalk Access 27\$494\$F\$0CorridorsCorridorsExposedCarwalk Access 27\$494\$F\$0CorridorsCorridorsLay-InCarwalk Access 27\$494 <td>Corridors</td> <td>Corridors</td> <td>Drinking Fountains</td> <td>Vestibule 0221</td> <td></td> <td></td> <td>EA</td> <td>\$0</td> <td></td>	Corridors	Corridors	Drinking Fountains	Vestibule 0221			EA	\$0	
CorridorsCorridorsDinking FountainsAuditorium VestibulesEA\$0CorridorsCorridorsDinking FountainsStair 21EA\$0CorridorsCorridorsDropLay-InAuditorium Lobby72,93\$F\$0CorridorsCorridorsDropLay-InStei D1472,93\$F\$0CorridorsCorridorsDropLay-In1st Floor777\$F\$0CorridorsCorridorsDropLay-InVestibule 010977\$F\$0\$0CorridorsCorridorsDropLay-InVestibule 02217166\$F\$0CorridorsCorridorsDropLay-InStair 173.81\$F\$0CorridorsCorridorsDropLay-InAuditorium Vestibules73.81\$F\$0CorridorsCorridorsDropLay-InAuditorium Vestibules73.81\$F\$0CorridorsCorridorsDropLay-InAuditorium Vestibules73.81\$F\$0CorridorsCorridorsDropLay-InAuditorium Vestibules73.81\$F\$0CorridorsCorridorsExposedCatwalk Access 27441\$F\$0CorridorsCorridorsLay-InAuditorium Vestibules73.81\$F\$0CorridorsCorridorsLay-InAuditorium Vestibules73.81\$F\$0CorridorsCorridorsLay-In	Corridors	Corridors	Drinking Fountains	Vestibule 0101			EA	\$0	
CorridorsCorridorsDinking FountainsStair 0149EA\$0CorridorsCorridorsDinking FountainsStair 2F\$0CorridorsCorridorsDrop/Lay-InAuditorium Lobby72.938\$F\$0CorridorsCorridorsDrop/Lay-InIst Floor77.74\$F\$0CorridorsCorridorsDrop/Lay-InVestibule 010977.74\$F\$0CorridorsCorridorsDrop/Lay-InStair 174.95\$F\$0CorridorsCorridorsDrop/Lay-InStair 274.94\$F\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules73.810\$F\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules73.810\$F\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules73.90\$F\$0CorridorsCorridorsExposedCatwalk Access 174.94\$F\$0CorridorsCorridorsExposedCatwalk Access 274.94\$F\$0CorridorsCorridorsLay-InCatwalk Access 274.94\$F\$0CorridorsCorridorsLay-InCatwalk Access 274.94\$F\$0CorridorsCorridorsLay-InAuditorium Vestibules73.18\$1\$1CorridorsCorridorsLay-InAuditorium Vestibules7	Corridors	Corridors	Drinking Fountains	Auditorium Lobby			EA	\$0	
CorridorsCorridorsDinking FountainsStair 2EA\$0CorridorsCorridorsDrop/Lay-InAuditorium Lobby72,93\$F\$0CorridorsCorridorsDrop/Lay-InYestibule 01097774\$F\$0CorridorsCorridorsDrop/Lay-InVestibule 02217746\$F\$0CorridorsCorridorsDrop/Lay-InStair 173,810\$F\$0CorridorsCorridorsDrop/Lay-InStair 273,810\$F\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibule 0273,810\$F\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibule 0273,810\$F\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibule 0273,810\$F\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibule 0273,910\$F\$0CorridorsCorridorsExposedCatwalk Access 173,910\$F\$0CorridorsCorridorsExposedCatwalk Access 274,45\$0\$0CorridorsCorridorsLay-InStair 174,94\$F\$0CorridorsCorridorsLay-InCatwalk Access 273,05\$A\$0CorridorsCorridorsLay-InAuditorium Vestibules74,94\$A\$0CorridorsCorridors </td <td>Corridors</td> <td>Corridors</td> <td>Drinking Fountains</td> <td>Auditorium Vestibules</td> <td></td> <td></td> <td>EA</td> <td>\$0</td> <td></td>	Corridors	Corridors	Drinking Fountains	Auditorium Vestibules			EA	\$0	
CorridorsCorridorsDrop/Lay-InAuditorium Lobby72,938SF\$0CorridorsCorridorsDrop/Lay-In1st Floor72,083SF\$0CorridorsCorridorsDrop/Lay-InVestibule 02010777.66SF\$0CorridorsCorridorsDrop/Lay-InStair 174.35SF\$0CorridorsCorridorsDrop/Lay-InStair 274.94SF\$0CorridorsCorridorsDrop/Lay-InStair 273.810SF\$0CorridorsCorridorsDrop/Lay-InStair 273.910SF\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules73.00SF\$0CorridorsCorridorsExposedStalr 274.94SF\$0CorridorsCorridorsExposedCatwalk Access 173.00SF\$0CorridorsCorridorsExposedCatwalk Access 274.74SF\$0CorridorsCorridorsLay-InStair 274.74SF\$0CorridorsCorridorsLay-InStair 274.74SF\$0CorridorsCorridorsLay-InStair 273.075EA\$0CorridorsCorridorsLay-InCorridors73.075EA\$0CorridorsCorridorsLay-InVestibule 011073.16EA <td>Corridors</td> <td>Corridors</td> <td>Drinking Fountains</td> <td>Stair 0149</td> <td></td> <td></td> <td>EA</td> <td>\$0</td> <td></td>	Corridors	Corridors	Drinking Fountains	Stair 0149			EA	\$0	
CorridorsCorridorsDrop/Lay-In1st Floor72,083SF\$0CorridorsCorridorsDrop/Lay-InVestibule 0201774SF\$0CorridorsCorridorsDrop/Lay-InVestibule 02217435SF\$0CorridorsCorridorsDrop/Lay-InStai 17435SF\$0CorridorsCorridorsDrop/Lay-InStair 27444SF\$0CorridorsCorridorsDrop/Lay-InStair 27444SF\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules7300SF\$0CorridorsCorridorsDrop/Lay-InCatwalk Access 17451SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsLay-InStair 27444SF\$0CorridorsCorridorsLay-InStair 27447SF\$0CorridorsCorridorsLay-InStair 27447SF\$0CorridorsCorridorsLay-InStair 27444\$1\$1\$1CorridorsCorridorsLay-InStair 27448\$2\$0CorridorsLay-InAuditorium Vestibules73.075EA\$0\$0	Corridors	Corridors	Drinking Fountains	Stair 2			EA	\$0	
CorridorsCorridorsDrop/Lay-InVestibule 010977778\$0CorridorsCorridorsDrop/Lay-InVestibule 02117166SF\$0CorridorsCorridorsDrop/Lay-InStair 173.43SF\$0CorridorsCorridorsDrop/Lay-InZafi 274.94SF\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules73.12SF\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules73.00SF\$0CorridorsCorridorsCorridorsExposedCatwalk Access 174.44SF\$0CorridorsCorridorsExposedCatwalk Access 274.44SF\$0CorridorsCorridorsExposedCatwalk Access 274.44\$5\$0CorridorsCorridorsExposedCatwalk Access 274.94\$6\$0CorridorsCorridorsLay-InTel foor73.075\$6\$0CorridorsCorridorsLay-InAuditorium Vestibules71.16\$A\$0CorridorsCorridorsLay-InAuditorium Vestibule 0.2171.81\$A\$0CorridorsCorridorsLay-InAuditorium Vestibules71.81\$A\$0CorridorsCorridorsLay-InVestibule 0.0171.81\$A\$0Corridors <t< td=""><td>Corridors</td><td>Corridors</td><td>Drop/Lay-In</td><td>Auditorium Lobby</td><td>7</td><td>2,936</td><td>SF</td><td>\$0</td><td></td></t<>	Corridors	Corridors	Drop/Lay-In	Auditorium Lobby	7	2,936	SF	\$0	
CorridorsCorridorsDrop/Lay-InVestibule 02217166SF\$0CorridorsCorridorsDrop/Lay-InStair 17435SF\$0CorridorsCorridorsDrop/Lay-In2nd Floor73.810SF\$0CorridorsCorridorsDrop/Lay-InStair 27494SF\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules7312SF\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules7300SF\$0CorridorsCorridorsExposedCatwalk Access 17451SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorsCatwalk Access 27447SF\$0CorridorsCorridorsLay-In1st Floor72,083EA\$0CorridorsCorridorsLay-InStair 27444EA\$0CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197181EA\$0CorridorsCorridorsLay-InVestibule 01017166EA\$0CorridorsCorridorsLay-InVestibule 01017166EA	Corridors	Corridors	Drop/Lay-In	1st Floor	7	2,083	SF	\$0	
CorridorsCorridorsDro/Lay-InStair 17435SF\$0CorridorsCorridorsDro/Lay-In2nd Floor73.810SF\$0CorridorsCorridorsDro/Lay-InStair 27494SF\$0CorridorsCorridorsDro/Lay-InAuditorium Vestibules7312SF\$0CorridorsCorridorsExposed1st Floor7300SF\$0CorridorsCorridorsExposedCatwalk Access 17441SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorCatwalk Access 27447SF\$0CorridorsCorridorsLay-InStair 27444SF\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-InAuditorium Vestibules73.075EA\$0CorridorsCorridorsLay-InVestibule 02117181EA\$0CorridorsCorridorsLay-InVestibule 0117181EA\$0CorridorsCorridorsLay-InVestibule 01017181EA\$0CorridorsCorridorsLay-InVestibule 01017181EA\$0Co	Corridors	Corridors	Drop/Lay-In	Vestibule 0109	7	74	SF	\$0	
CorridorsCorridorsDrop/Lay-In2nd Floor73,810SF\$0CorridorsCorridorsDrop/Lay-InStair 27494SF\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules7312SF\$0CorridorsCorridorsExposed1st Floor7431SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorsCatwalk Access 27447SF\$0CorridorsCorridorsLay-InCatwalk Access 27447SF\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-In2nd Floor73.05EA\$0CorridorsCorridorsLay-InAditorium Vestibules73.12EA\$0CorridorsCorridorsLay-InVestibule 011971.16EA\$0CorridorsCorridorsLay-InVestibule 0109774.8\$0CorridorsCorridorsLay-InVestibule 010971.81EA\$0CorridorsCorridorsLay-InVestibule 010971.81EA\$0CorridorsCorridorsLay-InVestibule 010972.93<	Corridors	Corridors	Drop/Lay-In	Vestibule 0221	7	166	SF	\$0	
CorridorsCorridorsDrop/Lay-InStair 27494SF\$0CorridorsCorridorsDrop/Lay-InAuditorium Vestibules7312SF\$0CorridorsCorridorsExposed1st Floor7300SF\$0CorridorsCorridorsExposedCatwalk Access 17451SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorsCatwalk Access 27447\$5\$0CorridorsCorridorsFloorsCatwalk Access 27447\$5\$0CorridorsCorridorsExposedCatwalk Access 27447\$5\$0CorridorsCorridorsLay-In1st Floor72,083EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-InVestibule 01073,075EA\$0CorridorsCorridorsLay-InVestibule 01197166EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0Cor	Corridors	Corridors	Drop/Lay-In	Stair 1	7	435	SF	\$0	
CorridorsCorridorsDro/Lay-InAuditorium Vestibules7312SF\$0CorridorsCorridorsExposed1st Floor7300SF\$0CorridorsCorridorsExposedCatwalk Access 17451SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorsFloorsCatwalk Access 27447SF\$0CorridorsCorridorsCorridorsIst Floor72,083EA\$0CorridorsCorridorsLay-InStair 27444EA\$0CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InAuditorium Vestibule 02217312EA\$0CorridorsCorridorsLay-InVestibule 01197166EA\$0CorridorsCorridorsLay-InVestibule 01197150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InKetibule 0109774EA\$0CorridorsCorridorsLay-InKetibule 0109774EA <td>Corridors</td> <td>Corridors</td> <td>Drop/Lay-In</td> <td>2nd Floor</td> <td>7</td> <td>3,810</td> <td>SF</td> <td>\$0</td> <td></td>	Corridors	Corridors	Drop/Lay-In	2nd Floor	7	3,810	SF	\$0	
CorridorsCorridorsExposed1st Floor7300SF\$0CorridorsCorridorsExposedCatwalk Access 17451SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorsCatwalk Access 2736SF\$0CorridorsCorridorsLay-In1st Floor72,083EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InAuditorium Vestibules73,12EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InAuditorium Lobby77,04EA\$0<	Corridors	Corridors	Drop/Lay-In	Stair 2	7	494	SF	\$0	
CorridorsCorridorsExposedCatwalk Access 17451SF\$0CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorsCatwalk Access 2736SF\$0CorridorsCorridorsLay-In1st Floor72,083EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InAuditorium Vestibules7312EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197150EA\$0CorridorsCorridorsLay-InVestibule 01197150EA\$0CorridorsCorridorsLay-InVestibule 010977451\$0CorridorsCorridorsLay-InVestibule 01097745\$0CorridorsCorridorsLay-InVestibule 01097745\$0CorridorsCorridorsLay-InVestibule 01097745\$0CorridorsCorridorsLay-InAuditorium Lobby72,93EA\$0CorridorsCorridorsLay-InAuditorium Lobby7104EA\$0 <td< td=""><td>Corridors</td><td>Corridors</td><td>Drop/Lay-In</td><td>Auditorium Vestibules</td><td>7</td><td>312</td><td>SF</td><td>\$0</td><td></td></td<>	Corridors	Corridors	Drop/Lay-In	Auditorium Vestibules	7	312	SF	\$0	
CorridorsCorridorsExposedCatwalk Access 27447SF\$0CorridorsCorridorsFloorsCatwalk Access 2736SF\$0CorridorsCorridorsLay-In1st Floor72,083EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InAuditorium Vestibules7312EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01017181EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Exposed	1st Floor	7	300	SF	\$0	
CorridorsCorridorsFloorsCatwalk Access 2736SF\$0CorridorsCorridorsLay-In1st Floor72,083EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InAuditorium Vestibules7312EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197181EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Exposed	Catwalk Access 1	7	451	SF	\$0	
CorridorsCorridorsLay-In1st Floor72,083EA\$0CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InAuditorium Vestibules7312EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197181EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Exposed	Catwalk Access 2	7	447	SF	\$0	
CorridorsCorridorsLay-InStair 27494EA\$0CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InAuditorium Vestibules7312EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197181EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InAuditorium Lobby7104EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Floors	Catwalk Access 2	7	36	SF	\$0	
CorridorsCorridorsLay-In2nd Floor73,075EA\$0CorridorsCorridorsLay-InAuditorium Vestibules7312EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197181EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Lay-In	1st Floor	7	2,083	EA	\$0	
CorridorsCorridorsLay-InAuditorium Vestibules7312EA\$0CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197181EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InVestibule 010972,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Lay-In	Stair 2	7	494	EA	\$0	
CorridorsCorridorsLay-InVestibule 02217166EA\$0CorridorsCorridorsLay-InVestibule 01197181EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Lay-In	2nd Floor	7	3,075	EA	\$0	
CorridorsCorridorsLay-InVestibule 01197181EA\$0CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Lay-In	Auditorium Vestibules	7	312	EA	\$0	
CorridorsCorridorsLay-InVestibule 01017150EA\$0CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Lay-In	Vestibule 0221	7	166	EA	\$0	
CorridorsCorridorsLay-InVestibule 0109774EA\$0CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Lay-In	Vestibule 0119	7	181	EA	\$0	
CorridorsCorridorsLay-InAuditorium Lobby72,936EA\$0CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Lay-In	Vestibule 0101	7	150	EA	\$0	
CorridorsCorridorsLay-InStair 01497104EA\$0	Corridors	Corridors	Lay-In	Vestibule 0109	7	74	EA	\$0	
	Corridors	Corridors	Lay-In	Auditorium Lobby	7	2,936	EA	\$0	
CorridorsCorridorsLightingVestibule 014375EA\$0	Corridors	Corridors	Lay-In	Stair 0149	7	104	EA		
	Corridors	Corridors	Lighting	Vestibule 0143	7	5	EA	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Corridors	Corridors	Lighting	1st Floor	7	737	EA	\$0	
Corridors	Corridors	Pendant/Surface	Catwalk Access 1	7	451	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 1	7	123	EA	\$0	
Corridors	Corridors	Pendant/Surface	Catwalk Access 2	7	447	EA	\$0	
Corridors	Corridors	Plaster/Drywall	Auditorium Vestibules	7	1,052	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Stair 2	7	35	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Vestibule 0109	7	245	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Vestibule 0143	6	450	SF	\$1,062	
Corridors	Corridors	Plaster/Drywall	Stair 0149	7	425	SF	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	4	EA	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor	7	55	LF	\$0	
Corridors	Corridors	Stair Handrails	Vestibule 0143			LF	\$0	
Corridors	Corridors	Stair Handrails	Catwalk Access 2	7	88	LF	\$0	
Corridors	Corridors	Stair Handrails	Vestibule 0109			LF	\$0	
Corridors	Corridors	Stair Handrails	Auditorium Lobby			LF	\$0	
Corridors	Corridors	Stair Handrails	Catwalk Access 1	7	54	LF	\$0	
Corridors	Corridors	Stair Handrails	Catwalk Access 2	7	90	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 2	7	71	LF	\$0	
Corridors	Corridors	Stair Handrails	Vestibule 0101			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 1	7	93	LF	\$0	
Corridors	Corridors	Stair Handrails	Auditorium Vestibules			LF	\$0	
Corridors	Corridors	Stair Handrails	Vestibule 0221			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 0149	7	20	LF	\$0	
Corridors	Corridors	Stair Handrails	Vestibule 0119			LF	\$0	
Corridors	Corridors	Stairs	Catwalk Access 2	7	55	EA	\$0	
Corridors	Corridors	Stairs	2nd Floor	7	7	EA	\$0	
Corridors	Corridors	Stairs	Catwalk Access 2	7	33	EA	\$0	
Corridors	Corridors	Stairs	Vestibule 0143	7	8	EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Vestibule 0109			EA	\$0	
Corridors	Corridors	Stairs	Auditorium Lobby			EA	\$0	
Corridors	Corridors	Stairs	Vestibule 0119			EA	\$0	
Corridors	Corridors	Stairs	Vestibule 0221			EA	\$0	
Corridors	Corridors	Stairs	Stair 0149	7	8	EA	\$0	
Corridors	Corridors	Stairs	Auditorium Vestibules			EA	\$0	
Corridors	Corridors	Stairs	Catwalk Access 1	7	37	EA	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stairs	Vestibule 0101			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	Auditorium Lobby	7	720	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor	7	115	SF	\$0	
Corridors	Corridors	Student Lockers	Vestibule 0221			EA	\$0	
Corridors	Corridors	Student Lockers	Vestibule 0101			EA	\$0	
Corridors	Corridors	Student Lockers	Auditorium Lobby			EA	\$0	
Corridors	Corridors	Student Lockers	Auditorium Vestibules			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 0149			EA	\$0	
Corridors	Corridors	Student Lockers	Vestibule 0119			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	7	150	EA	\$0	
Corridors	Corridors	Student Lockers	Stair 1			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 2			EA	\$0	
Corridors	Corridors	Student Lockers	Catwalk Access 1			EA	\$0	
Corridors	Corridors	Student Lockers	Vestibule 0109			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Vestibule 0143			EA	\$0	
Corridors	Corridors	Student Lockers	Catwalk Access 2			EA	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	737	SF	\$0	
Corridors	Corridors	Terrazzo	Stair 1	7	114	SF	\$0	
Corridors	Corridors	Terrazzo	Vestibule 0119	7	181	SF	\$0	
Corridors	Corridors	Terrazzo	Stair 2	7	106	SF	\$0	
Corridors	Corridors	Terrazzo	Vestibule 0101	7	150	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	2,083	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair 1	7	430	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair 2	7	389	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	7	6,998	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Auditorium Lobby	7	3,998	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Vestibule 0221	7	166	SF	\$0	
Corridors	Corridors	Wall Mounted	Stair 1	7	530	EA	\$0	
Corridors	Corridors	Walls	Vestibule 0101	7	166	SF	\$0	decorative cmu
Corridors	Corridors	Walls	1st Floor	7	1,000	SF	\$0	
Corridors	Corridors	Walls	Vestibule 0101	7	245	SF	\$0	
Corridors	Corridors	Walls	Stair 1	7	1,398	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	2,480	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	115	SF	\$0	
Corridors	Corridors	Walls	Stair 2	7	1,942	SF	\$0	
Corridors	Corridors	Walls	Vestibule 0119	7	444	SF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Walls	Auditorium Lo	bby 7	7,270	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 0149	7	104	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Vestibule 011	9 7	181	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Auditorium Lo	bby 7	1,062	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Vestibule 010	1 7	150	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 1	7	330	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	7	3,188	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 2	7	152	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Vestibule 014	3 7	240	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	737	SF	\$0	
Stairs	Corridors	Terrazzo	Stair 1	7	26	SF	\$0	
Stairs	Corridors	Terrazzo	Stair 2	7	26	SF	\$0	
Floor	Classroom	Carpet		7	1,715	SF	\$0	
Floor	Classroom	Tile/Sheet		7	775	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,769	SF	\$0	
Floor	Classroom	Tile/Sheet		7	727	SF	\$0	
Floor	Classroom	Tile/Sheet		7	775	SF	\$0	
Floor	Classroom	Tile/Sheet		7	775	SF	\$0	
Floor	Classroom	Tile/Sheet		7	775	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,452	SF	\$0	
Floor	Classroom	Tile/Sheet		7	775	SF	\$0	
Floor	Classroom	Tile/Sheet		7	600	SF	\$0	
Floor	Classroom	Tile/Sheet		7	775	SF	\$0	
Lighting	Classroom	Lay-In		7	17	EA	\$0	
Lighting	Classroom	Lay-In		7	8	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	30	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	30	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
LUNCH_FLOOR	Multipurpose Room	Lunchroom Floor	Scene Shop I	Rm 1131 6	1,406	SF	\$2,011	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Marker Board	Classroom	Marker Board		7	16	LF	\$0
Marker Board	Classroom	Marker Board		7	16	LF	\$O
Marker Board	Multipurpose Room	Marker Board	0114 Small Practice Room	7	8	LF	\$ 0
Marker Board	Multipurpose Room	Marker Board	Scene Shop Rm 1131			LF	\$O
Marker Board	Multipurpose Room	Marker Board	Green Room 0126			LF	\$ 0
Marker Board	Classroom	Marker Board		7	16	LF	\$ 0
Marker Board	Classroom	Marker Board		7	6	LF	\$ 0
Marker Board	Classroom	Marker Board		7	16	LF	\$ 0
Marker Board	Classroom	Marker Board		7	8	LF	\$ 0
Marker Board	Multipurpose Room	Marker Board	0116 Small Practice Room	7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	16	LF	\$0
Marker Board	Classroom	Marker Board		7	16	LF	\$0
Marker Board	Multipurpose Room	Marker Board	0112 Small Practice	7	8	LF	\$ 0
Marker Board	Classroom	Marker Board		7	16	LF	\$ 0
THEATER_WALL	Auditorium - Dedicated	Auditorium Walls	1st Floor	7	1,605	SF	\$ 0
THEATER_WALL	Auditorium - Dedicated	Auditorium Walls	1st Floor	7	1,106	SF	\$0
Wall	Classroom	Concrete Block		7	25	SF	\$0
Wall	Classroom	Concrete Block		7	1,792	SF	\$0
Wall	Classroom	Concrete Block		7	1,216	SF	\$0
Wall	Classroom	Concrete Block		7	1,400	SF	\$0
Wall	Classroom	Concrete Block		7	25	SF	\$0
Wall	Classroom	Concrete Block		7	925	SF	\$0
Wall	Classroom	Concrete Block		7	25	SF	\$0
Wall	Classroom	Concrete Block		7	25	SF	\$0
Wall	Classroom	Concrete Block		7	25	SF	\$0
Wall	Classroom	Concrete Block		7	25	SF	\$0
Wall	Classroom	Plaster/Drywall		7	1,119	SF	\$0
Wall	Classroom	Plaster/Drywall		7	972	SF	\$0
Wall	Classroom	Plaster/Drywall		7	972	SF	\$0
Wall	Classroom	Plaster/Drywall		7	972	SF	\$0
Wall	Classroom	Plaster/Drywall		7	972	SF	\$0
Wall	Classroom	Plaster/Drywall		7	972	SF	\$0
Wall	Classroom	Plaster/Drywall		7	816	SF	\$0
Wall	Classroom	Plaster/Drywall		7	972	SF	\$0
			ROOM	Sub To	tal		\$14,022



Building: Building Category: ROOM	A/B							
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
			Building Building A/B	Sub Tota	al		\$61,129	
Building: Building Category: EXTERIO								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Metal Flue	Main Roof	7	12	LF	\$0	
Doors		Exterior Steel Door	Entire Building	6	5	EA	\$1,652	
Doors		Exterior Steel Door	W delivery	5	1	EA	\$1,090	dented, holes
Doors		Overhead Rolling / Garage Door	W and N entrances	6	4	EA	\$4,107	paint
Doors		Side Lite	W and E entrances	7	4	EA	\$0	
Doors		Store Front Door	W, E, S entrances	7	13	EA	\$0	
Doors		Transom Lite	Entire Building	6	16	EA	\$4,530	
Foundation		Concrete Foundation	Basement	6	902	LF	\$140,466	significant floor cracking/ settlement at bay
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Site	6	42	EA	\$21,021	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Site	7	86	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	5	5	EA	\$2,503	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	13	EA	\$2,789	
Lintels		Lintels - Steel	Entire Building	7	400	LF	\$0	
Parapet		Coping - Metal	Entire Building	7	902	LF	\$0	
Roof System		Asphalt Gravel Ballast Roof	Roof	6	50,800	SF	\$323,992	
Roof System		Interior Downspouts	Entire Building	6	276	LF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Top	oping Roof	7	50,800	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	158,600	SF	\$0	
Walls		Concrete Block	E main entry	5	50	SF	\$965	graffiti
Walls		Concrete Block	E main entry	6	15	SF	\$99	open joint
Walls		Concrete Block	Entire Building	7	15,322	SF	\$0	
Walls		Concrete Block	West Door 5	5	150	SF	\$2,896	cracked
Walls		Precast Panel Wall	cornice and corners	6	14,372	SF	\$94,950	
Windows		Curtain wall - Glazed Double Pane	Entire Building	7	9,737	SF	\$0	
Windows		Curtain wall - Windows	Entire Building	7	1,666	SF	\$0	
Windows		Skylite - Lexan	Main Roof	4	1,840	SF	\$392,470	leaks reported
			EXTERIO	R Sub Tota	al		\$993,529	

Building: Building Category: ELECTR								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Building: Building Category: ELECTR								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Basement	7	2	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	25,594	SF	\$10,980	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	14,083	SF	\$7,451	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	23	EA	\$2,467	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	2	EA	\$215	
Emergency System		Emergency generator 60 to 100 KW natural gas - Outdoor	OUTSIDE COURTYARD	6	1	EA	\$10,511	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	4	27	EA	\$25,097	APPEARANCE IS POOR
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	5	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	s 1st Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	s 1st Floor	4	1	EA	\$930	POOR CONDITION
Main Service		Main Electrical service 2000 to 3000 A 277/480/3PH	Electrical Room	7	1	EA	\$0	
Main Service		Main Electrical service above 3000 A 120/208/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	7	16	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	6	12	EA	\$8,580	
Power Distribution		Main distribution panels 400-600 amp	Entire Building	7	10	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Basement	6	1	EA	\$1,430	
Power Distribution		Main distribution panels above 600 amp	Boiler Room	7	1	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Entire Building	7	1	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Basement	6	1	EA	\$1,216	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Basement	7	2	EA	\$0	
			ELECTRICAL	Sub To	tal		\$68,874	
Building: Building Category: FIRE PR								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	158,600	SF	\$0	
Fire Alarm		Fire Alarm System	Basement	7	158,600	SF	\$0	
			FIRE PROTECTION	Sub To	tal		\$0	

Building:	Building C
Category:	MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Building: Building C Category: MECHANIC	AL							
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Water Cooled - Centrifugal 100 to 200 tons	CHILLER ROOM	6	1	EA	\$14,872	
Air Conditioning		Chillers - Water Cooled - Centrifugal 100 to 200 tons	CHILLER ROOM	5	1	EA	\$74,360	1 COMPRESSOR IS OUT
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	7	2	EA	\$0	
Air Conditioning		Cooling Tower - Spray Type - greater than 300 tons	COURTYARD	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water less than 4,000 cfm	AUTO SHOP	5	1	EA	\$10,010	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water less than 4,000 cfm	Basement	5	1	EA	\$10,010	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	SOUTH EXTERIOR WALL OF AUTOSHOP	5	1	EA	\$5,720	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Ground llevel, north east corner of north exterior wall by cooling tower	5	1	EA	\$5,720	
Air Handling Systems		Fan Coil Unit - Hot Water and Chilled Water	Entire Building	7	129	EA	\$0	
Air Handling Systems		Make Up Air Unit - Roof Mounted - Gas-Heating less than 6,000 cfm	Roof	2	1	EA	\$28,600	NON OPERATIONAL
Air Handling Systems		Make Up Air Unit - Roof Mounted - Gas-Heating less than 6,000 cfm	Roof	4	1	EA	\$28,600	
Air Handling Systems		Roof Top Unit - Multi Zone - Gas-Heating greater than 45 tons	Roof	7	1	EA	\$0	
Air Handling Systems		Roof Top Unit - Multi Zone - Gas-Heating greater than 45 tons	Roof	7	1	EA	\$0	
Boiler Systems		Boiler Assembly - Condensing Hot Water Boiler 2,001MBH-3,000 MBH	Boiler Room	7	3	EA	\$0	
Boiler Systems		Boiler Auxiliary - Condensing Hot Water Boiler 2,001MBH-3,000 MBH	Boiler Room	7	3	EA	\$0	
Boiler Systems		Chemical Feeder - Steam Boiler	Basement	5	1	EA	\$1,502	
Boiler Systems		Glycol Feed System	CHILLER ROOM	7	1	EA	\$0	
Boiler Systems		Glycol Feed System	Basement	5	1	EA	\$1,716	
Boiler Systems		Glycol Feed System	Boiler Room	7	1	EA	\$0	
Heating Devices		Fin Tube Electric	Entire Building	6	12	LF	\$172	
Heating Devices		Fin Tube Electric	Electrical Room	4	4	LF	\$572	
Heating Devices		Unit Heater - Electric	Entire Building	6	1	EA	\$1,430	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	7	600	LF	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	7	2,000	LF	\$0	

Building: Building C Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Pumps - Chilled Water 10 to 20 HP	CHILLER ROOM	7	2	EA	\$0	
Mechanical Plumbing		Pumps - Condenser Water 21-50 HP	CHILLER ROOM	7	2	EA	\$0	
Mechanical Plumbing		Pumps - Dual Temperature Water 21 - 50 HP	Boiler Room	6	2	EA	\$11,440	
Temperature Control		Direct Digital Control (DDC) System	Basement	5	256,400	SF	\$1,283,282	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	127	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	4	EA	\$572	
Ventilation		Exhaust Fan - Indoor	1st Floor	5	1	EA	\$1,859	
Ventilation		Exhaust Fan - Indoor	1st Floor	6	1	EA	\$501	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	7	EA	\$10,511	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	3	1	EA	\$4,290	NON OPERATIONAL
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	4	14	EA	\$60,060	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	3	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	4	2	EA	\$4,576	
Ventilation		Lab Exhaust Hood	3rd Floor	3	1	EA	\$32,890	UNIT IS INOPERABLE
Ventilation		Lab Exhaust Hood	3rd Floor	6	1	EA	\$3,289	
Ventilation		Lab Exhaust Hood	1st Floor	3	2	EA	\$65,780	INOPERABLE
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Entire Building	7	3	EA	\$0	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	LUNCHROOM SERVING AREA	4	2	EA	\$53,768	
Ventilation		Type II Exhaust Hood - Warming Kitchen	KITCHEN	7	3	EA	\$0	

MECHANICAL Sub Total

\$1,716,529

Building: Building C Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	3	2	EA	\$45,760	UNITS ARE NON OPERATIONAL
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	1	EA	\$4,147	
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Boiler Room	5	1	EA	\$17,160	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	5	158,600	SF	\$27,216	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	158,600	SF	\$52,164	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	5	158,600	SF	\$181,438	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	158,600	SF	\$34,020	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	158,600	SF	\$40,824	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	158,600	SF	\$140,615	

Building: Building C Category: PLUMBING

Category: PLUMBING	i							
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	5	158,600	SF	\$83,915	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	158,600	SF	\$86,183	
Piping		Sanitary Piping	Entire Building	6	158,600	SF	\$63,503	
Piping		Storm Piping	Entire Building	6	158,600	SF	\$34,020	
Piping		Vent Piping	Entire Building	6	158,600	SF	\$24,948	
Pumps		Domestic Booster Pump duplex	Basement	5	1	EA	\$15,730	
Pumps		Ejector Pump	CHILLER ROOM	7	1	EA	\$0	
Pumps		Sump Pump	CHILLER ROOM	7	2	EA	\$0	
			PLUMB	ING Sub To	al		\$851,642	
Building: Building C Category: INTERIOR								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	211	6	380	SF	\$815	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	212	6	649	SF	\$1,392	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	332	6	320	SF	\$686	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	320	6	320	SF	\$686	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	317	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	315	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	219	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	304	6	220	SF	\$472	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	302	6	303	SF	\$650	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	3rd Floor	6	549	SF	\$1,178	
		- ··· · ·		_			•	

302

202

209

2nd Floor

6

7

7

7

SF

SF

SF

SF

303

100

488

488

\$650

\$0

\$0

\$0

Ceiling - Lay-In

Ceiling - Lay-In

Ceiling - Lay-In

Ceiling - Lay-In

Administrative

Suites/Offices

Administrative

Suites/Offices

Administrative

Suites/Offices

Administrative

Suites/Offices

Administrative Suites

Administrative Suites

Administrative Suites

Administrative Suites

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	213	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	217	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	215	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 100	7	1,550	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main Office	7	2,250	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 207	7	488	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	350	6	320	SF	\$686	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	313	7	194	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	kitchen office	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 211	7	194	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	219	6	100	SF	\$143	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	217	6	100	SF	\$143	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	213	6	100	SF	\$143	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	211	6	380	SF	\$543	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	304	6	220	SF	\$315	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	315	6	100	SF	\$143	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	215	6	100	SF	\$143	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	2nd Floor	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	317	6	100	SF	\$143	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile Ceramic/Porcelain	313	7	194	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile Ceramic/Porcelain	Room 211	7	194	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	202	7	488	SF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office	7	2,250	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 100	7	1,550	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 207	7	488	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	209	7	488	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	320	7	320	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	350	7	320	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	302	7	303	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	3rd Floor	7	549	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	332	7	320	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	212	7	649	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	302	7	303	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	302	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	211	7	4	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	213	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	209	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	2nd Floor	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	202	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	350	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	3rd Floor	7	6	SF	\$0 Room 318
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main Office	7	22	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 100	7	18	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	313	7	3	SF	\$0

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 207	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	219	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 211	6	3	SF	\$2
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	215	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	302	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	304	7	1	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	217	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	320	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	332	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	212	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	317	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	kitchen office	7	1	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 211	7	460	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 207	7	850	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	332	6	700	SF	\$2,002
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	213	7	370	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	217	7	370	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Main Office	7	2,600	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	212	7	700	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	209	7	850	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	313	7	460	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	215	7	370	SF	\$0

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	317	7	370	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	202	7	850	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	3rd Floor	7	680	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	315	7	370	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	304	7	440	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	219	7	275	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	302	7	710	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	302	7	710	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	350	5	700	SF	\$5,285	step cracking
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	2nd Floor	7	300	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 100	7	4,300	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	211	7	780	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	kitchen office	7	400	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	320	6	700	SF	\$2,002	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	304	7	160	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	212	7	300	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd Floor	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	3rd Floor	7	300	SF	\$0	
Classrooms		Work Sink	113	7	1	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	123	EA	\$34,826	
Doors		Interior Steel Doors incl hw	Entire Building	7	49	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	5	3	EA	\$1,416	
Doors		Interior Wood Doors incl hw	Entire Building	6	23	EA	\$6,512	
Doors		Interior Wood Doors incl hw	Entire Building	7	15	EA	\$0	
Doors		Store Front Door	Entire Building	7	16	EA	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Store Front Door	Entire Building	6	8	EA	\$1,888	
Doors		Transom Window	Entire Building	7	90	SF	\$0	
Drinking Fountains		Single Fountain	120 auto shop	7	1	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	5	2	EA	\$3,861	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	1	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	6	1	EA	\$386	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	2	EA	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	1st Floor	7	2,543	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Lay-In	1st Floor	7	12	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	1st Floor	7	30	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Concrete Block	1st Floor	7	2,100	SF	\$0	
Library	Library	Casework	2nd Floor	7	350	LF	\$0	
Library	Library	Flooring Carpet	2nd Floor	7	7,750	SF	\$0	
Library	Library	Lighting - Lay-In	2nd Floor	7	54	SF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd FL Boys			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd FL Girls (West)			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd FL - Men			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Basement			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	3rd FL - Girls (West)			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	3rd FL - Boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd FL - Women			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd FL - Girls (East)			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	1st FL Girls (East)			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Room 100			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd FL - Women			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	3rd FL - Girls (East)			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	kitchen womens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	kitchen men			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	next to 120			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	1st FL Boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd FL - Men			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	kitchen womens	7	10	EA	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Lockers	kitchen men	7	4	EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	1st FL Girls (East)			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd FL Boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	1st FL Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd FL - Women			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd FL Girls (West)			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Room 100			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd FL - Women			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd FL - Men			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Basement			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	3rd FL - Girls (West)			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	3rd FL - Boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd FL - Girls (East)			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd FL - Men			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	3rd FL - Girls (East)			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	3rd FL - Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd FL - Women			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	kitchen womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	kitchen men			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	next to 120			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	1st FL Boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	1st FL Girls (East)			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	3rd FL - Girls (East)			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Basement			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd FL - Men			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd FL - Girls (East)			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd FL - Women			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Room 100			EA	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Adult Standard Student Restroom	Showers	3rd FL - Girls (West)			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd FL Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd FL - Men			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd FL Girls (West)			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	1st Floor	7	4,200	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	113 faculty dining room	7	918	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	1st Floor	7	3,100	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	11,540	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	113 faculty dining room	6	918	SF	\$1,313	
Lunchroom	Lunchroom	Lighting - Lay-In	1st Floor	7	40	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	113 faculty dining room	7	9	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	24	SF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	1st Floor	7	33	LF	\$0	
Lunchroom	Lunchroom	Serving Line	113 faculty dining room			LF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	24	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	113 faculty dining room	7	1,250	SF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	7	1,650	SF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	1st Floor	7	1,400	SF	\$0	
Mechanical/Service Rooms		Boiler Room	Basement	7	1,630	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	6	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	7	3,550	SF	\$0	
Mechanical/Service Rooms		Storage Room	Entire Building	7	5,300	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Room 100	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	kitchen men	7	169	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	next to 120	7	150	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	1st FL Boys	7	224	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd FL - Girls (East)	7	265	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd FL Boys	7	224	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd FL - Women	7	215	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	3rd FL - Girls (East)	7	265	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	3rd FL - Boys	7	224	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd FL - Men	7	94	SF	\$0	

Group	Sub Group	Item	Location	Rank Q	uantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd FL Girls (West)	7	193	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Basement	7	130	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	3rd FL - Girls (West)	7	265	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	kitchen womens	7	169	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd FL - Women	7	215	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd FL - Men	7	94	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	1st FL Girls (East)	7	193	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Basement	6	130	SF	\$279	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd FL - Women	7	215	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd FL - Women	7	215	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	3rd FL - Boys	7	224	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	2nd FL - Girls (East)	7	265	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	2nd FL Boys	7	224	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	3rd FL - Girls (West)	7	265	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd FL - Men	7	94	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	1st FL Girls (East)	7	193	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	1st FL Boys	7	224	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	next to 120	7	150	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	kitchen men	7	169	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	kitchen womens	7	169	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	3rd FL - Girls (East)	7	265	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd FL - Men	7	94	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Room 100	7	25	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	2nd FL Girls (West)	7	193	SF	\$0	
Staff Restroom	Staff Restroom	Floor Drain	kitchen men	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	next to 120	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	1st FL Boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd FL - Women	7	1	EA	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Adult Standard Student Restroom	Floor Drain	1st FL Girls (East)	7	1	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd FL Girls (West)	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	kitchen womens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	Basement	7	1	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Floor Drain	3rd FL - Girls (West)	7	2	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Floor Drain	3rd FL - Boys	7	1	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd FL - Girls (East)	7	2	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Floor Drain	3rd FL - Girls (East)	7	2	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	3rd FL - Men			EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	3rd FL - Women	7	1	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd FL Boys	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	Room 100			EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	2nd FL - Men			EA	\$0
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st FL Boys	7	224	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd FL - Girls (West)	7	265	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd FL - Boys	7	224	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL Boys	7	224	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd FL - Girls (East)	7	265	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st FL Girls (East)	7	193	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Room 100	7	25	SF	\$O
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	kitchen womens	7	169	SF	\$O
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL Girls (West)	7	193	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	kitchen men	7	169	SF	\$O
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	next to 120	7	150	SF	\$0
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL - Girls (East)	7	265	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd FL - Women	7	215	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Basement	6	130	SF	\$186

Benito Juarez Community Academy High School

2150 S Laflin St Chicago, IL 60608

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	3rd FL - Women	7	215	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd FL - Women	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd FL - Girls (East)	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom		3rd FL - Boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	3rd FL - Girls (West)	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd FL - Men			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Room 100			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Basement			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	1st FL Girls (East)	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd FL Boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd FL Girls (West)	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd FL - Men			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	3rd FL - Girls (East)	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd FL - Women	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	1st FL Boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	2nd FL - Girls (East)	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	kitchen womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd FL - Women	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	3rd FL - Girls (West)	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Basement	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd FL - Men	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	3rd FL - Boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	1st FL Girls (East)	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	1st FL Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	kitchen men	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd FL - Women	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	3rd FL - Girls (East)	7	3	EA	\$0	

Building: Building C Category: INTERIOR

Group	Sub Group	ltem	Location	Rank Qua	antity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	3rd FL - Men	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	2nd FL Girls (West)	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	2nd FL Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Room 100	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	next to 120	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom		2nd FL Girls (West)	7	3	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Lay-In	2nd FL Boys	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd FL - Women	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	kitchen womens	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	kitchen men	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	next to 120	7	2	SF	\$0	
Staff Restroom	Adult Standard Student Restroom		1st FL Boys	7	3	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Lay-In	1st FL Girls (East)	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd FL - Women	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Basement	7	1	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Lay-In	3rd FL - Boys	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd FL - Men	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Room 100	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd FL - Men	7	2	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd FL - Girls (East)	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	next to 120	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	kitchen men	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	kitchen womens	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Basement	6	1	EA	\$179	
Staff Restroom	Adult Standard Student Restroom	Partitions	1st FL Girls (East)	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	3rd FL - Girls (West)	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd FL - Women	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	1st FL Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd FL - Men	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd FL - Men	7	1	EA	\$0	

Assessment Date: 5/1/2013

Group	Sub Group	Item	Location	Rank Q	uantity	Unit	Cost Reason	
Staff Restroom	Staff Restroom	Partitions	Room 100			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd FL Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd FL - Women	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	3rd FL - Girls (East)	7	5	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd FL Girls (West)	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	3rd FL - Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	next to 120	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd FL - Men	7	1	EA	\$O	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd FL Girls (West)			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	kitchen men	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd FL Boys	7	4	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	3rd FL - Girls (East)			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd FL - Women			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	kitchen womens			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd FL - Girls (East)			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	1st FL Boys	7	4	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	1st FL Girls (East)			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Room 100			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd FL - Men	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd FL - Women			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	3rd FL - Boys	7	4	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	3rd FL - Girls (West)			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Basement			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	1st FL Boys	6	720	SF	\$2,059	
Staff Restroom	Staff Restroom	Wall - Concrete Block	3rd FL - Women	7	900	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	kitchen men	7	520	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	2nd FL - Girls (East)	7	700	SF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Concrete Block	3rd FL - Men	7	380	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	next to 120	7	500	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Basement	6	300	SF	\$858	
Staff Restroom	Staff Restroom	Wall - Concrete Block	kitchen womens	7	520	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	3rd FL - Girls (West)	7	700	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	3rd FL - Boys	6	720	SF	\$2,059	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	2nd FL Boys	6	720	SF	\$2,059	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	1st FL Girls (East)	7	390	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	2nd FL Girls (West)	7	390	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	2nd FL - Men	7	380	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	2nd FL - Women	7	900	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	3rd FL - Girls (East)	7	700	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	Room 100	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd FL - Women	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	3rd FL - Girls (East)	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd FL - Men	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd FL Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	kitchen womens	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Room 100	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd FL Girls (West)	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Basement	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	next to 120	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	1st FL Boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	1st FL Girls (East)	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd FL - Women	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd FL - Men	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd FL - Girls (East)	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	kitchen men	7	1	EA	\$0	

Building: Building C Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Adult Standard Student Restroom	Water Closet	3rd FL - Girls (West)	7	5	EA	\$0
Staff Restroom	Adult Standard Student Restroom	Water Closet	3rd FL - Boys	7	2	EA	\$0
Vocational Shop	Classroom	Culinary Kitchen Equipment		7	14	EA	\$0
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0
Vocational Shop	Classroom	Work Sink		7	5	EA	\$0
Vocational Shop	Classroom	Work Sink		7	12	EA	\$0
Vocational Shop	Classroom	Work Sink		7	8	EA	\$0
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0
Vocational Shop	Classroom	Work Sink		7	7	EA	\$0
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0

INTERIOR Sub Total

\$76,104

Group	Sub Group	Item	Location	Rank C	Quantity	Unit	Cost	Reason
ADMIN_FLOOR	Administrative Suites/Offices	Administrative Office Floor	kitchen office	7	100	SF	\$0	
ADMIN_LIGHT	Administrative Suites/Offices	Administrative Office Lighting	315	7	2	EA	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	

Building:	Building C
Category:	ROOM

Group	Sub Group	Item	Location	Rank C	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	14	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		7	14	LF	\$0	
Casework	Classroom	Casework		7	14	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	22	LF	\$0	
Casework	Classroom	Casework		5	40	LF	\$7,150	
Casework	Classroom	Casework		7	200	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	70	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	35	LF	\$0	
Casework	Classroom	Casework				LF	\$0	

Building:	Building C
Category:	ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Ceiling	Classroom	Exposed Ceiling		7	1,520	SF	\$0
Ceiling	Classroom	Exposed Ceiling		7	2,992	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	387	SF	\$830
Ceiling	Classroom	Lay-In/Drop		6	387	SF	\$830
Ceiling	Classroom	Lay-In/Drop		6	910	SF	\$1,952
Ceiling	Classroom	Lay-In/Drop		6	1,520	SF	\$3,260
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		6	524	SF	\$1,124
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		6	548	SF	\$1,175
Ceiling	Classroom	Lay-In/Drop		6	548	SF	\$1,175
Ceiling	Classroom	Lay-In/Drop		6	548	SF	\$1,175
Ceiling	Classroom	Lay-In/Drop		6	548	SF	\$1,175
Ceiling	Classroom	Lay-In/Drop		7	1,810	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	987	SF	\$2,117
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		7	580	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		6	910	SF	\$1,952
Ceiling	Classroom	Lay-In/Drop		7	580	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	610	SF	\$1,308
Ceiling	Classroom	Lay-In/Drop		7	1,050	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	400	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	1,329	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	1,020	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	366	SF	\$785
Ceiling	Classroom	Lay-In/Drop		6	366	SF	\$785
Ceiling	Classroom	Lay-In/Drop		7	950	SF	\$O
Ceiling	Classroom	Lay-In/Drop		7	1,600	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	869	SF	\$O
Ceiling	Classroom	Lay-In/Drop		6	1,520	SF	\$3,260
Ceiling	Classroom	Lay-In/Drop		6	737	SF	\$1,581
Ceiling	Classroom	Lay-In/Drop		6	775	SF	\$1,662
Ceiling	Classroom	Lay-In/Drop		7	950	SF	\$0

Building:	Building C
Category:	ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Ceiling	Classroom	Lay-In/Drop		7	1,520	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	1,520	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	2,048	SF	\$O
Ceiling	Classroom	Lay-In/Drop		7	1,655	SF	\$O
Ceiling	Classroom	Lay-In/Drop		6	775	SF	\$1,662
Ceiling	Classroom	Lay-In/Drop		6	737	SF	\$1,581
Ceiling	Classroom	Lay-In/Drop		6	737	SF	\$1,581
Ceiling	Classroom	Lay-In/Drop		6	737	SF	\$1,581
Ceiling	Classroom	Lay-In/Drop		6	737	SF	\$1,581
Ceiling	Classroom	Lay-In/Drop		6	737	SF	\$1,581
Ceiling	Classroom	Lay-In/Drop		7	869	SF	\$O
Ceiling	Classroom	Lay-In/Drop		6	775	SF	\$1,662
Ceiling	Classroom	Lay-In/Drop		6	460	SF	\$987
Ceiling	Classroom	Lay-In/Drop		6	775	SF	\$1,662
Ceiling	Classroom	Lay-In/Drop		6	580	SF	\$1,244
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		7	610	SF	\$O
Ceiling	Classroom	Lay-In/Drop		6	610	SF	\$1,308
Ceiling	Classroom	Lay-In/Drop		6	610	SF	\$1,308
Ceiling	Classroom	Lay-In/Drop		6	987	SF	\$2,117
Ceiling	Classroom	Lay-In/Drop		6	610	SF	\$1,308
Ceiling	Classroom	Lay-In/Drop		6	737	SF	\$1,581
Ceiling	Classroom	Lay-In/Drop		6	666	SF	\$1,429
Ceiling	Classroom	Lay-In/Drop		7	1,055	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	460	SF	\$0
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4		LF	

Building:	Building C
Category:	ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Re	eason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	3	LF	\$365	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	17	LF	\$2,066	
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	113 faculty dining room	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	3	LF	\$365	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	17	LF	\$2,066	
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	3	LF	\$365	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
CLASSROOM	Classroom	Eye Wash Station		7	1	EA	\$0
CLASSROOM	Classroom	Science Lab Elements		7	12	SF	\$0
CLASSROOM	Classroom	Science Lab Elements		7	12	SF	\$0
CLASSROOM	Classroom	Science Lab Elements		7	1	SF	\$0
CLASSROOM	Classroom	Science Lab Elements		7	22	SF	\$0
CLASSROOM	Classroom	Science Lab Elements		7	12	SF	\$O
CLASSROOM	Classroom	Science Lab Elements		7	1	SF	\$0
Corridors	Corridors	Asphalt	Stair 4	6	566	SF	\$809
Corridors	Corridors	Asphalt	Stair 2	6	566	SF	\$809
Corridors	Corridors	Asphalt	Stair 1	6	566	SF	\$809
Corridors	Corridors	Asphalt	Stair 3	6	566	SF	\$809
Corridors	Corridors	Concrete Block	Stair 1	7	2,880	SF	\$0
Corridors	Corridors	Concrete Block	Stair 2	7	2,880	SF	\$0
Corridors	Corridors	Concrete Block	Stair 3	7	2,880	SF	\$0
Corridors	Corridors	Concrete Block	Basement Stair(West)	7	1,985	SF	\$0
Corridors	Corridors	Concrete Block	1st Floor	6	10,000	SF	\$28,600
Corridors	Corridors	Concrete Block	3rd Floor	7	11,540	SF	\$0
Corridors	Corridors	Concrete Block	Basement	7	4,370	SF	\$0
Corridors	Corridors	Concrete Block	Basement Stair(East)	7	1,985	SF	\$0
Corridors	Corridors	Concrete Block	Stair 4	7	2,880	SF	\$0
Corridors	Corridors	Concrete Block	2nd Floor	7	10,820	SF	\$0
Corridors	Corridors	Concrete Epoxy/Painted	Vestibules	6	520	SF	\$2,454
Corridors	Corridors	Concrete Epoxy/Painted	Basement Stair(West)	7	555	SF	\$0
Corridors	Corridors	Concrete Epoxy/Painted	Basement Stair(East)	7	555	SF	\$0
Corridors	Corridors	Concrete Epoxy/Painted	Basement	7	1,660	SF	\$0
Corridors	Corridors	Drinking Fountains	Basement			EA	\$0
Corridors	Corridors	Drinking Fountains	Stair 1			EA	\$0
Corridors	Corridors	Drinking Fountains	Stair 4			EA	\$0

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Corridors	Corridors	Drinking Fountains	Vestibules			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 3			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 2			EA	\$0	
Corridors	Corridors	Drinking Fountains	Basement Stair(West)			EA	\$ 0	
Corridors	Corridors	Drinking Fountains	Basement Stair(East)			EA	\$ 0	
Corridors	Corridors	Drop/Lay-In	3rd Floor	7	7,494	SF	\$ 0	
Corridors	Corridors	Drop/Lay-In	Stair 2	6	387	SF	\$830	
Corridors	Corridors	Drop/Lay-In	Stair 3	6	387	SF	\$830	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	5,582	SF	\$ 0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	9,268	SF	\$ 0	
Corridors	Corridors	Drop/Lay-In	Stair 1	6	387	SF	\$830	
Corridors	Corridors	Exposed	Basement	7	1,660	SF	\$O	
Corridors	Corridors	Lay-In	Stair 3	7	387	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	5,582	EA	\$0	
Corridors	Corridors	Lay-In	Stair 2	7	387	EA	\$0	
Corridors	Corridors	Lay-In	3rd Floor	7	7,494	EA	\$0	
Corridors	Corridors	Lay-In	Stair 1	7	387	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	6	9,268	EA	\$6,627	
Corridors	Corridors	Lighting	1st Floor	6	632	EA	\$58,744	
Corridors	Corridors	Lighting	Vestibules	6	520	EA	\$48,334	
Corridors	Corridors	Pendant/Surface	Basement Stair(East)	7	3	EA	\$0	
Corridors	Corridors	Pendant/Surface	Basement Stair(West)	7	3	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 2	7	285	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 4	7	672	EA	\$0	
Corridors	Corridors	Pendant/Surface	Basement	7	1,660	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 1	7	285	EA	\$ 0	
Corridors	Corridors	Pendant/Surface	Stair 3	7	285	EA	\$ 0	
Corridors	Corridors	Plaster/Drywall	Vestibules	6	460	SF	\$1,085	
Corridors	Corridors	Plaster/Drywall	2nd Floor	7	450	SF	\$0	
Corridors	Corridors	Plaster/Drywall	3rd Floor	7	300	SF	\$O	
Corridors	Corridors	Single Water Cooler	1st Floor	7	4	EA	\$0	
Corridors	Corridors	Single Water Cooler	3rd Floor	7	2	EA	\$O	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	4	EA	\$ 0	
Corridors	Corridors	Stair Handrails	Stair 1	6	144	LF	\$0	
Corridors	Corridors	Stair Handrails	Basement Stair(East)	7	23	LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Basement			LF	\$0	

Group	Sub Group	ltem	Location	Rank	Quantity	Unit	Cost Reason
Corridors	Corridors	Stair Handrails	Basement Stair(West)	7	23	LF	\$0
Corridors	Corridors	Stair Handrails	Vestibules			LF	\$0
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0
Corridors	Corridors	Stair Handrails	Stair 2	6	144	LF	\$0
Corridors	Corridors	Stair Handrails	Stair 4	6	144	LF	\$0
Corridors	Corridors	Stair Handrails	Stair 3	6	144	LF	\$0
Corridors	Corridors	Stairs	Basement			EA	\$0
Corridors	Corridors	Stairs	Basement Stair(East)	7	21	EA	\$0
Corridors	Corridors	Stairs	Vestibules			EA	\$0
Corridors	Corridors	Stairs	2nd Floor			EA	\$0
Corridors	Corridors	Stairs	3rd Floor			EA	\$0
Corridors	Corridors	Stairs	Basement Stair(West)	7	21	EA	\$0
Corridors	Corridors	Stairs	1st Floor			EA	\$0
Corridors	Corridors	Student Lockers	Basement			EA	\$0
Corridors	Corridors	Student Lockers	Basement Stair(East)			EA	\$0
Corridors	Corridors	Student Lockers	Vestibules			EA	\$0
Corridors	Corridors	Student Lockers	1st Floor	6	175	EA	\$25,025
Corridors	Corridors	Student Lockers	3rd Floor	6	446	EA	\$63,778
Corridors	Corridors	Student Lockers	Stair 4			EA	\$0
Corridors	Corridors	Student Lockers	Stair 3			EA	\$0
Corridors	Corridors	Student Lockers	Stair 2			EA	\$0
Corridors	Corridors	Student Lockers	Stair 1			EA	\$0
Corridors	Corridors	Student Lockers	2nd Floor	6	236	EA	\$33,748
Corridors	Corridors	Student Lockers	Basement Stair(West)			EA	\$0
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	6	7,494	SF	\$10,716
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	5,582	SF	\$7,982
Corridors	Corridors	Tile/Sheet Flooring	Stair 4	6	431	SF	\$616
Corridors	Corridors	Tile/Sheet Flooring	Stair 3	6	431	SF	\$616
Corridors	Corridors	Tile/Sheet Flooring	Stair 2	6	431	SF	\$616
Corridors	Corridors	Tile/Sheet Flooring	Stair 1	6	431	SF	\$616
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	7,500	SF	\$10,725
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	4	2,400	SF	\$33,977 uneven, missing material
Corridors Ceiling	Corridors	Plaster/Drywall	Basement Stair(East)	7	471	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 3	7	285	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	Vestibules	6	520	SF	\$1,472
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	632	SF	\$0

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 2	7	285	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 4	7	672	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	Basement Stair(West)	7	471	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 1	7	285	SF	\$O
Stairs	Corridors	Asphalt	Stair 4	6	48	SF	\$343
Stairs	Corridors	Asphalt	Stair 1	6	48	SF	\$343
Stairs	Corridors	Asphalt	Stair 2	6	48	SF	\$343
Stairs	Corridors	Asphalt	Stair 3	6	48	SF	\$343
Floor	Classroom	Carpet		6	775	SF	\$1,108
Floor	Classroom	Carpet		7	460	SF	\$O
Floor	Classroom	Carpet		6	548	SF	\$784
Floor	Classroom	Carpet		6	548	SF	\$784
Floor	Classroom	Concrete		7	2,992	SF	\$0
Floor	Classroom	Floor		7	524	SF	\$O
Floor	Classroom	Floor		7	1,520	SF	\$O
Floor	Classroom	Floor			1,050	SF	\$0
Floor	Classroom	Floor		7	737	SF	\$O
Floor	Classroom	Floor		7	1,520	SF	\$O
Floor	Classroom	Tile/Sheet		7	737	SF	\$O
Floor	Classroom	Tile/Sheet		7	666	SF	\$O
Floor	Classroom	Tile/Sheet		7	666	SF	\$O
Floor	Classroom	Tile/Sheet		7	666	SF	\$O
Floor	Classroom	Tile/Sheet		6	910	SF	\$1,301
Floor	Classroom	Tile/Sheet		7	737	SF	\$O
Floor	Classroom	Tile/Sheet		7	548	SF	\$0
Floor	Classroom	Tile/Sheet		7	737	SF	\$0
Floor	Classroom	Tile/Sheet		7	548	SF	\$0
Floor	Classroom	Tile/Sheet		7	737	SF	\$0
Floor	Classroom	Tile/Sheet		6	737	SF	\$1,054
Floor	Classroom	Tile/Sheet		7	1,520	SF	\$0
Floor	Classroom	Tile/Sheet		7	737	SF	\$0
Floor	Classroom	Tile/Sheet		7	387	SF	\$0
Floor	Classroom	Tile/Sheet		7	666	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,055	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,810	SF	\$0
Floor	Classroom	Tile/Sheet		7	666	SF	\$0
Floor	Classroom	Tile/Sheet		7	2,048	SF	\$0

Building:	Building C
Category:	ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Floor	Classroom	Tile/Sheet		7	666	SF	\$0
Floor	Classroom	Tile/Sheet		7	580	SF	\$0
Floor	Classroom	Tile/Sheet		7	387	SF	\$0
Floor	Classroom	Tile/Sheet		7	366	SF	\$0
Floor	Classroom	Tile/Sheet		6	610	SF	\$872
Floor	Classroom	Tile/Sheet		6	610	SF	\$872
Floor	Classroom	Tile/Sheet		7	666	SF	\$0
Floor	Classroom	Tile/Sheet		7	910	SF	\$0
Floor	Classroom	Tile/Sheet		7	987	SF	\$0
Floor	Classroom	Tile/Sheet		6	610	SF	\$872
Floor	Classroom	Tile/Sheet		6	869	SF	\$1,243
Floor	Classroom	Tile/Sheet		7	580	SF	\$0
Floor	Classroom	Tile/Sheet		6	610	SF	\$872
Floor	Classroom	Tile/Sheet		7	400	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,329	SF	\$0
Floor	Classroom	Tile/Sheet		7	775	SF	\$0
loor	Classroom	Tile/Sheet		7	366	SF	\$0
Floor	Classroom	Tile/Sheet		7	775	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,655	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,600	SF	\$0
Floor	Classroom	Tile/Sheet		7	580	SF	\$0
Floor	Classroom	Tile/Sheet		7	950	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,520	SF	\$0
Floor	Classroom	Tile/Sheet		7	950	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,520	SF	\$0
loor	Classroom	Tile/Sheet		6	775	SF	\$1,108
Floor	Classroom	Tile/Sheet		6	869	SF	\$1,243
Floor	Classroom	Tile/Sheet		7	666	SF	\$0
Floor	Classroom	Tile/Sheet		7	460	SF	\$0
Floor	Classroom	Tile/Sheet		7	610	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,020	SF	\$0
Floor	Classroom	Tile/Sheet		7	666	SF	\$0
Floor	Classroom	Tile/Sheet		7	987	SF	\$0
Floor	Classroom	Tile/Sheet		7	666	SF	\$0
KITCHEN_FLOOR	Cooking Kitchen	Kitchen Floor	1st Floor	7	2,543	SF	\$0
LIBRARY_CEILING	Library	Drop/Lay-In	2nd Floor	7	7,750	SF	\$0
LIBRARY_WALL	Library	Concrete Block	2nd Floor	7	3,500	SF	\$0

Building:	Building C
Category:	ROOM

Group	Sub Group	Item	Location R	ank	Quantity	Unit	Cost Reason
Lighting	Classroom	Lay-In		7	9	EA	\$O
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$O
Lighting	Classroom	Lay-In		7	9	EA	\$O
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	18	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$O
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$O
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$O
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$O
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$O
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	18	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$O
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$O
Lighting	Classroom	Lay-In		7	18	EA	\$0
Lighting	Classroom	Lay-In		7	11	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	18	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$0
Lighting	Classroom	Lay-In		7	2	EA	\$O
Lighting	Classroom	Lay-In		7	2	EA	\$O
Lighting	Classroom	Lay-In		7	3	EA	\$O
Lighting	Classroom	Lay-In		7	12	EA	\$0

Building:	Building C
Category:	ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Lighting	Classroom	Lay-In		7	22	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$0
Lighting	Classroom	Lay-In		7	2	EA	\$0
Lighting	Classroom	Lay-In		7	10	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$0
Lighting	Classroom	Lay-In		7	6	EA	\$0
₋ighting	Classroom	Lay-In		7	10	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	2	EA	\$0
Lighting	Classroom	Lay-In		7	23	EA	\$0
₋ighting	Classroom	Lay-In		7	21	EA	\$0
_ighting	Classroom	Lay-In		7	30	EA	\$0
ighting	Classroom	Lay-In		7	30	EA	\$0
_ighting	Classroom	Lay-In		7	18	EA	\$0
_ighting	Classroom	Lay-In		7	18	EA	\$0
ighting	Classroom	Lay-In		7	17	EA	\$0
_ighting	Classroom	Lighting		7	5	EA	\$0
ighting	Classroom	Lighting		7	6	EA	\$0
ighting	Classroom	Lighting		7	17	EA	\$0
ighting	Classroom	Lighting		7	5	EA	\$0
ighting	Classroom	Pendant/Surface		7	54	EA	\$0
Lighting	Classroom	Pendant/Surface		7	4	EA	\$0
_ighting	Classroom	Pendant/Surface		7	3	EA	\$0
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287
Marker Board	Lunchroom	Marker Board	113 faculty dining room			LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	23	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	7	LF	\$0
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0

Group	Sub Group	Item	Location	Rank Q	uantity	Unit	Cost Reason
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	7	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	7	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		7	7	LF	\$O
Marker Board	Classroom	Marker Board		7	9	LF	\$O
Marker Board	Classroom	Marker Board		7	17	LF	\$O
Marker Board	Classroom	Marker Board		7	7	LF	\$O
Marker Board	Classroom	Marker Board		7	7	LF	\$O
Marker Board	Classroom	Marker Board		7	17	LF	\$O
Marker Board	Classroom	Marker Board		7	7	LF	\$O
Marker Board	Classroom	Marker Board		7	17	LF	\$O
Marker Board	Classroom	Marker Board		6	7	LF	\$200
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		7	14	LF	\$O
Marker Board	Classroom	Marker Board		7	7	LF	\$O
Marker Board	Classroom	Marker Board		7	7	LF	\$O
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		7	17	LF	\$0
Marker Board	Classroom	Marker Board		6	17	LF	\$486
Marker Board	Classroom	Marker Board		6	17	LF	\$486

Group	Sub Group	Item	Location	Rank G	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	17	LF	\$0	
Marker Board	Classroom	Marker Board		6	7	LF	\$200	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	7	LF	\$0	
Marker Board	Classroom	Marker Board		7	17	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	17	LF	\$0	
Marker Board	Classroom	Marker Board		7	17	LF	\$0	
Marker Board	Classroom	Marker Board		7	17	LF	\$0	
Marker Board	Classroom	Marker Board		7	17	LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	3rd FL - Men		94	SF	\$0	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	2nd FL - Men		94	SF	\$0	
RESTROOM_LIGHT	Adult Standard Student Restroom	Restroom Lighting	2nd FL - Girls (East)	7	3	EA	\$0	
RESTROOM_LIGHT	Adult Standard Student Restroom	Restroom Lighting	3rd FL - Girls (West)	7	3	EA	\$0	
RESTROOM_LIGHT	Adult Standard Student Restroom	Restroom Lighting	3rd FL - Girls (East)	7	3	EA	\$0	
Wall	Classroom	Concrete Block		7	1,150	SF	\$0	
Wall	Classroom	Concrete Block		7	1,200	SF	\$0	
Wall	Classroom	Concrete Block		7	900	SF	\$0	
Wall	Classroom	Concrete Block		6	750	SF	\$2,145	
Wall	Classroom	Concrete Block		6	1,000	SF	\$2,860	
Wall	Classroom	Concrete Block		6	750	SF	\$2,145	
Wall	Classroom	Concrete Block		6	750	SF	\$2,145	
Wall	Classroom	Concrete Block		6	1,050	SF	\$3,003	
Wall	Classroom	Concrete Block		6	1,600	SF	\$4,576	
Wall	Classroom	Concrete Block		6	1,050	SF	\$3,003	
Wall	Classroom	Concrete Block		7	600	SF	\$0	
Wall	Classroom	Concrete Block		6	750	SF	\$2,145	
Wall	Classroom	Concrete Block		5	1,000	SF	\$7,550	step cracking
Wall	Classroom	Concrete Block		5	1,050	SF	\$7,928	Step cracking
Wall	Classroom	Concrete Block		7	1,050	SF	\$0	
Wall	Classroom	Concrete Block		6	1,000	SF	\$2,860	
Wall	Classroom	Concrete Block		6	1,000	SF	\$2,860	
Wall	Classroom	Concrete Block		6	1,050	SF	\$3,003	
Wall	Classroom	Concrete Block		7	1,800	SF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		6	1,000	SF	\$2,860	
Wall	Classroom	Concrete Block		6	1,000	SF	\$2,860	
Wall	Classroom	Concrete Block		6	1,000	SF	\$2,860	
Wall	Classroom	Concrete Block		7	700	SF	\$0	
Wall	Classroom	Concrete Block		6	1,000	SF	\$2,860	
Wall	Classroom	Concrete Block		7	750	SF	\$0	
Wall	Classroom	Concrete Block		6	850	SF	\$2,431	
Wall	Classroom	Concrete Block		7	1,920	SF	\$0	
Wall	Classroom	Concrete Block		5	1,000	SF	\$7,550	step cracking
Wall	Classroom	Concrete Block		7	1,200	SF	\$0	
Wall	Classroom	Concrete Block		7	2,500	SF	\$0	
Wall	Classroom	Concrete Block		6	750	SF	\$2,145	
Wall	Classroom	Concrete Block		6	750	SF	\$2,145	
Wall	Classroom	Concrete Block		6	750	SF	\$2,145	
Wall	Classroom	Concrete Block		5	600	SF	\$4,530	step cracking
Wall	Classroom	Concrete Block		7	860	SF	\$0	
Wall	Classroom	Concrete Block		7	1,600	SF	\$0	
Wall	Classroom	Concrete Block		7	1,500	SF	\$0	
Wall	Classroom	Concrete Block		7	1,280	SF	\$0	
Wall	Classroom	Concrete Block		7	770	SF	\$0	
Wall	Classroom	Concrete Block		7	650	SF	\$0	
Wall	Classroom	Concrete Block		7	1,500	SF	\$0	
Wall	Classroom	Concrete Block		7	800	SF	\$0	
Wall	Classroom	Concrete Block		7	700	SF	\$0	
Wall	Classroom	Concrete Block		7	1,600	SF	\$0	
Wall	Classroom	Concrete Block		7	1,050	SF	\$0	
Wall	Classroom	Concrete Block		7	550	SF	\$0	
Wall	Classroom	Concrete Block		7	880	SF	\$0	
Wall	Classroom	Concrete Block		7	700	SF	\$0	
Wall	Classroom	Concrete Block		7	880	SF	\$0	
Wall	Classroom	Concrete Block		6	1,000	SF	\$2,860	
Wall	Classroom	Concrete Block		7	1,500	SF	\$0	
Wall	Classroom	Concrete Block		7	900	SF	\$0	
Wall	Classroom	Concrete Block		7	1,600	SF	\$0	
Wall	Classroom	Concrete Block		7	1,000	SF	\$0	
Wall	Classroom	Concrete Block		7	900	SF	\$0	
Wall	Classroom	Concrete Block		7	700	SF	\$0	

Doors

Doors

Doors

Doors

Entrance

Assessment Date: 5/1/2013

2150 S Laflin St Chicago, IL 60608

Building: Building C Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	1,000	SF	\$0	
Wall	Classroom	Concrete Block		7	1,000	SF	\$0	
Wall	Classroom	Concrete Block		5	1,150	SF	\$8,683	step cracking above marker board
Wall	Classroom	Concrete Block		7	750	SF	\$0	
Wall	Classroom	Concrete Block		7	1,000	SF	\$0	
Wall	Classroom	Concrete Block		7	1,050	SF	\$0	
Wall	Classroom	Metal/Folding Panel		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	330	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	200	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	330	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	300	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	120	SF	\$0	
Wall	Classroom	Wall		7	1,675	SF	\$0	
			RC	OOM Sub Tot	al		\$551,232	
			Building Building	C Sub Tota	al		\$4,257,911	
Building: Buile Category: EXT	ding D ERIOR							
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Metal Flue	Main Roof	6	5	LF	\$322	corroded
Ormitiney								

Entire Building

Entire Building

Entire Building

East Entrances

E connector

6

6

7

6

7

10

6

4

18

92

ΕA

ΕA

ΕA

ΕA

LF

\$3,303

\$1,359

\$5,097

\$0

\$0

Exterior Steel Door

Store Front Door

Concrete Exterior Stairs

Transom Lite

Side Lite

Building: Building D Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Foundation		Concrete Foundation	Entire Building	7	745	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	3	EA	\$644	
Lighting		Exterior Lights - Wall Mounted	Entire Building	5	4	EA	\$2,002	
Lintels		Lintels - Steel	Entire Building	7	86	LF	\$0	
Parapet		Coping - Metal	main and low roofs	6	935	LF	\$0	corroded
Roof System		Asphalt Gravel Ballast Roof	Roof	6	31,500	SF	\$200,901	
Roof System		Interior Downspouts	Entire Building	6	184	LF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Top	pping Roof	7	31,500	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	39,200	SF	\$0	
Walls		Concrete Block	condensate pipe	4	4	SF	\$189	eroded
Walls		Concrete Block	NE and NW facade	5	530	SF	\$10,232	vertical crack, half painted concrete
Walls		Concrete Block	Entire Building	6	9,700	SF	\$64,084	concrete ribs are worn
Walls		Prefabricated Metal Panel Wall	base at SE	5	250	SF	\$7,150	bent and corroded
Walls		Prefabricated Metal Panel Wall	N and S and cornice	6	10,745	SF	\$91,270	metal panel rainscreen with CMU backup
Walls		Stucco	base of E and W	6	2,800	SF	\$20,020	
Walls		Stucco	West Façade	5	20	SF	\$429	hole
Windows		Storefront Windows	E 1 story connector	7	220	SF	\$0	
Windows		Windows - Sash Lexan	E and W facade	4	248	SF	\$42,833	
WINDOWS		Windows - Gash Eckan			-	01	\$457.404	

EXTERIOR Sub Total

\$457,184

Building: Building D Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	3,106	SF	\$1,332	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	2,000	SF	\$1,058	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	1,940	SF	\$1,026	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	2,000	SF	\$1,058	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	5	EA	\$536	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	4	EA	\$429	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	7	2	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	2	EA	\$215	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	4	9	EA	\$8,366	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose room	s 1st Floor	4	2	EA	\$1,859	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose room	s 1st Floor	3	1	EA	\$930	NON FUNCTIONAL
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose room	s 1st Floor	4	4	EA	\$3,718	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose room	s 1st Floor	7	2	EA	\$0	

Assessment Date: 5/1/2013

Building: Building D Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Public Announcement System	1st Floor	4	256,400	SF	\$909,297	
Emergency System		Security System - CCTV	1st Floor	4	256,400	SF	\$1,833,260	
Emergency System		Security System - Intrusion detection	1st Floor	6	197,800	SF	\$183,855	
Power Distribution		Lighting and power panels	Entire Building	6	3	EA	\$2,145	
Power Distribution		Main distribution panels 400-600 amp	Entire Building	6	1	EA	\$1,430	
			ELECTR	ICAL Sub To	tal		\$2,950,514	
Building: Building Category: FIRE Pl	0							
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	39,200	SF	\$0	
							A A	
Building: Buildin	-		FIRE PROTEC	TION Sub To	tal		\$0	
Category: MECHA	-	ltem	FIRE PROTEC		Quantity	Unit	\$0 Cost	Reason
Category: MECHA Group	NICAL	Item Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons				Unit EA		Reason
Category: MECHA Group Air Handling Systems	NICAL	Roof Top Unit - Single Zone - Gas-Heating 11 to	Location	Rank	Quantity		Cost	Reason
Category: MECHA Group Air Handling Systems Air Handling Systems	NICAL	Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 11 to	Location Roof	Rank	Quantity 1	EA	Cost \$25,740	Reason
Category: MECHA Group Air Handling Systems Air Handling Systems Air Handling Systems	NICAL	Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 31 to	Location Roof Roof	Rank 5 5	Quantity 1	EA EA	Cost \$25,740 \$25,740	Reason
Building: Building Category: MECHA Group Air Handling Systems Air Handling Systems Air Handling Systems Heating Devices Heating Devices	NICAL	Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 31 to 45 tons	Location Roof Roof Roof	Rank 5 5 7	Quantity 1 1	EA EA EA	Cost \$25,740 \$25,740 \$25,740 \$0	Reason
Category: MECHA Group Air Handling Systems Air Handling Systems Air Handling Systems Heating Devices Heating Devices	NICAL	Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 31 to 45 tons Fin Tube Hot Water	Location Roof Roof Roof Entire Building	Rank 5 5 7 7	Quantity 1 1 1 40	EA EA EA LF	Cost \$25,740 \$25,740 \$0 \$0	Reason
Category: MECHA Group Air Handling Systems Air Handling Systems Air Handling Systems Heating Devices Heating Devices Temperature Control	NICAL	Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 31 to 45 tons Fin Tube Hot Water Unit Heater - Electric	Location Roof Roof Roof Entire Building Entire Building	Rank 5 5 7 7 6	Quantity 1 1 1 40 2	EA EA EA LF EA	Cost \$25,740 \$25,740 \$0 \$0 \$2,860	Reason
Category: MECHA Group Air Handling Systems Air Handling Systems Air Handling Systems Heating Devices Heating Devices Temperature Control Unit Ventilation	NICAL	Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 31 to 45 tons Fin Tube Hot Water Unit Heater - Electric Thermostats - Direct Digital Control (DDC) Unit Ventilators - Self Contained Electric Heating	Location Roof Roof Roof Entire Building Entire Building Entire Building	Rank 5 5 7 7 6 6	Quantity 1 1 1 40 2 3	EA EA EA LF EA EA	Cost \$25,740 \$25,740 \$0 \$2,860 \$429	Reason
Category: MECHA Group Air Handling Systems Air Handling Systems Air Handling Systems Heating Devices	NICAL	Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons Roof Top Unit - Single Zone - Gas-Heating 31 to 45 tons Fin Tube Hot Water Unit Heater - Electric Thermostats - Direct Digital Control (DDC) Unit Ventilators - Self Contained Electric Heating and Cooling	Location Roof Roof Roof Entire Building Entire Building Entire Building Entire Building Entire Building	Rank 5 5 7 7 6 6 5	Quantity 1 1 1 40 2 3 2 2	EA EA LF EA EA EA	Cost \$25,740 \$25,740 \$0 \$0 \$2,860 \$429 \$17,160	Reason

Building: Building D Category: PLUMBING

•								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost R	eason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	5	39,200	SF	\$6,727	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	39,200	SF	\$12,893	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	5	39,200	SF	\$44,845	

Building: Building D Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	39,200	SF	\$8,408	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	39,200	SF	\$10,090	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	39,200	SF	\$34,755	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	5	39,200	SF	\$20,741	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	39,200	SF	\$21,301	
Piping		Sanitary Piping	Entire Building	6	39,200	SF	\$15,696	
Piping		Storm Piping	Entire Building	6	39,200	SF	\$8,408	
Piping		Vent Piping	Entire Building	6	39,200	SF	\$6,166	
Pool Systems		Pool Filtration System	1st Floor	5	1	EA	\$122,980	
Pool Systems		Pool Hot Water Heater - Gas Fired	1st Floor	6	2	EA	\$7,436	
Pool Systems		Pool Supply and Return Piping	1st Floor	5	300	LF	\$23,595	
Pool Systems		Pool Supply and Return Piping	1st Floor	5	300	LF	\$23,595	
			DI LIME		tal		\$367 636	

PLUMBING Sub Total

\$367,636

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Exposed	rm 021	6	260	SF	\$491	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	in girls locker room	7	145	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	in boys locker rm	7	145	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	rm 021	6	260	SF	\$1,227	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in girls locker room	5	145	SF	\$821	uneven- hard to open door
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in boys locker rm	7	145	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	in girls locker room	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	in boys locker rm	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	rm 021	6	3	SF	\$2	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	in girls locker room	6	320	SF	\$915	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 021	7	954	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	in boys locker rm	6	365	SF	\$1,044	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Steel Doors incl hw	Entire Building	6	28	EA	\$7,928	
Doors		Interior Steel Doors incl hw	Pool	7	5	EA	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	n Bleacher Seating	1st Floor	7	1,090	EA	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	m Ceiling - Exposed	1st Floor	7	1,055	SF	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	m Ceiling - Plaster/Drywall	1st Floor	7	885	SF	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	m Flooring - Tile/Sheet	1st Floor	6	885	SF	\$1,266	
Gymnasium / Auditorium	Competition Gymnasiur	m Flooring - Wood	1st Floor	6	1,055	SF	\$7,966	warped
Gymnasium / Auditorium	Competition Gymnasiur	m Lighting - Metal Halide/Sodium Vapor	1st Floor	7	56	EA	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	m Lighting - Pendant/Surface	1st Floor	7	4	EA	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	m Scoreboards	1st Floor	7	2	EA	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	m Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	m Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Competition Gymnasiur	m Walls - Concrete Block	1st Floor	7	14,242	SF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	Boys 1st fl	6	50	LF	\$286	
Locker/Shower Room	Locker/Shower Room	Benches	in office in girls gym office			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	2nd fl east old locker room used as an office			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	2nd fl west			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in office in boys locker rm			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	girls locker room 1st fl	4	62	LF	\$8,866	
Locker/Shower Room	Staff Restroom	Lockers	in office in boys locker rm			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	Boys 1st fl			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	2nd fl west	6	30	EA	\$1,472	
Locker/Shower Room	Locker/Shower Room	Lockers	girls locker room 1st fl	6	800	EA	\$39,262	
Locker/Shower Room	Locker/Shower Room	Lockers	girls locker room 1st fl	5	78	EA	\$12,633	
Locker/Shower Room	Locker/Shower Room	Lockers	in office in girls gym office	7	5	EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	2nd fl east old locker room used as an office	6	76	EA	\$3,730	
Locker/Shower Room	Locker/Shower Room	Showers	girls locker room 1st fl	6	12	EA	\$2,917	
Locker/Shower Room	Staff Restroom	Showers	in office in boys locker rm	7	1	EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	2nd fl east old locker room used as an office	5	5	EA	\$6,078	
Locker/Shower Room	Locker/Shower Room	Showers	in office in girls gym office	7	1	EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	Boys 1st fl	6	12	EA	\$2,917	
Locker/Shower Room	Locker/Shower Room	Showers	2nd fl west			EA	\$0	
Lunchroom	Multipurpose Room	Ceiling - Exposed	rm 023 weight rm	6	2,000	SF	\$3,775	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	rm 023 weight rm	6	28	SF	\$20	
Lunchroom	Multipurpose Room	Serving Line	rm 023 weight rm			LF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Multipurpose Room	Wall - Concrete Block	rm 023 weight rm	7	2,030	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	2	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Entire Building	6	2,653	SF	\$12,520	
Mechanical/Service Rooms		Storage Room	in pool room	6	74	SF	\$349	
Mechanical/Service Rooms		Storage Room	in boys locker rm	6	85	SF	\$401	
Staff Restroom	Staff Restroom	Accessories	in office in boys locker rm	6	90	SF	\$695	
Staff Restroom	Locker/Shower Room	Accessories	girls locker room 1st fl	6	1,929	SF	\$14,896	
Staff Restroom	Locker/Shower Room	Accessories	Boys 1st fl			SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	2nd fl west			SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	2nd fl east old locker room used as an office			SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	in office in girls gym office			SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in office in boys locker rm	6	90	SF	\$255	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	in office in girls gym office	7	125	SF	\$0	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	girls locker room 1st fl	6	1,929	SF	\$5,462	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	2nd fl west	7	515	SF	\$0	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	2nd fl east old locker room used as an office	5	745	SF	\$4,219	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	Boys 1st fl	6	1,510	SF	\$4,275	
Staff Restroom	Locker/Shower Room	Floor Drain	in office in girls gym office	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Floor Drain	girls locker room 1st fl	5	9	EA	\$13,514	
Staff Restroom	Staff Restroom	Floor Drain	in office in boys locker rm	5	1	EA	\$1,502	
Staff Restroom	Locker/Shower Room	Floor Drain	2nd fl west	6	3	EA	\$901	
Staff Restroom	Locker/Shower Room	Floor Drain	2nd fl east old locker room used as an office	6	2	EA	\$601	
Staff Restroom	Locker/Shower Room	Floor Drain	Boys 1st fl	5	10	EA	\$15,015	
Staff Restroom	Locker/Shower Room	Flooring - Concrete	Boys 1st fl	7	1,005	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Concrete	2nd fl east old locker room used as an office	6	745	SF	\$3,516	
Staff Restroom	Locker/Shower Room	Flooring - Concrete	2nd fl west	6	515	SF	\$2,430	
Staff Restroom	Locker/Shower Room	Flooring - Concrete	girls locker room 1st fl	6	1,929	SF	\$9,103	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in office in boys locker rm	6	90	SF	\$229	
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	in office in girls gym office	7	125	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	Boys 1st fl	6	505	SF	\$1,285	
Staff Restroom	Staff Restroom	Hand Dryer	in office in boys locker rm			EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	Boys 1st fl	7	4	EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	2nd fl east old locker room used as an office			EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	2nd fl west			EA	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Locker/Shower Room	Hand Dryer	girls locker room 1st fl	7	9	EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	in office in girls gym office			EA	\$0	
Staff Restroom	Locker/Shower Room	Lavatory	in office in girls gym office	6	1	EA	\$372	
Staff Restroom	Locker/Shower Room	Lavatory	2nd fl east old locker room used as an office	5	1	EA	\$1,859	
Staff Restroom	Locker/Shower Room	Lavatory	2nd fl west	6	1	EA	\$372	
Staff Restroom	Locker/Shower Room	Lavatory	girls locker room 1st fl	6	3	EA	\$1,115	
Staff Restroom	Staff Restroom	Lavatory	in office in boys locker rm	6	1	EA	\$372	
Staff Restroom	Locker/Shower Room	Lavatory	Boys 1st fl	6	2	EA	\$744	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	2nd fl east old locker room used as an office	4	3	SF	\$11	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	Boys 1st fl	6	17	SF	\$12	
Staff Restroom	Staff Restroom	Lighting - Lay-In	in office in boys locker rm	7	1	SF	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	girls locker room 1st fl	6	19	SF	\$14	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	in office in girls gym office	7	2	SF	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	2nd fl east old locker room used as an office	6	7	SF	\$5	
Staff Restroom	Locker/Shower Room	Lighting - Pendant/ Surface	Boys 1st fl	7	7	SF	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Pendant/ Surface	2nd fl west	6	6	SF	\$4	
Staff Restroom	Locker/Shower Room	Lighting - Pendant/ Surface	girls locker room 1st fl	6	7	SF	\$5	
Staff Restroom	Locker/Shower Room	Partitions	2nd fl west			EA	\$0	
Staff Restroom	Locker/Shower Room	Partitions	in office in girls gym office	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Partitions	girls locker room 1st fl	6	4	EA	\$717	
Staff Restroom	Locker/Shower Room	Partitions	Boys 1st fl	6	1	EA	\$179	
Staff Restroom	Locker/Shower Room	Partitions	2nd fl east old locker room used as an office	5	1	EA	\$572	
Staff Restroom	Staff Restroom	Partitions	in office in boys locker rm	5	2	EA	\$1,144	
Staff Restroom	Locker/Shower Room	Urinals	Boys 1st fl	6	1	EA	\$372	
Staff Restroom	Locker/Shower Room	Urinals	in office in girls gym office			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in office in boys locker rm	6	1	EA	\$372	
Staff Restroom	Locker/Shower Room	Urinals	2nd fl west	6	1	EA	\$372	
Staff Restroom	Locker/Shower Room	Urinals	2nd fl east old locker room used as an office	5	1	EA	\$1,859	
Staff Restroom	Locker/Shower Room	Urinals	girls locker room 1st fl			EA	\$0	
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	2nd fl west	7	710	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	2nd fl east old locker room used as an office	6	1,651	SF	\$4,722	
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	Boys 1st fl	6	3,095	SF	\$8,852	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in office in boys locker rm	6	370	SF	\$1,058	

Building: Building D Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost F	Reason
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	girls locker room 1st fl	6	2,620	SF	\$7,493	
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	in office in girls gym office	7	455	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Tile Ceramic/ Porcelain	girls locker room 1st fl	6	420	SF	\$1,069	
Staff Restroom	Locker/Shower Room	Wall - Tile Ceramic/ Porcelain	Boys 1st fl	7	550	SF	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	in office in girls gym office	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	2nd fl east old locker room used as an office	5	1	EA	\$1,859	
Staff Restroom	Locker/Shower Room	Water Closet	2nd fl west	6	1	EA	\$372	
Staff Restroom	Locker/Shower Room	Water Closet	Boys 1st fl	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Water Closet	in office in boys locker rm	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	girls locker room 1st fl	6	4	EA	\$1,487	
Swimming Pool		Accessories	Pool	7	7,098	SF	\$0	
Swimming Pool		Bleacher Seating/Plank seating	Pool	6	35	EA	\$495	
Swimming Pool		Floor Tile	1st Floor	7	3,500	SF	\$0	
Swimming Pool		Lighting Pendant - Metal Halide/ High Pressure Sodium	1st Floor	7	20	SF	\$0	
Swimming Pool		Paint	1st Floor	7	7,528	SF	\$0	
Swimming Pool		Pool Basin	1st Floor	7	3,598	SF	\$0	
Swimming Pool		Pool Deck	1st Floor	7	3,500	SF	\$0	
Swimming Pool		Pool deck drains	1st Floor	6	18	EA	\$6,692	
Swimming Pool		Splined Ceiling including access	1st Floor	7	7,098	SF	\$0	
Swimming Pool		Structural Glazed Tile	1st Floor	7	3,749	SF	\$0	
			INTERIOR Sub Total			\$240,097		

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	750	SF	\$1,609	
Ceiling	Classroom	Lay-In/Drop		6	750	SF	\$1,609	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Multipurpose Room	Chalk Board	rm 023 weight rm	4		LF		
Corridors	Corridors	Concrete Block	1st Floor	6	2,490	SF	\$7,121	
Corridors	Corridors	Concrete Block	2nd fl corridor including stair 1 and 2	7	6,954	SF	\$0	

Benito Juarez Community Academy High School

2150 S Laflin St Chicago, IL 60608

Group	Sub Group	ltem	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Concrete Epoxy/Painted	2nd fl corridor including stair 1 and 2	6	162	SF	\$764	
Corridors	Corridors	Drinking Fountains	2nd fl corridor including stair 1 and 2			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st Floor			EA	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	6	1,398	SF	\$2,999	
Corridors	Corridors	Lay-In	1st Floor	7	1,398	EA	\$0	
Corridors	Corridors	Lay-In	2nd fl corridor including stair 1 and 2	7	1,708	EA	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd fl corridor including stair 1 and 2	7	124	LF	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd fl corridor including stair 1 and 2	6	46	EA	\$329	
Corridors	Corridors	Student Lockers	2nd fl corridor including stair 1 and 2			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	7	26	EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2nd fl corridor including stair 1 and 2	7	1,432	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	1,398	SF	\$1,999	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd fl corridor including stair 1 and 2	7	1,708	SF	\$0	
Floor	Classroom	Tile/Sheet		6	750	SF	\$1,073	
Floor	Classroom	Tile/Sheet		5	750	SF	\$4,247	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
Lighting	Classroom	Lay-In		7	11	EA	\$0	
LUNCH_FLOOR	Multipurpose Room	Lunchroom Floor	rm 023 weight rm	7	2,000	SF	\$0	
Marker Board	Classroom	Marker Board		6	10	LF	\$286	
Marker Board	Classroom	Marker Board		6	10	LF	\$286	
Marker Board	Multipurpose Room	Marker Board	rm 023 weight rm			LF	\$0	
Wall	Classroom	Plaster/Drywall		6	180	SF	\$425	
Wall	Classroom	Plaster/Drywall		6	180	SF	\$425	
			ROOM	ROOM Sub Total			\$23,171	
			Building Building D Su	ıb Tot	al		\$4,121,470	

Building: SITE Category: SITE								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Building: SITE Category: SITE								
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Athletic		Baseball - Natural	Site - East	7	19,000	SF	\$0	
Athletic		Football/Soccer - Synthetic including exc and retention	Site ¿ North	7	68,256	SF	\$0	
Civil/Drainage		Bioswale	Site ¿ South	7	4,760	SF	\$0	
Civil/Drainage		Catch Basin	Entire Site	7	19	EA	\$0	
Civil/Drainage		Site Drain	site - W and W of bioswale	7	4	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	37	EA	\$0	
Fencing		Chain Link	site- W at backstop	7	38	LF	\$0	
Fencing		Chain Link	NW lot and generator	5	338	LF	\$12,084	
Fencing		Guard Rail	W at alley	7	291	LF	\$0	
Fencing		Ornamental Iron	Entire Site	7	3,014	LF	\$0	
Fencing		Ornamental Iron	Site ¿ South	6	217	LF	\$4,096	refinish
Fencing		Ornamental Iron	W side of NE lot	5	8	LF	\$498	
Fencing		Wood Fencing w/ Steel Frame	NE and parking lots	7	614	LF	\$0	
Fencing		Wood Fencing w/ Steel Frame	W trash enclosure	6	235	LF	\$2,883	refinish
Landscape		Benches	Entire Site	7	30	EA	\$0	
Landscape		Grass	Entire Site	7	115,900	SF	\$0	
Landscape		Grass	W plaza	4	6,684	SF	\$26,476	grass pave removed and replaced with gravel
Landscape		Hardscape - Concrete	Site ¿ West	4	100	SF	\$1,888	Cracked
Landscape		Hardscape - Concrete	Entire Site	7	44,700	SF	\$0	
Landscape		Hardscape - Pavers	Entire Site	7	26,465	SF	\$0	
Landscape		Hardscape - Pavers	gravel area in courtyard	4	100	SF	\$2,116	sinkhole
Landscape		Hardscape - Pavers	Courtyard	7	10,064	SF	\$0	
Landscape		Hardscape - Pavers	Site ¿ South	7	26,465	SF	\$0	
Landscape		Parkway trees	Entire Site	7	19,800	EA	\$0	
Landscape		Parkway trees	Entire Site	7	37	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	19,800	SF	\$0	
Landscape		Retaining Wall - Concrete	S at bioswale	7	600	SF	\$0	
Landscape		Trash Receptacles	Entire Site	7	14	EA	\$0	
Parking Lot		Asphalt	N and NE lots	7	58,234	SF	\$0	
Parking Lot		Concrete	site W	7	14,145	SF	\$0	
Parking Lot		Concrete Curbs	NE lots and W lot	7	2,066	LF	\$0	
Parking Lot		Parking lot interior plantings	NE lots	7	15	LF	\$0	

Building: SITE

Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Pavers	W parking lot	7	4,083	SF	\$0	
Parking Lot		Trash Compactor	Site ¿ West	6	1	EA	\$3,575	
Parking Lot		Trash Enclosure	Site ¿ West	6	544	SF	\$5,834	
Parking Lot		Vehicular Screening	NE and W lots	7	278	LF	\$0	
Sidewalks		Internal Walks	Entire Site	7	2,382	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	39,900	SF	\$0	
Signage		Flag Pole	South Courtyard	7	3	EA	\$0	
Signage		Monument Sign - Lighted	Site ¿ South	6	1	EA	\$0	Faded graffiti, was washed but can still see remnants
			S	SITE Sub To	tal		\$59,451	
			SITI	E Sub Tot	al		\$59,451	
Total Campus	Need ²³					\$	8,499,961	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.



Room Summary														
Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building:	Build	ing C		1			<u>. </u>							
120	2992	1		6	40	54	9		Ν	Ν	Y	Classroom		
122	1055		6	24	40	72	12		Ν	Ν	Ν	Classroom		
124	2048			20	40				Ν	Ν	Ν	Classroom		
125	1810				40	241	144		Ν	Ν	Ν	Classroom		
126	524		3	14	40	36	6		Ν	Ν	Y	Classroom		
132	950	0	8	36	40	72	12		Ν	Ν	N	Classroom		
133	950	0	8	36	40	72	12		Ν	Ν	Y	Classroom		
201	460	0	4	12	40	0	0		Ν	Ν	Ν	Classroom		
203	610	0	1	42	40	0	0	0	Ν	Ν	N	Classroom		
205	1050	1	32	64	40	160	0		Ν	Ν	Ν	Classroom		
206	400	0	2	14	40	54	9		Ν	Ν	Y	Classroom		
210	366			22	40	36	6		Ν	Ν	N	Classroom		
214	387	0	2	22	40	36	6	0	Ν	Ν	N	Classroom		
214	366			22	40	36	3		Ν	Ν	N	Classroom		
216	1020		7	24	40	90	15		Ν	Ν	Y	Classroom		
218	1329		4	16	40	126	21		Ν	Ν	N	Classroom		
221	987	0	32	70	40	160	0	0	Ν	Ν	Y	Classroom		
222	1655	1	6	26	40	144	24	0	Ν	Ν	N	Classroom		
223	987	0	32	70	40	160	0	0	Ν	Ν	Y	Classroom		
224	387	0	2	22	40	36	6	0	Ν	Ν	N	Classroom		
226	1520	1	7	32	40	72	12	0	Ν	Ν	Y	Classroom		
228	666	1	4	14	40	24	6	0	Ν	Ν	Y	Classroom		
230	775	0	6	14	40	72	12	0	Ν	Ν	Y	Classroom		
232	460	0	4	12	40	36	6	0	Ν	Ν	Y	Classroom		
234	610	0	1	22	40	54	9	0	Ν	Ν	Y	Classroom		
236	610	0	1	20	40	36	6	0	Ν	Ν	Y	Classroom		
238	610	0	1	20	40	36	6	0	Ν	Ν	Y	Classroom		
240	610	0	1	42	40	0	9	0	Ν	Ν	Ν	Classroom		
242	580	0		14	40	0	Ű	0	Ν	Ν	Y	Classroom		
246	869	1	12	34	40	108	18	0	Ν	Ν	Y	Classroom		
248	548	0	4	20	40	36	6	0	Ν	Ν	Y	Classroom		
250	548	0	4	20	40	36	6	0	Ν	Ν	Y	Classroom		
252	548	0	4	20	40	36	6	0	Ν	Ν	Y	Classroom		
300	580	0	6	14	40	80	0	0	Ν	Ν	Y	Classroom		
301	580	0	6	14	40	80	0	0	Ν	Ν	Y	Classroom		
303/305	1600	0	1	20	40	200	0	0	Ν	Ν	Y	Classroom		



Room Su	oom Summary													
Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet		Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
306	666	1	1	16	40	24	6	0	N	Ν	Y	Classroom		
307	737	1	4	14	40	80	0	0	N	N	Y	Classroom		
308	666	1	5	18	40	32	8	0	N	N	Y	Classroom		
309	737	1	5	12	40	96	0	0	N	N	Y	Classroom		
310	666	1	6	20	40	32	8	0	N	Ν	Y	Classroom		
311	737	1	6	18	40	80	0	0	N	N	Y	Classroom		
312	775	1	6	20	40	32	8	0	N	N	Y	Classroom		
314	775	1	3	16	40	24	6	0	N	N	Y	Classroom		
316	775	1	3	16	40	32	8	0	N	N	Y	Classroom		
319	1520	1	5	70	40	180	0	0	N	N	Y	Classroom		
321	737	1	6	64	40	60	0	0	N	Ν	Y	Classroom		
322	869	1	8	26	40	32	8	0	N	N	Y	Classroom		
324	737	1	6	18	40	32	8	0	N	N	Y	Classroom		
326	737	1	6	18	40	32	8	0	N	N	Y	Classroom		
328	737	1	6	16	40	32	8	0	N	N	Y	Classroom		
330	910	1	8	22	40	32	8	0	N	N	Y	Classroom		
334	666	1	4	14	40	24	6	0	N	N	Y	Classroom		
336	666	1	4	14	40	24	6	0	N	N	Y	Classroom		
338	666	1	4	14	40	24	6	0	N	N	Y	Classroom		
340	666	1	4	14	40	24	6	0	N	N	Y	Classroom		
342	666	1	4	14	40	24	6	0	N	N	Y	Classroom		
344	1520	1	4	70	40	32	8	0	N	N	Y	Classroom		
346	666	1	4	14	40	24	6	0	N	N	Y	Classroom		
348	548	0	1	8	40	0	0	0	N	N	Y	Classroom		
352	910	1	8	22	40	32	8	0	N	N	Y	Classroom		
354	1520	1	1	20	40	48	8	0	N	N	Y	Classroom		
356	1520	1	4	18	40	40	10	0	N	N	Y	Classroom		
Other	488			44					N	N	N	Administrative Suites/Offices		209
Other	100			4					N	Ν	Y	Administrative Suites/Offices		2nd Floor
Other	488			12					N	Ν	Ν	Administrative Suites/Offices		202
Other	380			10					N	Ν	Y	Administrative Suites/Offices		211
Other	303			4					N	Ν	Y	Administrative Suites/Offices		302
Other	220			8					N	Ν	Y	Administrative Suites/Offices		304
Other	303			4					N	Ν	Y	Administrative Suites/Offices		302
Other	265								N	Ν	Ν	Restroom	Adult Standard Student Restroom	3rd FL - Girls (East)
Other	215								N	Ν	Ν	Restroom	Staff Restroom	3rd FL - Women
Other	7750								N	N	N	Library		2nd Floor



Room Su	oom Summary													
Room Number	Room Size		Data Outlet			Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	488			44					N	Ν	Ν	Administrative Suites/Offices		Room 207
Other	184								N	Ν	Ν	Corridors		Basement Stair(West)
Other	94								Ν	Ν	Ν	Restroom	Staff Restroom	3rd FL - Men
Other	320			6					Ν	Ν	Y	Administrative Suites/Offices		350
Other	549			8					N	Ν	Y	Administrative Suites/Offices		3rd Floor
Other	100			4					N	Ν	Y	Administrative Suites/Offices		315
Other									Ν	Ν	Ν	Corridors		Stair 1
Other									N	Ν	Ν	Corridors		Stair 2
Other									N	Ν	Ν	Corridors		Stair 3
Other									N	Ν	Ν	Corridors		Stair 4
Other	5582								N	Ν	Ν	Corridors		2nd Floor
Other	7494								N	Ν	Ν	Corridors		3rd Floor
Other	9900								N	Ν	N	Corridors		1st Floor
Other	520								N	Ν	Ν	Corridors		Vestibules
Other	169								N	Ν	Ν	Restroom	Staff Restroom	kitchen womens
Other	169								N	Ν	Ν	Restroom	Staff Restroom	kitchen men
Other	150								N	Ν	Ν	Restroom	Staff Restroom	next to 120
Other	320			6					N	Ν	Y	Administrative Suites/Offices		320
Other	100			4					N	Ν	Y	Administrative Suites/Offices		317
Other	130								N	Ν	Ν	Restroom	Staff Restroom	Basement
Other	94								N	Ν	Ν	Restroom	Staff Restroom	2nd FL - Men
Other	215								N	Ν	Ν	Restroom	Staff Restroom	2nd FL - Women
Other	918								N	Ν	Ν	Lunch & Multipurpose Room	Lunchroom	113 faculty dining room
Other	2543								N	Ν	Ν	Kitchen	Cooking Kitchen	1st Floor
Other	100			4					N	Ν	Ν	Administrative Suites/Offices		kitchen office
Other	265								N	Ν	Ν	Restroom	Adult Standard Student Restroom	3rd FL - Girls (West)
Other	265								N	Ν	Ν	Restroom	Adult Standard Student Restroom	2nd FL - Girls (East)
Other	224								N	Ν	Ν	Restroom	Adult Standard Student Restroom	1st FL Boys
Other	193								N	Ν	Ν	Restroom	Adult Standard Student Restroom	1st FL Girls (East)
Other	1660								N	Ν	Ν	Corridors		Basement
Other	184								N	Ν	Ν	Corridors		Basement Stair(East)
Other	194			4					Ν	Ν	Ν	Administrative Suites/Offices		313
Other	100			4					N	Ν	Y	Administrative Suites/Offices		217
Other	11540								N	Ν	Ν	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	224								N	Ν	N	Restroom	Adult Standard Student Restroom	3rd FL - Boys
Other	100			4					N	Ν	Y	Administrative Suites/Offices		215
Other	100			4					N	Ν	Y	Administrative Suites/Offices		213

	Room Size	Voice	Data		r									
	Size		Data Outlet	Elect Outlet	Noise Level		Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	224								N	Ν	Ν	Restroom	Adult Standard Student Restroom	2nd FL Boys
Other	193								N	Ν	Ν	Restroom	Adult Standard Student Restroom	2nd FL Girls (West)
Other	649			8					Ν	Ν	Y	Administrative Suites/Offices		212
Other	320			6					Ν	Ν	Y	Administrative Suites/Offices		332
Other	2250			24					Ν	Ν	Y	Administrative Suites/Offices		Main Office
Other	1550			50					Ν	Ν	Y	Administrative Suites/Offices		Room 100
Other	25								Ν	Ν	Ν	Restroom	Staff Restroom	Room 100
Other	100			4					Ν	Ν	Y	Administrative Suites/Offices		219
Other	194			4					Ν	Ν	Ν	Administrative Suites/Offices		Room 211
·													•	
Building: E	Build	ing A/	/B											
113	727			12	40	54	24		Ν	Ν	Y	Classroom		
275	775	1	6	28	40	176	32		Ν	Ν	Ν	Classroom		
276	775	1	6	28	40	176	32		Ν	Ν	Y	Classroom		
277	775	1	6	28	40	176	32		Ν	Ν	Y	Classroom		
278	775	1	6	28	40	176	32		Ν	Ν	Y	Classroom		
279	775	1	6	28	40	176	32		Ν	Ν	Y	Classroom		
280	775	1	6	28	40	176	32		Ν	Ν	Y	Classroom		
300	600	1	5	14	40	16	4	0	Ν	Ν	Y	Classroom		
304	1452	2	8	18	40	8	2	0	Ν	Ν	Y	Classroom		
	1715	1	5	18	40	350	10		Ν	Ν	Ν	Classroom		
Room	1700		-	4.0	40	100	4.0					0		
Music Room	1769	1	5	18	40	420	10		Ν	Ν	Ν	Classroom		
	1406								Ν	Ν	Ν	Lunch & Multipurpose Room	Multipurpose Room	Scene Shop Rm 1131
Other	150								N	N	N	Corridors		Vestibule 0101
Other	3998								N	N	N	Corridors		Auditorium Lobby
Other	530								N	Ν	Ν	Restroom	Locker/Shower Room	Girls Dressing Room 1st fl
Other	530								N	Ν	Ν	Restroom	Locker/Shower Room	Boys Dressing Room 1st fl
Other	516								N	N	Ν	Lunch & Multipurpose Room	Multipurpose Room	Green Room 0126
Other	82								N	N	N	Restroom	Staff Restroom	1st fl mens
Other	100								N	Ν	Ν	Restroom	Staff Restroom	1st fl womens
Other	110			8					N	Ν	Y	Administrative Suites/Offices	1	rm 2213
Other	166								N	Ν	Ν	Corridors	1	Vestibule 0221
Other	606			40					N	Ν	Ν	Administrative Suites/Offices		Control and Sound Rooms
Other									N	Ν	Ν	Corridors	1	Stair 2
Other	250								N	Ν	Ν	Restroom	Adult Standard Student Restroom	1st floor boys
Other	312								N	Ν	Ν	Restroom	Adult Standard Student Restroom	1st floor girls



Other 312	lect No utlet Le	Noise Level \	Glaze								
Other 6998 Image: Constraint of the system Other 250 Image: Constraint of the system Image: Constraint of the system Other 104 Image: Constraint of the system Image: Constraint of the system Image: Constraint of the system Other 114 Image: Constraint of the system Image: Consystem Image: Consystem Image:		20101	Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Dither Dither Dither 250 Dither 104 Dither 104 Dither 114 Dither 181 Dither 3120 Dither 3120 Dither 240 Dither 8720 Dither 586 2 Building: Building D 225 Dither 260 2 Dither 515 2 Dither 1940 2 Dither 1708 2 <td></td> <td></td> <td></td> <td></td> <td></td> <td>N</td> <td>N</td> <td>Ν</td> <td>Restroom</td> <td>Adult Standard Student Restroom</td> <td>2nd floor girls</td>						N	N	Ν	Restroom	Adult Standard Student Restroom	2nd floor girls
Dther 250 Dther 104 Dther 104 Dther 312 Dther 114 Dther 181 Dther 74 Dther 3120 Dther 586 Dther 586 Dther 586 Dther 586 Dther 260 Dther 515 Dther 1940 Dther 1708						Ν	Ν	Ν	Corridors		2nd Floor
Dther 104 Image: Constraint of the state of the	\mp					Ν	Ν	Ν	Corridors		Stair 1
Dther 312 Image: Constraint of the state of the stat						Ν	Ν	Ν	Restroom	Adult Standard Student Restroom	2nd floor boys
Dther 114 Dther 181 Dther 74 Dther 3120 Dther 3120 Dther 240 Dther 260 Dther 515 Dther 515 Dther 1940 Dther 1708						Ν	Ν	Ν	Corridors		Stair 0149
Other 114 Image: constraint of the state						Ν	Ν	Ν	Corridors		Auditorium Vestibules
Dther 114 Dther 181 Dther 181 Dther 74 Dther 74 Dther 3120 Dther 149 Dther 149 Dther 240 Dther 240 Dther 240 Dther 586 Dther 586 Dther 586 Dther 25 Dther 260 Dther 515 Dther 1940 Dther 1708						Ν	Ν	Ν	Lunch & Multipurpose Room	Multipurpose Room	0112 Small Practice
Other 181 Other 181 Other 74 Other 3120 Other 3120 Other 149 Other 240 Other 240 Other 240 Other 586 Other 25 25 750 26 750 Other 515 Other 1940 Other 1708						Ν	Ν	Ν	Lunch & Multipurpose Room	Multipurpose Room	0114 Small Practice Room
Other 74 Other 74 Other 3120 Other 3120 Other 149 Other 149 Other 240 Other 240 Other 240 Other 240 Other 240 Other 250 Other 586 225 750 226 750 Other 260 Other 515 Other 1940 Other 1708 Other 2000 Other 1510						Ν	Ν	Ν	Lunch & Multipurpose Room	Multipurpose Room	0116 Small Practice Room
Other 74 Image: Constraint of the state						Ν	Ν	Ν	Corridors		Vestibule 0119
Other 3120 Other 149 Other 240 Other 240 Other 240 Other 200 Other 200 Other 200 Other 586 225 750 226 750 Other 515 Other 1940 Other 1708 Other 1510						Ν	Ν	Ν	Corridors		Catwalk Access 1
Dther 149 Dther 240 Dther 240 Dther 240 Dther 240 Dther 240 Dther 240 Dther 8720 Dther 586 2 Building: Building D 25 25 750 26 Dther 260 20 Dther 515 20 Dther 1940 20 Dther 1708 2000 Dther 1510 2000						Ν	Ν	Ν	Corridors		Vestibule 0109
Other 240 Dther 240 Dther 8720 Dther 586 2 Building: Building D 25 25 750 2 26 750 2 Dther 260 2 Dther 1940 2 Dther 1708 2 Dther 1510 2						Ν	Ν	Ν	Corridors		1st Floor
Other 8720 Other 8720 Other 586 2 Building: Building D 25 750 025 750 0 026 750 0 Other 260 0 Other 515 0 Other 1940 0 Other 1708 0 Other 1510 0	8					Ν	Ν	Ν	Administrative Suites/Offices		Ticket Office 0146
Building: Building D 025 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 750 2 026 751 2 026 1940 2 021 2 2 021 2 2 021 2 2 021 2 2 021 2 2 021 2 2						Ν	Ν	Ν	Corridors		Vestibule 0143
Dther 586 2 Building: Building D 25 750 26 025 750 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0						Ν	Ν	Ν	Corridors		Catwalk Access 2
Building: Building D 025 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 755 026 755 026 750 026 750 027 1708 028 1510						Ν	Ν	Ν	Auditorium & Theater	Auditorium - Dedicated	1st Floor
025 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 026 750 027 1940 028 0 029 0 029 0 029 0 029 0 029 0 029 0	26					N	Ν	N	Administrative Suites/Offices		rm 0115- office
D26 750 Image: Constraint of the state		40	35			N	N	Y	Classroom		1
Dther 260 Image: Constraint of the state of the stat	8 8	40 40	35 35			N N	N N		Classroom		
Other 515 Other 1940 Other 1708 Other 2000 Other 1510	8	40	35			N	N		Administrative Suites/Offices		rm 021
Dther 1940 Dther 1708 Dther 2000 Dther 1510	- 0						N			Leeker/Chevyer Deer	-
Other 1708 Other 2000 Other 1510	\rightarrow					N		N	Restroom	Locker/Shower Room	2nd fl west
Z000 Z000 Other 1510						N	N		Gymnasia	Competition Gymnasium	1st Floor
Dther 1510						Ν	Ν	Ν	Corridors		2nd fl corridor including stair 1 and 2
						Ν	Ν	Ν	Lunch & Multipurpose Room	Multipurpose Room	rm 023 weight rm
Othor 145						Ν	Ν	Ν	Restroom	Locker/Shower Room	Boys 1st fl
Juner 145	6					N	Ν	Y	Administrative Suites/Offices		in boys locker rm
Other 1398						Ν	Ν	Ν	Corridors		1st Floor
Other 90	+					N	Ν	Ν	Restroom	Staff Restroom	in office in boys locker rm
Other 1929	+					N	Ν	Ν	Restroom	Locker/Shower Room	girls locker room 1st fl
Other 145	6					N	Ν	Y	Administrative Suites/Offices		in girls locker room
Other 125						N	Ν	Ν	Restroom	Locker/Shower Room	in office in girls gym office
Other 745						N	N	Ν	Restroom	Locker/Shower Room	2nd fl east old locker room us