

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7: The item/system is new or in good condition and no work is required.
- Rank 6: The item/system requires general cleaning and/or routine maintenance.
- Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.1

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main

Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|------------|-----------|----------------------------------|--------------------------------------|------|----------|------|-------------|
| Canopy | | Concrete/ Stucco Canopy | West | 6 | 664 | SF | \$18,800 |
| Chimney | | Metal Flue | South | 7 | 127 | LF | \$0 |
| Doors | | Exterior Steel Door | Entire Building and At Roof Level | 6 | 10 | EA | \$3,303 |
| Doors | | Side Lite | West | 7 | 3 | EA | \$0 |
| Doors | | Store Front Door | West | 7 | 12 | EA | \$0 |
| Doors | | Transom Lite | West and East | 7 | 18 | EA | \$0 |
| Entrance | | Concrete Exterior Stairs | Door 6 - East | 6 | 12 | LF | \$1,287 |
| Entrance | | Concrete Ramp | East | 6 | 30 | LF | \$4,183 |
| Entrance | | Concrete Ramp | Door 9 - East | 5 | 3 | LF | \$1,380 |
| Entrance | | Entrance Controls - Audio | West | 7 | 1 | EΑ | \$0 |
| Entrance | | Power Door Operator and Controls | West | 7 | 1 | EΑ | \$0 |
| Entrance | | Ramp Handrails | East | 6 | 137 | LF | \$0 |
| Entrance | | Stair Handrails | East | 6 | 3 | LF | \$0 |
| Foundation | | Concrete Foundation | Entire Building | 7 | 797 | LF | \$0 |



Building: Main Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|-----------|---|------------------------------------|----------|----------|------|-----------|--------|
| Lighting | | Exterior Lights - Wall Mounted | Entire Building | 7 | 12 | EA | \$0 | |
| Lintels | | Lintels - Steel | Entire Building | 6 | 838 | LF | \$31,636 | |
| Parapet | | Coping - Stone | Entire Building | 7 | 1,005 | LF | \$0 | |
| Parapet | | Parapet > 30" Height | West - 3 Story | 6 | 72 | LF | \$18,687 | |
| Parapet | | Parapet 16" to 30" Height | Entire Building | 6 | 957 | LF | \$198,708 | |
| Roof System | | Interior Downspouts | Entire Building | 6 | 310 | LF | \$0 | |
| Roof System | | Modified Bitumen Roof | Upper Roof and South Lower Roof | 5 | 25,368 | SF | \$299,279 | |
| Roof System | | Modified Bitumen Roof | West Lower Roof | 6 | 1,302 | SF | \$9,216 | |
| Roof System | | Roof Structure: Steel/Metal Deck/Concrete Topping | Entire Building | 7 | 26,670 | SF | \$0 | |
| Superstructure | | Metal Deck/Concrete Topping | Entire Building | 7 | 67,964 | SF | \$0 | |
| Walls | | Brick | Entire Building | 7 | 23,201 | SF | \$0 | |
| Walls | | Brick | Entire Building | 5 | 677 | SF | \$15,335 | |
| Walls | | Stone - Cast | Entire Building | 7 | 4,397 | SF | \$0 | |
| Windows | | Window - Guards perforated | Entire Building | 6 | 3,904 | SF | \$0 | |
| Windows | | Windows - Decorative | West | 7 | 72 | SF | \$0 | |
| Windows | | Windows - Sash Aluminum Double-pane | Entire Building | 6 | 5,248 | SF | \$45,028 | |
| Windows | | Windows - Sash Aluminum Double-pane | Entire Building | 5 | 1,312 | SF | \$45,309 | |
| | | | EXTERIO | R Sub To | tal | | \$692 152 | |

EXTERIOR Sub Total

\$692,152

Building: Main

Category: ELECTRICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|------------------|-----------|--|---------------------|------|----------|------|-------------|
| Emergency System | | Automatic Transfer switch | 2nd Floor Mech Room | 7 | 1 | EA | \$0 |
| Emergency System | | Emergency A/C power - Corridors and Stairs | Entire Building | 7 | 9,377 | SF | \$0 |
| Emergency System | | Emergency A/C power - Gym and Lunch rooms | Entire Building | 7 | 6,264 | SF | \$0 |
| Emergency System | | Emergency A/C power - Students Toilets | Entire Building | 7 | 1,792 | SF | \$0 |
| Emergency System | | Emergency Battery Packs - Corridors and Stairs | 1st Floor | 7 | 2 | EA | \$0 |
| Emergency System | | Emergency Battery Packs - Corridors and Stairs | 2nd Floor | 7 | 6 | EA | \$0 |
| Emergency System | | Emergency Battery Packs - Corridors and Stairs | 3rd Floor | 7 | 3 | EA | \$0 |
| Emergency System | | Emergency Battery Packs - Lunchroom and Gym | 1st Floor | 7 | 2 | EA | \$0 |
| Emergency System | | Exit Signs - Corridors and Stairs | 3rd Floor | 7 | 3 | EA | \$0 |
| Emergency System | | Exit Signs - Corridors and Stairs | 1st Floor | 7 | 18 | EA | \$0 |
| Emergency System | | Exit Signs - Corridors and Stairs | 2nd Floor | 7 | 3 | EA | \$0 |
| Emergency System | | Exit Signs - Lunchroom - Gym - multipurpose rooms | s 2nd Floor | 7 | 2 | EA | \$0 |
| Emergency System | | Exit Signs - Lunchroom - Gym - multipurpose rooms | s 1st Floor | 7 | 6 | EA | \$0 |
| Emergency System | | Independent Electrical Service for emergency power | Sprinkler Room | 7 | 1 | EA | \$0 |





Building: Main

Category: ELECTRICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|--------------------|-----------|--|---------------------|----------|----------|------|-------------|
| Emergency System | | Independent Electrical Service for emergency power | Electrical Room | 7 | 1 | EA | \$0 |
| Emergency System | | Public Announcement System | Main Office | 7 | 67,964 | SF | \$0 |
| Emergency System | | Security System - CCTV | Entire Building | 7 | 67,964 | SF | \$0 |
| Emergency System | | Security System - Intrusion detection | Entire Building | 7 | 67,964 | SF | \$0 |
| Main Service | | Main Electrical service 1600 A 277/480/3PH | Electrical Room | 7 | 1 | EA | \$0 |
| Power Distribution | | Lighting and power panels | 2nd Floor Mech Room | 7 | 3 | EA | \$0 |
| Power Distribution | | Lighting and power panels | 2nd Floor | 7 | 2 | EA | \$0 |
| Power Distribution | | Lighting and power panels | 3rd Floor | 7 | 3 | EA | \$0 |
| Power Distribution | | Lighting and power panels | 1st Floor | 7 | 4 | EA | \$0 |
| Power Distribution | | Main distribution panels 400-600 amp | 2nd Floor Mech Room | 7 | 1 | EA | \$0 |
| Power Distribution | | Main distribution panels above 600 amp | 2nd Floor Mech Room | 7 | 4 | EA | \$0 |
| Power Distribution | | Main distribution panels less than 400 amp | 2nd Floor Mech Room | 7 | 1 | EA | \$0 |
| Power Distribution | | Transformers 277/480-120/208 | 2nd Floor Mech Room | 7 | 3 | EA | \$0 |
| | | | ELECTRICAL | L Sub To | al | | \$0 |

Building: Main

Category: FIRE PROTECTION

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost F | Reason |
|--------------------|-----------|--------------------------|-----------------|-------------|----------|------|--------|--------|
| Fire Alarm | | Fire Alarm Strobe Lights | Entire Building | 7 | 67,964 | SF | \$0 | |
| Fire Alarm | | Fire Alarm System | Electrical Room | 7 | 67,964 | SF | \$0 | |
| Fire Alarm | | Fire Pump Controller | Sprinkler Room | 7 | 1 | EA | \$0 | |
| Pump Room Assembly | | Fire Pump 25-50hp | Sprinkler Room | 7 | 1 | EA | \$0 | |
| Pump Room Assembly | | Jockey Pump | Sprinkler Room | 7 | 1 | EA | \$0 | |
| Sprinkler System | | Sprinkler Heads | Entire Building | 7 | 67,964 | SF | \$0 | |
| Sprinkler System | | Wet Sprinkler System | Sprinkler Room | 7 | 67,964 | SF | \$0 | |
| | | | FIRE PROTECTI | ION Sub Tot | al | | \$0 | |

Building: Main

Category: MECHANICAL

| outogory. In Eorn and | · ·- | | | | | | | |
|-----------------------|-----------|---|---------------------|------|----------|------|-------------|--|
| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason | |
| Air Conditioning | | Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 201 to 300 tons | Roof | 4 | 1 | EA | \$420,420 | |
| Air Handling Systems | | Air Handling Unit Package - Multi Zone - Hot Water 6,001 to 10,000 cfm | 3rd Floor Mech Room | 6 | 1 | EA | \$5,577 | |
| Air Handling Systems | | Air Handling Unit Package - Multi Zone - Hot Water above 30,000 cfm | 3rd Floor Mech Room | 7 | 1 | EA | \$0 | |





Building: Main

Category: MECHANICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------------|-----------|---|---------------------|------|----------|------|----------|--------|
| Air Handling Systems | | Air intake for all Air Handling Units except built up AHU | 3rd Floor East Wall | 7 | 1 | EA | \$0 | |
| ir Handling Systems | | Make Up Air Unit - Roof Mounted - Gas-Heating less than 6,000 cfm | Roof | 6 | 1 | EA | \$2,860 | |
| Air Handling Systems | | Return Fans - Indoor 5,000 to 10,000 CFM | 3rd Floor Mech Room | 7 | 1 | EA | \$0 | |
| ir Handling Systems | | Return Fans - Indoor greater than 20,000 CFM | 3rd Floor Mech Room | 7 | 1 | EA | \$0 | |
| ir Handling Systems | | Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons | Roof | 5 | 1 | EA | \$25,740 | |
| ir Handling Systems | | Variable Air Volume (VAV) Box With Hot Water Coi | I 3rd Floor | 6 | 17 | EA | \$5,591 | |
| ir Handling Systems | | Variable Air Volume (VAV) Box With Hot Water Coi | l 2nd Floor | 6 | 17 | EA | \$5,591 | |
| ir Handling Systems | | Variable Air Volume (VAV) Box With Hot Water Coi | I 1st Floor | 6 | 21 | EA | \$6,907 | |
| oiler Systems | | Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler 3,001MBH-4,000 MBH | Boiler Room | 6 | 2 | EA | \$26,026 | |
| oiler Systems | | Boiler Auxiliary Non-Condensing Hot Water Boiler 3,001MBH-4,000 MBH | Boiler Room | 7 | 2 | EA | \$0 | |
| oiler Systems | | Chemical Pot Feeder - Hot Water | Boiler Room | 6 | 2 | EA | \$601 | |
| oiler Systems | | Combustion Dampers | Boiler Room | 7 | 1 | EA | \$0 | |
| oiler Systems | | Glycol Feed System | Boiler Room | 7 | 1 | EA | \$0 | |
| eating Devices | | Cabinet Heaters With Hot Water Coils | 2nd Floor | 7 | 3 | EA | \$0 | |
| eating Devices | | Cabinet Heaters With Hot Water Coils | 1st Floor | 7 | 4 | EA | \$0 | |
| eating Devices | | Fin Tube Hot Water | 2nd Floor | 6 | 24 | LF | \$412 | |
| eating Devices | | Fin Tube Hot Water | 1st Floor | 7 | 22 | LF | \$0 | |
| eating Devices | | Fin Tube Hot Water | 3rd Floor | 6 | 24 | LF | \$412 | |
| eating Devices | | Unit Heater - Hot Water | Boiler Room | 7 | 2 | EA | \$0 | |
| eating Devices | | Unit Heater - Hot Water | 3rd Floor Mech Room | 7 | 1 | EA | \$0 | |
| eating Devices | | Unit Heater - Hot Water | 2nd Floor Mech Room | 7 | 1 | EA | \$0 | |
| lechanical Plumbing | | Piping - Hydronic Supply and Return - Copper | Entire Building | 7 | 200 | LF | \$0 | |
| lechanical Plumbing | | Pumps - Chilled Water 10 to 20 HP | Boiler Room | 7 | 2 | EA | \$0 | |
| lechanical Plumbing | | Pumps - Hot Water 5 to 10 HP | Boiler Room | 7 | 2 | EA | \$0 | |
| emperature Control | | Hybrid Pneumatic/Direct Digital Control (DDC) System | Entire Building | 6 | 67,964 | SF | \$68,032 | |
| emperature Control | | Thermostats - Direct Digital Control (DDC) | 1st Floor | 7 | 18 | EA | \$0 | |
| emperature Control | | Thermostats - Direct Digital Control (DDC) | 3rd Floor | 7 | 17 | EA | \$0 | |
| emperature Control | | Thermostats - Pneumatic | 2nd Floor | 7 | 16 | EA | \$0 | |
| entilation | | Exhaust Fan - Indoor | 1st Floor | 7 | 2 | EA | \$0 | |
| entilation | | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof | 6 | 5 | EA | \$2,145 | |
| entilation | | Exhaust Fans - Roof Mounted 500 to 1,500 cfm | Roof | 6 | 2 | EA | \$458 | |
| /entilation | | Exhaust Fans - Roof mounted less than 500 CFM | Roof | 6 | 1 | EA | \$157 | |
| /entilation | | Type I Exhaust Hood - Kitchen or Culinary Arts | 1st Floor | 7 | 1 | EA | \$0 | |





Building: Main

Category: MECHANICAL

Group Sub Group Item Location Rank Quantity Unit Cost Reason

MECHANICAL Sub Total \$570,929

Building: Main

Category: PLUMBING

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|--|---------------------|------------|----------|------|---------------|--------|
| Hot Water | | Hot Water Heater - Gas more than 300,000 BTU/HR | 2nd Floor Mech Room | 7 | 2 | EA | \$0 | |
| Hot Water | | Storage Tank less than 500 gallons | Boiler Room | 5 | 1 | EA | \$7,436 | |
| Piping | | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Domestic Piping - Cold Water Risers | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Domestic Piping - Hot Water from Riser to fixtures | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Domestic Piping - Hot Water Return Risers | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Domestic Piping - Hot Water Risers | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Domestic Piping Cold Water Horizontal lines | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Domestic Piping Hot Water Horizontal lines | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Domestic Piping Hot Water Return Lines | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Sanitary Piping | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Storm Piping | Entire Building | 7 | 67,964 | SF | \$0 | |
| Piping | | Vent Piping | Entire Building | 7 | 67,964 | SF | \$0 | |
| Pumps | | Domestic Booster Pump duplex | 2nd Floor Mech Room | 7 | 1 | EA | \$0 | |
| | | | DLUMBING | . O. I. T. | | | 67.400 | |

PLUMBING Sub Total

\$7,436

Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|----------------------------------|-------------------|--|------|----------|------|-------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Exposed | 1st Floor Telecommunications Office | 6 | 47 | SF | \$89 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Engineer's Office | 6 | 75 | SF | \$161 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Case Manager Office | 6 | 146 | SF | \$313 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Office 1 in Multipurpose Room | 6 | 111 | SF | \$238 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Gym Office | 5 | 114 | SF | \$646 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Office 2 in Multipurpose Room | 6 | 111 | SF | \$238 | |



Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|-----------------------|----------------------------------|-----------------------|--|------|----------|------|-------------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Manager's Office | 6 | 76 | SF | \$163 |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor in Main Office | 6 | 157 | SF | \$337 |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Main Office | 6 | 702 | SF | \$1,506 |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Vault/Office | 6 | 162 | SF | \$347 |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Main Office Conference | 6 | 160 | SF | \$343 |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Assistant Principal's Office | 5 | 148 | SF | \$838 |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Principal's Office | 6 | 237 | SF | \$508 |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Office In Library | 6 | 164 | SF | \$352 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Principal's Office | 7 | 237 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Assistant Principal's Office | 6 | 148 | SF | \$212 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Main Office | 6 | 702 | SF | \$1,004 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor in Main Office | 6 | 157 | SF | \$225 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Concrete | Manager's Office | 6 | 76 | SF | \$359 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Office 2 in Multipurpose Room | 6 | 111 | SF | \$159 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Office 1 in Multipurpose Room | 6 | 111 | SF | \$159 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Office In Library | 6 | 164 | SF | \$235 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Gym Office | 6 | 114 | SF | \$163 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Engineer's Office | 6 | 75 | SF | \$107 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Case Manager Office | 6 | 146 | SF | \$209 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Telecommunications Office | 6 | 47 | SF | \$67 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | Vault/Office | 6 | 162 | SF | \$232 |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Main Office Conference | 6 | 160 | SF | \$229 |



Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|-----------------------|----------------------------------|----------------------------|--|------|----------|------|-------------|
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Vault/Office | 7 | 3 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Case Manager Office | 7 | 2 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Principal's Office | 7 | 3 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Main Office Conference | 7 | 2 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Main Office | 7 | 14 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor in Main Office | 7 | 2 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Office 1 in Multipurpose Room | 7 | 1 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Engineer's Office | 7 | 1 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Gym Office | 7 | 2 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Office In Library | 6 | 1 | SF | \$1 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Office 2 in Multipurpose Room | 7 | 1 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Manager's Office | 7 | 1 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Assistant Principal's Office | 7 | 2 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st Floor Telecommunications Office | 7 | 1 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | Manager's Office | 6 | 329 | SF | \$941 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 1st Floor in Main Office | 7 | 200 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 1st Floor Main Office | 6 | 801 | SF | \$2,291 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | Vault/Office | 6 | 499 | SF | \$1,427 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 1st Floor Principal's Office | 7 | 248 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 1st Floor Engineer's Office | 6 | 304 | SF | \$869 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 1st Floor Assistant Principal's Office | 7 | 193 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 1st Floor Main Office Conference | 6 | 460 | SF | \$1,316 |



Building: Main Category: INTERIOR

| Category: INTERIOR | Sub Craun | lto-m | Lacation | Donle | Ougatit | l lmi4 | Cast Bassan |
|------------------------|----------------------------------|------------------------------|--|-------|----------|--------|-------------|
| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | Gym Office | 6 | 394 | SF | \$1,127 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | Office In Library | 6 | 243 | SF | \$695 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 1st Floor Telecommunications Office | 6 | 385 | SF | \$1,101 |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block | 1st Floor Case Manager Office | 6 | 244 | SF | \$698 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Office In Library | 6 | 243 | SF | \$573 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Office 2 in Multipurpose Room | 6 | 387 | SF | \$913 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor in Main Office | 7 | 233 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Main Office | 6 | 610 | SF | \$1,439 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Main Office Conference | 6 | 120 | SF | \$283 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Assistant Principal's Office | 7 | 226 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Principal's Office | 7 | 248 | SF | \$0 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Case Manager Office | 6 | 175 | SF | \$413 |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Office 1 in Multipurpose Room | 6 | 387 | SF | \$913 |
| Doors | | Interior Steel Doors incl hw | Entire Building | 6 | 48 | EA | \$13,591 |
| Doors | | Interior Wood Doors incl hw | Entire Building | 6 | 58 | EA | \$16,422 |
| Doors | | Interior Wood Doors incl hw | Entire Building | 5 | 1 | EA | \$472 |
| Doors | | Interior Wood Doors incl hw | Entire Building | 7 | 1 | EA | \$0 |
| Doors | | Side-lite | Entire Building | 6 | 600 | SF | \$11,154 |
| Doors | | Store Front Door | Entire Building | 6 | 12 | EA | \$2,831 |
| Drinking Fountains | Corridors | Single Fountain | 1st Floor | 6 | 2 | EA | \$772 |
| Drinking Fountains | Corridors | Single Fountain | 2nd Floor | 6 | 4 | EA | \$1,544 |
| Drinking Fountains | Corridors | Single Fountain | 3rd Floor | 6 | 4 | EA | \$1,544 |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating | 1st Floor | | | EA | \$0 |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Exposed | 1st Floor | 6 | 3,503 | SF | \$26,649 |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Tile/Sheet | 1st Floor | 6 | 3,503 | SF | \$5,009 |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------------|---|-----------------------------|------------------------------|------|----------|------|----------|--------|
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Pendant/Surface | 1st Floor | 6 | 20 | EA | \$2,431 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards | 1st Floor | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System | 1st Floor | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Stage Curtain | 1st Floor | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Concrete Block | 1st Floor | 6 | 6,847 | SF | \$58,747 | |
| Kitchen | Cooking Kitchen | Ceiling - Plaster/Drywall | 1st Floor | 6 | 961 | SF | \$3,628 | |
| Kitchen | Cooking Kitchen | Ceiling - Plaster/Drywall | Dishwashing Room | 6 | 118 | SF | \$445 | |
| Kitchen | Cooking Kitchen | Flooring - Concrete | 1st Floor | 6 | 961 | SF | \$4,535 | |
| Kitchen | Cooking Kitchen | Flooring - Concrete | Dishwashing Room | 6 | 118 | SF | \$557 | |
| Kitchen | Cooking Kitchen | Lighting - Lay-In | Dishwashing Room | 5 | 2 | SF | \$4 | |
| Kitchen | Cooking Kitchen | Lighting - Lay-In | 1st Floor | 7 | 7 | SF | \$0 | |
| Kitchen | Cooking Kitchen | Wall - Concrete Block | Dishwashing Room | 6 | 461 | SF | \$1,318 | |
| Kitchen | Cooking Kitchen | Wall - Concrete Block | 1st Floor | 6 | 1,474 | SF | \$4,216 | |
| Library | Library | Casework | 2nd Floor | 6 | 130 | LF | \$3,988 | |
| Library | Library | Flooring Carpet | 2nd Floor | 6 | 2,171 | SF | \$3,105 | |
| Library | Library | Lighting - Pendant/ Surface | 2nd Floor | 7 | 48 | SF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 2nd Floor Girls South | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 1st Floor Women's Staff | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 1st Floor Men's Staff Locker | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 1st Floor Women | | | LF | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Benches | In Preschool 102 | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | In Rooms 106/108 | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 1st Floor Girls Locker Room | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 1st Floor Boys Locker Room | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | In Art Room 221 | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 2nd Floor Boys South | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 3rd Floor Boys North | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 2nd Floor Girls North | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 3rd Floor Girls North | | | LF | \$0 | |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------|---|---------|-----------------------------------|------|----------|------|-------|--------|
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 3rd Floor Girls South | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 3rd Floor Boys South | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 3rd Floor Women's Staff | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 2nd Floor Women's Staff | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 2nd Floor Men's Staff | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 3rd Floor Men's Staff | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 1st Floor Men | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 2nd Floor Boys North | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 1st Floor Main Office Restroom | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 1st Floor Women's Staff | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 2nd Floor Girls North | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 1st Floor Men's Staff Locker | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 1st Floor Main Office Restroom | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 3rd Floor Girls South | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 3rd Floor Boys South | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 3rd Floor Women's Staff | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 1st Floor Women | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 1st Floor Men | | | EA | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Lockers | In Preschool 102 | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 1st Floor Girls Locker Room | 6 | 5 | EA | \$245 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 1st Floor Boys Locker Room | 6 | 5 | EA | \$245 | |
| Locker/Shower Room | Staff Restroom | Lockers | In Art Room 221 | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 2nd Floor Boys South | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 2nd Floor Boys North | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 2nd Floor Women's Staff | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 3rd Floor Boys North | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 3rd Floor Men's Staff | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 3rd Floor Girls North | | | EA | \$0 | |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank C | Quantity | Unit | Cost Reason |
|---------------------|---|-----------------------|-----------------------------------|--------|----------|------|-------------|
| Locker/Shower Room | Staff Restroom | Lockers | 2nd Floor Men's Staff | | | EA | \$0 |
| Locker/Shower Room | Children's Standard | Lockers | 2nd Floor Girls South | | | EA | \$0 \$0 |
| Looker, Chewer Room | Student Restroom | 2001010 | End i loci onic oddin | | | | 4 0 |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | In Rooms 106/108 | | | EA | \$0 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 3rd Floor Boys North | | | EA | \$0 |
| Locker/Shower Room | Staff Restroom | Showers | In Art Room 221 | | | EA | \$0 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 2nd Floor Boys North | | | EA | \$0 |
| Locker/Shower Room | Staff Restroom | Showers | 1st Floor Men | | | EA | \$0 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 2nd Floor Girls South | | | EA | \$0 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 2nd Floor Boys South | | | EA | \$0 |
| Locker/Shower Room | Locker/Shower Room | Showers | 1st Floor Boys Locker Room | 6 | 1 | EA | \$243 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | In Rooms 106/108 | | | EA | \$0 |
| Locker/Shower Room | Staff Restroom | Showers | 1st Floor Main Office Restroom | | | EA | \$0 |
| Locker/Shower Room | Locker/Shower Room | Showers | 1st Floor Men's Staff Locker | | | EA | \$0 |
| Locker/Shower Room | Locker/Shower Room | Showers | 1st Floor Women's Staff | | | EA | \$0 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 2nd Floor Girls North | | | EA | \$0 |
| Locker/Shower Room | Early Childhood Student Restroom | Showers | In Preschool 102 | | | EA | \$0 |
| Locker/Shower Room | Locker/Shower Room | Showers | 1st Floor Girls Locker Room | 6 | 1 | EA | \$243 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 3rd Floor Girls South | | | EA | \$0 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 3rd Floor Boys South | | | EA | \$0 |
| Locker/Shower Room | Staff Restroom | Showers | 3rd Floor Women's Staff | | | EA | \$0 |
| Locker/Shower Room | Staff Restroom | Showers | 2nd Floor Women's Staff | | | EA | \$0 |
| Locker/Shower Room | Staff Restroom | Showers | 2nd Floor Men's Staff | | | EA | \$0 |
| Locker/Shower Room | Staff Restroom | Showers | 3rd Floor Men's Staff | | | EA | \$0 |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 3rd Floor Girls North | | | EA | \$0 |
| Locker/Shower Room | Staff Restroom | Showers | 1st Floor Women | | | EA | \$0 |
| Lunchroom | Multipurpose Room | Ceiling - Lay-In | 1st Floor Faculty Lounge | 6 | 2,670 | SF | \$5,727 |
| Lunchroom | Lunchroom | Ceiling - Lay-In | 1st Floor | 6 | 2,761 | SF | \$5,922 |
| Lunchroom | Multipurpose Room | Flooring - Tile/Sheet | 1st Floor Faculty Lounge | 6 | 2,670 | SF | \$3,818 |
| | | | | | | | |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------------|---|--------------------------|-------------------------------------|------|----------|------|-----------|--------|
| Lunchroom | Lunchroom | Flooring - Tile/Sheet | 1st Floor | 6 | 2,761 | SF | \$3,948 | |
| Lunchroom | Multipurpose Room | Lighting - Lay-In | 1st Floor Faculty Lounge | 6 | 28 | SF | \$20 | |
| Lunchroom | Lunchroom | Lighting - Lay-In | 1st Floor | 6 | 34 | SF | \$24 | |
| Lunchroom | Lunchroom | Serving Line | 1st Floor | 7 | 42 | LF | \$0 | |
| Lunchroom | Cooking Kitchen | Serving Line | 1st Floor | | | LF | \$0 | |
| Lunchroom | Cooking Kitchen | Serving Line | Dishwashing Room | | | LF | \$0 | |
| Lunchroom | Multipurpose Room | Serving Line | 1st Floor Faculty Lounge | | | LF | \$0 | |
| Lunchroom | Multipurpose Room | Wall - Concrete Block | 1st Floor Faculty Lounge | 6 | 2,021 | SF | \$5,780 | |
| Lunchroom | Lunchroom | Wall - Concrete Block | 1st Floor | 6 | 2,093 | SF | \$5,986 | |
| Lunchroom | Lunchroom | Wall - Plaster/Drywall | 1st Floor | 6 | 398 | SF | \$939 | |
| Lunchroom | Multipurpose Room | Wall - Plaster/Drywall | 1st Floor Faculty Lounge | 6 | 707 | SF | \$1,668 | |
| MDF/IDF | | Finishes | 2nd Floor | 7 | 108 | SF | \$0 | |
| MDF/IDF | | Ventilation and Cooling | 2nd Floor | 5 | 108 | EA | \$756,756 | |
| Mechanical/Service Rooms | | Boiler Room | 3rd Floor | 7 | 825 | SF | \$0 | |
| Mechanical/Service Rooms | | Janitor's Closet | Entire Building | 6 | 3 | SF | \$14 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | 1st Floor Electric Room | 5 | 107 | SF | \$1,212 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | Water Pump Room | 6 | 143 | SF | \$675 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | 3rd Floor Elevator Machine Room | 6 | 152 | SF | \$717 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | 3rd Floor Mechanical Room | 7 | 1,262 | SF | \$0 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | 2nd Floor Electrical Room | 6 | 795 | SF | \$3,752 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor | 6 | 101 | SF | \$477 | |
| Mechanical/Service Rooms | | Storage Room | 2nd Floor | 7 | 468 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | Storage in Science Classroom 300 | 7 | 240 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | Storage in Preschool | 7 | 58 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | 2nd Floor | 7 | 810 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor Outdoor Storage | 5 | 83 | SF | \$940 | |
| Mechanical/Service Rooms | | Storage Room | Gym Storage | 6 | 180 | SF | \$849 | |
| Mechanical/Service Rooms | | Storage Room | Storage in 102 | 7 | 61 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | Engineer's Office Storage | 6 | 59 | SF | \$278 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor Receiving Area | 6 | 154 | SF | \$727 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor | 6 | 77 | SF | \$363 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor Multipurpose Storage | 6 | 123 | SF | \$580 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor Pantry | 6 | 135 | SF | \$637 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 3rd Floor Boys South | 7 | 212 | SF | \$0 | |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---|---------------------------|-----------------------------------|-------|-----------|------|---------|--------|
| Group | Sub Group | item | Location | Nalik | Qualitity | | Cost | Reason |
| Staff Restroom | Locker/Shower Room | Accessories | 1st Floor Girls Locker Room | | | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Accessories | 1st Floor Boys Locker Room | | | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | In Art Room 221 | 6 | 46 | SF | \$355 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 2nd Floor Boys South | 5 | 212 | SF | \$5,402 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 2nd Floor Boys North | 5 | 212 | SF | \$5,402 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 3rd Floor Boys North | 7 | 212 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | In Rooms 106/108 | 6 | 48 | SF | \$371 | |
| Staff Restroom | Staff Restroom | Accessories | 2nd Floor Women's Staff | 7 | 62 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | 2nd Floor Men's Staff | 7 | 62 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 3rd Floor Girls North | 7 | 212 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | 3rd Floor Men's Staff | 7 | 62 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 2nd Floor Girls South | 5 | 212 | SF | \$5,402 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 2nd Floor Girls North | 5 | 212 | SF | \$5,402 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 3rd Floor Girls South | 7 | 212 | SF | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Accessories | In Preschool 102 | 6 | 48 | SF | \$371 | |
| Staff Restroom | Staff Restroom | Accessories | 1st Floor Men | 6 | 46 | SF | \$355 | |
| Staff Restroom | Staff Restroom | Accessories | 1st Floor Women | 6 | 46 | SF | \$355 | |
| Staff Restroom | Staff Restroom | Accessories | 1st Floor Main Office Restroom | 6 | 53 | SF | \$409 | |
| Staff Restroom | Locker/Shower Room | Accessories | 1st Floor Men's Staff Locker | 6 | 51 | SF | \$394 | |
| Staff Restroom | Locker/Shower Room | Accessories | 1st Floor Women's Staff | 6 | 46 | SF | \$355 | |
| Staff Restroom | Staff Restroom | Accessories | 3rd Floor Women's Staff | 7 | 62 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 1st Floor Men | 6 | 46 | SF | \$130 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 1st Floor Women | 6 | 46 | SF | \$130 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 1st Floor Main Office Restroom | 6 | 53 | SF | \$150 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 1st Floor Men's Staff Locker | 6 | 51 | SF | \$144 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 1st Floor Women's Staff | 6 | 46 | SF | \$130 | |
| Staff Restroom | Early Childhood Student Restroom | Ceiling - Plaster/Drywall | In Preschool 102 | 6 | 48 | SF | \$136 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 3rd Floor Women's Staff | 7 | 62 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | In Art Room 221 | 6 | 46 | SF | \$130 | |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|----------------|---|---------------------------|-----------------------------------|------|----------|------|-------------|
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 2nd Floor Men's Staff | 7 | 62 | SF | \$0 |
| | | · · | | | 212 | SF | \$600 |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor Boys South | 6 | 212 | | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | In Rooms 106/108 | 6 | 48 | SF | \$136 |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 3rd Floor Men's Staff | 7 | 62 | SF | \$0 |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 1st Floor Boys Locker Room | 6 | 68 | SF | \$193 |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 2nd Floor Women's Staff | 7 | 62 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor Boys South | 6 | 212 | SF | \$600 |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor Boys North | 6 | 212 | SF | \$600 |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor Boys North | 6 | 212 | SF | \$600 |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor Girls South | 6 | 212 | SF | \$600 |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor Girls North | 6 | 212 | SF | \$600 |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor Girls North | 6 | 212 | SF | \$600 |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor Girls South | 6 | 212 | SF | \$600 |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 1st Floor Girls Locker Room | 6 | 60 | SF | \$170 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | In Rooms 106/108 | 6 | 1 | EA | \$300 |
| Staff Restroom | Staff Restroom | Floor Drain | 3rd Floor Men's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Floor Drain | 2nd Floor Men's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Floor Drain | 2nd Floor Women's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Floor Drain | 3rd Floor Women's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Floor Drain | 1st Floor Women's Staff | 6 | 1 | EA | \$300 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 3rd Floor Boys South | 7 | 1 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 3rd Floor Girls South | 7 | 1 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 3rd Floor Girls North | 7 | 1 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 2nd Floor Girls North | 7 | 1 | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Floor Drain | 1st Floor Men's Staff Locker | 6 | 1 | EA | \$300 |
| Staff Restroom | Staff Restroom | Floor Drain | 1st Floor Main Office Restroom | 6 | 1 | EA | \$300 |
| Staff Restroom | Staff Restroom | Floor Drain | 1st Floor Women | | | EA | \$0 |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|----------------|---|---------------------|-----------------------------------|------|------------|------|-------------|
| | • | | | Hank | - auditity | | |
| Staff Restroom | Staff Restroom | Floor Drain | 1st Floor Men | _ | _ | EA | \$0 |
| Staff Restroom | Early Childhood Student Restroom | Floor Drain | In Preschool 102 | 6 | 1 | EA | \$300 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 2nd Floor Girls South | 7 | 1 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 3rd Floor Boys North | 7 | 1 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 2nd Floor Boys North | 7 | 1 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 2nd Floor Boys South | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Floor Drain | In Art Room 221 | 7 | 1 | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Floor Drain | 1st Floor Boys Locker Room | 6 | 1 | EA | \$300 |
| Staff Restroom | Locker/Shower Room | Floor Drain | 1st Floor Girls Locker Room | 6 | 1 | EA | \$300 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | 3rd Floor Boys North | 6 | 212 | SF | \$1,000 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | In Rooms 106/108 | 6 | 48 | SF | \$227 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | 2nd Floor Girls South | 5 | 212 | SF | \$1,000 |
| Staff Restroom | Locker/Shower Room | Flooring - Concrete | 1st Floor Men's Staff Locker | 6 | 51 | SF | \$241 |
| Staff Restroom | Staff Restroom | Flooring - Concrete | 1st Floor Main Office Restroom | 6 | 53 | SF | \$250 |
| Staff Restroom | Staff Restroom | Flooring - Concrete | 1st Floor Women | 6 | 46 | SF | \$217 |
| Staff Restroom | Staff Restroom | Flooring - Concrete | 1st Floor Men | 6 | 46 | SF | \$217 |
| Staff Restroom | Early Childhood Student Restroom | Flooring - Concrete | In Preschool 102 | 6 | 48 | SF | \$227 |
| Staff Restroom | Locker/Shower Room | Flooring - Concrete | 1st Floor Women's Staff | 6 | 46 | SF | \$217 |
| Staff Restroom | Locker/Shower Room | Flooring - Concrete | 1st Floor Girls Locker Room | 6 | 60 | SF | \$283 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | 2nd Floor Girls North | 5 | 212 | SF | \$1,000 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | 3rd Floor Girls North | 6 | 212 | SF | \$1,000 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | 2nd Floor Boys South | 5 | 212 | SF | \$1,000 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | 3rd Floor Girls South | 6 | 212 | SF | \$1,000 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | 2nd Floor Boys North | 5 | 212 | SF | \$1,000 |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Concrete | 3rd Floor Boys South | 6 | 212 | SF | \$1,000 |
| Staff Restroom | Staff Restroom | Flooring - Concrete | 3rd Floor Women's Staff | 7 | 62 | SF | \$0 |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|----------------|---|-----------------------|-----------------------------------|------|----------|------|-------------|
| Staff Restroom | Staff Restroom | Flooring - Concrete | 2nd Floor Women's Staff | 7 | 62 | SF | \$0 |
| Staff Restroom | Locker/Shower Room | Flooring - Concrete | 1st Floor Boys Locker Room | n 6 | 68 | SF | \$321 |
| Staff Restroom | Staff Restroom | Flooring - Concrete | 2nd Floor Men's Staff | 7 | 62 | SF | \$0 |
| Staff Restroom | Staff Restroom | Flooring - Concrete | 3rd Floor Men's Staff | 7 | 62 | SF | \$0 |
| Staff Restroom | Staff Restroom | Flooring - Tile/Sheet | In Art Room 221 | 6 | 46 | SF | \$66 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 3rd Floor Boys South | | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 2nd Floor Girls South | | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 2nd Floor Boys South | | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 3rd Floor Girls North | | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 2nd Floor Girls North | | | EA | \$0 |
| Staff Restroom | Staff Restroom | Hand Dryer | 1st Floor Main Office Restroom | | | EA | \$0 |
| Staff Restroom | Staff Restroom | Hand Dryer | 3rd Floor Women's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 2nd Floor Boys North | | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 3rd Floor Boys North | | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 3rd Floor Girls South | | | EA | \$0 |
| Staff Restroom | Staff Restroom | Hand Dryer | 2nd Floor Women's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Hand Dryer | 2nd Floor Men's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Hand Dryer | 1st Floor Women | 5 | 1 | EA | \$716 |
| Staff Restroom | Early Childhood Student Restroom | Hand Dryer | In Preschool 102 | | | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 1st Floor Men's Staff Locker | | | EA | \$0 |
| Staff Restroom | Staff Restroom | Hand Dryer | 3rd Floor Men's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Hand Dryer | In Art Room 221 | | | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 1st Floor Boys Locker Room | | | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 1st Floor Girls Locker Room | l | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | In Rooms 106/108 | | | EA | \$0 |
| Staff Restroom | Staff Restroom | Hand Dryer | 1st Floor Men | 5 | 1 | EA | \$716 |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 1st Floor Women's Staff | | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 2nd Floor Girls South | 7 | 2 | EA | \$0 |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|----------------|---|-------------------|-----------------------------------|------|----------|------|-------------|
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 2nd Floor Boys South | 7 | 2 | EA | \$0 |
| Staff Restroom | Staff Restroom | Lavatory | 3rd Floor Men's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Lavatory | 2nd Floor Men's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Staff Restroom | Lavatory | 2nd Floor Women's Staff | 7 | 1 | EΑ | \$0 |
| Staff Restroom | Staff Restroom | Lavatory | 3rd Floor Women's Staff | 7 | 1 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 3rd Floor Boys South | 7 | 2 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 3rd Floor Girls South | 7 | 2 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 3rd Floor Girls North | 7 | 2 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 2nd Floor Boys North | 7 | 2 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 3rd Floor Boys North | 7 | 2 | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Lavatory | 1st Floor Women's Staff | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Lavatory | In Art Room 221 | 7 | 1 | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Lavatory | 1st Floor Boys Locker Roo | om | | EA | \$0 |
| Staff Restroom | Locker/Shower Room | Lavatory | 1st Floor Girls Locker Roo | m | | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | In Rooms 106/108 | 6 | 1 | EA | \$372 |
| Staff Restroom | Early Childhood Student Restroom | Lavatory | In Preschool 102 | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Lavatory | 1st Floor Men | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Lavatory | 1st Floor Women | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Lavatory | 1st Floor Main Office Restroom | 6 | 1 | EA | \$372 |
| Staff Restroom | Locker/Shower Room | Lavatory | 1st Floor Men's Staff Lock | er 6 | 1 | EA | \$372 |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 2nd Floor Girls North | 7 | 2 | EA | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd Floor Girls South | 6 | 3 | SF | \$2 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Girls South | 6 | 3 | SF | \$2 |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 1st Floor Women | 7 | 1 | SF | \$0 |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 1st Floor Men | 7 | 1 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | In Rooms 106/108 | 7 | 1 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd Floor Girls North | 6 | 3 | SF | \$2 |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|----------------|---|-----------------------------|-----------------------------------|------|----------|------|-------------|
| Staff Restroom | Locker/Shower Room | Lighting - Lay-In | 1st Floor Boys Locker Room | 7 | 1 | SF | \$0 |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | In Art Room 221 | 7 | 1 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Boys South | 6 | 3 | SF | \$2 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Boys South | 6 | 1 | SF | \$1 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Boys North | 6 | 3 | SF | \$2 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Boys North | 6 | 1 | SF | \$1 |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 1st Floor Main Office Restroom | 7 | 1 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd Floor Boys North | 6 | 1 | SF | \$1 |
| Staff Restroom | Early Childhood Student Restroom | Lighting - Lay-In | In Preschool 102 | 6 | 1 | SF | \$1 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Girls South | 6 | 1 | SF | \$1 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Girls North | 6 | 3 | SF | \$2 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Girls North | 6 | 1 | SF | \$1 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd Floor Girls North | 6 | 1 | SF | \$1 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd Floor Girls South | 6 | 1 | SF | \$1 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd Floor Boys South | 6 | 1 | SF | \$1 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd Floor Boys South | 6 | 3 | SF | \$2 |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 3rd Floor Women's Staff | 7 | 1 | SF | \$0 |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 2nd Floor Women's Staff | 7 | 1 | SF | \$0 |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 2nd Floor Men's Staff | 7 | 1 | SF | \$0 |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 3rd Floor Men's Staff | 7 | 1 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd Floor Boys North | 6 | 3 | SF | \$2 |
| Staff Restroom | Locker/Shower Room | Lighting - Lay-In | 1st Floor Girls Locker Room | 7 | 1 | SF | \$0 |
| Staff Restroom | Locker/Shower Room | Lighting - Pendant/ Surface | 1st Floor Women's Staff | 6 | 1 | SF | \$1 |
| Staff Restroom | Locker/Shower Room | Lighting - Pendant/ Surface | 1st Floor Men's Staff Locker | 6 | 1 | SF | \$1 |
| Staff Restroom | Children's Standard Student Restroom | Partitions | In Rooms 106/108 | | | EA | \$0 |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason | |
|----------------|---|------------|-----------------------------------|------|----------|------|-------------|--|
| Staff Restroom | Children's Standard Student Restroom | Partitions | 3rd Floor Boys South | 5 | 1 | EA | \$572 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 3rd Floor Girls South | 6 | 5 | EA | \$897 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 3rd Floor Girls North | 6 | 5 | EA | \$897 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 2nd Floor Girls North | 6 | 5 | EA | \$897 | |
| Staff Restroom | Early Childhood Student Restroom | Partitions | In Preschool 102 | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 3rd Floor Boys North | 6 | 1 | EA | \$179 | |
| Staff Restroom | Staff Restroom | Partitions | 1st Floor Main Office Restroom | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | 1st Floor Girls Locker Room | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | 1st Floor Boys Locker Room | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | In Art Room 221 | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 2nd Floor Boys South | 5 | 1 | EA | \$572 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 2nd Floor Girls South | 6 | 5 | EA | \$897 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 2nd Floor Boys North | 5 | 1 | EA | \$572 | |
| Staff Restroom | Staff Restroom | Partitions | 1st Floor Women | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | 1st Floor Men's Staff Locker | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | 1st Floor Women's Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 3rd Floor Women's Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 2nd Floor Women's Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 3rd Floor Men's Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 2nd Floor Men's Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 1st Floor Men | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Urinals | 1st Floor Girls Locker Room | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 1st Floor Main Office Restroom | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Urinals | 1st Floor Men's Staff Locker | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 2nd Floor Boys North | 7 | 4 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Urinals | 1st Floor Women's Staff | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 2nd Floor Boys South | 7 | 4 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 1st Floor Women | | | EA | \$0 | |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|---|-----------------------|------------------------------|-----------|----------|------|---------|--------|
| • | • | | | - 101.714 | | | | |
| Staff Restroom | Staff Restroom | Urinals | 1st Floor Men | | | EΑ | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | In Rooms 106/108 | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 3rd Floor Boys North | 4 | 1 | EA | \$3,718 | |
| Staff Restroom | Locker/Shower Room | Urinals | 1st Floor Boys Locker Room | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | In Art Room 221 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 3rd Floor Men's Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 2nd Floor Men's Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 2nd Floor Women's Staff | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 3rd Floor Women's Staff | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 3rd Floor Boys South | 7 | 4 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 3rd Floor Boys North | 7 | 3 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Urinals | In Preschool 102 | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 2nd Floor Boys South | 7 | 495 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | 2nd Floor Men's Staff | 7 | 215 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | 2nd Floor Women's Staff | 7 | 215 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | 3rd Floor Women's Staff | 7 | 215 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 3rd Floor Boys South | 7 | 495 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 3rd Floor Girls South | 7 | 495 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 3rd Floor Girls North | 7 | 495 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 2nd Floor Girls North | 7 | 495 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 2nd Floor Girls South | 7 | 495 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | 3rd Floor Men's Staff | 7 | 215 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 2nd Floor Boys North | 7 | 495 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Wall - Concrete Block | 1st Floor Girls Locker Room | 6 | 219 | SF | \$626 | |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | In Art Room 221 | 7 | 200 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Wall - Concrete Block | 1st Floor Boys Locker Room | 6 | 228 | SF | \$652 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | In Rooms 106/108 | 6 | 179 | SF | \$512 | |
| Staff Restroom | Locker/Shower Room | Wall - Concrete Block | 1st Floor Men's Staff Locker | 6 | 267 | SF | \$764 | |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|----------------|---|-------------------------------|-----------------------------------|------|----------|------|-------------|
| Staff Restroom | Staff Restroom | Wall - Concrete Block | 1st Floor Men | 6 | 276 | SF | \$789 |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | 1st Floor Women | 6 | 276 | SF | \$789 |
| Staff Restroom | Staff Restroom | Wall - Concrete Block | 1st Floor Main Office Restroom | 6 | 279 | SF | \$798 |
| Staff Restroom | Locker/Shower Room | Wall - Concrete Block | 1st Floor Women's Staff | 6 | 252 | SF | \$721 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 3rd Floor Boys North | 7 | 495 | SF | \$0 |
| Staff Restroom | Early Childhood Student Restroom | Wall - Concrete Block | In Preschool 102 | 6 | 179 | SF | \$512 |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 3rd Floor Men's Staff | 7 | 80 | SF | \$0 |
| Staff Restroom | Locker/Shower Room | Wall - Structural Glazed Tile | 1st Floor Women's Staff | 6 | 60 | SF | \$429 |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 2nd Floor Women's Staff | 7 | 80 | SF | \$0 |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 2nd Floor Men's Staff | 7 | 80 | SF | \$0 |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 3rd Floor Women's Staff | 7 | 80 | SF | \$ 0 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | 3rd Floor Boys South | 7 | 242 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | 3rd Floor Girls North | 7 | 242 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | 2nd Floor Girls North | 7 | 242 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | 2nd Floor Girls South | 7 | 242 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | 3rd Floor Boys North | 7 | 242 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | In Rooms 106/108 | 6 | 60 | SF | \$429 |
| Staff Restroom | Locker/Shower Room | Wall - Structural Glazed Tile | 1st Floor Men's Staff Locker | 6 | 60 | SF | \$429 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | 3rd Floor Girls South | 7 | 242 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | 2nd Floor Boys North | 7 | 242 | SF | \$0 |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 1st Floor Main Office Restroom | 6 | 57 | SF | \$408 |
| Staff Restroom | Early Childhood Student Restroom | Wall - Structural Glazed Tile | In Preschool 102 | 6 | 60 | SF | \$429 |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 1st Floor Women | 6 | 55 | SF | \$393 |
| Staff Restroom | Locker/Shower Room | Wall - Structural Glazed Tile | 1st Floor Girls Locker Room | 6 | 90 | SF | \$644 |
| Staff Restroom | Locker/Shower Room | Wall - Structural Glazed Tile | 1st Floor Boys Locker Room | 6 | 90 | SF | \$644 |
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | In Art Room 221 | 7 | 55 | SF | \$0 |
| Staff Restroom | Children's Standard Student Restroom | Wall - Structural Glazed Tile | 2nd Floor Boys South | 7 | 242 | SF | \$0 |



Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|---------------------|---|-------------------------------------|-----------------------------------|------|----------|------|-------------|
| Staff Restroom | Staff Restroom | Wall - Structural Glazed Tile | 1st Floor Men | 6 | 55 | SF | \$393 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 3rd Floor Girls North | 6 | 5 | EA | \$1,859 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 2nd Floor Girls North | 6 | 5 | EA | \$1,859 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 3rd Floor Girls South | 6 | 5 | EA | \$1,859 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 3rd Floor Boys South | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Water Closet | 3rd Floor Women's Staff | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Water Closet | 2nd Floor Women's Staff | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Water Closet | 3rd Floor Men's Staff | 6 | 1 | EA | \$372 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 2nd Floor Girls South | 6 | 5 | EA | \$1,859 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | In Rooms 106/108 | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Water Closet | 2nd Floor Men's Staff | 6 | 1 | EA | \$372 |
| Staff Restroom | Locker/Shower Room | Water Closet | 1st Floor Men's Staff Locker | 6 | 1 | EA | \$372 |
| Staff Restroom | Locker/Shower Room | Water Closet | 1st Floor Boys Locker Room | | | EA | \$ 0 |
| Staff Restroom | Locker/Shower Room | Water Closet | 1st Floor Women's Staff | 6 | 1 | EA | \$372 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 3rd Floor Boys North | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Water Closet | 1st Floor Main Office Restroom | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Water Closet | 1st Floor Women | 6 | 1 | EA | \$372 |
| Staff Restroom | Staff Restroom | Water Closet | 1st Floor Men | 6 | 1 | EA | \$372 |
| Staff Restroom | Early Childhood Student Restroom | Water Closet | In Preschool 102 | 6 | 1 | EA | \$372 |
| Staff Restroom | Locker/Shower Room | Water Closet | 1st Floor Girls Locker Room | | | EA | \$ 0 |
| Staff Restroom | Staff Restroom | Water Closet | In Art Room 221 | 6 | 1 | EA | \$372 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 2nd Floor Boys South | 6 | 1 | EA | \$372 |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 2nd Floor Boys North | 6 | 1 | EA | \$372 |
| Vertical Conveyance | | Elevator - Roped Holeless Hydraulic | Entire Building | 7 | 1 | EA | \$0 |
| Vocational Shop | Classroom | Work Sink | - | 7 | 1 | EA | \$0 |
| Vocational Shop | Classroom | Work Sink | | 7 | 2 | EA | \$0 |
| Vocational Shop | Classroom | Work Sink | | 5 | 1 | EA | \$1,931 |
| Vocational Shop | Classroom | Work Sink | | 6 | 2 | EA | \$772 |
| Vocational Shop | Classroom | Work Sink | | 6 | 2 | EA | \$772 |
| Vocational Shop | Classroom | Work Sink | | 6 | 2 | EA | \$772 |





Building: Main Category: INTERIOR

| Group | Sub Group | Item | Location | Rank Qua | antity | Unit | Cost Reason | |
|-----------------|-----------|-----------|----------|-----------------|--------|------|-------------|--|
| Vocational Shop | Classroom | Work Sink | | 6 | 2 | EA | \$772 | |
| | | | INT | FRIOR Sub Total | | | \$1 075 410 | |

Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|----------|-----------|-------------|----------|------|----------|------|-------------|
| Casework | Classroom | Casework | | 7 | 65 | LF | \$0 |
| Casework | Classroom | Casework | | 6 | 18 | LF | \$644 |
| Casework | Classroom | Casework | | 7 | 23 | LF | \$0 |
| Casework | Classroom | Casework | | 6 | 53 | LF | \$1,895 |
| Casework | Classroom | Casework | | 6 | 44 | LF | \$1,573 |
| Casework | Classroom | Casework | | 6 | 32 | LF | \$1,144 |
| Casework | Classroom | Casework | | 6 | 46 | LF | \$1,645 |
| Casework | Classroom | Casework | | 7 | 28 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 52 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 52 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 52 | LF | \$ 0 |
| Casework | Classroom | Casework | | 7 | 52 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 28 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 28 | LF | \$0 |
| Casework | Classroom | Casework | | 6 | 52 | LF | \$1,859 |
| Casework | Classroom | Casework | | 7 | 52 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 57 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 28 | LF | \$0 |
| Casework | Classroom | Casework | | 6 | 66 | LF | \$2,360 |
| Casework | Classroom | Casework | | 7 | 28 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 57 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 57 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 48 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 57 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 57 | LF | \$0 |
| Casework | Classroom | Casework | | 6 | 52 | LF | \$1,859 |
| Casework | Classroom | Casework | | 7 | 23 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 52 | LF | \$0 |
| Casework | Classroom | Casework | | 7 | 57 | LF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 882 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 882 | SF | \$0 |





Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|-------------|-----------|-------------|-----------|------|----------|------|-------------|
| Ceiling | Classroom | Lay-In/Drop | | 6 | 352 | SF | \$755 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 882 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,018 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,132 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 882 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 882 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,134 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 882 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,305 | SF | \$2,799 |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,010 | SF | \$2,166 |
| Ceiling | Classroom | Lay-In/Drop | | 5 | 1,147 | SF | \$6,495 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 5 | 796 | SF | \$4,508 |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 352 | SF | \$755 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 882 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 932 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,018 | SF | \$0 |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,042 | SF | \$2,235 |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | |
| Chalk Board | Classroom | Chalk Board | | 4 | 24 | LF | \$2,917 |
| Chalk Board | Lunchroom | Chalk Board | 1st Floor | 4 | | LF | |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 |
| Chalk Board | Classroom | Chalk Board | | 4 | 14 | LF | \$1,702 |
| Chalk Board | Classroom | Chalk Board | | 4 | 24 | LF | \$2,917 |
| Chalk Board | Classroom | Chalk Board | | 4 | 24 | LF | \$2,917 |
| Chalk Board | Classroom | Chalk Board | | 4 | 16 | LF | \$1,945 |
| Chalk Board | Classroom | Chalk Board | | 4 | 18 | LF | \$2,188 |
| Chalk Board | Classroom | Chalk Board | | 4 | 18 | LF | \$2,188 |



Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|-------------|-------------------|------------------------|--------------------------|------|----------|------|-------------|
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | |
| Chalk Board | Classroom | Chalk Board | | 4 | 14 | LF | \$1,702 |
| Chalk Board | Classroom | Chalk Board | | 4 | 16 | LF | \$1,945 |
| Chalk Board | Classroom | Chalk Board | | 4 | 24 | LF | \$2,917 |
| Chalk Board | Classroom | Chalk Board | | 4 | 8 | LF | \$972 |
| Chalk Board | Classroom | Chalk Board | | 4 | 18 | LF | \$2,188 |
| Chalk Board | Classroom | Chalk Board | | 4 | 16 | LF | \$1,945 |
| Chalk Board | Classroom | Chalk Board | | 4 | 14 | LF | \$1,702 |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 |
| Chalk Board | Classroom | Chalk Board | | 4 | 24 | LF | \$2,917 |
| Chalk Board | Multipurpose Room | Chalk Board | 1st Floor Faculty Lounge | 4 | | LF | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | |
| Chalk Board | Classroom | Chalk Board | | 4 | 18 | LF | \$2,188 |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 |
| Chalk Board | Classroom | Chalk Board | | 4 | 24 | LF | \$2,917 |
| Chalk Board | Classroom | Chalk Board | | 4 | 8 | LF | \$972 |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | |
| Corridors | Corridors | Concrete Block | 3rd Floor | 6 | 1,883 | SF | \$5,385 |
| Corridors | Corridors | Concrete Block | Vestibule Total | 6 | 282 | SF | \$807 |
| Corridors | Corridors | Concrete Block | Middle Stair | 7 | 3,286 | SF | \$0 |
| Corridors | Corridors | Concrete Block | 2nd Floor | 6 | 1,857 | SF | \$5,311 |
| Corridors | Corridors | Concrete Block | 1st Floor | 6 | 3,129 | SF | \$8,949 |
| Corridors | Corridors | Concrete Block | North Stair | 7 | 3,262 | SF | \$0 |
| Corridors | Corridors | Concrete Block | South Stair | 7 | 3,262 | SF | \$0 |
| Corridors | Corridors | Concrete Epoxy/Painted | South Stair | 6 | 164 | SF | \$774 |
| Corridors | Corridors | Concrete Epoxy/Painted | North Stair | 6 | 164 | SF | \$774 |
| Corridors | Corridors | Concrete Epoxy/Painted | Middle Stair | 6 | 164 | SF | \$774 |
| Corridors | Corridors | Drinking Fountains | South Stair | | | EA | \$0 |
| Corridors | Corridors | Drinking Fountains | Vestibule Total | | | EA | \$0 |
| Corridors | Corridors | Drinking Fountains | Middle Stair | | | EA | \$0 |
| Corridors | Corridors | Drinking Fountains | North Stair | | | EA | \$0 |
| Corridors | Corridors | Drop/Lay-In | Vestibule Total | 5 | 64 | SF | \$362 |
| Corridors | Corridors | Drop/Lay-In | 1st Floor | 6 | 3,242 | SF | \$6,954 |
| Corridors | Corridors | Drop/Lay-In | 3rd Floor | 6 | 2,472 | SF | \$5,302 |
| Corridors | Corridors | Drop/Lay-In | 2nd Floor | 6 | 2,472 | SF | \$5,302 |
| | | | | | | | |





Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|------------------------|-----------------|------|----------|------|----------|--------|
| Corridors | Corridors | Exposed | Middle Stair | 6 | 548 | SF | \$1,034 | |
| Corridors | Corridors | Exposed | South Stair | 6 | 548 | SF | \$1,034 | |
| Corridors | Corridors | Exposed | North Stair | 6 | 548 | SF | \$1,034 | |
| Corridors | Corridors | Lay-In | 3rd Floor | 6 | 2,472 | EA | \$1,767 | |
| Corridors | Corridors | Lay-In | Vestibule Total | 6 | 396 | EA | \$283 | |
| Corridors | Corridors | Lay-In | 1st Floor | 6 | 4,037 | EA | \$2,886 | |
| Corridors | Corridors | Lay-In | 2nd Floor | 6 | 2,472 | EA | \$1,767 | |
| Corridors | Corridors | Pendant/Surface | Middle Stair | 6 | 473 | EA | \$338 | |
| Corridors | Corridors | Pendant/Surface | South Stair | 6 | 473 | EA | \$338 | |
| Corridors | Corridors | Pendant/Surface | North Stair | 6 | 473 | EA | \$338 | |
| Corridors | Corridors | Plaster/Drywall | Vestibule Total | 6 | 157 | SF | \$370 | |
| Corridors | Corridors | Stair Handrails | Middle Stair | 6 | 124 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 1st Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 3rd Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | North Stair | 6 | 124 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 2nd Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Vestibule Total | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | South Stair | 6 | 124 | LF | \$0 | |
| Corridors | Corridors | Stairs | 1st Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | South Stair | 6 | 52 | EA | \$372 | |
| Corridors | Corridors | Stairs | 3rd Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | Middle Stair | 6 | 52 | EA | \$372 | |
| Corridors | Corridors | Stairs | 2nd Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | Vestibule Total | | | EA | \$0 | |
| Corridors | Corridors | Stairs | North Stair | 6 | 52 | EA | \$372 | |
| Corridors | Corridors | Structural Glazed Tile | Vestibule Total | 6 | 185 | SF | \$1,323 | |
| Corridors | Corridors | Structural Glazed Tile | 2nd Floor | 6 | 1,857 | SF | \$13,278 | |
| Corridors | Corridors | Structural Glazed Tile | 3rd Floor | 6 | 1,883 | SF | \$13,463 | |
| Corridors | Corridors | Structural Glazed Tile | 1st Floor | 6 | 2,438 | SF | \$17,432 | |
| Corridors | Corridors | Student Lockers | Middle Stair | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 3rd Floor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Vestibule Total | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | North Stair | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 2nd Floor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 1st Floor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | South Stair | | | EA | \$0 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | Vestibule Total | 6 | 332 | SF | \$845 | |



Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|-------------------|-----------|---------------------|-----------------|------|----------|------|-------------|
| Corridors | Corridors | Tile/Sheet Flooring | Vestibule Total | 6 | 64 | SF | \$92 |
| Corridors | Corridors | Tile/Sheet Flooring | 3rd Floor | 6 | 2,472 | SF | \$3,535 |
| Corridors | Corridors | Tile/Sheet Flooring | 2nd Floor | 6 | 2,472 | SF | \$3,535 |
| Corridors | Corridors | Tile/Sheet Flooring | 1st Floor | 6 | 4,037 | SF | \$5,773 |
| Corridors | Corridors | Tile/Sheet Flooring | Middle Stair | 6 | 309 | SF | \$442 |
| Corridors | Corridors | Tile/Sheet Flooring | South Stair | 6 | 309 | SF | \$442 |
| Corridors | Corridors | Tile/Sheet Flooring | North Stair | 6 | 309 | SF | \$442 |
| Corridors | Corridors | Walls | Vestibule Total | 6 | 20 | SF | \$47 |
| Corridors Ceiling | Corridors | Plaster/Drywall | 1st Floor | 6 | 795 | SF | \$2,251 |
| Corridors Ceiling | Corridors | Plaster/Drywall | Vestibule Total | 6 | 332 | SF | \$940 |
| Floor | Classroom | Tile/Sheet | | 6 | 882 | SF | \$1,261 |
| Floor | Classroom | Tile/Sheet | | 6 | 882 | SF | \$1,261 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 1,042 | SF | \$1,490 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 882 | SF | \$1,261 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 1,134 | SF | \$1,622 |
| Floor | Classroom | Tile/Sheet | | 6 | 882 | SF | \$1,261 |
| Floor | Classroom | Tile/Sheet | | 6 | 1,010 | SF | \$1,444 |
| Floor | Classroom | Tile/Sheet | | 6 | 1,305 | SF | \$1,866 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 796 | SF | \$1,138 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 932 | SF | \$1,333 |
| Floor | Classroom | Tile/Sheet | | 6 | 1,018 | SF | \$1,456 |
| Floor | Classroom | Tile/Sheet | | 6 | 352 | SF | \$503 |
| Floor | Classroom | Tile/Sheet | | 6 | 882 | SF | \$1,261 |
| Floor | Classroom | Tile/Sheet | | 6 | 882 | SF | \$1,261 |
| Floor | Classroom | Tile/Sheet | | 6 | 882 | SF | \$1,261 |
| Floor | Classroom | Tile/Sheet | | 6 | 352 | SF | \$503 |
| Floor | Classroom | Tile/Sheet | | 6 | 1,132 | SF | \$1,619 |





Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|-----------------|-----------|-----------------|-----------|------|----------|------|-------------|
| Floor | Classroom | Tile/Sheet | | 6 | 1,147 | SF | \$1,640 |
| Floor | Classroom | Tile/Sheet | | 6 | 1,018 | SF | \$1,456 |
| LIBRARY_CEILING | Library | Drop/Lay-In | 2nd Floor | 5 | 2,171 | SF | \$12,294 |
| LIBRARY_WALL | Library | Concrete Block | 2nd Floor | 6 | 1,087 | SF | \$3,109 |
| LIBRARY_WALL | Library | Plaster/Drywall | 2nd Floor | 6 | 430 | | \$1,015 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 11 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 4 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 18 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 11 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 4 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EΑ | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EΑ | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 11 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 10 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 |
| Lighting | Classroom | Pendant/Surface | | 7 | 24 | EA | \$0 |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 |
| Marker Board | Lunchroom | Marker Board | 1st Floor | | | LF | \$0 |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 |





Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|--------------|-------------------|----------------|--------------------------|------|----------|------|-------------|
| Marker Board | Classroom | Marker Board | | | | LF | \$0 |
| Marker Board | Multipurpose Room | Marker Board | 1st Floor Faculty Lounge | | | LF | \$0 |
| Marker Board | Classroom | Marker Board | | | | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | | | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | 6 | 8 | LF | \$229 |
| Marker Board | Classroom | Marker Board | | | | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | | | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | 7 | 6 | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | 6 | 8 | LF | \$229 |
| Marker Board | Classroom | Marker Board | | | | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | | | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 |
| Marker Board | Classroom | Marker Board | | 4 | 10 | LF | \$1,216 |
| Marker Board | Classroom | Marker Board | | | | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | | | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | 4 | 10 | LF | \$1,216 |
| Marker Board | Classroom | Marker Board | | 4 | 12 | LF | \$1,459 |
| Marker Board | Classroom | Marker Board | | 7 | 6 | LF | \$ 0 |
| Marker Board | Classroom | Marker Board | | 7 | 6 | LF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 224 | SF | \$ 0 |
| Wall | Classroom | Concrete Block | | 7 | 564 | SF | \$ 0 |
| Wall | Classroom | Concrete Block | | 7 | 524 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 777 | SF | \$ 0 |
| Wall | Classroom | Concrete Block | | 7 | 144 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 144 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 144 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 144 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 204 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 204 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 564 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 254 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 1,017 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 777 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 524 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 254 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 6 | 540 | SF | \$1,544 |





Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost Reason |
|-------|-----------|-----------------|----------|------|----------|------|-------------|
| Wall | Classroom | Concrete Block | | 7 | 512 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 777 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 777 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 224 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 524 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 774 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 7 | 777 | SF | \$0 |
| Wall | Classroom | Concrete Block | | 6 | 736 | SF | \$2,105 |
| Wall | Classroom | Concrete Block | | 6 | 941 | SF | \$2,691 |
| Wall | Classroom | Concrete Block | | 6 | 813 | SF | \$2,325 |
| Wall | Classroom | Concrete Block | | 6 | 605 | SF | \$1,730 |
| Wall | Classroom | Concrete Block | | 7 | 1,017 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 240 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 240 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 850 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 550 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 6 | 388 | SF | \$915 |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,066 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,066 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,066 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,066 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,006 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,006 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 620 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 480 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 240 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 6 | 432 | SF | \$1,019 |
| Wall | Classroom | Plaster/Drywall | | 7 | 480 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 6 | 273 | SF | \$644 |
| Wall | Classroom | Plaster/Drywall | | 6 | 298 | SF | \$703 |
| Wall | Classroom | Plaster/Drywall | | 6 | 333 | SF | \$786 |
| Wall | Classroom | Plaster/Drywall | | 7 | 240 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 360 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 620 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 550 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 850 | SF | \$0 |
| Wall | Classroom | Plaster/Drywall | | 7 | 240 | SF | \$0 |





Building: Main Category: ROOM

| Group | Sub Group | Item | Location | Rank Qu | uantity | Unit | Cost | Reason |
|-------|-----------|-----------------|----------|-------------|---------|------|-----------|--------|
| Wall | Classroom | Plaster/Drywall | | 7 | 480 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 550 | SF | \$0 | |
| | | | ROO | M Sub Total | | | \$267,961 | |

Building Main Sub Total \$2,613,888

Building: SITE Category: SITE

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|-----------|---|-----------------------|----------|----------|------|----------|------------|
| Civil/Drainage | | Catch Basin | Entire Site | 6 | 4 | EA | \$2,174 | |
| Civil/Drainage | | Site Manhole | Entire Site | 7 | 4 | EA | \$0 | |
| Fencing | | Chain Link | West | 7 | 18 | LF | \$0 | |
| Fencing | | Ornamental Iron | South | 4 | 20 | LF | \$3,775 | |
| Fencing | | Ornamental Iron | Entire Site | 6 | 865 | LF | \$16,328 | |
| Landscape | | Benches | West | 7 | 2 | EA | \$0 | |
| Landscape | | Grass | South Lot | 5 | 6,669 | SF | \$8,678 | |
| Landscape | | Grass | West | 7 | 11,756 | SF | \$0 | |
| Landscape | | Grass | Site ¿ West | 4 | 800 | SF | \$3,169 | Dead Grass |
| Landscape | | Hardscape - Concrete | North, West and South | 7 | 2,360 | SF | \$0 | |
| Landscape | | Parkway trees | West | 4 | 3 | EA | \$7,362 | |
| Landscape | | Parkway trees | Entire Site | 7 | 13 | EA | \$0 | |
| Landscape | | Planting Beds/ Areas | West and North | 7 | 2,856 | SF | \$0 | |
| Landscape | | Trash Receptacles | West and South | 7 | 4 | EA | \$0 | |
| Parking Lot | | Lights, Pole Mounted | Entire Building | 7 | 6 | EA | \$0 | |
| Playground | | Playground Equipment - Pre-K 3-5 | North | 7 | 1 | EA | \$0 | |
| Playground | | Playground Equipment - School Age 5-12 | South | 7 | 1 | EA | \$0 | |
| Playground | | Playground Surfacing - Poured Surface | North and South | 7 | 4,656 | SF | \$0 | |
| Sidewalks | | Internal Walks | North and South | 7 | 313 | LF | \$0 | |
| Sidewalks | | Perimeter Sidewalks | Entire Site | 7 | 5,008 | SF | \$0 | |
| Signage | | Flag Pole | West | 7 | 2 | EA | \$0 | |
| Signage | | Marquee - Building Mounted Back Lighted | West | 7 | 1 | EA | \$0 | |
| | | | SITE | E Sub To | tal | | \$41,485 | |

SITE Sub Total \$41,485

Page 31 Assessment Date: 4/25/2013



4619 S Wolcott Ave Chicago, IL 60609

Building: SITE Category: SITE

Group Sub Group Item Location Rank Quantity Unit Cost Reason

Total Campus Need ^{2 3} \$2,655,374

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.



4619 S Wolcott Ave Chicago, IL 60609

| Room | Room | Voice | Data | Elect | Noise | Glaze | Operable | No. of | Window | Smart | Power | Room Type | Room Sub Type | Location |
|----------|------|--------|------|--------|-------|----------------|----------------|--------------|--------|-------|-------|------------|--------------------------------------|-------------------------|
| Number | Size | Outlet | | Outlet | | Window Area | Window Area | Window AC | Stop | Board | Strip | rtoom rypo | Troom Gas Type | 255411577 |
| uilding: | Main | | | | | | | | | | | | l | L |
| 02 | 1010 | 1 | 4 | 20 | 40 | 108 | 36 | | N | N | Υ | Classroom | | |
| 06 | 1147 | 1 | 5 | 20 | 40 | 144 | 48 | 40 | N | N | Υ | Classroom | | |
| 08 | 1042 | 1 | 4 | 22 | 40 | 144 | 48 | | N | N | Υ | Classroom | | |
| 18 | 796 | 1 | 3 | 20 | 40 | 108 | 36 | | N | N | Υ | Classroom | | |
| 02 | 1305 | 1 | 8 | 32 | 40 | 108 | 36 | | N | N | Υ | Classroom | | |
| 03 | 882 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 06 | 882 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 07 | 352 | 5 | 11 | 18 | 40 | 36 | 4 | | N | N | N | Classroom | | |
| 08 | 1018 | 1 | 8 | 24 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 09 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 11 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 15 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 17 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 18 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 19 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 21 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 22 | 882 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 00 | 1132 | 1 | 8 | 24 | 40 | 144 | 16 | | Υ | Υ | N | Classroom | | |
| 02 | 882 | 2 | 50 | 96 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 03 | 882 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 06 | 882 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 07 | 352 | 5 | 11 | 18 | 40 | 36 | 4 | | N | N | N | Classroom | | |
| 08 | 1018 | 1 | 8 | 24 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 09 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 11 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 15 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 19 | 932 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | Υ | N | Classroom | | |
| 21 | 1134 | 1 | 8 | 24 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| 22 | 882 | 1 | 7 | 18 | 40 | 108 | 12 | | Υ | N | N | Classroom | | |
| ther | 212 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 2nd Floor Girls South |
| ther | 212 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 2nd Floor Girls North |
| ther | 212 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 3rd Floor Boys North |
| ther | 212 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 3rd Floor Girls North |
| ther | 212 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 3rd Floor Girls South |
| ther | 212 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 3rd Floor Boys South |
| Other | 62 | | | | | | | | N | N | N | Restroom | Staff Restroom | 3rd Floor Women's Staff |



4619 S Wolcott Ave Chicago, IL 60609

| Room | Room | Voice | Data | Elect | Noise | Glaze | Operable | No. of | Window | Smart | Power | Room Type | Room Sub Type | Location |
|--------|------|--------|--------|--------|-------|----------------|----------------|--------------|--------|-------|-------|-------------------------------|---|---|
| Number | Size | Outlet | Outlet | Outlet | | Window Area | Window Area | Window AC | Stop | Board | Strip | | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, | |
| Other | 62 | | | | | | | | N | N | N | Restroom | Staff Restroom | 2nd Floor Women's Staff |
| Other | 62 | | | | | | | | N | N | N | Restroom | Staff Restroom | 3rd Floor Men's Staff |
| Other | 212 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 2nd Floor Boys North |
| Other | | | | | | | | | N | N | N | Corridors | | Middle Stair |
| Other | 46 | | | | | | | | N | N | N | Restroom | Staff Restroom | In Art Room 221 |
| Other | 62 | | | | | | | | N | N | N | Restroom | Staff Restroom | 2nd Floor Men's Staff |
| Other | 160 | | | 10 | | | | | N | N | Υ | Administrative Suites/Offices | | 1st Floor Main Office Conference |
| Other | | | | | | | | | N | N | N | Corridors | | North Stair |
| Other | 46 | | | | | | | | N | N | N | Restroom | Staff Restroom | 1st Floor Women |
| Other | 53 | | | | | | | | N | N | N | Restroom | Staff Restroom | 1st Floor Main Office Restroom |
| Other | 51 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | 1st Floor Men's Staff Locker |
| Other | 46 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | 1st Floor Women's Staff |
| Other | 157 | | | 10 | | | | | N | N | Υ | Administrative Suites/Offices | | 1st Floor in Main Office |
| Other | 48 | | | | | | | | N | N | N | Restroom | Early Childhood Student Restroom | In Preschool 102 |
| Other | 162 | | | 8 | | | | | N | N | Υ | Administrative Suites/Offices | | Vault/Office |
| Other | 48 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | In Rooms 106/108 |
| Other | 148 | | | 8 | | | | | N | N | Υ | Administrative Suites/Offices | | 1st Floor Assistant Principal's Office |
| Other | 237 | | | 8 | | | | | N | N | N | Administrative Suites/Offices | | 1st Floor Principal's Office |
| Other | 146 | | | 8 | | | | | N | N | Υ | Administrative Suites/Offices | | 1st Floor Case Manager Office |
| Other | 3503 | | | | | | | | N | N | N | Gymnasia | Standard Dedicated Gymnasium | 1st Floor |
| Other | 4037 | | | | | | | | N | N | N | Corridors | | 1st Floor |
| Other | 2472 | | | | | | | | N | N | N | Corridors | | 2nd Floor |
| Other | 2472 | | | | | | | | N | Ν | N | Corridors | | 3rd Floor |
| Other | 702 | | | 18 | | | | | N | N | Υ | Administrative Suites/Offices | | 1st Floor Main Office |
| Other | 164 | | | 4 | | | | | N | Ν | N | Administrative Suites/Offices | | Office In Library |
| Other | | | | | | | | | N | Ν | N | Corridors | | South Stair |
| Other | 396 | | | | | | | | N | N | N | Corridors | | Vestibule Total |
| Other | 2171 | | | | | | | | N | N | N | Library | | 2nd Floor |
| Other | 118 | | | | | | | | N | N | N | Kitchen | Cooking Kitchen | Dishwashing Room |
| Other | 2670 | | | | | | | | N | N | N | Lunch & Multipurpose Room | Multipurpose Room | 1st Floor Faculty Lounge |
| Other | 111 | | | 6 | | | | | N | N | N | Administrative Suites/Offices | | 1st Floor Office 1 in Multipurpose Room |
| Other | 46 | | | | | | | | N | N | N | Restroom | Staff Restroom | 1st Floor Men |
| Other | 47 | | | | | | | | N | N | N | Administrative Suites/Offices | | 1st Floor Telecommunications Office |
| Other | 212 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 2nd Floor Boys South |
| Other | 114 | | | 4 | | | | | N | N | Υ | Administrative Suites/Offices | | Gym Office |



4619 S Wolcott Ave Chicago, IL 60609

| Room S | ummar | у | | | | | | | | | |
|----------------|-------|-----------------|---|--|----------------------------|----------------|----------------|---|-------------------------------|--------------------|---|
| Room Number | | Voice Outlet | | | Operable Window Area | Window Stop | Smart Board | | 71 | Room Sub Type | Location |
| Other | 68 | | | | | N | N | N | Restroom | Locker/Shower Room | 1st Floor Boys Locker Room |
| Other | 60 | | | | | N | N | N | Restroom | Locker/Shower Room | 1st Floor Girls Locker Room |
| Other | 75 | | 6 | | | N | N | N | Administrative Suites/Offices | | 1st Floor Engineer's Office |
| Other | 961 | | | | | N | N | Ν | Kitchen | Cooking Kitchen | 1st Floor |
| Other | 2761 | | | | | N | N | Ν | Lunch & Multipurpose Room | Lunchroom | 1st Floor |
| Other | 76 | | 8 | | | N | N | Υ | Administrative Suites/Offices | | Manager's Office |
| Other | 111 | | 6 | | | N | N | N | Administrative Suites/Offices | | 1st Floor Office 2 in Multipurpose Room |