### **Facility Assessment Detail**

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About\_CPS/Policies\_and\_guidelines/Pages/facilitystandards.aspx.

#### **Condition Rankings and Descriptions**

- Rank 7: The item/system is new or in good condition and no work is required.
- Rank 6: The item/system requires general cleaning and/or routine maintenance.
- Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.1

#### Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

**Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

**Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	Main Entrance	6	880	SF	\$21,179	paint
Chimney		Metal Flue	upper roof - north	7	5	LF	\$0	
Doors		Exterior Steel Door	Roof	7	7	EA	\$0	
Doors		Exterior Steel Door	throughout	7	10	EA	\$0	
Doors		Side Lite	throughout	7	8	EA	\$0	
Doors		Store Front Door	throughout	7	16	EA	\$0	
Doors		Transom Lite	throughout	7	5	EA	\$0	
Entrance		Concrete Ramp	Northeast Entrance #4	7	30	LF	\$0	
Entrance		Entrance Controls - Audio	Entrances 1, 5 & 6	7	3	EA	\$0	
Entrance		Ramp Handrails	Northeast Entrance #4	7	38	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	893	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Building	6	15	EA	\$7,508	clean lenses
Lighting		Exterior Lights - Parapet or Roof Mounted	East Façade	5	2	EA	\$2,860	replace bulbs
Lighting		Exterior Lights - Wall Mounted	West Façade	4	1	EA	\$1,573	replace inoperable fixture

#### Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	13	EA	\$2,789	clean lenses
Lintels		Lintels - Stone	Entire Building	7	963	LF	\$0	
Parapet		Coping - Stone	Roofs	5	1,553	LF	\$135,424	replace sealant throughout
Parapet		Parapet > 30" Height	Roofs	7	1,553	LF	\$0	
Roof System		Interior Downspouts	Roofs	6	3,443	LF	\$0	
Roof System		Interior Downspouts	roof above gymnasium - south	5	48	LF	\$5,148	drain leaks into gymnasium - evidence of water ponding at drain
Roof System		Modified Bitumen Roof	Roofs	6	30,675	SF	\$217,133	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roofs	7	30,676	SF	\$0	
Superstructure		Steel	north mechanical room	5	60	SF	\$1,570	settling cracks in floor
Superstructure		Steel	Entire Building	7	96,104	SF	\$0	
Walls		Brick	Entire Building	7	49,203	SF	\$0	
Walls		Brick	3rd fl. east elevation, N & S	5	8	SF	\$181	step cracks in mortar
Walls		Concrete Block	chiller roof - isolated areas throughout	5	200	SF	\$3,861	cracks
Walls		Concrete Block	chiller roof	7	3,370	SF	\$0	
Walls		Stone - Cast	Entire Building	7	4,465	SF	\$0	
Windows		Curtain wall - Glazed Double Pane	Entire Building	7	1,816	SF	\$0	
Windows		Window - Guards perforated	1st Floor	7	3,168	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	6,864	SF	\$0	

EXTERIOR Sub Total

\$399,225

#### Building: Main Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Emergency System		Automatic Transfer switch	Electrical Room -1st Floor	7	1	EA	\$0
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	7	14	EA	\$0
Emergency System		Emergency Battery Packs - Toilets	Entire Building	7	5	EA	\$0
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	32	EA	\$7,459
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose roon	ns Lunchroom - 1st Floor	6	8	EA	\$1,865
Emergency System		Independent Electrical Service for emergency power	Electrical Room - 1st Floor	7	1	EA	\$0
Emergency System		Public Announcement System	Entire Building	7	96,164	SF	\$0
Emergency System		Security System - Intrusion detection	Entire Building	7	96,164	SF	\$0
Main Service		Main Electrical service 2000 A 277/480/3PH	Electrical Room - 1st Floor	7	1	EA	\$0
Power Distribution		Lighting and power panels	Entire Building	7	14	EA	<b>\$</b> 0

#### Building: Main Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank (	Quantity	Unit	Cost	Reason
Power Distribution		Main distribution panels 400-600 amp	Entire Building	7	2	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Entire Building	7	2	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Entire Building	7	4	EA	\$0	
			ELECTR	ICAL Sub Tota	ıl		\$9,324	
Building: Main								

#### Building: Main Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	96,164	SF	\$0	
Fire Alarm		Fire Alarm System	Entire Building	7	96,164	SF	\$0	
Fire Alarm		Fire Pump Controller	Entire Building	7	1	EA	\$0	
Pump Room Assembly		Fire Pump 25-50hp	Entire Building	7	1	EA	\$0	
Pump Room Assembly		Jockey Pump	Entire Building	7	1	EA	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	7	96,164	SF	\$0	
			FIRE PROTECTION Sub Total				\$0	

#### Building: Main Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 201 to 300 tons	Roof	6	1	EA	\$60,060	
Air Conditioning		Condensing Unit - Roof Mounted 5 to 10 tons	Roof	7	1	EA	\$0	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	6	3	EA	\$2,574	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water 15,001 - 20,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 4,000 to 8,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Fan Power Box With Hot Water Coil	Entire Building	7	50	EA	\$0	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	Mechanical Room	6	1	EA	\$2,431	
Air Handling Systems		Return Fans - Indoor 5,000 to 10,000 CFM	Mechanical Room	6	1	EA	\$1,716	
Air Handling Systems		Return Fans - Indoor greater than 20,000 CFM	Mechanical Room	6	1	EA	\$3,289	
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	Entire Building	7	17	EA	\$0	
Boiler Systems		Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler 1,001MBH-2,000 MBH	Mechanical Room	6	3	EA	\$23,595	

### Building: Main Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Boiler Systems		Boiler Auxiliary Non-Condensing Hot Water Boiler 1,001MBH-2,000 MBH	Mechanical Room	6	3	EA	\$15,015	
Boiler Systems		Chemical Feed System (Steam Boilers)	Mechanical Room	6	2	EA	\$4,290	
Boiler Systems		Chemical Pot Feeder - Hot Water	Mechanical Room	7	1	EA	\$0	
Boiler Systems		Combustion Dampers	Mechanical Room	6	2	EA	\$572	
Boiler Systems		Gas Boosters	Mechanical Room	7	2	EA	\$0	
Heating Devices		Radiators - Hot Water	Mechanical Room	7	10	EA	\$0	
Heating Devices		Radiators - Hot Water	Entire Building	7	20	EA	\$0	
Heating Devices		Wall Heater - Electric	Entire Building	7	1	EA	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	7	20,000	LF	\$0	
Mechanical Plumbing		Pumps - Chilled Water 10 to 20 HP	Mechanical Room	7	3	EA	\$0	
Mechanical Plumbing		Pumps - Hot Water 11 to 20 HP	Mechanical Room	7	2	EA	\$0	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	7	96,164	SF	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	70	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	5	EA	\$2,145	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	2	EA	\$0	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	6	1	EA	\$157	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Kitchen	7	1	EA	\$0	
			MECHANIC	CAL Sub To	al		\$115,844	

### Building: Main Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost R	eason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Mechanical Room	6	2	EA	\$13,442	
Hot Water		Storage Tank less than 500 gallons	Entire Building	7	1	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	96,164	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	96,164	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	96,164	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	96,164	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	96,164	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	96,164	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	96,164	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	96,164	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	96,164	SF	\$0	
Piping		Storm Piping	Entire Building	7	96,164	SF	\$0	

Building: Main Category: PLUMBIN	G							
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Vent Piping	Entire Building	7	96,164	SF	\$0	
			PLUMBING	Sub To	tal		\$13,442	
Building: Main Category: INTERIOR	ł							
Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 105, Case Manager's Office	5 7	538	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 204 (2-31)	6	620	SF	\$1,330	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Work Room 208A (2-22)	7	125	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Office 212B (2-17)	7	115	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Vault/Workroom #107E	7	245	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 217, Gym Coordinator's Office	7	105	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 104 (1-47)	7	875	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Parent's Room (1-46)	7	300	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Counselor 108A (1-42)	7	97	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Kitchen Manager's Office	7	60	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Teacher's Resource Room #101-103	7	1,448	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Speech 204A (2-30)	7	113	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main Office	7	558	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Conference Room # 107A	7	301	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Principal's Office Room 107B	7	134	SF	\$0	
dministrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Asst Principal's Office # 107C	7	136	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Office, Room 219	7	85	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 113 District Office	7	198	SF	\$0	

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	ltem	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Faculty Lounge	7	813	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Counselor's Office # 107H	7	122	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Social Services 108B (1-41)	7	97	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Nurse's Office 212A (2-18)	7	86	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Engineer's Office	7	85	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Social Services 108B (1-41)	6	97	SF	\$139
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Speech 204A (2-30)	6	113	SF	\$162
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office	7	558	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Conference Room # 107A	7	301	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Principal's Office Room 107B	7	134	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Asst Principal's Office # 107C	7	136	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Counselor 108A (1-42)	6	97	SF	\$139
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	Engineer's Office	7	85	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 104 (1-47)	7	875	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Kitchen Manager's Office	7	60	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 204 (2-31)	7	620	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Work Room 208A (2-22)	7	125	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Office 212B (2-17)	7	115	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Parent's Room (1-46)	7	300	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Teacher's Resource Room #101-103	7	1,448	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 105, Case Manager's Office	7	538	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Vault/Workroom #107E	7	245	SF	\$0

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	ltem	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Counselor's Office # 107H	7	122	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Faculty Lounge	7	813	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 113 District Office	7	198	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Office, Room 219	7	85	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 217, Gym Coordinator's Office	7	105	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Nurse's Office 212A (2-18)	7	86	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Teacher's Resource Room #101-103	7	24	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main Office	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 105, Case Manager's Office	7	9	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Conference Room # 107A	7	4	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Principal's Office Room 107B	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Asst Principal's Office # 107C	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Vault/Workroom #107E	7	4	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 217, Gym Coordinator's Office	7	3	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Office, Room 219	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Counselor's Office # 107H	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Faculty Lounge	7	12	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 113 District Office	7	4	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Nurse's Office 212A (2-18)	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Engineer's Office	7	1	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 204 (2-31)	7	10	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Kitchen Manager's Office	7	1	SF	\$0

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Work Room 208A (2-22)	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Social Services 108B (1-41)	7	1	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Office 212B (2-17)	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 104 (1-47)	7	13	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Counselor 108A (1-42)	7	1	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Parent's Room (1-46)	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Speech 204A (2-30)	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Counselor 108A (1-42)	7	530	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Vault/Workroom #107E	7	410	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Asst Principal's Office # 107C	7	507	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Work Room 208A (2-22)	7	460	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Counselor's Office # 107H	7	598	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Speech 204A (2-30)	7	426	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Nurse's Office 212A (2-18)	7	364	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Social Services 108B (1-41)	7	530	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Parent's Room (1-46)	7	800	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Office 212B (2-17)	7	400	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Kitchen Manager's Office	7	140	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Engineer's Office	7	140	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 104 (1-47)	6	1,468	SF	\$4,198
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Conference Room # 107A	7	793	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 204 (2-31)	7	1,009	SF	\$0

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Faculty Lounge	7	1,482	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 217, Gym Coordinator's Office	7	210	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 113 District Office	7	500	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Office, Room 219	7	342	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Teacher's Resource Room #101-103	7	1,781	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 105, Case Manager's Office	7	1,144	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	7	735	SF	\$0
Classrooms		Work Sink	Room 104 (1-47	7	1	EA	\$0
Classrooms		Work Sink	Room 112 (1-25)	7	2	EA	\$0
Computer Labs		Wireless System	Computer Room 206 (2-27)	7	1	EA	\$0
Corridor		Ceiling - Lay-In	Entire Building	6	25,432	SF	\$54,552
Corridor		Flooring Terrazzo	Entire Building	7	25,432	SF	\$0
Corridor		Lighting - Lay-In	Entire Building	7	225	SF	\$0
Corridor		Lighting - Pendant/ Surface	Entire Building	7	234	SF	\$O
Corridor		Stair Handrails	Entire Building	7	182	LF	\$0
Corridor		Stairs - Terrazzo	Entire Building	7	168	LF	\$0
Corridor		Walls - Structural Glazed Tile	Entire Building	7	17,440	SF	\$0
Doors		Interior Steel Doors incl hw	throughout	7	46	EA	\$0
Doors		Interior Wood Doors incl hw	throughout	7	93	EA	\$0
Doors		Side-lite	Main Entrance	7	4	SF	\$0
Doors		Side-lite	throughout	7	189	SF	\$0
Doors		Store Front Door	Main Entrance #1	7	6	EA	\$0
Doors		Transom Window	Main Entrance	7	3	SF	\$0
Drinking Fountains		Double Water Cooler	Entire Building	7	6	EA	\$0
Drinking Fountains		Single Fountain	Rooms 100, 102, 110 & 112 (1-54, 1-50, 1-30 & 1-25)	7	4	EA	\$0
Fine Art Room		Work Sink	Workroom 208A (2-22)	7	1	EA	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	2nd Floor	7	100	EA	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Exposed	2nd Floor	7	5,026	SF	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	2nd Floor	7	5,026	SF	\$0

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	2nd Floor	7	20	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	2nd Floor	7	4,176	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	2nd Floor	7	4,176	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	1st Floor	7	1,428	SF	\$0	
Kitchen	Cooking Kitchen	Flooring - Concrete	1st Floor	7	1,428	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Lay-In	1st Floor	7	12	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Concrete Block	1st Floor	7	1,720	SF	\$0	
Library	Library	Flooring Carpet	2nd Floor Room 208 (2-24)	7	3,100	SF	\$0	
Library	Library	Lighting - Lay-In	2nd Floor Room 208 (2-24)	7	40	SF	\$0	
Locker/Shower Room		Accessories	Room 218, 218A	7	251	SF	\$0	
Locker/Shower Room		Accessories	Room 220, 220A	7	224	SF	\$0	
Locker/Shower Room		Benches	Room 218, 218A	7	12	LF	\$0	
Locker/Shower Room		Floor Drain	Room 218, 218A	7	2	EA	\$0	
Locker/Shower Room		Flooring Epoxy/Painted	Room 218, 218A	7	251	SF	\$0	
Locker/Shower Room		Flooring Epoxy/Painted	Room 220, 220A	7	224	SF	\$0	
Locker/Shower Room		Lighting - Lay-In	Room 218, 218A	7	40	SF	\$0	
Locker/Shower Room		Lighting - Lay-In	Room 220. 220A	7	15	SF	\$0	
Locker/Shower Room		Lockers	Rooms 218, 218A	7	20	EA	\$0	
Locker/Shower Room		Lockers	Rooms 220, 220A	7	20	EA	\$0	
Locker/Shower Room		Showers	Rooms 218, 218A Boy's Room	7	3	EA	\$0	
Locker/Shower Room		Showers	Rooms 220, 220A, Girl's Room	7	3	EA	\$0	
Locker/Shower Room		Structural Glazed Tile	Rooms 220, 220A	7	300	SF	\$0	
Locker/Shower Room		Structural Glazed Tile	Rooms 218, 218A	7	730	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	1st Floor	6	4,685	SF	\$10,049	Has some water damaged tiles
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	4,685	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	1st Floor	7	55	SF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	30	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	7	5,064	SF	\$0	
MDF/IDF		Finishes	2nd Floor	7	148	SF	\$0	
MDF/IDF		Ventilation and Cooling	2nd Floor	7	1	EA	\$0	
Mechanical/Service Rooms		Boiler Room	4th Floor	7	2,233	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Room 121 Janitor's Closet in Kitchen	7	1	SF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Janitor's Closet	3rd Floor	7	20	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	2nd Floor	7	20	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	1st Floor	7	1	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	245	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	2nd Floor	7	16	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	4th Floor	7	1,229	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	156	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	3rd Floor	7	16	SF	\$0	
Mechanical/Service Rooms		Storage Room	Room 112 (1-25)	7	1,000	SF	\$0	
Mechanical/Service Rooms		Storage Room	Rooms 100B, 102B, 110B & 112B (1-53, 1-48, 1-29 & 1- 24)	7	380	SF	\$0	
Mechanical/Service Rooms		Storage Room	2nd Floor	7	553	SF	\$0	
Mechanical/Service Rooms		Storage Room	Room 120 Kitchen Storage	7	210	SF	\$0	
Mechanical/Service Rooms		Storage Room	Book Storage 208B (2-21)	7	76	SF	\$0	
Mechanical/Service Rooms		Storage Room	Music Storage 304A (3-18)	7	140	SF	\$0	
Mechanical/Service Rooms		Storage Room	Art Storage 310A (3-08)	6	140	SF	\$661	
Mechanical/Service Rooms		Storage Room	Art Storage 312A (3-07)	6	140	SF	\$661	
Mechanical/Service Rooms		Storage Room	Science Prep 302A (3-18)	7	140	SF	\$0	
Mechanical/Service Rooms		Storage Room	Room 221A in Gym	7	26	SF	\$0	
Mechanical/Service Rooms		Storage Room	Storage 2-34	7	113	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Room 112A (1-23)	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Floor	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Room 218B, Boy's Room in Gym	7	54	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Room 110A (1-28)	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Room 102A (1-48)	7	40	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Room 100A (1-52)	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boy's Room	7	193	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Room 107G in Main Office	7	41	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Room 2220B, Girl's Room in Gym	7	54	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Women's Room near Kitchen	7	86	SF	\$0	

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Girl's Room	7	436	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Boy's Room	7	503	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Boy's Room	7	503	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Girl's Room	7	436	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Girl's Room	7	218	SF	\$0
Staff Restroom	Staff Restroom	Accessories	3rd Floor	7	42	SF	\$O
Staff Restroom	Staff Restroom	Accessories	2nd Floor	7	42	SF	\$O
Staff Restroom	Staff Restroom	Accessories	Men's Room near Kitchen	7	86	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	2nd Floor Girl's Room	7	436	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Men's Room near Kitchen	7	86	SF	<b>\$</b> 0
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd Floor	7	42	SF	\$O
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd Floor	7	42	SF	\$O
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	1st Floor Girl's Room	7	218	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	3rd Floor Girl's Room	7	436	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	2nd Floor Boy's Room	7	503	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	3rd Floor Boy's Room	7	503	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Women's Room near Kitchen	7	86	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Room 107G in Main Office	7	41	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	1st Floor Boy's Room	7	193	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st Floor	7	42	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	Room 112A (1-23)	7	40	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	Room 102A (1-48)	7	40	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	Room 100A (1-52)	7	40	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	Room 218B, Boy's Room in Gym	7	54	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	Room 110A (1-28)	7	40	SF	\$0

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Early Childhood Student Restroom	Floor Drain	Room 110A (1-28)	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Room 218B, Boy's Room in Gym	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boy's Room	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Boy's Room	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Girl's Room	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Room 2220B, Girl's Room in Gym	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Floor Drain	Room 112A (1-23)	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Girl's Room	7	2	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Floor Drain	Room 102A (1-48)	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Boy's Room	7	2	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Floor Drain	Room 100A (1-52)	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Girl's Room	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	Room 2220B, Girl's Room in Gym	7	55	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Concrete	Women's Room near Kitchen	7	86	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	Room 218B, Boy's Room in Gym	7	54	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	1st Floor Girl's Room	7	218	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Concrete	Men's Room near Kitchen	7	86	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	Room 112A (1-23)	7	40	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	Room 110A (1-28)	7	40	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	Room 102A (1-48)	7	40	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st Floor	7	42	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st Floor Boy's Room	7	193	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Terrazzo	Room 107G in Main Office	7	41	SF	\$0

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd Floor Boy's Room	7	503	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd Floor Boy's Room	7	503	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd Floor Girl's Room	7	436	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd Floor	7	42	SF	\$O
Staff Restroom	Staff Restroom	Flooring - Terrazzo	3rd Floor	7	42	SF	\$O
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd Floor Girl's Room	7	436	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	Room 100A (1-52)	7	40	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Boy's Room	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Girl's Room	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Girl's Room	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Boy's Room	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Boy's Room	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Girl's Room	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	Room 218B, Boy's Room in Gym	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Boy's Room	7	6	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Girl's Room	7	6	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	2nd Floor	7	1	EA	\$O
Staff Restroom	Staff Restroom	Lavatory	3rd Floor	7	1	EA	\$O
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Girl's Room	7	6	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Boy's Room	7	6	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	Room 2220B, Girl's Room in Gym	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Lavatory	Room 110A (1-28)	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	Men's Room near Kitchen	7	1	EA	\$O
Staff Restroom	Staff Restroom	Lavatory	Room 107G in Main Office	7	1	EA	\$0

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Early Childhood Student Restroom	Lavatory	Room 100A (1-52)	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boy's Room	7	3	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Lavatory	Room 102A (1-48)	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	1st Floor	7	1	EA	\$O
Staff Restroom	Early Childhood Student Restroom	Lavatory	Room 112A (1-23)	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	Women's Room near Kitchen	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Girl's Room	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Room 2220B, Girl's Room in Gym	7	2	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd Floor Boy's Room	7	10	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd Floor Boy's Room	7	10	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd Floor Girl's Room	7	10	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st Floor Girl's Room	7	5	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd Floor	7	1	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	Men's Room near Kitchen	7	2	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd Floor	7	1	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	Room 100A (1-52)	7	1	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	Room 107G in Main Office	7	1	SF	\$O
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st Floor Boy's Room	7	5	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st Floor	7	1	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	Room 112A (1-23)	7	1	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	Room 110A (1-28)	7	1	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	Room 102A (1-48)	7	1	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	Women's Room near Kitchen	7	2	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Room 218B, Boy's Room in Gym	7	2	SF	\$0

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd Floor Girl's Room	7	10	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Girl's Room	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Girl's Room	7	6	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Boy's Room	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Boy's Room	7	4	EA	\$0
Staff Restroom	Staff Restroom	Partitions	Women's Room near Kitchen	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Girl's Room	7	6	EA	\$0
Staff Restroom	Staff Restroom	Partitions	Men's Room near Kitchen	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boy's Room	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd Floor Boy's Room	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boy's Room	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Boy's Room	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor Girl's Room	7	590	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	3rd Floor	7	252	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd Floor	7	252	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor Girl's Room	7	365	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd Floor Girl's Room	7	590	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor Boy's Room	7	754	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Men's Room near Kitchen	7	125	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd Floor Boy's Room	7	754	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Room 107G in Main Office	7	312	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor Boy's Room	7	306	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st Floor	7	252	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	Room 112A (1-23)	7	260	SF	\$0

1119 N Cleveland Ave Chicago, IL 60610

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	Room 110A (1-28)	7	260	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	Room 102A (1-48)	7	260	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	Room 100A (1-52)	7	260	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Women's Room near Kitchen	7	125	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Room 2220B, Girl's Room in Gym	7	342	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Room 218B, Boy's Room in Gym	7	342	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Boy's Room	7	4	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Water Closet	Room 102A (1-48)	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Girl's Room	7	8	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	3rd Floor	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	2nd Floor	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Girl's Room	7	4	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Water Closet	Room 100A (1-52)	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Boy's Room	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	Room 218B, Boy's Room in Gym	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	Room 2220B, Girl's Room in Gym	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	Women's Room near Kitchen	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	Men's Room near Kitchen	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	Room 107G in Main Office	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boy's Room	7	2	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	1st Floor	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Water Closet	Room 112A (1-23)	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Water Closet	Room 110A (1-28)	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Girl's Room	7	8	EA	\$0

#### Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank Q	Quantity	Unit	Cost Reason	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	3	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
			INTER	RIOR Sub Total	I		\$71,890	

Group	Sub Group	Item	Location	Rank C	Quantity	Unit	Cost Reason	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Principal's Office Room 107B	7	507	SF	\$0	
Casework	Classroom	Casework		7	35	LF	\$0	
Casework	Classroom	Casework		7	35	LF	<b>\$</b> 0	
Casework	Classroom	Casework		7	22	LF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Casework	Classroom	Casework		7	22	LF	\$0
Casework	Classroom	Casework		7	39	LF	\$0
Casework	Classroom	Casework		7	33	LF	\$0
Casework	Classroom	Casework		7	45	LF	\$0
Casework	Classroom	Casework		7	35	LF	\$O
Casework	Classroom	Casework		7	22	LF	\$O
Casework	Classroom	Casework		7	35	LF	\$O
Casework	Classroom	Casework		7	33	LF	\$O
Casework	Classroom	Casework		7	60	LF	\$O
Casework	Classroom	Casework		7	33	LF	\$O
Casework	Classroom	Casework		7	35	LF	\$O
Casework	Classroom	Casework		7	35	LF	\$O
Casework	Classroom	Casework		7	35	LF	\$O
Casework	Classroom	Casework		7	22	LF	\$O
Casework	Classroom	Casework		7	26	LF	\$O
Casework	Classroom	Casework		7	35	LF	\$O
Casework	Classroom	Casework		7	35	LF	\$O
Casework	Classroom	Casework				LF	\$O
Casework	Classroom	Casework		7	59	LF	\$O
Casework	Classroom	Casework		7	59	LF	\$O
Casework	Classroom	Casework		7	45	LF	\$O
Casework	Classroom	Casework		7	38	LF	\$O
Casework	Classroom	Casework		7	35	LF	\$0
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework		7	35	LF	\$0
Casework	Classroom	Casework		7	26	LF	\$0
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	585	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	908	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	830	SF	\$1,780
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	1,180	SF	\$2,531
Ceiling	Classroom	Lay-In/Drop		7	549	SF	\$O
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$O
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0

Building:	Main
Category:	ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	850	SF	\$1,823
Ceiling	Classroom	Lay-In/Drop		6	850	SF	\$1,823
Ceiling	Classroom	Lay-In/Drop		6	982	SF	\$2,106
Ceiling	Classroom	Lay-In/Drop		6	850	SF	\$1,823
Ceiling	Classroom	Lay-In/Drop		6	620	SF	\$1,330
Ceiling	Classroom	Lay-In/Drop		6	1,180	SF	\$2,531
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	945	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	850	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	908	SF	\$0
Ceiling	Classroom	Lay-In/Drop		6	830	SF	\$1,780
Ceiling	Classroom	Lay-In/Drop		7	550	SF	\$0
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459

Building:	Main
Category:	ROOM

Group	Sub Group	Item	Location	Rank C	Quantity	Unit	Cost Reason	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
CLASSROOM	Classroom	Science Lab Elements		7	1,180	SF	\$0	
Floor	Classroom	Tile/Sheet		7	850	SF	\$0	
Floor	Classroom	Tile/Sheet		6	982	SF	\$1,404	
Floor	Classroom	Tile/Sheet		7	830	SF	\$O	
Floor	Classroom	Tile/Sheet		7	830	SF	\$0	
Floor	Classroom	Tile/Sheet		7	850	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$O	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$O	
Floor	Classroom	Tile/Sheet		7	945	SF	\$O	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$O	
Floor	Classroom	Tile/Sheet		6	1,180	SF	\$1,687	
Floor	Classroom	Tile/Sheet		7	620	SF	\$O	
Floor	Classroom	Tile/Sheet		7	1,180	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$O	
Floor	Classroom	Tile/Sheet		7	585	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$O	
Floor	Classroom	Tile/Sheet		7	908	SF	\$0	
Floor	Classroom	Tile/Sheet		7	850	SF	\$0	
Floor	Classroom	Tile/Sheet		7	549	SF	\$0	
Floor	Classroom	Tile/Sheet		7	550	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$O	
Floor	Classroom	Tile/Sheet		7	850	SF	\$0	
Floor	Classroom	Tile/Sheet		7	850	SF	\$0	
Floor	Classroom	Tile/Sheet		7	850	SF	\$0	
Floor	Classroom	Tile/Sheet		7	908	SF	\$0	

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
LIBRARY_CEILING	Library	Drop/Lay-In	2nd Floor Room 208 (2-24)	6	3,100	SF	\$6,650
LIBRARY_WALL	Library	Concrete Block	2nd Floor Room 208 (2-24)	7	1,512	SF	\$0
LIBRARY_WALL	Library	Plaster/Drywall	2nd Floor Room 208 (2-24)	7	620		\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	10	EA	\$0
Lighting	Classroom	Lay-In		7	15	EA	\$0
Lighting	Classroom	Lay-In		7	13	EA	\$0
Lighting	Classroom	Lay-In		7	13	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	16	EA	\$0
Lighting	Classroom	Lay-In		7	16	EA	\$0
Lighting	Classroom	Lay-In		7	13	EA	\$0
Lighting	Classroom	Lay-In		7	16	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	15	EA	\$0
Lighting	Classroom	Lay-In		7	15	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	9	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Lighting	Classroom	Lay-In		7	12	EA	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0

Group	Sub Group	Item	Location	Rank C	uantity	Unit	Cost Reason
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	40	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$O
Marker Board	Classroom	Marker Board		7	12	LF	\$O
Marker Board	Classroom	Marker Board		7	12	LF	\$O
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	Room 2220B, Girl's Room in Gym	7	55	SF	\$O
Wall	Classroom	Concrete Block		7	630	SF	\$O
Wall	Classroom	Concrete Block		7	239	SF	\$O
Wall	Classroom	Concrete Block		7	239	SF	\$O
Wall	Classroom	Concrete Block		7	630	SF	\$O
Wall	Classroom	Concrete Block		7	630	SF	\$O
Wall	Classroom	Concrete Block		7	378	SF	\$O
Wall	Classroom	Concrete Block		7	756	SF	\$O
Wall	Classroom	Concrete Block		7	756	SF	\$O
Wall	Classroom	Concrete Block		7	630	SF	\$O
Wall	Classroom	Concrete Block		7	630	SF	\$O
Wall	Classroom	Concrete Block		7	845	SF	\$O
Wall	Classroom	Concrete Block		7	630	SF	\$0

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		6	1,200	SF	\$3,432	
Wall	Classroom	Concrete Block		7	378	SF	\$0	
Wall	Classroom	Concrete Block		7	630	SF	\$0	
Wall	Classroom	Concrete Block		6	1,360	SF	\$3,890	
Wall	Classroom	Concrete Block		7	600	SF	\$0	
Wall	Classroom	Concrete Block		7	600	SF	\$0	
Wall	Classroom	Concrete Block		7	800	SF	\$0	
Wall	Classroom	Concrete Block		7	764	SF	\$0	
Wall	Classroom	Concrete Block		7	630	SF	\$0	
Wall	Classroom	Concrete Block		6	1,200	SF	\$3,432	
Wall	Classroom	Concrete Block		6	1,200	SF	\$3,432	
Wall	Classroom	Concrete Block		7	1,000	SF	\$0	
Wall	Classroom	Concrete Block		6	490	SF	\$1,401	
Wall	Classroom	Concrete Block		6	600	SF	\$1,716	
Wall	Classroom	Concrete Block		7	380	SF	\$0	
Wall	Classroom	Concrete Block		7	800	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	216	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	432	SF	\$1,019	Wall damaged due to marker board removal
Wall	Classroom	Plaster/Drywall		7	216	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	245	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	307	SF	\$724	
Wall	Classroom	Plaster/Drywall		7	500	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	245	SF	\$578	
Wall	Classroom	Plaster/Drywall		6	470	SF	\$1,109	
Wall	Classroom	Plaster/Drywall		6	470	SF	\$1,109	
Wall	Classroom	Plaster/Drywall		7	432	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	490	SF	\$1,156	

#### Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	425	SF	\$1,003	
Wall	Classroom	Plaster/Drywall		6	425	SF	\$1,003	
Wall	Classroom	Plaster/Drywall		7	860	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	260	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	695	SF	\$1,640	
Wall	Classroom	Plaster/Drywall		6	490	SF	\$1,156	
Wall	Classroom	Plaster/Drywall		6	490	SF	\$1,156	
Wall	Classroom	Plaster/Drywall		6	425	SF	\$1,003	
			ROO	M Sub To	tal		\$87,374	
			Building Main	Sub Tot	al		\$697,098	

#### Building: SITE Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	throughout site	7	6	EA	\$0	
Civil/Drainage		Site Manhole	throughout site	7	2	EA	\$0	
Fencing		Chain Link	north site - at gas regulators	7	15	LF	\$0	
Fencing		Ornamental Iron	NE parking lot	4	3	LF	\$566	
Fencing		Ornamental Iron	throughout site	6	816	LF	\$15,403	paint
Landscape		Benches	throughout site	7	16	EA	\$0	
Landscape		Grass	throughout site	6	17,297	SF	\$6,926	water and seed
Landscape		Hardscape - Concrete	west site	7	2,828	SF	\$0	
Landscape		Irrigation	planter areas	5	5,826	SF	\$10,997	irrigation control boxes are missing lids and may not operate.
Landscape		Parkway trees	throughout site perimeter	7	20	EA	\$0	
Landscape		Parkway trees	west site perimeter	4	2	EA	\$4,908	cut down to stumps
Landscape		Planting Beds/ Areas	throughout site	7	4,881	SF	\$0	
Landscape		Trash Receptacles	throughout site	7	7	EA	\$0	
Parking Lot		Asphalt	NE site	6	18,032	SF	\$15,471	repair cracks and seal coat
Parking Lot		Concrete	NE site	7	1,810	SF	\$0	repair cracks
Parking Lot		Concrete Curbs	NE site	7	744	LF	\$0	
Parking Lot		Lighting	NE site	7	4	EA	\$0	
Parking Lot		Parking lot interior plantings	NE site	7	189	LF	\$0	
Parking Lot		Trash Compactor	NE site	7	1	EA	\$0	

### Building: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Vehicular Screening	NE site	7	387	LF	\$0	
Playground		Playground Equipment - Combo 3-12	SE site	7	1	EA	\$0	
Playground		Playground Equipment - School Age 5-12	SE site	7	1	EA	\$0	
Playground		Playground Surfacing - Square Rubber Mats	SE site	4	3,602	SF	\$79,838	
Sidewalks		Internal Walks	throughout site	7	847	LF	\$0	
Sidewalks		Internal Walks	SW site, play area	6	11	LF	\$104	cracks
Sidewalks		Perimeter Sidewalks	throughout site perimeter	7	7,259	SF	\$0	
Sidewalks		Perimeter Sidewalks	N site perimeter	6	20	SF	\$38	cracks
Signage		Flag Pole	west site	7	1	EA	\$0	
Signage		Monument Sign - Lighted	NW site	7	1	EA	\$0	
			SITE	Sub To	tal		\$134,251	
			SITE S	ub Tot	al		\$134,251	
Total Campus	Nood 23						\$831,350	_

<sup>1</sup> It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

<sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.



Room Su	ımmar	у												
Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building:	Main													1
100	1000	1	9	20	57	180	48	0	Ν	Ν	Y	Classroom		
102	1000	1	9	20	57	180	48	0	Ν	Ν	Y	Classroom		
106	945	1	9	20	57	180	48	0	Ν	Ν	Ν	Classroom		
110	1000	1	9	20	57	180	48	0	Ν	Ν	Y	Classroom		
111	850	1	6	12	57	180	48		Ν	Ν	Ν	Classroom		
201	850	1	5	18	57	108	9		Ν	Ν	Y	Classroom		
202	620	1	8	18	57	72	6	0	Y	Ν	Ν	Classroom		
203	850	1	5	18	57	108	9		Ν	Ν	Y	Classroom		
205	585	1	7	18	57	72	6		Ν	Ν	Y	Classroom		
206	982	1	35	62	57	108	9	0	Y	Y	Y	Classroom		
207	850	1	7	12	57	108	9		Y	Ν	Ν	Classroom		
209	850	1	7	12	57	108	9		Y	Ν	Ν	Classroom		
210	830	1	10	22	57	108	9	0	Y	Ν	Ν	Classroom		
211	850	1	7	12	57	108	9		Y	Ν	Ν	Classroom		
212	830	1	10	22	57	108	9	0	Y	Ν	Ν	Classroom		
213	850	1	7	12	57	108	9		Y	Ν	Ν	Classroom		
301	908	1	8	14	57	108	9		Ν	Ν	Y	Classroom		
302	1180	1	9	24	57	144	12	0	Y	Ν	Ν	Classroom		
303	908	1	8	22	57	108	9		Ν	Ν	Y	Classroom		
304	1180	1	9	24	57	144	12	0	Y	Ν	Y	Classroom		
305	549	1	5	18	57	72	6		Ν	Ν	Y	Classroom		
306	850	1	9	20	57	108	9	0	Y	Ν	Ν	Classroom		
307	850	1	5	14	57	108	9		Y	Ν	Ν	Classroom		
308	550	1	8	20	57	72	6	0	Y	Ν	Y	Classroom		
309	850	1	5	14	57	108	9		Y	Ν	Ν	Classroom		
310	850	1	9	20	57	108	9	0	Y	Ν	Y	Classroom		
311	850	1	5	14	57	108	9		Y	Ν	Ν	Classroom		
312	850	1	9	20	57	108	9	0	Y	Ν	Ν	Classroom		
313	850	1	5	14	57	108	9	0	Y	Ν	Ν	Classroom		
Other	436								Ν	Ν	Ν	Restroom	Children's Standard Student Restroom	3rd Floor Girl's Room
Other	115			4					Ν	Ν	Y	Administrative Suites/Offices		Office 212B (2-17)
Other	503								Ν	Ν	Ν	Restroom	Children's Standard Student Restroom	2nd Floor Boy's Room
Other	503								Ν	Ν	Ν	Restroom	Children's Standard Student Restroom	3rd Floor Boy's Room
Other	86			4					Ν	Ν	Ν	Administrative Suites/Offices		Nurse's Office 212A (2-18)
Other	218								Ν	Ν	Ν	Restroom	Children's Standard Student Restroom	1st Floor Girl's Room
Other	3100								Ν	Ν	Ν	Library		2nd Floor Room 208 (2-24)



Room Su	ımmar	y											
Room Number		Voice Outlet	Data Outlet	Elect Outlet		Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	105			4				Ν	Ν	Ν	Administrative Suites/Offices		Room 217, Gym Coordinator's Office
Other	113			4				Ν	Ν	Y	Administrative Suites/Offices		Speech 204A (2-30)
Other	620			18				Ν	Ν	Ν	Administrative Suites/Offices		Room 204 (2-31)
Other	125			6				Ν	Ν	Ν	Administrative Suites/Offices		Work Room 208A (2-22)
Other	198			10				Ν	Ν	Ν	Administrative Suites/Offices		Room 113 District Office
Other	42							Ν	Ν	Ν	Restroom	Staff Restroom	2nd Floor
Other	41							Ν	Ν	Ν	Restroom	Staff Restroom	Room 107G in Main Office
Other	301			6				Ν	Ν	Ν	Administrative Suites/Offices		Conference Room # 107A
Other	134			6				Ν	Ν	Ν	Administrative Suites/Offices		Principal's Office Room 107B
Other	136			6				Ν	Ν	Ν	Administrative Suites/Offices		Asst Principal's Office # 107C
Other	245			6				Ν	Ν	Ν	Administrative Suites/Offices		Vault/Workroom #107E
Other	538			8				Ν	Ν	Y	Administrative Suites/Offices		Room 105, Case Manager's Office
Other	813			12				Ν	Ν	Ν	Administrative Suites/Offices		Faculty Lounge
Other	1448			24				Ν	Ν	Y	Administrative Suites/Offices		Teacher's Resource Room #101- 103
Other	4685							Ν	Ν	Ν	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	1428							Ν	Ν	Ν	Kitchen	Cooking Kitchen	1st Floor
Other	86							N	Ν	Ν	Restroom	Staff Restroom	Men's Room near Kitchen
Other	86							Ν	Ν	Ν	Restroom	Staff Restroom	Women's Room near Kitchen
Other	85			6				Ν	Ν	Ν	Administrative Suites/Offices		Engineer's Office
Other	60			4				Ν	Ν	Ν	Administrative Suites/Offices		Kitchen Manager's Office
Other	122			4				Ν	Ν	Ν	Administrative Suites/Offices		Counselor's Office # 107H
Other	40							Ν	Ν	Ν	Restroom	Early Childhood Student Restroom	Room 112A (1-23)
Other	5026							Ν	Ν	Ν	Gymnasia	Standard Dedicated Gymnasium	2nd Floor
Other	436							Ν	Ν	Ν	Restroom	Children's Standard Student Restroom	2nd Floor Girl's Room
Other	54							Ν	Ν	Ν	Restroom	Children's Standard Student Restroom	Room 218B, Boy's Room in Gym
Other	55							Ν	Ν	Ν	Restroom	Children's Standard Student Restroom	Room 2220B, Girl's Room in Gym
Other	85			4				N	Ν	Ν	Administrative Suites/Offices		Office, Room 219
Other	40							Ν	Ν	Ν	Restroom	Early Childhood Student Restroom	Room 100A (1-52)
Other	558			8				Ν	Ν	Y	Administrative Suites/Offices		Main Office
Other	40			1				Ν	Ν	Ν	Restroom	Early Childhood Student Restroom	Room 110A (1-28)
Other	42				1			Ν	Ν	Ν	Restroom	Staff Restroom	3rd Floor
Other	875			20				Ν	Ν	Y	Administrative Suites/Offices		Room 104 (1-47)
Other	300			6				Ν	Ν	Ν	Administrative Suites/Offices		Parent's Room (1-46)
Other	97			12				Ν	Ν	Ν	Administrative Suites/Offices		Counselor 108A (1-42)
Other	97			12				Ν	Ν	Ν	Administrative Suites/Offices		Social Services 108B (1-41)
Other	42		1	1				Ν	Ν	Ν	Restroom	Staff Restroom	1st Floor

Room Summary														
Room							Operable						Room Sub Type	Location
Number	Size	Outlet	Outlet	Outlet	Level	Window	Window		Stop	Board	Strip			
						Area	Area	AC						
Other	193								N	Ν	Ν	Restroom	Children's Standard Student Restroom	1st Floor Boy's Room
Other	40								N	N	Ν	Restroom	Early Childhood Student Restroom	Room 102A (1-48)