Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7: The item/system is new or in good condition and no work is required.
- Rank 6: The item/system requires general cleaning and/or routine maintenance.
- Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.1

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main

Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	east and west facades	7	756	SF	\$0	
Chimney		Brick Chimney - Concrete/ Mortar Liner	north	6	34	LF	\$17,017	
Chimney		Brick Chimney - Concrete/ Mortar Liner	North- Top of Chimney	5	12	LF	\$21,450	
Doors		Exterior Steel Door	Entire Building	7	19	EΑ	\$0	
Doors		Exterior Steel Door	doors 6,7,10-13	6	6	EΑ	\$1,982	
Doors		Transom Lite	doors 1,5,8-11	7	12	EΑ	\$0	
Entrance		Concrete Exterior Stairs	Entire Building	7	177	LF	\$0	
Entrance		Concrete Exterior Stairs	doors 6 and 7	6	15	LF	\$1,609	spalled, cracked corners
Entrance		Concrete Ramp	doors 1 and 5	7	55	LF	\$0	
Entrance		Entrance Controls - Audio	door 3	7	1	EΑ	\$0	
Entrance		Ramp Handrails	doors 1 and 5	7	116	LF	\$0	
Entrance		Stair Handrails	door 5	7	16	LF	\$0	
Foundation		Concrete Foundation	Basement	7	1,020	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	7	18	EA	\$0	





Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	4	EA	\$0	
Lintels		Lintels - Steel	Entire Building	5	1,375	LF	\$393,250	
Lintels		Lintels - Steel	southwest facade	4	90	LF	\$39,254	corroded
Parapet		Coping - Metal	Entire Building	7	1,307	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	241	LF	\$0	
Roof System		Modified Bitumen Roof	center of roof	4	500	SF	\$11,798	ponding, bubbles/ soft spots under roofing
Roof System		Modified Bitumen Roof	Roof	5	29,942	SF	\$353,241	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Top	ping Roof	7	30,442	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	68,227	SF	\$0	
Walls		Brick	Entire Building	7	23,445	SF	\$0	
Walls		Stone - Cast	entrances	7	830	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	2,573	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	8,696	SF	\$0	
			EVTER	100 0 1 7			A000 F00	

EXTERIOR Sub Total

\$839,599

Building: Main

Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Boiler Room	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	10,113	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	7,264	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	1,488	SF	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	3rd Floor	7	2	EA	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	2nd Floor	7	2	EA	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	1st Floor	7	3	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	7	2	EA	\$0	
Emergency System		Emergency generator below 60 KW natural gas - Outdoor	Site ¿ West	6	1	EA	\$7,508	
Emergency System		Exit Signs - Corridors and Stairs	3rd Floor	7	3	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	3	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	10	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose room	s 1st Floor	7	7	EA	\$0	
Emergency System		Public Announcement System	Main Office	7	68,227	SF	\$0	
Emergency System		Security System - CCTV	Main Office	7	68,227	SF	\$0	
Emergency System		Security System - Intrusion detection	Main Office	7	68,227	SF	\$0	
Main Service		Main Electrical service 1600 A 120/208/3PH	Electrical Room	5	1	EA	\$26,956	
Power Distribution		Lighting and power panels	1st Floor	4	1	EA	\$5,434	





Building: Main

Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost F	Reason
Power Distribution		Lighting and power panels	2nd Floor	6	2	EA	\$1,430	
Power Distribution		Lighting and power panels	1st Floor	6	8	EA	\$5,720	
Power Distribution		Lighting and power panels	Electrical Room	6	2	EA	\$1,430	
Power Distribution		Lighting and power panels	Boiler Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Boiler Room	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	3rd Floor	6	1	EA	\$715	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	4	2	EA	\$37,180	
Power Distribution		Main distribution panels less than 400 amp	Boiler Room	7	2	EA	\$0	
			ELECTRI	ICAL Sub Tot	al		\$91,806	

Building: Main

Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	68,227	SF	\$0	
Fire Alarm		Fire Alarm System	Electrical Room	4	68,227	SF	\$240,985	
			FIRE PROTECTION	\$240,985				

Building: Main

Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Air Conditioning		Window A/C Unit	1st Floor	6	6	EA	\$1,287
Air Conditioning		Window A/C Unit	2nd Floor	6	8	EA	\$1,716
Air Conditioning		Window A/C Unit	3rd Floor	6	12	EA	\$2,574
Air Handling Systems		Air Handling Unit Package - Single Zone - Steam 4,000 to 8,000 cfm	2nd Floor	7	1	EA	\$0
Air Handling Systems		Air Handling Unit Package - Single Zone - Steam 12,001 to 20,000 cfm	2nd Floor	7	1	EA	\$0
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Building South Face	7	1	EA	\$0
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Building North Face	7	1	EA	\$0
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	2nd Floor	6	1	EA	\$2,431
Air Handling Systems		Return Fans - Indoor less than 5,000 CFM	2nd Floor	7	1	EA	\$0
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 50-75 HP	Boiler Room	7	2	EA	\$0
Boiler Systems		Boiler Auxiliary - Steam Boiler 50-75 HP	Boiler Room	7	2	EA	\$0
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	7	1	EA	\$ 0
Boiler Systems		Combustion Dampers	Boiler Room	7	4	EA	\$0



Building: Main

Category: MECHANICAL

Boller Systems Feed Water Pumps and Tank - Steam Boilers Boiler Room 7	Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices Cabinet Heaters With Steam Coils 3rd Floor 6 7 EA \$3,504 Heating Devices Cabinet Heaters With Steam Coils 2nd Floor 6 5 EA \$2,503 Heating Devices Cabinet Heaters With Steam Coils 1st Floor 6 13 EA \$6,507 Heating Devices Unit Heater - Electric Boiler Room 7 1 EA \$0 Heating Devices Wall Heater - Electric 1st Floor 6 1 EA \$0 Heating Devices Wall Heater - Electric 1st Floor 6 1 EA \$103 Heating Devices Wall Heater - Electric 1st Floor 6 1 EA \$103 Heating Devices Wall Heater - Electric Boiler Room 6 1 EA \$103 Mechanical Plumbing Piping - Steam - Steel or Galvanized Entire Building 5 500 LF \$24,739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 1 1 \$2,826	Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	7	1	EA	\$0	
Heating Devices Cabinet Heaters With Steam Coils 2nd Floor 6 5 EA \$2,503 Heating Devices Cabinet Heaters With Steam Coils 1st Floor 6 13 EA \$6,507 Heating Devices Unit Heater - Electric Boiler Room 7 1 EA \$0 Heating Devices Wall Heater - Electric Boiler Room 7 1 EA \$0 Mechanical Plumbing Piping - Condensate - Steel or Galvanized Entire Building 5 500 LF \$16,266 Mechanical Plumbing Piping - Steam - Steel or Galvanized Entire Building 5 500 LF \$24,739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 1 EA \$2,860 Temperature Control Direct Digital Control (DDC) System Engineer's Office 6 68,227 SF \$68,295 Temperature Control Thermostats - Direct Digital Control (DDC) 3rd Floor 7 15 EA \$0 Temperature Control Thermostats - Direct Digital Control (DDC)	Heating Devices		Cabinet Heaters With Steam Coils	1st Floor	7	3	EA	\$0	
Heating Devices Cabinet Heaters With Steam Coils 1st Floor 6 13 EA \$6,507 Heating Devices Unit Heater - Electric Boiler Room 7 1 EA \$0 Heating Devices Wall Heater - Electric 1st Floor 6 1 EA \$103 Mechanical Plumbing Piping - Condensate - Steel or Galvanized Entire Building 5 500 LF \$24,739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 5 500 LF \$24,739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 6 68,227 SF \$68,295 Temperature Control Thermostats - Direct Digital Control (DDC) 1st Floor 7 15 EA \$0 Temperature Control Thermostats - Direct Digital Control (DDC) 2nd Floor 7 18 EA \$0 Unit Ventilation Unit Ventilators - Steam 2nd Floor 7 17 EA \$28,314 Unit Ventilators Unit Ventilators - Steam 3rd Floor	Heating Devices		Cabinet Heaters With Steam Coils	3rd Floor	6	7	EA	\$3,504	
Heating Devices Unit Heater - Electric Boiler Room 7 1 EA \$0 Heating Devices Wall Heater - Electric 1st Floor 6 1 EA \$103 Mechanical Plumbing Piping - Condensate - Steel or Galvanized Entire Building 5 500 LF \$16,266 Mechanical Plumbing Piping - Steam - Steel or Galvanized Entire Building 5 500 LF \$24,739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 1 EA \$2,4739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 1 EA \$2,4739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 1 EA \$2,4739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 1 EA \$2,860 Mechanical Plumbing Piping - Steam Stell Floor 6 68,227 SF \$6,295 Temperature Control Thermostats - Direct Digital Control (DDC) 2nd Floor 7 1 <td< td=""><td>Heating Devices</td><td></td><td>Cabinet Heaters With Steam Coils</td><td>2nd Floor</td><td>6</td><td>5</td><td>EA</td><td>\$2,503</td><td></td></td<>	Heating Devices		Cabinet Heaters With Steam Coils	2nd Floor	6	5	EA	\$2,503	
Heating Devices Wall Heater - Electric 1st Floor 6 1 EA \$103 Mechanical Plumbing Piping - Condensate - Steel or Galvanized Entire Building 5 500 LF \$16,266 Mechanical Plumbing Piping - Steam - Steel or Galvanized Entire Building 5 500 LF \$24,739 Mechanical Plumbing Pumps - Vacuum Boiler Room 6 1 EA \$2,860 Temperature Control Direct Digital Control (DDC) 1st Floor 7 15 EA \$8,295 Temperature Control Thermostats - Direct Digital Control (DDC) 2nd Floor 7 15 EA \$0 Temperature Control Thermostats - Direct Digital Control (DDC) 2nd Floor 7 15 EA \$0 Unit Ventilation Unit Ventilators - Steam 2nd Floor 7 17 EA \$28,314 Unit Ventilation Unit Ventilators - Steam 3rd Floor 6 17 EA \$26,741 Unit Ventilators Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm <t< td=""><td>Heating Devices</td><td></td><td>Cabinet Heaters With Steam Coils</td><td>1st Floor</td><td>6</td><td>13</td><td>EA</td><td>\$6,507</td><td></td></t<>	Heating Devices		Cabinet Heaters With Steam Coils	1st Floor	6	13	EA	\$6,507	
Mechanical PlumbingPiping - Condensate - Steel or GalvanizedEntire Building5500LF\$16,266Mechanical PlumbingPiping - Steam - Steel or GalvanizedEntire Building5500LF\$24,739Mechanical PlumbingPumps - VacuumBoiler Room61EA\$2,860Temperature ControlDirect Digital Control (DDC) SystemEngineer's Office668,227SF\$68,295Temperature ControlThermostats - Direct Digital Control (DDC)1st Floor715EA\$0Temperature ControlThermostats - Direct Digital Control (DDC)2nd Floor717EA\$0Unit VentilationUnit Ventilators - Steam2nd Floor717EA\$28,314Unit VentilationUnit Ventilators - Steam3rd Floor618EA\$26,741Unit VentilationUnit Ventilators - Steam1st Floor613EA\$20,449VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof74EA\$0VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof74EA\$4,290VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof71EA\$4,290VentilationType I Exhaust Hood - Kitchen or Culinary Arts1st Floor71EA\$0	Heating Devices		Unit Heater - Electric	Boiler Room	7	1	EA	\$0	
Mechanical PlumbingPiping - Steam - Steel or GalvanizedEntire Building5500LF\$24,739Mechanical PlumbingPumps - VacuumBoiler Room61EA\$2,860Temperature ControlDirect Digital Control (DDC) SystemEngineer's Office668,227SF\$68,295Temperature ControlThermostats - Direct Digital Control (DDC)1st Floor715EA\$0Temperature ControlThermostats - Direct Digital Control (DDC)2nd Floor718EA\$0Temperature ControlThermostats - Direct Digital Control (DDC)3rd Floor717EA\$0Unit VentilationUnit Ventilators - Steam2nd Floor618EA\$28,314Unit VentilationUnit Ventilators - Steam3rd Floor617EA\$26,741Unit VentilationUnit Ventilators - Steam1st Floor613EA\$20,449VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof74EA\$0VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof71EA\$4,290VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof71EA\$4,290VentilationType I Exhaust Hood - Kitchen or Culinary Arts1st Floor71EA\$0	Heating Devices		Wall Heater - Electric	1st Floor	6	1	EA	\$103	
Mechanical PlumbingPumps - VacuumBoiler Room61EA\$2,860Temperature ControlDirect Digital Control (DDC) SystemEngineer's Office668,227SF\$66,295Temperature ControlThermostats - Direct Digital Control (DDC)1st Floor715EA\$0Temperature ControlThermostats - Direct Digital Control (DDC)2nd Floor718EA\$0Temperature ControlThermostats - Direct Digital Control (DDC)3rd Floor717EA\$0Unit VentilationUnit Ventilators - Steam2nd Floor618EA\$28,314Unit VentilationUnit Ventilators - Steam3rd Floor617EA\$26,741Unit VentilationUnit Ventilators - Steam1st Floor613EA\$20,449VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof74EA\$0VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof74EA\$4,290VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary Arts1st Floor71EA\$0	Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	5	500	LF	\$16,266	
Temperature Control Direct Digital Control (DDC) System Engineer's Office 6 68,227 SF \$68,295 Temperature Control Thermostats - Direct Digital Control (DDC) 1st Floor 7 15 EA \$0 Temperature Control Thermostats - Direct Digital Control (DDC) 2nd Floor 7 18 EA \$0 Temperature Control Thermostats - Direct Digital Control (DDC) 3rd Floor 7 17 EA \$0 Unit Ventilation Unit Ventilators - Steam 2nd Floor 6 18 EA \$28,314 Unit Ventilation Unit Ventilators - Steam 3rd Floor 6 17 EA \$26,741 Unit Ventilation Unit Ventilators - Steam 1st Floor 6 13 EA \$20,449 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 4 EA \$0 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 A \$4 EA \$4,290 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 1 EA \$4,290 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts 1st Floor 7 1 EA \$0	Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	500	LF	\$24,739	
Temperature Control Thermostats - Direct Digital Control (DDC) 1st Floor 7 15 EA \$0 Temperature Control Thermostats - Direct Digital Control (DDC) 2nd Floor 7 18 EA \$0 Temperature Control Thermostats - Direct Digital Control (DDC) 3rd Floor 7 17 EA \$0 Unit Ventilation Unit Ventilators - Steam 2nd Floor 6 18 EA \$28,314 Unit Ventilation Unit Ventilators - Steam 3rd Floor 6 17 EA \$26,741 Unit Ventilation Unit Ventilators - Steam 1st Floor 6 13 EA \$20,449 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 4 EA \$0 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 4 EA \$4,290 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts 1st Floor 7 1 EA \$0 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts 1st Floor 7 1 EA \$0	Mechanical Plumbing		Pumps - Vacuum	Boiler Room	6	1	EA	\$2,860	
Temperature ControlThermostats - Direct Digital Control (DDC)2nd Floor718EA\$0Temperature ControlThermostats - Direct Digital Control (DDC)3rd Floor717EA\$0Unit VentilationUnit Ventilators - Steam2nd Floor618EA\$28,314Unit VentilationUnit Ventilators - Steam3rd Floor617EA\$26,741Unit VentilationUnit Ventilators - Steam1st Floor613EA\$20,449VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof74EA\$0VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof41EA\$4,290VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary Arts1st Floor71EA\$0	Temperature Control		Direct Digital Control (DDC) System	Engineer's Office	6	68,227	SF	\$68,295	
Temperature Control Thermostats - Direct Digital Control (DDC) 3rd Floor 7 17 EA \$0 Unit Ventilation Unit Ventilators - Steam 2nd Floor 6 18 EA \$28,314 Unit Ventilation Unit Ventilators - Steam 3rd Floor 6 17 EA \$26,741 Unit Ventilation Unit Ventilators - Steam 1st Floor 6 13 EA \$20,449 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 4 EA \$0 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 4 EA \$4,290 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 1 EA \$4,290 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts 1st Floor 7 1 EA \$0	Temperature Control		Thermostats - Direct Digital Control (DDC)	1st Floor	7	15	EA	\$0	
Unit Ventilation Unit Ventilators - Steam 2nd Floor 6 18 EA \$28,314 Unit Ventilation Unit Ventilators - Steam 3rd Floor 6 17 EA \$26,741 Unit Ventilation Unit Ventilators - Steam 1st Floor 6 13 EA \$20,449 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 4 EA \$0 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 4 1 EA \$4,290 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 1 EA \$0 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts 1st Floor 7 1 EA \$0	Temperature Control		Thermostats - Direct Digital Control (DDC)	2nd Floor	7	18	EA	\$0	
Unit Ventilation Unit Ventilators - Steam 3rd Floor 6 17 EA \$26,741 Unit Ventilation Unit Ventilators - Steam 1st Floor 6 13 EA \$20,449 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 7 4 EA \$0 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof 4 1 EA \$4,290 Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof 7 1 EA \$0 Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts 1st Floor 7 1 EA \$0	Temperature Control		Thermostats - Direct Digital Control (DDC)	3rd Floor	7	17	EA	\$0	
Unit Ventilation Unit Ventilators - Steam 1st Floor 6 13 EA \$20,449 Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Ventilation Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm Roof Ventilation Exhaust Fans - Roof Mounted 500 to 1,500 cfm Roof Type I Exhaust Hood - Kitchen or Culinary Arts 1st Floor 7 1 EA \$0 Ventilation	Unit Ventilation		Unit Ventilators - Steam	2nd Floor	6	18	EA	\$28,314	
VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof74EA\$0VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof41EA\$4,290VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary Arts1st Floor71EA\$0	Unit Ventilation		Unit Ventilators - Steam	3rd Floor	6	17	EA	\$26,741	
VentilationExhaust Fans - Roof Mounted 1,501 to 8,000 cfmRoof41EA\$4,290VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary Arts1st Floor71EA\$0	Unit Ventilation		Unit Ventilators - Steam	1st Floor	6	13	EA	\$20,449	
VentilationExhaust Fans - Roof Mounted 500 to 1,500 cfmRoof71EA\$0VentilationType I Exhaust Hood - Kitchen or Culinary Arts1st Floor71EA\$0	Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	4	EA	\$0	
Ventilation Type I Exhaust Hood - Kitchen or Culinary Arts 1st Floor 7 1 EA \$0	Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	4	1	EA	\$4,290	
	Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	1	EA	\$0	
Ventilation Type II Exhaust Hood - Warming Kitchen 1st Floor 7 1 EA \$0	Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	7	1	EA	\$0	
	Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	7	1	EA	\$0	

MECHANICAL Sub Total

\$212,578

Building: Main Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	7	2	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	68,227	SF	\$22,440	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	68,227	SF	\$43,904	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	68,227	SF	\$14,635	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	68,227	SF	\$31,221	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	68,227	SF	\$37,075	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	68,227	SF	\$162,933	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	68,227	SF	\$134,639	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	68,227	SF	\$78,052	





Building: Main

Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Piping		Sanitary Piping	Entire Building	5	68,227	SF	\$41,953	
Piping		Storm Piping	Entire Building	5	68,227	SF	\$32,196	
Piping		Vent Piping	Entire Building	5	68,227	SF	\$24,391	
Pumps		Domestic Booster Pump duplex	Boiler Room	7	1	EA	\$0	
·							A	

PLUMBING Sub Total

\$623,438

Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	engineers office	7	63	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	kitchen office	7	35	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	305	7	365	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	207 womens lounge	7	256	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	307 office	7	256	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	principals office	7	154	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	main office	7	364	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	105 counselors` office	7	360	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	gym office	7	98	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	107 nurses office	7	244	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	107 nurses office	7	244	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	305	7	365	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	main office	7	364	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	principals office	7	154	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	207 womens lounge	7	256	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	307 office	7	256	SF	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	gym office	7	98	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	105 counselors` office	7	360	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	engineers office	7	63	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	kitchen office	7	35	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	107 nurses office	7	5	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	kitchen office	7	1	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	105 counselors` office	7	8	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	307 office	7	5	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	main office	7	8	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	principals office	7	2	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	engineers office	4	1	SF	\$7
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	gym office	4	1	SF	\$7
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	207 womens lounge	7	5	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	305	7	8	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	engineers office	7	288	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	principals office	7	480	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	307 office	7	740	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	207 womens lounge	7	740	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	gym office	7	310	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	105 counselors` office	7	760	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	main office	7	740	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	107 nurses office	7	980	SF	\$0





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank (Quantity	Unit	Cost I	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	kitchen office	7	170	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	305	7	669	SF	\$0	
Corridor		Stairs - Asphalt	102 boiler room	7	14	LF	\$0	
Corridor		Stairs - Terrazzo	gym	7	10	LF	\$0	
Corridor		Stairs - Wood	gym	7	10	LF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	11	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	5	EA	\$1,416	
Doors		Interior Wood Doors incl hw	Entire Building	6	22	EA	\$6,229	
Doors		Interior Wood Doors incl hw	Entire Building	5	4	EA	\$1,888	
Doors		Interior Wood Doors incl hw	Entire Building	7	83	EA	\$0	
Doors		Store Front Door	Entire Building	7	5	EA	\$0	
Doors		Transom Window	Entire Building	7	36	SF	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	4	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	6	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	4	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Plaster/Drywall	1st Floor	7	4,641	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Tile/Sheet	1st Floor	7	352	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Wood	1st Floor	7	448	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Lay-In	1st Floor	7	4	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Metal Halide/Sodium Vapor	1st Floor	7	26	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	1st Floor	7	2	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Concrete Block	1st Floor	7	2,672	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Plaster/Drywall	1st Floor	7	1,210	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Structural Glazed Tile	1st Floor	7	924	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Plaster/Drywall	1st Floor	7	1,042	SF	\$0	
Kitchen	Cooking Kitchen	Flooring - Tile Quarry	1st Floor	7	1,042	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	1st Floor	7	18	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Structural Glazed Tile	1st Floor	7	1,512	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	main office			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor girls			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	In Room 106			LF	\$0	





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank Quantity	Unit	Cost Reason	
Locker/Shower Room	Staff Restroom	Benches	2nd floor mens		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	307 mens		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	207 womens		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	engineer locker room		LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	In Room 108		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor womens		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor boys		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor mens at lobby		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor womens at lobby		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	kitchen		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	nurses office		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor unisex at boys		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls		LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	main office		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor mens		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	kitchen		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor womens at lobby		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	nurses office		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	207 womens		EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	In Room 108		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor unisex at boys		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	engineer locker room	6 4	EA	\$196	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor womens		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor girls		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys		EA	\$0	





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor mens at lobby			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	In Room 106			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	307 mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	307 mens			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	In Room 106			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor mens at lobby			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	main office			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	In Room 108			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor womens at lobby			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	kitchen			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	nurses office			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor unisex at boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	engineer locker room			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	207 womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor mens			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	1st Floor	7	2,623	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	2,623	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	72	SF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor			LF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	1st Floor	7	16	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	7	2,288	SF	\$0	





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Mechanical/Service Rooms		Boiler Room	102	7	1,012	SF	\$0
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	3	SF	\$14
Mechanical/Service Rooms		Mechanical/Service Rooms	Entire Building	7	735	SF	\$0
Mechanical/Service Rooms		Storage Room	3rd Floor	7	253	SF	\$0
Mechanical/Service Rooms		Storage Room	yard storage	6	80	SF	\$378
Mechanical/Service Rooms		Storage Room	2nd Floor	7	204	SF	\$0
Mechanical/Service Rooms		Storage Room	1st Floor	7	266	SF	\$0
Mechanical/Service Rooms		Storage Room	107	7	10	SF	\$0
Mechanical/Service Rooms		Storage Room	main office	7	91	SF	\$0
Mechanical/Service Rooms		Storage Room	In Room 108	7	64	SF	\$0
Mechanical/Service Rooms		Storage Room	In Room 106	7	64	SF	\$0
Mechanical/Service Rooms		Storage Room	kitchen	7	344	SF	\$0
Staff Restroom	Staff Restroom	Accessories	main office	7	48	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor boys	7	240	SF	\$0
Staff Restroom	Staff Restroom	Accessories	3rd floor womens	7	42	SF	\$0
Staff Restroom	Staff Restroom	Accessories	1st floor unisex at boys	7	42	SF	\$0
Staff Restroom	Staff Restroom	Accessories	kitchen	6	35	SF	\$270
Staff Restroom	Staff Restroom	Accessories	nurses office	6	30	SF	\$232
Staff Restroom	Staff Restroom	Accessories	1st floor womens at lobby	6	63	SF	\$486
Staff Restroom	Staff Restroom	Accessories	1st floor mens at lobby	6	63	SF	\$486
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys	7	240	SF	\$0
Staff Restroom	Staff Restroom	Accessories	engineer locker room	7	105	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls	7	240	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls	7	240	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys	7	240	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 108	7	48	SF	\$0
Staff Restroom	Staff Restroom	Accessories	207 womens	7	80	SF	\$0
Staff Restroom	Staff Restroom	Accessories	307 mens	7	80	SF	\$0
Staff Restroom	Staff Restroom	Accessories	2nd floor mens	7	42	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 106	7	48	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor girls	7	240	SF	\$0





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls	7	240	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor mens	7	42	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	In Room 106	7	48	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor womens at lobby	7	63	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	307 mens	7	80	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	7	240	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	7	240	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor mens at lobby	7	63	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	kitchen	7	35	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	nurses office	7	30	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor unisex at boys	7	42	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	207 womens	7	80	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	7	240	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	7	240	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	In Room 108	7	48	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	main office	7	48	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	engineer locker room	7	105	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd floor womens	7	42	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys	7	240	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor girls	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor boys	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	1st floor mens at lobby			EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	kitchen			EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	3rd floor womens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	1st floor womens at lobby			EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	1st floor unisex at boys	7	1	EA	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys	6	1	EA	\$300
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 108	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	main office	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	engineer locker room	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 106	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	207 womens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	nurses office			EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	307 mens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	2nd floor mens	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys	7	240	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	In Room 108	7	48	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls	7	240	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls	7	240	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor girls	7	240	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor boys	7	240	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor mens at lobby	7	63	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor womens at lobby	7	63	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	In Room 106	7	48	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys	7	240	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	kitchen	7	35	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	3rd floor womens	7	42	SF	\$ 0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	nurses office	7	30	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	main office	7	48	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	engineer locker room	7	105	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	207 womens	7	80	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	307 mens	7	80	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd floor mens	7	42	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor unisex at boys	7	42	SF	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Staff Restroom	Hand Dryer	1st floor womens at lobby			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor girls	7	2	EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	207 womens			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	307 mens			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor mens			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor womens			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	1st floor unisex at boys			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	nurses office			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	kitchen			EA	\$0
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	In Room 108			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	1st floor mens at lobby			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	main office			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls	7	2	EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	engineer locker room			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys	7	2	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	In Room 106			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor boys	7	3	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	1st floor unisex at boys	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	nurses office	7	1	EA	\$ 0
Staff Restroom	Staff Restroom	Lavatory	kitchen	7	1	EA	\$ 0
Staff Restroom	Staff Restroom	Lavatory	1st floor womens at lobby	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	1st floor mens at lobby	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	3rd floor womens	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	7	3	EA	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	7	3	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 108	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	main office	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	engineer locker room	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	207 womens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	307 mens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	2nd floor mens	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 106	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor boys	4	1	SF	\$4
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor girls	4	1	SF	\$4
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor boys	4	1	SF	\$4
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor girls	4	1	SF	\$4
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor girls	4	1	SF	\$4
Staff Restroom	Staff Restroom	Lighting - Lay-In	nurses office	4	1	SF	\$4
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor boys	4	1	SF	\$4
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd floor boys	4	3	SF	\$13
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd floor womens	7	1	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor unisex at boys	4	1	SF	\$4
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	kitchen	7	1	SF	\$ 0
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor mens at lobby	4	1	SF	\$4
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys	4	3	SF	\$13
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	307 mens	7	1	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor womens at lobby	4	1	SF	\$4
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd floor mens	7	1	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd floor girls	4	3	SF	\$13
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	207 womens	7	1	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	engineer locker room	4	2	SF	\$9





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	main office	4	1	SF	\$4
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	In Room 108	7	1	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys	4	3	SF	\$13
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls	4	3	SF	\$13
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls	4	3	SF	\$13
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	In Room 106	7	1	SF	\$0
Staff Restroom	Staff Restroom	Partitions	kitchen	7	1	EA	\$0
Staff Restroom	Staff Restroom	Partitions	1st floor unisex at boys			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys	7	3	EA	\$0
Staff Restroom	Staff Restroom	Partitions	1st floor womens at lobby	6	1	EA	\$179
Staff Restroom	Staff Restroom	Partitions	1st floor mens at lobby	6	1	EA	\$179
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor boys	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	7	8	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	7	8	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys	7	3	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Partitions	In Room 108			EA	\$0
Staff Restroom	Staff Restroom	Partitions	main office			EA	\$0
Staff Restroom	Staff Restroom	Partitions	207 womens	7	2	EA	\$0
Staff Restroom	Staff Restroom	Partitions	307 mens	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Partitions	In Room 106			EA	\$0
Staff Restroom	Staff Restroom	Partitions	2nd floor mens	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor girls	7	8	EA	\$0
Staff Restroom	Staff Restroom	Partitions	3rd floor womens	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Urinals	In Room 108			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys	7	5	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys	7	5	EA	\$0





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
	•				•		
Staff Restroom Staff Restroom	Staff Restroom Staff Restroom	Urinals	1st floor mens at lobby	7	1	EA EA	\$0 \$0
		Urinals	1st floor unisex at boys	7	_		
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys	7	5	EA	\$0
Staff Restroom	Staff Restroom	Urinals	main office			EA	\$0
Staff Restroom	Staff Restroom	Urinals	307 mens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Urinals	2nd floor mens			EA	\$0
Staff Restroom	Early Childhood Student Restroom	Urinals	In Room 106			EA	\$0
Staff Restroom	Staff Restroom	Urinals	3rd floor womens			EA	\$0
Staff Restroom	Staff Restroom	Wall - Concrete Block	2nd floor mens	7	190	SF	\$0
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor unisex at boys	7	190	SF	\$0
Staff Restroom	Staff Restroom	Wall - Concrete Block	307 mens	7	340	SF	\$0
Staff Restroom	Staff Restroom	Wall - Concrete Block	207 womens	7	340	SF	\$0
Staff Restroom	Staff Restroom	Wall - Concrete Block	engineer locker room	7	340	SF	\$0
Staff Restroom	Staff Restroom	Wall - Concrete Block	main office	7	265	SF	\$0
Staff Restroom	Staff Restroom	Wall - Concrete Block	nurses office	7	155	SF	\$0
Staff Restroom	Staff Restroom	Wall - Concrete Block	kitchen	7	170	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st floor womens at lobby	7	256	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st floor mens at lobby	7	256	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor boys	7	664	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys	7	664	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor girls	7	664	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girls	7	664	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls	7	664	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	In Room 108	7	265	SF	\$0
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	In Room 106	7	265	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys	7	664	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys	7	3	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 106	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	2nd floor mens	7	1	EA	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Staff Restroom	Water Closet	307 mens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	207 womens	7	2	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	engineer locker room	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	main office	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 108	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls	7	8	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	7	8	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	7	3	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	1st floor mens at lobby	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	1st floor womens at lobby	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	kitchen	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	nurses office	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	1st floor unisex at boys	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	3rd floor womens	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls	7	8	EA	\$0
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0
			INTERIOR	Sub To	tal		\$14,712

INTERIOR Sub Total

Building: Main Category: ROOM

Group	Sub Group	Item	Location Ran	k Quantity	Unit	Cost Reason
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	7	18	LF	\$0
Casework	Classroom	Casework			LF	\$0
Casework	Classroom	Casework	6	12	LF	\$429





Building: Main Category: ROOM

Group	Sub Group	Item	Location Rank	Quantity	Unit	Cost Reason
Casework	Classroom	Casework	7	18	LF	\$0
Casework	Classroom	Casework	7	18	LF	\$0
Casework	Classroom	Casework	6	23	LF	\$822
Casework	Classroom	Casework	6	52	LF	\$1,859
Casework	Classroom	Casework	6	21	LF	\$751
Casework	Classroom	Casework	6	21	LF	\$751
Casework	Classroom	Casework	7	18	LF	\$0
Casework	Classroom	Casework	7	18	LF	\$0
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	6	18	LF	\$644
Casework	Classroom	Casework	6	23	LF	\$822
Casework	Classroom	Casework	7	18	LF	\$0
Casework	Classroom	Casework	7	18	LF	\$0
Casework	Classroom	Casework	6	18	LF	\$644
Casework	Classroom	Casework	6	18	LF	\$644
Casework	Classroom	Casework	6	18	LF	\$644
Casework	Classroom	Casework	6	18	LF	\$644
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	7	30	LF	\$0
Casework	Classroom	Casework	6	48	LF	\$1,716
Casework	Classroom	Casework	7	30	LF	\$0
Ceiling	Classroom	Lay-In/Drop	7	1,074	SF	\$0
Ceiling	Classroom	Lay-In/Drop	7	1,074	SF	\$0
Ceiling	Classroom	Lay-In/Drop	7	1,074	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	897	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall	7	897	SF	\$0





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank Q	uantity	Unit Co	st Reason
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	1,488	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	698	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	698	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0
Ceiling	Classroom	Plaster/Drywall		7	698	SF	\$0
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank 0	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Corridors	Corridors	Concrete Block	3rd Floor	7	1,820	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor	7	2,020	SF	\$0	
Corridors	Corridors	Concrete Block	stair 3	7	900	SF	\$0	
Corridors	Corridors	Concrete Block	2nd Floor	7	1,820	SF	\$0	
Corridors	Corridors	Concrete Block	stair 4	7	900	SF	\$0	
Corridors	Corridors	Concrete Block	stair 2	7	900	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	1st Floor	7	501	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	stair 2	7	572	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	stair 3	7	572	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	stair 4	7	572	SF	\$0	
Corridors	Corridors	Drinking Fountains	stair 3			EA	\$0	
Corridors	Corridors	Drinking Fountains	stair 4			EA	\$0	



Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Corridors	Corridors	Drinking Fountains	stair 2			EA	\$0
Corridors	Corridors	Pendant/Surface	stair 4	7	574	EA	\$ 0
Corridors	Corridors	Pendant/Surface	stair 2	7	574	EA	\$0
Corridors	Corridors	Pendant/Surface	3rd Floor	7	2,806	EA	\$0
Corridors	Corridors	Pendant/Surface	1st Floor	7	4,501	EA	\$0
Corridors	Corridors	Pendant/Surface	2nd Floor	7	2,806	EA	\$0
Corridors	Corridors	Pendant/Surface	stair 3	7	574	EA	\$0
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0
Corridors	Corridors	Stair Handrails	stair 4	7	70	LF	\$0
Corridors	Corridors	Stair Handrails	stair 3	7	70	LF	\$0
Corridors	Corridors	Stair Handrails	stair 2	7	70	LF	\$0
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0
Corridors	Corridors	Stairs	2nd Floor			EA	\$0
Corridors	Corridors	Stairs	1st Floor			EA	\$ 0
Corridors	Corridors	Stairs	3rd Floor			EA	\$0
Corridors	Corridors	Structural Glazed Tile	stair 4	7	1,020	SF	\$0
Corridors	Corridors	Structural Glazed Tile	stair 3	7	1,020	SF	\$ 0
Corridors	Corridors	Structural Glazed Tile	1st Floor	7	5,100	SF	\$ 0
Corridors	Corridors	Structural Glazed Tile	2nd Floor	7	2,600	SF	\$ 0
Corridors	Corridors	Structural Glazed Tile	3rd Floor	7	2,600	SF	\$0
Corridors	Corridors	Structural Glazed Tile	stair 2	7	1,020	SF	\$ 0
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0
Corridors	Corridors	Student Lockers	stair 4			EA	\$0
Corridors	Corridors	Student Lockers	stair 2			EA	\$ 0
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$ 0
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0
Corridors	Corridors	Student Lockers	stair 3			EA	\$0
Corridors	Corridors	Tile Ceramic/Porcelain	stair 2	7	84	SF	\$0
Corridors	Corridors	Tile Ceramic/Porcelain	stair 3	7	84	SF	\$ 0
Corridors	Corridors	Tile Ceramic/Porcelain	1st Floor	7	287	SF	\$0
Corridors	Corridors	Tile Ceramic/Porcelain	stair 4	7	84	SF	\$0
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	7	2,806	SF	\$0
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	3,713	SF	\$ 0
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	7	2,806	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	4,501	SF	\$ 0
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	7	2,806	SF	\$0



Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	7	2,806	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	stair 2	7	574	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	stair 3	7	574	SF	\$0
Corridors Ceiling	Corridors	Plaster/Drywall	stair 4	7	574	SF	\$0
Stairs	Corridors	Terrazzo	stair 4	7	38	SF	\$0
Stairs	Corridors	Terrazzo	stair 2	7	38	SF	\$0
Stairs	Corridors	Terrazzo	stair 3	7	38	SF	\$0
Floor	Classroom	Carpet		7	1,488	SF	\$0
Floor	Classroom	Floor		6	897	SF	\$3,848
Floor	Classroom	Floor		6	897	SF	\$3,848
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		7	1,074	SF	\$0
Floor	Classroom	Tile/Sheet		7	1,074	SF	\$0
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		7	1,074	SF	\$0
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058
Floor	Classroom	Tile/Sheet		7	720	SF	\$0
Floor	Classroom	Tile/Sheet		7	720	SF	\$0





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank Q	uantity	Unit	Cost	Reason
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058	
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058	
Floor	Classroom	Tile/Sheet		6	698	SF	\$998	
Floor	Classroom	Tile/Sheet		6	698	SF	\$998	
Floor	Classroom	Tile/Sheet		6	698	SF	\$998	
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058	
Floor	Classroom	Tile/Sheet		6	740	SF	\$1,058	
GYM_FLOOR	Gymnasium.Auditorium	Gymnasia Floor	1st Floor	7	3,825	SF	\$0	
Lighting	Classroom	Lay-In		7	48	EA	\$0	
Lighting	Classroom	Lighting		7	30	EA	\$0	
Lighting	Classroom	Lighting		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	23	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	23	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	35	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0	





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank Q	uantity	Unit	Cost Reason
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0
Lighting	Classroom	Pendant/Surface		7	16	EA	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$ 0
Marker Board	Classroom	Marker Board		7	24	LF	\$ 0
Marker Board	Classroom	Marker Board		7	24	LF	\$ 0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$ 0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$ 0
Marker Board	Classroom	Marker Board		7	24	LF	\$ 0
Marker Board	Classroom	Marker Board		7	24	LF	\$ 0
Marker Board	Classroom	Marker Board		7	24	LF	\$ 0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	12	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	24	LF	\$0
RESTROOM_WALL	Staff Restroom	Restroom Walls	3rd floor womens	7	190	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	910	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	910	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	1,042	SF	\$0
Wall	Classroom	Concrete Block		7	1,042	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	1,042	SF	\$0
Wall	Classroom	Concrete Block		7	1,402	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	862	SF	\$0
Wall	Classroom	Concrete Block		7	862	SF	\$0
Wall	Classroom	Concrete Block		7	862	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0
Wall	Classroom	Concrete Block		7	873	SF	\$0



Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Concrete Block		7	873	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	30	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	60	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	30	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	60	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	30	SF	\$0	
-			ROOM	/I Sub Tot	al		\$35,873	

Building Main Sub Total

\$2,058,991

Building: SITE Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	6	3	EA	\$1,630	per engineer- parking lot catch basins flood
Civil/Drainage		Site Manhole	Entire Site	6	4	EA	\$2,917	
Fencing		Chain Link	Entire Site	6	808	LF	\$11,589	minor corrosion throughout
Fencing		Guard Rail	Site ¿ South	7	124	LF	\$0	
Fencing		Ornamental Iron	Entire Site	7	484	LF	\$0	
Landscape		Benches	Site ¿ South	7	3	EA	\$0	
Landscape		Grass	Site - East	6	2,700	SF	\$1,081	
Landscape		Hardscape - Concrete	east, south	6	2,453	SF	\$4,630	
Landscape		Parkway trees	north, east	7	9	EA	\$0	
Landscape		Trash Receptacles	Entire Site	7	4	EA	\$0	
Parking Lot		Asphalt	south and west	6	28,360	SF	\$24,333	
Parking Lot		Trash Enclosure	Site ¿ South	7	645	SF	\$0	
Playground		Playground Equipment - Pre-K 3-5	Site ¿ South	7	1	EA	\$0	



7424 S Morgan St Chicago, IL 60621

Building: SITE Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Playground		Playground Equipment - School Age 5-12	Site ¿ South	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Site ¿ South	7	5,665	SF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	6	17,096	SF	\$32,270	
Signage		Flag Pole	Site - East	6	1	EA	\$0	corrosion along bottom
Signage		Marquee - Free Standing Back Lighted	Site - East	7	1	EA	\$0	
				SITE Sub Tot	al		\$78,451	
				SITE Sub Tota	al		\$78,451	

Total Campus Need ^{2 3} \$2,137,442

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.



7424 S Morgan St Chicago, IL 60621

Room Su	ımmar	у												
Room Number	Room Size	Voice	Data Outlet	Elect Outlet		Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building:	Main		•		<u> </u>					•	•			
01	720			6	40	112	48		N	N	Υ	Classroom		
03	720			6	40	112	48		N	N	N	Classroom		
06	897			8	40		54	2	N	N	Υ	Classroom		
08	897			8	40	126	54	2	N	N	Υ	Classroom		
09	740	1	7	24	40	112	48		N	N	Υ	Classroom		
11	740	1	7	24	40	112	48		N	N	Υ	Classroom		
12	740	1	7	24	40		48		N	N	Υ	Classroom		
13	740	1	7	24	40	112	48		N	N	Υ	Classroom		
15	698			8	40		48		N	N	Υ	Classroom		
01	1488	2	4	12	40	147	59	3	N	N	N	Classroom		
02	740			8	40		48		N	N	Υ	Classroom		
04	740			8	40	112	48		N	N	Υ	Classroom		
05	1074		24	106	40	154	66	2	N	N	N	Classroom		
06	740			8	40	112	48		N	N	Υ	Classroom		
08	740			8	40	112	48		N	N	Υ	Classroom		
:09	1074		24	8	40	154	66	2	N	N	N	Classroom		
210	740	1	7	24	40	112	51		N	N	N	Classroom		
211	1074		24	8	40	154	66	2	N	N	N	Classroom		
12	740			8	40	112	48		N	N	Υ	Classroom		
14	740			8	40	112	48		N	N	N	Classroom		
215	698			8	40	112	48		N	N	Υ	Classroom		
:16	740			8	40	112	48		N	N	N	Classroom		
01	720			6	40	112	48		N	N	Υ	Classroom		
02	720			6	40	112	48		N	N	N	Classroom		
03	720			6	40	112	48		N	N	Υ	Classroom		
04	720			6	40	112	48		N	N	N	Classroom		
06	720			6	40	112	48		N	N	N	Classroom		
07	720			6	40	112	48		N	N	N	Classroom		
808	720			6	40	112	48		N	N	N	Classroom		
09	720			6	40	112	48		N	N	N	Classroom		
10	740	1	7	24	40	105	45	1	N	N	N	Classroom		
11	720			6	40	112	48		N	N	N	Classroom		
12	740	1	7	24	40	105	45	1	N	N	N	Classroom		
13	720			6	40	112	48		N	N	N	Classroom		
14	720			6	40	112	48		N	N	N	Classroom		
315	698			8	40	112	48		N	N	Υ	Classroom		



7424 S Morgan St Chicago, IL 60621

Room Su	ımmar	у												
Room Number	Room Size	Voice Outlet		Elect Outlet	Noise Level		Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
316	720			6	40	112	48		N	N	N	Classroom		
Other	2806								N	N	N	Corridors		3rd Floor
Other	1042								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	80								N	N	N	Restroom	Staff Restroom	207 womens
Other	105								N	N	N	Restroom	Staff Restroom	engineer locker room
Other	2623								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	48								N	N	N	Restroom	Early Childhood Student Restroom	In Room 108
Other	48								N	N	N	Restroom	Staff Restroom	main office
Other	48								N	N	N	Restroom	Early Childhood Student Restroom	In Room 106
Other	2806								N	N	N	Corridors		2nd Floor
Other	35			2					N	N	Υ	Administrative Suites/Offices		kitchen office
Other	240								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls
Other									N	N	N	Corridors		stair 2
Other									N	N	N	Corridors		stair 3
Other	240								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor girls
Other	240								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys
Other	240								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor boys
Other	63								N	N	N	Restroom	Staff Restroom	1st floor mens at lobby
Other	4501								N	N	N	Corridors		1st Floor
Other	256			8					N	N	N	Administrative Suites/Offices		307 office
Other									N	N	N	Corridors		stair 4
Other	42								N	N	N	Restroom	Staff Restroom	3rd floor womens
Other	42								N	N	N	Restroom	Staff Restroom	2nd floor mens
Other	42								N	N	N	Restroom	Staff Restroom	1st floor unisex at boys
Other	63			2					N	N	Υ	Administrative Suites/Offices		engineers office
Other	30								N	N	N	Restroom	Staff Restroom	nurses office
Other	35								N	N	N	Restroom	Staff Restroom	kitchen
Other	80								N	N	N	Restroom	Staff Restroom	307 mens
Other	98			2					N	N	Υ	Administrative Suites/Offices		gym office
Other	365			6					N	N	Υ	Administrative Suites/Offices		305
Other	360			10					N	N	Υ	Administrative Suites/Offices		105 counselors` office
Other	154			6					N	N	Υ	Administrative Suites/Offices		principals office
Other	364		l	10					N	N	Υ	Administrative Suites/Offices		main office
Other	256			8			1		N	N	Υ	Administrative Suites/Offices		207 womens lounge
Other	244			6					N	N	Υ	Administrative Suites/Offices		107 nurses office
Other	240								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys
Other	240		 	 					N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls



7424 S Morgan St Chicago, IL 60621

Room Summary														
Room	Room	Voice	Data	Elect	Noise	Glaze	Operable	No. of	Window	Smart	Power	Room Type	Room Sub Type	Location
Number	Size	Outlet	Outlet	Outlet	Level	Window	Window	Window	Stop	Board	Strip			
						Area	Area	AC						
Other	4641								N	N	N	Gymnasia	Gymnasium.Auditorium	1st Floor
Other	63								N	N	N	Restroom	Staff Restroom	1st floor womens at lobby