

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7: The item/system is new or in good condition and no work is required.
- Rank 6: The item/system requires general cleaning and/or routine maintenance.
- Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.1

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main

Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	perimeter at each floor	6	8,754	SF	\$247,861	slab edges, spalling
Canopy		Metal Canopy	Center Entrance at each Elevation	7	1,014	SF	\$0	
Chimney		Metal Flue	Penthouse at main roof 5	7	5	LF	\$0	
Doors		Exterior Steel Door	South Loading Dock	6	1	EA	\$330	
Doors		Exterior Steel Door	Entire Building	7	40	EA	\$0	
Doors		Exterior Steel Door	Penthouse	7	8	EA	\$0	
Doors		Overhead Rolling / Garage Door	South Loading Dock	6	2	EA	\$2,054	
Doors		Side Lite	Entire Building	7	30	EA	\$0	
Doors		Transom Lite	Entire Building	7	18	EA	\$0	
Entrance		Concrete Exterior Stairs	Entire Building	6	570	LF	\$61,133	cracks and spalls
Entrance		Concrete Exterior Stairs	North Entrances	5	271	LF	\$87,194	spalls
Entrance		Concrete Exterior Stairs	East Entrances	7	121	LF	\$0	
Entrance		Entrance Controls - Audio	West to play;east main	7	2	EA	\$0	per engineer- need maintenance



Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Entrance Controls - Audio and Video	West to play	7	1	EA	\$0	
Entrance		Stair Handrails	North Entrances	5	60	LF	\$481	bent, repaint
Entrance		Stair Handrails	Entire Building	6	110	LF	\$0	paint
Foundation		Concrete Foundation	Parking Garage	7	480	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	1,095	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Site	7	24	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Site	6	6	EA	\$1,287	
Lighting		Exterior Lights - Wall Mounted	Entire Site	7	14	EA	\$0	
Lintels		Lintels - Steel	Penthouse Doors	7	24	LF	\$0	
Parapet		Coping - Metal	Entry Canopies	7	234	LF	\$0	
Parapet		Coping - Metal	Main Roof and Penthouses	7	1,620	LF	\$0	
Parapet		Coping - Stone	Parking Garage	6	380	LF	\$0	concrete coping
Parapet		Parapet > 30" Height	Parking Garage	7	380	LF	\$0	
Roof System		Interior Downspouts	Entry Canopies	6	48	LF	\$0	
Roof System		Interior Downspouts	Main Roof	6	1,350	LF	\$0	ponding at low lying areas
Roof System		Interior Downspouts	SE parking and South Bridge	6	150	LF	\$0	
Roof System		Modified Bitumen Roof	Parking Garage	7	27,225	SF	\$0	no membrane-waterproof coating
Roof System		Modified Bitumen Roof	Entry Canopies	6	1,014	SF	\$7,178	•
Roof System		Modified Bitumen Roof	Main Roof	6	63,245	SF	\$447,680	ponding at drains and misc. areas; no leaks reported
Roof System		Roof Structure: Concrete	Parking Garage	7	27,225	SF	\$0	•
Roof System		Roof Structure: Concrete	Main Roof	7	60,809	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Penthouse	7	2,436	SF	\$0	
Superstructure		Concrete	Parking Garage	7	27,225	SF	\$0	
Superstructure		Concrete	Entire Building	7	188,560	SF	\$0	
Superstructure		Steel	Penthouse	7	2,436	SF	\$0	
Walls		Precast Panel Wall	parking garage	6	5,890	SF	\$38,913	
Walls		Precast Panel Wall	Entire Building	6	7,000	SF	\$46,246	concrete structure, spalls
Walls		Precast Panel Wall	SE Corner by Door #4	5	5	SF	\$157	spall
Walls		Prefabricated Metal Panel Wall	Penthouses at Main Roof	6	4,290	SF	\$36,440	refinish
Windows		Curtain wall - Glazed Double Pane	Entire Building	7	16,980	SF	\$0	
Windows		Curtain wall - Insulated panel	Entire Building	7	23,915	SF	\$0	
Windows		Curtain wall - Windows	Entire Building	7	2,160	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	5,505	SF	\$0	
			EXTERIOR Sub Total				\$976,954	





Building: Main

Category: ELECTRICAL

Group **Sub Group** Item Location Rank Quantity Unit Cost Reason

Building: Main

Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Entire Building	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	16,082	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	26,790	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	2,952	SF	\$0	
Emergency System		Emergency generator below 60 KW natural gas - Indoor	Mechanical Room	6	1	EA	\$6,006	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	24	EΑ	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	s Entire Building	3	19	EA	\$17,661	No batteries or backup power
Emergency System		Public Announcement System	Entire Building	6	188,560	SF	\$113,249	
Emergency System		Security System - CCTV	Entire Building	5	188,560	SF	\$539,282	
Emergency System		Security System - Intrusion detection	Entire Building	7	188,560	SF	\$0	
Main Service		Main Electrical service 1200 A 120/208/3PH	Electrical Room	6	1	EA	\$7,150	
Main Service		Main Electrical service 1600 A 120/208/3PH	Electrical Room	6	1	EΑ	\$9,295	
Main Service		Main Electrical service 2000 A 277/480/3PH	Electrical Room	6	1	EΑ	\$15,194	
Main Service		Main Electrical service above 3000 A 277/480/3PH	Electrical Room	6	1	EΑ	\$44,688	
Power Distribution		Lighting and power panels	Entire Building	6	12	EΑ	\$8,580	
Power Distribution		Lighting and power panels	Entire Building	4	2	EΑ	\$10,868	
Power Distribution		Lighting and power panels	Entire Building	7	63	EΑ	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	6	4	EA	\$8,580	
Power Distribution		Transformers 277/480-120/208	Penthouse	7	1	EA	\$0	

ELECTRICAL Sub Total

\$780,551

Building: Main

Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	188,560	SF	\$0	
Fire Alarm		Fire Alarm System	Engineering Offices	6	215,785	SF	\$262,287	
Fire Alarm		Fire Pump Controller	Fire Pump Room	5	1	EA	\$9,295	
Pump Room Assembly		Fire Pump 50-75hp	Fire Pump Room	5	1	EA	\$16,874	
Pump Room Assembly		Jockey Pump	Fire Pump Room	5	1	EA	\$4,290	
Sprinkler System		Combination Wet and Dry Sprinkler System	Fire Pump Room	5	188,560	SF	\$701,066	
			FIRE PROTECTION		\$993,812			

Page 3





Building: Main

Category: MECHANICAL

Group Sub Group Item Location Rank Quantity Unit Cost Reason

Building: Main

Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Roof Mounted 21 to 30 tons	Roof	6	1	EA	\$2,574	
Air Conditioning		Window A/C Unit	Basement	6	1	EA	\$215	
Air Handling Systems		Roof Top Unit - Multi Zone - Gas-Heating 21 to 30 tons	Roof	6	18	EA	\$128,700	
Air Handling Systems		Roof Top Unit - Multi Zone - Gas-Heating 10 to 20 tons	Roof	6	4	EA	\$20,020	
Air Handling Systems		Roof Top Unit - Multi Zone - Gas-Heating 31 to 45 tons	Roof	6	9	EA	\$70,785	
Air Handling Systems		Roof Top Unit - Multi Zone - Gas-Heating less than 10 tons	Roof	6	1	EA	\$2,288	
Heat Exchangers		Heat Exchanger - Steam to Hot Water Shell Type	Generator	6	1	EA	\$4,719	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	5	1	EA	\$1,859	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	6	18	EA	\$9,009	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	7	14	EA	\$0	
Heating Devices		Fin Tube Electric	Entire Building	7	2,012	LF	\$0	
Heating Devices		Fin Tube Electric	Entire Building	6	40	LF	\$572	
Heating Devices		Fin Tube Electric	Entire Building	5	98	LF	\$7,007	
Heating Devices		Wall Heater - Electric	Entire Building	6	1	EA	\$103	
Heating Devices		Wall Heater - Electric	Entire Building	7	1	EA	\$0	
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	Penthouse	7	4	EA	\$0	
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	Generator	6	1	EA	\$1,430	
Temperature Control		Hybrid Pneumatic/Direct Digital Control (DDC) System	Entire Building	5	188,560	SF	\$943,743	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	4	4	EA	\$3,718	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	27	EΑ	\$3,861	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	150	EA	\$0	
Temperature Control		Zone Dampers	Roof	6	128	EA	\$18,304	
Ventilation		Exhaust Fan - Indoor	Loading dock	7	1	EA	\$0	
Ventilation		Exhaust Fan - Indoor	Basement	6	6	EA	\$3,003	
Ventilation		Exhaust Fan - Indoor	Penthouse	6	2	EA	\$1,001	
Ventilation		Exhaust Fan - Indoor	Elevator Machine Room	6	1	EA	\$501	
Ventilation		Exhaust Fan - Indoor	Penthouse	5	4	EA	\$7,436	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	1	EA	\$1,502	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	19	EA	\$8,151	
Ventilation		Exhaust Fans - Roof Mounted above 8,000 cfm	Roof	6	11	EA	\$23,595	





Building: Main

Category: MECHANICAL

Group	Sub Group	Item	Location	Rank Quan	tity	Unit	Cost	Reason
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Basement Kitchen	7	5	EA	\$0	
			MECHANICAL	Sub Total			\$4.264.004	

MECHANICAL Sub Total

\$1,264,094

Building: Main

Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Penthouse	6	2	EA	\$13,442	
Hot Water		Storage Tank less than 500 gallons	Penthouse	6	2	EA	\$3,718	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	188,560	SF	\$62,017	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	188,560	SF	\$121,338	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	188,560	SF	\$40,446	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	188,560	SF	\$86,285	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	188,560	SF	\$102,464	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	188,560	SF	\$450,300	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	188,560	SF	\$372,104	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	188,560	SF	\$215,713	
Piping		Sanitary Piping	Entire Building	5	188,560	SF	\$115,946	
Piping		Storm Piping	Entire Building	5	188,560	SF	\$88,981	
Piping		Vent Piping	Entire Building	5	188,560	SF	\$67,410	
Pumps		Domestic Booster Pump simplex	Mechanical Room	5	2	EA	\$17,160	
Pumps		Ejector Pump	Mechanical Room	5	2	EA	\$22,880	
Pumps		Ejector Pump	Mechanical Room	6	2	EA	\$6,006	

PLUMBING Sub Total

\$1,786,211

Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	2nd floor nurse	7	580	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	main office	7	1,127	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	3rd fl office	6	4,561	SF	\$9,783
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor office next to staff toilets	6	205	SF	\$440
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor office next to staff toilets	6	205	SF	\$440



Building: Main Category: INTERIOR

Category: INTERIOR	Sub Craun	lte un	Lagation	Darl	Ouantitu	l lmit	Cost Bosses
Group	Sub Group	Item	Location	Kank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	2nd floor technology office	7	275	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	2nd floor shared music office/ faculty lounge	7	275	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	in 3rd fl science lab (FP says storage)	7	375	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	work room in main office	7	115	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	principals office	7	232	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	asst principals office	7	215	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	clerks office	7	145	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	library office	7	145	SF	\$0
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	in kitchen	6	130	SF	\$279
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	3rd fl office	6	4,561	SF	\$6,522
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	work room in main office	5	115	SF	\$411
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	main office	5	1,127	SF	\$4,029
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	principals office	6	232	SF	\$332
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	asst principals office	6	215	SF	\$307
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	library office	7	145	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	2nd floor shared music office/ faculty lounge	7	275	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	clerks office	6	145	SF	\$207
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	2nd floor technology office	7	275	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	in 3rd fl science lab (FP says storage)	6	375	SF	\$1,770
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	2nd floor nurse	7	580	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor office next to staff toilets	7	205	SF	\$0
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor office next to staff toilets	7	205	SF	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in kitchen	7	130	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	in kitchen	7	4	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd floor technology office	7	8	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	clerks office	7	4	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	asst principals office	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	principals office	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	main office	7	25	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	work room in main office	7	5	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	library office	7	6	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd floor shared music office/ faculty lounge	7	8	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor office next to staff toilets	7	5	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor office next to staff toilets	7	4	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	3rd fl office	7	101	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	in 3rd fl science lab (FP says storage)	7	10	SF	\$0
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd floor nurse	7	12	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	in kitchen	7	276	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	main office	7	520	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	in 3rd fl science lab (FP says storage)	6	740	SF	\$2,116
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd floor shared music office/ faculty lounge	7	190	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	principals office	7	145	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	asst principals office	7	110	SF	\$0
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	clerks office	7	60	SF	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	main office	7	55	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd floor technology office	7	190	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	9	EA	\$2,548	
Doors		Interior Wood Doors incl hw	Entire Building	4	2	EA	\$6,418	
Doors		Interior Wood Doors incl hw	Entire Building	5	8	EA	\$3,775	
Doors		Interior Wood Doors incl hw	Entire Building	6	192	EA	\$54,363	
Doors		Interior Wood Doors incl hw	Entire Building	7	7	EA	\$0	
Doors		Transom Window	Entire Building	7	1,190	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1st floor primary gym			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	2nd floor gym 1			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	2nd floor gym 2			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	1st floor primary gym	7	3,860	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	2nd floor gym 1	7	3,860	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	2nd floor gym 2	7	3,860	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Sports Flooring	2nd floor gym 1	6	3,860	SF	\$24,839	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Sports Flooring	2nd floor gym 2	6	3,860	SF	\$24,839	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Sports Flooring	1st floor primary gym	6	3,860	SF	\$24,839	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	1st floor primary gym	6	40	EA	\$7,150	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	2nd floor gym 1	7	18	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	2nd floor gym 2	7	18	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	2nd floor gym 1	7	1	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st floor primary gym			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	2nd floor gym 2			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st floor primary gym			EA	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	2nd floor gym 1			EA	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1st floor primary gym			EA	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	2nd floor gym 1			EA	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	2nd floor gym 2			EA	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	2nd floor gym 1	7	1,755	SF	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	1st floor primary gym	7	2,860	SF	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	2nd floor gym 2	7	585	SF	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	2nd floor gym 2	7	495	SF	\$0
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	2nd floor gym 1	7	1,485	SF	\$0
Kitchen	Cooking Kitchen	Ceiling - Splined	Basement	6	4,030	SF	\$11,526
Kitchen	Cooking Kitchen	Flooring - Tile Quarry	Basement	7	4,030	SF	\$0
Kitchen	Cooking Kitchen	Lighting - Lay-In	Basement	6	71	SF	\$51
Kitchen	Cooking Kitchen	Wall - Structural Glazed Tile	Basement	7	3,942	SF	\$0
Library	Library	Casework	2nd Floor	6	255	LF	\$7,822
Library	Library	Flooring Carpet	2nd Floor	6	5,860	SF	\$8,380
Library	Library	Lighting - Pendant/ Surface	2nd Floor	7	105	SF	\$0
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls south			LF	\$0
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys north east			LF	\$0
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls east/south			LF	\$0
Locker/Shower Room	Locker/Shower Room	Benches	basement womens in kitchen corridor			LF	\$0
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 1st floor classroom off teachers toilets			LF	\$0
Locker/Shower Room	Locker/Shower Room	Benches	basement mens in kitchen corridor			LF	\$0
Locker/Shower Room	Staff Restroom	Benches	basement mens in kitchen corridor			LF	\$0
Locker/Shower Room	Staff Restroom	Benches	basement womens in kitchen corridor			LF	\$0
Locker/Shower Room	Early Childhood Student Restroom	Benches	1st fl girls east/south			LF	\$0





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls north		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls south		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys south		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl Men's West		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl womens		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys North West		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor nurses office		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys east		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys south		LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	1st fl boys east		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls south		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor nurses office		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls east/south		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls North East		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys North West		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd fl Men's West		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd fl Women's West		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in 1st floor classroom off teachers toilets		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl Men's West		LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl womens		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys south		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys east		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls North East		LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls east/south		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls east/south		EA	\$0	





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys south		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls south		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl womens		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl Men's West		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd fl Women's West		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd fl Men's West		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys south		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls North East		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls North East		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys east		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls south		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 1st floor classroom off teachers toilets		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys North West		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in 1st floor classroom off teachers toilets		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys east		EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	basement womens in kitchen corridor	6 20	EA	\$982	
Locker/Shower Room	Locker/Shower Room	Lockers	basement mens in kitchen corridor	6 15	EA	\$736	
Locker/Shower Room	Staff Restroom	Lockers	basement mens in kitchen corridor	6 3	EA	\$147	
Locker/Shower Room	Staff Restroom	Lockers	basement womens in kitchen corridor	6 3	EA	\$147	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	1st fl girls east/south		EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	1st fl boys east		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls north		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls south		EA	\$0	





Building: Main Category: INTERIOR

Group	Sub Group	Item	L	ocation.	Rank Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1	st fl boys south		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1	st fl Men's West		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1	st fl womens		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2	nd fl boys North West		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2	nd floor nurses office		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1	st fl boys north east		EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2	nd floor nurses office		EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3	rd fl Women's West		EA	\$0	
Locker/Shower Room	Staff Restroom	Showers		nd floor nurses office		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers		n 1st floor classroom off eachers toilets		EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1	st fl Men's West		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2	nd fl girls North East		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2	nd fl boys east		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2	nd fl girls east/south		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2	nd fl boys south		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2	nd fl girls south		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3	rd fl boys North West		EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2	nd fl Men's West		EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3	rd fl Men's West		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2	nd floor nurses office		EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers		asement mens in kitchen orridor	5 1	EA	\$1,216	
Locker/Shower Room	Staff Restroom	Showers	2	and fl womens		EA	\$0	
Locker/Shower Room	Staff Restroom	Showers		asement mens in kitchen orridor		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3	rd fl boys south		EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3	rd fl girls south		EA	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys east			EA	\$0
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls east/south			EA	\$0
Locker/Shower Room	Locker/Shower Room	Showers	basement womens in kitchen corridor			EA	\$0
Locker/Shower Room	Staff Restroom	Showers	basement womens in kitchen corridor			EA	\$0
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls North East			EA	\$0
Locker/Shower Room	Staff Restroom	Showers	1st fl womens			EA	\$0
Locker/Shower Room	Early Childhood Student Restroom	Showers	1st fl girls east/south			EA	\$0
Locker/Shower Room	Early Childhood Student Restroom	Showers	1st fl boys east			EA	\$0
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls north			EA	\$0
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys north east			EA	\$0
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls south			EA	\$0
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys south			EA	\$0
Locker/Shower Room	Children's Standard Student Restroom	Showers	in 1st floor classroom off teachers toilets			EA	\$0
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys North West			EA	\$0
Lunchroom	Lunchroom	Ceiling - Lay-In	3rd Floor	6	4,450	SF	\$9,545
Lunchroom	Lunchroom	Ceiling - Lay-In	1st FL Communication Dining	7	2,350	SF	\$0
Lunchroom	Multipurpose Room	Ceiling - Lay-In	1st fl offices/computer labs/ prep rooms	7	4,561	SF	\$0
Lunchroom	Multipurpose Room	Ceiling - Lay-In	2nd fl offices/computer labs/ prep rooms	7	4,561	SF	\$0
Lunchroom	Multipurpose Room	Ceiling - Lay-In	1st floor staff lunchroom/ lounge	7	600	SF	\$0
Lunchroom	Lunchroom	Ceiling - Lay-In	2nd Floor	6	4,450	SF	\$9,545
Lunchroom	Lunchroom	Ceiling - Lay-In	1st Floor	7	3,960	SF	\$0
Lunchroom	Lunchroom	Flooring - Carpet	1st FL Communication Dining	6	2,350	SF	\$3,361
Lunchroom	Multipurpose Room	Flooring - Carpet	1st fl offices/computer labs/ prep rooms	6	4,561	SF	\$6,522



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Multipurpose Room	Flooring - Carpet	1st floor staff lunchroom/ lounge	7	600	SF	\$0	
Lunchroom	Multipurpose Room	Flooring - Carpet	2nd fl offices/computer labs/ prep rooms	6	4,561	SF	\$6,522	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	3,960	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	3rd Floor	7	4,450	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	2nd Floor	7	4,450	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	3rd Floor	6	60	SF	\$43	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	2nd Floor	6	60	SF	\$43	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	2nd fl offices/computer labs/ prep rooms	7	101	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	74	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st FL Communication Dining	7	44	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	1st fl offices/computer labs/ prep rooms	7	101	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	1st floor staff lunchroom/ lounge	7	12	SF	\$0	
Lunchroom	Multipurpose Room	Serving Line	2nd fl offices/computer labs/ prep rooms			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	1st fl offices/computer labs/ prep rooms			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	1st floor staff lunchroom/ lounge			LF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	15	LF	\$0	
Lunchroom	Lunchroom	Serving Line	2nd Floor	7	20	LF	\$0	
Lunchroom	Lunchroom	Serving Line	3rd Floor	7	20	LF	\$0	
Lunchroom	Lunchroom	Serving Line	1st FL Communication Dining			LF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	Basement			LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	7	240	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	3,860	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Loading Dock	6	2,018	SF	\$9,523	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	1,740	SF	\$8,211	
Mechanical/Service Rooms		Storage Room	223/ 221	7	500	SF	\$0	
Mechanical/Service Rooms		Storage Room	main office	7	70	SF	\$0	
Mechanical/Service Rooms		Storage Room	in Kitchen	7	910	SF	\$0	
Mechanical/Service Rooms		Storage Room	library	7	290	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st floor primary gym	7	300	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys north east	7	145	SF	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys east	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls North East	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 1st floor classroom off teachers toilets	7	21	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor nurses office	7	18	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor nurses office	7	45	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys North West	7	145	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl womens	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls east/south	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls north	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in 1st floor classroom off teachers toilets	7	21	SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	basement mens in kitchen corridor	7	295	SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	basement womens in kitchen corridor	7	278	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	basement mens in kitchen corridor	7	55	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl Men's West	7	85	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	basement womens in kitchen corridor	7	129	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	1st fl girls east/south	7	170	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	1st fl boys east	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys south	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys east	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys south	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys south	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls south	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls south	7	170	SF	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls east/south	7	170	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls North East	7	170	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys North West	7	145	SF	\$0
Staff Restroom	Staff Restroom	Accessories	3rd fl Women's West	7	85	SF	\$0
Staff Restroom	Staff Restroom	Accessories	3rd fl Men's West	7	85	SF	\$0
Staff Restroom	Staff Restroom	Accessories	2nd fl Men's West	7	85	SF	\$0
Staff Restroom	Staff Restroom	Accessories	2nd fl womens	7	145	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls south	7	170	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls south	6	170	SF	\$481
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys North West	7	145	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd fl Men's West	7	85	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st fl Men's West	7	85	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st fl womens	7	145	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys North West	7	145	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor nurses office	7	45	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls North East	7	170	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor nurses office	7	18	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	in 1st floor classroom off teachers toilets	7	21	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls North East	7	170	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys east	6	170	SF	\$481
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls east/south	7	170	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys south	7	145	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys north east	7	145	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl womens	7	145	SF	\$0
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl Men's West	7	85	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls east/south	7	170	SF	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	1st fl boys east	6	170	SF	\$481	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	1st fl girls east/south	7	170	SF	\$0	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	basement womens in kitchen corridor	7	278	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	in 1st floor classroom off teachers toilets	7	21	SF	\$0	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	basement mens in kitchen corridor	7	295	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	basement mens in kitchen corridor	7	55	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	basement womens in kitchen corridor	7	129	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys south	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys south	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys east	6	170	SF	\$481	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls north	6	170	SF	\$481	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls south	6	170	SF	\$481	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd fl Women's West	7	85	SF	\$ 0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls south	6	170	SF	\$481	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor nurses office	7	1	EA	\$ 0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl Men's West	7	1	EΑ	\$ 0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls east/south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl womens	6	1	EΑ	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys North West	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor nurses office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys south	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys south	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls south	7	1	EA	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys east	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls east/south	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls North East	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys North West	6	1	EA	\$300
Staff Restroom	Staff Restroom	Floor Drain	3rd fl Men's West	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	3rd fl Women's West	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	2nd fl Men's West	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	2nd fl womens	6	1	EΑ	\$300
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls North East	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls south	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys south	6	1	EA	\$300
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys east	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 1st floor classroom off teachers toilets	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in 1st floor classroom off teachers toilets	7	1	EA	\$0
Staff Restroom	Locker/Shower Room	Floor Drain	basement mens in kitchen corridor	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	basement mens in kitchen corridor	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	basement womens in kitchen corridor	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Floor Drain	1st fl girls east/south	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Floor Drain	1st fl boys east	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls north	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys north east	6	1	EA	\$300
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls south	7	1	EA	\$0
Staff Restroom	Locker/Shower Room	Floor Drain	basement womens in kitchen corridor			EA	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	basement womens in kitchen corridor	7	91	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls north	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in 1st floor classroom off teachers toilets	7	21	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	basement mens in kitchen corridor	7	29	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	basement womens in kitchen corridor	7	22	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	basement mens in kitchen corridor	7	120	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys east	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys south	7	130	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys north east	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls south	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys south	7	145	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st fl womens	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys North West	7	145	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor nurses office	7	18	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in 1st floor classroom off teachers toilets	7	21	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl Men's West	7	85	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls North East	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys south	5	15	SF	\$236	broken uneven tile
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls south	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys east	7	170	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls east/south	6	170	SF	\$433	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys North West	7	145	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl Women's West	7	85	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl womens	7	145	SF	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls south	7	170	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys south	7	130	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls east/south	6	170	SF	\$433
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys east	7	170	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls east/south	6	170	SF	\$433
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	2nd floor nurses office	7	45	SF	\$0
Staff Restroom	Locker/Shower Room	Flooring - Tile/Sheet	basement mens in kitchen corridor	7	175	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	basement mens in kitchen corridor	7	26	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	basement womens in kitchen corridor	7	107	SF	\$0
Staff Restroom	Locker/Shower Room	Flooring - Tile/Sheet	basement womens in kitchen corridor	7	187	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys south			EA	\$0
Staff Restroom	Locker/Shower Room	Hand Dryer	basement womens in kitchen corridor			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 1st floor classroom off teachers toilets			EA	\$0
Staff Restroom	Locker/Shower Room	Hand Dryer	basement mens in kitchen corridor			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	basement mens in kitchen corridor			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	basement womens in kitchen corridor			EA	\$0
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	1st fl girls east/south			EA	\$0
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	1st fl boys east			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls north			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys north east			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls south			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls North East			EA	\$0





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys North West			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls east/south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd fl Women's West			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl Men's West			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd fl Men's West			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl Men's West			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor nurses office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys east			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys North West			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor nurses office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in 1st floor classroom off teachers toilets			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls North East			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys east			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls east/south			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl Men's West	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Lavatory	basement womens in kitchen corridor	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	1st fl boys east	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys north east	7	1	EA	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls north	6	2	EA	\$744
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys south	7	1	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Lavatory	1st fl girls east/south	6	1	EA	\$372
Staff Restroom	Early Childhood Student Restroom	Lavatory	1st fl girls east/south	5	1	EA	\$1,859
Staff Restroom	Staff Restroom	Lavatory	basement womens in kitchen corridor	6	1	EA	\$372
Staff Restroom	Staff Restroom	Lavatory	basement mens in kitchen corridor	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 1st floor classroom off teachers toilets	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	1st fl womens	7	2	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	2nd floor nurses office	7	1	EA	\$0
Staff Restroom	Locker/Shower Room	Lavatory	basement mens in kitchen corridor	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls North East	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys south	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls south	6	1	EA	\$372
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls south	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys east	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls east/south	6	1	EA	\$372
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys North West	6	2	EA	\$744
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls North East	6	1	EA	\$372
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys North West	7	2	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	3rd fl Men's West	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	3rd fl Women's West	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	in 1st floor classroom off teachers toilets	7	1	EA	\$0
Staff Restroom	Staff Restroom	Lavatory	2nd fl womens	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls south	6	1	EA	\$372



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls east/south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys east	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls North East	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Lavatory	2nd fl Men's West	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls east/south	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor nurses office	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl Men's West	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl boys south	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl girls south	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl boys north east	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl girls north	7	3	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	1st fl boys east	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	basement womens in kitchen corridor	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 1st floor classroom off teachers toilets	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl womens	7	3	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	1st fl girls east/south	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd fl boys south	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl boys North West	7	3	SF	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	basement mens in kitchen corridor	6	5	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd fl Men's West	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd fl boys North West	7	3	SF	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd fl girls North East	7	3	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd fl girls east/south	7	3	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd fl girls south	7	3	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd fl Women's West	7	2	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl Men's West	7	1	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl girls North East	7	3	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor nurses office	6	2	SF	\$1
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd floor nurses office	6	1	SF	\$1
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd fl boys east	7	3	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in 1st floor classroom off teachers toilets	6	1	SF	\$1
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl womens	7	3	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl boys east	7	3	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl girls east/south	7	3	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl boys south	7	3	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl girls south	7	3	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	basement womens in kitchen corridor	7	2	SF	\$0
Staff Restroom	Locker/Shower Room	Lighting - Pendant/ Surface	basement womens in kitchen corridor	7	7	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	basement mens in kitchen corridor	4	1	SF	\$4
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	basement mens in kitchen corridor	7	1	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys south			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls south	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys north east			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls north	7	3	EA	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Early Childhood Student Restroom	Partitions	1st fl girls east/south	7	4	EA	\$0
Staff Restroom	Locker/Shower Room	Partitions	basement womens in kitchen corridor	7	2	EA	\$0
Staff Restroom	Locker/Shower Room	Partitions	basement mens in kitchen corridor	7	2	EA	\$0
Staff Restroom	Staff Restroom	Partitions	1st fl Men's West	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	in 1st floor classroom off teachers toilets			EA	\$0
Staff Restroom	Early Childhood Student Restroom	Partitions	1st fl boys east	7	1	EA	\$0
Staff Restroom	Staff Restroom	Partitions	basement mens in kitchen corridor	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys east	7	1	EA	\$0
Staff Restroom	Staff Restroom	Partitions	basement womens in kitchen corridor	7	2	EA	\$0
Staff Restroom	Staff Restroom	Partitions	1st fl womens	7	4	EA	\$0
Staff Restroom	Staff Restroom	Partitions	3rd fl Men's West	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys North West			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls North East	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls east/south	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls south	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys south			EA	\$0
Staff Restroom	Staff Restroom	Partitions	3rd fl Women's West	7	1	EA	\$0
Staff Restroom	Staff Restroom	Partitions	2nd fl Men's West	7	1	EA	\$0
Staff Restroom	Staff Restroom	Partitions	2nd floor nurses office			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls south	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys south			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls east/south	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys east	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls North East	7	3	EA	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	in 1st floor classroom off teachers toilets			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl womens	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys North West			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor nurses office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys north east	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls north			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	1st fl boys east	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	1st fl girls east/south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	basement womens in kitchen corridor			EA	\$0	
Staff Restroom	Locker/Shower Room	Urinals	basement womens in kitchen corridor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in 1st floor classroom off teachers toilets			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls east/south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	basement mens in kitchen corridor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl Men's West	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys east	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl girls east/south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl girls North East			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys North West	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls North East			EA	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Staff Restroom	Urinals	3rd fl Women's West	7	1	EA	\$0
Staff Restroom	Staff Restroom	Urinals	1st fl Men's West	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls south			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys south	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys east	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	in 1st floor classroom off teachers toilets			EA	\$0
Staff Restroom	Staff Restroom	Urinals	2nd floor nurses office			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor nurses office			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys North West	7	3	EA	\$0
Staff Restroom	Staff Restroom	Urinals	3rd fl Men's West	7	1	EA	\$0
Staff Restroom	Locker/Shower Room	Urinals	basement mens in kitchen corridor	7	1	EA	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	3rd fl Women's West	7	355	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in 1st floor classroom off teachers toilets	7	140	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls North East	7	460	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys east	7	460	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls east/south	7	460	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys south	6	520	SF	\$3,718
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls south	7	460	SF	\$0
Staff Restroom	Locker/Shower Room	Wall - Structural Glazed Tile	basement womens in kitchen corridor	7	800	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd fl Men's West	7	355	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor nurses office	7	110	SF	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	3rd fl Men's West	7	355	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl boys North West	6	520	SF	\$3,718
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl girls North East	7	460	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl girls east/south	7	460	SF	\$0



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl boys east	7	460	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd fl womens	6	520	SF	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys north east	6	500	SF	\$3,575	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in 1st floor classroom off teachers toilets	7	140	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Structural Glazed Tile	basement mens in kitchen corridor	7	832	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	basement mens in kitchen corridor	7	344	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	basement womens in kitchen corridor	7	544	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	1st fl girls east/south	7	460	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd floor nurses office	7	115	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls north	7	460	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor nurses office	7	105	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls south	7	460	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl Men's West	7	355	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl womens	6	520	SF	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys North West	5	20	SF	\$944 cracking	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys North West	6	500	SF	\$3,575	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl boys south	6	520	SF	\$3,718	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	1st fl boys east	7	460	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl girls south	7	460	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd fl Men's West	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	basement womens in kitchen corridor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls east/south	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls south	7	3	EA	\$0	



Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Staff Restroom	Water Closet	2nd fl womens	7	4	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	3rd fl Women's West	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 1st floor classroom off teachers toilets	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys North West	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls North East	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls east/south	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys east	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls south	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys south	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	2nd fl Men's West	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls south	7	3	EA	\$0
Staff Restroom	Early Childhood Student Restroom	Water Closet	1st fl girls east/south	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	in 1st floor classroom off teachers toilets	7	1	EA	\$0
Staff Restroom	Locker/Shower Room	Water Closet	basement mens in kitchen corridor	7	2	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	basement mens in kitchen corridor	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	basement womens in kitchen corridor	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys east	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys north east	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls North East	7	3	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys south	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	1st fl Men's West	7	1	EA	\$0
Staff Restroom	Staff Restroom	Water Closet	1st fl womens	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys North West	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor nurses office	7	1	EA	\$0





Building: Main Category: INTERIOR

Group	Sub Group	Item	Location	Rank Qu	uantity	Unit	Cost Reas	son
Staff Restroom	Staff Restroom	Water Closet	2nd floor nurses office	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	1st fl boys east	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls north	7	3	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	5	1	EA	\$56,628	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	25	EA	\$9,653	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
-			INTERIO	R Sub Total			\$371,254	

Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	2nd floor technology office	7	240	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	1st floor office next to staff toilets	7	430	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	3rd fl office	7	325	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	1st floor office next to staff toilets	7	270	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	clerks office	7	123	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	1st floor office next to staff toilets	7	290	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	3rd fl office	7	400	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	2nd floor technology office	7	140	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	2nd floor shared music office/ faculty lounge	7	140	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	2nd floor shared music office/ faculty lounge	7	240	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	3rd fl office	6	3,050	SF	\$7,196	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	main office	7	270	SF	\$0	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	2nd floor nurse	7	390	SF	\$0	





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	work room in main office	7	350	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	1st floor office next to staff toilets	7	150	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	clerks office	7	100	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	2nd floor nurse	7	710	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	work room in main office	7	210	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	main office	6	462	SF	\$1,090
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	main office	7	780	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	principals office	7	252	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	principals office	7	55	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	asst principals office	7	100	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	asst principals office	7	153	SF	\$0
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	library office	7	480	SF	\$0
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework		7	14	LF	\$0
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework		6	195	LF	\$6,971
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework		6	20	LF	\$715
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework				LF	\$ 0





Building: Main Category: ROOM

Group	VI Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework		7	10	LF	\$0
Casework	Classroom	Casework		7	18	LF	\$0
Casework	Classroom	Casework		7	36	LF	\$0
Casework	Classroom	Casework				LF	\$0
Casework	Classroom	Casework				LF	\$0
Ceiling	Classroom	Lay-In/Drop		7	420	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	420	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	420	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	885	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	500	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	420	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	420	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	420	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	420	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	6,564	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	420	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	2,277	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	585	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	440	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	960	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	440	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	7,982	SF	\$0
Ceiling	Classroom	Lay-In/Drop		7	960	SF	\$0
Chalk Board	Lunchroom	Chalk Board	3rd Floor	4	12	LF	\$1,459
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF	





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486
Chalk Board	Lunchroom	Chalk Board	1st FL Communication Dining	4		LF	
Chalk Board	Multipurpose Room	Chalk Board	1st fl offices/computer labs/ prep rooms	4		LF	
Chalk Board	Multipurpose Room	Chalk Board	2nd fl offices/computer labs/ prep rooms	4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Multipurpose Room	Chalk Board	1st floor staff lunchroom/ lounge	4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Lunchroom	Chalk Board	2nd Floor	4	12	LF	\$1,459
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board	Classroom	Chalk Board		4		LF	
CLASSROOM	Classroom	Eye Wash Station		6	4	EA	\$10,725
Corridors	Corridors	Carpet	3rd Floor	5	5,057	SF	\$18,079
Corridors	Corridors	Carpet	2nd Floor	5	5,057	SF	\$18,079
Corridors	Corridors	Concrete Block	Kitchen Corridor in Basement	7	224	SF	\$0





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Concrete Block	2nd Floor	7	640	SF	\$0	
Corridors	Corridors	Concrete Block	3rd Floor	7	640	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor	7	1,020	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	Kitchen Corridor in Basement	6	80	SF	\$378	
Corridors	Corridors	Concrete Epoxy/Painted	West Stairs	6	634	SF	\$2,992	
Corridors	Corridors	Concrete Epoxy/Painted	all stairs except West Stairs (7 total)	6	3,080	SF	\$14,535	
Corridors	Corridors	Drinking Fountains	Kitchen Corridor in Basement			EA	\$0	
Corridors	Corridors	Drinking Fountains	West Stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	all stairs except West Stairs (7 total)			EA	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	5,583	SF	\$0	
Corridors	Corridors	Drop/Lay-In	3rd Floor	7	5,057	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	5,057	SF	\$0	
Corridors	Corridors	Floors	1st Floor	7	256	SF	\$0	
Corridors	Corridors	Lay-In	Kitchen Corridor in Basement	7	385	EA	\$0	
Corridors	Corridors	Pendant/Surface	all stairs except West Stairs (7 total)	7	3,752	EA	\$0	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	5,057	EA	\$0	
Corridors	Corridors	Pendant/Surface	3rd Floor	7	5,057	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	5,583	EA	\$0	
Corridors	Corridors	Pendant/Surface	West Stairs	7	704	EA	\$0	
Corridors	Corridors	Single Water Cooler	3rd Floor	7	8	EA	\$0	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	8	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	6	3	EA	\$1,845	
Corridors	Corridors	Single Water Cooler	1st Floor	7	9	EA	\$0	
Corridors	Corridors	Splined	Kitchen Corridor in Basement	6	80	SF	\$172	
Corridors	Corridors	Stair Handrails	West Stairs	6	121	LF	\$0	
Corridors	Corridors	Stair Handrails	all stairs except West Stairs (7 total)	6	642	LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Kitchen Corridor in Basement			LF	\$0	





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost F	Reason
Corridors	Corridors	Stairs	Kitchen Corridor in Basement			EA	\$0	
Corridors	Corridors	Stairs	all stairs except West Stairs (7 total)	7	298	EA	\$0	
Corridors	Corridors	Stairs	West Stairs	7	56	EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	Kitchen Corridor in Basement	7	740	SF	\$0	
Corridors	Corridors	Student Lockers	all stairs except West Stairs (7 total)			EA	\$0	
Corridors	Corridors	Student Lockers	West Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	Kitchen Corridor in Basement			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Kitchen Corridor in Basement	7	305	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	270	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	2,770	SF	\$0	
Corridors	Corridors	Walls	all stairs except West Stairs (7 total)	7	16,570	SF	\$0	
Corridors	Corridors	Walls	West Stairs	7	2,980	SF	\$0	
Corridors	Corridors	Walls	1st Floor	7	4,220	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	3,320	SF	\$0	
Corridors	Corridors	Walls	3rd Floor	6	3,794	SF	\$8,952	
Corridors	Corridors	Walls	2nd Floor	6	3,794	SF	\$8,952	
Corridors	Corridors	Walls	1st Floor	7	2,770	SF	\$0	
Corridors	Corridors	Walls	3rd Floor	7	2,770	SF	\$0	
Corridors	Corridors	Walls	1st Floor	7	3,794	SF	\$0	
Corridors	Corridors	Walls	3rd Floor	7	3,320	SF	\$0	
Corridors	Corridors	Walls	Kitchen Corridor in Basement	6	120	SF	\$283	
Corridors Ceiling	Corridors	Plaster/Drywall	West Stairs	7	704	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	all stairs except West Stairs (7 total)	7	3,752	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Kitchen Corridor in Basement	7	305	SF	\$0	



Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Floor	Classroom	Carpet		6	7,982	SF	\$11,414
Floor	Classroom	Carpet		6	420	SF	\$601
Floor	Classroom	Carpet		6	7,982	SF	\$11,414
Floor	Classroom	Carpet		6	420	SF	\$601
Floor	Classroom	Carpet		7	440	SF	\$0
Floor	Classroom	Carpet		6	420	SF	\$601
Floor	Classroom	Carpet		6	7,982	SF	\$11,414
Floor	Classroom	Carpet		6	420	SF	\$601
Floor	Classroom	Carpet		6	7,327	SF	\$10,478
Floor	Classroom	Carpet		6	420	SF	\$601
Floor	Classroom	Carpet		6	7,982	SF	\$11,414
Floor	Classroom	Carpet		6	7,982	SF	\$11,414
Floor	Classroom	Carpet		7	440	SF	\$0
Floor	Classroom	Carpet		7	420	SF	\$0
Floor	Classroom	Carpet		7	960	SF	\$0
Floor	Classroom	Carpet		7	960	SF	\$0
Floor	Classroom	Carpet		6	7,327	SF	\$10,478
Floor	Classroom	Carpet		6	7,982	SF	\$11,414
Floor	Classroom	Carpet		6	100	SF	\$143
Floor	Classroom	Carpet		6	7,302	SF	\$10,442
Floor	Classroom	Carpet		7	585	SF	\$0
Floor	Classroom	Carpet		6	420	SF	\$601
Floor	Classroom	Carpet		7	420	SF	\$0
Floor	Classroom	Carpet		6	885	SF	\$1,266
Floor	Classroom	Tile/Sheet		6	2,277	SF	\$3,256
Floor	Classroom	Tile/Sheet		6	6,564	SF	\$9,387
Floor	Classroom	Tile/Sheet		7	400	SF	\$0
Floor	Classroom	Tile/Sheet		7	680	SF	\$ 0
Floor	Classroom	Tile/Sheet		7	655	SF	\$ 0
Floor	Classroom	Tile/Sheet		7	655	SF	\$ 0
GYM_WALL	Standard Dedicated Gymnasium	Gymnasia Walls	2nd floor gym 2	7	5,160	SF	\$0
GYM_WALL	Standard Dedicated Gymnasium	Gymnasia Walls	1st floor primary gym	6	360	SF	\$3,089
GYM_WALL	Standard Dedicated Gymnasium	Gymnasia Walls	1st floor primary gym	7	730	SF	\$0
GYM_WALL	Standard Dedicated Gymnasium	Gymnasia Walls	2nd floor gym 1	7	3,240	SF	\$0





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
KITCHEN_LIGHT	Cooking Kitchen	Kitchen Lighting	Basement	4	5	EA	\$3,039 recessed
LIBRARY_CEILING	Library	Drop/Lay-In	2nd Floor	7	5,860	SF	\$0
LIBRARY_WALL	Library	Library Walls	2nd Floor	7	3,740	SF	\$0
LIBRARY_WALL	Library	Mansory	2nd Floor	7	415	SF	\$0
Lighting	Classroom	Pendant/Surface		7	17	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
Lighting	Classroom	Pendant/Surface		7	36	EA	\$0
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0
Lighting	Classroom	Pendant/Surface		7	80	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
Lighting	Classroom	Pendant/Surface		7	26	EA	\$0
Lighting	Classroom	Pendant/Surface		7	26	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0
Lighting	Classroom	Pendant/Surface		6	230	EA	\$16,445
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
Lighting	Classroom	Pendant/Surface		7	134	EA	\$0
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	2nd fl offices/computer labs/ prep rooms	7	400	SF	\$0
LUNCH_WALL	Lunchroom	Lunchroom Walls	1st Floor	7	100	SF	\$0
LUNCH_WALL	Lunchroom	Lunchroom Walls	1st Floor	6	1,390	SF	\$3,975
LUNCH_WALL	Lunchroom	Lunchroom Walls	1st FL Communication Dining	7	160	SF	\$0
LUNCH_WALL	Lunchroom	Lunchroom Walls	1st FL Communication Dining	7	1,330	SF	\$0





Building: Main Category: ROOM

Group	Sub Group	Itam	Location	Pank	Quantity	Unit	Cost Reason
Group	Sub Group	Item	Location	Kdlik	Quantity	Unit	COST Reason
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	1st fl offices/computer labs/ prep rooms	7	400	SF	\$0
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	1st fl offices/computer labs/ prep rooms	7	325	SF	\$0
LUNCH_WALL	Lunchroom	Lunchroom Walls	1st Floor	7	700	SF	\$0
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	2nd fl offices/computer labs/ prep rooms	7	325	SF	\$0
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	1st floor staff lunchroom/ lounge	7	960	SF	\$0
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	2nd fl offices/computer labs/ prep rooms	6	3,050	SF	\$8,723
LUNCH_WALL	Lunchroom	Lunchroom Walls	3rd Floor	6	960	SF	\$2,746
LUNCH_WALL	Lunchroom	Lunchroom Walls	3rd Floor	7	1,125	SF	\$0
LUNCH_WALL	Lunchroom	Lunchroom Walls	3rd Floor	7	745	SF	\$0
LUNCH_WALL	Lunchroom	Lunchroom Walls	2nd Floor	7	745	SF	\$0
LUNCH_WALL	Lunchroom	Lunchroom Walls	2nd Floor	6	760	SF	\$2,174
LUNCH_WALL	Lunchroom	Lunchroom Walls	2nd Floor	7	1,325	SF	\$0
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	1st fl offices/computer labs/ prep rooms	6	3,050	SF	\$8,723
Marker Board	Multipurpose Room	Marker Board	1st floor staff lunchroom/ lounge			LF	\$0
Marker Board	Multipurpose Room	Marker Board	1st fl offices/computer labs/ prep rooms	7	24	LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Classroom	Marker Board		7	8	LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Lunchroom	Marker Board	3rd Floor			LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Lunchroom	Marker Board	1st FL Communication Dining			LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Multipurpose Room	Marker Board	2nd fl offices/computer labs/ prep rooms	7	24	LF	\$0
Marker Board	Classroom	Marker Board		7	10	LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0
Marker Board	Classroom	Marker Board				LF	\$0



Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	4	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	4	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	48	LF	\$0	
Marker Board	Classroom	Marker Board		7	4	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Lunchroom	Marker Board	2nd Floor			LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	1st fl Men's West	7	85	SF	\$0	
RESTROOM_FLOOR	Children's Standard Student Restroom	Restroom Floor	3rd fl girls North East	7	170	SF	\$0	
RESTROOM_FLOOR	Children's Standard Student Restroom	Restroom Floor	2nd fl boys south	4	15	SF	\$467	missing uneven tile
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	2nd fl Men's West	7	85	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st fl boys south	6	500	SF	\$1,273	
Wall	Classroom	Masonry		7	545	SF	\$0	
Wall	Classroom	Masonry		7	550	SF	\$0	
Wall	Classroom	Masonry		7	995	SF	\$0	
Wall	Classroom	Masonry		7	200	SF	\$0	
Wall	Classroom	Masonry		7	995	SF	\$0	
Wall	Classroom	Masonry		7	300	SF	\$0	
Wall	Classroom	Masonry		7	1,567	SF	\$0	
Wall	Classroom	Masonry		7	995	SF	\$0	
Wall	Classroom	Masonry		7	300	SF	\$0	
Wall	Classroom	Masonry		7	545	SF	\$0	
Wall	Classroom	Masonry		7	995	SF	\$0	
Wall	Classroom	Masonry		7	995	SF	\$0	
Wall	Classroom	Masonry		7	995	SF	\$0	
Wall	Classroom	Masonry		7	140	SF	\$0	
Wall	Classroom	Masonry		7	545	SF	\$0	
Wall	Classroom	Masonry		7	320	SF	\$0	
Wall	Classroom	Masonry		7	300	SF	\$0	
Wall	Classroom	Masonry		7	995	SF	\$0	
Wall	Classroom	Masonry		7	145	SF	\$0	



Building: Main Category: ROOM

		Item	Location		Quantity	Unit	Cost Reason
Wall	Classroom	Masonry		7	155	SF	\$0
Wall	Classroom	Masonry		7	995	SF	\$0
Wall	Classroom	Masonry		7	145	SF	\$0
Wall	Classroom	Masonry		7	545	SF	\$0
Wall	Classroom	Masonry		7	145	SF	\$0
Wall	Classroom	Masonry		7	995	SF	\$0
Wall	Classroom	Masonry		7	300	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	695	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	540	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		6	285	SF	\$672
Wall	Classroom	Metal/Folding Panel		6	285	SF	\$672
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	630	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	1,115	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		6	285	SF	\$672
Wall	Classroom	Metal/Folding Panel		7	800	SF	\$0
Wall	Classroom	Metal/Folding Panel		6	285	SF	\$672
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		6	285	SF	\$672
Wall	Classroom	Metal/Folding Panel		6	285	SF	\$672
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	1,135	SF	\$0
Wall	Classroom	Metal/Folding Panel		6	285	SF	\$672
Wall	Classroom	Metal/Folding Panel		7	865	SF	\$0
Wall	Classroom	Metal/Folding Panel		7	785	SF	\$0
Wall	Classroom	Metal/Folding Panel		6	285	SF	\$672
Wall	Classroom	Metal/Folding Panel		7	695	SF	\$0
Wall	Classroom	Plaster/Drywall		7	160	SF	\$0
Wall	Classroom	Wall		7	245	SF	\$0
Wall	Classroom	Wall		7	245	SF	\$0
Wall	Classroom	Wall		7	750	SF	\$0 glass
Wall	Classroom	Wall		7	670	SF	\$0





Building: Main Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Wall		7	245	SF	\$0	
Wall	Classroom	Wall		7	750	SF	\$0	glass
Wall	Classroom	Wall		7	750	SF	\$0	glass
Wall	Classroom	Wall		7	750	SF	\$0	glass
Wall	Classroom	Wall		7	750	SF	\$0	glass
Wall	Classroom	Wall		7	750	SF	\$0	glass
Wall	Classroom	Wall		7	245	SF	\$0	
Wall	Classroom	Wall		7	750	SF	\$0	glass
Wall	Classroom	Wall		7	750	SF	\$0	
Wall	Classroom	Wall		7	720	SF	\$0	
Wall	Classroom	Wall		7	750	SF	\$0	glass
Wall	Classroom	Wall		7	300	SF	\$0	
			ROOM	Sub To	tal		\$279,881	

Building Main Sub Total

\$6,452,757

Building: CAC Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Doors		Exterior Steel Door	NW Corner	6	2	EA	\$661
Doors		Exterior Steel Door	Entire Site	7	24	EΑ	\$0
Doors		Exterior Steel Door	At Mech. Wells	7	8	EΑ	\$0
Doors		Exterior Steel Door	At SW Mech. Wells	4	2	EΑ	\$6,607
Doors		Side Lite	Outer Corners and Connector	7	11	EA	\$0
Doors		Transom Lite	At SW Mech. Well	7	2	EΑ	\$0
Doors		Transom Lite	At SW Mech Well (wood)	4	2	EΑ	\$5,663
Entrance		Stair Handrails	Catwalk at Roof	6	28	LF	\$0
Entrance		Steel or Aluminum Stairs	Catwalk at Roof	6	110	LF	\$779
Foundation		Concrete Foundation	Entire Building	7	832	LF	\$0
Lighting		Exterior Lights - Wall Mounted	Entire Site	7	10	EΑ	\$0
Roof System		Interior Downspouts	Entire Building	6	513	LF	\$0
Roof System		Modified Bitumen Roof	Main Roof and Mech. Wells	7	44,000	SF	\$0
Roof System		Roof Structure: Concrete	Entire Building	7	44,000	SF	\$0
Superstructure		Concrete	Entire Building	7	44,000	SF	\$0
Walls		Precast Panel Wall	Entire Building	6	19,400	SF	\$128,168
Windows		Curtain wall - Glazed Double Pane	Entire Building	7	2,455	SF	\$0





Building: CAC

Category: EXTERIOR

Group	Sub Group	Item	Location	Rank Quantity	Unit	Cost Reason	
Windows		Curtain wall - Glazed Single Pane	Entire Building	7 1,295	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7 1,900	SF	\$0	
-			EXTERI	OR Sub Total		\$141,877	

Building: CAC

Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	2,816	SF	\$0
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	900	SF	\$0
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	7	2	EA	\$0
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	3	16	EA	\$14,872
Emergency System		Public Announcement System	Entire Building	6	44,000	SF	\$26,426
Emergency System		Security System - Intrusion detection	Entire Building	7	44,000	SF	\$0
Main Service		Main Electrical service 2000 A 120/208/3PH	Electrical Room	6	1	EA	\$12,155
Main Service		Main Electrical service 2000 A 277/480/3PH	Electrical Room	6	1	EA	\$15,194
Power Distribution		Lighting and power panels	Entire Building	6	5	EA	\$3,575
Power Distribution		Main distribution panels above 600 amp	Electrical Room	6	2	EA	\$4,290
Power Distribution		Transformers 277/480-120/208	Electrical Room	6	1	EA	\$1,144
							A

ELECTRICAL Sub Total

\$77,656

Building: CAC

Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Roof Top Unit - Single Zone - Gas-Heating 11 to 20 tons	Roof	6	2	EA	\$8,580	
Air Handling Systems		Roof Top Unit - Single Zone - Gas-Heating 21 to 30 tons	Roof	6	4	EA	\$25,740	
Air Handling Systems		Roof Top Unit - Single Zone - Gas-Heating less than 5 tons	Roof	6	1	EA	\$1,430	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	7	6	EA	\$0	
Heating Devices		Fin Tube Electric	Entire Building	6	40	LF	\$572	
Heating Devices		Fin Tube Electric	Entire Building	5	12	LF	\$858	
Heating Devices		Fin Tube Electric	Entire Building	7	168	LF	\$0	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	5	44,000	SF	\$220,220	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	27	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	4	1	EA	\$930	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	6	EA	\$858	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	4	EA	\$6,006	





Building: CAC

Category: MECHANICAL

Group	Sub Group	Item	Location	Rank Quan	tity	Unit	Cost	Reason
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	3	EA	\$1,287	
			MECHANICAL	Sub Total			\$266.481	

Building: CAC

Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Electric less than 50 KW	Mechanical Room	6	2	EA	\$2,803	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	44,000	SF	\$14,472	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	44,000	SF	\$28,314	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	44,000	SF	\$9,438	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	44,000	SF	\$20,134	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	44,000	SF	\$23,910	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	44,000	SF	\$105,076	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	44,000	SF	\$86,830	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	44,000	SF	\$50,336	
Piping		Sanitary Piping	Entire Building	5	44,000	SF	\$27,056	
Piping		Storm Piping	Entire Building	5	44,000	SF	\$20,764	
Piping		Vent Piping	Entire Building	5	44,000	SF	\$15,730	
			DILIMBI	INC. Cub Ta			£404.0C0	

PLUMBING Sub Total

\$404,862

Building: CAC Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Steel Doors incl hw	Entire Building	6	8	EA	\$2,265	
Doors		Interior Wood Doors incl hw	Entire Building	6	41	EA	\$11,609	
Doors		Interior Wood Doors incl hw	Entire Building	5	3	EA	\$1,416	
Locker/Shower Room	Staff Restroom	Benches	SE mens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	NW girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	NW boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	SE boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	SE girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	SE womens			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	SE mens			EA	\$0	



Building: CAC Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Lockers	SE womens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	SE girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	SE boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	NW girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	NW boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	SE boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	SE girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	SE mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	NW boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	NW girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	SE womens			EA	\$0	
Lunchroom	Multipurpose Room	Ceiling - Exposed	1st Floor	7	25,360	SF	\$0	
Lunchroom	Multipurpose Room	Flooring - Carpet	1st Floor	6	13,285	SF	\$18,998	
Lunchroom	Multipurpose Room	Flooring - Carpet	1st Floor	6	12,075	SF	\$17,267	
Lunchroom	Multipurpose Room	Serving Line	1st Floor			LF	\$0	
Lunchroom	Multipurpose Room	Wall - Concrete Block	1st Floor	7	9,020	SF	\$0	
Mechanical/Service Rooms		Storage Room	work room	7	94	SF	\$0	
Mechanical/Service Rooms		Storage Room	Entire Building	6	2,539	SF	\$11,982	
Staff Restroom	Children's Standard Student Restroom	Accessories	NW girls	7	225	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	NW boys	7	225	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	SE boys	7	225	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	SE girls	7	225	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	SE womens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	SE mens	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	SE boys	7	225	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	SE girls	7	225	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	SE womens	7	91	SF	\$0	



Building: CAC Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	SE mens	7	91	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	NW boys	7	225	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	NW girls	7	225	SF	\$0
Staff Restroom	Staff Restroom	Floor Drain	SE mens	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	SE girls	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	SE boys	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	NW boys	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Floor Drain	NW girls	7	1	EA	\$0
Staff Restroom	Staff Restroom	Floor Drain	SE womens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	SE mens	7	91	SF	\$0
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	SE womens	7	91	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	SE girls	7	225	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	SE boys	7	225	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	NW boys	7	225	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	NW girls	7	225	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	SE girls			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	SE boys			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	NW girls			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	SE womens			EA	\$0
Staff Restroom	Staff Restroom	Hand Dryer	SE mens			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	NW boys			EA	\$0
Staff Restroom	Staff Restroom	Lavatory	SE mens	6	1	EA	\$372
Staff Restroom	Staff Restroom	Lavatory	SE womens	6	2	EA	\$744
Staff Restroom	Children's Standard Student Restroom	Lavatory	SE girls	6	3	EA	\$1,115
Staff Restroom	Children's Standard Student Restroom	Lavatory	NW boys	6	5	EA	\$1,859



Building: CAC Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	SE girls	7	1	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Lavatory	SE boys	6	5	EA	\$1,859
Staff Restroom	Children's Standard Student Restroom	Lavatory	NW girls	6	5	EA	\$1,859
Staff Restroom	Children's Standard Student Restroom	Lavatory	SE girls	5	1	EA	\$1,859
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	SE girls	7	4	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	SE boys	7	4	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	NW boys	7	4	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	SE mens	7	2	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	NW girls	7	4	SF	\$0
Staff Restroom	Staff Restroom	Lighting - Lay-In	SE womens	7	2	SF	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	SE girls	7	6	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	NW girls	7	6	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	SE boys	7	2	EA	\$0
Staff Restroom	Staff Restroom	Partitions	SE womens	7	2	EA	\$0
Staff Restroom	Staff Restroom	Partitions	SE mens	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Partitions	NW boys	7	2	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	NW girls			EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	NW boys	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	SE boys	7	4	EA	\$0
Staff Restroom	Children's Standard Student Restroom	Urinals	SE girls	7	4	EA	\$0
Staff Restroom	Staff Restroom	Urinals	SE womens			EA	\$0
Staff Restroom	Staff Restroom	Urinals	SE mens	7	1	EA	\$0
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	SE womens	6	300	SF	\$2,145
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	NW girls	6	563	SF	\$4,025
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	NW boys	6	563	SF	\$4,025



Building: CAC Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	SE girls	6	563	SF	\$4,025	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	SE mens	6	300	SF	\$2,145	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	SE boys	6	563	SF	\$4,025	
Staff Restroom	Children's Standard Student Restroom	Water Closet	NW girls	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	NW girls	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	SE boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	SE girls	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	SE womens	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	SE mens	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	NW boys	7	2	EA	\$0	
Vertical Conveyance		Stage Lift	in link to main building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
			INTERIOR	R Sub To	tal		\$96,226	

Building: CAC Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		5	5	LF	\$894	
Casework	Classroom	Casework		6	13	LF	\$465	
Casework	Classroom	Casework		5	5	LF	\$894	
Casework	Classroom	Casework		6	13	LF	\$465	
Ceiling	Classroom	Exposed Ceiling		7	1,595	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	1,650	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	1,595	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	743	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	837	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	743	SF	\$0	



Building: CAC Category: ROOM

Chalk Board Classroom Chalk Board 4 LF Chalk Board Classroom Chalk Board 4 LF Chalk Board Classroom Chalk Board 4 LF Chalk Board Classroom Chalk Board 1st Floor 4 LE Chalk Board Classroom Chalk Board 1st Floor 4 LE Chalk Board Classroom Chalk Board 4 LE Chridons Classroom Chalk Board 4 LE Corridors Exp. \$3,53 Corridors Corridors Corridors Corri	Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost Reason
Chalk Board Classroom Chalk Board 4 LF Chalk Board 1 4 LF Chalk Board 1 1 LF Chalk Board Classroom Chalk Board 4 LF Chalk Board Classroom Chalk Board 4 LF Corridors EA \$0 Corridors Corridors Corridors Corridors Drinking Fountains mezzamine walkway 7 1,777 SF \$0 Corridors Corridors	Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board Classroom Chalk Board 1st Floor 4 LF Chalk Board Chalk Board 2st Floor Chalk Board 4st Floor LF Chalk Board Chridors Corridors Elink to main school T EA \$0 Corridors Corridors Corridors Drinking Fountains SE link to main school T EA \$0 Corridors Corridors	Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board Multipurpose Room Chalk Board 1st Floor 4 LF Chalk Board Chalk Board LF Chalk Board LP Chardors Corridors Elink to main school T 15A \$1 \$1 \$1 \$1 \$1 \$1 \$1 \$1 \$1 \$1 \$1 \$1 \$1	Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board Classroom Chalk Board 4 LF LF Chalk Board Classroom Chalk Board 4 LF LF Corridors Exposed mezzzanine walkway 7 1,70 Exposed Solar Solar Solar	Chalk Board	Classroom	Chalk Board		4		LF	
Chalk Board Classroom Chalk Board Elink to main school 7 6.35 SF \$0 Corridors Corridors Conridors Conridors Conridors 7 1.42 SF \$0 Corridors Drinking Fountains SE link to main school T EA \$0 Corridors Corridors Corridors Corridors Drinking Fountains mezzanine walkway T T,177 SF \$0 Corridors Corridors Corridors Drinking Fountains mezzanine walkw	Chalk Board	Multipurpose Room	Chalk Board	1st Floor	4		LF	
Corridors Corridors Concrete Block SE link to main school 7 6.35 SF \$0 Corridors Corridors Concrete Block entire building- vestibules 7 1,224 SF \$0 Corridors Drinking Fountains SE link to main school 7 9.98 SF \$0 Corridors Corridors Orridors Orridors Drinking Fountains SE link to main school 7 9.98 SF \$0 Corridors Corridors Drinking Fountains SE link to main school 7 1.77 SF \$0 Corridors Corridors Exposed	Chalk Board	Classroom	Chalk Board		4		LF	
Corridors Corridors Concrete Block entire building-vestibules 7 1,424 SF \$0 Corridors Corridors Concrete Block enzezanine walkway 7 2,924 SF \$0 Corridors Drinking Fountains SE link to main school 7 958 \$5 \$0 Corridors Corridors Drinking Fountains SE link to main school F \$0 \$0 Corridors Corridors Drinking Fountains enterzanine walkway F \$1 \$0 Corridors Corridors Exposed mezzanine walkway F \$1 \$5 \$0 Corridors Corridors Exposed entire building-vestibules F \$0 \$0 Corridors Corridors L	Chalk Board	Classroom	Chalk Board		4		LF	
Corridors Corridors Concrete Block entire building- vestibules 7 2,924 SF \$0 Corridors Drinking Fountains SE link to main school 7 958 SF \$0 Corridors Corridors Drinking Fountains SE link to main school 7 958 SF \$0 Corridors Corridors Drinking Fountains mezzanine walkway 7 1,770 SF \$0 Corridors Corridors Exposed mezzanine walkway 7 1,770 SF \$0 Corridors Corridors Lay-In seli hust main school 7 2,924 SF \$0 <td< td=""><td>Corridors</td><td>Corridors</td><td>Concrete Block</td><td>SE link to main school</td><td>7</td><td>635</td><td>SF</td><td>\$0</td></td<>	Corridors	Corridors	Concrete Block	SE link to main school	7	635	SF	\$0
Corridors Corridors Concrete Block mezzanine walkway 7 480 SF \$0 Corridors Corridors Concrete Epoxy/Painted mezzanine walkway 6 1,770 SF \$8,353 Corridors Corridors Corridors Corridors Corridors Corridors Corridors Corridors Corridors Drinking Fountains SE link to main school 7 958 SF \$0 Corridors Corridors Drinking Fountains SE link to main school 7 958 SF \$0 Corridors Corridors Drinking Fountains mezzanine walkway 7 1,770 SF \$0 Corridors Corridors Exposed mezzanine walkway 7 1,770 SF \$0 Corridors Corridors Exposed mezzanine walkway 7 422 SF \$0 Corridors Corridors Lay-In self building- vestibules 7 495 EA \$0 Corridors Corridors	Corridors	Corridors	Concrete Block	entire building- vestibules	7	1,424	SF	\$0
Corridors Corridors Concrete Epoxy/Painted mezzanine walkway 6 1,770 SF \$8,353 Corridors Corridors Concridors Concrete Epoxy/Painted entre building- vestibules 6 1,046 SF \$4,936 Corridors Corridors Corridors Corridors Drinking Fountains SE link to main school 7 958 S \$0 Corridors Corridors Corridors Drinking Fountains entire building- vestibules F EA \$0 Corridors Corridors Corridors Exposed mezzanine walkway 7 1,770 SF \$0 Corridors Corridors Exposed mezzanine walkway 7 2,244 SF \$0 Corridors Corridors Exposed mezzanine walkway 7 4,422 EA \$0 Corridors Corridors Lay-In SE link to main school 7 9,58 EA \$0 Corridors Corridors Corridors Lighting <th< td=""><td>Corridors</td><td>Corridors</td><td>Concrete Block</td><td>entire building- vestibules</td><td>7</td><td>2,924</td><td>SF</td><td>\$0</td></th<>	Corridors	Corridors	Concrete Block	entire building- vestibules	7	2,924	SF	\$0
Corridors Corridors Concrete Epoxy/Painted entire building- vestibules 6 1,046 SF \$4,936 Corridors Corridors Corridors Corridors Drinking Fountains SE link to main school 7 958 SF \$0 Corridors Corridors Drinking Fountains entire building- vestibules EA \$0 Corridors Corridors Drinking Fountains mezzanine walkway FA \$0 Corridors Corridors Exposed mezzanine walkway 7 1,770 SF \$0 Corridors Corridors Exposed entire building- vestibules 7 224 SF \$0 Corridors Corridors Lay-In entire building- vestibules 7 442 EA \$0 Corridors Corridors Lay-In Elnk to main school 7 958 EA \$0 Corridors Corridors Metal Panel SE link to main school 7 234 SF \$0 Corridors	Corridors	Corridors	Concrete Block	mezzanine walkway	7	480	SF	\$0
Corridors Conridors Conridors Conridors SE link to main school 7 958 SF \$0 Corridors Corridors Drinking Fountains SE link to main school EA \$0 Corridors Corridors Drinking Fountains entire building- vestibules EA \$0 Corridors Corridors Exposed mezzanine walkway 7 1,770 SF \$0 Corridors Corridors Exposed metzanine walkway 7 1,770 SF \$0 Corridors Corridors Lay-In entire building- vestibules 7 242 SF \$0 Corridors Corridors Lay-In SE link to main school 7 958 EA \$0 Corridors Corridors Lay-In SE link to main school 7 234 SF \$0 Corridors Corridors Corridors Metal Panel SE link to main school 7 234 SF \$0 Corridors Corridors Stai	Corridors	Corridors	Concrete Epoxy/Painted	mezzanine walkway	6	1,770	SF	\$8,353
Corridors Corridors Corridors Corridors Corridors EA \$0 Corridors Corridors Drinking Fountains entire building- vestibules EA \$0 Corridors Corridors Exposed mezzanine walkway 7 1,770 SF \$0 Corridors Corridors Exposed entire building- vestibules 7 422 SF \$0 Corridors Corridors Lay-In entire building- vestibules 7 422 SF \$0 Corridors Corridors Lay-In SE link to main school 7 958 EA \$0 Corridors Corridors Lighting mezzanine walkway 7 422 EA \$0 Corridors Corridors Corridors Lighting mezzanine walkway 7 234 SF \$0 Corridors Corridors Metal Panel SE link to main school 7 234 SF \$0 Corridors Corridors Stair Handrails	Corridors	Corridors	Concrete Epoxy/Painted	entire building- vestibules	6	1,046	SF	\$4,936
Corridors Corridors Drinking Fountains entire building- vestibules EA \$0 Corridors Corridors Drinking Fountains mezzanine walkway 7 1,70 SF \$0 Corridors Corridors Exposed entire building- vestibules 7 224 SF \$0 Corridors Corridors Lay-In entire building- vestibules 7 442 EA \$0 Corridors Corridors Lay-In SE link to main school 7 958 EA \$0 Corridors Corridors Lay-In SE link to main school 7 958 EA \$0 Corridors Corridors Metal Panel SE link to main school 7 234 SF \$0 Corridors Corridors Metal Panel SE link to main school 7 234 SF \$0 Corridors Corridors Stair Handrails mezzanine walkway 6 350 EA \$257 Corridors Corridors Stair Handrails SE link to main school F \$0 \$0 Corridors Corridors Stair Handrails SE link to main school F \$0 \$0 Corridors Corridors </td <td>Corridors</td> <td>Corridors</td> <td>Concrete Epoxy/Painted</td> <td>SE link to main school</td> <td>7</td> <td>958</td> <td>SF</td> <td>\$0</td>	Corridors	Corridors	Concrete Epoxy/Painted	SE link to main school	7	958	SF	\$0
CorridorsCorridorsDrinking Fountainsmezzanine walkway71,770SF\$0CorridorsCorridorsExposedmezzanine walkway71,770SF\$0CorridorsCorridorsExposedentire building- vestibules7224SF\$0CorridorsCorridorsLay-Inentire building- vestibules7442EA\$0CorridorsCorridorsLightingmezzanine walkway-EA\$0CorridorsCorridorsMetal PanelSE link to main school7234SF\$0CorridorsCorridorsPendant/Surfaceentire building- vestibules6350EA\$257CorridorsCorridorsStair Handrailsmezzanine walkway6354LF\$0CorridorsCorridorsStair HandrailsSE link to main schoolLF\$0CorridorsCorridorsStair HandrailsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsWallsSE link to main schoolFEA <td>Corridors</td> <td>Corridors</td> <td>Drinking Fountains</td> <td>SE link to main school</td> <td></td> <td></td> <td>EA</td> <td>\$0</td>	Corridors	Corridors	Drinking Fountains	SE link to main school			EA	\$0
CorridorsCorridorsExposedmezzanine walkway71,770SF\$0CorridorsCorridorsExposedentire building- vestibules7224SF\$0CorridorsCorridorsLay-Inentire building- vestibules7442EA\$0CorridorsCorridorsLay-InSE link to main school7958EA\$0CorridorsCorridorsLightingmezzanine walkwayEA\$0CorridorsCorridorsMetal PanelSE link to main school7234SF\$0CorridorsCorridorsPendant/Surfaceentire building- vestibules6360EA\$257CorridorsCorridorsStair Handrailsmezzanine walkway6360EA\$257CorridorsCorridorsStair HandrailsSE link to main schoolF\$0CorridorsCorridorsStair HandrailsSE link to main schoolF\$0CorridorsCorridorsStairsSE link to main schoolF\$0CorridorsCorridorsStairsmezzanine walkwayF\$0CorridorsCorridorsStudent Lockersmezzanine walkwayF\$0CorridorsCorridorsStudent LockersSE link to main schoolFEA\$0CorridorsCorridorsStudent LockersSE link to main schoolFEA\$0CorridorsCorridorsWallsSE link to main schoolF\$210 <td>Corridors</td> <td>Corridors</td> <td>Drinking Fountains</td> <td>entire building- vestibules</td> <td></td> <td></td> <td>EA</td> <td>\$0</td>	Corridors	Corridors	Drinking Fountains	entire building- vestibules			EA	\$0
CorridorsCorridorsExposedentire building- vestibules7224SF\$0CorridorsCorridorsLay-Inentire building- vestibules7442EA\$0CorridorsCorridorsLay-InSE link to main school7958EA\$0CorridorsCorridorsLightingmezzanine walkwayEA\$0CorridorsCorridorsMetal PanelSE link to main school7234SF\$0CorridorsCorridorsPendant/Surfaceentire building- vestibules6360EA\$257CorridorsCorridorsStair Handrailsmezzanine walkway6354LF\$0CorridorsCorridorsStair Handrailsentire building- vestibulesLF\$0CorridorsCorridorsStairsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsentire building- vestibulesEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent LockersElink to main schoolEA\$0CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corri	Corridors	Corridors	Drinking Fountains	mezzanine walkway			EA	\$0
Corridors Corridors Lay-In entire building-vestibules 7 442 EA \$0 Corridors Corridors Lay-In SE link to main school 7 958 EA \$0 Corridors Corridors Lighting mezzanine walkway EA \$0 Corridors Corridors Metal Panel SE link to main school 7 234 \$F \$0 Corridors Corridors Pendant/Surface entire building- vestibules 6 360 EA \$257 Corridors Corridors Stair Handrails mezzanine walkway 6 354 LF \$0 Corridors Corridors Stair Handrails entire building- vestibules LF \$0 Corridors Corridors Stair Handrails SE link to main school LF \$0 Corridors Corridors Stairs SE link to main school LF \$0 Corridors Corridors Stairs mezzanine walkway EA \$0 Corridors Corridors Student Lockers SE link to main school LF EA </td <td>Corridors</td> <td>Corridors</td> <td>Exposed</td> <td>mezzanine walkway</td> <td>7</td> <td>1,770</td> <td>SF</td> <td>\$0</td>	Corridors	Corridors	Exposed	mezzanine walkway	7	1,770	SF	\$0
CorridorsCorridorsLay-InSE link to main school7958EA\$0CorridorsCorridorsLightingmezzanine walkwayEA\$0CorridorsCorridorsMetal PanelSE link to main school7234SF\$0CorridorsCorridorsPendant/Surfaceentire building- vestibules6360EA\$257CorridorsCorridorsStair Handrailsmezzanine walkway6354LF\$0CorridorsCorridorsStair Handrailsentire building- vestibulesLF\$0CorridorsCorridorsStair HandrailsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsmezzanine walkwayLF\$0CorridorsCorridorsStudent Lockersmezzanine walkwayLF\$0CorridorsCorridorsStudent LockersSE link to main schoolLF\$0CorridorsCorridorsStudent LockersSE link to main schoolLF\$0CorridorsCorridorsStudent LockersSE link to main schoolLF\$0CorridorsCorridorsStudent LockersSE link to main schoolS\$1\$5\$991CorridorsCorridorsWallsmezzanine walkway7\$4,248SF\$0Corridors <td>Corridors</td> <td>Corridors</td> <td>Exposed</td> <td>entire building- vestibules</td> <td>7</td> <td>224</td> <td>SF</td> <td>\$0</td>	Corridors	Corridors	Exposed	entire building- vestibules	7	224	SF	\$0
CorridorsCorridorsLightingmezzanine walkwayEA\$0CorridorsCorridorsMetal PanelSE link to main school7234SF\$0CorridorsCorridorsPendant/Surfaceentire building- vestibules6360EA\$257CorridorsCorridorsStair Handrailsmezzanine walkway6354LF\$0CorridorsCorridorsStair Handrailsentire building- vestibulesLF\$0CorridorsCorridorsStairsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsStudent LockerssE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0CorridorsCorridorsWallsmezzanine walkway74,248SF\$0CorridorsCorridorsWallsmezzanine walkway74,248SF\$0 </td <td>Corridors</td> <td>Corridors</td> <td>Lay-In</td> <td>entire building- vestibules</td> <td>7</td> <td>442</td> <td>EA</td> <td>\$0</td>	Corridors	Corridors	Lay-In	entire building- vestibules	7	442	EA	\$0
CorridorsCorridorsMetal PanelSE link to main school7234SF\$0CorridorsCorridorsPendant/Surfaceentire building- vestibules6360EA\$257CorridorsCorridorsStair Handrailsmezzanine walkway6354LF\$0CorridorsCorridorsStair Handrailsentire building- vestibulesLF\$0CorridorsCorridorsStair HandrailsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsentire building- vestibulesEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent LockersEInk to main schoolEA\$0CorridorsCorridorsStudent LockersEInk to main schoolEA\$0CorridorsCorridorsWallsSE link to main school\$\$1\$1\$1CorridorsCorridorsWallsmezzanine walkway\$\$4,248\$F\$0CorridorsCorridorsWallsmezzanine walkway\$7\$4,248\$F\$0CorridorsCorridorsWallsmezzanine walkway\$7\$4,248\$F\$0 <td>Corridors</td> <td>Corridors</td> <td>Lay-In</td> <td>SE link to main school</td> <td>7</td> <td>958</td> <td>EA</td> <td>\$0</td>	Corridors	Corridors	Lay-In	SE link to main school	7	958	EA	\$0
CorridorsCorridorsPendant/Surfaceentire building- vestibules6360EA\$257CorridorsCorridorsStair Handrailsmezzanine walkway6354LF\$0CorridorsCorridorsStair Handrailsentire building- vestibulesLF\$0CorridorsCorridorsStair HandrailsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsentire building- vestibulesEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent LockersElink to main schoolEA\$0CorridorsCorridorsStudent LockersElink to main schoolEA\$0CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0CorridorsCorridorsWallsmezzanine walkway74,248SF\$0CorridorsCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Lighting	mezzanine walkway			EA	\$0
CorridorsCorridorsStair Handrailsmezzanine walkway6354LF\$0CorridorsCorridorsStair Handrailsentire building- vestibulesLF\$0CorridorsCorridorsStair HandrailsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsentire building- vestibulesEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent LockersEInk to main schoolEA\$0CorridorsCorridorsStudent LockersEInk to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Metal Panel	SE link to main school	7	234	SF	\$0
CorridorsCorridorsStair Handrailsentire building- vestibulesLF\$0CorridorsCorridorsStair HandrailsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsentire building- vestibulesEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsStudent LockersSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Pendant/Surface	entire building- vestibules	6	360	EA	\$257
CorridorsCorridorsStair HandrailsSE link to main schoolLF\$0CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsentire building- vestibulesEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Stair Handrails	mezzanine walkway	6	354	LF	\$0
CorridorsCorridorsStairsSE link to main schoolEA\$0CorridorsCorridorsStairsentire building- vestibulesEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Stair Handrails	entire building- vestibules			LF	\$0
CorridorsCorridorsStairsentire building- vestibulesEA\$0CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Stair Handrails	SE link to main school			LF	\$0
CorridorsCorridorsStairsmezzanine walkwayEA\$0CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Stairs	SE link to main school			EA	\$0
CorridorsCorridorsStudent Lockersmezzanine walkwayEA\$0CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Stairs	entire building- vestibules			EA	\$0
CorridorsCorridorsStudent LockersSE link to main schoolEA\$0CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Stairs	mezzanine walkway			EA	\$0
CorridorsCorridorsStudent Lockersentire building- vestibulesEA\$0CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Student Lockers	mezzanine walkway			EA	\$0
CorridorsCorridorsWallsSE link to main school5210SF\$991CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Student Lockers	SE link to main school			EA	\$0
CorridorsCorridorsWallsmezzanine walkway74,248SF\$0Corridors CeilingCorridorsPlaster/DrywallSE link to main school7908SF\$0	Corridors	Corridors	Student Lockers	entire building- vestibules			EA	\$0
Corridors Ceiling Corridors Plaster/Drywall SE link to main school 7 908 SF \$0	Corridors	Corridors	Walls	SE link to main school	5	210	SF	\$991
·	Corridors	Corridors	Walls	mezzanine walkway	7	4,248	SF	\$0
Corridors Ceiling Corridors Plaster/Drywall SE link to main school 4 50 SF \$661	Corridors Ceiling	Corridors	Plaster/Drywall	SE link to main school	7	908	SF	\$0
	Corridors Ceiling	Corridors	Plaster/Drywall	SE link to main school	4	50	SF	\$661



Building: CAC Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors Ceiling	Corridors	Plaster/Drywall	entire building- vestibules	6	224	SF	\$634	
Floor	Classroom	Carpet		4	837	SF	\$8,690	
Floor	Classroom	Carpet		5	743	SF	\$2,656	
Floor	Classroom	Carpet		5	1,595	SF	\$5,702	
Floor	Classroom	Carpet		6	1,650	SF	\$2,360	
loor	Classroom	Carpet		5	743	SF	\$2,656	
loor	Classroom	Carpet		6	740	SF	\$1,058	
loor	Classroom	Concrete		6	855	SF	\$4,035	
ighting	Classroom	Lay-In		7	11	EA	\$0	
ighting	Classroom	Lay-In		7	11	EA	\$0	
ighting	Classroom	Lay-In		7	11	EA	\$0	
ighting	Classroom	Lighting		6	18	EA	\$1,673	
ighting	Classroom	Lighting		6	18	EA	\$1,673	
ighting	Classroom	Lighting		6	18	EA	\$1,673	
UNCH_LIGHT	Multipurpose Room	Lunchroom Lighting	1st Floor	6	259	EA	\$24,074	
UNCH_WALL	Multipurpose Room	Lunchroom Walls	1st Floor	7	2,612	SF	\$0	
larker Board	Classroom	Marker Board				LF	\$0	
larker Board	Classroom	Marker Board				LF	\$0	
larker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
larker Board	Multipurpose Room	Marker Board	1st Floor			LF	\$0	
larker Board	Classroom	Marker Board				LF	\$0	
larker Board	Classroom	Marker Board		7	4	LF	\$0	
Vall	Classroom	Concrete Block		6	1,048	SF	\$2,997	
Vall	Classroom	Concrete Block		7	878	SF	\$0	
Vall	Classroom	Concrete Block		7	625	SF	\$0	
Vall	Classroom	Concrete Block		7	625	SF	\$0	
/all	Classroom	Concrete Block		7	878	SF	\$0	
/all	Classroom	Metal/Folding Panel		6	143	SF	\$337	
Vall	Classroom	Metal/Folding Panel		7	2,311	SF	\$0	
Vall	Classroom	Metal/Folding Panel		7	2,311	SF	\$0	
Vall	Classroom	Metal/Folding Panel		7	2,345	SF	\$0	
			ROOM	Sub To	al		\$78,134	

Building CAC Sub Total

\$1,065,234





Building: SITE Category: SITE

Group Sub Group Item Location Rank Quantity Unit Cost Reason

Building: SITE Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	NE Play Area and Concrete Amphitheater	6	2	EA	\$1,087	ponding
Civil/Drainage		Catch Basin	Entire Site	7	17	EA	\$0	
Civil/Drainage		Site Drain	North and West of Main Building	4	5	EA	\$5,577	concrete boxes, filled with water, missing grates
Civil/Drainage		Site Drain	Entire Site	7	14	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	23	EA	\$0	
Fencing		Chain Link	CAC Rooftop Play Area	7	820	LF	\$0	
Fencing		Chain Link	South Lot Line and SW Play Area	6	1,260	LF	\$18,072	
Fencing		Guard Rail	West Drive	6	612	LF	\$17,328	
Fencing		Ornamental Iron	Entire Site	7	2,810	LF	\$0	missing post caps
Fencing		Wood Fencing w/ Steel Frame	South Lot Line	6	780	LF	\$9,570	
Landscape		Asphalt Play Area/Hardscape	South West Playlot	5	636	SF	\$1,801	deteriorated
Landscape		Asphalt Play Area/Hardscape	West Amphitheater	6	1,260	SF	\$1,081	
_andscape		Asphalt Play Area/Hardscape	NE Play lot	6	8,352	SF	\$7,166	ponding
_andscape		Benches	West Center Play Lot and NE Play lot	7	6	EA	\$0	
Landscape		Benches	West Door 6	6	1	EA	\$236	
_andscape		Benches	West of CAC and Main Entry Plaza	6	8	EA	\$1,888	concrete
Landscape		Benches	NE Play area	5	2	EA	\$1,557	wood, deteriorating
_andscape		Grass	North West- Baseball field- sinkhole	3	20	SF	\$79	
Landscape		Grass	Entire Site	7	159,270	SF	\$0	
_andscape		Hardscape - Concrete	Entire Site	6	80,711	SF	\$152,350	
_andscape		Hardscape - Concrete	under overhangs @ CAC	5	1,947	SF	\$12,139	pitted
_andscape		Hardscape - Concrete	West of CAC	5	2,022	SF	\$12,607	ponding
Landscape		Hardscape - Pavers	East Main Entry	6	5,422	SF	\$15,352	uneven at perimeter
_andscape		Hardscape - Pavers	West Amphitheater	6	1,040	SF	\$2,945	ponding
Landscape		Irrigation	North and East	7	7,000	SF	\$0	
_andscape		Parkway trees	Entire Site	7	29	EA	\$0	
_andscape		Planting Beds/ Areas	West of CAC	5	1,644	SF	\$0	ponding
andscape		Planting Beds/ Areas	NW of CAC	4	400	SF	\$4,530	ponding, asphalt
Landscape		Planting Beds/ Areas	East Main Entry	7	96	SF	\$0	
Landscape		Planting Beds/ Areas	NE Playlot	7	6,162	SF	\$0	



Building: SITE Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Landscape		Planting Beds/ Areas	Corners of CAC	6	930	SF	\$0	
Landscape		Retaining Wall - Concrete	South Drive, Loading Dock, Stairs	6	16,086	SF	\$379,549	
Landscape		Trash Receptacles	NE Field and NE play	5	4	EA	\$2,741	
Landscape		Trash Receptacles	West Site and West Center Play Lot	7	2	EA	\$0	
Parking Lot		Asphalt	South Lot and Drive	4	44,625	SF	\$382,883	pot holes
Parking Lot		Asphalt	SE Parking Structure	6	2,725	SF	\$2,338	ponding at entrance
Parking Lot		Asphalt	West Drive	5	3,425	SF	\$9,698	cracks
Parking Lot		Asphalt	NW Lot	7	23,520	SF	\$0	
Parking Lot		Concrete	North West Parking Lot Driveway	5	1,200	SF	\$7,482	cracked, uneven
Parking Lot		Concrete Curbs	North West Parking Lot	7	344	LF	\$0	
Parking Lot		Concrete Curbs	South Parking and Drive	6	1,838	LF	\$11,092	spalling
Parking Lot		Parking lot interior plantings	NW and South Lots	7	11	LF	\$0	
Parking Lot		Trash Compactor	South Loading Dock	7	1	EA	\$0	
Playground		Playground Equipment - Pre-K 3-5	West Center	7	1	EA	\$0	
Playground		Playground Equipment - Pre-K 3-5	South West	6	1	EA	\$0	multiple pieces of equipment
Playground		Playground Equipment - School Age 5-12	NE Corner	6	1	EA	\$0	heavy timber
Playground		Playground Surfacing - Square Rubber Mats	West Center	4	2,080	SF	\$46,103	
Playground		Playground Surfacing - Wood Chips	North East	6	4,065	SF	\$5,813	gravel, eroded
Playground		Playground Surfacing - Wood Chips	South West	6	7,200	SF	\$10,296	eroded
Service Garage		Garage - Built-In	South Loading Dock	7	1,711	SF	\$0	ponding inside door
Sidewalks		Perimeter Sidewalks	Entire Site	6	9,635	SF	\$18,187	
Signage		Flag Pole	SE over parking garage	7	1	EA	\$0	
			SITE	Sub To	tal		\$1,141,545	

SITE Sub Total \$1,141,545



4140 N Marine Dr Chicago, IL 60613

Building: SITE Category: SITE

Group Sub Group Item Location Rank Quantity Unit Cost Reason

Total Campus Need ^{2 3} \$8,659,537

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.



4140 N Marine Dr Chicago, IL 60613

Room Su	mmar	у												
Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet		Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building:	Main													
1 off staff T	500			6	40				N	Υ	Υ	Classroom		
100	7982	35	40	122	40	734	55		Y	N	Υ	Classroom		
100A	420	15		4	40				N	N	Υ	Classroom		
110	7982	35	40	122	40	734	55		Υ	N	Υ	Classroom		
110A	420	15		4	40				N	N	Υ	Classroom		
120	7982	35	40	122	40	734	55		Υ	N	Υ	Classroom		
200	7982	35	40	122	40	734	55		Υ	N	Υ	Classroom		
200A	420	15		4	40				N	N	Υ	Classroom		
210	7982	35	40	122	40	734	55		Υ	N	Υ	Classroom		
210A	420	15	16	36	40				N	N	Υ	Classroom		
220	7982	35	40	122	40	734	55		Υ	N	Υ	Classroom		
220A	420	15	16	36	40				N	N	Υ	Classroom		
221 on plan	960	1	2	6	40	335			N	Υ	Υ	Classroom		
223 on plan	960	1	2	6	40	195			N	Υ	Υ	Classroom		
3 near	885			6	40				N	Υ	Υ	Classroom		
staff Ts 3 off dining	585			6	40				N	Υ	Υ	Classroom	1	T
300	7982	35	40		40	734	55		Y	N	Y	Classroom		
300A	420	15		122	40	734	33		N	N	Y	Classroom		
310	7982	35		-	40	734	55		Y	N	Y	Classroom		
310A	420	15		122	40	7.54	55		N	N	Y	Classroom		
320	7982	35		122	40	734	55		Y	N	Y	Classroom		
320A	420	15		4	40	7.54	33		N	N	Y	Classroom		
3rd fl	6564	14		•	40	556	20		Y	N	Y	Classroom		
science	0304	14	24	30	40	330	20		'	IN	ı	Classicom		
3rd fl west	2277	2	66	180	40	476	110		Υ	N	Υ	Classroom		
Library 1	440			4	40	125			N	Υ	Υ	Classroom		
Library 2	440			4	40	125			N	N	Υ	Classroom		
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls east/south
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys east
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls North East
Other	145								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys North West
Other									N	N	N	Corridors		West Stairs
Other	4030								N	N	N	Kitchen	Cooking Kitchen	Basement
Other	145			6					N	N	Υ	Administrative Suites/Offices		clerks office
Other	145								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys south



4140 N Marine Dr Chicago, IL 60613

Room Su	ımmar	У												
Room Number	Room Size	Voice Outlet	Data Outlet		Noise Level		Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip		Room Sub Type	Location
Other	21								N	N	N	Restroom	Children's Standard Student Restroom	in 1st floor classroom off teachers toilets
Other	145								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys North West
Other	145			4					N	N	N	Administrative Suites/Offices		library office
Other	215			6					N	N	Υ	Administrative Suites/Offices		asst principals office
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls south
Other	145								N	N	N	Restroom	Staff Restroom	2nd fl womens
Other	85								N	N	N	Restroom	Staff Restroom	2nd fl Men's West
Other	295								N	N	N	Restroom	Locker/Shower Room	basement mens in kitchen corridor
Other	85								N	N	N	Restroom	Staff Restroom	3rd fl Men's West
Other	3960								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls North East
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls east/south
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys east
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls south
Other	145								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys south
Other	4450								N	N	N	Lunch & Multipurpose Room	Lunchroom	3rd Floor
Other	4561			40					N	N	Υ	Administrative Suites/Offices		3rd fl office
Other	375			8					N	N	Υ	Administrative Suites/Offices		in 3rd fl science lab (FP says
				1		1	1							storage)
Other	85								N	N	N	Restroom	Staff Restroom	3rd fl Women's West
Other	170								N	N	N	Restroom	Early Childhood Student Restroom	1st fl girls east/south
Other	580			6					N	N	N	Administrative Suites/Offices		2nd floor nurse
Other	145								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys south
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls south
Other	18								N	N	N	Restroom	Staff Restroom	2nd floor nurses office
Other	145								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys north east
Other									N	N	N	Corridors		all stairs except West Stairs (7 total)
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls north
Other	85								N	N	N	Restroom	Staff Restroom	1st fl Men's West
Other	2350								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st FL Communication Dining
Other	45								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor nurses office
Other	385								N	N	N	Corridors		Kitchen Corridor in Basement
Other	4561			112					N	N	Υ	Lunch & Multipurpose Room	Multipurpose Room	1st fl offices/computer labs/ prep rooms
Other	3860								N	N	N	Gymnasia	Standard Dedicated Gymnasium	2nd floor gym 1
Other	3860								N	N	N	Gymnasia	Standard Dedicated Gymnasium	2nd floor gym 2
Other	5057								N	N	N	Corridors	January Dodious Cymnasian	3rd Floor
Accoccmon		<u> </u>	I	<u> </u>	l	<u> </u>	<u> </u>		.,,	l ''				Page 54



4140 N Marine Dr Chicago, IL 60613

Room	Room	Voice	Data	Elect		Glaze	Operable	No. of		Smart	Power	Room Type	Room Sub Type	Location
Number	Size	Outlet	Outlet	Outlet	Level	Window Area	Window Area	Window AC	Stop	Board	Strip			
Other	5057								N	N	N	Corridors		2nd Floor
Other	5583								N	N	N	Corridors		1st Floor
Other	5860								N	N	N	Library		2nd Floor
Other	129								N	N	N	Restroom	Staff Restroom	basement womens in kitchen corridor
Other	170								N	N	N	Restroom	Early Childhood Student Restroom	1st fl boys east
Other	145								N	N	N	Restroom	Staff Restroom	1st fl womens
Other	4450								N	N	N	Lunch & Multipurpose Room	Lunchroom	2nd Floor
Other	3860								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st floor primary gym
Other	4561			112					N	N	Υ	Lunch & Multipurpose Room	Multipurpose Room	2nd fl offices/computer labs/ prep rooms
Other	600								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	1st floor staff lunchroom/ lounge
Other	55								N	N	N	Restroom	Staff Restroom	basement mens in kitchen corrido
Other	232			8					N	N	Υ	Administrative Suites/Offices		principals office
Other	278								N	N	N	Restroom	Locker/Shower Room	basement womens in kitchen corridor
Other	21								N	N	N	Restroom	Children's Standard Student Restroom	in 1st floor classroom off teacher toilets
Other	1127			10					N	N	N	Administrative Suites/Offices		main office
Other	115			16					N	N	Υ	Administrative Suites/Offices		work room in main office
Other	205			4					N	N	Υ	Administrative Suites/Offices		1st floor office next to staff toilets
Other	130			4					N	N	Υ	Administrative Suites/Offices		in kitchen
Other	275			4					N	N	N	Administrative Suites/Offices		2nd floor technology office
Other	275			4					N	N	N	Administrative Suites/Offices		2nd floor shared music office/ faculty lounge
Other	205			4					N	N	Υ	Administrative Suites/Offices		1st floor office next to staff toilets
Building:	CAC													
Music CR	743	1		2	40				N	N	N	Classroom		
Music CR 2	837	1	43	94	40				N	N	Υ	Classroom		
NE	743	1		2	40				N	N	N	Classroom		
workroom														
Other	91								N	N	N	Restroom	Staff Restroom	SE mens
Other	91								N	N	N	Restroom	Staff Restroom	SE womens
Other	225								N	N	N	Restroom		SE girls
Other	225								N	N	N	Restroom	Children's Standard Student Restroom	SE boys
Other	225								N	N	N	Restroom	Children's Standard Student Restroom	NW boys
Other	225								N	N	N	Restroom	Children's Standard Student Restroom	NW girls
Other	1046								N	N	N	Corridors		entire building- vestibules
Other	1770								N	N	N	Corridors		mezzanine walkway



4140 N Marine Dr Chicago, IL 60613

Room Summary														
Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC		Smart Board			Room Sub Type	Location
Other	25360								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	1st Floor
Other	958			2					N	N	N	Corridors		SE link to main school
Studio 1	1595	1	1	11	40	93			N	N	Υ	Classroom		
Studio 2	1650		36	81	40	111			N	N	N	Classroom		
Studio 3	1595	1	1	11	40	93			N	N	Υ	Classroom		