

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	Main, south student entrances	7	844	SF	\$0	
Chimney		Metal Flue	Roof	6	26	LF	\$1,673	
Doors		Exterior Steel Door	Entire Building	7	15	EA	\$0	
Doors		Overhead Rolling / Garage Door	South Façade	7	1	EA	\$0	
Doors		Store Front Door	Entire Building	7	11	EA	\$0	
Entrance		Entrance Controls - Audio and Video	Entire Building	7	3	EA	\$0	
Entrance		Power Door Operator and Controls	Entrances	7	6	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	1,109	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	15	EA	\$3,218	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	15	EA	\$3,218	
Lintels		Lintels - Steel	Entire Building	6	930	LF	\$35,109	
Parapet		Coping - Metal	Roof	7	1,484	LF	\$0	
Parapet		Coping - Metal	Music classroom roof	7	23	LF	\$0	
Parapet		Coping - Stone	Chiller	7	73	LF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Parapet < 16" Height	High roof	7	194	LF	\$0	
Parapet		Parapet > 30" Height	Lower Roof	7	161	LF	\$0	
Parapet		Parapet 16" to 30" Height	Roof	7	1,202	LF	\$0	
Roof System		Exterior Downspouts	Music classroom roof	7	4	LF	\$0	
Roof System		Interior Downspouts	Roof	6	1,394	LF	\$0	
Roof System		Modified Bitumen Roof	Green roof	7	12,731	SF	\$0	
Roof System		PVC Membrane Roof	Roof	7	26,589	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roof	6	39,320	SF	\$311,501	
Superstructure		Steel	Entire Building	7	104,990	SF	\$0	
Walls		Brick	Entire Building	7	48,579	SF	\$0	
Walls		Brick	Chiller	6	24	SF	\$159	Cracking around mechanical screen attachment point
Walls		Prefabricated Metal Panel Wall	Chiller	7	1,168	SF	\$0	
Windows		Clerestory - Glass Double-Pane	High roof	7	123	SF	\$0	
Windows		Curtain wall - Glazed Double Pane	Entire Building	6	6,152	SF	\$58,063	
Windows		Window - Guards perforated	1st Floor	7	1,771	SF	\$0	
Windows		Window - Guards wire guard	Gym	7	270	SF	\$0	
Windows		Windows - Casement Aluminum Double-pane	Entire Building	7	6,960	SF	\$0	
EXTERIOR Sub Total							\$412,939	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	4	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Corridors and Stairs	7	19,796	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Gym / Multi Purpose Room	7	5,856	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Lunch Room	7	4,178	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Student Toilets	6	2,804	SF	\$1,203	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Main Entry	7	1	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	Gym / Multi Purpose Room	7	9	EA	\$0	
Emergency System		Emergency generator 100 to 150 KW natural gas - Indoor	Mechanical Room	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Corridors and Stairs	6	26	EA	\$6,060	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Gym / Multi Purpose Room	7	16	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Lunch Room	7	3	EA	\$0	
Emergency System		Public Announcement System	Main Office	7	104,990	SF	\$0	
Emergency System		Security System - CCTV	MDF Rm	5	104,990	SF	\$300,271	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Security System - Intrusion detection	Electrical Room	6	104,990	SF	\$97,588	
Main Service		Main Electrical service - Live Front - 2000 to 3000 A 277/480/3PH	Electrical Room	6	1	EA	\$30,388	
Power Distribution		Lighting and power panels	Entire Building	4	4	EA	\$21,736	Fuses
Power Distribution		Lighting and power panels	Entire Building	6	25	EA	\$17,875	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	8	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	5	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Electrical Room	7	2	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	7	EA	\$0	

ELECTRICAL Sub Total \$475,121

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	104,990	SF	\$0	
Fire Alarm		Fire Alarm System	Electrical Room	6	104,990	SF	\$127,615	Noted Detector in Elevator Pit with original construction cover.
Fire Alarm		Fire Pump Controller	Mechanical Room	7	1	EA	\$0	
Pump Room Assembly		Fire Pump 25-50hp	Mechanical Room	7	1	EA	\$0	
Pump Room Assembly		Jockey Pump	Mechanical Room	7	1	EA	\$0	
Sprinkler System		Combination Wet and Dry Sprinkler System	Entire Building	6	104,990	SF	\$75,068	Have had freeze up problems.
Sprinkler System		Sprinkler Heads	Entire Building	7	104,990	SF	\$0	

FIRE PROTECTION Sub Total \$202,683

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 100 to 200 tons	Roof	6	2	EA	\$55,770	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	6	1	EA	\$858	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 12,001 to 20,000 cfm	Mechanical Room	7	2	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 12,001 to 20,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 20,001 to 30,000 cfm	Mechanical Room	7	2	EA	\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Roof	7	4	EA	\$0	
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	Entire Building	6	75	EA	\$24,668	
Boiler Systems		Boiler Assembly - Condensing Hot Water Boiler 2,001MBH-3,000 MBH	Boiler Room	7	2	EA	\$0	
Boiler Systems		Boiler Auxiliary - Condensing Hot Water Boiler 2,001MBH-3,000 MBH	Boiler Room	7	2	EA	\$0	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	7	2	EA	\$0	
Boiler Systems		Glycol Feed System	Boiler Room	7	2	EA	\$0	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	6	9	EA	\$4,505	
Heating Devices		Radiators - Hot Water	Entire Building	7	78	EA	\$0	
Heating Devices		Unit Heater - Electric	Mechanical Room	7	1	EA	\$0	
Heating Devices		Unit Heater - Hot Water	Mechanical Room	7	8	EA	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	7	600	LF	\$0	
Mechanical Plumbing		Pumps - Chilled Water 10 to 20 HP	Boiler Room	7	2	EA	\$0	
Mechanical Plumbing		Pumps - Chilled Water less than 10 HP	Boiler Room	7	2	EA	\$0	
Mechanical Plumbing		Pumps - Hot Water 5 to 10 HP	Boiler Room	7	2	EA	\$0	
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	Mechanical Room	7	4	EA	\$0	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	7	104,990	SF	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	84	EA	\$12,012	
Ventilation		Exhaust Fan - Indoor	Entire Building	7	2	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	6	EA	\$2,574	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	6	3	EA	\$472	
Ventilation		Type II Exhaust Hood - Warming Kitchen	Kitchen	7	2	EA	\$0	
MECHANICAL Sub Total							\$100,858	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Electric less than 50 KW	Consession Closet	7	1	EA	\$0	
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Mechanical Room	7	2	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	104,990	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	104,990	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	104,990	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	104,990	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	104,990	SF	\$0	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	104,990	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	104,990	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	104,990	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	104,990	SF	\$0	
Piping		Storm Piping	Entire Building	7	104,990	SF	\$0	
Piping		Vent Piping	Entire Building	7	104,990	SF	\$0	
Pumps		Domestic Booster Pump duplex	Mechanical Room	7	1	EA	\$0	
Pumps		Sump Pump	Elevator Sump Pit	7	1	EA	\$0	
PLUMBING Sub Total							\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Third floor, library office	7	148	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor engineer's office to south of kitchen	7	120	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Second floor, teachers lounge	7	637	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor inside gym	7	147	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor main office suite	7	2,475	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor office suite at north	7	1,575	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	1st floor office suite at north	7	687	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	1st floor main office suite	7	1,238	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	1st floor engineer's office to south of kitchen	7	120	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Terrazzo	1st floor main office suite	7	619	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Second floor, teachers lounge	7	637	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor office suite at north	7	888	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Third floor, library office	6	148	SF	\$212	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor main office suite	7	619	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor inside gym	7	147	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st floor main office suite	7	36	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st floor inside gym	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Second floor, teachers lounge	7	9	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st floor engineer's office to south of kitchen	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Third floor, library office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st floor office suite at north	7	30	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor main office suite	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Second floor, teachers lounge	7	1,082	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st floor engineer's office to south of kitchen	7	408	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st floor inside gym	7	445	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st floor main office suite	7	1,863	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st floor office suite at north	7	1,587	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Third floor, library office	7	233	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor office suite at north	7	1,587	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor main office suite	7	1,863	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Third floor, library office	6	233	SF	\$550	
Doors		Interior Steel Doors incl hw	3rd Floor	7	35	EA	\$0	
Doors		Interior Steel Doors incl hw	2nd Floor	7	26	EA	\$0	
Doors		Interior Steel Doors incl hw	1st Floor	7	63	EA	\$0	
Doors		Interior Wood Doors incl hw	3rd Floor	7	16	EA	\$0	
Doors		Interior Wood Doors incl hw	1st Floor	7	32	EA	\$0	
Doors		Interior Wood Doors incl hw	2nd Floor	7	23	EA	\$0	
Doors		Side-lite	1st Floor	7	340	SF	\$0	
Doors		Side-lite	2nd Floor	7	204	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Side-lite	3rd Floor	7	132	SF	\$0	
Doors		Store Front Door	1st Floor	7	10	EA	\$0	
Doors		Transom Window	1st Floor	7	100	SF	\$0	
Drinking Fountains	Corridors	Triple Fountain	2nd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Triple Fountain	3rd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Triple Fountain	1st Floor	7	2	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Bleacher Seating	1st Floor	7	75	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Exposed	1st Floor	7	5,568	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Lay-In	1st Floor	7	288	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Tile/Sheet	1st Floor	7	1,445	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Wood	1st Floor	7	4,411	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Lay-In	1st Floor	7	4	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Metal Halide/Sodium Vapor	1st Floor	7	16	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Scoreboards	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	1st Floor	7	2	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Concrete Block	1st Floor	7	6,674	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Concrete Block	1st Floor	7	1,243	SF	\$0	
Kitchen	Warming Kitchen	Ceiling - Lay-In	1st Floor	7	1,242	SF	\$0	
Kitchen	Warming Kitchen	Flooring - Concrete	1st Floor	7	1,242	SF	\$0	
Kitchen	Warming Kitchen	Lighting - Lay-In	1st Floor	7	15	SF	\$0	
Kitchen	Warming Kitchen	Wall - Concrete Block	1st Floor	7	1,427	SF	\$0	
Library	Library	Flooring Carpet	3rd Floor	7	3,775	SF	\$0	
Library	Library	Lighting - Pendant/ Surface	3rd Floor	7	42	SF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor inside Nurse's office	7	1	EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	1st Floor	7	4,178	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	4,178	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	1st Floor	7	55	SF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	48	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	7	4,076	SF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	1st Floor	7	680	SF	\$0	
Lunchroom	Lunchroom	Wall - Structural Glazed Tile	1st Floor	7	680	SF	\$0	
MDF/IDF		Finishes	Second floor, southwest	7	306	SF	\$0	
MDF/IDF		Ventilation and Cooling	second floor, southwest	7	1	EA	\$0	
Mechanical/Service Rooms		Boiler Room	Second floor, southeast	6	2,798	SF	\$13,204	
Mechanical/Service Rooms		Janitor's Closet	1st Floor	7	3	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	3rd Floor	6	2	SF	\$9	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Janitor's Closet	2nd Floor	6	2	SF	\$9	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor middle of corridor	7	850	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor south of kitchen	7	463	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Third floor, fan room	6	3,025	SF	\$14,275	
Mechanical/Service Rooms		Mechanical/Service Rooms	Third floor, east end, electrical closet	7	18	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Second floor, south end of building, ATS room	6	86	SF	\$406	
Mechanical/Service Rooms		Mechanical/Service Rooms	Third floor, west end, electrical closet	7	15	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Second floor, southwest, emergent generator room	7	594	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Second floor, west end, electrical closet 215A	7	58	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Second floor, west end, electrical room	7	14	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor elevator machine room	7	56	SF	\$0	
Mechanical/Service Rooms		Storage Room	3rd floor inside Music room #330	7	270	SF	\$0	
Mechanical/Service Rooms		Storage Room	Third floor, east en, room 326	7	212	SF	\$0	
Mechanical/Service Rooms		Storage Room	Third floor, room 305	6	167	SF	\$788	
Mechanical/Service Rooms		Storage Room	Second floor, room 203	7	197	SF	\$0	
Mechanical/Service Rooms		Storage Room	Second floor, room 205	7	234	SF	\$0	
Mechanical/Service Rooms		Storage Room	Second floor, book storage, room 215B	7	150	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st floor inside gym	7	259	SF	\$0	
Mechanical/Service Rooms		Storage Room	Second floor, room 200, art room storage	7	200	SF	\$0	
Mechanical/Service Rooms		Storage Room	Second floor, room 201, storage	7	154	SF	\$0	
Mechanical/Service Rooms		Storage Room	Library, storage room	6	326	SF	\$1,538	
Staff Restroom	Staff Restroom	Accessories	Third floor, East end, Men staff	7	67	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor west end boy's	7	249	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor women's at west end of main corridor	7	74	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor east end girl's	7	253	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor east end boy's	7	253	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor west end girl's	7	249	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor south of kitchen, women's	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor south of kitchen, men's	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Third floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor south of kitchen opening to exterior, man's	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Second floor, west end, boys	7	230	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor south of kitchen opening to exterior, women's	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Second floor, west end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor inside Nurse's office	7	89	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	124B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	123B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	122B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	121B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	120B	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Second floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor east end of main corridor, men's	7	67	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Third floor, west end, boys	7	230	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor inside main office suite	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Second floor, East end, Men staff	7	67	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Second floor, east end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Second floor, east end, boys	7	230	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	Third floor, east end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Third floor, west end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Third floor, east end, boys	7	230	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	119B	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Second floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor south of kitchen, women's	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor inside main office suite	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor south of kitchen opening to exterior, man's	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor south of kitchen, men's	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor east end of main corridor, men's	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor women's at west end of main corridor	7	74	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Second floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Third floor, East end, Men staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Second floor, East end, Men staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Second floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	119B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	120B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	121B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	122B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	123B	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Third floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st floor south of kitchen opening to exterior, women's	7	64	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	124B	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor inside Nurse's office	7	89	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor west end girl's	7	249	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor east end boy's	7	253	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Third floor, west end, boys	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Third floor, west end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Third floor, east end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Second floor, east end, boys	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Second floor, east end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Second floor, west end, boys	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor west end boy's	7	249	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor east end girl's	7	253	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Second floor, west end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Third floor, east end, boys	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Third floor, west end, boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Third floor, east end, boys	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Third floor, west end, Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Second floor, east end, boys	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	Second floor, East end, Men staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Second floor, west end, women staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Third floor, west end, women staff	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Second floor, west end, Girls	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Third floor, east end, Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Second floor, west end, boys	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	119B	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	120B	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	121B	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	123B	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	124B	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor inside Nurse's office	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor west end girl's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor south of kitchen, men's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Third floor, East end, Men staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor inside main office suite	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor south of kitchen opening to exterior, man's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor south of kitchen opening to exterior, women's	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Second floor, east end, Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor east end girl's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor east end of main corridor, men's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor south of kitchen, women's	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	122B	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor west end boy's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor women's at west end of main corridor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Second floor, west end, women staff	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor east end boy's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	1st floor south of kitchen opening to exterior, man's	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	1st floor south of kitchen, men's	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	1st floor south of kitchen opening to exterior, women's	7	64	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	1st floor south of kitchen, women's	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor east end girl's	7	253	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor inside main office suite	7	67	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor east end boy's	7	253	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor west end girl's	7	249	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Third floor, east end, boys	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, west end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor west end boy's	7	249	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor east end of main corridor, men's	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor women's at west end of main corridor	7	74	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Third floor, East end, Men staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Third floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Third floor, west end, boys	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Third floor, west end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Third floor, east end, Girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, east end, boys	7	230	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, east end, Girls	7	220	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	121B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	124B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	123B	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, west end, boys	7	230	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, west end, women staff	7	67	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Second floor, East end, Men staff	7	67	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	120B	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor inside Nurse's office	7	89	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	119B	7	64	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	122B	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor east end girl's	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor west end boy's	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor east end boy's	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Third floor, west end, boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Third floor, east end, boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Third floor, west end, Girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Third floor, east end, Girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Second floor, east end, boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Second floor, east end, Girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Second floor, west end, Girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Second floor, west end, boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor inside Nurse's office	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor west end girl's	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Third floor, East end, Men staff	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	120B	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	119B	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Second floor, west end, Girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Second floor, west end, boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Second floor, west end, women staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Second floor, East end, Men staff	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Second floor, east end, Girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Second floor, east end, boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Third floor, east end, Girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Third floor, west end, Girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Third floor, east end, boys	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	122B	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Third floor, west end, women staff	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	123B	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Second floor, west end, women staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor women's at west end of main corridor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor east end of main corridor, men's	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor east end girl's	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor east end boy's	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor west end girl's	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor west end boy's	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor south of kitchen, women's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor south of kitchen, men's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor south of kitchen opening to exterior, women's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor south of kitchen opening to exterior, man's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor inside main office suite	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Third floor, west end, boys	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	124B	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor inside Nurse's office	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	121B	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Third floor, east end, boys	7	7	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Second floor, west end, Girls	7	7	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Second floor, west end, women staff	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Second floor, East end, Men staff	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Second floor, east end, Girls	7	7	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Second floor, east end, boys	7	7	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Third floor, west end, Girls	7	7	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor east end of main corridor, men's	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Third floor, west end, boys	7	7	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Third floor, west end, women staff	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Third floor, East end, Men staff	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	120B	7	1	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Third floor, east end, Girls	7	7	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor women's at west end of main corridor	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	Second floor, west end, women staff	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor east end girl's	7	8	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor east end boy's	7	8	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor west end girl's	7	8	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor west end boy's	7	8	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor south of kitchen, women's	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor south of kitchen, men's	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor south of kitchen opening to exterior, women's	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	121B	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor south of kitchen opening to exterior, man's	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	122B	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor inside main office suite	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	Second floor, west end, boys	7	7	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	124B	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor inside Nurse's office	7	2	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	119B	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	123B	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Third floor, west end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Second floor, west end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Second floor, west end, Girls	7	4	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	Second floor, east end, Girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Second floor, east end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Third floor, east end, Girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor inside Nurse's office	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Third floor, east end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor east end girl's	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor east end boy's	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor west end boy's	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Third floor, west end, Girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor west end girl's	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor east end boy's	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor west end boy's	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Third floor, west end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Third floor, east end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Second floor, east end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Second floor, west end, boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor women's at west end of main corridor	7	280	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Third floor, east end, boys	7	574	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Second floor, west end, Girls	7	574	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Third floor, east end, Girls	7	574	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Third floor, west end, Girls	7	574	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor inside main office suite	7	262	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor south of kitchen opening to exterior, man's	7	287	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor south of kitchen opening to exterior, women's	7	287	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor south of kitchen, men's	7	287	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Second floor, east end, boys	7	574	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor east end of main corridor, men's	7	262	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Second floor, east end, Girls	7	574	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Second floor, west end, women staff	7	299	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Third floor, East end, Men staff	6	270	SF	\$772	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Third floor, west end, women staff	6	270	SF	\$772	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Third floor, west end, boys	7	574	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Second floor, west end, boys	7	574	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st floor inside Nurse's office	7	260	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Second floor, East end, Men staff	6	270	SF	\$772	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Second floor, west end, women staff	6	270	SF	\$772	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor south of kitchen, women's	7	287	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor east end boy's	7	587	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor west end girl's	7	580	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor east end girl's	7	587	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor west end boy's	7	580	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor inside Nurse's office	7	87	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	Third floor, west end, women staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Third floor, East end, Men staff	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	Second floor, west end, women staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor women's at west end of main corridor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor east end of main corridor, men's	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor east end girl's	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor west end girl's	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Third floor, west end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor west end boy's	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor south of kitchen, women's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor south of kitchen, men's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor south of kitchen opening to exterior, man's	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor south of kitchen opening to exterior, women's	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor east end boy's	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, west end, Girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor inside main office suite	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	120B	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	124B	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	123B	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor inside Nurse's office	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	121B	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, west end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Third floor, east end, boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Second floor, west end, women staff	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	Second floor, East end, Men staff	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, east end, Girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Second floor, east end, boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Third floor, east end, Girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Third floor, west end, Girls	7	4	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	119B	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	122B	7	1	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vertical Conveyance		Stage Lift	1st floor inside gym/auditorium	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	3	EA	\$1,158	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total \$36,611

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	33	LF	\$0	
Casework	Classroom	Casework		7	37	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		6	29	LF	\$1,037	
Casework	Classroom	Casework		7	37	LF	\$0	
Casework	Classroom	Casework		7	47	LF	\$0	
Casework	Classroom	Casework		6	51	LF	\$1,823	
Casework	Classroom	Casework		6	29	LF	\$1,037	
Casework	Classroom	Casework		6	29	LF	\$1,037	
Casework	Classroom	Casework		6	29	LF	\$1,037	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		6	29	LF	\$1,037	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	14	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		6	29	LF	\$1,037	
Casework	Classroom	Casework		7	50	LF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	738	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	791	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,185	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,291	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	771	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,291	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,200	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,200	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,200	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,200	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,200	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	872	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	738	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	838	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,200	SF	\$0	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
CLASSROOM	Classroom	Science Lab Elements		7	1,291	SF	\$0	
Corridors	Corridors	Concrete Block	3rd Floor	7	8,192	SF	\$0	
Corridors	Corridors	Concrete Block	2nd Floor	7	8,722	SF	\$0	
Corridors	Corridors	Concrete Block	Entire building stair wells	7	10,320	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor	7	14,297	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	Entire building stair wells	7	280	SF	\$0	
Corridors	Corridors	Drop/Lay-In	3rd Floor	7	5,426	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	4,338	SF	\$0	
Corridors	Corridors	Drop/Lay-In	Entire building stair wells	7	1,641	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	6,870	SF	\$0	
Corridors	Corridors	Exposed	2nd Floor	7	681	SF	\$0	
Corridors	Corridors	Exposed	3rd Floor	7	610	SF	\$0	
Corridors	Corridors	Lay-In	Entire building stair wells	7	1,871	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	6,870	EA	\$0	
Corridors	Corridors	Lay-In	3rd Floor	7	5,426	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	3,931	EA	\$0	
Corridors	Corridors	Pendant/Surface	3rd Floor	7	610	EA	\$0	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	1,088	EA	\$0	
Corridors	Corridors	Stair Handrails	Entire building stair wells	7	384	LF	\$0	
Corridors	Corridors	Student Lockers	3rd Floor	7	256	EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	7	176	EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	7	271	EA	\$0	
Corridors	Corridors	Terrazzo	Entire building stair wells	7	1,150	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	6,155	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	4,388	SF	\$0	
Corridors	Corridors	Terrazzo	3rd Floor	7	5,426	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	7	610	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	715	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	25	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	10	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Metal/Folding Panel		7	259	SF	\$0	
Wall	Classroom	Metal/Folding Panel		7	259	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	845	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	845	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	845	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	845	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	845	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	379	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	379	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	260	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	845	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	495	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	580	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	563	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	563	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	563	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	495	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	753	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	845	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	845	SF	\$0	
ROOM Sub Total							\$22,268	
Building Main Sub Total							\$1,250,481	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	6	6	EA	\$3,260	
Civil/Drainage		Site Drain	Main Entrance	6	2	EA	\$223	
Civil/Drainage		Site Manhole	Entire Site	7	5	EA	\$0	
Fencing		Chain Link	Southeast corner	7	21	LF	\$0	
Fencing		Ornamental Iron	Entire Site	7	858	LF	\$0	
Landscape		Benches	Playground	6	3	EA	\$708	
Landscape		Grass	Entire Site	6	4,768	SF	\$1,909	
Landscape		Hardscape - Concrete	Entire Site	7	11,582	SF	\$0	
Landscape		Parkway trees	Entire Site	6	11	EA	\$3,146	
Landscape		Planting Beds/ Areas	Entire Site	6	5,312	SF	\$0	
Parking Lot		Asphalt	Parking Lot	7	8,282	SF	\$0	
Parking Lot		Concrete	Main Entrance	6	5,509	SF	\$0	
Parking Lot		Concrete Curbs	Parking Lot	7	863	LF	\$0	
Parking Lot		Lights, Pole Mounted	Parking Lot	6	6	EA	\$6,864	
Parking Lot		Trash Compactor	West end of parks building	7	1	EA	\$0	
Parking Lot		Trash Enclosure	Site 2 South	7	400	SF	\$0	
Playground		Playground Equipment - Combo 3-12	Playground	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Playground	7	3,630	SF	\$0	
Sidewalks		Internal Walks	Entire Site	6	523	LF	\$4,936	
Sidewalks		Perimeter Sidewalks	Entire Site	7	4,909	SF	\$0	
Signage		Flag Pole	Entire Building	7	1	EA	\$0	

SITE Sub Total \$21,047

SITE Sub Total \$21,047

Total Campus Need ^{2 3} \$1,271,527

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
119	1200	1	10	38	40	163	42	0	N	N	N	Classroom		
120	1200	1	10	38	40	163	42	0	N	N	N	Classroom		
121	1200	1	10	38	40	163	42	0	N	N	N	Classroom		
122	1200	1	10	38	40	163	42	0	N	N	N	Classroom		
123	1200	1	10	38	40	163	42	0	N	N	N	Classroom		
124	1200	1	10	38	40	163	42	0	N	N	N	Classroom		
126	872	1	8	34	40	122	32	0	N	N	N	Classroom		
200	1291	1	6	22	40	59	0		N	N	N	Classroom		
201	1291	1	13	40	40	106	0		N	N	N	Classroom		
214	771	1	5	18	40	117	29		N	N	N	Classroom		
216	791	1	5	18	40	117	29		N	N	N	Classroom		
217	838	1	8	30	40	117	29		N	N	N	Classroom		
218	838	1	8	30	40	117	29		N	N	N	Classroom		
219	838	1	8	30	40	117	29		N	N	N	Classroom		
220	838	1	8	30	40	117	29		N	N	N	Classroom		
221	838	1	8	30	40	117	29		N	N	N	Classroom		
222	838	1	8	30	40	117	29		N	N	N	Classroom		
223	838	1	8	30	40	117	29		N	N	N	Classroom		
224	838	1	8	30	40	117	29		N	N	N	Classroom		
225	838	1	8	30	40	117	29		N	N	N	Classroom		
226	838	1	8	30	40	117	29		N	N	N	Classroom		
228	838	1	8	30	40	117	29		N	N	N	Classroom		
228	838	1	8	30	40	117	29		N	N	N	Classroom		
303	1185	1	10	20	40	160	40		N	N	N	Classroom		
314	880	1	10	20	40	120	30		N	N	N	Classroom		
316	880	1	10	20	40	120	30		N	N	N	Classroom		
317	880	1	10	20	40	80			N	N	N	Classroom		
318	880	1	10	20	40	120	30		N	N	N	Classroom		
319	880	1	10	20	40	120	30		N	N	N	Classroom		
320	880	1	10	20	40	120	30		N	N	N	Classroom		
321	880	1	10	20	40	120	30		N	N	N	Classroom		
322	880	1	10	20	40	120	30		N	N	N	Classroom		
323	880	1	10	20	40	120	30		N	N	N	Classroom		
324	880	1	10	20	40	120	30		N	N	N	Classroom		
325	880	1	10	20	40	120	30		N	N	N	Classroom		
327	880	1	10	20	40	120	30		N	N	N	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
330	1475		10	20	40	200	50		N	N	N	Classroom		
Other	64								N	N	N	Restroom	Staff Restroom	1st floor south of kitchen opening to exterior, women's
Other	67								N	N	N	Restroom	Staff Restroom	Second floor, west end, women staff
Other	74								N	N	N	Restroom	Staff Restroom	1st floor women's at west end of main corridor
Other	67								N	N	N	Restroom	Staff Restroom	1st floor east end of main corridor, men's
Other	253								N	N	N	Restroom	Children's Standard Student Restroom	1st floor east end girl's
Other	253								N	N	N	Restroom	Children's Standard Student Restroom	1st floor east end boy's
Other	249								N	N	N	Restroom	Children's Standard Student Restroom	1st floor west end girl's
Other	64								N	N	N	Restroom	Early Childhood Student Restroom	119B
Other	996								N	N	N	Corridors		Entire building stair wells
Other	67								N	N	N	Restroom	Staff Restroom	1st floor inside main office suite
Other	64								N	N	N	Restroom	Staff Restroom	1st floor south of kitchen, men's
Other	67								N	N	N	Restroom	Staff Restroom	Third floor, East end, Men staff
Other	64								N	N	N	Restroom	Early Childhood Student Restroom	120B
Other	64								N	N	N	Restroom	Early Childhood Student Restroom	121B
Other	64								N	N	N	Restroom	Early Childhood Student Restroom	122B
Other	6870								N	N	N	Corridors		1st Floor
Other	89								N	N	N	Restroom	Children's Standard Student Restroom	1st floor inside Nurse's office
Other	1575			48					N	N	Y	Administrative Suites/Offices		1st floor office suite at north
Other	64								N	N	N	Restroom	Early Childhood Student Restroom	123B
Other	64								N	N	N	Restroom	Early Childhood Student Restroom	124B
Other	2475			36					N	N	Y	Administrative Suites/Offices		1st floor main office suite
Other	249								N	N	N	Restroom	Children's Standard Student Restroom	1st floor west end boy's
Other	120			6					N	N	N	Administrative Suites/Offices		1st floor engineer's office to south of kitchen
Other	64								N	N	N	Restroom	Staff Restroom	1st floor south of kitchen, women's
Other	67								N	N	N	Restroom	Staff Restroom	Second floor, west end, women staff
Other	1242								N	N	N	Kitchen	Warming Kitchen	1st Floor
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	Second floor, west end, Girls
Other	4178								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	Second floor, west end, boys
Other	5856								N	N	N	Gymnasia	Gymnasium.Auditorium	1st Floor
Other	67								N	N	N	Restroom	Staff Restroom	Second floor, East end, Men staff
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	Second floor, east end, Girls
Other	3775								N	N	N	Library		3rd Floor

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	Second floor, east end, boys
Other	6036								N	N	N	Corridors		3rd Floor
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	Third floor, east end, Girls
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	Third floor, west end, Girls
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	Third floor, east end, boys
Other	5019								N	N	N	Corridors		2nd Floor
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	Third floor, west end, boys
Other	67								N	N	N	Restroom	Staff Restroom	Third floor, west end, women staff
Other	637			24					N	N	N	Administrative Suites/Offices		Second floor, teachers lounge
Other	147			6					N	N	N	Administrative Suites/Offices		1st floor inside gym
Other	148			8					N	N	N	Administrative Suites/Offices		Third floor, library office
Other	64								N	N	N	Restroom	Staff Restroom	1st floor south of kitchen opening to exterior, man's