

**Facility Assessment Report**

This report contains the detailed findings of the facility condition assessment completed on the date noted in the document footer. Assessors rate each facility item by visual observation only; they do not test the operation of equipment or perform destructive testing of walls, ceilings, or floors. Each facility item is ranked on a 7-point scale: a rank 7 means the item is new or in like-new condition and no work is required while rank 1 means the item has failed and has led to an immediate life safety condition<sup>1</sup>. The remaining ranks generally mean that the item requires regular maintenance (rank 5 or 6) or full replacement (rank 2, 3 or 4). To enhance reporting and capital planning analysis, each assessed item must also be assigned a recommended replacement range (used to specify the time span, in years, before replacement is recommended). Definitions for Quantity and Unit of Measure (UOM) can be found at the end of this report.

For additional detail and definition on rank values as they relate to each assessed item or the recommended replacement range, please visit the "CPS Guide to Biennial Facility Assessments" found on the Facilities Standards webpage under CPS Policies and Guidelines at <http://www.cps.edu/facilityassessment>.

Campus Summary			
BuildingName	Year Constructed	Number of Floors	Building Area (Sq Ft)
Main	1969	3	75,510
<b>Campus Total</b>			<b>75,510</b>

**Category : Exterior**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
Entrance							
	Exterior Doors - Exterior FRP Door	#1 - SW	3	EA	7	10+ years	
	Exterior Stairs - Concrete	#1 - SW	48	LF	7	10+ years	
	Stair Handrail - Steel_Stair Handrail	#1 - SW	2	LF	6	10+ years	
	Exterior Doors - Exterior Steel Door	#10 Exit - NW	1	EA	6	10+ years	
	Exterior Stairs - Concrete	#10 Exit - NW	7	LF	7	10+ years	
	Stair Handrail - Steel_Stair Handrail	#10 Exit - NW	4	LF	6	10+ years	
	Exterior Doors - Exterior Steel Door	#11 Exit - SW	1	EA	7	10+ years	
	Exterior Stairs - Concrete	#11 Exit - SW	14	LF	7	10+ years	
	Stair Handrail - Steel_Stair Handrail	#11 Exit - SW	8	LF	7	10+ years	
	Entrance Control - Audio and Video	#2 - S	1	EA	7	6-10 years	
	Exterior Doors - Exterior FRP Door	#2 - S	3	EA	6	10+ years	
	Exterior Stairs - Concrete	#2 - S	32	LF	7	10+ years	
	Power Door Operator and Controls	#2 - S	1	EA	7	6-10 years	
	Ramp Handrail - Steel_Ramp Handrail	#2 - S	80	LF	6	10+ years	
	Ramps - Concrete	#2 - S	40	LF	6	10+ years	minor cracking
	Stair Handrail - Steel_Stair Handrail	#2 - S	14	LF	6	10+ years	
	Entrance Control - Audio	#3 - SE	1	EA	7	10+ years	
	Exterior Doors - Exterior FRP Door	#3 - SE	3	EA	7	10+ years	
	Exterior Stairs - Concrete	#3 - SE	12	LF	7	10+ years	
	Exterior Doors - Exterior Steel Door	#4 Exit - SE	1	EA	6	10+ years	
	Exterior Stairs - Concrete	#4 Exit - SE	4	LF	7	10+ years	
	Exterior Doors - Exterior Steel Door	#5 SE	1	EA	6	10+ years	
	Exterior Stairs - Concrete	#5 SE	25	LF	5	1-2 years	Cracked Surface
	Stair Handrail - Steel_Stair Handrail	#5 SE	12	LF	6	10+ years	

**Category : Exterior**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Exterior Doors - Exterior Steel Door	#6 NE	1	EA	7	10+ years	
	Ramp Handrail - Steel_Ramp Handrail	#6 NE	8	LF	6	10+ years	
	Ramps - Concrete	#6 NE	16	LF	6	10+ years	
	Exterior Doors - Exterior Steel Door	#6.5 NE Exit	1	EA	6	10+ years	
	Ramp Handrail - Steel_Ramp Handrail	#6.5 NE Exit	20	LF	6	10+ years	
	Ramps - Concrete	#6.5 NE Exit	8	LF	6	10+ years	
	Exterior Doors - Exterior Steel Door	#7 Exit - NE	1	EA	7	10+ years	
	Exterior Stairs - Concrete	#7 Exit - NE	16	LF	5	1-2 years	cracking
	Stair Handrail - Steel_Stair Handrail	#7 Exit - NE	18	LF	6	10+ years	
	Entrance Control - Audio and Video	#8 - N	1	EA	7	10+ years	
	Exterior Doors - Exterior FRP Door	#8 - N	2	EA	7	10+ years	
	Ramp Handrail - Steel_Ramp Handrail	#8 - N	36	LF	6	10+ years	
	Ramps - Concrete	#8 - N	18	LF	7	10+ years	
	Exterior Doors - Exterior FRP Door	#9 - N	2	EA	6	10+ years	
	Exterior Stairs - Concrete	#9 - N	12	LF	7	10+ years	
<b>Foundation</b>							
	Foundation - Concrete	Entire Building	1,141	LF	7	10+ years	
	Superstructure - Metal Deck/ Concrete Topping	Entire Building	75,510	SF	7	10+ years	
<b>Lighting</b>							
	Exterior Lighting - Parapet or Roof Mounted	Entire Building	15	EA	7	6-10 years	
	Exterior Lighting - Wall Mounted	Entire Building	26	EA	7	6-10 years	
<b>Roof System</b>							
	Coping - Metal	East Lower Roof	143	LF	6	10+ years	
	Downspouts - Interior Downspouts	East Lower Roof	24	LF	6	10+ years	
	Roof - Asphalt Gravel Ballast	East Lower Roof	2,312	SF	5	6-10 years	
	Roof Structure - Steel / Metal Deck/ Concrete Topping	East Lower Roof	2,312	SF	7	10+ years	
	Coping - Metal	East Lowest Roof	305	LF	6	10+ years	
	Downspouts - Interior Downspouts	East Lowest Roof	28	LF	6	10+ years	
	Roof - Asphalt Gravel Ballast	East Lowest Roof	5,175	SF	5	6-10 years	
	Roof Structure - Steel / Metal Deck/ Concrete Topping	East Lowest Roof	5,175	SF	7	10+ years	
	Access Ladder - Metal	Main Roof	3	EA	7	10+ years	
	Chimney - Brick Chimney- Concrete/ Mortar Liner	Main Roof	14	LF	7	10+ years	
	Chimney - Brick Chimney- Concrete/ Mortar Liner	Main Roof	33	LF	7	10+ years	
	Coping - Metal	Main Roof	839	LF	6	10+ years	
	Downspouts - Interior Downspouts	Main Roof	216	LF	6	10+ years	

**Category : Exterior**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Roof - Asphalt Gravel Ballast	Main Roof	19,174	SF	5	6-10 years	
	Roof Hatch - Metal	Main Roof	3	EA	7	10+ years	
	Roof Structure - Steel / Metal Deck/ Concrete Topping	Main Roof	19,174	SF	7	10+ years	
	Coping - Metal	West Low Roof	274	LF	6	10+ years	
	Downspouts - Interior Downspouts	West Low Roof	28	LF	6	10+ years	
	Roof - Asphalt Gravel Ballast	West Low Roof	5,862	SF	5	6-10 years	
	Roof Structure - Steel / Metal Deck/ Concrete Topping	West Low Roof	5,862	SF	7	10+ years	

**Walls**

	Canopy - Metal	Entire Building	355	SF	5	2-5 years	
	Cheek-Wall - Concrete	Entire Building	82	SF	7	10+ years	
	Exterior Walls - Brick	Entire Building	24,450	SF	6	10+ years	
	Exterior Walls - Brick	Entire Building	25	SF	4	1-2 years	cracked brick and pieces of brick missing on corner of the building near door 10
	Exterior Walls - Concrete Block	Entire Building	140	SF	7	10+ years	
	Exterior Walls - Stone-Cut	Entire Building	886	SF	7	10+ years	

**Windows**

	Curtain wall - Glazed Double Pane	Entire Building	7,490	SF	7	10+ years	
	Curtain wall - Insulated Panel	Entire Building	2,420	SF	7	10+ years	
	Curtain wall - Louver	Entire Building	369	SF	7	10+ years	
	Guard - Guards perforated	Entire Building	3,160	SF	7	10+ years	
	Lintels - Steel	Entire Building	785	LF	7	10+ years	
	Windows - Sash Aluminum Double-pane	Entire Building	445	SF	7	10+ years	

**Category : Electrical**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<b>Emergency System</b>							
	Automatic Transfer Switch	Electrical Room	1	EA	7	10+ years	
	Security System - CCTV	Entire Building	75,510	SF	6	6-10 years	
	Security System - Intrusion Detection	Entire Building	75,510	SF	6	6-10 years	
	Exit Signs - Corridors and Stairs	Entire Building	11	EA	6	10+ years	
	Exit Signs - Corridors and Stairs	Entire Building	5	EA	4	2-5 years	Some exit signs will need to be replaced based poor performance
	Exit Signs - Gym	Entire Building	6	EA	6	10+ years	
	Exit Signs - Lunchroom	Entire Building	3	EA	6	10+ years	
	Emergency Battery Packs - Corridors and Stairs	Entire Building	32	EA	6	6-10 years	
	Emergency Battery Packs - Gym	Entire Building	6	EA	6	6-10 years	

**Category : Electrical**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Emergency Battery Packs - Lunchrooms	Entire Building	8	EA	6	6-10 years	
	Emergency Battery Packs - Students Toilets	Entire Building	8	EA	6	6-10 years	
	Emergency A/C Power - Corridors and Stairs	Entire Building	6,214	SF	6	6-10 years	
	Emergency A/C Power - Gym	Entire Building	4,285	SF	6	6-10 years	
	Emergency A/C Power - Lunchrooms	Entire Building	2,987	SF	6	6-10 years	
	Emergency A/C Power - Students Toilets	Entire Building	1,722	SF	6	6-10 years	

Main Service

	Main Electrical Service - 1600 A 120/208/3PH	Electrical Room	1	EA	6	10+ years	
	Independent Electrical Service for emergency power	Electrical Room	1	EA	6	10+ years	
	PA System	Entire Building	75,510	SF	6	6-10 years	

Power Distribution

	Lighting and Power Panels - Above 100 A	Entire Building	7	EA	6	10+ years	
	Lighting and Power Panels - Above 100 A	Entire Building	1	EA	6	10+ years	
	Lighting and Power Panels - Above 100 A	Entire Building	4	EA	6	10+ years	
	Lighting and Power Panels - Above 100 A	Entire Building	1	EA	6	10+ years	
	Lighting and Power Panels - Above 100 A	Entire Building	5	EA	6	10+ years	
	Lighting and Power Panels - Above 100 A	Entire Building	3	EA	6	10+ years	
	Main Distribution Panels - 400 - 600 amp	Entire Building	1	EA	6	10+ years	
	Main Distribution Panels - Greater than 600 amp	Entire Building	1	EA	6	10+ years	
	Main Distribution Panels - Less than 400 amp	Entire Building	1	EA	6	10+ years	
	Main Distribution Panels - Less than 400 amp	Entire Building	1	EA	6	10+ years	

**Category : Fire Protection**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<u>Fire Alarm</u>							
	Fire Alarm Panel	Boiler Room	1	EA	7	10+ years	
	Fire Alarm Strobe Lights	Boiler Room	75,510	SF	7	10+ years	
	Fire Alarm_System	Boiler Room	75,510	SF	6	10+ years	

**Category : Mechanical**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<u>Air Conditioning</u>							
	Condensing Unit- Ground Mounted - Less	Basement	1	EA	6	6-10 years	

**Category : Mechanical**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	than 5 tons						
<u>Air Handling Systems</u>							
	Indoor Return Fans- Centrifugal Squirrel Cage - 10001 - 20000 CFM	Basement	1	EA	6	10+ years	
	Air Handling Unit- Package Single Zone- Indoor- Steam Coils - 12001-20000 cfm	Basement	1	EA	5	6-10 years	
	Air Intake	Basement	1	EA	4	1-2 years	Air intake is damaged and needs to be repaired. Only usable manually.
	Zone Dampers	Basement	1	EA	6	10+ years	
	Indoor Return Fans- Centrifugal Squirrel Cage - Less than 5000 CFM	Basement	1	EA	6	10+ years	
	Air Handling Unit- Package Single Zone- Indoor- Steam Coils - 4000-8000 cfm	Boiler Room	1	EA	5	6-10 years	
	Air Intake	Boiler Room	1	EA	5	10+ years	
	Zone Dampers	Boiler Room	1	EA	6	10+ years	
	Outdoor Return Fans- Air Handling Unit Type - Less than 5000 CFM	Boiler Room	1	EA	6	10+ years	
<u>Boiler Systems</u>							
	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler - 76 - 100 HP	Boiler Room	2	EA	6	6-10 years	
	Chemical Feed System	Boiler Room	1	EA	6	6-10 years	
	Chemical Feeder	Boiler Room	1	EA	6	6-10 years	
	Combustion Dampers	Boiler Room	2	EA	6	10+ years	
	Condensate Pump	Boiler Room	2	EA	6	2-5 years	
	Feed Water Pumps and Tank	Boiler Room	1	EA	6	6-10 years	
	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler - 76 - 100 HP	Boiler Room	2	EA	6	10+ years	
	Piping - Condensate Pipe- Steel	Boiler Room	400	LF	7	10+ years	
	Piping - Steam Pipe- Steel	Boiler Room	400	LF	7	10+ years	
	Steam Traps	Boiler Room	103	EA	5	6-10 years	
	Vacuum Pump	Boiler Room	1	EA	6	6-10 years	
<u>Heating Devices</u>							
	Radiators - Steam	Boiler Room	3	EA	5	6-10 years	
	Unit Heater - Gas	Boiler Room	1	EA	5	2-5 years	
	Cabinet Heaters - With Steam Coil	Entire Building	33	EA	6	10+ years	
<u>Temperature Control</u>							
	DDC System	Engineers Office	75,510	SF	5	1-2 years	most of adjustments are done manually
	Thermostats - DDC	Engineers Office	1	EA	6	6-10 years	

**Category : Mechanical**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<u>Unit Ventilation</u>							
	Unit Ventilators- Floor Mounted- Steam Heating Coils Only	Entire Building	44	EA	5	6-10 years	
	Unit Ventilators- Floor Mounted- Steam Heating Coils Only	Entire Building	15	EA	5	6-10 years	
<u>Ventilation</u>							
	Exhaust Fans- Indoor - Less than 500 CFM	1st floor, roof and Kitchen	1	EA	6	6-10 years	
	Exhaust Fans- Roof Mounted - 1501 - 8000 CFM	1st floor, roof and Kitchen	6	EA	6	6-10 years	
	Exhaust Fans- Roof Mounted - Less than 500 CFM	1st floor, roof and Kitchen	6	EA	6	6-10 years	
	Type I Exhaust Hood- Kitchen	1st floor, roof and Kitchen	1	EA	6	6-10 years	

**Category : Plumbing**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<u>Hot Water</u>							
	Gas Heater - 300001 - 600000 BTU/HR	Boiler Room	2	EA	4	1-2 years	Water heater is older than 25 years and will need to be replaced
<u>Piping</u>							
	Domestic Piping-Cold Water Horizontal Lines	Entire Building	75,510	SF	6	6-10 years	
	Domestic Piping-Cold Water Risers	Entire Building	75,510	SF	6	6-10 years	
	Domestic Piping-Cold Water from Risers to Fixtures	Entire Building	75,510	SF	4	2-5 years	pipes are corroded, valves appear as not functional
	Domestic Piping-Hot Water Horizontal Lines	Entire Building	75,510	SF	6	6-10 years	
	Domestic Piping-Hot Water Return Lines	Entire Building	75,510	SF	6	6-10 years	
	Domestic Piping-Hot Water Return Risers	Entire Building	75,510	SF	6	6-10 years	
	Domestic Piping-Hot Water from Risers to Fixtures	Entire Building	75,510	SF	6	6-10 years	
	Sanitary Piping	Entire Building	75,510	SF	6	6-10 years	
	Storm Piping	Entire Building	75,510	SF	6	6-10 years	
	Vent Piping	Entire Building	75,510	SF	6	6-10 years	
<u>Pumps</u>							
	Pumps - Domestic Booster Pump-Simplex	Basement, Boiler Room	1	EA	6	6-10 years	
	Pumps - Sump-Simplex	Basement, Boiler Room	1	EA	6	6-10 years	
	Pumps - Sump-Simplex	Basement, Boiler Room	1	EA	6	6-10 years	
	Pumps - Sump-Simplex	Basement, Boiler Room	1	EA	6	6-10 years	

**Category : Room**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<u>Administrative Suites/Offices</u>							
	AC Unit	1st Floor Principal's Office	1	EA	5	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor Principal's Office	171	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor Principal's Office	1	EA	6	10+ years	
	Floor - Tile	1st Floor Principal's Office	171	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor Principal's Office	4	EA	6	6-10 years	
	Power Distribution	1st Floor Principal's Office	8	EA	6	6-10 years	
	Walls - Concrete Block	1st Floor Principal's Office	213	SF	6	10+ years	
	Ceiling - Plaster/Drywall	1st Floor Conference Room 107A	149	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor Conference Room 107A	1	EA	6	10+ years	
	Floor - Tile	1st Floor Conference Room 107A	149	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor Conference Room 107A	2	EA	6	6-10 years	
	Power Distribution	1st Floor Conference Room 107A	6	EA	6	10+ years	
	Walls - Concrete Block	1st Floor Conference Room 107A	186	SF	6	10+ years	
	Ceiling - Plaster/Drywall	1st Floor Gym Office	152	SF	6	10+ years	
	Doors - Steel Doors incl hw	1st Floor Gym Office	2	EA	6	10+ years	
	Floor - Tile	1st Floor Gym Office	152	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor Gym Office	2	EA	6	6-10 years	
	Power Distribution	1st Floor Gym Office	2	EA	6	10+ years	
	Walls - Concrete Block	1st Floor Gym Office	190	SF	6	10+ years	
	Ceiling - Plaster/Drywall	1st Floor Library Office	127	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor Library Office	1	EA	6	10+ years	
	Floor - Tile	1st Floor Library Office	127	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor Library Office	2	EA	6	6-10 years	
	Power Distribution	1st Floor Library Office	4	EA	6	6-10 years	
	Walls - Concrete Block	1st Floor Library Office	158	SF	6	10+ years	
	AC Unit	1st Floor Room 107, Main Office	1	EA	5	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor Room 107, Main Office	378	SF	6	10+ years	
	Doors - Side-lite	1st Floor Room 107, Main Office	12	SF	6	10+ years	
	Doors - Steel Doors incl hw	1st Floor Room 107, Main Office	1	EA	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor Room 107, Main Office	1	EA	6	10+ years	
	Floor - Tile	1st Floor Room 107, Main Office	378	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor Room 107, Main Office	6	EA	6	6-10 years	
	Power Distribution	1st Floor Room 107, Main Office	8	EA	6	10+ years	
	Storage/ Closet	1st Floor Room 107, Main Office	12	SF	5	10+ years	
	Walls - Concrete Block	1st Floor Room 107, Main Office	472	SF	6	10+ years	
	AC Unit	1st Floor Room 111, Faculty Lounge	1	EA	5	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor Room 111, Faculty Lounge	750	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor Room 111, Faculty Lounge	1	EA	6	10+ years	
	Floor - Tile	1st Floor Room 111, Faculty Lounge	750	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor Room 111, Faculty Lounge	16	EA	6	6-10 years	
	Power Distribution	1st Floor Room 111, Faculty Lounge	14	EA	6	10+ years	
	Walls - Concrete Block	1st Floor Room 111, Faculty Lounge	900	SF	6	10+ years	
	Work Slnk	1st Floor Room 111, Faculty Lounge	1	EA	5	6-10 years	

**Category : Room**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Ceiling - Plaster/Drywall	1st floor Work Room	188	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st floor Work Room	1	EA	6	10+ years	
	Floor - Tile	1st floor Work Room	188	SF	6	10+ years	
	Lighting - Pendent/Surface	1st floor Work Room	2	EA	6	6-10 years	
	Power Distribution	1st floor Work Room	2	EA	6	10+ years	
	Walls - Concrete Block	1st floor Work Room	235	SF	6	10+ years	
<b>Gymnasia</b>							
	Ceiling - Plaster/Drywall	1st Floor Room 100	4,285	SF	6	10+ years	
	Doors - Steel Doors incl hw	1st Floor Room 100	2	EA	6	10+ years	
	Floor - Wood	1st Floor Room 100	4,285	SF	6	10+ years	
	Lighting - Metal Halide/Sodium Vapor	1st Floor Room 100	12	EA	6	6-10 years	
	Scoreboards	1st Floor Room 100	1	EA	5	6-10 years	
	Sound System	1st Floor Room 100	1	EA	5	6-10 years	
	Stage	1st Floor Room 100	942	SF	6	10+ years	
	Stage Curtain	1st Floor Room 100	2	EA	5	10+ years	
	Stage Lift	1st Floor Room 100	1	EA	5	10+ years	
	Stage Lighting System	1st Floor Room 100	1	EA	5	6-10 years	
	Stage-Stairs - Wood	1st Floor Room 100	4	LF	6	10+ years	
	Walls - Concrete Block	1st Floor Room 100	2,590	SF	6	10+ years	
	Walls - Structural Glazed Tile	1st Floor Room 100	2,590	SF	6	10+ years	
	AC Unit	Fitness Center Rm 212	1	EA	5	6-10 years	
	Ceiling - Plaster/Drywall	Fitness Center Rm 212	575	SF	6	10+ years	
	Doors - Transom Window	Fitness Center Rm 212	108	SF	6	10+ years	
	Doors - Wood Doors inclu hw	Fitness Center Rm 212	1	EA	6	10+ years	
	Floor - Tile/Sheet	Fitness Center Rm 212	575	SF	5	10+ years	
	Lighting - Pendent/Surface	Fitness Center Rm 212	12	EA	6	6-10 years	
	Walls - Concrete Block	Fitness Center Rm 212	634	SF	6	10+ years	
<b>Kitchen</b>							
	Ceiling - Plaster/Drywall	1st Floor	1,121	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor	2	EA	6	10+ years	
	Floor - Tile Quarry	1st Floor	1,121	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	18	EA	6	6-10 years	
	Serving Line	1st Floor	16	LF	6	6-10 years	
	Walls - Structural Glazed Tile	1st Floor	1,401	SF	6	10+ years	
<b>Library</b>							
	Casework	Room 101	76	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	Room 101	1,458	SF	6	10+ years	
	Doors - Wood Doors inclu hw	Room 101	2	EA	6	10+ years	
	Floor - Tile	Room 101	1,458	SF	6	10+ years	
	Lighting - Pendent/Surface	Room 101	32	EA	6	6-10 years	



**Category : Room**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Walls - Concrete Block	Room 101	1,312	SF	6	10+ years	
	Walls - Plaster/Drywall	Room 101	439	SF	6	10+ years	
<b>Lunch &amp; Multipurpose Room</b>							
	Ceiling - Plaster/Drywall	1st Floor	2,987	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor	2	EA	6	10+ years	
	Floor - Tile	1st Floor	2,987	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	50	EA	6	6-10 years	
	Walls - Concrete Block	1st Floor	1,866	SF	6	10+ years	
	Walls - Structural Glazed Tile	1st Floor	1,866	SF	6	10+ years	
<b>MDF_IDE</b>							
	Doors - Wood Doors inclu hw	3rd floor Room 314A	1	EA	6	10+ years	
	Finishes	3rd floor Room 314A	225	SF	5	6-10 years	
	Window AC Unit	3rd floor Room 314A	1	EA	5	6-10 years	
<b>Mechanical/ Service Rooms</b>							
	Janitor's Closet	1st Floor	26	SF	5	10+ years	
	Storage Room	1st Floor	68	SF	5	10+ years	
	Storage Room	1st Floor	73	SF	5	10+ years	
	Vaults	1st Floor	30	SF	5	10+ years	
	Vaults	1st Floor	59	SF	5	10+ years	
	Janitor's Closet	2nd Floor	26	SF	5	10+ years	
	Janitor's Closet	3rd Floor	26	SF	5	10+ years	
	Boiler Room	Basement	1,623	SF	5	10+ years	
	Crawl Space - Unfinished	Basement	25,580	SF	5	10+ years	
	Mechanical/ Service Rooms	Basement	600	SF	5	10+ years	
<b>Restroom</b>							
	Accessories	1st Floor	46	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor	46	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor	1	EA	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	1st Floor	46	SF	6	10+ years	
	Lavatory	1st Floor	1	EA	6	6-10 years	
	Lighting - Pendent/Surface	1st Floor	1	EA	6	6-10 years	
	Walls - Concrete Block	1st Floor	66	SF	6	10+ years	
	Water Closet	1st Floor	1	EA	6	6-10 years	
	Accessories	1st Floor	275	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor	275	SF	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	1st Floor	275	SF	6	10+ years	
	Floor Drain	1st Floor	1	EA	7	10+ years	
	Lavatory	1st Floor	3	EA	6	6-10 years	
	Lighting - Pendent/Surface	1st Floor	3	EA	6	6-10 years	

**Category : Room**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Partitions	1st Floor	6	EA	5	6-10 years	
	Walls - Structural Glazed Tile	1st Floor	343	SF	6	10+ years	
	Water Closet	1st Floor	7	EA	6	6-10 years	
	Accessories	1st Floor	299	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor	299	SF	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	1st Floor	299	SF	6	10+ years	
	Floor Drain	1st Floor	1	EA	7	10+ years	
	Lavatory	1st Floor	3	EA	6	6-10 years	
	Lighting - Pendent/Surface	1st Floor	3	EA	6	6-10 years	
	Partitions	1st Floor	4	EA	5	6-10 years	
	Urinals	1st Floor	3	EA	6	6-10 years	
	Walls - Concrete Block	1st Floor	374	SF	6	10+ years	
	Water Closet	1st Floor	4	EA	6	10+ years	
	Accessories	1st Floor Room 115A	46	SF	5	6-10 years	
	Ceiling - Lay-in	1st Floor Room 115A	46	SF	6	6-10 years	
	Doors - Wood Doors inclu hw	1st Floor Room 115A	1	EA	6	6-10 years	
	Floor - Tile	1st Floor Room 115A	46	SF	6	10+ years	
	Floor Drain	1st Floor Room 115A	1	EA	7	10+ years	
	Lavatory	1st Floor Room 115A	1	EA	6	6-10 years	
	Lighting - Lay-in	1st Floor Room 115A	1	EA	6	6-10 years	
	Walls - Metal Panel	1st Floor Room 115A	57	SF	6	10+ years	
	Water Closet	1st Floor Room 115A	1	EA	6	6-10 years	
	Accessories	1st floor In the Principal's Office	46	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	1st floor In the Principal's Office	46	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st floor In the Principal's Office	1	EA	6	10+ years	
	Floor - Tile	1st floor In the Principal's Office	46	SF	6	10+ years	
	Lavatory	1st floor In the Principal's Office	1	EA	6	6-10 years	
	Lighting - Pendent/Surface	1st floor In the Principal's Office	1	EA	6	10+ years	
	Walls - Concrete Block	1st floor In the Principal's Office	66	SF	6	10+ years	
	Water Closet	1st floor In the Principal's Office	1	EA	6	10+ years	
	Accessories	2nd Floor	46	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	46	SF	6	10+ years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	2nd Floor	46	SF	6	10+ years	
	Lavatory	2nd Floor	1	EA	6	6-10 years	
	Lighting - Pendent/Surface	2nd Floor	1	EA	6	6-10 years	
	Walls - Concrete Block	2nd Floor	66	SF	6	10+ years	
	Water Closet	2nd Floor	1	EA	6	10+ years	
	Accessories	2nd Floor	275	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	275	SF	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	2nd Floor	275	SF	6	10+ years	
	Floor Drain	2nd Floor	1	EA	7	10+ years	
	Lavatory	2nd Floor	3	EA	6	6-10 years	
	Lighting - Pendent/Surface	2nd Floor	3	EA	6	6-10 years	

**Category : Room**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Partitions	2nd Floor	6	EA	5	6-10 years	
	Walls - Structural Glazed Tile	2nd Floor	343	SF	6	10+ years	
	Water Closet	2nd Floor	7	EA	6	6-10 years	
	Accessories	2nd Floor	299	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	299	SF	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	2nd Floor	299	SF	6	10+ years	
	Floor Drain	2nd Floor	1	EA	7	10+ years	
	Lavatory	2nd Floor	3	EA	6	6-10 years	
	Lighting - Pendent/Surface	2nd Floor	3	EA	6	6-10 years	
	Partitions	2nd Floor	4	EA	5	6-10 years	
	Urinals	2nd Floor	3	EA	6	6-10 years	
	Walls - Concrete Block	2nd Floor	374	SF	6	10+ years	
	Water Closet	2nd Floor	4	EA	6	6-10 years	
	Accessories	3rd Floor	46	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	3rd Floor	46	SF	6	10+ years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	3rd Floor	46	SF	6	10+ years	
	Lavatory	3rd Floor	1	EA	6	6-10 years	
	Lighting - Pendent/Surface	3rd Floor	1	EA	6	6-10 years	
	Walls - Concrete Block	3rd Floor	66	SF	6	10+ years	
	Water Closet	3rd Floor	1	EA	6	6-10 years	
	Accessories	3rd Floor	275	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	3rd Floor	275	SF	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	3rd Floor	275	SF	6	10+ years	
	Floor Drain	3rd Floor	1	EA	7	10+ years	
	Lavatory	3rd Floor	3	EA	6	6-10 years	
	Lighting - Pendent/Surface	3rd Floor	3	EA	6	6-10 years	
	Partitions	3rd Floor	6	EA	5	6-10 years	
	Walls - Structural Glazed Tile	3rd Floor	343	SF	6	10+ years	
	Water Closet	3rd Floor	7	EA	6	6-10 years	
	Accessories	3rd Floor	299	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	3rd Floor	299	SF	6	10+ years	
	Floor - Tile Ceramic/ Porcelain	3rd Floor	299	SF	6	10+ years	
	Floor Drain	3rd Floor	1	EA	7	10+ years	
	Lavatory	3rd Floor	3	EA	6	6-10 years	
	Lighting - Pendent/Surface	3rd Floor	3	EA	6	6-10 years	
	Partitions	3rd Floor	4	EA	5	6-10 years	
	Urinals	3rd Floor	3	EA	6	6-10 years	
	Walls - Concrete Block	3rd Floor	374	SF	6	10+ years	
	Water Closet	3rd Floor	4	EA	6	10+ years	
	Accessories	In the Main Office	46	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	In the Main Office	46	SF	5	10+ years	
	Doors - Wood Doors inclu hw	In the Main Office	1	EA	6	10+ years	
	Floor - Tile	In the Main Office	46	SF	6	10+ years	

**Category : Room**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Lavatory	In the Main Office	1	EA	6	6-10 years	
	Lighting - Pendent/Surface	In the Main Office	1	EA	6	6-10 years	
	Walls - Concrete Block	In the Main Office	66	SF	6	10+ years	
	Water Closet	In the Main Office	1	EA	6	6-10 years	
	Accessories	Room 106	36	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	Room 106	36	SF	6	10+ years	
	Doors - Wood Doors inclu hw	Room 106	1	EA	6	10+ years	
	Floor - Tile	Room 106	36	SF	6	10+ years	
	Lavatory	Room 106	1	EA	6	6-10 years	
	Lighting - Pendent/Surface	Room 106	1	EA	6	6-10 years	
	Walls - Concrete Block	Room 106	57	SF	6	10+ years	
	Water Closet	Room 106	1	EA	6	6-10 years	
	Accessories	Room 108	36	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	Room 108	36	SF	6	10+ years	
	Doors - Wood Doors inclu hw	Room 108	1	EA	6	10+ years	
	Floor - Tile	Room 108	36	SF	6	10+ years	
	Lavatory	Room 108	1	EA	6	6-10 years	
	Lighting - Pendent/Surface	Room 108	1	EA	6	6-10 years	
	Walls - Concrete Block	Room 108	52	SF	6	10+ years	
	Water Closet	Room 108	1	EA	6	6-10 years	
	Accessories	Room 110	36	SF	5	6-10 years	
	Ceiling - Plaster/Drywall	Room 110	36	SF	6	10+ years	
	Doors - Wood Doors inclu hw	Room 110	1	EA	6	10+ years	
	Floor - Tile	Room 110	36	SF	6	10+ years	
	Lavatory	Room 110	1	EA	6	6-10 years	
	Lighting - Pendent/Surface	Room 110	1	EA	6	6-10 years	
	Walls - Concrete Block	Room 110	52	SF	6	10+ years	
	Water Closet	Room 110	1	EA	6	6-10 years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<u>Classroom #102 (Regular Classroom)</u>							
	AC Units	1st Floor	1	EA	5	6-10 years	
	Casework	1st Floor	15	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor	750	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor	1	EA	6	10+ years	
	Floor - Tile	1st Floor	750	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	16	EA	6	6-10 years	
	Marker Board	1st Floor	32	LF	6	6-10 years	
	Walls - Concrete Block	1st Floor	809	SF	6	10+ years	
<u>Classroom #103 (Office)</u>							
	AC Units	2nd Floor	1	EA	5	6-10 years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Casework	2nd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	810	SF	6	10+ years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	6	10+ years	
	Lighting - Pendent/Surface	2nd Floor	14	EA	6	6-10 years	
	Marker Board	2nd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	745	SF	6	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	6	10+ years	
<hr/>							
<b>Classroom #104 (Regular Classroom)</b>							
	AC Units	1st Floor	1	EA	5	6-10 years	
	Casework	1st Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	1st Floor	750	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor	1	EA	6	10+ years	
	Floor - Tile	1st Floor	750	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	16	EA	6	6-10 years	
	Marker Board	1st Floor	32	LF	6	6-10 years	
	Walls - Concrete Block	1st Floor	809	SF	6	10+ years	
	Walls - Concrete Block	1st Floor	2	SF	6	10+ years	
<hr/>							
<b>Classroom #105 (Office)</b>							
	AC Units	1st Floor	1	EA	5	6-10 years	
	Casework	1st Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	1st Floor	810	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor	1	EA	6	10+ years	
	Floor - Tile	1st Floor	810	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	14	EA	6	6-10 years	
	Marker Board	1st Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	1st Floor	745	SF	6	10+ years	
	Walls - Plaster/Drywall	1st Floor	248	SF	6	10+ years	
<hr/>							
<b>Classroom #106 (Kindergarten)</b>							
	AC Units	1st Floor	2	EA	5	6-10 years	
	Casework	1st Floor	15	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor	1,125	SF	6	10+ years	
	Chalk Board	1st Floor	6	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	1st Floor	2	EA	5	10+ years	
	Floor - Tile	1st Floor	1,125	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	21	EA	6	6-10 years	
	Marker Board	1st Floor	8	LF	6	6-10 years	
	Walls - Concrete Block	1st Floor	1,184	SF	6	10+ years	
	Work Sink	1st Floor	1	EA	7	10+ years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<u>Classroom #108 (Kindergarten)</u>							
	AC Units	1st Floor	2	EA	5	6-10 years	
	Casework	1st Floor	15	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor	1,125	SF	6	10+ years	
	Chalk Board	1st Floor	6	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	1st Floor	2	EA	6	10+ years	
	Floor - Tile	1st Floor	1,125	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	21	EA	6	6-10 years	
	Marker Board	1st Floor	8	LF	6	6-10 years	
	Walls - Concrete Block	1st Floor	1,184	SF	6	10+ years	
<u>Classroom #109 (Regular Classroom)</u>							
	AC Units	1st Floor	1	EA	5	6-10 years	
	Casework	1st Floor	30	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor	810	SF	6	10+ years	
	Doors - Wood Doors inclu hw	1st Floor	1	EA	6	10+ years	
	Floor - Tile	1st Floor	810	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	14	EA	6	6-10 years	
	Marker Board	1st Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	1st Floor	745	SF	6	10+ years	
	Walls - Plaster/Drywall	1st Floor	248	SF	6	10+ years	
<u>Classroom #110 (Pre School)</u>							
	AC Units	1st Floor	2	EA	5	6-10 years	
	Casework	1st Floor	15	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	1st Floor	1,125	SF	6	10+ years	
	Chalk Board	1st Floor	6	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	1st Floor	2	EA	6	10+ years	
	Floor - Tile	1st Floor	1,125	SF	6	10+ years	
	Lighting - Pendent/Surface	1st Floor	21	EA	6	6-10 years	
	Marker Board	1st Floor	8	LF	6	6-10 years	
	Walls - Concrete Block	1st Floor	1,184	SF	6	10+ years	
	Work Sink	1st Floor	1	EA	7	10+ years	
<u>Classroom #200 (Regular Classroom)</u>							
	Casework	2nd Floor	15	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	750	SF	6	10+ years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	750	SF	6	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	6	6-10 years	
	Marker Board	2nd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	809	SF	6	10+ years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<b>Classroom #201 (Regular Classroom)</b>							
	AC Units	2nd Floor	1	EA	5	6-10 years	
	Casework	2nd Floor	30	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	810	SF	6	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	6	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	6	6-10 years	
	Marker Board	2nd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	745	SF	6	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	6	10+ years	
<b>Classroom #202 (Regular Classroom)</b>							
	AC Units	2nd Floor	1	EA	5	6-10 years	
	Casework	2nd Floor	15	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	725	SF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	25	SF	4	0-1 year	Damaged ceiling area near windows
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	750	SF	6	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	6	6-10 years	
	Marker Board	2nd Floor	32	LF	6	6-10 years	
	Walls - Masonry	2nd Floor	809	SF	6	10+ years	
<b>Classroom #203 (Regular Classroom)</b>							
	AC Units	2nd Floor	1	EA	5	6-10 years	
	Casework	2nd Floor	30	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	810	SF	6	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	6	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	6	6-10 years	
	Marker Board	2nd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	745	SF	6	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	6	10+ years	
<b>Classroom #204 (Regular Classroom)</b>							
	AC Units	2nd Floor	1	EA	5	6-10 years	
	Casework	2nd Floor	15	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	750	SF	6	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	750	SF	6	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	6	6-10 years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Marker Board	2nd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	809	SF	6	10+ years	
<b>Classroom #205 (Regular Classroom)</b>							
	AC Units	2nd Floor	1	EA	5	6-10 years	
	Casework	2nd Floor	30	LF	6	6-10 years	
	Ceiling - Plaster/Drywall	2nd Floor	810	SF	6	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	6	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	6	6-10 years	
	Marker Board	2nd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	745	SF	6	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	6	10+ years	
<b>Classroom #206 (Other Instructional Use)</b>							
	AC Units	2nd Floor	1	EA	7	6-10 years	
	Casework	2nd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	750	SF	7	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	750	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	7	6-10 years	
	Marker Board	2nd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	809	SF	7	10+ years	
<b>Classroom #207 (Computer Lab)</b>							
	AC Units	2nd Floor	2	EA	7	6-10 years	
	Casework	2nd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	810	SF	7	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	7	6-10 years	
	Marker Board	2nd Floor	16	LF	6	6-10 years	
	Student Lockers - One Tier	2nd Floor	6	EA	6	10+ years	
	Walls - Concrete Block	2nd Floor	745	SF	7	10+ years	
	Wireless System	2nd Floor	1	EA	7	6-10 years	
<b>Classroom #208 (Regular Classroom)</b>							
	AC Units	2nd Floor	1	EA	7	6-10 years	
	Casework	2nd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	730	SF	7	10+ years	



**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Ceiling - Plaster/Drywall	2nd Floor	20	SF	5	1-2 years	Damaged ceiling areas
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	750	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	7	6-10 years	
	Marker Board	2nd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	809	SF	7	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	7	10+ years	
<b>Classroom #209 (Office)</b>							
	AC Units	2nd Floor	1	EA	7	6-10 years	
	Casework	2nd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	810	SF	7	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	7	6-10 years	
	Marker Board	2nd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	7	10+ years	
<b>Classroom #210 (Other Instructional Use)</b>							
	AC Units	2nd Floor	1	EA	7	6-10 years	
	Casework	2nd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	560	SF	7	10+ years	Damaged areas of the ceiling
	Ceiling - Plaster/Drywall	2nd Floor	15	SF	5	0-1 year	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	575	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	12	EA	7	6-10 years	
	Marker Board	2nd Floor	16	LF	6	6-10 years	
	Walls - Plaster/Drywall	2nd Floor	634	SF	7	10+ years	
<b>Classroom #211 (Store Room)</b>							
	AC Units	2nd Floor	1	EA	7	6-10 years	Small damaged area of ceiling needs repaired.
	Casework	2nd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	795	SF	7	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	15	SF	5	0-1 year	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	7	6-10 years	
	Marker Board	2nd Floor	12	LF	6	6-10 years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Walls - Concrete Block	2nd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	7	10+ years	
<b>Classroom #213 (Regular Classroom)</b>							
	AC Units	2nd Floor	1	EA	7	6-10 years	
	Casework	2nd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	800	SF	7	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	10	SF	5	0-1 year	Ceiling areas need repaired
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	7	6-10 years	
	Marker Board	2nd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	7	10+ years	
<b>Classroom #214 (Regular Classroom)</b>							
	AC Units	2nd Floor	1	EA	7	6-10 years	
	Casework	2nd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	575	SF	7	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	575	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	12	EA	7	6-10 years	
	Marker Board	2nd Floor	16	LF	6	6-10 years	
	Walls - Plaster/Drywall	2nd Floor	634	SF	7	10+ years	
<b>Classroom #215 (Special Education)</b>							
	AC Units	2nd Floor	1	EA	7	6-10 years	
	Casework	2nd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	810	SF	6	10+ years	
	Chalk Board	2nd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	2nd Floor	1	EA	6	10+ years	
	Floor - Tile	2nd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	16	EA	7	6-10 years	
	Marker Board	2nd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	2nd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	2nd Floor	248	SF	7	10+ years	
<b>Classroom #216 (Science Classroom)</b>							
	AC Units	2nd Floor	2	EA	7	6-10 years	
	Casework	2nd Floor	70	LF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	1,764	SF	7	10+ years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Doors - Wood Doors inclu hw	2nd Floor	2	EA	6	10+ years	
	Floor - Tile	2nd Floor	1,764	SF	7	10+ years	
	Lighting - Pendent/Surface	2nd Floor	46	EA	7	6-10 years	
	Marker Board	2nd Floor	12	LF	6	6-10 years	
	Student Lockers - One Tier	2nd Floor	11	EA	6	10+ years	
	Walls - Concrete Block	2nd Floor	1,383	SF	7	10+ years	
	Walls - Plaster/Drywall	2nd Floor	461	SF	7	10+ years	
	Work Sink	2nd Floor	2	EA	7	6-10 years	

Classroom #300 (Regular Classroom)

	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	675	SF	7	10+ years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	675	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	12	EA	7	6-10 years	
	Marker Board	3rd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	734	SF	7	10+ years	

Classroom #301 (Regular Classroom)

	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	810	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	16	EA	7	6-10 years	
	Marker Board	3rd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	3rd Floor	248	SF	7	10+ years	

Classroom #302 (Regular Classroom)

	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	750	SF	7	10+ years	
	Chalk Board	3rd Floor	14	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	750	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	16	EA	7	6-10 years	
	Marker Board	3rd Floor	32	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	809	SF	7	10+ years	

Classroom #303 (Regular Classroom)

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	810	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	16	EA	7	6-10 years	
	Marker Board	3rd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	3rd Floor	248	SF	7	10+ years	

Classroom #304 (Regular Classroom)

	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	750	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	750	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	16	EA	6	6-10 years	
	Marker Board	3rd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	809	SF	7	10+ years	

Classroom #305 (Regular Classroom)

	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	810	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	15	EA	7	6-10 years	
	Marker Board	3rd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	3rd Floor	248	SF	7	10+ years	

Classroom #306 (Special Education)

	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	750	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	750	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	16	EA	7	6-10 years	
	Marker Board	3rd Floor	16	LF	6	6-10 years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Walls - Concrete Block	3rd Floor	809	SF	7	10+ years	
<b>Classroom #307 (Regular Classroom)</b>							
	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	810	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	15	EA	7	6-10 years	
	Marker Board	3rd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	3rd Floor	248	SF	7	10+ years	
<b>Classroom #308 (Regular Classroom)</b>							
	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	750	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	750	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	16	EA	7	6-10 years	
	Marker Board	3rd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	809	SF	7	10+ years	
<b>Classroom #309 (Regular Classroom)</b>							
	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	810	SF	7	10+ years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	15	EA	7	6-10 years	
	Marker Board	3rd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	3rd Floor	248	SF	7	10+ years	
<b>Classroom #310 (Store Room)</b>							
	Casework	3rd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	750	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	750	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	16	EA	7	6-10 years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Marker Board	3rd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	809	SF	7	10+ years	
<b>Classroom #311 (Art Room)</b>							
	AC Units	3rd Floor	2	EA	7	6-10 years	
	Casework	3rd Floor	60	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	1,620	SF	7	10+ years	
	Doors - Wood Doors inclu hw	3rd Floor	2	EA	6	10+ years	
	Floor - Tile	3rd Floor	1,620	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	32	EA	7	6-10 years	
	Marker Board	3rd Floor	16	LF	6	6-10 years	
	Storage/ Closet	3rd Floor	84	SF	7	10+ years	
	Walls - Concrete Block	3rd Floor	1,308	SF	7	10+ years	
	Walls - Plaster/Drywall	3rd Floor	436	SF	7	10+ years	
	Work Sink	3rd Floor	2	EA	7	6-10 years	
<b>Classroom #312 (Regular Classroom)</b>							
	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	575	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	575	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	12	EA	7	6-10 years	
	Marker Board	3rd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	634	SF	7	10+ years	
<b>Classroom #313 (Office)</b>							
	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	30	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	810	SF	7	10+ years	
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	810	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	16	EA	7	6-10 years	
	Marker Board	3rd Floor	12	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	745	SF	7	10+ years	
	Walls - Plaster/Drywall	3rd Floor	248	SF	7	10+ years	
<b>Classroom #314 (Regular Classroom)</b>							
	AC Units	3rd Floor	1	EA	7	6-10 years	
	Casework	3rd Floor	15	LF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	575	SF	7	10+ years	
	Chalk Board	3rd Floor	16	LF	4	2-5 years	

**Category : Classroom**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Doors - Wood Doors inclu hw	3rd Floor	1	EA	6	10+ years	
	Floor - Tile	3rd Floor	575	SF	7	10+ years	
	Lighting - Pendent/Surface	3rd Floor	12	EA	7	6-10 years	
	Marker Board	3rd Floor	16	LF	6	6-10 years	
	Walls - Concrete Block	3rd Floor	634	SF	7	10+ years	

**Category : Interior**
**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<b>Corridor</b>							
	Ceiling - Plaster/Drywall	1st Floor	1,924	SF	6	10+ years	
	Doors - Wood Doors include hw	1st Floor	4	EA	6	10+ years	
	Drinking Fountains - Single Fountain	1st Floor	4	EA	5	10+ years	
	Floor - Tile/Sheet	1st Floor	1,924	SF	5	10+ years	
	Lighting - Pendent/Surface	1st Floor	40	EA	6	6-10 years	
	Walls - Concrete Block	1st Floor	2,134	SF	6	10+ years	
	Ceiling - Plaster/Drywall	2nd Floor	1,848	SF	6	10+ years	
	Drinking Fountains - Single Fountain	2nd Floor	4	EA	5	10+ years	
	Floor - Tile/Sheet	2nd Floor	1,848	SF	5	10+ years	
	Lighting - Pendent/Surface	2nd Floor	40	EA	6	6-10 years	
	Walls - Concrete Block	2nd Floor	1,878	SF	6	10+ years	
	Ceiling - Plaster/Drywall	3rd Floor	1,848	SF	6	10+ years	
	Drinking Fountains - Single Fountain	3rd Floor	4	EA	5	10+ years	
	Floor - Tile/Sheet	3rd Floor	1,848	SF	5	10+ years	
	Lighting - Pendent/Surface	3rd Floor	40	EA	6	6-10 years	
	Walls - Concrete Block	3rd Floor	1,878	SF	6	10+ years	

**Safety**

	Camera Viewing Station	Entire Building	3	EA	5	6-10 years	
	Security Cameras	Entire Building	6	EA	5	6-10 years	
	Security Cameras	Entire Building	3	EA	5	6-10 years	
	Security Cameras	Entire Building	1	EA	5	6-10 years	
	Security Cameras	Entire Building	1	EA	5	6-10 years	

**Stairs**

	Ceiling - Plaster/Drywall	South	198	SF	6	10+ years	
	Floor - Tile	South	198	SF	6	10+ years	
	Handrails	South	402	LF	5	10+ years	
	Lighting - Pendent/Surface	South	12	EA	6	6-10 years	
	Stairs - Terrazzo	South	774	LF	6	10+ years	
	Walls - Plaster/Drywall	South	252	SF	6	10+ years	
	Ceiling - Plaster/Drywall	Southeast	198	SF	6	10+ years	
	Floor - Tile	Southeast	198	SF	6	10+ years	

**Category : Interior**

**Building : Main**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
	Handrails	Southeast	402	LF	5	10+ years	
	Lighting - Pendent/Surface	Southeast	12	EA	6	6-10 years	
	Stairs - Terrazzo	Southeast	774	LF	6	10+ years	
	Walls - Plaster/Drywall	Southeast	252	SF	6	10+ years	
	Ceiling - Plaster/Drywall	Southwest	198	SF	6	10+ years	
	Floor - Tile	Southwest	198	SF	6	10+ years	
	Handrails	Southwest	402	LF	5	10+ years	
	Lighting - Pendent/Surface	Southwest	12	EA	6	6-10 years	
	Stairs - Terrazzo	Southwest	774	LF	6	10+ years	
	Walls - Plaster/Drywall	Southwest	252	SF	6	10+ years	

Vertical Conveyance

	Elevator - Elevator- Roped Holeless Hydraulic		1	EA	7	10+ years	
--	---	--	---	----	---	-----------	--



**Category : Site**
**Building : Site**

Group	Item - Type	Location	Quantity	UOM	Rank	Recommend Replacement	Comments
<u>Civil/Drainage</u>							
	Civil/ Drainage - Catch Basin	Entire Site	5	EA	7	10+ years	
	Civil/ Drainage - Site Manhole	Entire Site	4	EA	7	10+ years	
<u>Fencing</u>							
	Fencing - Chain Link	Entire Site	905	LF	6	10+ years	
	Fencing - Chain Link	Entire Site	100	LF	4	0-1 year	Damaged fence sections
	Fencing - New Standard Ornamental	Entire Site	1,080	LF	6	10+ years	
	Fencing - Wood Fencing w/ Steel Frame	Entire Site	328	LF	7	6-10 years	
<u>Landscape</u>							
	Benches	Entire Site	6	EA	4	0-1 year	worn out
	Landscape - Grass	Entire Site	7,020	SF	6	10+ years	
	Landscape - Hardscape- Concrete	Entire Site	200	SF	7	10+ years	
	Landscape - Hardscape- Concrete	Entire Site	175	SF	6	10+ years	by playground
	Parkway trees	Entire Site	25	EA	6	10+ years	
	Play Area - Synthetic Turf Play Field	Entire Site	11,520	SF	7	10+ years	
	Trash Receptacles	Entire Site	2	EA	6	10+ years	
<u>Parking Lot</u>							
	Surface - Asphalt	North Courtyard	16,500	SF	5	1-2 years	Parking lot needs resurfaced
	Trash Enclosure - Chain Links	North Courtyard	825	SF	6	10+ years	
<u>Playground</u>							
	Equipment - School Age 5-12	North Courtyard	1	EA	6	10+ years	
	Surface - Poured Surface	North Courtyard	1,520	SF	6	10+ years	
<u>Sidewalks</u>							
	Sidewalks - Internal Walks	Entire Site	65	LF	6	10+ years	
	Sidewalks - Perimeter Sidewalks	Entire Site	11,600	SF	7	10+ years	
<u>Signage</u>							
	Flag Pole - Flag Pole	South Courtyard	1	EA	7	10+ years	
	Marquee - Free Standing Back Lighted	South Courtyard	1	EA	7	10+ years	

<sup>1</sup> It is very rare for assessors to find a feature in this condition. If assessors do, they are required to report it to CPS right away, and CPS facilities will address it immediately. As a result, no features should be ranked "1" in this report; by the time the report is compiled, they will have been resolved.

**Definitions**

- **Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated
  - **Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
-

**Classroom Summary**

Current Usage	Intended Usage	Room Location	Room Number	Floor Plan Room Number	Area (SF)	Glazed Window Area	Operable Window Area	Window Stop	Smart-Board
<b>Building : Main</b>									
Art Room	Regular Classroom	3rd Floor	311	311	1,620	312	104	Y	N
Computer Lab	Regular Classroom	2nd Floor	207	207	810	148	52	Y	N
Kindergarten	Kindergarten	1st Floor	106	106	1,125	288	84	Y	N
Kindergarten	Kindergarten	1st Floor	108	108	1,125	288	84	Y	N
Office	Regular Classroom	1st Floor	105	107	810	115	20	Y	N
Office	Regular Classroom	2nd Floor	103	105	810	115	20	Y	N
Office	Regular Classroom	2nd Floor	209	209	810	156	52	Y	N
Office	Regular Classroom	3rd Floor	313	313	810	156	52	Y	N
Other Instructional Use	Regular Classroom	2nd Floor	206	206	750	144	49	Y	N
Other Instructional Use	Regular Classroom	2nd Floor	210	210	575	108	42	Y	N
Pre School	Pre School	1st Floor	110	110	1,125	288	84	Y	N
Regular Classroom	Regular Classroom	1st Floor	102	102	750	144	49	Y	Y
Regular Classroom	Regular Classroom	1st Floor	104	104	750	144	49	Y	Y
Regular Classroom	Regular Classroom	1st Floor	109	109	810	120	20	Y	N
Regular Classroom	Regular Classroom	2nd Floor	200	200	750	144	49	Y	N
Regular Classroom	Regular Classroom	2nd Floor	201	201	810	156	52	Y	N
Regular Classroom	Regular Classroom	2nd Floor	202	202	750	144	49	Y	N
Regular Classroom	Regular Classroom	2nd Floor	203	203	810	156	52	Y	N
Regular Classroom	Regular Classroom	2nd Floor	204	204	750	156	52	Y	N
Regular Classroom	Regular Classroom	2nd Floor	205	205	810	156	52	Y	N
Regular Classroom	Regular Classroom	2nd Floor	208	208	750	144	49	Y	Y
Regular Classroom	Regular Classroom	2nd Floor	213	213	810	156	52	Y	N
Regular Classroom	Regular Classroom	2nd Floor	214	214	575	108	42	Y	N
Regular Classroom	Regular Classroom	3rd Floor	300	300	675	108	42	Y	N
Regular Classroom	Regular Classroom	3rd Floor	301	301	810	156	52	Y	Y
Regular Classroom	Regular Classroom	3rd Floor	302	302	750	140	42	Y	N
Regular Classroom	Regular Classroom	3rd Floor	303	303	810	156	52	Y	N
Regular Classroom	Regular Classroom	3rd Floor	304	304	750	144	49	Y	N
Regular Classroom	Regular Classroom	3rd Floor	305	305	810	156	52	Y	N
Regular Classroom	Regular Classroom	3rd Floor	307	307	810	156	52	Y	N
Regular Classroom	Regular Classroom	3rd Floor	308	308	750	144	49	Y	N
Regular Classroom	Regular Classroom	3rd Floor	309	309	810	156	52	Y	N
Regular Classroom	Regular Classroom	3rd Floor	312	312	575	108	42	Y	N
Regular Classroom	Regular Classroom	3rd Floor	314	314	575	108	42	Y	N
Science Classroom	Science Classroom	2nd Floor	216	216	1,764	261	72	N	N
Special Education	Regular Classroom	2nd Floor	215	215	810	156	52	Y	N
Special Education	Regular Classroom	3rd Floor	306	306	750	144	49	Y	N
Store Room	Regular Classroom	2nd Floor	211	211	810	156	52	Y	N

**Classroom Summary**

<b>Current Usage</b>	<b>Intended Usage</b>	<b>Room Location</b>	<b>Room Number</b>	<b>Floor Plan Room Number</b>	<b>Area (SF)</b>	<b>Glazed Window Area</b>	<b>Operable Window Area</b>	<b>Window Stop</b>	<b>Smart-Board</b>
Store Room	Regular Classroom	3rd Floor	310	310	750	144	49	Y	N