Chicago Public Schools

6 Month Asbestos Surveillance

2018 - Fall

	School: Address:	Stephen Decatur Classical Elementary School 7030 N Sacramento Avenue		Oracle Unit: Region:	29031 01	Building ID: Mail Room:	2990 32
	HERE IF I	NO CHANGE TO ASBESTOS	Asbestos Surveyor: Survey Date: Email Address:	Monaghan, Kevin 12/19/2018			
Γ	A copy of th	ne2016/2017 notice to parents and staff regard	ing the asbestos managem	ent plan notifications was d	istributed via:		

	Each child's back	back	X Notice	printed in school's nev	vsletter Notice printed in school's calendar Other								
HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	sment Category	
01	Acoustic Plaster	2500	SF	1st Fl Corridor, Eng. Office, Boiler Room, Kitchen		Surface	No	None	0		YES	XNO	
2016 - Fal	II: No Change												
Comments	S:												
2017 - Spi	ring: No Change				-								
Comments	S:												
2017 - Fal	II: No Change												
Comment	S:	_											
2018 - Spi	ring : No Change												
Comments	s:	_											

2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
02	12"x12" Acoustic Tile	12500	SF	Rm 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, Office, Corridors, Gym, Storage		Miscellaneous	Yes	None	0		YES XNO

2040 Falls Na Ohanara	
2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03	12"x12" White w/ Grey Streaks VFT	13500	SF	Rm 100, 101, 102, 103, 104, 105, 107, 108, 109, 111, 112, Corridors, Kitchen, Storage by Office, Main Office & Principal's Office		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
04	9"x9" Gold VFT	210	SF	Main Office Storage Room		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
05	12"x12" White w/ Grey Streaks VFT Mastic	13500	SF	Rm 100, 101, 102, 103, 104, 105, 107, 108, 109, 111, 112, Corridors, Kitchen, Storage by Office, Main Office & Principal's Office		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2010 Fall: No Change
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
06	9"x9" Gold VFT Mastic	210	SF	Main Office Storage Room		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
07	Vinyl Baseboard	3500	LF	Rm 100, 101, 102, 103, 104, 105, 107, 106, 109, 108, 111, 110, 112, Office, Corridors, Gym, Storage		Miscellaneous	No	None	0		

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

VFT = *Vinyl Floor Tile Friable* = *Can be crumbled, pulverized, or reduced to powder by hand pressure.*

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
08	Vinyl Baseboard Mastic	3500	LF	Rm 100, 101, 102, 103, 104, 105, 107, 106, 109, 108, 111, 110, 112, Office, Corridors, Gym, Storage		Miscellaneous	No	None	0		YES XNO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
09	Linoleum (NOT OBSERVED)	0		Rm 100, 102, 101 (NOT OBSERVED)							YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	Linoleum Mastic (NOT OBSERVED)	0		Rm 100, 102, 101 (NOT OBSERVED)							YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HAN	No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11		12"x12" Tan w/ Beige Streaks VFT	850	SF	Rm 106		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	12"x12" Tan w/ Beige Streaks VFT Mastic	850	SF	Room 106		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	12"x12" Cream VFT	400	SF	Rm 110		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14	12"x12" Cream VFT Mastic	400	SF	Rm 110		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	12"x12" Chocolate VFT	400	SF	Rm 110		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

	HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
F	16	12"x12" Chocolate VFT Mastic	400	SF	Rm 110		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 Spring: No Change
2017 - Spring: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17	12"x12" Beige w/ Brown Streaks VFT (NOT OBSERVED)	1350	SF	Gym/All Purpose Room (NOT OBSERVED)		Miscellaneous	No	None	0		YES XNO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18	12"x12" Beige w/ Brown Streaks VFT Mastic (NOT OBSERVED)	1350	SF	Gym/All Purpose Room (NOT OBSERVED)		Miscellaneous	No	None	0		

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
19	9" x 9" Grayish Green VFT	4	SF	Gym/All Purpose Room Closet (MDF)		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
19 A	9" x 9" Grayish Green VFT Mastic	4	SF	Gym/All Purpose Room Closet (MDF)		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	12 x 12 inch Light Brown w/White Streaks VFT	60	SF	All-Purpose Lunch Room Closet (Food Storage Room)		Miscellaneous	No	None	0		YES XNO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20 A	12 x 12 inch Lt. Brn w/Wht Streaks VFT Mastic	60	SF	All-Purpose Lunch Room Closet (Food Storage Room)		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2018 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	

H.	IA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
2	:1	2' x 2' Ceiling Tiles with Grooves	2500	SF	Corridors		Miscellaneous	Yes	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
22	12" X 12" white-with-blue streaks VFT	1100	SF	Gym / All-purpose Room		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2019 Spring : No Change
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
22A	12" X 12" white-with-blue streaks VFT Mastic	1100	SF	Gym / All-purpose Room		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	12" X 12" Blue VFT	480	SF	Gym / All-purpose Room		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23A	12" X 12" Blue VFT Mastic	480	SF	Gym / All-purpose Room		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change	
Comments:	
2017 - Fall: No Change	
Comments:	
2017 - Spring: No Change	
Comments:	
2018 - Spring : No Change	
Comments:	
2018 - Fall: No Change	
Comments:	

H	IA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
в	3	MJP on Fiberglass Pipe Insulation	30	LF	Pipe Chase, Between Girl's and Boy's Bathrooms		TSI	Yes	None	0		YES XNO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

ALL LEA Responsibilities, for this school, will be met.

Alunha /2

Robert Christlieb

NOTICE TO PARENTS AND STAFF REGARDING THE ASBESTOS MANAGEMENT PLAN NOTIFICATION

School:	Stephen Decatur Classical Elementary School
Date:	12/19/2018

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2016.

Asbestos surveillances are conducted every six months.

CHECK ONE

A copy of this notice was sent home in each child's backpack.

X A copy of this notice was printed in the school's newsletter and sent home with each child

A copy of this notice was printed in the school's calendar and sent home with each child

Other.

A COPY OF THIS NOTICE MUST BE PLACED IN THE SCHOOL'S ASBESTOS MANAGEMENT PLAN.