

# Chicago Public Schools

## 6 Month Asbestos Surveillance

### 2018 - Fall

**School:** Noble - UIC College Prep  
**Address:** 1231 S. Damen

**Oracle Unit:** 66147  
**Region:** 03

**Building ID:** 3540  
**Mail Room:** 38

**CHECK HERE IF NO CHANGE TO ASBESTOS**

**Asbestos Surveyor:** SZHAO9  
**Survey Date:** 12/19/2018  
**Email Address:** szhao@noblenetwork.org

A copy of the 2016/2017 notice to parents and staff regarding the asbestos management plan notifications was distributed via:

Each child's backpack    
 Notice printed in school's newsletter    
 Notice printed in school's calendar    
 Other

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1	Plaster (1884)			Throughout Building		Surface					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments: No asbestos contained material
2017 - Spring: No Change
Comments: No asbestos contained material
2017 - Fall: No Change
Comments: No asbestos contained material
2018 - Spring : No Change
Comments: No asbestos contained material
2018 - Fall: No Change
Comments: No asbestos contained material

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
2	9" x 9" Red Floor Tile (w/Specks) - Abated			Rooms 206,103, and 204		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: Abated
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
3	12" x 12" Tan w/Red Streaks Floor Tile	200	SF	Engineer's Office		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
4	2' x 4' Ceiling Tile (1884)			3rd Floor Classrooms, Clinic		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained material
2017 - Fall: No Change
Comments:no asbestos cantained material
2018 - Spring : No Change
Comments:No asbestos contained material
2018 - Fall: No Change
Comments:No asbestos contained material

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
5	Linoleum			Gym							<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained material
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:No asbestos contained material
2018 - Fall: No Change
Comments:No asbestos contained material

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6	9" x 9" Red Floor Tile (wSpecks) Mastic			Rooms 206,103, and 204		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
7	12" x 12" Off-White Floor Tile Mastic			Washrooms		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8	Linoleum Mastic - REMOVED			Gym							<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
9	9" x 9" Green Floor Tile- Abated			Nurse's Office and Room 113		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	12" x 12" Off-White Floor Tile - Abated			3rd, 2nd Floor Faculty Washrooms		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11	9" x 9" Green Floor Tile Mastic- Abated			Nurse's Office and Room 113		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	12" x 12" Tan w/Red Streaks Floor Tile Mastic			Engineer's Office and Assembly Hall		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained material
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:No asbestos contained material
2018 - Fall: No Change
Comments:No asbestos contained material

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	Plaster (1910)			Throughout Building		Surface					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained material
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:No asbestos contained material
2018 - Fall: No Change
Comments:No asbestos contained material

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14	9" x 9" Red with White Streaks Floor Tile			Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	9" x 9" Red with White Streaks Floor Tile Mastic			Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16	9" x 9" Wood Grain Green Floor Tile			Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17	9" x 9" Wood Grain Green Floor Tile Mastic			Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18	12" x 12" Blue Floor Tile			Lunchroom		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
19	12" x 12" Blue Floor Tile Mastic			Lunchroom		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	12" x 12" Yellow Floor Tile			Lunchroom		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	12" x 12" Yellow Floor Tile Mastic			Lunchroom		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
22	12" x 12" Speckled Brown Floor Tile			Room 114		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	12" x 12" Speckled Brown Floor Tile Mastic			Room 114		Miscellaneous		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24	12" x 12" Brown w/Yellow Speckled Floor Tile - Abated			Room 113 (1910 bldg.)		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25	12" x 12"Brown w/Yellow Speckled Floor Tile Mastic - Abated			Room 113 (1910 bldg.)		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	12" x 12" Brown w/White Speckles Floor Tile	175	SF	2nd Floor Teacher's Washroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	12" x 12" Brown w/White Speckles Floor Tile	175	SF	2nd Floor Teacher's Washroom		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28	12" x 12" Green Floor Tile			Room 106A (1884 Building)		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
29	12" x 12" Green Floor Tile Mastic			Room 106A (1884 Building)		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
30	12" x 12" Beige Floor Tile - Abated			Principal's Office and Room 104		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
31	12" x 12" Beige Floor Tile Mastic - Abated			Principal's Office and Room 104		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
32	12" x 12" Off-Gray Floor Tile w/White Streaks - Abated			Principal's Office and 104		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
33	12" x 12" Off-Gray Floor Tile w/White Streaks - Abated			Principal's Office and 104		Miscellaneous					<input checked="" type="checkbox"/> YES   <input type="checkbox"/> NO

2016 - Fall: Abated
Comments:Abated
2017 - Spring: No Change
Comments:Abated
2017 - Fall: No Change
Comments:abated
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
34	Exterior Door Caulk NON AHERA			Exterior of Building		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
35	Exterior Brick (Non AHERA)			Exterior of Building		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained material
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
36	Exterior Brick Mortar (Non AHERA)			Exterior of Building		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained material
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
37	Baseboard			Throughout Building		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained material
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
38	Baseboard Mastic			Throughout Building		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained material
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:abated
2018 - Fall: No Change
Comments:abated

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
39	Window Glaze - Non AHERA			Exterior of Field House		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
40	12" x 12" Yellow Floor Tile	500	SF	2nd & 3rd floors Teacher's Bathrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
41	12" x 12" Yellow Floor Tile Mastic	500	SF	2nd & 3rd floors Teacher's Bathrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
42	12" x 12" Blue w/ Dk Blue and Gray Spots FT			Room 113, Clinic		Miscellaneous		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
43	12" x 12" Blue w/ Dk Blue and Gray Spots FT Mastic			Room 113, Clinic		Miscellaneous		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
44	12" x 12" Yellow w/ Rust and White Specks FT	1200	SF	Room 113- Exam Rooms Clinic		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
45	12" x 12" Yellow w/ Rust & White Specks FT Mastic	1200	SF	Room 113- Exam Rooms Clinic		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
46	12" x 12" Dark Blue Floor Tile			Room 112-Gym Stage, Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
47	12" x 12" Dark Blue Floor Tile Mastic			Room 112-Gym Stage, Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
48	12" x 12" Cream Floor Tile			Room 112- Gym Stage, Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
49	12" x 12" Cream Floor Tile Mastic			Room 112- Gym Stage, Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
50	12" x 12" Blue Floor Tile			Room 101, 101 C, 102, 105, 107, 108, 201, 201C, 202, 202C, 204, 205, 207, 207C, 208, 208C		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
51	12" x 12" Blue Floor Tile Mastic			Room 101, 101 C, 102, 105, 107, 108, 201, 201C, 202, 202C, 204, 205, 207, 207C, 208, 208C		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
52	Dry Erase Board Mastic	5126	SF	All Classrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
53	Vault Door Liner	15	SF	Room 102C - Now Storage 202A		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
54	Blue Carpet Adhesive	1200	SF	Room 104 (Main Office)		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
55	12" x 12" white floor tile with gray and black	6500	SF	Rooms Main Office, 108, 203, 206, 303, 304, 306, Staff room, exercize room, kitchen, lunchroom. 1910 Basement Hallway		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
56	Mastic for 12" x 12" white floor tile	6500	SF	Rooms: Main office, 108, 203, 303, 304, 306, Staff room, exercise room, kitchen and lunchroom. 1910 Basement Hallway.		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change	Comments:
2017 - Spring: No Change	Comments:
2017 - Fall: No Change	Comments:
2018 - Spring : No Change	Comments:
2018 - Fall: No Change	Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
57	2'x4' Ceiling tile white smooth	3200	SF	Rooms 403, 404, 405, 406		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change	Comments:
2017 - Spring: No Change	Comments:
2017 - Fall: No Change	Comments:
2018 - Spring : No Change	Comments:
2018 - Fall: No Change	Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
58	Gray carpet mastic	2000	SF	Rooms 108, 109, 110, 113		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change	Comments:
2017 - Spring: No Change	Comments:
2017 - Fall: No Change	Comments:
2018 - Spring : No Change	Comments:
2018 - Fall: No Change	Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
59	12x12 white ft with light brown			Room 111		Miscellaneous		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change	Comments:
2017 - Spring: No Change	Comments:
2017 - Fall: No Change	Comments:
2018 - Spring : No Change	Comments:
2018 - Fall: No Change	Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
60	Mastic for 12x12 white floor tile with light brown			Room 111		Miscellaneous		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
61	12"x12" White w/Blue Specks Floor Tile	1600	SF	1884 Building East Foyer Entrance		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
62	12"x12" White w/Blue Specks Floor Tile Mastic	1600	SF	1884 Building East Foyer Entrance		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
63	2'x2' Smooth Ceiling Tile	750	SF	Boys and Girls Restrooms in 1910 Building		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
64	12"x12" Black Floor Tile	900	SF	2nd and 3rd Floor Ramp from 1884 to 1910		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
65	12"x12" Black Floor Tile Mastic	900	SF	2nd and 3rd Floor Ramp from 1884 to 1910		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
66	Brown linoleum	200	SF	Serving Room in 1910 Building		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
67	Brown Linoleum Mastic	200	SF	Servng Room in 1910 Building		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
A&E	Mag Pipe Insulation	500	LF	Throughout Areas in Basement		TSI	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
B&F	Cardboard Pipe Insulation			Boiler Room and Boy's Bathroom		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:No asbestos contained material
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:no asbestos contained material
2018 - Spring : No Change
Comments:No asbestos contained material
2018 - Fall: No Change
Comments:No asbestos contained material

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
C	Fiberglass Pipe Insulation - Not a Suspect Material										<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:no asbestos contained material
2017 - Spring: No Change
Comments:No asbestos contained materials
2018 - Spring : No Change
Comments:No asbestos contained materials
2018 - Fall: No Change
Comments:No asbestos contained material

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
D	Boiler Gasket			Boiler Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
G	Fittings (Mud) on Fiberglass Pipe Insulation	100	LF	Throughout Basement		TSI	Yes	None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
H	Suspended Water Tank Insulation - Abated			Boiler Room		TSI					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
I	Cementitious Valve Headers			Boiler Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments: No asbestos contained material
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
J	Insulation in AHU			AHU 1-3 Behind Sheet Metal Panels		TSI					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

*ALL LEA Responsibilities, for this school, will be met.*



---

Robert Christlieb

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***



NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Noble - UIC College Prep

Date: 6/12/2018

---

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2016. Asbestos surveillances are conducted every six months.

CHECK ONE

- A copy of this notice was sent home in each child's backpack.
- A copy of this notice was printed in the school's newsletter and sent home with each child
- A copy of this notice was printed in the school's calendar and sent home with each child
- Other.
- 

A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***