Chicago Public Schools

6 Month Asbestos Surveillance 2018 - Fall

70070 Chicago Military Academy High School 1800 School: **Oracle Unit: Building ID:** Address: 3516 South Giles Avenue Region: Mail Room: Asbestos Surveyor: Salvati, James X CHECK HERE IF NO CHANGE TO ASBESTOS Survey Date: 12/6/2018 Email Address: jvsalvati@cps.edu A copy of the 2016/2017 notice to parents and staff regarding the asbestos management plan notifications was distributed via: Notice printed in school's newsletter Each child's backpack Notice printed in school's calendar Other HA No Material Description Material Location Asbestos Friable Damage Damage Change in Assessment Category Material Material Damage Quantity Units Type Category Quantity Type YES 001 2' x 2' Lay In Ceiling Panels SF X NO 80000 Throughout Facility Miscellaneous Yes None 0 2016 - Fall: No Change Comments: 2017 - Fall: No Change Comments: 2017 - Spring: No Change Comments: 2018 - Spring: No Change Comments: 2018 - Fall: No Change Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	ment Category
01	9" x 9" Black Vinyl Floor Tile - REMOVED					Miscellaneous					YES	X NO
2016 - Fall: N	o Change]							
Comments:	Ü											
2017 - Spring	: No Change											
Comments:	_											
2017 - Fall: N	o Change											
Comments:												
2018 - Spring	: No Change											
Comments:												
2018 - Fall: N	o Change											
Comments:												

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
002	4" Green Vinyl Baseboard	700	LF	1st Floor Corridors, Classrooms, Alcoves & Offices		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	essment Category
003	4" Green Vinyl Baseboard Adhesive	700	LF	1st Floor Corridors, Classrooms, Alcoves & Offices		Miscellaneous	No	None	0		YES	X NO
2016 - Fall:	No Change	<u> </u>	<u> </u>	·	Ī							
Comments:]							
2017 - Sprir	ng: No Change				-							
Comments:												
2017 - Fall:	No Change				=							
Comments:												
2018 - Sprir	ng : No Change											
Comments:												
2018 - Fall:	No Change											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
004	4" Blue Vinyl Baseboard	400	LF	1st Floor Southeast and Southwest Stairways		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

Comments:

005	4" Blue Vinyl Baseboard Adhesive	400	SF	1st Floor Southeast and Southwest Stairways		Miscellaneous	No	None	0	YES	X NO
004C Fall N	In Ohana				7						
2016 - Fall: N	io Change										
Comments:											
2017 - Spring	j: No Change				1						
Comments:											
					1						
2017 - Fall: N	lo Change				1						
Comments:											
					1						
2018 - Spring	j : No Change										
Comments:	-										
2018 - Fall: N	lo Change										
Comments:					1						

Type

Material

Category

Damage

Type

Friable

Damage

Quantity

Damage

Units

Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
006	4" Gray Vinyl Baseboard	800	LF	3rd Floor Corridors, Classrooms, Alcoves & Offices		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No

Material Description

Material

Quantity

Material

Units

007	4" Gray Vinyl Baseboard Adhesive	800	SF	3rd Floor Corridors, Classrooms, Alcoves & Offices		Miscellaneous	No	None	0		YES	X NO
2016 - Fall:	No Change			•	1	•	•	•	•	•	•	
Comments:	140 Change				-							
Comments.					+							
2017 - Sprin	g: No Change											
Comments:												
2017 - Fall:	No Change				-							
Comments:	110 Chango											
]							
2018 - Sprin	g : No Change											
Comments:												
2018 - Fall:	No Change											
Comments:	ito onango				†							
Commente					-							
					_							
HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	sment Category
008	4" Blond Vinyl Baseboard	500	LF	2nd Floor Corridors, Lunchroom, Kitchen, Classrooms, Alcoves & Offices		Miscellaneous	No	None	0		YES	X NO

Material

Category

Asbestos

Type

Friable

Damage

Type

Damage

Quantity

Damage

Units

HA No

Material Description

Material

Units

Material

Quantity

Material Location

Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	essment Category
009	4" Blond Vinyl Baseboard Adhesive	500	SF	2nd Floor Corridors, Lunchroom, Kitchen, Classrooms, Alcoves & Offices		Miscellaneous	No	None	0		YES	X NO
2016 - Fall:	: No Change											
Comments); 											
2017 - Spri	ing: No Change											
Comments	:											
2017 - Fall:	: No Change											
Comments	S :											
2018 - Spri	ing : No Change											
Comments	S :											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
010	1" Light Brown Ceramic Tile Grout	1800	SF	1st, 2nd & 3rd Floor Washrooms		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

2018 - Fall: No Change

Comments:

011	1" Light Brown Ceramic Tile Grout Adhesive	1800	SF	1st, 2nd & 3rd Floor Washrooms		Miscellaneous	No	None	0		YES	X NO
2016 - Fall:	: No Change				7							
Comments												
2017 - Spri	ng: No Change											
Comments	:											
2017 - Fall:	: No Change											
Comments	:											
2018 - Spri	ng : No Change											
Comments	:											
	: No Change											
Comments	:				_							
					_							
HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	sment Category
L			1		+	+	1	+	+	1	1	

Type

Material

Category

Miscellaneous

No

Friable

Damage

Type

Damage

Quantity

0

None

Damage

Units

Change in Assessment Category

30000

SF

HA No

012

Comments:

Comments:

Drywall

2016 - Fall: No Change

2017 - Spring: No Change

Material Description

1" Light Brown Ceramic Tile

Material

Units

Material

Quantity

Material Location

1st, 2nd & 3rd Floor

Throughout Facility

Page 7

YES

X NO

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Ass	sessment Category
013	Drywall Compound	30000	SF	Throughout Facility		Miscellaneous	No	None	0		YES	X NO
2016 - Fall: N	lo Change											
Comments:					_							
2017 - Spring	g: No Change				-							
Comments:												
2017 - Fall: N	No Change											
Comments:												
2018 - Spring	g : No Change											
Comments:												
2018 - Fall: N	lo Change				-							
Comments:												
					_							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
014	12" x 12" Blue/Gray Streaked Floor Tile	2000	SF	1st Floor SE & SW Stairways and Kitchen		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
015	12" x 12" Blue/Gray Streaked Floor Tile Mastic	2000	SF	1st Floor SE & SW Stairways and Kitchen		Miscellaneous	No	None	0		YES X NO
004C Fall N	- Oh										

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
016	12" x 12" Green Mix Floor Tile	3000	SF	Classrooms 110, 111, 112 & 113		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:

017	12" x 12" Green Mix Floor Tile Mastic	3000	SF	Classrooms 110, 111, 112 & 113		Miscellaneous	No	None	0	YES	X NO
2016 Fall N	lo Chango]						
2016 - Fall: N	io Change										
Comments:											
2017 - Fall: N	lo Change										
Comments:											
2017 - Spring	g: No Change										
Comments:	-										
2018 - Fall: N	lo Change										
Comments:											
2018 - Spring	g : No Change										
Comments:	,										
L					ı						

Type

Material

Category

Damage

Type

Friable

Damage

Quantity

Damage

Units

Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
018	12" x 12" Blond Floor Tile	4000	SF	2nd Floor Corridors, Lunchroom, Kitchen, Classrooms, Alcoves & Offices		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No

Material Description

Material

Quantity

Material

Units

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
019	12" x 12" Blond Floor Tile Mastic	4000	SF	2nd Floor Corridors, Lunchroom, Kitchen, Classrooms, Alcoves & Offices		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
020	12" x 12" Gray Mix Floor Tile	10800	SF	2nd & 3rd Floor Classrooms, Corridors, Stairways, Alcoves, Kitchen, Kitchen Office & Cafeteria		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:
<u> </u>

Oracle Unit: 70070

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
021	12" x 12" Gray Mix Floor Tile Mastic	10800	SF	2nd & 3rd Floor Classrooms, Corridors, Stairways, Alcoves, Kitchen, Kitchen Office & Cafeteria		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
022	Quarry Tile Grout	500	SF	1st Floor Corridor		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

023	Duct Sealant	2000	SF	Basement		Miscellaneous	No	None	0		YES	X NO
2016 - Fall: N	o Change											
Comments:												
2017 - Fall: No Change												
Comments:												
2017 - Spring	: No Change											
Comments:												
2018 - Fall: N	o Change											
Comments:												
2018 - Spring	: No Change											
Comments:												
					l							
HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	ment Category

Type

Material

Category

Miscellaneous

Friable

Damage

Type

Damage

Units

Damage

Quantity

0

None

Change in Assessment Category

700

SF

HA No

024

Adhesive

Material Description

Material

Quantity

Material

Units

Material Location

Beneath All Marker

Boards in the Facility

YES

X NO

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	sment Category
25	Carpet Adhesive	1650	SF	Offices, Media Center, Conference Room, 204		Miscellaneous	No	None	0		YES	X NO
2016 - Fall: No Change Comments:												

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	Green, Red and Gray Terrazzo	10000	SF	Entrance, stairwells, and hallways		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	12"x12" White w/Blue Floor Tile	40	SF	Elevator		Miscellaneous	No	None	0		YES X NO
2016 - Fall: No Change											

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28	12"x12" White w/Blue Floor Tile Mastic	40	SF	Elevator		Miscellaneous	No	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
HA-100	2'x4' white ceiling tile	5000	SF	throughout the building		Miscellaneous	Yes	None	0		YES X NO

2016 - Fall: No Change
Comments:
2017 - Spring: No Change
Comments:
2017 - Fall: No Change
Comments:
2018 - Spring : No Change
Comments:
2018 - Fall: No Change
Comments:

ALL LEA Responsibilities, for this school, will be met.

Robert Christlieb

NOTICE TO PARENTS AND STAFF REGARDING THE ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Chicago Military Academy High School
Date: 12/7/2018
This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.
Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2016. Asbestos surveillances are conducted every six months.
CHECK ONE
A copy of this notice was sent home in each child's backpack.
A copy of this notice was printed in the school's newsletter and sent home with each child
A copy of this notice was printed in the school's calendar and sent home with each child
Other.
A COPY OF THIS NOTICE MUST BE PLACED IN THE

VFT = Vinyl Floor Tile
Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

SCHOOL'S ASBESTOS MANAGEMENT PLAN.

Oracle Unit: 70070