

# Chicago Public Schools

## 6 Month Asbestos Surveillance

### 2024 Fall Six Month Survey

**School:** Edward A Bouchet Math & Science Academy ES  
**Address:** 7355 S. Jeffrey Blvd.

**Oracle Unit:** 22371  
**Region:** 05

**Building ID:** 2430  
**Mail Room:** 46

☐ **CHECK HERE IF NO CHANGE TO ASBESTOS**

**Asbestos Surveyor:** Montelione, Anthony  
**Survey Date:** 12/17/2024  
**Email Address:** amontelione@cps.k12.il.us

A copy of the 2022/2023 notice to parents and staff regarding the asbestos management plan notifications was distributed via:

☐ Each child's backpack ☐ Notice printed in school's newsletter ☐ Notice printed in school's calendar ☐ Other |

| HA No | Material Description                     | Material Quantity | Material Units | Material Location  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|--|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03    | 12"x12" Brown w/White Streaks Floor Tile | 15000             | SF             | 1st, 2nd, 3rd & Basement Corridors North Girls' Restroom 1, 2, 3, Basement, Teachers' Restroom 1, 2, 3 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

2022 Fall Six Month Survey: No Change

Comments:

2023 Fall Six Month Survey: No Change

Comments:

2023 Spring Six Month Survey: No Change

Comments:

2024 Spring Six Month Survey: No Change

Comments:

2024 Fall Six Month Survey: No Change

Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

Oracle Unit: 22371

Page 1

| HA No | Material Description                  | Material Quantity | Material Units | Material Location   | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---------------------------------------|-------------------|----------------|---|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03A   | 12"x12" Tan w/Brown Specks Floor Tile | 20700             | SF             | Rooms 001, 002, 004, 005, 100-102, 104-106, 108-110, 200-203, 206-210, 302, 311, 331, Dining Room & Pass Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description             | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03B   | 12"x12" Mottled Beige Floor Tile | 1800              | SF             | Rooms 101 & 205   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

| HA No | Material Description               | Material Quantity | Material Units | Material Location                                  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|------------------------------------|-------------------|----------------|--|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03C   | 12"x12" Off White w/Tan Floor Tile | 7400              | SF             | Rooms 001, 100, 105, 200, 204, 300, 301 & Corridor |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                          | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03D   | 12"x12" Tan w/White & Brown Floor Tile ABATED |                   |                | Room 104          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

| HA No | Material Description             | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03E   | 12"x12" Green Mottled Floor Tile | 250               | SF             | Engineer's Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                      | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03F   | Purple 12"x12" Carpet Mastic NOT OBSERVED |                   |                | Room 108          |               | Miscellaneous     |         | None        |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 04    | Linoleum ABATED      |                   |                | Room 200          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 05    | Green Linoleum       | 2300              | SF             | Gym               |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description | Material Quantity | Material Units | Material Location                                  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|--|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 06    | Vinyl Mopboard       | 500               | LF             | Restrooms throughout, 2nd Floor Corridor, Room 109 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description  | Material Quantity | Material Units | Material Location    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|-----------------------|-------------------|----------------|----------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 07    | Vinyl Mopboard Mastic | 500               | LF             | Restrooms Throughout |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 08    | Fire Doors           | 6                 | EA             | Gym               |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: Abated      |
| Comments:Currently under abatement      |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description          | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|-------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 09    | Incinerator Door NOT OBSERVED |                   |                | Boiler Room       |               | Miscellaneous     |         | None        |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description                 | Material Quantity | Material Units | Material Location                               | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--------------------------------------|-------------------|----------------|---|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 10    | Aircell Pipe Insulation NOT OBSERVED |                   |                | Unexcavated Areas, N & S Heat Plenum, Pump Room |               | TSI               | Yes     |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



| HA No | Material Description                 | Material Quantity | Material Units | Material Location   | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--------------------------------------|-------------------|----------------|---|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 11    | 12"x12" Brown w/White Streaks Mastic | 15000             | SF             | 1st, 2nd, 3rd & Basement Corridors, North Girls' Restroom 1, 2, 3, Basement, Teachers' Restroom 1, 2, 3 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                         | Material Quantity | Material Units | Material Location   | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|---|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 11A   | 12"x12" Tan w/Brown Specks Floor Tile Mastic | 20700             | SF             | Rooms 001, 002, 004, 005, 100-102, 104-106, 108-110, 200-203, 206-210, 302, 311, 331, Dining Room & Pass Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                    | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 11B   | 12"x12" Mottled Beige Floor Tile Mastic | 1800              | SF             | Rooms 101 & 205   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description                      | Material Quantity | Material Units | Material Location                                  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|--|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 11C   | 12"x12" Off-White w/Tan Floor Tile Mastic | 6900              | SF             | Rooms 001, 100, 105, 200, 204, 300, 301 & Corridor |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                      | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 11D   | 12"x12" Tan w/White & Brown Mastic ABATED |                   |                | Room 104          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

| HA No | Material Description                    | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 11E   | 12"x12" Green Mottled Floor Tile Mastic | 250               | SF             | Engineer's Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description   | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 12    | Linoleum Mastic ABATED |                   |                | Room 200          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description                                 | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 13    | 12"x12" Cream w/Beige & Grey Floor Tile NOT OBSERVED | 900               | SF             | Room 200          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                        | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 14    | 12"x12" Brown Vinyl Floor Tile NOT OBSERVED | 2000              | SF             | 2nd & 3rd Floor Corridors |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description                         | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 14M   | 12"x12" Brown Floor Tile Mastic NOT OBSERVED | 2000              | SF             | 2nd & 3rd Floor Corridors |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 15    | 12"x12" Gray Speckled Vinyl Floor Tile NOT OBSERVED | 600               | SF             | Room 108          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description                                 | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 15M   | 12"x12" Gray Speckled Floor Tile Mastic NOT OBSERVED | 600               | SF             | Room 108          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                 | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--------------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 16    | 12"x12" White w/Gray Speckles ABATED |                   |                | Rooms 001, 002, 004 & 005 |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description                         | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 16M   | 12"x12" White w/ Gray Speckles Mastic ABATED |                   |                | Rooms 001, 002, 004 & 005 |               | Miscellaneous     |         |             | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



| HA No | Material Description | Material Quantity | Material Units | Material Location   | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|---------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 17    | Hard Plaster         | 50000             | SF             | Throughout Building |               | Surface           | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description                    | Material Quantity | Material Units | Material Location          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|----------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 18    | 12x12 White, Grey & Blue Mix Floor Tile | 3000              | SF             | CPC- Play Area & Copy Room |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                           | Material Quantity | Material Units | Material Location          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|----------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 18A   | 12x12 White, Grey & Blue Mix Floor Tile Mastic | 3000              | SF             | CPC- Play Area & Copy Room |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

| HA No | Material Description                     | Material Quantity | Material Units | Material Location       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|-------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 19    | 12x12 Beige Blue & Yellow Mix Floor Tile | 2000              | SF             | CPC- Room 136 & Storage |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                            | Material Quantity | Material Units | Material Location       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|-------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 19A   | 12x12 Beige Blue & Yellow Mix Floor Tile Mastic | 2000              | SF             | CPC- Room 136 & Storage |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description                    | Material Quantity | Material Units | Material Location       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|-------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 20    | 12x12 White Green & Blue Mix Floor Tile | 2000              | SF             | CPC- Room 135 & Storage |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                           | Material Quantity | Material Units | Material Location       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|-------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 20A   | 12x12 White Green & Blue Mix Floor Tile Mastic | 2000              | SF             | CPC- Room 135 & Storage |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

| HA No | Material Description                         | Material Quantity | Material Units | Material Location            | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--|-------------------|----------------|------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 21    | 12x12 Grey & White w/Black Specks Floor Tile | 4000              | SF             | CPC- Rooms 133/134 & Storage |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                | Material Quantity | Material Units | Material Location            | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|---|-------------------|----------------|------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 21A   | 12x12 Grey & White w/Black Specks Floor Tile Mastic | 4000              | SF             | CPC- Rooms 133/134 & Storage |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description | Material Quantity | Material Units | Material Location        | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|--------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 22    | Tan Baseboards       | 1200              | LF             | CPC- Throughout Building |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description   | Material Quantity | Material Units | Material Location        | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|------------------------|-------------------|----------------|--------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 22A   | Tan Baseboard Adhesive | 1200              | SF             | CPC- Throughout Building |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 23    | Grey Tile Grout      | 300               | SF             | CPC- Bathrooms    |               | Surface           | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description           | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|--------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03A   | 9"x9" Red Floor Tile<br>ABATED |                   |                | 2nd & 3rd Floor Corridors |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

| HA No | Material Description    | Material Quantity | Material Units | Material Location                            | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|-------------------------|-------------------|----------------|--|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| A     | Aircell Pipe Insulation | 150               | LF             | Kitchen, Basement<br>Corridor, Room 100, 200 |               | TSI               | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| B     | Magblock ABATED      |                   |                | Boiler Room       |               | TSI               |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| G     | Preform ABATED       |                   |                | Boiler Room       |               | TSI               |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



| HA No | Material Description  | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|-----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| H     | Boiler Gaskets ABATED |                   |                | Boiler Rom        |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |

| HA No | Material Description        | Material Quantity | Material Units | Material Location  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category   |
|-------|-----------------------------|-------------------|----------------|--|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| NEW   | Newly Installed Suspect ACM |                   |                | Installed After Implementation of Management Plan or After Renovations |               | Miscellaneous     |         | Unknown     |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|   |
|---|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|   |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|   |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|   |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

*ALL LEA Responsibilities, for this school, will be met.*

A handwritten signature in black ink, appearing to read 'R. Schleyer', written over a horizontal line.

Richard J. Schleyer

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***

NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Edward A Bouchet Math & Science Academy ES

Date: 12/17/2024

---

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2022.  
Asbestos surveillances are conducted every six months.

CHECK ONE

- ☐ A copy of this notice was sent home in each child's backpack.
- ☐ A copy of this notice was printed in the school's newsletter and sent home with each child
- ☐ A copy of this notice was printed in the school's calendar and sent home with each child
- ☐ Other.
- 

A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***