Chicago Public Schools

6 Month Asbestos Surveillance

2024 Fall Six Month Survey

School:	Jonathan Burr Elementary School		Oracle Unit:	22471	Building ID:	2530
Address:	1621 W. Wabansia Avenue		Region:	02	Mail Room:	33
CHECK HERE IF	NO CHANGE TO ASBESTOS	Asbestos Surveyor: Survey Date: Email Address:	Coleman, Timothy 10/29/2024			

	A copy of the2022/20	23 notice to	parents and	I staff regarding the as	sbestos manag	ement plan no	otifications w	as distribute	ed via:			
	Each child's backp	ack	X Notice	printed in school's ne	wsletter	Notice p	rinted in sch	ool's calenda	ar Ot	her		
HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Ass	essment Category
1A	Boiler Jacket	760	SF	Boiler Room		TSI	Yes	None	0		YES	XNO
2022 Fall S Comments	Six Month Survey: No C	hange										
2023 Fall S Comments	Six Month Survey: No C	hange			_							
	g Six Month Survey: No	Change			_							
2024 Fall S	Six Month Survey: Dama Damaged	aged										
	g Six Month Survey: Da :Damaged during repai	-										
·												

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1B	Water Tank Insulation	140	SF	Boiler Room		TSI	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change	
Comments:	
2023 Spring Six Month Survey: No Change	
Comments:	
2023 Fall Six Month Survey: No Change	
Comments:	
2024 Spring Six Month Survey: No Change	
Comments:	
2024 Fall Six Month Survey: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1C	Aircell Pipe Insulation	366	LF	Boiler Room, Tank Room, Engine Room, Fan Room, Kitchen Storage, NW Basement Hall (Pump Room)		TSI	Yes	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

VFT = *Vinyl Floor Tile Friable* = *Can be crumbled, pulverized, or reduced to powder by hand pressure.* Oracle Unit: 22471 Page 2

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1D	MJP E/F/V on Aircell Pipe Insulation	73	FITTING	Boiler Room, Tank Room, Engine Room, Fan Room, Kitchen Storage, NW Basement Hall (Pump Room)		TSI	Yes	None	0		

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1E	Cardboard Pipe Insulation	554	LF	Boiler Room, Tank Room, Engine Room, NW Basement Hallway		TSI	Yes	None	0		

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1F	MJP E/F/V on Cardboard Pipe Insulation	47	FITTING	Boiler Room, Tank Room, Engine Room, NW Basement Hallway (Pump Room)		TSI	Yes	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA N	No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1G		MJP E/F/V on Fiberglass Pipe Insulation	75	FITTING	Enginer Room, Pump Room, Boiler Room		TSI	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03	12" x 12" Off White w/ Speckles VFT	0		Room 002 Closet, Room 308 (Abated)		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
05	12" x 12" Off White w/ Speckles VFT Mastic	0		Room 002 Closet, Room 308 (Abated)		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	0	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
06		Hard Coat Plaster	144000	SF	Throughout - 1st, 2nd, 3rd floors, basement		Surface	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
07	12" x 12" Beige w/ White & Dark Streaks VFT	3750	SF	Auditorium N & S Stair Landings, Rooms 200, 201, 207, 303, 201 washroom, 203, 301, 2nd Floor Teachers & Girls Toilet Rooms. (204 T.O.)		Miscellaneous	No	None	0		

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
07A	12" x 12" Beige w/ White & Dark Streaks VFT Mastic	3750	SF	Auditorium N & S Stair Landings, Rooms 200, 201, 207, 303, 201 washroom, 203, 301, 2nd Floor Teachers & Girls Toilet Rooms. (204 T.O.)		Miscellaneous	No	None	0		

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
08	12" x 12" Light Brown w/ White & Brown Speckles VFT	4950	SF	Rooms 006, 008, 009, Kitchen, 108, Main Office, Prin. Office (not observed), 206, 300, 307, (104 & 204 Tiled Over), 106, 302 closet, 101		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: Abated
Comments:Room 006

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
08A	12" x 12" Light Brown w/ White & Brown Spec VFT Mastic	4950	SF	Rooms 006, 008, 009, Kitchen, 108, Main Office, Prin. Office (not observed), 206, 300, 307, (104 & 204 Tiled Over), 106, 302 closet. 101		Miscellaneous	No	None	0		

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: Abated
Comments:Room 006

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
09	12" x 12" Brown w/ White & Brown Speckles VFT	2600	SF	Rooms 006, 008, 009, Kitchen, 108, Main Office, Prin. Office (not observed), 206, 300, 307, (104 Tiled Over)		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: Abated
Comments:Room 006

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
09A	12" x 12" Brown w/ White & Brown Speckles VFT Mastic	2600	SF	Rooms 006, 008, 009, Kitchen, 108, Main Office, Prin. Office (not observed), 206, 300, 307, (104 Tiled Over)		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: Abated
Comments:Room 006

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	12" x 12" White w/ Dark Speckles VFT	180	SF	1st Floor Women's Toilet		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

VFT = *Vinyl Floor Tile Friable* = *Can be crumbled, pulverized, or reduced to powder by hand pressure.* Oracle Unit: 22471 Page 12

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10A	12" x 12" White w/ Dark Speckles VFT Mastic	180	SF	1st Floor Women's Toilet		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

H	A No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1'	1	12" x 12" Dark Brown w/ White & Orange Speckles VFT	800	SF	Room 007, Break Room		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11A	12" x 12" Dark Brown w/ Orange Speckles VFT Mastic	800	SF	Room 007, Break Room		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	12" x 12" Green w/ White Streaks VFT	1100	SF	Eng. Supply Rm (Store Room), Fan Room, Break Room, Sprinkler Room		Miscellaneous	No	None	0		YES X NO

022 Fall Six Month Survey: No Change
omments:
023 Spring Six Month Survey: No Change
omments:
023 Fall Six Month Survey: No Change
omments:
024 Spring Six Month Survey: No Change
omments:
024 Fall Six Month Survey: No Change
omments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12A	12" x 12" Green w/ White Streaks VFT Mastic	1100	SF	Eng. Supply Rm (Store Room), Fan Room, Break Room, Sprinkler Room		Miscellaneous	No	None	0		

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	12" x 12" Coffee w Dark Streaks NOT OBSERVED	0		Room 002 Toilet NOT OBSERVED		Miscellaneous	No	None			YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13A	12" x 12" Coffee w/ Dark Streaks VFT Mastic NOT OBSERVED	0		Room 002 Toilet NOT OBSERVED		Miscellaneous					

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14	1' x 1' White Ceiling Tile	1800	SF	Auditorium Wall, main office reception area		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Charles Circ Month Current No Change
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	Multi Color Swirl Linoleum	325	SF	Room 204 Closet, 2nd fl. men's toilet		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15A	Multi Color Swirl Linoleum Mastic	325	SF	Room 204 Closet, 2nd fl. men's toilet		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16	Orange Linoleum	0		1st Floor telephone booth (removed from school)		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Caring Civ Month Current No Change
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	C	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16A		Orange Linoleum Mastic	0		1st Floor telephone booth (removed from school)		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17	12" x 12" Light Blue w/ Specks VFT	1600	SF	Room 204 (over HA's 7 & 8), 107 and office		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17A	12" x 12" Light Blue w/ Specks VFT Mastic	1600	SF	Room 204 (over HA's 7 & 8), 107 and office		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

H	A No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18	8	12" x 12" Peach w/ Specks VFT	650	SF	Room 104 (over HA's 8 & 9)		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18A	12" x 12" Peach w/ Specks VFT Mastic	650	SF	Room 104 (over HA's 8 & 9)		Miscellaneous	No	None	0		

2000 Fall Circ Manthe Crimery No. Ob an an
2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
19	12" x 12" Blue w/Light Blue Streaks VFT	980	SF	Room 204 (Closet), 102		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
19A	12" x 12" Blue w/Light Blue Streaks VFT Mastic	980	SF	Room 204 (Closet), 102		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	12" x 12" Blue/Gray with Streaks VFT	1100	SF	Room 308		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20A	12" x 12" Blue/Gray with Streaks VFT Mastic	1100	SF	Room 308		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	12" x 12" Red w/Specks VFT	1600	SF	Room 202		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21A	12" x 12" Red w/Specks VFT Mastic	1600	SF	Room 202		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	Green Carpet Mastic	750	SF	Room 302 (Library) NOT OBSERVED		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24	12" x 12" Plum Floor Tile	1200	SF	Auditoriun		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA N	10	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25		12" x 12" Plum Floor Tile Mastic	1200	SF	Auditorium		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	12" x 12" Lavander Floor Tile	800	SF	Auditorium		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	12" x 12" Lavander Floor Tile Mastic	800	SF	Auditorium		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28	Carpet MASTIC - blue with multi-color specks	400	SF	Principal's office		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
29	12" x 12" Dark blue w/ light blue streaks VFT	1200	SF	Room 002		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

H	A No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
30	0	12" x 12" Dark blue w/ light blue streaks VFT MASTIC	1200	SF	Room 002		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
31	Incinerator Gasket/Insulation	1	SF	Boiler/coal room		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
32	12" x 12" White w/ green & black specks VFT	100	SF	Bsmt corridor & stairwell landing to 1st floor		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
33	12" x 12" White w/ green & black specks VFT MASTIC	100	SF	Bsmt corridor & stairwell to 1st floor		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

ſ	HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
	34	12" x 12" Black w/ green and black specks VFT	100	SF	Bsmt corridor & stairwell landing to 1st floor		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
35	12" x 12" Black w/ green & black specks VFT MASTIC	100	SF	Bsmt corridor & stairwell landing to 1st floor		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
36	12" x 12" Aqua w/ black & white specks VFT	2000	SF	Basement corridors		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	0	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
37		12" x 12" Aqua w/ black & white specks VFT MASTIC	2000	SF	Basement Corridors		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
38	9" x 9" Gray w/ white streaks VFT	2	SF	Auditorium at entry door to crawlspace under stairwell to balcony		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
39	9" x 9" Gray w/ white streaks VFT MASTIC	2	SF	Auditorium at entry door to crawlspace under stairwell to balcony		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA	No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
40		12" x 12" Light Gray w/ Specks VFT	2000	SF	Room 007, 208, and Library / 302		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
40A	12" x 12" Light Gray w/ Specks VFT Mastic	2000	SF	Room 007, 208, and Library / 302		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
41	Drywall System	200	SF	Fan Room near Engineer's Office		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
42	Red Fire Stop	6	LF	Various Locations Throughout Building		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

ALL LEA Responsibilities, for this school, will be met.

Richard J.Schleyer

NOTICE TO PARENTS AND STAFF REGARDING THE ASBESTOS MANAGEMENT PLAN NOTIFICATION

School:	Jonathan Burr Elementary School	

Date: 10/29/2024

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2022.

Asbestos surveillances are conducted every six months.

CHECK ONE

A copy of this notice was sent home in each child's backpack.

X A copy of this notice was printed in the school's newsletter and sent home with each child

A copy of this notice was printed in the school's calendar and sent home with each child

Other.

A COPY OF THIS NOTICE MUST BE PLACED IN THE SCHOOL'S ASBESTOS MANAGEMENT PLAN.