Chicago Public Schools

6 Month Asbestos Surveillance 2024 Fall Six Month Survey

Wendell Smith Elementary School 23641 3870 School: **Oracle Unit: Building ID:** Address: 744 E 103rd Street Region: 06 Mail Room: Asbestos Surveyor: Lietz, Richard X CHECK HERE IF NO CHANGE TO ASBESTOS Survey Date: 11/20/2024 Email Address: rklietz@cps.k12.il.us A copy of the 2022/2023 notice to parents and staff regarding the asbestos management plan notifications was distributed via: Notice printed in school's newsletter X Other cps web site Each child's backpack Notice printed in school's calendar HA No Material Description Material Location Friable Damage Change in Assessment Category Material Asbestos Material Damage Damage Quantity Units Type Category Quantity Type Library (Under Carpet), YES X NO 12x12 Tan & Beige Floor Engineer's Office & 01A 5000 SF Miscellaneous No None 0 Storage Room, 2nd Floor Locker Rooms 2022 Fall Six Month Survey: No Change Comments: 2023 Spring Six Month Survey: No Change Comments: 2023 Fall Six Month Survey: No Change Comments: 2024 Spring Six Month Survey: No Change Comments: 2024 Fall Six Month Survey: No Change

Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Ass	essment Category
01B	12x12 Taupe Specked Floor Tile	600	SF	Park District Area		Miscellaneous	No	None	0		YES	X NO
2022 Fall Six Comments:	Month Survey: No Ch	ange										
2023 Spring S Comments:	Six Month Survey: No	Change			-							
	Month Survey: No Ch	ange										
Comments:												
2024 Spring S	Six Month Survey: No	Change										
Comments:												
	Month Survey: No Ch	ange										
Comments:												

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
01C	12x12 Off-White Speckled Floor Tile ABATED 2012			ABATED 2012		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

01D	12x12 Brown Specked Floor Tile	192	SF	Kitchen Storage		Miscellaneous	No	None	0	YES	X NO
2022 Fall Six	Month Survey: No Ch	2000									
	Month Survey. No Ch	ange									
Comments:											
2023 Fall Six	Month Survey: No Ch	ange									
Comments:	-										
2023 Spring S	Six Month Survey: No	Change									
Comments:	•										
2024 Spring S	Six Month Survey: No	Change									
Comments:											
2024 Fall Six	Month Survey: No Ch	ange									
Comments:	- · · · · · · · · · · · · · · · · · · ·	<u> </u>									
Comments.											
					J						

Type

Material

Category

Damage Quantity Damage

Units

Change in Assessment Category

Damage

Type

Friable

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
05A	12x12 Tan and Beige Floor Tile Mastic	5000	SF	Library (under the carpet), Engineer's Office & Storage Room, 2nd Floor Locker Rooms		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No

Material Description

Material

Quantity

Material

Units

Material Location

05B	12x12 Taupe Specked Floor Tile Mastic	600	SF	Park District Area		Miscellaneous	No	None	0	YES	X NO
					i						
2022 Fall Six	Month Survey: No Cha	ange									
Comments:											
2023 Spring S	Six Month Survey: No	Change									
Comments:											
2023 Fall Six	Month Survey: No Cha	ange									
Comments:											
2024 Spring S	Six Month Survey: No	Change									
Comments:											
2024 Fall Six	Month Survey: No Cha	ange									
Comments:											

Type

Material

Category

Damage

Type

Friable

Damage

Quantity

Damage

Units

Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
05C	12x12 Off-White Speckled Floor Tile Mastic ABATED 2012			ABATED 2012		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No

Material Description

Material

Quantity

Material

Units

Material Location

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	ssment Category
05D	12x12 Brown Speckled Floor Tile Mastic	192	SF	Kitchen Storage		Miscellaneous	No	None	0		YES	X NO
2022 Fall Civ	Month Cuminu No Ch	0000	•	_	1					•		

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
06A	Dark Brown Vinyl Baseboard	390	LF	1st & 2nd Floor Corridors, RR, Perimeter Outside		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	essment Category
06B	Brown Vinyl Baseboard	855	LF	1st Floor Office Area, Gym, Library, 2nd Floor Book Storage Area		Miscellaneous	No	None	0		YES	X NO
2022 Fall Six	Month Survey: No Ch]	•	•	•	•	•					

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
06C	Gray Vinyl Baseboard	124	LF	1st Floor Library Work Room, Kitchen, and Office Near Vault		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessn	nent Category
06D	Black Vinyl Baseboard	58	LF	1st Floor Lecture Room		Miscellaneous	No	None	0		YES	X NO
2022 Fall Six Month Survey: No Change Comments:												

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
, ,
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
07A	Dark Brown Vinyl Baseboard Mastic	390	LF	1st & 2nd Floor Corridors, RR, Perimeter Outside		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessn	nent Category
07B	Brown Vinyl Baseboard Mastic	855	LF	1st Floor Office Area, Gym, Library, 2nd Floor Book Storage Area		Miscellaneous	No	None	0		YES	X NO
2022 Fall Six Month Survey: No Change							-		•	•		

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
07C	Gray Vinyl Baseboard Mastic	124	LF	1st Floor Library Work Room, Kitchen, Office Near Vault		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	sment Category
07D	Black Vinyl Baseboard Mastic	58	LF	1st Floor Lecture Room		Miscellaneous	No	None	0		YES	X NO
2022 Fall Six Month Survey: No Change Comments:												
2023 Fall Six Month Survey: No Change Comments:												

2023 Spring Six Month Survey: No Change Comments:

2024 Spring Six Month Survey: No Change Comments:

2024 Fall Six Month Survey: No Change

Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
08	Drywall	120	SF	1st Floor Health Room- East Wall		Miscellaneous	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11	Furnace Intake Gasket	16	SF	Mechanical Room		TSI	No	None	0		YES X NO
2022 Fall Six	Month Survey: No Ch	ango									

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: Abated
Comments:MEP Project/Good Condition
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: Abated
Comments: Abated in 8 of 2023
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	Drywall Compound	25	SF	1st Floor Health Room- East Wall		Miscellaneous	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	2x2 Lay In Ceiling Panels	1000	SF	1st Floor Office Area		Miscellaneous	Yes	None	0		YES X NO
2022 Fall Six	Month Survey: No Cha	ange									

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2004 Fall Civ Month Convey No Change
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14	Metal Panel Cardboard Insulation	14880	SF	1st & 2nd Floor Classrooms		Miscellaneous	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	12x12 Gray Speckled Floor Tile	600	SF	1st Floor Storage Room & Washrooms Lobby Area (Area used by Park District)		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16	12x12 Grey Speckled Floor Tile Mastic	600	SF	1st Floor Storage Room & Washrooms Lobby Area (Area used by Park District)		Miscellaneous	No	None	0		YES X NO

17	Blue Carpet Mastic ABATED			Room 214 (Abated)		Miscellaneous					YES	X NO
2022 Fall Six	Month Survey: No Ch	ange]							
Comments:	•	<u> </u>										
2023 Fall Six	Month Survey: No Ch	ange			-							
Comments:	•											
2023 Spring	Six Month Survey: No	Change										
Comments:												
2024 Spring	Six Month Survey: No	Change										
Comments:					1							
2024 Fall Six	Month Survey: No Ch	ange										
Comments:					-							
					J							
HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	sment Category
18	12x12 Dark Blue Floor Tile	25000	SF	Throughout Building, 1st & 2nd Floor Classrooms and Corridors		Miscellaneous	No	None	0		YES	X NO

Type

Material

Category

Friable

Damage

Type

Damage

Quantity

Damage

Units

2022 Fall Six Month Survey: No Change	
Comments:	
2023 Fall Six Month Survey: No Change	
Comments:	
2023 Spring Six Month Survey: No Change	
Comments:	
2024 Spring Six Month Survey: No Change	
Comments:	
2024 Fall Six Month Survey: No Change	
Comments:	

HA No

Material Description

Material

Units

Material

Quantity

Material Location

Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	essment Category
19	12x12 Dark Blue Floor Tile Mastic	25000	SF	Throughout Building, 1st & 2nd Floor Classrooms & Corridors		Miscellaneous	No	None	0		YES	X NO
-	•	•	•	•	•	•	•	•	•	•	•	

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	12x12 Light Blue Floor Tile	25000	SF	Throughout Building, 1st & 2nd Floor Classrooms & Corridors		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	12x12 Light Blue Floor Tile Mastic	25000	SF	Throughout Building, 1st & 2nd Floor Classrooms & Corridors		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24	Spray-On Fire Proofing on I-Beams	10000	SF	Throughout Building Above the Ceiling Tiles		Miscellaneous	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25	Blue Stair Treads	660	SF	Stairways		Miscellaneous	No	None	0		YES X NO
2022 Fall Six	Month Survey: No Cha	ange									

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: Repaired
Comments:Good Condition
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25A	Dark Blue Vinyl Stair Tread Adhesive	660	SF	Stairways		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: Repaired
Comments:Good Condition
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	Brown Ceramic Tile Grout	1260	SF	Boys' & Girls' Washrooms and Teachers' Washrooms Throughout Facility		Miscellaneous	No	None	0		YES X NO
2022 Fall Six	Month Survey: No Ch	ange									

2022 Fall Six Month Survey: No Change
2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Chring Civ Month Curvou No Change
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	Brown Ceramic Tile Adhesive	1260	SF	Boys' & Girls' Washrooms and Teachers' Washrooms Throughout Facility		Miscellaneous	No	None	0		YES X NO

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28	Gray Ceramic Wall Tile Grout	1862	SF	1st and 2nd Floor Boys' & Girls' Washrooms, 2nd Floor Multi-Purpose Room		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
<u> </u>

Oracle Unit: 23641

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
29	Gray Ceramic Wall Tile Adhesive	1862	SF	1st and 2nd Floor Boys' & Girls' Washrooms, 2nd Floor Multi-Purpose Room		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
30	1'x1' White Fissured Ceiling Tile	60000	SF	Throughout Facility		Miscellaneous	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
31	Clay Colored Ceramic Tile Grout	1300	SF	Kitchen and Kitchen Locker Room		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
32	Clay Colored Ceramic Tile Adhesive	1300	SF	Kitchen and Kitchen Locker Room		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
33	Gray Carpet Adhesive	3200	SF	Library and Reading Room		Miscellaneous	No	None	0		YES X NO
					1						_

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
34	Gray Ceramic Tile Grout	120	SF	Washrooms by Library & Vestibule		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	essment Category
35	Gray Ceramic Tile Adhesive	120	SF	Washrooms by Library & Vestibule		Miscellaneous	No	None	0		YES	X NO
2022 Fall Six	Month Survey: No Ch											

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
36	Vinyl Tan Wood Floor	4800	SF	Gym		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	ssment Category
37	Plaster	50000	SF	Throughout 1st Floor		Miscellaneous	Yes	None	0		YES	X NO
2022 Fall Si	x Month Survey: No C	hange				•						
Comments:												
2023 Fall Si	x Month Survey: No C	hange										
Comments:												
2023 Spring	Six Month Survey: No	Change										
Comments:												
2024 Fall Si	x Month Survey: No C	hange										
Comments:	,	<u> </u>										
	Six Month Survey: No	Change										
Comments:												

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
А	Cementitious Elbows	75	LF	Mechanical Room		TSI	Yes	None	5		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
C1	Mag Block Pipe Insulation	30	LF	Mechanical Room		TSI	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: Abated
Comments:good Condition/MEP Project
2024 Spring Six Month Survey: Abated
Comments: Abated 8-2023
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
C2	Magblock Joint Insulation	10	LF	Mechanical Engineer Storage		TSI	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: Abated
Comments:Good Condition/MEP project
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: Abated
Comments: Abated 8-2023
· · · · · · · · · · · · · · · · · · ·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
D	Insulation Cloth	4	SF	Mechanical Room		TSI	No	None	0		YES X NO
2022 Fall Six	Month Survey: No Ch]									

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2004 5 11 21 14 14 2
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
F	Cementitious Duct Insulation	300	SF	Mechanical Room and Kitchen Area		TSI	Yes	Loc	3		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
NEW	Newly Installed Suspect ACM			Installed After Implementation of Management Plan and After Renovations		Miscellaneous		Unknown			YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

ALL LEA Responsibilities, for this school, will be met.

Richard J.Schleyer

NOTICE TO PARENTS AND STAFF REGARDING THE ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Wendell Smith Elementary School
Date: 8/1/2024
This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.
Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2022. Asbestos surveillances are conducted every six months.
CHECK ONE
A copy of this notice was sent home in each child's backpack.
A copy of this notice was printed in the school's newsletter and sent home with each child
A copy of this notice was printed in the school's calendar and sent home with each child
X Other. cps web site
A COPY OF THIS NOTICE MUST BE PLACED IN THE

VFT = Vinyl Floor Tile
Oracle Unit: 23641

SCHOOL'S ASBESTOS MANAGEMENT PLAN.