

# Chicago Public Schools

## 6 Month Asbestos Surveillance

### 2024 Fall Six Month Survey

**School:** James Madison Elementary School  
**Address:** 7433 S. Dorchester

**Oracle Unit:** 24301  
**Region:** 05

**Building ID:** 4570  
**Mail Room:** 46

☒ **CHECK HERE IF NO CHANGE TO ASBESTOS**

**Asbestos Surveyor:** Rodgers, Lewis  
**Survey Date:** 11/5/2024  
**Email Address:** lrodgers9@cps.edu

A copy of the 2022/2023 notice to parents and staff regarding the asbestos management plan notifications was distributed via:

☐ *Each child's backpack* ☒ *Notice printed in school's newsletter* ☐ *Notice printed in school's calendar* ☐ *Other*

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
01	9x9 Black VAT ABATED			1938 Building- Corridors		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

Oracle Unit: 24301

Page 1

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
01A	9x9 Tan VAT ABATED			1938 Building- Teachers' Lounge		Miscellaneous		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
01B	9x9 Maroon VAT ABATED			1938 Building- Corridors		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
01C	9x9 White VAT ABATED			1938 Building- Engineer's Office		Miscellaneous		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
01D	9x9 Beige VAT ABATED			Rooms 200, 203, 103, 202, 204		Miscellaneous		None			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
01E	9x9 Black Streaked VAT ABATED			1st & 2nd Floor Corridors, in Patches		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
02	Linoleum Flooring	660	SF	Room 213		Miscellaneous	No		0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
003M	12" x 12" Brown w/Tan Streaks Floor Tile Mastic	3000	SF	Throughout 1st & 2nd Floor Corridors		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03	12x12 Beige Floor Tile- NOT OBSERVED			Office		Miscellaneous	No				<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03A	12x12 Tan Floor Tile-NOT OBSERVED			1938 Building- Room 206 & 208		Miscellaneous	No				<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03B	12x12 White Floor Tile	150	SF	Engineer's Lounge		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03C	12x12 White Floor Tile ABATED			Room 201		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03D	12x12 Salmon Floor Tile ABATED			Room 201		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03E	12x12 Gray VAT ABATED			Room 200		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
06	Brown Vinyl Baseboard	1300	LF	1938 Building-Throughout		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
07	Brown Vinyl Baseboard Mastic	1300	LF	Throughout 1938 Building		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
08	Linoleum Flooring Mastic	660	SF	Room 213		Miscellaneous	No		0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	Carpet Mastic	673	SF	1960 Addition- Room 100		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11	12x12 Beige Floor Tile Mastic NOT OBSERVED			Office		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11A	12x12 Tan Floor Tile Mastic NOT OBSERVED			1938 Building- Room 206 & 208		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11B	12x12 White Floor Tile Mastic	150	SF	Engineer's Lounge		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11C	12x12 White Floor Tile Mastic			Room 201		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11D	12x12 Salmon Floor Tile Mastic			Room 201		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11E	12x12 Gray VAT Mastic			Room 200		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	9x9 Black VAT Mastic			1938 Building- Corridors		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12A	9x9 Tan VAT Mastic			1938 Building- Teachers' Lounge		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12B	9x9 Maroon VAT Mastic			1938 Building- Corridors		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12C	9x9 White VAT Mastic			1938 Building- Engineer's Office		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12D	9x9 Beige VAT Mastic			Rooms 200, 203, 103, 202, 204		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12E	9x9 Black Streaked VAT Mastic ABATED			1st & 2nd Floor Corridors in patches		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	12x12 Tan Floor Tile NOT OBSERVED			Rooms 206 & 208		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13A	12x12 Beige Vinyl Floor Tile NOT OBSERVED			1961 Addition- Room 201, Corridors Across Rooms 100, 101		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14	12x12 Tan Floor Tile Mastic NOT OBSERVED			Rooms 206 & 208		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14A	12x12 Beige Vinyl Floor Tile Mastic NOT OBSERVED			1961 Addition- Room 201, Corridors across Rooms 100, 101		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	Black Baseboard ABATED			1961 Addition- Rooms 100, 101, 103, 201		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16	Black Baseboard Mastic ABATED			1961 Addition- Rooms 100, 101, 103, 201		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17	9x9 Beige VAT ABATED			1961 Addition- Rooms 200A, 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17A	9x9 Crème VAT ABATED			1961 Addition- Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17B	12"x12" Beige Floor Tile	8800	SF	Rooms 100, 101, 103, 200, 201, 202, 203, 204, 206, 208, 210		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17C	12"x12" Yellow Floor Tile	7300	SF	1st & 2nd Floor Corridors		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18	9x9 Beige VAT Mastic ABATED			1961 Addition- Rooms 200A, 203		Miscellaneous		Loc			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18A	9x9 Crème VAT Mastic ABATED			1961 Addition- Room 203		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18B	12"X12" Beige Floor Tile Adhesive	8800	SF	Rooms 100, 101, 103, 200, 201, 203, 204, 206, 208, 210		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18C	12"x12" Yellow Floor Tile Adhesive	7300	SF	1st & 2nd Floor Corridors		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	Orange/Brown Carpet Mastic	900	SF	Modular Building		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	Baseboard	400	LF	Only in Classrooms & Cafeteria		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
22	Baseboard Mastic	400	LF	Only in Classrooms & Cafeteria		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	Drywall	11000	SF	Modular Building-Stairwells & behind Steel Panels		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24	12x12 White Floor Tile	1200	SF	Modular Building-Corridors		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24A	12x12 Brown Floor Tile	1000	SF	Modular Building- Kitchen Area, Gym		Miscellaneous	No		0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24B	12x12 Beige Floor Tile	600	SF	Modular Building- Cafeteria		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24C	9x9 Black Floor Tile ABATED			Modular Building Corridors		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24D	12x12 White Speck Floor Tile	320	SF	Room 001		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25	12x12 White Floor Tile Mastic	1200	SF	Modular Building- Corridors		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25A	12x12 Brown Floor Tile Mastic	1000	SF	Modular Building- Kitchen Area & Gym		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25B	12x12 Beige Floor Tile Mastic	600	SF	Modular Building-Cafeteria		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25C	9x9 Black Floor Tile Mastic ABATED			Modular Building-Corridors		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25D	12x12 White Speck Floor Tile Mastic	320	SF	Room 001		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	2'x4' Ceiling Tile	1200	SF	1938 Building- Corridors		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	2'x4' Ceiling Tile	7500	SF	1961 Addition - Corridors		Miscellaneous	Yes	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
29	9"x9" Off-White w/Red Streaks Floor Tile	200	SF	Engineer's Lounge		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
30	9"x9" Off-White w/Red Streaks Mastic	200	SF	Engineer's Lounge		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
31	Blackboards	4500	SF	Classrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
32	Blackboard Mastic	4500	SF	Classrooms		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
33	Plaster	150000	SF	Main Building		Surface	No		0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
34	Terrazzo Flooring	500	SF	Stairs & Landings on 1st and 2nd Floors		Miscellaneous	No	None	0		<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
CMMI	Cardboard Lagging ABATED			Engineer's Office Restroom, Teachers' Lounge (Abated)		TSI					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
I	Pipe Joints-NOT OBSERVED			Above Ceiling in Modular Building 1st Floor		TSI					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
MD	Cardboard Elbows ABATED			1938 Building- Restroom Pipe Chases, Engineer's Office, Teachers' Restroom (Abated)		TSI					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
NEW	Newly Installed Suspect ACM			Installed After Implementation of Management Plan		Miscellaneous		Unknown			<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

*ALL LEA Responsibilities, for this school, will be met.*

A handwritten signature in black ink, appearing to read 'R. Schleyer', is positioned above a horizontal line.

Richard J. Schleyer

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***

NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: James Madison Elementary School  
Date: 11/5/2024

---

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2022.  
Asbestos surveillances are conducted every six months.

CHECK ONE

- ☐ A copy of this notice was sent home in each child's backpack.
- ☒ A copy of this notice was printed in the school's newsletter and sent home with each child
- ☐ A copy of this notice was printed in the school's calendar and sent home with each child
- ☐ Other.
- 

A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***