## **Chicago Public Schools**

## 6 Month Asbestos Surveillance 2024 Fall Six Month Survey

**Oracle Unit:** 

25231

Address: 5248 S. Sawyer Ave Region: 04 Mail Room: Asbestos Surveyor: Gutierrez, Francisco X CHECK HERE IF NO CHANGE TO ASBESTOS Survey Date: 10/23/2024 Email Address: fgutierrez21@cps.edu A copy of the 2022/2023 notice to parents and staff regarding the asbestos management plan notifications was distributed via: Notice printed in school's newsletter Each child's backpack Notice printed in school's calendar Other HA No Material Description Material Location Asbestos Friable Damage Change in Assessment Category Material Material Damage Damage Quantity Units Type Category Quantity Type YES X NO Hard coat 1918 Building Miscellaneous 2022 Fall Six Month Survey: No Change Comments: 2023 Fall Six Month Survey: No Change Comments: 2023 Spring Six Month Survey: No Change Comments: 2024 Spring Six Month Survey: No Change Comments: 2024 Fall Six Month Survey: No Change Comments:

Sidney Sawyer Elementary School

School:

5710

Building ID:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	ssment Category
2	9" x 9" Beige Floor Tile	1700	SF	Throughout 1900 Building - Classrooms		Miscellaneous	No	Loc	600	SF	YES	X NO
2022 Fall S	Six Month Survey: No C	hange			]							
Comments	S:	•			1							
2023 Fall S	Six Month Survey: No C	hange			=							
Comments	S:	-			1							
2023 Sprin	2023 Spring Six Month Survey: No Change											
Comments	S:											
2024 Spring Six Month Survey: No Change												
Comments:					1							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
3	12" x 12" Brown Floor Tile		SF	Throughout 1900 Building - Classrooms 301, 302, 303, 304, 306, 203		Miscellaneous				SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

2024 Fall Six Month Survey: No Change

Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	sment Category
4	2' x 4' Drop Ceiling			Main Office (106) and Library (004)		Miscellaneous					YES	X NO
	Month Survey: No C	hange										
Comments:		_										
2023 Fall Six	Month Survey: No C											
Comments:												
2023 Spring	Six Month Survey: No	Change			=							
Comments:												
2024 Spring	Six Month Survey: No	Change										
Comments:												
2024 Fall Six	Month Survey: No C	hange			-							
Comments:	•	<del>-</del>										

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
5	Linoleum		SF	Office and Room 211, 311		Miscellaneous				SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
· · · · · · · · · · · · · · · · · · ·

HA No

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	essment Category
6	Fire doors	21	SF	1900 Building- Basement (across from room B3)		Miscellaneous	No	None	0	SF	YES	X NO
2022 Fall Six Month Survey: No Change Comments:												
2023 Fall Six Month Survey: No Change Comments:												

2023 Spring Six Month Survey: No Change Comments:

2024 Spring Six Month Survey: No Change
Comments:

2024 Fall Six Month Survey: No Change

Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8	12" x 12" Floor Tile Mastic	10000	SF	Throughout 1900 Building - Classrooms		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	sment Category
9	Linoleum adhesive		SF	Office and room 211, 311		Miscellaneous				SF	YES	X NO
2022 Fall Six	Month Survey: No Ch	ange			]							
Comments:	•	•			]							
2023 Fall Six	Month Survey: No Ch	ange										
Comments:	•	-			]							
2023 Spring S	Six Month Survey: No	Change			}							
Comments:												
2024 Spring S	Six Month Survey: No	Change										
Comments:												
2024 Fall Six	Month Survey: No Ch	ange			-							
Comments:	•											
					]							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	9" x 9" Green Floor Tile Mastic			Throughout 1918 Building, Room 102		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessr	nent Category
11	12" x 12" Beige Floor Tile Mastic	10000	SF	Throughout 1918 Building		Miscellaneous	No	None	0	SF	YES	X NO
	Month Survey: No Ch	ange			]							
Comments:												
2023 Fall Six	Month Survey: No Ch	ange										
Comments:	•	•										
2023 Spring S	Six Month Survey: No	Change										
Comments:	•											
2024 Spring S	Six Month Survey: No	Change										
Comments:	,											
2024 Fall Six	Month Survey: No Ch	ange										
Comments:												

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	9" x 9" Green Floor Tile		SF	Throughout 1918 Building, Room 102		Miscellaneous				SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

Page 6

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in A	ssessment Category
13	12" x 12" Beige Floor Tile	10000	SF	Throughout 1918 Building		Miscellaneous	No	None	0	SF	YES	X NO
2022 Fall S	Six Month Survey: No Ch	ange										
Comments	:	<u> </u>										
2023 Fall S	Six Month Survey: No Ch	ange										
Comments	:											
2023 Sprin	g Six Month Survey: No	Change										
Comments	:											
	g Six Month Survey: No	Change										
Comments	:											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14	9" x 9" Beige Floor Tile Mastic	1700	SF	Throughout 1900 Building - Classrooms		Miscellaneous	No	Loc	600	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

2024 Fall Six Month Survey: No Change

Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	essment Category
15	9" x 9" Multi-Color Floor Tile			Room 207		Miscellaneous					YES	X NO
2022 Fall Six Comments:	Month Survey: No Ch	nange										
	Month Survey: No Ch	nange										
Comments:												
	Six Month Survey: No	Change										
Comments:												
2024 Spring S	Six Month Survey: No	Change										
Comments:	•											
2024 Fall Six	Month Survey: No Ch	nange										
Comments:												

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16	9" x 9" Multi-Color Floor Tile Mastic			Room 207		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

		Quantity	Units		Туре	Category	Туре	Quantity	Units		
17	12" x 12" Light Gray and Beige Floor Tile		SF	Room 202		Miscellaneous			SF	YES	X NO
2022 Fall Six	Month Survey: No Ch	ange									
Comments:					-						
2023 Fall Six	Month Survey: No Ch	ange			_						
Comments:					 						
2023 Spring	Six Month Survey: No	Change									
Comments:					-						
2024 Spring	Six Month Survey: No	Change			-						
Comments:											
2024 Fall Six	Month Survey: No Ch	ange									
Comments:		-			1						

Material

Damage

Friable

Damage

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18	12" x 12" Light Gray and Beige Floor Tile Mastic			Room 202		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change Comments:  2023 Fall Six Month Survey: No Change Comments:  2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change Comments:	
2023 Fall Six Month Survey: No Change Comments:  2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	2022 Fall Six Month Survey: No Change
Comments:  2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	Comments:
Comments:  2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	
2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	2023 Fall Six Month Survey: No Change
Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	Comments:
Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	
2024 Spring Six Month Survey: No Change Comments: 2024 Fall Six Month Survey: No Change	2023 Spring Six Month Survey: No Change
Comments: 2024 Fall Six Month Survey: No Change	Comments:
Comments: 2024 Fall Six Month Survey: No Change	
2024 Fall Six Month Survey: No Change	2024 Spring Six Month Survey: No Change
	Comments:
Comments:	2024 Fall Six Month Survey: No Change
	Comments:

HA No

Material Description

Material

Material Material Location

Damage Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	sment Category
19	Blue carpet adhesive - removed			Library (Basement)		Miscellaneous					YES	X NO
2022 Fall Six	Month Survey: No Cl	nange			7							
Comments:												
2023 Fall Six	Month Survey: No Cl	nange										
Comments:												
2023 Spring	Six Month Survey: No	Change										
Comments:					4							
2024 Spring	Six Month Survey: No	Change										
Comments:					4							
	Month Survey: No Cl	nange										
Comments:					4							
L					_							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	12" x 12" Light Beige w/ Dark Beige & White Specks Floor Tile	800	SF	Room 207, 208,		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	12" x 12" Beige w/ Dark Beige & White Specks Floor Tile	800	SF	Room 207, 208		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
22	Mastic Associated w/ 12" x 12" Beige and Light Beige Floor Tile (HA's 20 & 21)	800	SF	Room 207, 208		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	12" x 12" Beige Floor Tile	500	SF	Room 110		Miscellaneous	No	None	0	SF	YES X NO
					1						

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
0004 0 1 0 1 0 1 0
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24	12" x 12" Brown Floor Tile Mastic	500	SF	Room 110		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25	Wood flooring	13200	SF	301, 005, 303, 304, 311, 310, 305, 209, 206, 204, 203, Gym (1900 Building), 202, 201, Auditorium Balcony, Stage, 101, 103, 112, 111, 109, 108, Teacher's Lounge, Teacher's Lounge Storage Room, 004		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	12" x 12" Off-White w/Beige Streaks Floor Tile	500	SF	Rooms 302, 210		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	Mastic for 12" x 12" Off- White w/Beige Floor Tile	500	SF	Rooms 302, 210		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28	Chalkboard/whiteboard adhesive	3100	SF	Rooms 301, 302, 303, 304, 311, 310, 207, 208, 206, 210, 211, 204, 203, 202, 201, 103, 104, 111, 109, 108, 107		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
29	Blue speckled laminate sheet flooring	950	SF	Rooms 311, 211		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	ssment Category
30	Mastic for Blue Speckled Laminate Sheet Flooring	950	SF	Rooms 311, 211		Miscellaneous	No	None	0	SF	YES	X NO
2022 Fall Six Comments:	( Month Survey: No Ch	ange										
	Month Survey: No Ch	ange										
Comments:												
2023 Spring	Six Month Survey: No	Change										
Comments:												
2024 Spring	Six Month Survey: No	Change										
Comments:												
2024 Fall Six	Month Survey: No Ch	ange										
Comments:	,											

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
31	2'x4' fissured ceiling tile	450	SF	Room 209		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
32	Mastic for Blue/Gray Carpet	400	SF	Room 205		Miscellaneous	No	None	0	SF	YES X NO
2022 Fall Six Comments:	Month Survey: No Cha	ange									

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
33	12" x 12" Off-White w/White Streaks Floor Tile	500	SF	Room 102		Miscellaneous	No	Loc	3	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
34	Mastic for 12" x 12" Off- White w/White Streaks Floor Tile	500	SF	Room 102		Miscellaneous	No	Loc	3	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
35	2'x2' fissured ceiling tile	300	SF	Rooms 112, 002		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
36	12" x 12" Beige w/Brown Streaks Floor Tile	400	SF	Rooms 104, 110		Miscellaneous	No	Dist	13	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
37	Mastic for 12" x 12" Beige w/Brown Streaks Floor Tile	400	SF	Rooms 104, 110		Miscellaneous	No	Loc	8	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
· · · · · · · · · · · · · · · · · · ·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
38	12" x 12" Gray and Brown Streaks w/White Floor Tile	250	SF	Room 110		Miscellaneous	No	Loc	5	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
39	Mastic for 12" x 12" Gray and Brown Streaks w/White Floor Tile	250	SF	Room 110		Miscellaneous	No	Loc	5	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

Page 20

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
40	Blue carpet adhesive	200	SF	Room 106		Miscellaneous	No	None	0	SF	YES X NO
2022 Fall Six Month Survey: No Change											

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2004 Fall Civ Month Curvey No Change
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
41	Gray laminate sheet flooring	150	SF	Room 106		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
42	Mastic for Gray Laminate Sheet Flooring	150	SF	Room 106		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
43	12" x 12" Beige w/Gray Streaks Floor Tile	400	SF	Room 107		Miscellaneous	No	Loc	3	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
· · · · · · · · · · · · · · · · · · ·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
44	Mastic for 12" x 12" Beige w/Gray Streaks Floor Tile	400	SF	Room 107		Miscellaneous	No	Loc	3	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

Oracle Unit: 25231

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
45	2' x 4' Fissured Ceiling Tile (2x2 Look)	25000	SF	Teacher's Lounge (1900s Building), 333, 332, 334, 335, 330, 331, 328, 326, 324, 329, 327, 322, 325, 320, 225, 220, 221, 224, 226, 233, 228, 235, 140, 136, 141, 134, 137, 135, 133, Main Office (New Building), Assistant Principal's Office (New Building), Principal's Office (New Building), Main Office (New Building), Main Office Restroom (New Building), 132, 131, 130, 133, 129, 128		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
46	12" x 12" White w/Gray Streaks Floor Tile	7800	SF	Rooms 334, 335, 332, 333, 330, 331, 328, 326, 324, 327, 322, 325, 320, 225, 222, 222 Storage Room, 227, 229, 231, 224, 226, 233, 228, 235, 140, 138, 136, 141, 134, Main Office Workroom, 133, 132, 131, 130, 128		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
<u> </u>

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
47	Mastic for 12" x 12" White w/Gray Streaks Floor Tile	7800	SF	Rooms 334, 335, 332, 333, 330, 331, 328, 326, 324, 327, 322, 325, 320, 225, 222, 222 Storage Room, 227, 229, 231, 224, 226, 233, 228, 235, 140, 138, 136, 141, 134, Main Office Workroom, 133, 131, 132, 130, 128		Miscellaneous	No	None	0	SF	YES X NO

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
48	12" x 12" Dark Green w/White Specks Floor Tile	2500	SF	Rooms 334, 331, 326, 325, 320, 225, 231, 228, 138, 132		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
49	Mastic for 12" x 12" Dark Green w/White Specks Floor Tile	2500	SF	Rooms 334, 331, 326, 325, 320, 225, 231, 228, 138, 132		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
50	12" x 12" Dark Blue w/White Specks Floor Tile	2500	SF	Rooms 335, 330, 329, 322, 229, 224, 235, 140, 141, 134, 128		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
51	Mastic for 12" x 12" Dark Blue w/White Specks Floor Tile	2500	SF	Rooms 335, 330, 329, 322, 229, 224, 235, 140, 141, 134, 128		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
52	12" x 12" Yellow w/White Streaks Floor Tile	2500	SF	Rooms 332, 333, 324, 327, 227, 226, 233, 136, 130		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
Comments.
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
53	Mastic for 12" x 12" Yellow w/White Streaks Floor Tile	2500	SF	Rooms 332, 333, 324, 327, 227, 226, 233, 136, 130		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
54	Mastic for Dark Multi- Coloured Carpet	3000	SF	Rooms 220, 222, 223, 135, 137, Main Office, Assistant Principal's Office, Principal's Office, 129		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
А	Aircell pipe insulation	750	LF	Throughout 1918 Building		TSI	Yes	Loc	1	LF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in A	ssessment Category
В	Aircell pipe insulation joints	75	LF	Throughout 1918 Building		TSI	Yes	None	0	LF	YES	X NO
2022 Fall Six	Month Survey: No Ch	ange			]							
Comments:												
2023 Fall Six	Month Survey: No Ch	ange			-							
Comments:	•	- C										
2023 Spring	Six Month Survey: No	Change			-							
Comments:	,	J										
2024 Fall Six	Month Survey: No Ch	ange			_							
Comments:	,	<u> </u>										
2024 Spring	Six Month Survey: No	Change										
Comments:												
					J							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
С	Cardboard pipe insulation	150	LF	Throughout 1900 Building		TSI	Yes	None	0	LF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

Page 31

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	ssment Category
D	Cardboard pipe insulation joints	15	LF	Throughout 1900 Building		TSI	Yes	None	0	LF	YES	X NO
2022 Fall Six	Month Survey: No Ch	ange			]							
Comments:	•											
2023 Fall Six	Month Survey: No Ch	ange			-							
Comments:												
2023 Spring	Six Month Survey: No	Change			-							
Comments:												
2024 Fall Six	Month Survey: No Ch	ange			-							
Comments:												
2024 Spring	Six Month Survey: No	Change			-							
Comments:												
					1							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
Е	Aircell duct wrap			Boy's Play Room 1900 Building		TSI					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	ssment Category
G	Fiberglass joints			Throughout 1918 Building		TSI					YES	X NO
2022 Fall Six	Month Survey: No Ch	nange			]							
Comments:	•											
2023 Fall Six	Month Survey: No Ch	nange										
Comments:												
2023 Spring	Six Month Survey: No	Change			_							
Comments:					=							
2024 Fall Six	Month Survey: No Ch	nange										
Comments:					=							
	Six Month Survey: No	Change										
Comments:					=							
					J							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
Н	Boiler gaskets	15	SF	Boiler Room		Miscellaneous	Yes	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
I	Boiler covering	750	SF	Boiler Room		TSI	Yes	None	0	SF	YES X NO
2022 Fall Six Month Survey: No Change											

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
J	Tank covering	600	SF	Engine and Tank Room		TSI	Yes	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
K	Aircell pipe insulation	750	LF	Throughout 1900 Building		TSI	Yes	None	0	LF	X YES NO

2022 Fall Six Month Survey: Abated	
Comments:North End Garden Level outside boys bathroom.	Steam and
Condesate line were abated. Roughly 6 ft was abated in the c	orner.
Fiberglass was replaced after repair	
2023 Fall Six Month Survey: No Change	
Comments:	
2023 Spring Six Month Survey: No Change	
Comments:	
2024 Fall Six Month Survey: No Change	
Comments:	
2024 Spring Six Month Survey: No Change	
Comments:	

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessm	ent Category
L	Aircell pipe insulation joints	75	LF	Throughout 1900 Building		TSI	Yes	None	0	LF	YES	X NO
2022 Fall Six	Month Survey: No Ch	ange			]							
Comments:	-											
2023 Spring S	Six Month Survey: No	Change										
Comments:		<u> </u>			1							
2023 Fall Six	Month Survey: No Ch	ange										
Comments:												
2024 Spring S	Six Month Survey: No	Change										
Comments:												
2024 Fall Six	Month Survey: No Ch	ange										
Comments:	•											
					J							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
М	Cardboard pipe insulation			Throughout 1918 Building		TSI					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	sment Category
N	Cardboard joints			Throughout 1918 Building		TSI					YES	X NO
2022 Fall Six	Month Survey: No Ch	nange			]			•	•	•		
Comments:					=							
2023 Spring	Six Month Survey: No	Change			-							
Comments:		•										
2023 Fall Six	Month Survey: No Ch	nange										
Comments:												
2024 Spring	Six Month Survey: No	Change										
Comments:	•	-			- -							
2024 Fall Six	Month Survey: No Ch	nange			-							
Comments:	,	<u> </u>										
					J							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
0	Fiberglass joints	30	LF	Throughout 1900 Building		TSI	Yes	None	0	LF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	ssment Category
Р	Incinerator insulation - removed			Boiler Room		TSI					YES	X NO
2022 Fall S	Six Month Survey: No C	hange										
2023 Fall S Comments	Six Month Survey: No C	hange										
	g Six Month Survey: No	Change										
Comments	<u>:</u>											
2024 Fall S	Six Month Survey: No C	hange										
Comments	:											
2024 Sprin	g Six Month Survey: No	Change										
Comments												

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
Q	12" x 12" Blue Mix Floor Tile	1000	SF	1900 BLDG- Room B-1, Room 305, 306, 001, 001 Storage Room		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
R	12" x 12" Blue Mix Floor Tile Mastic	1000	SF	1900 BLDG-Room B-1, Room 305, 306, 001, 001 Storage Room		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
S	12" x 12" Yellow Mix Floor Tile	1000	SF	1900 BLDG- Room B-1, Room 305, 306, 001		Miscellaneous	No	None	0	SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	ssment Category
Т	12" x 12" Yellow Mix Floor Tile Mastic	1000	SF	1900 BLDG-Room B-1, Room 305, 306, 001		Miscellaneous	No	None	0	SF	YES	X NO
2022 Fall Six	Month Survey: No Ch	ange			]							

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
U	12" x 12" Beige Mix Floor Tile		SF	1918 BLDG Room 206, 208		Miscellaneous				SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	sment Category
V	12" x 12" Beige Mix Floor Tile Mastic		SF	1918 BLDG Room 206, 208		Miscellaneous		71		SF	YES	X NO
2022 Fall Six Comments:	Month Survey: No Cha	ange										

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
, ,
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
W	12" x 12" Brown Mix Floor Tile		SF	1918 BLDG- Room 206, 208		Miscellaneous				SF	YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	ssment Category
Х	12" x 12" Brown Mix Floor Tile Mastic		SF	1918 BLDG- Room 206, 208		Miscellaneous				SF	YES	X NO
2022 Fall S Comments:	ix Month Survey: No Ch	nange				•						
2023 Fall S Comments:	ix Month Survey: No Ch	nange										
		01			_							
Comments:	g Six Month Survey: No	Change										
2024 Fall S	ix Month Survey: No Ch	nange										
Comments:												
	g Six Month Survey: No	Change										
Comments:												

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
Υ	9" x 9" Dark Brown w/Beige Streaks Floor Tile			1900 BLDG - Room 007 by Lunchroom		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
Z	9" x 9" Dark Brown w/Beige Streaks Floor Tile Mastic			1900 BLDG Room 007 by Lunchroom		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

Oracle Unit: 25231

ALL LEA Responsibilities, for this school, will be met.

Richard J.Schleyer

## NOTICE TO PARENTS AND STAFF REGARDING THE ASBESTOS MANAGEMENT PLAN NOTIFICATION

	Sidney Sawyer Elementary School
Date: 1	10/23/2024
the Asbestos	tify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of s Management Plan is available at each school during school hours by appointment. review the Asbestos Management Plan must be made at least 24 hours in advance.
The last insp	be advised that CPS conducts asbestos inspections of all Schools every three years. Dection was completed in 2022. Irveillances are conducted every six months.
CHECK ONE	
A cop	by of this notice was sent home in each child's backpack.
A cop	by of this notice was printed in the school's newsletter and sent home with each child
A cop	by of this notice was printed in the school's calendar and sent home with each child
Other	r.
	OF THIS NOTICE MUST BE PLACED IN THE DOL'S ASBESTOS MANAGEMENT PLAN.