## **Chicago Public Schools**

## 6 Month Asbestos Surveillance 2024 Fall Six Month Survey

James Wadsworth Elementary School 25711 6890 School: **Oracle Unit: Building ID:** Address: 6650 S. Ellis Region: 05 Mail Room: Asbestos Surveyor: Aviles, Abraham X CHECK HERE IF NO CHANGE TO ASBESTOS Survey Date: 12/19/2024 Email Address: A copy of the 2022/2023 notice to parents and staff regarding the asbestos management plan notifications was distributed via: Notice printed in school's newsletter Each child's backpack Notice printed in school's calendar Other HA No Material Description Material Location Friable Damage Change in Assessment Category Material Asbestos Material Damage Damage Quantity Units Type Category Quantity Type Corridors and YES 02 SF X NO Acoustic Plaster 5200 No None 0 Surface Classrooms Throughout 2022 Fall Six Month Survey: No Change Comments: 2023 Fall Six Month Survey: No Change Comments: 2023 Spring Six Month Survey: No Change Comments: 2024 Spring Six Month Survey: No Change Comments: 2024 Fall Six Month Survey: No Change Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	sment Category
05	9x9 Beige Floor Tile- (Partially Removed) - NOT OBSERVED			Rooms 114, 163, Lunchroom, Office		Miscellaneous					YES	X NO
2022 Fall Six Month Survey: No Change Comments:											•	

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
06	12x12 Off-White w/Brown Floor Tile	600	SF	1st Floor Corridor off Lunchroom, Room 304		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	sment Category
07	9x9 Beige Floor Tile Mastic NOT OBSERVED			Rooms 114 & 163, Lunchroom, Office		Miscellaneous					YES	X NO
2022 Fall Six	Month Survey: No Ch	ange										
Comments:												
2023 Fall Six	Month Survey: No Ch	ange										
Comments:												
2023 Spring	Six Month Survey: No	Change										
Comments:												
2024 Spring	Six Month Survey: No	Change										
Comments:												
2024 Fall Six	Month Survey: No Ch	ange										

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
08	12x12 Off-White w/Pink Floor Tile Mastic	600	SF	1st floor Corridor off Lunchroom, Room 304		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
09	12x12 White Floor Tile	10000	SF	Gym, 3rd Floor Corridor, Rooms 301, 303, 201, 207, 208, 211 & 3rd Floor Teachers' Lounge		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	ment Category
09A	12x12 Dark & Light Blue Floor Tile	14600	SF	Lunchroom, Rooms: 214, 212, 210, 209, 205, 206, 202, 201, 302, 305, 306, 308, 314, 307, 309, 310, 311, 312, 313, Main Office		Miscellaneous	No	None	0		YES	X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	12x12 White Floor Tile Mastic	10000	SF	Gym, 3rd Floor Corridor, Rooms 301, 303, 201, 207, 208, 211 & 3rd Floor Teachers' Lounge		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10A	12x12 Dark & Light Blue Floor Tile Mastic	14600	SF	Lunchroom, 214, 212, 210, 209, 205, 206, 202, 201, 306, 308, 314, 307, 309, 310, 311, 312, 313, Main Office		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11	9x9 Dark Beige Floor Tile - NOT OBSERVED			2nd Floor Corridor		Miscellaneous		None			YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

	HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Catego	ry
	11A	12x12 Dark & Light Pink Floor Tile (Checkerboard pattern)	3052	SF	2nd Floor Corridor		Miscellaneous	No	None	0		YES X NO	
ı	2022 Fall Six	Month Survey: No Ch	ango	·		]							

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	9x9 Dark Beige Floor Tile Mastic- Not Observed			2nd Floor Corridor		Miscellaneous		None			YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12A	12x12 Dark & Light Pink floor Tile Mastic	3052	SF	2nd Floor Corridor		Miscellaneous	No	None	0		YES X NO
2022 Fall Six	2022 Fall Six Month Survey: No Change										

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	9x9 Dark Brown Floor Tile- Not Observed			2nd Floor Corridor, Room 206		Miscellaneous		None			YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	essment Category
14	9x9 Dark Brown Floor Tile Mastic- Not Observed			2nd Floor Corridor, Room 206		Miscellaneous					YES	X NO
2022 Fall Six	Month Survey: No Ch	ange			]							
Comments:		<b>3</b> -										
2023 Fall Six	Month Survey: No Ch	ange										
Comments:												
2023 Spring	Six Month Survey: No	Change										
Comments:					 							
2024 Spring	Six Month Survey: No	Change										
Comments:					 							
2024 Fall Six	Month Survey: No Ch	ange										
Comments:	·			<u> </u>	  -							
					J							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	Interior Window Caulk ABATED			Throughout School		Miscellaneous		None			YES X NO

2022 Fall Six Month Survey: No Change Comments:  2023 Fall Six Month Survey: No Change Comments:  2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change Comments:	
2023 Fall Six Month Survey: No Change Comments:  2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	2022 Fall Six Month Survey: No Change
Comments:  2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	Comments:
Comments:  2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	
2023 Spring Six Month Survey: No Change Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	2023 Fall Six Month Survey: No Change
Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	Comments:
Comments:  2024 Spring Six Month Survey: No Change Comments:  2024 Fall Six Month Survey: No Change	
2024 Spring Six Month Survey: No Change Comments: 2024 Fall Six Month Survey: No Change	2023 Spring Six Month Survey: No Change
Comments: 2024 Fall Six Month Survey: No Change	Comments:
Comments: 2024 Fall Six Month Survey: No Change	
2024 Fall Six Month Survey: No Change	2024 Spring Six Month Survey: No Change
	Comments:
Comments:	2024 Fall Six Month Survey: No Change
	Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16	Blue Carpet Mastic	1176	SF	Room 203, Library		Miscellaneous	No	None	0		YES X NO
2022 Fall Six	2022 Fall Six Month Survey: No Change										

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17	12x12 Beige (Brown) w/Tan Specks	42	SF	3rd Floor Men's Washroom		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

18	12x12 Beige (Brown) w/Tan Specks Mastic	42	SF	3rd Floor Men's Washroom		Miscellaneous	No	None	0	YES	X NO
2022 Fall Six	Month Survey: No Ch	ange			1						
Comments:	William Garvey. 140 On	arige									
					†						
2023 Fall Six	Month Survey: No Cha	ange									
Comments:											
0000 0	Circ Marath Commercia Na	Ob			1						
	Six Month Survey: No	Cnange									
Comments:					_						
2024 Spring	Six Month Survey: No	Change			-						
Comments:											
	Month Survey: No Ch	ange									
Comments:											
1											

Asbestos

Type

Material

Category

Damage Type

Friable

Damage Quantity Damage

Units

Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
19	12x12 Light Pink/Beige w/Pink Specks Floor Tile	7882	SF	1st Floor Corridor, Room 101, Counseling, 105, 108, 110, 106, 104a, 104b		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No

Material Description

Material

Quantity

Material

Units

Material Location

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	12x12 Light Pink/Beige w/Pink Specks Mastic	7882	SF	1st Floor Corridor, Rooms: 101, Counseling Room, 105, 108, 110, 106, 104a, 104b		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
0004 5 11 01 14 11 0 11 11 11
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	12x12 White w/Blue Specks Floor Tile ABATED			Rooms 107 & 109		Miscellaneous			0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asses	ssment Category
22	12x12 White w/Blue Specks Floor Tile Mastic ABATED			Rooms 107 & 109		Miscellaneous					YES	X NO
2022 Fall Six	Month Survey: No Ch	ange										
Comments:												
2023 Spring	Six Month Survey: No	Change										
Comments:					_							
2023 Fall Six	Month Survey: No Ch	ange										
Comments:					_							
2024 Fall Six	Month Survey: No Ch	ange										
Comments:					_							
2024 Spring	Six Month Survey: No	Change										

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	12x12 Floor Tile	20	SF	Lunchroom		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24	Black Undercoating on Sink	400	SF	Rooms 103, 106, 107, 108, 109, 210		Miscellaneous	No	None	0		YES X NO
					1						

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25	12"x12" Green w/Speckles Vinyl Floor Tile	800	SF	Lunchroom, Office, Kitchen		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25A	12"x12" Green w/Speckles Vinyl Floor Tile Mastic	800	SF	Lunchroom, Office, Kitchen		Miscellaneous	No	None	0		YES X NO
2022 Fall Six	Month Survey: No Ch	ange									

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	12"x12" Beige Floor Tile	500	SF	Room 201		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26A	12"x12" Beige Floor Tile Mastic	500	SF	Room 201		Miscellaneous	No	None	0		YES X NO
2022 Fall Six	Month Survey: No Ch	ange									

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	12"x12" Blue/Light Blue Floor Tile	1000	SF	Lunchroom		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Cate	gory
27A	12"x12" Blue/Light Blue Floor Tile Mastic	1000	SF	Lunchroom		Miscellaneous	No	None	0		YES X NO	
2022 Fall Six	Month Survey: No Cha	ange										

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28	Terrazzo Floor Tile	200	SF	Main Entrance, Stairs & Landings		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28A	Terrazzo Floor Tile Mastic	200	SF	Main Entrance, Stairs & Landings		Miscellaneous	No	None	0		YES X NO
2022 Fall Six	Month Survey: No Ch	ango									

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
29	12"x12" Blue/Grey Floor Tile	1000	SF	Room 107, 109 & 110		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

		Quantity	Units		Туре	Category		Туре	Quantity	Units		
29A	12"x12" Blue/Grey Floor Tile Mastic	1000	SF	Rooms 107, 109 & 110		Miscellaneous	No	None	0		YES	X NO
2022 Fall Six	Month Survey: No Ch	ange										
Comments:												
2023 Fall Six	Month Survey: No Ch	ange										
Comments:												
2023 Spring S	Six Month Survey: No	Change										
Comments:												
2024 Spring S	Six Month Survey: No	Change										
Comments:												
2024 Fall Six	Month Survey: No Ch	ange										

Asbestos

Material

Damage

Friable

Damage

Material Material Location

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
А	Duct Manifold ABATED			Fan Room, Mechanical Room (Abated)		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No

Comments:

Material Description

Material

Damage Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assess	sment Category
В	Fiberglass Joint Compound ABATED			Boiler Room, Fan Room, Pump Room, Toilet Chases, Unexcavated Areas (Abated)		TSI					YES	X NO
2022 Fall Six	Month Survey: No Ch	ange			1							
Comments:	,											
2023 Spring	Six Month Survey: No	Change										
Comments:												
2023 Fall Six	Month Survey: No Ch	ange										
Comments:												
2024 Spring	Six Month Survey: No	Change										
Comments:												
2024 Fall Six	Month Survey: No Ch	ange										

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
С	Header Insulation- ABATED			Pump Room		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

Comments:

Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessm	ent Category
D	Tank Jacket- ABATED			Pump Room (Abated)		Miscellaneous					YES	X NO
2022 Fall Six	Month Survey: No Cl	nange			]							
Comments:	•	<u> </u>			]							
2023 Fall Six	Month Survey: No Cl	nange			_							
Comments:												
2023 Spring S	Six Month Survey: No	Change			_							
Comments:					-							
2024 Fall Six	Month Survey: No Cl	nange										
Comments:					-							
	Six Month Survey: No	Change										
Comments:					_							
					_							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
FT-1	Ceramic Tile Adhesive/Grout	350	SF	Assistant Principal's Office, Rooms 107 & 109		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No

Change in Assessment Category

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
NEW	Newly Installed Suspect ACM			Installed After Implementation of Management Plan and After Renovations		Miscellaneous		Unknown			YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
·

ALL LEA Responsibilities, for this school, will be met.

Richard J.Schleyer

## NOTICE TO PARENTS AND STAFF REGARDING THE ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: <u>Jar</u>	mes Wadsworth Elementary School
Date: <u>12/1</u>	18/2024
the Asbestos N	y you in accordance with Illinois and Federal Asbestos Regulations, that a copy of Management Plan is available at each school during school hours by appointment. Eview the Asbestos Management Plan must be made at least 24 hours in advance.
The last inspec	e advised that CPS conducts asbestos inspections of all Schools every three years. ction was completed in 2022. eillances are conducted every six months.
CHECK ONE	
A copy of	of this notice was sent home in each child's backpack.
A copy of	of this notice was printed in the school's newsletter and sent home with each child
A copy of	of this notice was printed in the school's calendar and sent home with each child
Other.	
	THIS NOTICE MUST BE PLACED IN THE DL'S ASBESTOS MANAGEMENT PLAN.