

# Chicago Public Schools

## 6 Month Asbestos Surveillance

### 2024 Fall Six Month Survey

**School:** Benito Juarez Community Academy High School  
**Address:** 2150 S. Laflin

**Oracle Unit:** 46421  
**Region:** 03

**Building ID:** 1890  
**Mail Room:** 38

☐ **CHECK HERE IF NO CHANGE TO ASBESTOS**

**Asbestos Surveyor:** Guhr, Thomas  
**Survey Date:** 10/18/2024  
**Email Address:** tguhr@cps.k12.il.us

A copy of the 2022/2023 notice to parents and staff regarding the asbestos management plan notifications was distributed via:

☐ Each child's backpack ☐ Notice printed in school's newsletter ☐ Notice printed in school's calendar ☒ Other | Posted on CPS Website

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
1	Hard spray-on fireproofing			1st Floor Corridor & 2nd Floor Gym		Surface					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

Oracle Unit: 46421

Page 1

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
2	Sofloor tile spray-on fire proofing			Throughout 2nd Floor		Surface					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
3	2' x 2' Ceiling Tile			1st Floor Corridor & Swimming Pool Area		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: Abated
Comments:Brand new ceiling

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
4	2' x 4' Ceiling Tile			Throughout 2nd Floor and Office		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
5	2' x 4' Ceiling tile			3rd Floor Corridors, Classrooms 312, 332, 333 & 335 (332 Carpet)		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6A	12" x 12" Cr警 w/White Speck Floor Tile			Basement		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6B	12" x 12" Speckled Red Floor Tile			2nd & 3rd Floor Stairwells & Basement		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6C	12" x 12" Speckled Brown Floor Tile	16800	SF	Throughout 1st & 2nd Floors & Engineer's Office in Basement, Lunch Room		Miscellaneous	No	Dist	12	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6D	12" x 12" Reddish Brown Floor Tile			1st Floor Corridor & Room 102		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6E	12" x 12" Green Floor Tile			1st Floor Stairwell		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6F	12" x 12" Yellow Floor Tile	15500	SF	1st & 3rd Floor Corridors, Throughout 2nd Floor & Rooms 312 & 320		Miscellaneous	No	Dist	3100	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6G	12" x 12" Cr警 w/Black Spots Floor Tile			1st & 2nd Floor Corridors & Rooms 125, 312, 312, 330, 332 & 333		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6H	12" x 12" Speckled Black Floor Tile			1st, 2nd & 3rd Floor Corridors, 230, 248, 207, and 226		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6I	12" x 12" Cr警 w/Brown Speck Floor Tile	8000	SF	Rooms 250, 248, 224, 214, E and W Corridor Hallways		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6J	12" x 12" Cr警 w/Gray Specks Floor Tile			Throughout 2nd Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6K	12" x 12" Pepper Floor Tile			Classrooms 342, 340, and 338		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6L	12" x 12" Mottled Brown Floor Tile			2nd and 3rd Floor Corridors		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
6M	12" x 12" Blue Floor Tile			MDF Room (205) Room 205 is a classroom with 12x12"" White/Brown Specks VFT		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
7	Lab Tables and Counter Tops	800	SF	Classrooms 319 & 354		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8A	12" x 12" Cr警 w/White Speck Floor Tile Mastic	100	SF	Basement Womens Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8B	12" x 12" Speckled Red Floor Tile Mastic	300	SF	2nd & 3rd Floors Stairwells & Basement		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8C	12" x 12" Speckled Brown Floor Tile Mastic	16800	SF	Throughout 1st & 2nd Floors & Engineer's Office in the Basement, Lunch Room		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8D	12" x 12" Reddish Brown Floor Tile	6500	SF	Room 102, 124, and 1st floor hallway		Miscellaneous	No	Dist	1300	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8E	12" x 12" Green Floor Tile Mastic	200	SF	1st Floor Stairwell		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8F	12" x 12" Yellow Floor Tile Mastic	15500	SF	1st & 3rd Floor Corridors, Throughout 2nd Floor & Rooms 312 & 320		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8G	12" x 12" Cr警 w/Black Spots Floor Tile Mastic			1st & 2nd Floor Corridors & Rooms 125, 312, 312, 330, 332 & 333		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8H	12" x 12" Speckled Black Floor Tile Mastic	150	SF	1st, 2nd & 3rd Floor Corridors, 230, 248, 207, and 226		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8I	12" x 12" Cr警 w/Brown Speck Floor Tile Mastic	8000	SF	Throughout 2nd Floor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8J	12" x 12" Cr警 w/Gray Specks Floor Tile Mastic			Throughout 2nd Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8K	12" x 12" Mottled Brown Floor Tile Mastic	80	SF	2nd and 3rd Floor Corridors		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8L	12" x 12" Pepper Floor Tile Mastic	3000	SF	Classrooms 342, 340, and 338		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
8M	12" x 12" Blue Floor Tile Mastic			MDF Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
9	Sink			3rd Floor Corridors, Classrooms 312, 332 & 335		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	Drywall tape			3rd Floor Corridors, Classrooms 312, 332 & 335		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10A	Drywall mud			3rd Floor Corridors, Classrooms 312, 332 & 335		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11	Roof flashing - Non-AHERA			Roof Top Deck		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	Roof field - Non-AHERA			Roof		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	Carpet mastic			1st Floor Corridors, 126 & Scattered Throughout 2nd Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14	Troweled on Sink Covering	8	SF	Room 337 (Faculty Lunch Room)		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	Exterior brick - Non-AHERA			Exterior of Building		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
16	Exterior brick mortar (non_ahera)			Exterior of Building		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17	Cinder block			Throughout 3rd Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18	Cinder block mortar			Throughout 3rd Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
19	Plaster ceiling			Exterior of Building at Entrances		Surface					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	Fume hood	15	SF	Classrooms 319		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	Concrete floor			Throughout 3rd Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
22	Black baseboard			Scattered Throughout 2nd Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
22D	Black baseboard adhesive			Scattered Throughout 2nd Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	Kilns	2	EA	0115		Miscellaneous	No	None	0	EA	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24	Gray Linoleum w/Black, White, Gray Spots			Room 344		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25	Gray Linoleum w/Black, White, Gray Spots Mastic			Room 344		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	New drywall	1500	SF	Cafeteria, Front Breezeway Corridor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	New drywall compound	1500	SF	Cafeteria, Front Breezeway Corridor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28	Light brown ceramic flooring & grout	7500	SF	Patio		Miscellaneous	No	Loc	25	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
29	Light brown tile mastic	7500	SF	Patio		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
30	Blue gray carpet mastic	10000	SF	2nd Floor Media Center		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
31	Gray ceramic flooring & grout	160	SF	1st Floor Womens Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
32	Gray ceramic flooring mastic	160	SF	1st Floor Womens Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
33	Brown & gold ceramic flooring & grout	200	SF	1st Floor Boys Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
34	Brown & gold ceramic flooring mastic	200	SF	1st Floor Boys Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
35	Brown & white ceramic flooring & grout	200	SF	1st Floor Girls Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
36	Brown & white ceramic floor mastic	200	SF	1st Floor Girls Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
37	Black Ceramic Flooring and Grout	720	SF	2nd, 3rd Floor Bpys Bathroom and 3rd Floor SW Rooms		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
38	Black ceramic flooring mastic	720	SF	2nd, 3rd, Floor Boys Bathroom and 3rd Floor SW Rooms		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
39	Brown ceramic flooring & grout	1800	SF	1st, 2nd Mens Bathroom, 2nd, 3rd Womens and Girls Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
40	Brown ceramic flooring mastic	1800	SF	1st, 2nd Mens Bathroom 2nd, 3rd Womens and Girls Bathroom		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
100	12" x 12" Vinyl Floor Tile Dark Orange	1200	SF	Room 100		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
101	12" x 12" Vinyl Floor Tile Dark Orange Mastic	1200	SF	Room 100		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
102	12" x 12" Gold Vinyl Floor Tile	400	SF	Room 100		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
103	12" x 12" Gold Vinyl Floor Tile Mastic	400	SF	Room 100		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
104	12" x 12" White Multi Specks Vinyl Floor Tile	4500	SF	Clinic		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
105	12" x 12" White Multi Specks Vinyl Floor Tile Mastic	4500	SF	Clinic		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
106	12" x 12" Green Vinyl Floor Tile	450	SF	Clinic		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
107	12" x 12" Green Vinyl Floor Tile Mastic	450	SF	Clinic		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
108	12" x 12" Orange/Brown Vinyl Floor Tile	450	SF	Clinic		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
109	12" x 12" Orange/Brown Vinyl Floor Tile Mastic	450	SF	Clinic		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
110	Joint compound	1500	LF	Clinic		Miscellaneous	No	None	0	LF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
111	Drywall	8000	SF	Clinic		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
112	2x2 ceiling tile	5500	SF	Clinic		Miscellaneous	Yes	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
113	12" x 12" Dark Orange Vinyl Floor Tile	2500	SF	Medical Lab		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
114	12" x 12" Dark Orange Vinyl Floor Tile Mastic	2500	SF	Medical Lab		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
115	12" x 12" Maroon Vinyl Floor Tile	500	SF	Medical Lab		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
116	12" x 12" Maroon Vinyl Floor Tile Mastic	500	SF	Medical Lab		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
117	12" x 12" Dull White Vinyl Floor Tile	500	SF	Medical Lab		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
118	12" x 12" Dull White Vinyl Floor Tile Mastic	500	SF	Medical Lab		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
119	12" x 12" Brown Blotted Vinyl Floor Tile	600	SF	Main Office		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
120	12" x 12" Brown Blotted Vinyl Floor Tile Mastic	600	SF	Main Office		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
121	12" x 12" Darkyellow Vinyl Floor Tile	600	SF	Main Office		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
122	12" x 12" Darkyellow Vinyl Floor Tile Mastic	600	SF	Main Office		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
123	12" x 12" Pinkish Red Vinyl Floor Tile	600	SF	Main Office		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
124	12" x 12" Pinkish Red Vinyl Floor Tile Mastic	600	SF	Main Office		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
125	Brake shoes		EA	Elevators (not observed)		Miscellaneous				EA	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
126	Gaskets		EA	Generator Room (not observed)		TSI				EA	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
127	Gray multicolored carpet	3200	SF	Auditorium, Band Room		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
128	12" x 12" White/Brown Specks Vinyl Floor Tile	2200	SF	2nd Floor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
129	12" x 12" White/Brown Specks Vinyl Floor Tile Mastic	2200	SF	2nd Floor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
130	12" x 12" Bright Orange Vinyl Floor Tile	800	SF	Rooms 275-280		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
131	12" x 12" Bright Orange Vinyl Floor Tile Mastic	800	SF	2nd Floor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
132	12" x 12" Bright Blue Vinyl Floor Tile	800	SF	Rooms 275-280		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
133	12" x 12" Bright Blue Vinyl Floor Tile Mastic	800	SF	2nd Floor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
134	12" x 12" Bright Green Vinyl Floor Tile	800	SF	Rooms 275-280		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
135	12" x 12" Bright Green Vinyl Floor Tile Mastic	800	SF	2nd Floor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
136	2x2 ceiling tile	12000	SF	Bridge Corridor, Rooms 275-280, 2221-2224, 2213, 1118, 1123, 1126, E Hall Stairs, Boys/Girls Dressing Rooms, 1st Floor Corridor		Miscellaneous	Yes	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
137	Window caulk	6000	SF	Throughout 2nd Floor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
138	Door caulk	4000	SF	Throughout 2nd Floor		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
139	Spray on Fire Proofing	50000	SF	Throughout 2nd Floor		Surface	Yes	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
140	Red sealant	10000	LF	Throughout 2nd Floor		Miscellaneous	No	None	0	LF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
141	2x2 black ceiling tile	1200	SF	Control Room Auditorium		Miscellaneous	Yes	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
142	12"x8' acoustic panels	3000	SF	Auditorium		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**



HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
143	Light blue acoustic panels	500	SF	Auditorium		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
144	Orange acoustic panels	500	SF	Auditorium		Miscellaneous	No	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
145	4'x4' ceiling tile	7500	SF	Auditorium, Room 281 Choir Room		Miscellaneous	Yes	None	0	SF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
146	Baseboard	8000	LF	Throughout School		Miscellaneous	No	None	0	LF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
147	Mastic Associated w/ Baseboard	8000	LF	Throughout School		Miscellaneous	No	None	0	LF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
A	Fittings on Fiberglass Pipe Insulation			Boiler Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
B	Canvas wrap over breeching			Boiler Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
C	Fiberglass boiler insulation			Boiler Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
D	Boiler breeching			Boiler Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
E	Canvas wrap over water tank			Boiler Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
F	Cementitious pipe fittings			Throughout 1st Floor and Pool Equipment Room		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
G	Cementitious pipe fittings			Auto Shop (on Heater) /Throughout 1st Floor		Miscellaneous					<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
H	Gasket on Oven	10	LF	Classroom 334 (not observed)		Miscellaneous	No	None	0	LF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
I	Boiler gasket	60	LF	Boiler Room (not observed)		Miscellaneous	No	None	0	LF	<input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

*ALL LEA Responsibilities, for this school, will be met.*

A handwritten signature in black ink, appearing to read 'Richard J. Schleyer', written in a cursive style.

---

Richard J. Schleyer

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***



NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Benito Juarez Community Academy High School

Date: 10/18/2024

---

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2022.  
Asbestos surveillances are conducted every six months.

**CHECK ONE**

- ☐ A copy of this notice was sent home in each child's backpack.
- ☐ A copy of this notice was printed in the school's newsletter and sent home with each child
- ☐ A copy of this notice was printed in the school's calendar and sent home with each child
- ☒ Other. Posted on CPS Website

---

A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***