

# Chicago Public Schools

## 6 Month Asbestos Surveillance

### 2024 Fall Six Month Survey

**School:** John M Harlan Community Academy High School  
**Address:** 9652 S. Michigan

**Oracle Unit:** 51021  
**Region:** 06

**Building ID:** 1350  
**Mail Room:** 48

☐ **CHECK HERE IF NO CHANGE TO ASBESTOS**

**Asbestos Surveyor:** Brew, Ethan  
**Survey Date:** 10/22/2024  
**Email Address:** ebrew1@cps.edu

A copy of the 2022/2023 notice to parents and staff regarding the asbestos management plan notifications was distributed via:

☐ *Each child's backpack* ☐ *Notice printed in school's newsletter* ☒ *Notice printed in school's calendar* ☐ *Other*

| HA No | Material Description       | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 01    | Acoustical Ceiling Plaster | 9000              | SF             | Auditorium        |               | Surface           | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments: n/a                           |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

Oracle Unit: 51021

Page 1

| HA No | Material Description | Material Quantity | Material Units | Material Location   | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|---------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 02    | Hard Plaster         | 108000            | SF             | Throughout Facility |               | Surface           | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description | Material Quantity | Material Units | Material Location   | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|---------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 03    | 1'x1' Ceiling Tile   | 120000            | SF             | Throughout Facility |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                            | Material Quantity | Material Units | Material Location                                                                                          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------------|-------------------|----------------|------------------------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04A   | 12x12 Various Shades of Beige Floor Tile ABATED |                   |                | 1st Floor West Exit & Corridor, SW Exits, NE Corridor & Men's Washroom (1st Floor), Swimming Pool Corridor |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                          | Material Quantity | Material Units | Material Location                                                           | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------|-------------------|----------------|-----------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04B   | 12x12 Various Shades of Tan Floor Tile ABATED |                   |                | Corridor outside Room 134, Water Fountain, outside Room 124 & 126 patchwork |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description                   | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04C   | 12x12 Multicolor Dark Beige Floor Tile | 1920              | SF             | Rooms 220 and 222 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                  | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04D   | 12x12 Light Blue Floor Tile<br>ABATED |                   |                | Room 134          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                  | Material Quantity | Material Units | Material Location                                                                                                        | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------|-------------------|----------------|--------------------------------------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04E   | 12x12 Cream w/Brown Specks Floor Tile | 7120              | SF             | Rooms 115A, 116, 117, 117B, 119, 124, 126, 133, 134, 135, 138A, 139, 210, 211, 213, 217, 218A, Girls Locker Room Office. |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

***VFT = Vinyl Floor Tile***  
***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***

| HA No | Material Description                                        | Material Quantity | Material Units | Material Location  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------------------------|-------------------|----------------|--------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04F   | 12x12 Grey (Dark Tan) w/White Streaks Floor Tile<br>REMOVED |                   |                | 2nd Floor Corridor |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                           | Material Quantity | Material Units | Material Location                                                                           | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------------|-------------------|----------------|---------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04G   | 12x12 Beige w/Brown & White Streaks Floor Tile | 16000             | SF             | Mens Faculty, 1st Floor: Corridor, SE Stairwell, Main Office Sitting Area, Ladies' Restroom |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                         | Material Quantity | Material Units | Material Location                                 | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------|-------------------|----------------|---------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04H   | 12x12 Crème w/Tan & White Streaks Floor Tile | 7050              | SF             | Faculty Dining Room & Cafeteria, Ladies' Restroom |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                         | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04I   | 12x12 Beige w/White Specks Floor Tile ABATED |                   |                | 1st Floor SE Exit |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                          | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04J   | 12x12 Taupe w/Brown & White Specks Floor Tile | 216               | SF             | Room 212          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description              | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 04K   | 12x12 Multicolor Cream Floor Tile | 2108              | SF             | Rooms 220 and 222 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                     | Material Quantity | Material Units | Material Location                                        | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------|-------------------|----------------|----------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 05A   | 9x9 Tan w/White Streaks Vinyl Floor Tile | 4560              | SF             | Rooms 224, 229, 230, 242, 216, 121, 123 and Office Vault |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                                                                |
|--------------------------------------------------------------------------------|
| 2022 Fall Six Month Survey: No Change                                          |
| Comments:                                                                      |
|                                                                                |
| 2023 Spring Six Month Survey: Abated                                           |
| Comments:room 121 floor removed                                                |
|                                                                                |
| 2023 Fall Six Month Survey: No Change                                          |
| Comments:                                                                      |
|                                                                                |
| 2024 Spring Six Month Survey: No Change                                        |
| Comments:                                                                      |
|                                                                                |
| 2024 Fall Six Month Survey: Abated                                             |
| Comments:abatement has not yet happened. Work in progress. Classroom is closed |
|                                                                                |

| HA No | Material Description                 | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 05B   | 9x9 Beige w/Brown Streaks Floor Tile | 1500              | SF             | Rooms 135 and 136 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                      | Material Quantity | Material Units | Material Location                                          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------|-------------------|----------------|------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 06A   | 9x9 Tan w/White Streaks Floor Tile Mastic | 3500              | SF             | Rooms 230, 229, 230, 242, 216, 121, 123, 224, Office Vault |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                                                                |
|--------------------------------------------------------------------------------|
| 2022 Fall Six Month Survey: No Change                                          |
| Comments:                                                                      |
|                                                                                |
| 2023 Spring Six Month Survey: No Change                                        |
| Comments:                                                                      |
|                                                                                |
| 2023 Fall Six Month Survey: No Change                                          |
| Comments:                                                                      |
|                                                                                |
| 2024 Spring Six Month Survey: No Change                                        |
| Comments:                                                                      |
|                                                                                |
| 2024 Fall Six Month Survey: Abated                                             |
| Comments:abatement has not yet happened. Work in progress. Classroom is closed |
|                                                                                |

| HA No | Material Description                        | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 06B   | 9x9 Beige w/Brown Streaks Floor Tile Mastic | 1000              | SF             | Rooms 135 and 136 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                            | Material Quantity | Material Units | Material Location                                                                                        | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------------------------|-------------------|----------------|----------------------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07A   | 12x12 Various Shades of Beige Floor Tile Mastic<br>NOT OBSERVED | 2081              | SF             | 1st Floor West Exit & Corridor, SW Exits, NE Corridor & 1st Floor Men's Washroom, Swimming Pool Corridor |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                       | Material Quantity | Material Units | Material Location                                                           | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------------------------|-------------------|----------------|-----------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07B   | 12x12 Various Shades of Tan Floor Tile Mastic NOT OBSERVED |                   |                | Corridor Outside Room 134, Water Fountain, Outside Room 124 & 126 Patchwork |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description                          | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07C   | 12x12 Multicolor Dark Beige Floor Tile Mastic | 1920              | SF             | Rooms 220 and 222 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                      | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07D   | 12x12 Light Blue Floor Tile Mastic ABATED |                   |                | Room 134          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                         | Material Quantity | Material Units | Material Location                                                                                   | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------|-------------------|----------------|-----------------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07E   | 12x12 Cream w/Brown Specks Floor Tile Mastic | 7120              | SF             | Rooms 115A, 117, 117B, 119, 133, 135, 138A, 139, 210, 211, 213, 218A and Girls' Locker Room Office. |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                              | Material Quantity | Material Units | Material Location  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------------------------------|-------------------|----------------|--------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07F   | 12x12 Grey (Dark Tan) w/White Streaks Floor Tile<br>Mastic ABATED |                   |                | 2nd Floor Corridor |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                                   | Material Quantity | Material Units | Material Location                                                                          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------------------------|-------------------|----------------|--------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07G   | Mastic -12x12 Beige w/Brown & White Streaks Floor Tile | 17020             | SF             | Mens Faculty, 1st Floor: Corridor, SE Stairwell, Main Office Sitting Area, Ladies Restroom |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                | Material Quantity | Material Units | Material Location                                 | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------------|-------------------|----------------|---------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07H   | 12x12 Crème w/Tan & White Streaks Floor Tile Mastic | 7050              | SF             | Faculty Dining Room & Cafeteria, Ladies' Restroom |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                                | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07I   | 12x12 Beige w/White Specks Floor Tile Mastic ABATED |                   |                | 1st Floor SE Exit |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                 | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07J   | 12x12 Taupe w/Brown & White Specks Floor Tile Mastic | 216               | SF             | Room 212          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description                     | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 07K   | 12x12 Multicolor Cream Mastic Floor Tile | 2108              | SF             | Rooms 220 and 222 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description    | Material Quantity | Material Units | Material Location                      | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------|-------------------|----------------|----------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 08    | 1x1 Ceiling Tile Mastic | 120000            | SF             | 1st & 2nd Floor Corridors & Classrooms |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description   | Material Quantity | Material Units | Material Location      | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------|-------------------|----------------|------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 09    | Drywall (Gypsum Board) | 120000            | SF             | Above 1x1 Ceiling Tile |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description     | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 10    | 1x2 Ceiling Tile REMOVED |                   |                | Boys' Gym         |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 11A   | Gray Baseboard       | 195               | LF             | Room 109 & 104    |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location                                           | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 11B   | Black Baseboard      | 680               | LF             | Rooms 105, 110 (Gym), 112, 113, 115, 121, 134 & Main Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 11C   | Cream Baseboard      | 142               | LF             | Rooms 106 and 108 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description  | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 12A   | Gray Baseboard Mastic | 195               | LF             | Room 109 & 104    |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description   | Material Quantity | Material Units | Material Location                                           | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------|-------------------|----------------|-------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 12B   | Black Baseboard Mastic | 680               | LF             | Rooms 105, 110 (Gym), 112, 113, 115, 121, 134 & Main Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: Abated    |
| Comments:room 121 floor removed         |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description   | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 12C   | Cream Baseboard Mastic | 142               | LF             | Rooms 106 and 108 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description      | Material Quantity | Material Units | Material Location                 | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------|-------------------|----------------|-----------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 13    | Yellow Sheet Goods Mastic | 208               | SF             | Counter Tops, Rooms 109, 103, 105 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 13A   | Light Grey Linoleum  | 3300              | SF             | Room 109 and 110  |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description     | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 13C   | Black with Gray Linoleum | 840               | SF             | Rooms 106 & 108   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description       | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 14A   | Light Grey Linoleum Mastic | 3300              | SF             | Rooms 109 & 110   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description            | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 14C   | Black with Gray Linoleum Mastic | 840               | SF             | Rooms 106 & 108   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location                                                                                                                                                         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 15A   | Blue Carpet Mastic   | 4800              | SF             | Attendance Office & Surrounding Offices, Assistant Principal's Office, Corridor, Offices D, E, F, H; Main Office, Principal's Office, Girls' Locker Room Office, Room 131 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description   | Material Quantity | Material Units | Material Location                    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------|-------------------|----------------|--------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 15B   | Burgundy Carpet Mastic | 80                | SF             | Boys' Locker Room and Coach's Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                               | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 15P   | 12x12 Black w/Maroon Checkerboard Vinyl Floor Tile | 1390              | SF             | Room 217 Corridor |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description         | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 16    | Wood Panel Mastic<br>REMOVED |                   |                | Room 124          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description              | Material Quantity | Material Units | Material Location          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|----------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 17    | Interior Window Glazing<br>ABATED |                   |                | Throughout 1st & 2nd Floor |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description              | Material Quantity | Material Units | Material Location          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|----------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 17A   | Interior Window Glazing<br>ABATED |                   |                | Throughout 1st & 2nd Floor |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 18    | 2x4 Ceiling Tile     | 840               | SF             | Room 108          |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 19    | Drywall              | 400               | SF             | Room 108          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description           | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 20    | Transite Countertops<br>ABATED |                   |                | Room 108          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description       | Material Quantity | Material Units | Material Location                                                    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------|-------------------|----------------|----------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 25    | 12x12 Dark Blue Floor Tile | 4960              | SF             | Rooms 135, 136, 208, 214, 218, 226, 241 & 2nd Floor Teachers' Lounge |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                 | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 25C   | 12x12 Tan w/Streaks Vinyl Floor Tile | 700               | SF             | Room 215          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                        | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 25D   | 12x12 Tan w/Streaks Vinyl Floor Tile Mastic | 700               | SF             | Room 215          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description              | Material Quantity | Material Units | Material Location                                                    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|----------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 25M   | 12x12 Dark Blue Floor Tile Mastic | 4960              | SF             | Rooms 135, 136, 208, 214, 218, 226, 241 & 2nd Floor Teachers' Lounge |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                   | Material Quantity | Material Units | Material Location                                                                                                                           | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------|-------------------|----------------|---------------------------------------------------------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 26    | 12x12 White w/Beige Streaks Floor Tile | 12000             | SF             | Rooms 112, 115, 122, 124, 125, 126, 130, 133, 134A, 207, 209, 219, 219A, 221, 228, 227A, 231, 232, 234, 236, 238, 240, Lunchrom and Library |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                           | Material Quantity | Material Units | Material Location                                                                                                                                 | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------------|-------------------|----------------|---------------------------------------------------------------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 26M   | 12x12 White w/ Beige Streaks Floor Tile Mastic | 12000             | SF             | Rooms 112, 115, 122, 124, 125, 126, 130, 133, 134A, 207, 209, 219, 219A, 221, 228, 227A, 231, 232, 234, 236, 238, 240, and Library, and lunchroom |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description             | Material Quantity | Material Units | Material Location           | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------|-------------------|----------------|-----------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 27    | 12x12 Brown and White Floor Tile | 1500              | SF             | Hallway in Modular Building |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description                    | Material Quantity | Material Units | Material Location           | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------|-------------------|----------------|-----------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 27M   | 12x12 Brown and White Floor Tile Mastic | 1500              | SF             | Hallway in Modular Building |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description               | Material Quantity | Material Units | Material Location                                  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------|-------------------|----------------|----------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 28    | 2'x4' White Fissured Ceiling Tiles | 5000              | SF             | Hallway and Classrooms Throughout Modular Building |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                   | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 29    | 12x12 Red Floor Tile (Duplicate- HA61) |                   |                | Rooms 112         |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                           | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 30    | 12x12 Red Floor Tile Mastic (Duplicate- HA61M) |                   |                | Rooms 112         |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                    | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 31    | 12x12 Blue Floor Tile (Duplicate- HA60) |                   |                | Rooms 112         |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                            | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 32    | 12x12 Blue Floor Tile Mastic (Duplicate- HA60M) |                   |                | Rooms 112         |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                    | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 33    | 12x12 White Floor Tile (Duplicate HA62) |                   |                | Rooms 112         |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                             | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 34    | 12x12 White Floor Tile Mastic (Duplicate- HA62M) |                   |                | Rooms 112 and 114 |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description       | Material Quantity | Material Units | Material Location                                              | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------|-------------------|----------------|----------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 35    | 12x12 Dark Blue Floor Tile | 12000             | SF             | Corridors Border, Stairwells, Rooms 218, 214, 208, 241 and 226 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                 | Material Quantity | Material Units | Material Location                                                    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------|-------------------|----------------|----------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 36    | 12x12 Dark Blue Floor Tile<br>Mastic | 12000             | SF             | Corridors Border,<br>Stairwells, Rooms 218,<br>214, 208, 241 and 226 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description      | Material Quantity | Material Units | Material Location          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------|-------------------|----------------|----------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 37    | 12x12 Sky Blue Floor Tile | 10500             | SF             | Corridors and Room<br>138A |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description             | Material Quantity | Material Units | Material Location       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------|-------------------|----------------|-------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 38    | 12x12 Sky Blue Floor Tile Mastic | 10500             | SF             | Corridors and Room 138A |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description     | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 39    | 22"x22" White Floor Tile | 5000              | SF             | Main Hall         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description            | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 40    | 22"x22" White Floor Tile Mastic | 5000              | SF             | Main Hall         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description          | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 41    | 22"x22" Light Blue Floor tile | 5000              | SF             | Main Hall         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                 | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 42    | 22"x22" Light Blue Floor Tile Mastic | 5000              | SF             | Main Hall         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description         | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 43    | 22"x22" Dark Blue Floor Tile | 5000              | SF             | Main Hall         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 44    | 22"x22" Dark Blue Floor Tile Mastic | 5000              | SF             | Main Hall         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description      | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 45    | 22"x22" Orange Floor Tile | 5000              | SF             | Main Hall         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description             | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 46    | 22"x22" Orange Floor Tile Mastic | 5000              | SF             | Main Hall         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 47    | 2'x2' Ceiling Tile   | 5000              | SF             | Main Hall         |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                         | Material Quantity | Material Units | Material Location                    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------|-------------------|----------------|--------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 48    | 12"x12" H Blue Mix Speckled Vinyl Floor Tile | 3300              | SF             | Annex Building-Throughout Classrooms |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                              | Material Quantity | Material Units | Material Location                    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------------|-------------------|----------------|--------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 48M   | 12x12 H Blue Mix Speckled Vinyl Floor Tile Mastic | 3300              | SF             | Annex Building-Throughout Classrooms |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                            | Material Quantity | Material Units | Material Location            | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------------|-------------------|----------------|------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 49    | 12x12 Dark Blue Mixed Speckled Vinyl Floor Tile | 3300              | SF             | Annex- Throughout Classrooms |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                  | Material Quantity | Material Units | Material Location            | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------|-------------------|----------------|------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 49M   | 12x12 Dark Blue Mixed Speckled Mastic | 3300              | SF             | Annex- Throughout Classrooms |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description       | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 50    | 2'x4' Grooved Ceiling Tile | 5000              | SF             | Throughout Annex  |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                       | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 51    | 12x12 Cream w/Beige Specs Vinyl Floor Tile | 800               | SF             | Annex- 1st Floor Corridor |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description              | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 51M   | 12x12 Cream w/Beige Specks Mastic | 800               | SF             | Annex- 1st Floor Corridor |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                      | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 52    | 12x12 Tan w/Cream Specks Vinyl Floor Tile | 800               | SF             | Annex- 1st Floor Corridor |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description            | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 52M   | 12x12 Tan w/Cream Specks Mastic | 800               | SF             | Annex- 1st Floor Corridor |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description  | Material Quantity | Material Units | Material Location            | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------|-------------------|----------------|------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 53    | Blue Baseboard Mastic | 1000              | SF             | Annex- Throughout Classrooms |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                        | Material Quantity | Material Units | Material Location     | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------|-------------------|----------------|-----------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 54    | 12x12 Brown Mixed Speckled Vinyl Floor Tile | 200               | SF             | Boys & Girls Washroom |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description              | Material Quantity | Material Units | Material Location       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|-------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 54M   | 12x12 Brown Mixed Speckled Mastic | 200               | SF             | Boys' & Girls' Washroom |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description             | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 55    | 12x12 Baby Blue Vinyl Floor Tile | 500               | SF             | Room 138          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                    | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 55M   | 12x12 Baby Blue Vinyl Floor Tile Mastic | 500               | SF             | Room 138          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 56    | 2'x4' Ceiling Tile   | 560               | SF             | Rooms 137 and 138 |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 57    | Tan Linoleum ABATED  |                   |                | Room 104          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description       | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 57M   | Tan Linoleum Mastic ABATED |                   |                | Room 104          |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description              | Material Quantity | Material Units | Material Location             | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|-------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 58    | Lab Counter Tops Vinyl Floor Tile | 2000              | SF             | Rooms 104, 106, 107, 109, 110 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 59    | Fume Hoods           | 40                | SF             | Room 106          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                     | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 60    | 12x12 Teal Mix Speckled Vinyl Floor Tile | 200               | SF             | Room 112          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 60A   | Linoleum Mastic      | 800               | SF             | Room 112          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description           | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 60M   | 12x12 Teal Mix Speckled Mastic | 200               | SF             | Room 112          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                              | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 61    | 12x12 Salmon (Pink) Mix Speckled Vinyl Floor Tile | 200               | SF             | Room 112          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                        | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 61M   | 12x12 Salmon (Pink) Vinyl Floor Tile Mastic | 200               | SF             | Room 112          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                        | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 62    | 12x12 White w/Green Specks Vinyl Floor Tile | 200               | SF             | Room 112          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                               | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 62M   | 12x12 White w/Green Specks Vinyl Floor Tile Mastic | 200               | SF             | Room 112          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                         | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 63    | 12x12 H Gray Mixed Speckled Vinyl Floor Tile | 600               | SF             | Rooms 113 & 118   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                                | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 63M   | 12x12 H Gray Mixed Speckled Vinyl Floor Tile Mastic | 600               | SF             | Rooms 113 & 118   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 64    | Orange Linoleum      | 300               | SF             | Rooms 114, 116    |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description   | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 64M   | Orange Linoleum Mastic | 300               | SF             | Rooms 114, 116    |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|----------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 65    | White Linoleum       | 1320              | SF             | Rooms 107, 114 & 116 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description  | Material Quantity | Material Units | Material Location    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------|-------------------|----------------|----------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 65M   | White Linoleum Mastic | 1320              | SF             | Rooms 107, 114 & 116 |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 66    | Blue Linoleum        | 300               | SF             | Rooms 114 & 116   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 66M   | Blue Linoleum Mastic | 300               | SF             | Rooms 114 & 116   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                        | Material Quantity | Material Units | Material Location                          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------|-------------------|----------------|--------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 67    | 12x12 Beige Mixed Speckled Vinyl Floor Tile | 2000              | SF             | Rooms 204, 206, 239, Kitchen & Locker Room |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                               | Material Quantity | Material Units | Material Location                          | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------------|-------------------|----------------|--------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 67M   | 12x12 Beige Mixed Speckled Vinyl Floor Tile Mastic | 2000              | SF             | Rooms 204, 206, 239, Kitchen & Locker Room |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                        | Material Quantity | Material Units | Material Location                       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------|-------------------|----------------|-----------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 68    | 12x12 White w/Black Specks Vinyl Floor Tile | 160               | SF             | Elevator Vestibule & Engineering Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                               | Material Quantity | Material Units | Material Location                       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------------|-------------------|----------------|-----------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 68M   | 12x12 White w/Black Specks Vinyl Floor Tile Mastic | 160               | SF             | Elevator Vestibule & Engineering Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description       | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 69    | 9x9 Peach Vinyl Floor Tile | 566               | SF             | Room 120          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description              | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 69M   | 9x9 Peach Vinyl Floor Tile Mastic | 566               | SF             | Room 120          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description      | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 70    | 9x9 Grey Vinyl Floor Tile | 284               | SF             | Room 120          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description                | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 70M   | 9x9 Grey Vinyl Floor Tile<br>Mastic | 284               | SF             | Room 120          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                  | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 71    | 12"x12" Blue Mottled Vinyl Floor Tile | 600               | SF             | Room 120 & 131    |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description                         | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 72    | 12"x12" Blue Mottled Vinyl Floor Tile Mastic | 600               | SF             | Rooms 120 & 131   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                          | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 73    | 12"x12" White w/Brown Specks Vinyl Floor Tile | 900               | SF             | Rooms 120 & 131   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                                 | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 74    | 12"x12" White w/Brown Specks Vinyl Floor Tile Mastic | 900               | SF             | Rooms 120 & 131   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                        | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 75    | 12"x12" Royal Blue Mottled Vinyl Floor Tile | 600               | SF             | Rooms 120 & 131   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                               | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 76    | 12"x12" Royal Blue Mottled Vinyl Floor Tile Mastic | 600               | SF             | Rooms 120 & 131   |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                       | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 77    | 2'x2' Gray w/White Specks Vinyl Floor Tile | 700               | SF             | Room 104          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description                              | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 78    | 2'x2' Gray w/White Specks Vinyl Floor Tile Mastic | 700               | SF             | Room 104          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                     | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 79    | 2'x2' Blue w/Tan Specks Vinyl Floor Tile | 235               | SF             | Room 104          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                            | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| 80    | 2'x2' Blue w/Tan Specks Vinyl Floor Tile Mastic | 235               | SF             | Room 104          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description           | Material Quantity | Material Units | Material Location                 | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------|-------------------|----------------|-----------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| E     | Insulation in Fire Rated Doors | 240               | SF             | At Fire Stops Throughout Facility |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description              | Material Quantity | Material Units | Material Location               | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------|-------------------|----------------|---------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| G     | MJV on Fiberglass Pipe Insulation | 698               | LF             | Throughout Basement Crawl Space |               | TSI               | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description | Material Quantity | Material Units | Material Location    | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------|-------------------|----------------|----------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| H     | Vibration Collars    | 5                 | SF             | Basement Boiler Room |               | TSI               | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No  | Material Description           | Material Quantity | Material Units | Material Location        | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|--------------------------------|-------------------|----------------|--------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-100 | 2'x4' Plain White Ceiling Tile | 150               | SF             | 1st Floor Boys' Restroom |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No  | Material Description                            | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|-------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-101 | 2'x4' White Ceiling Tile w/Grooves and Pinholes | 7000              | SF             | Classrooms        |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No  | Material Description          | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|-------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-102 | Acoustical "Pop Corn" Plaster | 9000              | SF             | Auditorium        |               | Surface           | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No  | Material Description                       | Material Quantity | Material Units | Material Location               | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|--------------------------------------------|-------------------|----------------|---------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-103 | 2'x4' White Ceiling Tile w/Random Fissures | 1800              | SF             | Classroom, Corridor, Men's Room |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No  | Material Description                        | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|---------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-104 | 2'x4' White Ceiling Tile with Regular Holes | 200               | SF             | Ladies Room       |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No  | Material Description                                  | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|-------------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-105 | 12"x12" Beige w/White & Brown Specks Vinyl Floor Tile | 400               | SF             | Restrooms         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No   | Material Description                                         | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|---------|--------------------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-105m | 12"x12" Beige w/White & Brown Specks Vinyl Floor Tile Mastic | 400               | SF             | Restrooms         |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No  | Material Description                        | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|---------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-106 | 12"x12" Off-White w/Beige Specks Floor Tile | 500               | SF             | Corridor          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No       | Material Description                            | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------------|-------------------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-106/107m | 12"x12" Off-White and Brown Floor Tile Adhesive | 1000              | SF             | Corridor          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No  | Material Description                 | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|--------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-107 | 12"X12" Brown with Specks Floor Tile | 500               | SF             | Corridor          |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No  | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-108 | Red Carpet Adhesive  | 3000              | SF             | Classrooms        |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No  | Material Description | Material Quantity | Material Units | Material Location                                                                                   | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|----------------------|-------------------|----------------|-----------------------------------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-109 | Gray Carpet Adhesive | 3000              | SF             | Rooms 102A, 224A, Attendance Office, 131A, 130, Auditorium, Main Office, Assitant Principals Office |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No  | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|----------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-110 | 4" Black Baseboard   | 5000              | LF             | Throughout        |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No   | Material Description        | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|---------|-----------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-110M | 4" Black Baseboard Adhesive | 5000              | LF             | Throughout        |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No  | Material Description                                    | Material Quantity | Material Units | Material Location                     | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|--------|---------------------------------------------------------|-------------------|----------------|---------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| HA-111 | Hard Joint Mudded Fittings on Fiberglass Insulated Pipe | 4                 | LF             | Utility Sink Room by the Water Heater |               | TSI               | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| I     | 12x12 Light Blue Floor Tile<br>(Duplicate of HA 37) |                   |                | 1st & 2nd Floor Corridors |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                               | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| J     | 12x12 Dark Blue Floor Tile<br>(Duplicate of HA 35) |                   |                | 1st & 2nd Floor Corridors |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description  | Material Quantity | Material Units | Material Location  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------|-------------------|----------------|--------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| K     | Brown Linoleum ABATED |                   |                | Rooms 104 and 104A |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description         | Material Quantity | Material Units | Material Location  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|------------------------------|-------------------|----------------|--------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| L     | Brown Linoleum Mastic ABATED |                   |                | Rooms 104 and 104A |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                                    | Material Quantity | Material Units | Material Location        | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|---------------------------------------------------------|-------------------|----------------|--------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| M     | 12x12 Light Blue Floor Tile Mastic (Duplicate of HA 38) |                   |                | 1st & 2nd Floor Corridor |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

| HA No | Material Description                                   | Material Quantity | Material Units | Material Location         | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|--------------------------------------------------------|-------------------|----------------|---------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| N     | 12x12 Dark Blue Floor Tile Mastic (Duplicate of HA 36) |                   |                | 1st & 2nd Floor Corridors |               | Miscellaneous     |         |             |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description        | Material Quantity | Material Units | Material Location                                                       | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-----------------------------|-------------------|----------------|-------------------------------------------------------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| NEW   | Newly Installed Suspect ACM |                   |                | Installed After Implementation of Management Plan and After Renovations |               | Miscellaneous     |         | Unknown     |                 |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

| HA No | Material Description                | Material Quantity | Material Units | Material Location  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|-------------------------------------|-------------------|----------------|--------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| O     | 1x1 Slotted Acoustical Ceiling Tile | 800               | SF             | Boys' & Girls' Gym |               | Miscellaneous     | Yes     | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

| HA No | Material Description                         | Material Quantity | Material Units | Material Location  | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category                                         |
|-------|----------------------------------------------|-------------------|----------------|--------------------|---------------|-------------------|---------|-------------|-----------------|--------------|-----------------------------------------------------------------------|
| P     | 1x1 Slotted Acoustical Ceiling Tile Adhesive | 800               | SF             | Boys' & Girls' Gym |               | Miscellaneous     | No      | None        | 0               |              | <input type="checkbox"/> YES   <input checked="" type="checkbox"/> NO |

|                                         |
|-----------------------------------------|
| 2022 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2023 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2023 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |
| 2024 Spring Six Month Survey: No Change |
| Comments:                               |
|                                         |
| 2024 Fall Six Month Survey: No Change   |
| Comments:                               |
|                                         |

**VFT = Vinyl Floor Tile**  
**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**

*ALL LEA Responsibilities, for this school, will be met.*

A handwritten signature in black ink, appearing to read 'Richard J. Schleyer', written in a cursive style.

---

Richard J. Schleyer

***VFT = Vinyl Floor Tile***

***Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.***

NOTICE TO PARENTS AND STAFF REGARDING THE  
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: John M Harlan Community Academy High School

Date: 10/22/2024

---

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2022.  
Asbestos surveillances are conducted every six months.

CHECK ONE

- ☐ A copy of this notice was sent home in each child's backpack.
- ☐ A copy of this notice was printed in the school's newsletter and sent home with each child
- ☒ A copy of this notice was printed in the school's calendar and sent home with each child
- ☐ Other.
- 

A COPY OF THIS NOTICE MUST BE PLACED IN THE  
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

**VFT = Vinyl Floor Tile**

**Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.**