Chicago Public Schools

6 Month Asbestos Surveillance

2024 Fall Six Month Survey

	chool: ddress:	CICS - Wrightwood 8130 S. California Ave.		Oracle Unit: Region:	66381 02	Building ID: Mail Room:	3180 44
			Asbestos Surveyor:	DCANCEL1			
X CHECK HE	RE IF N	IO CHANGE TO ASBESTOS	Survey Date:	11/11/2024			
			Email Address:	dcancel1@cps.edu			

	A copy of the2022/20	23 notice to p	parents and	I staff regarding the ask	estos manaç	gement plan no	otifications w	as distribute	ed via:			
	Each child's backp	ack	Notice	printed in school's new	sletter	Notice p	rinted in sch	ool's calenda	ar X Ot	ther Websi	te	
HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Asse	ssment Category
01	Pipe Insulation	1350	LF	Cafeteria (above ceiling tile), Basement/Pipe Chases		TSI	Yes	None	0		YES	XNO
2022 Fall	Six Month Survey: No C	hange			7							
Comment		0										
2023 Fall	Six Month Survey: No C	hange			-							
Comment		<u> </u>										
2023 Spri Comment	ng Six Month Survey: No	o Change			-							
	ng Six Month Survey: No	o Change										
Comment	S:				_							
2024 Fall Comment	Six Month Survey: No C	hange			-							
					1							

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
02	Pipe Joint Insulation	3150	LF	Cafeteria (above ceiling tile), Basement/Pipe Chases		TSI	Yes	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03	12 x 12 Beige Floor Tile	9000	SF	Kitchen/basement, lunchroom, and mechanical room		Miscellaneous	No	Loc	6		

022 Fall Six Month Survey: No Change
Comments:
023 Fall Six Month Survey: No Change
Comments:
023 Spring Six Month Survey: No Change
Comments:
024 Spring Six Month Survey: No Change
Comments:
024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
03M	12"x12" Beige Floor Tile	9000	SF	Kitchen/Basement/Lunchr oom/Mechanical Room		Miscellaneous	No	Loc	6		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
04	12"x12" Red Floor Tile Mastic	968	SF	Mechanical / Storage Rm		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
05	12"x12" Ceiling Tile Glue	18000	SF	Corridors/Basement, Rooms 1 - 8, 25-27, 30- 32		Miscellaneous	No	None	0		

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
06	9"x9" Green Floor Tile - Abated			Rooms 19, 20, 21, 28, 29, 31, 32, 33, 35		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
Comments.
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
07	9"x9" Tan Floor Tile - Abated			Rooms 19, 20, 21, 28, 31, 32, 33, 35, 37		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
08	Spray-on Ceiling	1464	SF	Art Room		Surface	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
09	9"x9" Gray Floor Tile - Abated	0		Room 11		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
10	Boiler Insulation (ABATED 2004)			Boiler Room		TSI	Yes				YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
11	12"x12" Floor Tile	100	SF	1st Floor Storage Room		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Foll Six Month Sunyou: No Change
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
12	2x4 Ceiling Tile	20000	SF	Bldg A - 1st and 2nd Floor Hallways, principal, main, and counselor's offices, E and W boys, girls, men, women bathrooms, cafeteria, all purpose room, library, computer lab, nurse office, boiler office		Miscellaneous	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
13	Red and Beige Terrazzo	15000	SF	Buildings A and B - Hallways, Stairwells, Bathroom		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey No Change
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	C	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
14		Carpet Mastic over Tile - Removed			Rooms 11, 17-18, 21, 25- 32, and Library Offices		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
15	12 x 12 Brown Floor Tile	1500	SF	Rooms 12(not observed), 19, 20		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

	HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
F	16	12 x 12 Brown Floor Tile Mastic	1500	SF	Rooms 12, 19, 20		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
17	12 x 12 Beige Floor Tile	9000	SF	Kitchen/Basement/Lunchr oom/Mechanical Room		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
18	12 x 12 Red Floor Tile	968	SF	Mechanical / Storage Rm		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
19	9 x 9 Green Floor Tile Mastic - Abated			Rooms 4, 8, 19, 20-21, 28, 31, 33, 35, 37		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
20	9" x 9" Tan Floor Tile Mastic - Abated			Rooms 4, 8, 19-21, 28, 31, 33, 35 & 37		Miscellaneous					YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
21	12" x 12" Beige Floor Tile w/Gray Streaks	3600	SF	Rooms 10, 14, 17, 22 & 24		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
22	12" x 12" Beige Floor Tile w/Gray Streaks Mastic	3600	SF	Rooms 10, 14, 17, 22 & 24		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
23	12" x 12" Tan Floor Tile w/Brown Streaks	7438	SF	Rooms 2, 4, 6, 7, 8, 14, 15, 23, 30		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Chrise Civ Marth Curvey No Change
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
24	12" x 12" Tan Floor Tile w/Brown Streaks Mastic	7438	SF	Rooms 2, 4, 6, 7, 8, 14, 15, 23, 30		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey No Change
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
25	1' x 1' White Ceiling Tile w/Deep Fissures	11650	SF	Rooms 1-8, 25-28 & 30- 32		Miscellaneous	Yes	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
26	12" x 12" Dark Gray Floor Tile w/Black Streaks	12988	SF	Rooms 1, 3, 5, 9, 11, 13, 16, 18, 21, 26-29, 31, 32, principal's, main, counselor's office, basement-library		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

VFT = *Vinyl Floor Tile Friable* = *Can be crumbled, pulverized, or reduced to powder by hand pressure.* Oracle Unit: 66381 Page 15

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
27	12" x 12" Dark Gray Floor Tile w/Black Streaks Mastic	12988	SF	Rooms 1, 3, 5, 9, 11, 13, 16, 18, 21 & 26-29, 31, 32, principal's, main, counselor's office, basement-library		Miscellaneous	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
28	Plaster	30000	SF	Classrooms 9-24, East wing 1st and 2nd floor		Surface	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
29	Mortar- CMU	35000	SF	Throughout building - west wing, classrooms 1- 8, 25-28, corridors, boys and girls restrooms		Surface	No	None	0		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
30	9"x9" brown w/ tan + peach streaks VFT	230	SF	Social Worker Office by boiler room		Miscellaneous	No	Loc	6		YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
30M	9"x9" brown w/ tan + peach streaks VFT Mastic	220	SF	Social Worker's Office by boiler room		Miscellaneous	No	Loc	6		YES X NO

2020 Fall Oir Marth Oursen Na Ohan an
2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
31	Red duct sealant	50	LF	Boiler room		Miscellaneous	No	None	0		YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
32	12 x 12 Beige speckled floor tile	1000	SF	Social workers office, Rm 12 & 25		Miscellaneous	No	None			YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
32M	12 x 12 Beige speckled floor tile Mastic	1000	SF	Social workers office, Rms 12 & 25		Miscellaneous	No	None			YES XNO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category
33	Beige Duct Sealant	40	SF	Above Ceiling tile and mechanical room		Miscellaneous	No	None			YES X NO

2022 Fall Six Month Survey: No Change
Comments:
2023 Fall Six Month Survey: No Change
Comments:
2023 Spring Six Month Survey: No Change
Comments:
2024 Spring Six Month Survey: No Change
Comments:
2024 Fall Six Month Survey: No Change
Comments:

ALL LEA Responsibilities, for this school, will be met.

Richard J.Schleyer

NOTICE TO PARENTS AND STAFF REGARDING THE ASBESTOS MANAGEMENT PLAN NOTIFICATION

School:	CICS -	Wrightwood
---------	--------	------------

Date: 11/11/2024

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2022.

Asbestos surveillances are conducted every six months.

CHECK ONE

A copy of this notice was sent home in each child's backpa
--

A copy of this notice was printed in the school's newsletter and sent home with each child

A copy of this notice was printed in the school's calendar and sent home with each child



A COPY OF THIS NOTICE MUST BE PLACED IN THE SCHOOL'S ASBESTOS MANAGEMENT PLAN.