

Chicago Public Schools

6 Month Asbestos Surveillance

2024 Fall Six Month Survey

School: Noble - Hansberry College Prep
Address: 8748 Aberdeen

Oracle Unit: 66574
Region:

Building ID: 59883
Mail Room: 49

☒ **CHECK HERE IF NO CHANGE TO ASBESTOS**

Asbestos Surveyor: Marrero, Elizabeth
Survey Date: 11/14/2024
Email Address: emarrero5@cps.k12.il.us

A copy of the 2022/2023 notice to parents and staff regarding the asbestos management plan notifications was distributed via:

☐ Each child's backpack ☐ Notice printed in school's newsletter ☐ Notice printed in school's calendar ☒ Other | Posted to the CPS website

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|---|-------------------|----------------|------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 01 | MJP on Non-Suspect Pipe NOT OBSERVED | | | All Floors in Building | | TSI | Yes | | | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

2022 Fall Six Month Survey: No Change

Comments:

2023 Fall Six Month Survey: No Change

Comments:

2023 Spring Six Month Survey: No Change

Comments:

2024 Spring Six Month Survey: No Change

Comments:

2024 Fall Six Month Survey: No Change

Comments:

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

Oracle Unit: 66574

Page 1

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|--|-------------------|----------------|------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 02 | Wrapped Paper Pipe Cover NOT OBSERVED | | | All Floors in Building | | TSI | Yes | | | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|---|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 03 | MJP on Wrapped Pipe Cover NOT OBSERVED | | | Boiler Room #1 | | TSI | Yes | | | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|----------------------------|-------------------|----------------|------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 04 | Pipe Covering NOT OBSERVED | | | All Floors in Building | | TSI | Yes | | | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|-----------------------------------|-------------------|----------------|------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 05 | MJP on Pipe Covering NOT OBSERVED | | | All Floors in Building | | TSI | Yes | | | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|---|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 06 | 1'x1' Acoustical Ceiling Tile NOT OBSERVED | | | Ground Floor | | Miscellaneous | Yes | | | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|----------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 07 | Vinyl Floor Tile NOT OBSERVED | | | Ground Floor | | Miscellaneous | No | | | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|--------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 08 | 12x12 Beige w/ Dark Spots Floor Tile | 300 | SF | Room 185 | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|--|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 09 | 12x12 Beige w/Dark Spots Floor Tile Mastic | 300 | SF | Room 185 | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|---------------------------|-------------------|----------------|--|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 10 | 2'x4' Smooth Ceiling Tile | 5000 | SF | Rooms 171, 175, 176, 178, 180, 181, 181, 185, Boys' and Girls' Washroom and Hallways | | Miscellaneous | Yes | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|---------------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 11 | 12x12 Gray w/Black & Beige Floor Tile | 1500 | SF | Hallways | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|--|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 12 | 12x12 Gray w/Black & Beige Floor Tile Mastic | 1500 | SF | Hallways | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|-------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 13 | 2'x4' Flat Ceiling Tile | 800 | SF | Kitchen | | Miscellaneous | Yes | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|----------------------|-------------------|----------------|--------------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 14 | Spray-On Insulation | 300 | SF | Storage Room West of Gym | | Miscellaneous | Yes | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|--------------------------------|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 15 | Glue Associated w/Rubber Floor | 800 | SF | Room 171 | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|--|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 16 | 12x12 Dark Gray w/Beige Spots Floor Tile | 1200 | SF | Rooms 175 and 176 | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|--|-------------------|----------------|-------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 17 | 12x12 Dark Gray w/ Beige Spots Floor Tile Mastic | 1200 | SF | Rooms 175 and 176 | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|----------------------------|-------------------|----------------|----------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 18 | Gray/Black Carpet Adhesive | 1200 | SF | Rooms 180, 181 & 182 | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|-------------------------|-------------------|----------------|---------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 19 | Gray Baseboard Adhesive | 1500 | LF | Throughout Building | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|----------------------|-------------------|----------------|---------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 20 | Drywall | 10000 | SF | Throughout Building | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|----------------------|-------------------|----------------|---------------------|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| 21 | Drywall Compound | 2000 | SF | Throughout Building | | Miscellaneous | No | None | 0 | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

| HA No | Material Description | Material Quantity | Material Units | Material Location | Asbestos Type | Material Category | Friable | Damage Type | Damage Quantity | Damage Units | Change in Assessment Category |
|-------|-----------------------------|-------------------|----------------|---|---------------|-------------------|---------|-------------|-----------------|--------------|---|
| NEW | Newly Installed Suspect ACM | | | Installed After Implementation of Management Plan and After Renovations | | Miscellaneous | | Unknown | | | <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO |

| |
|---|
| 2022 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2023 Spring Six Month Survey: No Change |
| Comments: |
| |
| 2024 Fall Six Month Survey: No Change |
| Comments: |
| |
| 2024 Spring Six Month Survey: No Change |
| Comments: |
| |

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

ALL LEA Responsibilities, for this school, will be met.

A handwritten signature in black ink, appearing to read 'R. Schleyer', is positioned above a horizontal line.

Richard J. Schleyer

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.

NOTICE TO PARENTS AND STAFF REGARDING THE
ASBESTOS MANAGEMENT PLAN NOTIFICATION

School: Noble - Hansberry College Prep

Date: 8/1/2024

This is to notify you in accordance with Illinois and Federal Asbestos Regulations, that a copy of the Asbestos Management Plan is available at each school during school hours by appointment. Requests to review the Asbestos Management Plan must be made at least 24 hours in advance.

Also please be advised that CPS conducts asbestos inspections of all Schools every three years. The last inspection was completed in 2022. Asbestos surveillances are conducted every six months.

CHECK ONE

- ☐ A copy of this notice was sent home in each child's backpack.
- ☐ A copy of this notice was printed in the school's newsletter and sent home with each child
- ☐ A copy of this notice was printed in the school's calendar and sent home with each child
- ☒ Other. Posted to the CPS website
-

A COPY OF THIS NOTICE MUST BE PLACED IN THE
SCHOOL'S ASBESTOS MANAGEMENT PLAN.

VFT = Vinyl Floor Tile

Friable = Can be crumbled, pulverized, or reduced to powder by hand pressure.