

**ILLINOIS DEPARTMENT OF PUBLIC HEALTH
AHERA THREE YEAR REINSPECTION
ASBESTOS ABATEMENT PROGRAM
SCHOOL INFORMATION FORM**

SECTION I

NAME OF SCHOOL DISTRICT: CHICAGO SCHOOL DIST 299
SCHOOL ID NUMBER: 14-016-2990-0053
SCHOOL NAME: Lenart Center
ADDRESS OF SCHOOL: 8101 S. LaSalle Street
CITY: Chicago, IL, 60620

DATE LAST THREE YEAR REINSPECTION WAS COMPLETED 3/22/2016

If the address on this form is different than the address of the building, submit a written explanation.

SECTION II (Please type or print)

PLEASE COMPLETE THE FOLLOWING FOR YOUR THREE YEAR REINSPECTION:

DATE REINSPECTION COMPLETED: 10/1/2019 ENROLLMENT 293
IDPH INSPECTOR LICENSE NUMBER: 100-09106
IDPH LICENSED INSPECTOR NAME(Please Print): Michael Hasier
IDPH MP LICENSE NUMBER: 100-00746
IDPH LICENSED MANAGEMENT PLANNER NAME (Please Print): Amy Williams

DESIGNATED PERSON (Please Print): Robert Christlieb PHONE: (773) 553-3197



10/1/2019

Signature of Designated Person

Date

SECTION III

PLEASE COMPLETE THE FOLLOWING INFORMATION FOR ANY CHANGES WITHIN THE SCHOOL DISTRICT.

School building has been sold. Date of Sale: _____

School has been closed. Date closed: _____

School building has been demolished. Date: _____

School building is asbestos free since last reinspection: _____

Please explain in writing why the school building is now asbestos free and include the supporting documentation.

If a new school building has been added to the district, submit either an exclusionary statement or a management plan and inspection report. Include the complete name, address and city of school building.

Explain in writing if the address of the building is different than the address on this form:

THREE-YEAR REINSPECTION

CHICAGO SCHOOL DIST 299

Lenart Center

8101 S. LaSalle Street
Chicago, IL, 60620

Unit: 29361
Building ID: 7240

IDPH ID Number: 14-016-2990-0053

REPORT DATE:

Tuesday, October 01, 2019

Prepared for:

**Chicago Public Schools
42 West Madison Street
Chicago, IL 60602**

Prepared by:

TEM Environmental, Inc.

174 N. Brandon Drive

Glendale Heights, IL, 60139

Phone 630-790-0880

Fax 630-790-0882

**DO NOT REMOVE FROM SCHOOL
REQUIRED BY FEDERAL LAW**

September 30, 2019

Mr. Glen E. Garner
Asbestos Program
Illinois Department of Public Health
525 West Jefferson Street
Springfield, Illinois 62761

Re: Chicago Public Schools - 2019 Three-Year Reinspections

Dear Mr. Glen:

TEM Environmental, Inc. , Managing Environmental Consultant (MEC), conducted the Three-Year Reinspections and performed management plan updates for the Chicago Public Schools (CPS) facilities in Region 5, 6 Elementary Schools. Please update your records with the following information.

School District: 299 Unit: 29361 Region: 05 IDPH ID:14-016-2990-0053

School: Lenart Center Building ID: 7240

Address: 8101 S. LaSalle Street

Chicago, IL, 60620

Building Contact:

Contact Phone:

Current Building Owners: Chicago Public Schools

Review Date: 10/24/2019

Inspector: Michael Hasier

Inspector IDPH License: 100-09106

Management Planner: Amy Williams

Management Planner IDPH License: 100-00746

If you have any questions or comments, please contact us at 630-790-0880

Sincerely,
TEM Environmental, Inc.

Amy Williams
100-00746

Environmental Notification to Occupants

To: Faculty, Staff and Parents
From: Chicago Public Schools
Date: September 30, 2019

RE: Lenart Center, Unit 29361
8101 S. LaSalle Street
Chicago, IL, 60620

Dear Faculty, Staff and Parents,

This letter is to notify you that the 2019 asbestos three year re-inspection has been completed at Lenart Center, following the Federal Asbestos Hazard Emergency Response Act (AHERA), 40 CFR Part 763, Subpart E and is available for your review at the main office of the school.

Although asbestos-containing materials have been identified at Lenart Center, there is no reason to believe that any threat to the health of students or staff exists at this time. CPS will continue to carefully monitor the condition of asbestos-containing materials and if conditions warrant, all appropriate steps will be taken to maintain the health and safety of all building occupants.

If you have any questions regarding this matter or require additional information, please feel free to contact Robert Christlieb, the designated Local Education Authority's Designated Person at (773) 553-3197 .

Table of Contents

- I. School and Inspection Information
- II. Executive Summary
- III. Methodology
- IV. Abatement History
- V. Reassessments and Recommendations
- VI. Conclusions

Table I: Inspector's Reinspection Findings

Table II: Management Planner's Review

APPENDICES:

- Appendix A: Assessment Sheets, Drawings and Photos
- Appendix B: Inspector and Management Planner Licenses
- Appendix C: Laboratory Accreditations
- Appendix D: Laboratory Results
- Appendix E: Chain of Custody Forms

SCHOOL AND INSPECTION INFORMATION

1. School Information

School: Lenart Center	Unit: 29361	Region: 05
Address: 8101 S. LaSalle Street	Chicago, IL, 60620	
IDPH ID: 14-016-2990-0053	Building ID: 7240	
Contact:	Phone:	

2. Description of Facility

Original Construction: 1961	Additional Construction:
Total Square Footage: 60474	No of Floors: 3
Current Occupancy: 293	

3. LEA Designated Person

Contact: Robert Christlieb	Phone: (773) 553-3197
Address: 42 West Madison Street	
Chicago, IL 60602	

4. Managing Environmental Consultant

MEC: TEM Environmental, Inc.	
Contact: Steven Geneser	
Address 174 N. Brandon Drive	
Glendale Heights, IL, 60139	
Phone: 630-790-0880	Fax: 630-790-0882

5. Inspector

Inspector Name: Michael Hasier

Inspector IDPH license # 100-09106

Signature:
Date: 9/30/2019

6. Management Planner

Management Planner Name: Amy Williams

Management Planner IDPH license # 100-00746

Signature:
Date: 10/24/2019

7. Review Date:10/24/2019

8. LEA Designated Person's Acknowledgement

The reinspection report and recommendations have been received by me and appropriate action will be taken by the School District.

Signature:



Date: 10/1/2019

Name: Robert Christlieb

II. EXECUTIVE SUMMARY

TEM Environmental, Inc. was retained by the Chicago Public Schools (CPS) to perform a three-year asbestos reinspection of the Lenart Center. This inspection was conducted in accordance with the United States Environmental Protection Agency (USEPA) Asbestos Hazard Emergency Response Act (AHERA) part 763.85 (b), and the ongoing Operations and Maintenance Program (O&M) originally designed in the School's Asbestos Management Plan. The purpose of this three-year reinspection is to record any condition changes in the asbestos-containing building material (ACBM) in the school since the previous three-year reinspection and the six-month periodic surveillance, to identify, assess, and include any Homogeneous Areas (HA) not identified in the Management Plan, and to recommend an appropriate response action to manage asbestos.

The inspector conducted a three-year reinspection of this facility under Illinois Department of Public Health (IDPH) school reinspection requirements and AHERA, sections 763.85 and 763.88. The main building and each addition to the main building, if constructed at different dates, were inspected separately. Laboratory accreditations are included in Appendix C, laboratory results are included in Appendix D, and chain of custody forms are included in Appendix E.

Note: During previous inspections, some of the HA(s) were identified together as 9" x 9" floor tile (FT), mastics assoc. with 9" x 9" FT, 12" x 12" FT, mastics assoc. with 12" x 12" FT, pipe insulation, etc. Some of these HA(s) have been re-identified by areas that are uniform in color, texture, construction date, application date, and general appearance.

The inspector has determined the following:

A. The following HAs have changed assessment categories for Building 7240:

B. The following new homogenous areas have been identified for Building 7240:

C. This reinspection covered only physically accessible and visible areas and materials that were identified in the LEA's management plan. The following materials were concealed and/or contained in areas that were inaccessible for sampling and have been classified as Assumed:

16	Tank Insulation
17	Aircell Pipe Insulation
18	Plaster
19	Braided Pipe Wrap
20	Green Linoleum Flooring Mastic
CM-1	Carpet Mastic
FT-2	Cream/Peach Linoleum
FT-3	12x12 Teal Floor Tile (part of checkerboard)
FT-4	12x12 Caramel Floor Tile
FT-7	Blue Linoleum
FT-8	12x12 White Floor Tile
FT-9	Brown Linoleum
FTM-1	9x9 Brown Floor Tile Mastic
FTM-7	Blue Linoleum Mastic
FTM-8	12x12 White Floor Tile Mastic
FTM-9	Brown Linoleum Mastic

The following areas were deemed to be inaccessible:

20	Green Linoleum Flooring Mastic
CM-1	Carpet Mastic
FTM-1	9x9 Brown Floor Tile Mastic
FTM-3	12x12 Teal Floor Tile Mastic
FTM-4	12x12 Caramel Floor Tile Mastic
FTM-5	9x9 Green Floor Tile Mastic
FTM-6	9x9 Tan Floor Tile Mastic
FTM-7	Blue Linoleum Mastic
FTM-8	12x12 White Floor Tile Mastic
FTM-9	Brown Linoleum Mastic

Materials were also listed as "assumed" if they were in good condition and sampling was not conducted to avoid damage.

This reinspection was conducted by Michael Hasier, IDPH License # 100-09106. The Management Plan was updated by Amy Williams, IDPH License # 100-00746. Inspector and Management Planner Licenses are included in Appendix B.

III. METHODOLOGY

Tasks performed on-site included the following:

1. Review current management plan, identify HA(s) and extract appropriate information.
2. Examine and verify abatement records.
3. Touch and visually and physically reinspect and reassess the condition of all friable known or assumed ACBM.
4. Touch and visually and physically reinspect all non-friable known or assumed ACBM to determine whether these materials have become friable since the last inspection or periodic surveillance.
5. Identify any condition changes that may affect Hazard ranking of known ACBM or Assumed ACBM, as well as any HA(s) that have become friable since the last reinspection.
6. Collect bulk samples from each newly discovered friable HA or previously assumed and submit for laboratory analysis.
7. Tabulate reinspection findings and submit for management planner review and recommendations with appropriate response actions based on the AHERA Damage Category of the ACBM.
8. Submit reinspection findings and management planner recommendations to the LEA within thirty (30) days for inclusion into the management plan.

IV. ABATEMENT HISTORY

The information collected from the existing management plan and inspection report(s) and from interviews with the school official revealed that the following asbestos abatement was conducted at the school since the previous Three year Reinspection.

Abatement Dates:

V. REASSESSMENTS AND RECOMMENDATIONS

The reassessments and recommendations are summarized in Tables I and II on the following pages. Detailed Hazard Assessment Sheets and Drawings and Photos (if applicable) are included in Appendix A.

VI. CONCLUSIONS

The Lenart Center Building 7240 Three-Year reinspection has been completed and response actions have been recommended for both friable and non-friable materials. A timely execution of the response actions recommended will enable the LEA and the Designated Person(s) to effectively manage the existing ACBM.

This three-year reinspection report should be inspected in the current Management plan at the CPS Central Office, and one (1) copy should be kept at the school for use when planning any renovation and/or demolition activities in areas where ACBM has been identified. Also, periodic surveillance documentation and any summary reports from any response actions that are executed at the school should be used to update the Management Plan.

Table I
Inspector's Reinspection Findings

Chicago Public Schools

School Lenart Center Unit 29361 Building ID 7240

Address 8101 S. LaSalle Street Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) TEM Environmental, Inc.

174 N. Brandon Drive Glendale Heights, IL, 60139

Phone: 630-790-0880 Fax: 630-790-0882

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
10	Aircell Pipe Insulation	1,000	LF	Unexcavated Areas, Heat Plenums, Pump Room, Supply Room	CHR	TSI	Y	DIST	40		No	Damaged or significantly damaged friable thermal system insulating ACBM	3	HIGH
11	Aircell Fittings	200	SF	Unexcavated Areas, Heat Plenums, Pump Room, Supply Room	CHR	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
12	Aircell Duct Wrap	300	SF	Unexcavated Areas	CHR	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
13	Cardboard Pipe Insulation	270	LF	Unexcavated Areas and South Heat Plenum	CHR	TSI	Y	DIST	30		No	Damaged or significantly damaged friable thermal system insulating ACBM	5	HIGH
14	Cardboard Pipe Fittings	50	LF	Unexcavated Areas and South Heat Plenum	CHR	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
15	Rope Pipe Insulation	60	LF	North and South Fan Rooms	CHR	MISC	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
16	Tank Insulation	80	SF	Upper Tank Room, Boiler Room	ASSUMED	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
17	Aircell Pipe Insulation	190	LF	Below the Upper Tank	ASSUMED	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
18	Plaster	80,000	SF	Core Walls of Tunnel and Throughout	ASSUMED	SURFACE	N	NONE	0		No	ACBM with the potential for damage		LOW
19	Braided Pipe Wrap	10	LF	Auditorium Stage Stair Area	ASSUMED	TSI	Y	NONE	0		No	Any remaining friable ACBM or friable suspect ACBM		LOW
20	Green Linoleum Flooring Mastic	2,000	SF	2nd Floor SE Corridor and Elevator Lobby on 1st, 2nd, & 3rd Floors	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
CM-1	Carpet Mastic	2,750	SF	Room 110, Principal's Office, Main Office, General Office, Copy/Store Room	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT-1	9x9 Brown Floor Tile	2,600	SF	Engineer's Office, Restroom and	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lenart Center Unit 29361 Building ID 7240

Address 8101 S. LaSalle Street Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) TEM Environmental, Inc.

174 N. Brandon Drive Glendale Heights, IL, 60139

Phone: 630-790-0880 Fax: 630-790-0882

Inspector's Comments are Summarized at the End of the Report

HA No	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Type	Damage Quantity	Damage Units	Change in Assessment Category	Damage Category	Damage Reason	Disturbance Potential
				Auditorium										
FT-2	Cream/Peach Linoleum	1,300	SF	Lunchroom & Boys' Locker Room	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT-3	12x12 Teal Floor Tile (part of checkerboard)	1,385	SF	1st Floor Corridor	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT-4	12x12 Caramel Floor Tile	3,025	SF	1st & 3rd Floor Corridor (1st Floor part of checkerboard)	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT-5	9x9 Green Floor Tile	725	SF	2nd Floor Corridor N/S (part of checkerboard)	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT-6	9x9 Tan Floor Tile	725	SF	2nd Floor Corridor N/S-part of checkerboard	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT-7	Blue Linoleum	1,500	SF	2nd Floor Computer Lab and Room 303	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT-8	12x12 White Floor Tile	250	SF	2nd Floor MDF Room, Next to Computer Lab	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FT-9	Brown Linoleum	450	SF	2nd Floor Elevator Lobby	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FTM-1	9x9 Brown Floor Tile Mastic	2,600	SF	Engineer's Office, Restroom, and Auditorium	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FTM-3	12x12 Teal Floor Tile Mastic	1,385	SF	1st Floor Corridor- (part of checkerboard)	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FTM-4	12x12 Caramel Floor Tile Mastic	3,025	SF	1st & 3rd Floor Corridor	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FTM-5	9x9 Green Floor Tile Mastic	725	SF	2nd Floor Corridor N/S-part of checkerboard	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FTM-6	9x9 Tan Floor Tile Mastic	725	SF	2nd Floor Corridor N/S-part of checkerboard	CHR	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FTM-7	Blue Linoleum Mastic	1,500	SF	2nd Floor Computer Lab and Room 303	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FTM-8	12x12 White Floor Tile Mastic	250	SF	2nd Floor MDF Room, Next to Computer Lab	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW
FTM-9	Brown Linoleum Mastic	450	SF	2nd Floor Elevator Lobby	ASSUMED	MISC	N	NONE	0		No	ACBM with the potential for damage		LOW

Chicago Public Schools

School Lenart Center Unit 29361 Building ID 7240

Address 8101 S. LaSalle Street Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) TEM Environmental, Inc.

174 N. Brandon Drive Glendale Heights, IL, 60139

Phone: 630-790-0880 Fax: 630-790-0882

Inspector's Comments are Summarized at the End of the Report

Reinspection Date	<u>9/30/2019</u>
Inspector Name	<u>Michael Hasier</u>
<u>100-09106</u>	<u>5/15/2020</u>
Inspector's IDPH License Number / Expiration Date	

Inspector's Comments

HA Number:	Inspector Comments:
10	No Change From 2016
11	
12	
13	No change from 2016
14	
15	
16	
17	
18	
19	
20	
CM-1	
FT-1	
FT-2	
FT-3	
FT-4	
FT-5	
FT-6	
FT-7	
FT-8	
FT-9	
FTM-1	
FTM-3	

Chicago Public Schools

School Lenart Center **Unit** 29361 **Building ID** 7240

Address 8101 S. LaSalle Street **Region** 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Inspector's Reinspection Findings Table 1

Managing Environmental Consultant (MEC) TEM Environmental, Inc.

174 N. Brandon Drive Glendale Heights, IL, 60139

Phone: 630-790-0880 Fax: 630-790-0882

Inspector's Comments are Summarized at the End of the Report

HA Number:	Inspector Comments:
FTM-4	
FTM-5	
FTM-6	
FTM-7	
FTM-8	
FTM-9	

Table II

Management Planner's Review

Chicago Public Schools

School Lenart Center
Address 8101 S. LaSalle Street

Unit 29361
Chicago, IL, 60620

Building ID 7240
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) TEM Environmental, Inc.
174 N. Brandon Drive Glendale Heights, IL, 60139

Phone: 630-790-0880 Fax: 630-790-0882

Management Planner's Comments Summarized at the End of the Report

HA Number	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
10	Aircell Pipe Insulation	1,000	LF	Unexcavated Areas. Heat Plenums, Pump Room, Supply Room	Chrysotile	TSI	Yes	40	LF	1 Damaged or significantly damaged friable thermal system insulating ACBM	Remove
11	Aircell Fittings	200	SF	Unexcavated Areas, Heat Plenums, Pump Room, Supply Room	Chrysotile	TSI	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
12	Aircell Duct Wrap	300	SF	Unexcavated Areas	Chrysotile	TSI	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
13	Cardboard Pipe Insulation	270	LF	Unexcavated Areas and South Heat Plenum	Chrysotile	TSI	Yes	30	LF	1 Damaged or significantly damaged friable thermal system insulating ACBM	Remove
14	Cardboard Pipe Fittings	50	LF	Unexcavated Areas and South Heat Plenum	Chrysotile	TSI	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
15	Rope Pipe Insulation	60	LF	North and South Fan Rooms	Chrysotile	MISC	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
16	Tank Insulation	80	SF	Upper Tank Room, Boiler Room	Assumed	TSI	Yes	0	SF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
17	Aircell Pipe Insulation	190	LF	Below the Upper Tank	Assumed	TSI	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
18	Plaster	80,000	SF	Core Walls of Tunnel and Throughout	Assumed	SURFACE	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
19	Braided Pipe Wrap	10	LF	Auditorium Stage Stair Area	Assumed	TSI	Yes	0	LF	7 Any remaining friable ACBM or friable suspect ACBM	Follow O&M Plan
20	Green Linoleum Flooring Mastic	2,000	SF	2nd Floor SE Corridor and Elevator Lobby on 1st, 2nd, & 3rd Floors	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
CM-1	Carpet Mastic	2,750	SF	Room 110, Principal's Office, Main Office, General Office, Copy/Store Room	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT-1	9x9 Brown Floor Tile	2,600	SF	Engineer's Office, Restroom and Auditorium	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT-2	Cream/Peach Linoleum	1,300	SF	Lunchroom & Boys' Locker Room	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT-3	12x12 Teal Floor Tile (part of checkerboard)	1,385	SF	1st Floor Corridor	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT-4	12x12 Caramel Floor Tile	3,025	SF	1st & 3rd Floor Corridor (1st Floor part of checkerboard)	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT-5	9x9 Green Floor Tile	725	SF	2nd Floor Corridor N/S (part of checkerboard)	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT-6	9x9 Tan Floor Tile	725	SF	2nd Floor Corridor N/S-part of checkerboard	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT-7	Blue Linoleum	1,500	SF	2nd Floor Computer Lab and Room	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Lenart Center
Address 8101 S. LaSalle Street

Unit 29361
Chicago, IL, 60620

Building ID 7240
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) TEM Environmental, Inc.

174 N. Brandon Drive Glendale Heights, IL, 60139

Phone: 630-790-0880 Fax: 630-790-0882

Management Planner's Comments Summarized at the End of the Report

HA Number	Material Description	Material Quantity	Material Units	Material Location	Asbestos Type	Material Category	Friable	Damage Quantity	Damage Units	Damage Category	Response
				303							
FT-8	12x12 White Floor Tile	250	SF	2nd Floor MDF Room, Next to Computer Lab	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FT-9	Brown Linoleum	450	SF	2nd Floor Elevator Lobby	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FTM-1	9x9 Brown Floor Tile Mastic	2,600	SF	Engineer's Office, Restroom, and Auditorium	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FTM-3	12x12 Teal Floor Tile Mastic	1,385	SF	1st Floor Corridor-(part of checkerboard)	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FTM-4	12x12 Caramel Floor Tile Mastic	3,025	SF	1st & 3rd Floor Corridor	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FTM-5	9x9 Green Floor Tile Mastic	725	SF	2nd Floor Corridor N/S-part of checkerboard	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FTM-6	9x9 Tan Floor Tile Mastic	725	SF	2nd Floor Corridor N/S-part of checkerboard	Chrysotile	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FTM-7	Blue Linoleum Mastic	1,500	SF	2nd Floor Computer Lab and Room 303	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FTM-8	12x12 White Floor Tile Mastic	250	SF	2nd Floor MDF Room, Next to Computer Lab	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan
FTM-9	Brown Linoleum Mastic	450	SF	2nd Floor Elevator Lobby	Assumed	MISC	No	0	SF	6 ACBM with the potential for damage	Follow O&M Plan

Chicago Public Schools

School Lenart Center
Address 8101 S. LaSalle Street

Unit 29361
Chicago, IL, 60620

Building ID 7240
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) TEM Environmental, Inc.

174 N. Brandon Drive Glendale Heights, IL, 60139

Phone: 630-790-0880 Fax: 630-790-0882

Management Planner's Comments Summarized at the End of the Report

Review Date	10/24/2019
Manager Planner Name	Amy Williams
100-00746	5/15/2020
Manager IDPH License No/Expiration	

HA Number	Management Comments
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
CM-1	
FT-1	
FT-2	
FT-3	
FT-4	
FT-5	
FT-6	
FT-7	

Chicago Public Schools

School Lenart Center
Address 8101 S. LaSalle Street

Unit 29361
Chicago, IL, 60620

Building ID 7240
Region 05

ASBESTOS REINSPECTION FINDINGS AND RECOMMENDATIONS

Management Planner's Review Table II

Managing Environmental Consultant (MEC) TEM Environmental, Inc.
174 N. Brandon Drive Glendale Heights, IL, 60139

Phone: 630-790-0880 Fax: 630-790-0882

Management Planner's Comments Summarized at the End of the Report

HA Number	Management Comments
FT-8	
FT-9	
FTM-1	
FTM-3	
FTM-4	
FTM-5	
FTM-6	
FTM-7	
FTM-8	
FTM-9	

Chicago Public Schools

TEM Environmental, Inc.

2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	10		
MATERIAL DESCRIPTION:	Aircell Pipe Insulation		
HISTORICAL AHERA DAMAGE CATEGORY	1 Damaged or significantly damaged friable thermal system insulating ACM		
HISTORICAL DAMAGE REASON:	Deterioration Physical Damage		
HISTORICAL RESPONSE ACTION:	Remove		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	Yes

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **1. Damaged or significantly damaged friable thermal system insulating ACM**

DAMAGE REASON:	Deterioration Physical Damage		
DISTURBANCE POTENTIAL:	HIGH		
MATERIAL LOCATION:	Unexcavated Areas. Heat Plenums, Pump Room, Supply Room		
MATERIAL QUANTITY:	1000	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	40	DAMAGE UNITS:	LF
COMMENTS:	No Change From 2016		

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	10		
MATERIAL DESCRIPTION:	Aircell Pipe Insulation		
MATERIAL LOCATION:	Unexcavated Areas. Heat Plenums, Pump Room, Supply Room		
MATERIAL QUANTITY:	1000	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	40	DAMAGE UNITS:	LF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Remove

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	11		
MATERIAL DESCRIPTION:	Aircell Fittings		
HISTORICAL AHERA DAMAGE CATEGORY	7 Any remaining friable ACBM or friable suspect ACBM		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	Yes

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Unexcavated Areas, Heat Plenums, Pump Room, Supply Room		
MATERIAL QUANTITY:	200	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	11		
MATERIAL DESCRIPTION:	Aircell Fittings		
MATERIAL LOCATION:	Unexcavated Areas, Heat Plenums, Pump Room, Supply Room		
MATERIAL QUANTITY:	200	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	12		
MATERIAL DESCRIPTION:	Aircell Duct Wrap		
HISTORICAL AHERA DAMAGE CATEGORY	7 Any remaining friable ACBM or friable suspect ACBM		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	Yes

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Unexcavated Areas		
MATERIAL QUANTITY:	300	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	12		
MATERIAL DESCRIPTION:	Aircell Duct Wrap		
MATERIAL LOCATION:	Unexcavated Areas		
MATERIAL QUANTITY:	300	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	13		
MATERIAL DESCRIPTION:	Cardboard Pipe Insulation		
HISTORICAL AHERA DAMAGE CATEGORY	1 Damaged or significantly damaged friable thermal system insulating ACM		
HISTORICAL DAMAGE REASON:	Physical Damage		
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	Yes

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **1. Damaged or significantly damaged friable thermal system insulating ACM**

DAMAGE REASON:	Physical Damage		
DISTURBANCE POTENTIAL:	HIGH		
MATERIAL LOCATION:	Unexcavated Areas and South Heat Plenum		
MATERIAL QUANTITY:	270	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	30	DAMAGE UNITS:	LF
COMMENTS:	No change from 2016		

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **29361** BUIDLING ID: **7240**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Amy Williams**
SCHOOL NAME: **Lenart Center** REVIEW DATE: **10/24/2019**
ADDRESS: **8101 S. LaSalle Street** IDPH LICENSE NO: **100-09106**

HOMOGENEOUS AREA: **13**
MATERIAL DESCRIPTION: **Cardboard Pipe Insulation**
MATERIAL LOCATION: **Unexcavated Areas and South Heat Plenum**
MATERIAL QUANTITY: **270** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **30** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **29361** BUILDING ID: **7240**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Michael Hasier**
SCHOOL NAME: **Lenart Center** INSPECTION DATE: **9/30/2019**
ADDRESS: **8101 S. LaSalle Street** IDPH LICENSE NO: **100-09106**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **14**
MATERIAL DESCRIPTION: **Cardboard Pipe Fittings**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Chrysotile** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Unexcavated Areas and South Heat Plenum**
MATERIAL QUANTITY: **50** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**
COMMENTS:

Inspector's Signature: _____ Date: **09/30/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	14		
MATERIAL DESCRIPTION:	Cardboard Pipe Fittings		
MATERIAL LOCATION:	Unexcavated Areas and South Heat Plenum		
MATERIAL QUANTITY:	50	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	LF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	15		
MATERIAL DESCRIPTION:	Rope Pipe Insulation		
HISTORICAL AHERA DAMAGE CATEGORY	7 Any remaining friable ACBM or friable suspect ACBM		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	Yes

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	North and South Fan Rooms		
MATERIAL QUANTITY:	60	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	LF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	15		
MATERIAL DESCRIPTION:	Rope Pipe Insulation		
MATERIAL LOCATION:	North and South Fan Rooms		
MATERIAL QUANTITY:	60	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	LF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **29361** BUILDING ID: **7240**
CITY/STATE: **Chicago, Illinois** AHERA INSPECTOR: **Michael Hasier**
SCHOOL NAME: **Lenart Center** INSPECTION DATE: **9/30/2019**
ADDRESS: **8101 S. LaSalle Street** IDPH LICENSE NO: **100-09106**

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA: **16**
MATERIAL DESCRIPTION: **Tank Insulation**
HISTORICAL AHERA DAMAGE CATEGORY **7 Any remaining friable ACBM or friable suspect ACBM**
HISTORICAL DAMAGE REASON:
HISTORICAL RESPONSE ACTION: **Follow O&M Plan**
ASBESTOS TYPE: **Assumed** FRIABLE: **Yes**

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL: **LOW**
MATERIAL LOCATION: **Upper Tank Room, Boiler Room**
MATERIAL QUANTITY: **80** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**
COMMENTS:

Inspector's Signature: _____ Date: **09/30/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	16		
MATERIAL DESCRIPTION:	Tank Insulation		
MATERIAL LOCATION:	Upper Tank Room, Boiler Room		
MATERIAL QUANTITY:	80	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	17		
MATERIAL DESCRIPTION:	Aircell Pipe Insulation		
HISTORICAL AHERA DAMAGE CATEGORY	7 Any remaining friable ACBM or friable suspect ACBM		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	Yes

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Below the Upper Tank		
MATERIAL QUANTITY:	190	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	LF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	17		
MATERIAL DESCRIPTION:	Aircell Pipe Insulation		
MATERIAL LOCATION:	Below the Upper Tank		
MATERIAL QUANTITY:	190	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	LF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	18		
MATERIAL DESCRIPTION:	Plaster		
HISTORICAL AHERA DAMAGE CATEGORY	6 Any remaining friable ACBM or friable suspect ACBM		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Core Walls of Tunnel and Throughout		
MATERIAL QUANTITY:	80000	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	18		
MATERIAL DESCRIPTION:	Plaster		
MATERIAL LOCATION:	Core Walls of Tunnel and Throughout		
MATERIAL QUANTITY:	80000	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	19		
MATERIAL DESCRIPTION:	Braided Pipe Wrap		
HISTORICAL AHERA DAMAGE CATEGORY	7 Any remaining friable ACBM or friable suspect ACBM		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	Yes

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **7. Any remaining friable ACBM or friable suspect ACBM**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Auditorium Stage Stair Area		
MATERIAL QUANTITY:	10	MATERIAL UNITS:	LF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	LF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **29361** BUIDLING ID: **7240**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Amy Williams**
SCHOOL NAME: **Lenart Center** REVIEW DATE: **10/24/2019**
ADDRESS: **8101 S. LaSalle Street** IDPH LICENSE NO: **100-09106**

HOMOGENEOUS AREA: **19**
MATERIAL DESCRIPTION: **Braided Pipe Wrap**
MATERIAL LOCATION: **Auditorium Stage Stair Area**
MATERIAL QUANTITY: **10** MATERIAL UNITS: **LF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **LF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	20		
MATERIAL DESCRIPTION:	Green Linoleum Flooring Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor SE Corridor and Elevator Lobby on 1st, 2nd, & 3rd Floors		
MATERIAL QUANTITY:	2000	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	20				
MATERIAL DESCRIPTION:	Green Linoleum Flooring Mastic				
MATERIAL LOCATION:	2nd Floor SE Corridor and Elevator Lobby on 1st, 2nd, & 3rd Floors				
MATERIAL QUANTITY:	2000	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	CM-1		
MATERIAL DESCRIPTION:	Carpet Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Room 110, Principal's Office, Main Office, General Office, Copy/Store Room		
MATERIAL QUANTITY:	2750	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF

COMMENTS:

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	CM-1				
MATERIAL DESCRIPTION:	Carpet Mastic				
MATERIAL LOCATION:	Room 110, Principal's Office, Main Office, General Office, Copy/Store Room				
MATERIAL QUANTITY:	2750	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-1		
MATERIAL DESCRIPTION:	9x9 Brown Floor Tile		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Engineer's Office, Restroom and Auditorium		
MATERIAL QUANTITY:	2600	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-1		
MATERIAL DESCRIPTION:	9x9 Brown Floor Tile		
MATERIAL LOCATION:	Engineer's Office, Restroom and Auditorium		
MATERIAL QUANTITY:	2600	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-2		
MATERIAL DESCRIPTION:	Cream/Peach Linoleum		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Lunchroom & Boys' Locker Room		
MATERIAL QUANTITY:	1300	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-2		
MATERIAL DESCRIPTION:	Cream/Peach Linoleum		
MATERIAL LOCATION:	Lunchroom & Boys' Locker Room		
MATERIAL QUANTITY:	1300	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-3		
MATERIAL DESCRIPTION:	12x12 Teal Floor Tile (part of checkerboard)		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	1st Floor Corridor		
MATERIAL QUANTITY:	1385	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-3				
MATERIAL DESCRIPTION:	12x12 Teal Floor Tile (part of checkerboard)				
MATERIAL LOCATION:	1st Floor Corridor				
MATERIAL QUANTITY:	1385	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-4		
MATERIAL DESCRIPTION:	12x12 Caramel Floor Tile		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	1st & 3rd Floor Corridor (1st Floor part of checkerboard)		
MATERIAL QUANTITY:	3025	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-4				
MATERIAL DESCRIPTION:	12x12 Caramel Floor Tile				
MATERIAL LOCATION:	1st & 3rd Floor Corridor (1st Floor part of checkerboard)				
MATERIAL QUANTITY:	3025	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-5		
MATERIAL DESCRIPTION:	9x9 Green Floor Tile		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor Corridor N/S (part of checkerboard)		
MATERIAL QUANTITY:	725	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-5				
MATERIAL DESCRIPTION:	9x9 Green Floor Tile				
MATERIAL LOCATION:	2nd Floor Corridor N/S (part of checkerboard)				
MATERIAL QUANTITY:	725	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-6		
MATERIAL DESCRIPTION:	9x9 Tan Floor Tile		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor Corridor N/S-part of checkerboard		
MATERIAL QUANTITY:	725	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-6				
MATERIAL DESCRIPTION:	9x9 Tan Floor Tile				
MATERIAL LOCATION:	2nd Floor Corridor N/S-part of checkerboard				
MATERIAL QUANTITY:	725	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-7		
MATERIAL DESCRIPTION:	Blue Linoleum		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor Computer Lab and Room 303		
MATERIAL QUANTITY:	1500	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-7		
MATERIAL DESCRIPTION:	Blue Linoleum		
MATERIAL LOCATION:	2nd Floor Computer Lab and Room 303		
MATERIAL QUANTITY:	1500	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-8		
MATERIAL DESCRIPTION:	12x12 White Floor Tile		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor MDF Room, Next to Computer Lab		
MATERIAL QUANTITY:	250	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-8				
MATERIAL DESCRIPTION:	12x12 White Floor Tile				
MATERIAL LOCATION:	2nd Floor MDF Room, Next to Computer Lab				
MATERIAL QUANTITY:	250	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FT-9		
MATERIAL DESCRIPTION:	Brown Linoleum		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor Elevator Lobby		
MATERIAL QUANTITY:	450	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FT-9				
MATERIAL DESCRIPTION:	Brown Linoleum				
MATERIAL LOCATION:	2nd Floor Elevator Lobby				
MATERIAL QUANTITY:	450	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FTM-1		
MATERIAL DESCRIPTION:	9x9 Brown Floor Tile Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	Engineer's Office, Restroom, and Auditorium		
MATERIAL QUANTITY:	2600	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FTM-1				
MATERIAL DESCRIPTION:	9x9 Brown Floor Tile Mastic				
MATERIAL LOCATION:	Engineer's Office, Restroom, and Auditorium				
MATERIAL QUANTITY:	2600	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FTM-3		
MATERIAL DESCRIPTION:	12x12 Teal Floor Tile Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	1st Floor Corridor-(part of checkerboard)		
MATERIAL QUANTITY:	1385	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **29361** BUILDING ID: **7240**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Amy Williams**
SCHOOL NAME: **Lenart Center** REVIEW DATE: **10/24/2019**
ADDRESS: **8101 S. LaSalle Street** IDPH LICENSE NO: **100-09106**

HOMOGENEOUS AREA: **FTM-3**
MATERIAL DESCRIPTION: **12x12 Teal Floor Tile Mastic**
MATERIAL LOCATION: **1st Floor Corridor-(part of checkerboard)**
MATERIAL QUANTITY: **1385** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FTM-4		
MATERIAL DESCRIPTION:	12x12 Caramel Floor Tile Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	1st & 3rd Floor Corridor		
MATERIAL QUANTITY:	3025	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FTM-4				
MATERIAL DESCRIPTION:	12x12 Caramel Floor Tile Mastic				
MATERIAL LOCATION:	1st & 3rd Floor Corridor				
MATERIAL QUANTITY:	3025	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FTM-5		
MATERIAL DESCRIPTION:	9x9 Green Floor Tile Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor Corridor N/S-part of checkerboard		
MATERIAL QUANTITY:	725	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FTM-5				
MATERIAL DESCRIPTION:	9x9 Green Floor Tile Mastic				
MATERIAL LOCATION:	2nd Floor Corridor N/S-part of checkerboard				
MATERIAL QUANTITY:	725	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FTM-6		
MATERIAL DESCRIPTION:	9x9 Tan Floor Tile Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Chrysotile	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor Corridor N/S-part of checkerboard		
MATERIAL QUANTITY:	725	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **29361** BUIDLING ID: **7240**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Amy Williams**
SCHOOL NAME: **Lenart Center** REVIEW DATE: **10/24/2019**
ADDRESS: **8101 S. LaSalle Street** IDPH LICENSE NO: **100-09106**

HOMOGENEOUS AREA: **FTM-6**
MATERIAL DESCRIPTION: **9x9 Tan Floor Tile Mastic**
MATERIAL LOCATION: **2nd Floor Corridor N/S-part of checkerboard**
MATERIAL QUANTITY: **725** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FTM-7		
MATERIAL DESCRIPTION:	Blue Linoleum Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor Computer Lab and Room 303		
MATERIAL QUANTITY:	1500	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FTM-7				
MATERIAL DESCRIPTION:	Blue Linoleum Mastic				
MATERIAL LOCATION:	2nd Floor Computer Lab and Room 303				
MATERIAL QUANTITY:	1500	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FTM-8		
MATERIAL DESCRIPTION:	12x12 White Floor Tile Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6 ACBM with the potential for damage		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:	Follow O&M Plan		
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor MDF Room, Next to Computer Lab		
MATERIAL QUANTITY:	250	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc. 2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	MANAGEMENT PLANNER:	Amy Williams		
SCHOOL NAME:	Lenart Center	REVIEW DATE:	10/24/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

HOMOGENEOUS AREA:	FTM-8				
MATERIAL DESCRIPTION:	12x12 White Floor Tile Mastic				
MATERIAL LOCATION:	2nd Floor MDF Room, Next to Computer Lab				
MATERIAL QUANTITY:	250	MATERIAL UNITS:	SF		
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF		

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Follow O&M Plan

Comments:

Management Planner's Signature: _____ Date: 10/24/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Inspector Assessment Form (REASSESSMENT)

LEA NAME:	Chicago Public Schools	UNIT NUMBER:	29361	BUILDING ID:	7240
CITY/STATE:	Chicago, Illinois	AHERA INSPECTOR:	Michael Hasier		
SCHOOL NAME:	Lenart Center	INSPECTION DATE:	9/30/2019		
ADDRESS:	8101 S. LaSalle Street	IDPH LICENSE NO:	100-09106		

INFORMATION FROM PREVIOUS INSPECTION

HOMOGENEOUS AREA:	FTM-9		
MATERIAL DESCRIPTION:	Brown Linoleum Mastic		
HISTORICAL AHERA DAMAGE CATEGORY	6		
HISTORICAL DAMAGE REASON:			
HISTORICAL RESPONSE ACTION:			
ASBESTOS TYPE:	Assumed	FRIABLE:	No

RESULTS OF REINSPECTION AND REASSESSMENT

This homogeneous area was re-inspected and reassessed in accordance with Section 763.85 and 763.88 of AHERA and it's condition HAS NOT CHANGED when compared to the conditions of the last AHERA reinspection.

The current AHERA DAMAGE CATEGORY is determined to be **6. ACBM with the potential for damage**

DAMAGE REASON:

DISTURBANCE POTENTIAL:	LOW		
MATERIAL LOCATION:	2nd Floor Elevator Lobby		
MATERIAL QUANTITY:	450	MATERIAL UNITS:	SF
DAMAGE QUANTITY:	0	DAMAGE UNITS:	SF
COMMENTS:			

Inspector's Signature: _____ Date: 09/30/2019

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

Management Planner Review Form

LEA NAME: **Chicago Public Schools** UNIT NUMBER: **29361** BUIDLING ID: **7240**
CITY/STATE: **Chicago, Illinois** MANAGEMENT PLANNER: **Amy Williams**
SCHOOL NAME: **Lenart Center** REVIEW DATE: **10/24/2019**
ADDRESS: **8101 S. LaSalle Street** IDPH LICENSE NO: **100-09106**

HOMOGENEOUS AREA: **FTM-9**
MATERIAL DESCRIPTION: **Brown Linoleum Mastic**
MATERIAL LOCATION: **2nd Floor Elevator Lobby**
MATERIAL QUANTITY: **450** MATERIAL UNITS: **SF**
DAMAGE QUANTITY: **0** DAMAGE UNITS: **SF**

In accordance with Sections 763.88 and 763.90 of the Asbestos Hazard Emergency Response Act (AHERA) the LEA must select a management planner to review the results of the inspection and assessment and recommend appropriate response actions. The original inspection of the above identified homogeneous area has been reviewed in accordance with Sections 763.88 and 763.90 with the following recommendations.

The RESPONSE ACTION recommendation is:

Comments:

Management Planner's Signature: _____ Date: **10/24/2019**

Chicago Public Schools

TEM Environmental, Inc.
2019 AHERA REINSPECTION

APPENDIX B

Inspector and Management Planner Licenses

CERTIFICATE OF ACHIEVEMENT ASBESTOS ABATEMENT

Accredited by the Illinois Department of Public Health

This is to certify that MICHAEL HASIER
has completed the ASBESTOS INSPECTOR'S REFRESHER course and successfully passed the
examination on 05/01/2019 with a minimum score of 70% or better. Training was in accordance
with U.S. E.P.A. 40 CFR 763 Subpart E, Appendix C, Asbestos Containing Materials in Schools:
Model Accreditation Plan, TSCA II, Authorized by both AHERA & ASHARA.

05/01/2019

Course Dates:

05/01/2020

Expires:

1905BIR02

Certificate Number:



PUBLIC HEALTH & SAFETY inc.

Environmental and Occupational Services
375 S. Arland Ave., Chicago, IL 60607

www.public-health-safety.com

Office: 312-491-0081
Fax: 312-421-2901

Director of Training

Nicholas J. Peneff

Doctor of Public Health

Phone: 312-491-0081

FORM # A-010B

COPY OF THE ASBESTOS PROFESSIONAL LICENSE

Front of License

Back of License



ASBESTOS PROFESSIONAL LICENSE

ENDORSEMENTS

TO EXPIRES

SUPERVISOR/WORKER

3/1/2020

INSPECTOR

5/1/2020

ID NUMBER

ISSUED

EXPIRES

100 - 09106

5/8/2019

05/15/2020

PROJECT MANAGER

3/1/2020

MICHAEL S HASIER

444 OLD BARN RD., APT. B
BARRINGTON, IL 60010

Environmental Health



AIR SAMPLING PROFESSIONAL

Alteration of this license shall result in legal action
This license issued under authority of the State of Illinois
Department of Public Health

This license is valid only when accompanied by a valid
training course certificate.

Reliable
Environmental
Solutions, Inc. **RES**

This is to certify that **Amy J. Williams**

*has on 04/03/19, in Springfield, Illinois,
completed the requirements for asbestos accreditation under Section 206 of TSCA Title II*

Asbestos Building Inspector Refresher Training

*as accredited by the State of Illinois and approved by the U.S.E.P.A. under 40 CFR 763 (AHERA)
and passed the associated examination with a score of 70% or higher*

Course Date: April 03, 2019

COURSE LENGTH: 4 HOURS

Examination Date: April 03, 2019

Expiration Date: April 03, 2020

Certificate Number: BIR/0808

William S. Williams

Training Program Manager, William S. Williams

4211 Westgate Drive, Springfield, Illinois ☐ 217.787.9800 ☐ 217.787.9801 FAX ☐ www.ReliableEnv.com



2539 Vandalia Street, Collinsville, IL 62234 * Phone: 618-855-8764

Environmental and Occupational Safety & Health Training

Does hereby certify

William Williams

4211 Westgate Drive, Springfield, IL 62711

*Has successfully completed and passed the course examination with at least
70% for re-accreditation under AHERA (Title II)*

Asbestos Management Planner Refresher


Class Date: 02/15/2019
Examination Date: 02/15/2019
STC Certificate Number: STC-20190215-000527AMPR
Certification Expiration: 02/15/2020

David M. Mendoza – President/Training Director
Certified Environmental Specialist
OSHA Authorized Instructor

COPY OF THE ASBESTOS PROFESSIONAL LICENSE

Front of License

Back of License



ASBESTOS PROFESSIONAL LICENSE

ENDORSEMENTS

TC EXPIRES

INSPECTOR

4/21/2019

ID NUMBER

ISSUED

EXPIRES

100 - 00746

4/11/2019

05/15/2020

MANAGEMENT PLANNER

4/21/2019

PROJECT MANAGER

4/2/2020


AIR SAMPLING PROFESSIONAL

AMY J WILLIAMS

1408 S CLAY

JACKSONVILLE, IL 62650

Environmental Health



Alteration of this license shall result in legal action
This license issued under authority of the State of Illinois
Department of Public Health
This license is valid only when accompanied by a valid
training course certificate.

APPENDIX C

Laboratory Accreditations

APPENDIX D

Laboratory Results

APPENDIX E

Chain of Custody Forms

Three-Year Reinspection Key to Terms

	CODE	KEY
MATERIAL		
	ACBM	Asbestos Containing Building Materials
MATERIAL CATEGORY		
	MISC	Miscellaneous
	SURF	Surfacing
	TSI	Thermal System Insulation
MATERIAL UNITS		
	LF	Linear Feet
	SF	Square Feet
	CF	Cubic Feet
DAMAGE TYPE		
	Loc	Localized
	Dist	Distributed