

## Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at [http://www.cps.edu/About\\_CPS/Policies\\_and\\_guidelines/Pages/facilitystandards.aspx](http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx).

### Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.<sup>1</sup>

### Definitions

**Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.

**Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

**Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

**For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**

**Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

### Building: Main Category: EXTERIOR

| Group    | Sub Group | Item                                  | Location             | Rank | Quantity | Unit | Cost      | Reason   |
|----------|-----------|---------------------------------------|----------------------|------|----------|------|-----------|--|
| Canopy   |           | Metal Canopy                          | Main Entrance        | 6    | 3,650    | SF   | \$87,844  |  |
| Canopy   |           | Metal Canopy                          | South entrance       | 3    | 950      | SF   | \$152,424 | Water infiltration from roof of canopy into building. Floor tiles at entrance are de-laminated due to water infiltration |
| Chimney  |           | Brick Chimney - Stainless Steel Liner | South side of boiler | 5    | 140      | LF   | \$170,170 |  |
| Doors    |           | Exterior Steel Door                   | Entire Building      | 4    | 21       | EA   | \$69,369  |  |
| Doors    |           | Overhead Rolling / Garage Door        | South Façade         | 6    | 1        | EA   | \$1,027   |  |
| Doors    |           | Side Lite                             | Entire Building      | 7    | 15       | EA   | \$0       |  |
| Doors    |           | Store Front Door                      | Main Entrance        | 7    | 9        | EA   | \$0       |  |
| Doors    |           | Transom Lite                          | Entire Building      | 7    | 6        | EA   | \$0       |  |
| Entrance |           | Concrete Exterior Stairs              | Main Entrance        | 7    | 60       | LF   | \$0       |  |
| Entrance |           | Concrete Ramp                         | Central Courtyard    | 7    | 70       | LF   | \$0       |  |

**Building: Main**  
**Category: EXTERIOR**

| Group                     | Sub Group | Item                                      | Location                     | Rank | Quantity | Unit | Cost               | Reason  |
|---------------------------|-----------|---|------------------------------|------|----------|------|--------------------|---|
| Entrance                  |           | Entrance Controls - Audio and Video       | Main Entrance                | 7    | 1        | EA   | \$0                |   |
| Entrance                  |           | Power Door Operator and Controls          | Main Entrance                | 7    | 1        | EA   | \$0                |   |
| Foundation                |           | Concrete Foundation                       | Entire Building              | 7    | 148,000  | LF   | \$0                |   |
| Lighting                  |           | Exterior Lights - Parapet or Roof Mounted | Pole near dumpster enclosure | 6    | 4        | EA   | \$2,002            |   |
| Lighting                  |           | Exterior Lights - Parapet or Roof Mounted | North Courtyard              | 6    | 6        | EA   | \$3,003            | Clean lenses, photocells  |
| Lighting                  |           | Exterior Lights - Parapet or Roof Mounted | South Courtyard              | 6    | 4        | EA   | \$2,002            | Clean lenses  |
| Lighting                  |           | Exterior Lights - Parapet or Roof Mounted | Northeast corner             | 6    | 1        | EA   | \$501              |   |
| Lighting                  |           | Exterior Lights - Wall Mounted            | South of south entrance      | 5    | 2        | EA   | \$1,001            | Not working   |
| Lighting                  |           | Exterior Lights - Wall Mounted            | Above west roll-up door      | 6    | 1        | EA   | \$215              |   |
| Lighting                  |           | Exterior Lights - Wall Mounted            | Entire Building              | 6    | 58       | EA   | \$12,441           |   |
| Lintels                   |           | Lintels - Steel                           | Entire Building              | 7    | 75       | LF   | \$0                |   |
| Parapet                   |           | Coping - Metal                            | Main Roofs                   | 6    | 2,340    | LF   | \$0                |   |
| Parapet                   |           | Coping - Metal                            | Main Roofs                   | 7    | 1,020    | LF   | \$0                |   |
| Parapet                   |           | Parapet < 16" Height                      | Main Roofs                   | 7    | 120      | LF   | \$0                |   |
| Roof System               |           | Asphalt Gravel Ballast Roof               | Main Roofs                   | 6    | 94,056   | SF   | \$599,870          |   |
| Roof System               |           | EPDM/ Synthetic Rubber Roof               | North end and central area.  | 5    | 29,217   | SF   | \$250,682          | Bulding membrane at seams. Also low point of roof is not located at the roof drain. |
| Roof System               |           | Interior Downspouts                       | Entire Building              | 6    | 450      | LF   | \$0                |   |
| Roof System               |           | Roof Structure: Concrete                  | Main Roof                    | 7    | 148,000  | SF   | \$0                |   |
| Superstructure            |           | Concrete                                  | Entire Building              | 7    | 148,000  | SF   | \$0                |   |
| Walls                     |           | Brick                                     | Entire Building              | 6    | 45,350   | SF   | \$299,609          |   |
| Walls                     |           | Prefabricated Metal Panel Wall            | Entire Building              | 6    | 4,164    | SF   | \$35,370           |   |
| Walls                     |           | Prefabricated Metal Panel Wall            | Entire Building              | 6    | 2,910    | SF   | \$24,718           |   |
| Windows                   |           | Window - Guards perforated                | Entire Building              | 3    | 6,420    | SF   | \$490,795          | High percentage of them are broken  |
| Windows                   |           | Window - Guards wire guard                | Gym interiors                | 6    | 1,762    | SF   | \$0                |   |
| Windows                   |           | Windows - Sash Aluminum Double-pane       | South facade of              | 3    | 936      | SF   | \$161,662          | Balances completely broken  |
| Windows                   |           | Windows - Sash Aluminum Double-pane       | Entire Building              | 6    | 12,340   | SF   | \$105,877          |   |
| <b>EXTERIOR Sub Total</b> |           |   |                              |      |          |      | <b>\$2,470,581</b> |   |

**Building: Main**  
**Category: ELECTRICAL**

| Group            | Sub Group | Item                      | Location        | Rank | Quantity | Unit | Cost    | Reason |
|------------------|-----------|---------------------------|-----------------|------|----------|------|---------|--------|
| Emergency System |           | Automatic Transfer switch | Mechanical Room | 6    | 1        | EA   | \$1,430 |        |

**Building: Main**  
**Category: ELECTRICAL**

| Group              | Sub Group | Item  | Location             | Rank | Quantity | Unit | Cost      | Reason  |
|--------------------|-----------|---|----------------------|------|----------|------|-----------|---|
| Emergency System   |           | Emergency A/C power - Auditorium and aisle lighting               | Auditorium           | 2    | 6,408    | SF   | \$44,443  |   |
| Emergency System   |           | Emergency A/C power - Corridors and Stairs                        | Corridors and Stairs | 6    | 20,160   | SF   | \$8,649   |   |
| Emergency System   |           | Emergency A/C power - Gym and Lunch rooms                         | Gym                  | 6    | 15,530   | SF   | \$8,217   |   |
| Emergency System   |           | Emergency A/C power - Gym and Lunch rooms                         | Lunch Room           | 6    | 8,325    | SF   | \$4,405   |   |
| Emergency System   |           | Emergency A/C power - Students Toilets                            | Student Toilets      | 6    | 2,610    | SF   | \$1,120   |   |
| Emergency System   |           | Emergency Battery Packs - Corridors and Stairs                    | Corridors and Stairs | 6    | 30       | EA   | \$3,218   |   |
| Emergency System   |           | Emergency Battery Packs - Lunchroom and Gym                       | Gym                  | 6    | 9        | EA   | \$965     |   |
| Emergency System   |           | Emergency Battery Packs - Lunchroom and Gym                       | Lunch Room           | 6    | 7        | EA   | \$751     | Needs Batteries   |
| Emergency System   |           | Exit Signs - Auditorium   | Auditorium           | 6    | 8        | EA   | \$1,865   |   |
| Emergency System   |           | Exit Signs - Corridors and Stairs                                 | Corridors and Stairs | 6    | 28       | EA   | \$6,527   |   |
| Emergency System   |           | Exit Signs - Lunchroom - Gym - multipurpose rooms                 | Gym                  | 6    | 12       | EA   | \$2,797   |   |
| Emergency System   |           | Exit Signs - Lunchroom - Gym - multipurpose rooms                 | Lunch Room           | 6    | 8        | EA   | \$1,865   |   |
| Emergency System   |           | Public Announcement System  | Entire Building      | 6    | 148,000  | SF   | \$88,889  |   |
| Emergency System   |           | Security System - Intrusion detection                             | Entire Building      | 6    | 148,000  | SF   | \$137,566 |   |
| Emergency System   |           | System 1 emergency service configuration                          | Entire Building      | 6    | 148,000  | SF   | \$84,656  |   |
| Emergency System   |           | UPS 30 to 60 KW   | Mechanical Room      | 6    | 1        | EA   | \$13,585  |   |
| Main Service       |           | Main Electrical service - Live Front - 1500 A 120/208/3PH         | Mechanical Room      | 3    | 1        | EA   | \$130,416 | Switch gear is significantly deteriorated and substantially corroded due to water or steam leakage. |
| Main Service       |           | Main Electrical service - Live Front - 2000 to 3000 A 120/208/3PH | Mechanical Room      | 4    | 1        | EA   | \$257,400 |   |
| Power Distribution |           | Lighting and power panels   | Entire Building      | 4    | 9        | EA   | \$48,906  |   |
| Power Distribution |           | Lighting and power panels   | Entire Building      | 6    | 32       | EA   | \$22,880  |   |
| Power Distribution |           | Lighting and power panels   | Entire Building      | 6    | 4        | EA   | \$2,860   |   |
| Power Distribution |           | Main distribution panels 400-600 amp                              | Entire Building      | 6    | 1        | EA   | \$1,430   |   |
| Power Distribution |           | Main distribution panels above 600 amp                            | Entire Building      | 6    | 5        | EA   | \$10,725  |   |
| Power Distribution |           | Main distribution panels less than 400 amp                        | Entire Building      | 6    | 2        | EA   | \$2,431   |   |

**ELECTRICAL Sub Total \$887,993**

**Building: Main**  
**Category: FIRE PROTECTION**

| Group      | Sub Group | Item                     | Location        | Rank | Quantity | Unit | Cost      | Reason |
|------------|-----------|--------------------------|-----------------|------|----------|------|-----------|--------|
| Fire Alarm |           | Fire Alarm Strobe Lights | Entire Building | 6    | 148,000  | SF   | \$52,910  |        |
| Fire Alarm |           | Fire Alarm System        | Entire Building | 6    | 148,000  | SF   | \$179,894 |        |

**FIRE PROTECTION Sub Total \$232,804**

**Building: Main**  
**Category: MECHANICAL**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

**Building: Main**  
**Category: MECHANICAL**

| Group                | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost      | Reason   |
|----------------------|-----------|---|-----------------|------|----------|------|-----------|--|
| Air Conditioning     |           | Condensing Unit - Roof Mounted less than 5 tons                               | Roof            | 6    | 1        | EA   | \$858     |  |
| Air Conditioning     |           | Condensing Unit - Roof Mounted less than 5 tons                               | Roof            | 6    | 2        | EA   | \$1,716   |  |
| Air Conditioning     |           | Window A/C Unit   | Entire Building | 6    | 9        | EA   | \$1,931   |  |
| Air Conditioning     |           | Window A/C Unit   | Entire Building | 3    | 4        | EA   | \$8,580   | Units Inoperative  |
| Air Handling Systems |           | Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm       | Entire Building | 2    | 1        | EA   | \$62,920  | unit is inoperable the coil is leaking)  |
| Air Handling Systems |           | Air Handling Unit Package - Single Zone - Steam 4,000 to 8,000 cfm            | Entire Building | 2    | 1        | EA   | \$50,050  | unit is inoperable r the coil is leaking)  |
| Air Handling Systems |           | Air Handling Unit Package - Single Zone - Steam 8,001 to 12,000 cfm           | Entire Building | 5    | 1        | EA   | \$21,450  | Unit cannot maintain the proper temperatures during severe weather condition dampers are not fully opened, valves are not operating properly |
| Air Handling Systems |           | Air Handling Unit Package - Single Zone - Steam less than 4,000 cfm           | Entire Building | 5    | 3        | EA   | \$30,030  | Unit cannot maintain the proper temperatures during severe weather condition dampers are not fully opened, valves are not operating properly |
| Air Handling Systems |           | Air Handling Unit Package - Single Zone - Steam less than 4,000 cfm           | Entire Building | 2    | 3        | EA   | \$107,250 | Unit is inoperable the coil is leaking/busted  |
| Air Handling Systems |           | Air intake for all Air Handling Units except built up AHU                     | Entire Building | 6    | 10       | EA   | \$14,300  |  |
| Air Handling Systems |           | Return Fans - Indoor 10,001 to 20,000 CFM                                     | Mechanical Room | 5    | 3        | EA   | \$36,465  |  |
| Air Handling Systems |           | Return Fans - Indoor 5,000 to 10,000 CFM                                      | Mechanical Room | 5    | 3        | EA   | \$17,160  |  |
| Air Handling Systems |           | Return Fans - Indoor greater than 20,000 CFM                                  | Mechanical Room | 5    | 1        | EA   | \$16,445  |  |
| Air Handling Systems |           | Single Zone Built Up Air Handling Unit - Steam 4,000 to 8,000 cfm             | Mechanical Room | 2    | 2        | EA   | \$51,480  | dampers are not fully opened, valves are not operating properly  |
| Air Handling Systems |           | Single Zone Built Up Air Handling Unit Auxiliaries - Steam 4,000 to 8,000 cfm | Mechanical Room | 2    | 2        | EA   | \$14,300  | dampers are not fully opened, valves are not operating properly  |
| Boiler Systems       |           | Boiler Assembly - Steam - Flexible Tube Boiler greater than 200 HP            | Boiler Room     | 6    | 3        | EA   | \$92,664  |  |
| Boiler Systems       |           | Boiler Auxiliary - Steam Boiler greater than 200 HP                           | Boiler Room     | 6    | 3        | EA   | \$9,867   |  |
| Boiler Systems       |           | Chemical Feed System (Steam Boilers)  | Boiler Room     | 6    | 1        | EA   | \$2,145   |  |

**Building: Main**  
**Category: MECHANICAL**

| Group               | Sub Group | Item   | Location         | Rank | Quantity | Unit | Cost        | Reason  |
|---------------------|-----------|--|------------------|------|----------|------|-------------|---|
| Boiler Systems      |           | Combustion Dampers                             | Boiler Room      | 3    | 2        | EA   | \$11,154    | Combustion intake damper is inoperable and has failed in the open position,   |
| Boiler Systems      |           | Feed Water Pumps and Tank - Steam Boilers      | Boiler Room      | 3    | 3        | EA   | \$94,380    | Only two pumps are operable, with one or more redundant pumps out of service.   |
| Heat Exchangers     |           | Heat Exchanger - Steam to Hot Water Shell Type | Boiler Room      | 4    | 1        | EA   | \$21,164    |   |
| Heating Devices     |           | Cabinet Heaters With Steam Coils               | Entire Building  | 6    | 10       | EA   | \$5,005     |   |
| Heating Devices     |           | Radiators - Steam                              | Entire Building  | 5    | 73       | EA   | \$48,019    |   |
| Mechanical Plumbing |           | Condensate Assembly - Pumps and Tank           | Tunnel           | 3    | 2        | EA   | \$57,200    | Condensate pump system is not working   |
| Mechanical Plumbing |           | Condensate Assembly - Pumps and Tank           | Basement         | 5    | 3        | EA   | \$28,314    |   |
| Mechanical Plumbing |           | Piping - Condensate - Steel or Galvanized      | Entire Building  | 4    | 800      | LF   | \$78,364    |   |
| Mechanical Plumbing |           | Piping - Steam - Steel or Galvanized           | Entire Building  | 4    | 800      | LF   | \$95,810    |   |
| Mechanical Plumbing |           | Piping - Steam - Steel or Galvanized           | Boys Locker Room | 3    | 20       | LF   | \$2,395     | Steam Line has failed - Locker Room Unit cannot be run.   |
| Mechanical Plumbing |           | Pumps - Vacuum                                 | Boiler Room      | 6    | 2        | EA   | \$5,720     |   |
| Temperature Control |           | Pneumatic System                               | Entire Building  | 2    | 148,000  | SF   | \$1,058,200 | Controls are more than 30 years of age. The pneumatic controls do not work (control dampers and control valve actuators do not work), Compressor cannot maintain the system pressure, Refrigerated dryer does not work. |
| Temperature Control |           | Thermostats - Pneumatic                        | Entire Building  | 4    | 91       | EA   | \$59,860    |   |
| Unit Ventilation    |           | Unit Ventilators - Steam                       | Entire Building  | 4    | 56       | EA   | \$880,880   | the dampers and controls are inoperable   |
| Unit Ventilation    |           | Unit Ventilators - Steam                       | Entire Building  | 2    | 10       | EA   | \$157,300   | fan is not working, the dampers and controls are inoperable   |
| Ventilation         |           | Exhaust Fan - Indoor                           | Entire Building  | 4    | 2        | EA   | \$11,154    |   |
| Ventilation         |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof             | 3    | 1        | EA   | \$4,290     | cap is missing  |
| Ventilation         |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof             | 6    | 3        | EA   | \$1,287     |   |
| Ventilation         |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm   | Roof             | 6    | 13       | EA   | \$2,974     |   |
| Ventilation         |           | Exhaust Fans - Roof mounted less than 500 CFM  | Roof             | 6    | 4        | EA   | \$629       |   |
| Ventilation         |           | Lab Exhaust Hood                               | Room 108         | 6    | 1        | EA   | \$3,289     |   |

**Building: Main**  
**Category: MECHANICAL**

| Group                       | Sub Group | Item   | Location | Rank | Quantity | Unit | Cost               | Reason                           |
|-----------------------------|-----------|--|----------|------|----------|------|--------------------|----------------------------------|
| Ventilation                 |           | Type I Exhaust Hood - Kitchen or Culinary Arts | Kitchen  | 2    | 2        | EA   | \$53,768           | Fire suppression does not exist. |
| <b>MECHANICAL Sub Total</b> |           |  |          |      |          |      | <b>\$3,220,768</b> |                                  |

**Building: Main**  
**Category: PLUMBING**

| Group     | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost      | Reason  |
|-----------|-----------|--|-----------------|------|----------|------|-----------|---|
| Hot Water |           | Hot Water Heater - Gas 150,000 -300,000 BTU/HR       | Basement        | 6    | 2        | EA   | \$8,294   |   |
| Hot Water |           | Hot Water Heater - Gas more than 300,000 BTU/HR      | Boiler Room     | 6    | 1        | EA   | \$6,721   |   |
| Hot Water |           | Storage Tank more than 500 gallons                   | Basement        | 4    | 2        | EA   | \$57,200  |   |
| Piping    |           | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 4    | 148,000  | SF   | \$48,677  |   |
| Piping    |           | Domestic Piping - Cold Water Risers                  | Entire Building | 4    | 148,000  | SF   | \$95,238  |   |
| Piping    |           | Domestic Piping - Hot Water from Riser to fixtures   | Entire Building | 4    | 148,000  | SF   | \$31,746  | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed. |
| Piping    |           | Domestic Piping - Hot Water Return Risers            | Entire Building | 4    | 148,000  | SF   | \$67,725  | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed. |
| Piping    |           | Domestic Piping - Hot Water Risers                   | Entire Building | 4    | 148,000  | SF   | \$80,423  | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed. |
| Piping    |           | Domestic Piping Cold Water Horizontal lines          | Entire Building | 4    | 148,000  | SF   | \$353,439 |   |
| Piping    |           | Domestic Piping Hot Water Horizontal lines           | Entire Building | 4    | 148,000  | SF   | \$292,063 |   |
| Piping    |           | Domestic Piping Hot Water Return Lines               | Entire Building | 4    | 148,000  | SF   | \$169,312 | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed. |
| Piping    |           | Sanitary Piping                                      | Entire Building | 3    | 148,000  | SF   | \$141,799 | More than 40 years of age and there are many pipe clamps installed.                       |
| Piping    |           | Storm Piping   | Entire Building | 4    | 148,000  | SF   | \$105,820 |   |
| Piping    |           | Vent Piping  | Entire Building | 4    | 148,000  | SF   | \$84,656  |   |
| Pumps     |           | Domestic Booster Pump simplex                        | Boiler Room     | 2    | 1        | EA   | \$17,160  | Pump is more than 20 years of age and is not working,                                     |
| Pumps     |           | Domestic Booster Pump simplex                        | Boiler Room     | 2    | 1        | EA   | \$17,160  | System is inoperative   |

**Building: Main**  
**Category: PLUMBING**

| Group                     | Sub Group | Item         | Location    | Rank | Quantity | Unit | Cost               | Reason  |
|---------------------------|-----------|--------------|-------------|------|----------|------|--------------------|---|
| Pumps                     |           | Ejector Pump | Boiler Room | 3    | 1        | EA   | \$30,030           | The pumps are more than 20 years of age and one of the two pumps is not working and the other pump is in poor condition |
| <b>PLUMBING Sub Total</b> |           |              |             |      |          |      | <b>\$1,607,463</b> |   |

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                      | Location                                  | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|---------------------------|---|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Exposed         | 1st floor to north of Auditorium #135     | 6    | 183      | SF   | \$345   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In          | 1st floor to north of Auditorium #137     | 6    | 140      | SF   | \$300   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Basement engineer's office                | 6    | 204      | SF   | \$578   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 112A                                      | 7    | 127      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 1st floor Rm113-Police office             | 6    | 150      | SF   | \$425   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 1st floor to north of Auditorium #136     | 6    | 142      | SF   | \$305   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 1st floor Rms 131 & 131B                  | 6    | 1,390    | SF   | \$2,982 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 2nd floor Rm. 218A                        | 6    | 300      | SF   | \$644   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 2nd floor at SW                           | 6    | 235      | SF   | \$504   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 1st floor 3 offices #117, 117B & 119      | 6    | 2,461    | SF   | \$5,279 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 1st floor #123                            | 6    | 460      | SF   | \$987   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 1st floor main office                     | 6    | 3,600    | SF   | \$7,722 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 1st floor rm #118                         | 6    | 1,600    | SF   | \$3,432 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | First floor, room 133, vocal music office | 6    | 96       | SF   | \$206   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 1st floor inside girls gym                | 6    | 110      | SF   | \$236   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | 1st floor 2 offices inside boys gym       | 6    | 220      | SF   | \$472   |        |

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                       | Location                                  | Rank | Quantity | Unit | Cost    | Reason     |
|-----------------------|-------------------------------|----------------------------|---|------|----------|------|---------|------------|
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet          | 2nd floor at SW                           | 6    | 235      | SF   | \$336   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet          | 1st floor to north of Auditorium #137     | 6    | 140      | SF   | \$200   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet          | 1st floor Rms 131 & 131B                  | 6    | 1,390    | SF   | \$1,988 |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet          | 1st floor main office                     | 6    | 3,600    | SF   | \$5,148 |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Concrete        | Basement engineer's office                | 6    | 204      | SF   | \$963   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor to north of Auditorium #136     | 6    | 142      | SF   | \$203   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor Rm113-Police office             | 6    | 150      | SF   | \$215   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor #123                            | 6    | 460      | SF   | \$658   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 112A                                      | 6    | 127      | SF   | \$182   | Vinyl tile |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor 2 offices inside boys gym       | 6    | 220      | SF   | \$315   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor 3 offices #117, 117B & 119      | 6    | 2,461    | SF   | \$3,519 |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor inside girls gym                | 6    | 110      | SF   | \$157   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | First floor, room 133, vocal music office | 6    | 96       | SF   | \$137   |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 1st floor rm #118                         | 6    | 1,600    | SF   | \$2,288 |            |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | 2nd floor Rm. 218A                        | 6    | 300      | SF   | \$429   |            |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | 1st floor to north of Auditorium #137     | 6    | 2        | SF   | \$1     |            |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | 1st floor main office                     | 6    | 28       | SF   | \$20    |            |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor 3 offices #117, 117B & 119      | 6    | 36       | SF   | \$26    |            |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 112A                                      | 7    | 2        | SF   | \$0     |            |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | First floor, room 133, vocal music office | 6    | 1        | SF   | \$1     |            |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Basement engineer's office                | 4    | 4        | SF   | \$26    | T-12       |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor inside girls gym                | 6    | 2        | SF   | \$1     |            |



**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                       | Location                                  | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|----------------------------|---|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 2nd floor Rm. 218A                        | 6    | 10       | SF   | \$7     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor 2 offices inside boys gym       | 6    | 4        | SF   | \$3     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor rm #118                         | 6    | 35       | SF   | \$25    |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor #123                            | 6    | 8        | SF   | \$6     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor Rm113-Police office             | 6    | 1        | SF   | \$1     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 2nd floor at SW                           | 6    | 4        | SF   | \$3     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor Rms 131 & 131B                  | 6    | 17       | SF   | \$12    |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor to north of Auditorium #135     | 6    | 2        | SF   | \$1     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 1st floor to north of Auditorium #136     | 6    | 2        | SF   | \$1     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 1st floor Rms 131 & 131B                  | 6    | 1,811    | SF   | \$5,179 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | Basement engineer's office                | 6    | 700      | SF   | \$2,002 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 1st floor #123                            | 6    | 774      | SF   | \$2,214 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, room 133, vocal music office | 7    | 123      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 2nd floor at SW                           | 6    | 645      | SF   | \$1,845 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 1st floor to north of Auditorium #136     | 6    | 416      | SF   | \$1,190 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 1st floor 3 offices #117, 117B & 119      | 6    | 2,636    | SF   | \$7,539 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 1st floor rm #118                         | 6    | 1,600    | SF   | \$4,576 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 112A                                      | 6    | 260      | SF   | \$744   |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 1st floor Rm113-Police office             | 6    | 400      | SF   | \$1,144 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 1st floor 2 offices inside boys gym       | 6    | 640      | SF   | \$1,830 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 1st floor inside girls gym                | 6    | 320      | SF   | \$915   |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | 2nd floor Rm. 218A                        | 6    | 760      | SF   | \$2,174 |        |

**Building: Main**  
**Category: INTERIOR**

| Group                  | Sub Group                     | Item                           | Location   | Rank | Quantity | Unit | Cost      | Reason              |
|------------------------|-------------------------------|--------------------------------|--|------|----------|------|-----------|---------------------|
| Administrative Suites  | Administrative Suites/Offices | Walls - Concrete Block         | 1st floor to north of Auditorium #135              | 6    | 621      | SF   | \$1,776   |                     |
| Administrative Suites  | Administrative Suites/Offices | Walls - Concrete Block         | 1st floor to north of Auditorium #137              | 6    | 416      | SF   | \$1,190   |                     |
| Administrative Suites  | Administrative Suites/Offices | Walls - Concrete Block         | 1st floor main office                              | 6    | 6,750    | SF   | \$19,305  |                     |
| Auditorium - Dedicated | Auditorium - Dedicated        | Main Floor Seating             | 1st Floor  | 6    | 640      | EA   | \$23,557  |                     |
| Auditorium - Dedicated | Auditorium - Dedicated        | Sound System                   | 1st Floor  | 6    | 1        | EA   | \$35,750  |                     |
| Auditorium - Dedicated | Auditorium - Dedicated        | Stage Curtains                 | 1st Floor  | 6    | 2        | EA   | \$22,651  |                     |
| Auditorium - Dedicated | Auditorium - Dedicated        | Stage Lighting System          | 1st Floor  | 6    | 1        | EA   | \$114,400 |                     |
| Auditorium - Dedicated |                               | Stage Platform                 | 1st Floor  | 6    | 1,400    | SF   | \$5,946   |                     |
| Corridor               |                               | Ceiling - Lay-In               | 1st Floor  | 6    | 20,160   | SF   | \$43,243  |                     |
| Corridor               |                               | Ceiling - Splined              | 2nd Floor  | 6    | 7,440    | SF   | \$15,959  |                     |
| Corridor               |                               | Flooring Tile/ Sheet           | 1st floor main entrance next to main office suites | 4    | 100      | SF   | \$1,416   | Floor tiles missing |
| Corridor               |                               | Flooring Tile/ Sheet           | 1st Floor  | 6    | 20,160   | SF   | \$28,829  |                     |
| Corridor               |                               | Flooring Tile/ Sheet           | 2nd Floor  | 6    | 7,440    | SF   | \$10,639  |                     |
| Corridor               |                               | Lighting - Lay-In              | 1st Floor  | 6    | 20,160   | SF   | \$14,414  |                     |
| Corridor               |                               | Lighting - Lay-In              | 2nd Floor  | 6    | 7,440    | SF   | \$5,320   |                     |
| Corridor               |                               | Stair Handrails                | Basement   | 7    | 96       | LF   | \$0       |                     |
| Corridor               |                               | Stair Handrails                | 1st Floor  | 7    | 192      | LF   | \$0       |                     |
| Corridor               |                               | Stairs - Tile                  | 1st Floor  | 6    | 96       | LF   | \$725     |                     |
| Corridor               |                               | Stairs - Tile                  | Basement   | 6    | 48       | LF   | \$362     |                     |
| Corridor               |                               | Student Lockers                | 2nd Floor  | 6    | 400      | EA   | \$57,200  |                     |
| Corridor               |                               | Student Lockers                | 1st Floor  | 6    | 678      | EA   | \$96,954  |                     |
| Corridor               |                               | Walls - Concrete Block         | 1st Floor  | 6    | 4,300    | SF   | \$12,298  |                     |
| Corridor               |                               | Walls - Masonry                | 1st Floor  | 6    | 8,000    | SF   | \$102,960 |                     |
| Corridor               |                               | Walls - Plaster/Drywall        | 1st Floor  | 6    | 4,300    | SF   | \$10,146  |                     |
| Corridor               |                               | Walls - Plaster/Drywall        | 2nd Floor  | 6    | 4,340    | SF   | \$10,240  |                     |
| Corridor               |                               | Walls - Structural Glazed Tile | 2nd Floor  | 6    | 6,200    | SF   | \$44,330  |                     |
| Corridor               |                               | Walls - Structural Glazed Tile | 1st Floor  | 6    | 12,000   | SF   | \$85,800  |                     |
| Doors                  |                               | Interior Steel Doors incl hw   | Basement   | 6    | 5        | EA   | \$1,416   |                     |
| Doors                  |                               | Interior Steel Doors incl hw   | 1st Floor  | 6    | 132      | EA   | \$37,374  |                     |
| Doors                  |                               | Interior Steel Doors incl hw   | 2nd Floor  | 6    | 40       | EA   | \$11,326  |                     |
| Doors                  |                               | Interior Wood Doors incl hw    | 2nd Floor  | 6    | 10       | EA   | \$2,831   |                     |
| Doors                  |                               | Interior Wood Doors incl hw    | 1st Floor  | 6    | 75       | EA   | \$21,236  |                     |
| Doors                  |                               | Interior Wood Doors incl hw    | 1st floor entrance to Boys gym                     | 4    | 1        | EA   | \$3,209   | Door broken         |
| Doors                  |                               | Side-lite                      | 1st Floor  | 6    | 420      | SF   | \$7,808   |                     |

**Building: Main**  
**Category: INTERIOR**

| Group                  | Sub Group                    | Item                                 | Location  | Rank | Quantity | Unit | Cost     | Reason                                    |
|------------------------|------------------------------|--------------------------------------|---|------|----------|------|----------|---|
| Doors                  |                              | Side-lite                            | 1st Floor                                       | 6    | 117      | SF   | \$2,175  |   |
| Doors                  |                              | Side-lite                            | 2nd Floor                                       | 6    | 270      | SF   | \$5,019  |   |
| Doors                  |                              | Store Front Door                     | 1st Floor                                       | 7    | 1        | EA   | \$0      |   |
| Doors                  |                              | Transom Window                       | 2nd Floor                                       | 6    | 84       | SF   | \$1,562  |   |
| Drinking Fountains     |                              | Double Fountain                      | 2nd Floor                                       | 6    | 4        | EA   | \$2,631  |   |
| Drinking Fountains     |                              | Double Fountain                      | 1st Floor                                       | 6    | 6        | EA   | \$3,947  |   |
| Drinking Fountains     |                              | Single Fountain                      | 1st Floor                                       | 5    | 1        | EA   | \$1,931  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating                     | 1st floor boys                                  | 6    | 300      | EA   | \$7,250  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Exposed                    | 1st floor girls gym                             | 6    | 5,476    | SF   | \$41,659 |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Exposed                    | 1st floor boys                                  | 6    | 8,743    | SF   | \$66,513 |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Plaster/Drywall            | 1st floor weight room to east of boys locker rm | 6    | 1,311    | SF   | \$11,211 |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Wood                      | 1st floor boys                                  | 6    | 8,743    | SF   | \$66,013 |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Wood                      | 1st floor girls gym                             | 6    | 5,476    | SF   | \$41,346 |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Wood                      | 1st floor weight room to east of boys locker rm | 6    | 1,311    | SF   | \$9,899  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Metal Halide/Sodium Vapor | 1st floor girls gym                             | 6    | 32       | EA   | \$5,720  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Metal Halide/Sodium Vapor | 1st floor boys                                  | 6    | 40       | EA   | \$7,150  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Pendant/Surface           | 1st floor weight room to east of boys locker rm | 6    | 12       | EA   | \$1,459  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards                          | 1st floor boys                                  | 5    | 2        | EA   | \$13,704 | One is not working per building engineer. |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System                         | 1st floor girls gym                             | 6    | 1        | EA   | \$5,005  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System                         | 1st floor weight room to east of boys locker rm | 6    | 1        | EA   | \$5,005  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System                         | 1st floor boys                                  | 6    | 1        | EA   | \$5,005  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Concrete Block               | 1st floor girls gym                             | 6    | 5,380    | SF   | \$46,160 |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Concrete Block               | 1st floor boys                                  | 6    | 8,542    | SF   | \$73,290 |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Concrete Block               | 1st floor weight room to east of boys locker rm | 6    | 780      | SF   | \$6,692  |   |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Structural Glazed Tile       | 1st floor girls gym                             | 6    | 1,794    | SF   | \$12,827 |   |

**Building: Main**  
**Category: INTERIOR**

| Group                    | Sub Group                    | Item                              | Location  | Rank | Quantity | Unit | Cost      | Reason  |
|--------------------------|------------------------------|-----------------------------------|---|------|----------|------|-----------|---|
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium | Walls - Structural Glazed Tile    | 1st floor boys                                  | 6    | 2,136    | SF   | \$15,272  |   |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium | Walls - Structural Glazed Tile    | 1st floor weight room to east of boys locker rm | 6    | 780      | SF   | \$5,577   |   |
| Kitchen                  | Cooking Kitchen              | Ceiling - Plaster/Drywall         | 1st Floor                                       | 6    | 1,890    | SF   | \$7,135   |   |
| Kitchen                  | Cooking Kitchen              | Flooring - Tile Ceramic/Porcelain | 1st Floor                                       | 6    | 1,890    | SF   | \$4,811   |   |
| Kitchen                  | Cooking Kitchen              | Lighting - Pendant/Surface        | 1st Floor                                       | 6    | 20       | SF   | \$14      |   |
| Kitchen                  | Cooking Kitchen              | Wall - Concrete Block             | 1st Floor                                       | 6    | 1,800    | SF   | \$5,148   |   |
| Library                  | Library                      | Ceiling - Splined                 | 1st Floor                                       | 6    | 3,360    | SF   | \$7,207   |   |
| Library                  | Library                      | Flooring Tile/ Sheet              | 1st Floor                                       | 6    | 3,360    | SF   | \$4,805   |   |
| Library                  | Library                      | Lighting - Lay-In                 | 1st Floor                                       | 6    | 105      | SF   | \$75      |   |
| Locker/Shower Room       | Locker/Shower Room           | Benches                           | 1st floor girls                                 | 6    | 180      | LF   | \$1,030   |   |
| Locker/Shower Room       | Locker/Shower Room           | Benches                           | 1st floor boys                                  | 6    | 180      | LF   | \$1,030   |   |
| Locker/Shower Room       | Staff Restroom               | Lockers                           | 1st floor inside office #137                    | 6    | 3        | EA   | \$147     |   |
| Locker/Shower Room       | Locker/Shower Room           | Lockers                           | 1st floor girls                                 | 6    | 206      | EA   | \$10,110  |   |
| Locker/Shower Room       | Locker/Shower Room           | Lockers                           | 1st floor boys                                  | 6    | 160      | EA   | \$7,852   |   |
| Locker/Shower Room       | Locker/Shower Room           | Lockers                           | 1st floor employee inside kitchen               | 6    | 28       | EA   | \$1,374   |   |
| Locker/Shower Room       | Locker/Shower Room           | Lockers                           | Basement  | 6    | 4        | EA   | \$196     |   |
| Locker/Shower Room       | Locker/Shower Room           | Showers                           | 1st floor girls                                 | 6    | 7        | EA   | \$1,702   |   |
| Locker/Shower Room       | Locker/Shower Room           | Showers                           | 1st floor boys                                  | 6    | 7        | EA   | \$1,702   |   |
| Locker/Shower Room       | Locker/Shower Room           | Showers                           | Basement  | 6    | 1        | EA   | \$243     |   |
| Lunchroom                | Lunchroom                    | Ceiling - Splined                 | 1st Floor                                       | 6    | 8,325    | SF   | \$17,857  |   |
| Lunchroom                | Lunchroom                    | Flooring - Tile/Sheet             | 1st Floor                                       | 6    | 8,325    | SF   | \$11,905  |   |
| Lunchroom                | Lunchroom                    | Lighting - Pendant/Surface        | 1st Floor                                       | 6    | 120      | SF   | \$86      |   |
| Lunchroom                | Lunchroom                    | Serving Line                      | 1st Floor                                       | 7    | 120      | LF   | \$0       |   |
| Lunchroom                | Lunchroom                    | Wall - Concrete Block             | 1st Floor                                       | 6    | 4,200    | SF   | \$12,012  |   |
| Lunchroom                | Lunchroom                    | Wall - Structural Glazed Tile     | 1st Floor                                       | 6    | 2,100    | SF   | \$15,015  |   |
| MDF/IDF                  |                              | Finishes                          | 1st floor inside office #123                    | 6    | 182      | SF   | \$619     |   |
| MDF/IDF                  |                              | Ventilation and Cooling           | 1st floor inside office #123                    | 6    | 1        | EA   | \$1,401   |   |
| Mechanical/Service Rooms |                              | Boiler Room                       | Basement boiler room                            | 5    | 2,560    | SF   | \$28,994  | T-12 lights   |
| Mechanical/Service Rooms |                              | Crawl Space - Unfinished          | Basement  | 6    | 75,600   | SF   | \$142,703 |   |
| Mechanical/Service Rooms |                              | Janitor's Closet                  | Entire Building                                 | 6    | 5        | SF   | \$24      |   |
| Mechanical/Service Rooms |                              | Janitor's Closet                  | 2nd floor at NE                                 | 3    | 1        | SF   | \$28      | Possible water leaking through roof damaging electrical conduits; electric conduits failed, exposing wires. |

**Building: Main**  
**Category: INTERIOR**

| Group                    | Sub Group                       | Item                     | Location  | Rank | Quantity | Unit | Cost     | Reason  |
|--------------------------|---------------------------------|--------------------------|---|------|----------|------|----------|---|
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms | 1st floor next to boiler room - receiving rm & 2 storages | 6    | 1,120    | SF   | \$5,285  |   |
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms | 2nd Floor   | 6    | 7,800    | SF   | \$36,808 |   |
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms | Basement emergent power panel rm                          | 5    | 567      | SF   | \$6,422  | Ground water leakages through concrete floor slab |
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms | 1st floor elevator machine room                           | 7    | 83       | SF   | \$0      |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 2nd floor next to elevator                                | 6    | 200      | SF   | \$944    |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 2nd floor Rm #224 Book Storage                            | 5    | 600      | SF   | \$6,795  |   |
| Mechanical/Service Rooms |                                 | Storage Room             | First floor, room 133, storage rooms                      | 6    | 510      | SF   | \$2,407  | six storage rooms                                 |
| Mechanical/Service Rooms |                                 | Storage Room             | First floor, room 133,storage                             | 6    | 106      | SF   | \$500    |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 1st floor 2 storages off boys gym                         | 6    | 300      | SF   | \$1,416  |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 116A  | 6    | 27       | SF   | \$127    |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 112B  | 6    | 43       | SF   | \$203    |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 110A  | 6    | 177      | SF   | \$835    |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 106A  | 6    | 114      | SF   | \$538    |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 104B  | 5    | 177      | SF   | \$2,005  |   |
| Mechanical/Service Rooms |                                 | Storage Room             | Basement 2 storage  | 6    | 1,280    | SF   | \$6,040  |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 104C  | 6    | 203      | SF   | \$958    |   |
| Mechanical/Service Rooms |                                 | Storage Room             | 1st floor at SE   | 6    | 300      | SF   | \$1,416  |   |
| Mechanical/Service Rooms |                                 | Vaults                   | Basement  | 5    | 600      | SF   | \$6,795  | T-12 lights                                       |
| Staff Restroom           | Adult Standard Student Restroom | Accessories              | 1st floor boys along corridor at SE                       | 6    | 205      | SF   | \$1,583  |   |
| Staff Restroom           | Adult Standard Student Restroom | Accessories              | 1st floor girls along corridor at SE                      | 6    | 229      | SF   | \$1,768  |   |
| Staff Restroom           | Adult Standard Student Restroom | Accessories              | 2nd floor boys along corridor at NW                       | 6    | 205      | SF   | \$1,583  |   |
| Staff Restroom           | Adult Standard Student Restroom | Accessories              | 1st floor girls along corridor at NE                      | 6    | 229      | SF   | \$1,768  |   |
| Staff Restroom           | Adult Standard Student Restroom | Accessories              | 1st floor boys along corridor at NE                       | 6    | 205      | SF   | \$1,583  |   |
| Staff Restroom           | Adult Standard Student Restroom | Accessories              | 1st floor boys along corridor at NW                       | 6    | 205      | SF   | \$1,583  |   |
| Staff Restroom           | Adult Standard Student Restroom | Accessories              | 1st floor girls along corridor at NW                      | 6    | 229      | SF   | \$1,768  |   |
| Staff Restroom           | Staff Restroom                  | Accessories              | 1st floor inside office #137                              | 6    | 96       | SF   | \$741    |   |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                      | Location                              | Rank | Quantity | Unit | Cost     | Reason |
|----------------|---------------------------------|---------------------------|---------------------------------------|------|----------|------|----------|--------|
| Staff Restroom | Adult Standard Student Restroom | Accessories               | 2nd floor girls along corridor at NW  | 6    | 229      | SF   | \$1,768  |        |
| Staff Restroom | Adult Standard Student Restroom | Accessories               | 2nd floor girls along corridor at NE  | 6    | 229      | SF   | \$1,768  |        |
| Staff Restroom | Adult Standard Student Restroom | Accessories               | 2nd floor girls along corridor at SE  | 6    | 229      | SF   | \$1,768  |        |
| Staff Restroom | Locker/Shower Room              | Accessories               | 1st floor boys                        | 6    | 3,150    | SF   | \$24,324 |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor inside main office          | 6    | 48       | SF   | \$371    |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor unisex next to boiler room  | 6    | 65       | SF   | \$502    |        |
| Staff Restroom | Locker/Shower Room              | Accessories               | 1st floor employee inside kitchen     | 6    | 288      | SF   | \$2,224  |        |
| Staff Restroom | Adult Standard Student Restroom | Accessories               | 2nd floor boys along corridor at NE   | 6    | 205      | SF   | \$1,583  |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor inside principal office     | 6    | 22       | SF   | \$170    |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor inside nurses office        | 6    | 15       | SF   | \$116    |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor men's next to boiler room   | 6    | 194      | SF   | \$1,498  |        |
| Staff Restroom | Locker/Shower Room              | Accessories               | 1st floor girls                       | 6    | 3,150    | SF   | \$24,324 |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor women's next to boiler room | 6    | 115      | SF   | \$888    |        |
| Staff Restroom | Locker/Shower Room              | Accessories               | Basement                              | 6    | 191      | SF   | \$1,475  |        |
| Staff Restroom | Adult Standard Student Restroom | Accessories               | 2nd floor boys along corridor at SE   | 6    | 205      | SF   | \$1,583  |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor next to lunch room          | 6    | 293      | SF   | \$2,263  |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 2nd floor NW                          | 6    | 293      | SF   | \$2,263  |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor inside office in boys gym   | 6    | 22       | SF   | \$170    |        |
| Staff Restroom | Staff Restroom                  | Accessories               | 1st floor inside office in girls gym  | 6    | 22       | SF   | \$170    |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Exposed         | 1st floor men's next to boiler room   | 6    | 194      | SF   | \$366    |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Lay-In          | 1st floor unisex next to boiler room  | 6    | 65       | SF   | \$139    |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Lay-In          | 1st floor women's next to boiler room | 6    | 115      | SF   | \$247    |        |
| Staff Restroom | Locker/Shower Room              | Ceiling - Plaster/Drywall | Basement                              | 6    | 191      | SF   | \$541    |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd floor girls along corridor at NE  | 6    | 230      | SF   | \$651    |        |
| Staff Restroom | Locker/Shower Room              | Ceiling - Plaster/Drywall | 1st floor boys                        | 6    | 3,150    | SF   | \$8,919  |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                      | Location                             | Rank | Quantity | Unit | Cost  | Reason |
|----------------|---------------------------------|---------------------------|--------------------------------------|------|----------|------|-------|--------|
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st floor boys along corridor at NE  | 6    | 205      | SF   | \$580 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st floor boys along corridor at NW  | 6    | 205      | SF   | \$580 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st floor boys along corridor at SE  | 6    | 205      | SF   | \$580 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st floor girls along corridor at SE | 6    | 229      | SF   | \$648 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st floor girls along corridor at NE | 6    | 229      | SF   | \$648 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd floor boys along corridor at NW  | 6    | 206      | SF   | \$583 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd floor girls along corridor at NW | 6    | 230      | SF   | \$651 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd floor girls along corridor at SE | 6    | 230      | SF   | \$651 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd floor boys along corridor at NE  | 6    | 206      | SF   | \$583 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd floor boys along corridor at SE  | 6    | 206      | SF   | \$583 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st floor girls along corridor at NW | 6    | 229      | SF   | \$648 |        |
| Staff Restroom | Locker/Shower Room              | Ceiling - Splined         | 1st floor employee inside kitchen    | 6    | 288      | SF   | \$618 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Splined         | 1st floor inside main office         | 6    | 48       | SF   | \$103 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Splined         | 1st floor inside office in girls gym | 6    | 22       | SF   | \$47  |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Splined         | 1st floor inside office in boys gym  | 6    | 22       | SF   | \$47  |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Splined         | 2nd floor NW                         | 6    | 293      | SF   | \$628 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Splined         | 1st floor inside principal office    | 6    | 22       | SF   | \$47  |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Splined         | 1st floor inside office #137         | 6    | 96       | SF   | \$206 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Splined         | 1st floor next to lunch room         | 6    | 293      | SF   | \$628 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 2nd floor boys along corridor at NE  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 2nd floor boys along corridor at SE  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 1st floor boys along corridor at NE  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 2nd floor girls along corridor at NE | 6    | 1        | EA   | \$300 |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                              | Location                              | Rank | Quantity | Unit | Cost  | Reason |
|----------------|---------------------------------|-----------------------------------|---------------------------------------|------|----------|------|-------|--------|
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 2nd floor girls along corridor at SE  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Staff Restroom                  | Floor Drain                       | 1st floor women's next to boiler room | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Locker/Shower Room              | Floor Drain                       | Basement                              | 6    | 2        | EA   | \$601 |        |
| Staff Restroom | Staff Restroom                  | Floor Drain                       | 1st floor unisex next to boiler room  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 2nd floor boys along corridor at NW   | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 2nd floor girls along corridor at NW  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st floor boys along corridor at SE   | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st floor girls along corridor at NE  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st floor boys along corridor at NW   | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Locker/Shower Room              | Floor Drain                       | 1st floor boys                        | 6    | 3        | EA   | \$901 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st floor girls along corridor at NW  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Locker/Shower Room              | Floor Drain                       | 1st floor girls                       | 6    | 3        | EA   | \$901 |        |
| Staff Restroom | Locker/Shower Room              | Floor Drain                       | 1st floor employee inside kitchen     | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Staff Restroom                  | Floor Drain                       | 1st floor men's next to boiler room   | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st floor girls along corridor at SE  | 6    | 1        | EA   | \$300 |        |
| Staff Restroom | Locker/Shower Room              | Flooring - Concrete               | Basement                              | 6    | 191      | SF   | \$901 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor boys along corridor at NW   | 6    | 206      | SF   | \$524 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor girls along corridor at SE  | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor girls along corridor at NE  | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor girls along corridor at NW  | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor boys along corridor at NE   | 6    | 206      | SF   | \$524 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor girls along corridor at SE  | 6    | 229      | SF   | \$583 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor girls along corridor at NW  | 6    | 229      | SF   | \$583 |        |



**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                              | Location                              | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------------|---------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor girls along corridor at NE  | 6    | 229      | SF   | \$583   |        |
| Staff Restroom | Locker/Shower Room              | Flooring - Tile Ceramic/Porcelain | 1st floor girls                       | 6    | 2,700    | SF   | \$6,873 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor boys along corridor at SE   | 6    | 206      | SF   | \$524   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 1st floor unisex next to boiler room  | 6    | 65       | SF   | \$165   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 1st floor inside office #137          | 6    | 96       | SF   | \$244   |        |
| Staff Restroom | Locker/Shower Room              | Flooring - Tile Ceramic/Porcelain | 1st floor employee inside kitchen     | 6    | 288      | SF   | \$733   |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor boys along corridor at NE   | 6    | 205      | SF   | \$522   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 1st floor women's next to boiler room | 6    | 115      | SF   | \$293   |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor boys along corridor at SE   | 6    | 205      | SF   | \$522   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 1st floor inside office in boys gym   | 6    | 22       | SF   | \$56    |        |
| Staff Restroom | Locker/Shower Room              | Flooring - Tile Ceramic/Porcelain | 1st floor boys                        | 6    | 3,150    | SF   | \$8,018 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor boys along corridor at NW   | 6    | 205      | SF   | \$522   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 1st floor inside office in girls gym  | 6    | 22       | SF   | \$56    |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 1st floor men's next to boiler room   | 6    | 194      | SF   | \$494   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile/Sheet             | 2nd floor NW                          | 6    | 293      | SF   | \$419   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile/Sheet             | 1st floor inside nurses office        | 6    | 15       | SF   | \$21    |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile/Sheet             | 1st floor inside principal office     | 6    | 22       | SF   | \$31    |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile/Sheet             | 1st floor inside main office          | 6    | 48       | SF   | \$69    |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile/Sheet             | 1st floor next to lunch room          | 6    | 293      | SF   | \$419   |        |
| Staff Restroom | Staff Restroom                  | Hand Dryer                        | 1st floor women's next to boiler room | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Staff Restroom                  | Hand Dryer                        | 1st floor unisex next to boiler room  | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Locker/Shower Room              | Hand Dryer                        | 1st floor girls                       | 6    | 5        | EA   | \$1,085 |        |
| Staff Restroom | Staff Restroom                  | Hand Dryer                        | 1st floor men's next to boiler room   | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st floor boys along corridor at NE   | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st floor boys along corridor at NW   | 6    | 1        | EA   | \$217   |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item       | Location                             | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|------------|--------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Locker/Shower Room              | Hand Dryer | 1st floor boys                       | 6    | 2        | EA   | \$434   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 2nd floor boys along corridor at NW  | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 1st floor boys along corridor at SE  | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 1st floor girls along corridor at NE | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Locker/Shower Room              | Hand Dryer | 1st floor employee inside kitchen    | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 2nd floor boys along corridor at NE  | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 2nd floor girls along corridor at SE | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 2nd floor girls along corridor at NE | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 2nd floor girls along corridor at NW | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 1st floor girls along corridor at NW | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 1st floor girls along corridor at SE | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer | 2nd floor boys along corridor at SE  | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 2nd floor boys along corridor at NW  | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 1st floor girls along corridor at SE | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 1st floor boys along corridor at NW  | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 1st floor boys along corridor at NE  | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 1st floor boys along corridor at SE  | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 1st floor girls along corridor at NE | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 1st floor girls along corridor at NW | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 2nd floor girls along corridor at NW | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Locker/Shower Room              | Lavatory   | 1st floor girls                      | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 2nd floor girls along corridor at SE | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory   | 2nd floor boys along corridor at SE  | 6    | 3        | EA   | \$1,115 |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                        | Location                              | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------|---------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Lavatory                    | 2nd floor girls along corridor at NE  | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Locker/Shower Room              | Lavatory                    | 1st floor boys                        | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor inside main office          | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Locker/Shower Room              | Lavatory                    | Basement                              | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor inside office in girls gym  | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                    | 2nd floor boys along corridor at NE   | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor unisex next to boiler room  | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor women's next to boiler room | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor men's next to boiler room   | 6    | 2        | EA   | \$744   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor inside nurses office        | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor inside principal office     | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Locker/Shower Room              | Lavatory                    | 1st floor employee inside kitchen     | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor inside office #137          | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor next to lunch room          | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 2nd floor NW                          | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st floor inside office in boys gym   | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 1st floor inside principal office     | 6    | 1        | SF   | \$1     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 1st floor inside nurses office        | 6    | 1        | SF   | \$1     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 1st floor unisex next to boiler room  | 6    | 1        | SF   | \$1     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 1st floor inside office in boys gym   | 6    | 1        | SF   | \$1     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 1st floor inside office in girls gym  | 6    | 1        | SF   | \$1     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 1st floor inside main office          | 6    | 1        | SF   | \$1     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 1st floor inside office #137          | 6    | 1        | SF   | \$1     |        |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface | 1st floor girls                       | 6    | 18       | SF   | \$13    |        |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface | 1st floor employee inside kitchen     | 6    | 4        | SF   | \$3     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | 1st floor men's next to boiler room   | 6    | 3        | SF   | \$2     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | 1st floor next to lunch room          | 6    | 3        | SF   | \$2     |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                        | Location                              | Rank | Quantity | Unit | Cost  | Reason |
|----------------|---------------------------------|-----------------------------|---------------------------------------|------|----------|------|-------|--------|
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | 2nd floor NW                          | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface | 1st floor boys                        | 6    | 18       | SF   | \$13  |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st floor girls along corridor at NW  | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st floor boys along corridor at NW   | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st floor boys along corridor at NE   | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st floor boys along corridor at SE   | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st floor girls along corridor at SE  | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st floor girls along corridor at NE  | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd floor boys along corridor at NW   | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd floor girls along corridor at NW  | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd floor girls along corridor at SE  | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd floor boys along corridor at NE   | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd floor boys along corridor at SE   | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface | Basement                              | 4    | 4        | SF   | \$17  | T-12   |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd floor girls along corridor at NE  | 6    | 3        | SF   | \$2   |        |
| Staff Restroom | Locker/Shower Room              | Partitions                  | 1st floor employee inside kitchen     | 6    | 1        | EA   | \$179 |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | 1st floor men's next to boiler room   | 6    | 1        | EA   | \$179 |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | 1st floor women's next to boiler room | 6    | 2        | EA   | \$359 |        |
| Staff Restroom | Locker/Shower Room              | Partitions                  | 1st floor boys                        | 6    | 3        | EA   | \$538 |        |
| Staff Restroom | Locker/Shower Room              | Partitions                  | 1st floor girls                       | 6    | 5        | EA   | \$897 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st floor boys along corridor at NW   | 6    | 2        | EA   | \$359 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st floor boys along corridor at SE   | 6    | 2        | EA   | \$359 |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | 1st floor inside office #137          | 6    | 2        | EA   | \$359 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st floor girls along corridor at NE  | 6    | 5        | EA   | \$897 |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                  | Location                              | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------|---------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 1st floor boys along corridor at NE   | 6    | 2        | EA   | \$359   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 1st floor girls along corridor at NW  | 6    | 5        | EA   | \$897   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 2nd floor girls along corridor at NW  | 6    | 5        | EA   | \$897   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 2nd floor girls along corridor at NE  | 6    | 5        | EA   | \$897   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 2nd floor girls along corridor at SE  | 6    | 5        | EA   | \$897   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 2nd floor boys along corridor at NW   | 6    | 2        | EA   | \$359   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 2nd floor boys along corridor at NE   | 6    | 2        | EA   | \$359   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 2nd floor boys along corridor at SE   | 6    | 2        | EA   | \$359   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 1st floor girls along corridor at SE  | 6    | 5        | EA   | \$897   |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 2nd floor boys along corridor at SE   | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 1st floor boys along corridor at SE   | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Staff Restroom                  | Urinals               | 1st floor men's next to boiler room   | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 2nd floor boys along corridor at NE   | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Locker/Shower Room              | Urinals               | 1st floor boys                        | 6    | 6        | EA   | \$2,231 |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 1st floor boys along corridor at NW   | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 2nd floor boys along corridor at NW   | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 1st floor boys along corridor at NE   | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block | 1st floor next to lunch room          | 6    | 756      | SF   | \$2,162 |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block | 1st floor unisex next to boiler room  | 6    | 260      | SF   | \$744   |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block | 1st floor women's next to boiler room | 6    | 396      | SF   | \$1,133 |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block | 1st floor men's next to boiler room   | 6    | 611      | SF   | \$1,747 |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block | 1st floor inside principal office     | 6    | 160      | SF   | \$458   |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block | 1st floor inside main office          | 6    | 224      | SF   | \$641   |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                          | Location                             | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-------------------------------|--------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Locker/Shower Room              | Wall - Concrete Block         | 1st floor employee inside kitchen    | 6    | 712      | SF   | \$2,036 |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block         | 1st floor inside office in boys gym  | 6    | 160      | SF   | \$458   |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block         | 1st floor inside office #137         | 6    | 170      | SF   | \$486   |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block         | 1st floor inside office in girls gym | 6    | 160      | SF   | \$458   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd floor boys along corridor at SE  | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd floor boys along corridor at NE  | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 1st floor boys along corridor at NE  | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Locker/Shower Room              | Wall - Concrete Block         | 1st floor boys                       | 6    | 2,300    | SF   | \$6,578 |        |
| Staff Restroom | Locker/Shower Room              | Wall - Concrete Block         | 1st floor girls                      | 6    | 1,575    | SF   | \$4,505 |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block         | 2nd floor NW                         | 6    | 756      | SF   | \$2,162 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 1st floor boys along corridor at NW  | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd floor boys along corridor at NW  | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 1st floor boys along corridor at SE  | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 1st floor girls along corridor at SE | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 1st floor girls along corridor at NW | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd floor girls along corridor at NW | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd floor girls along corridor at NE | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Locker/Shower Room              | Wall - Concrete Block         | Basement                             | 6    | 700      | SF   | \$2,002 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd floor girls along corridor at SE | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 1st floor girls along corridor at NE | 6    | 265      | SF   | \$758   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 1st floor boys along corridor at SE  | 6    | 265      | SF   | \$1,895 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 1st floor boys along corridor at NW  | 6    | 265      | SF   | \$1,895 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 2nd floor boys along corridor at NW  | 6    | 265      | SF   | \$1,895 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 2nd floor girls along corridor at SE | 6    | 265      | SF   | \$1,895 |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                          | Location                              | Rank | Quantity | Unit | Cost     | Reason |
|----------------|---------------------------------|-------------------------------|---------------------------------------|------|----------|------|----------|--------|
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 2nd floor girls along corridor at NE  | 6    | 265      | SF   | \$1,895  |        |
| Staff Restroom | Locker/Shower Room              | Wall - Structural Glazed Tile | 1st floor boys                        | 6    | 2,300    | SF   | \$16,445 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 2nd floor boys along corridor at NE   | 6    | 265      | SF   | \$1,895  |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 2nd floor girls along corridor at NW  | 6    | 265      | SF   | \$1,895  |        |
| Staff Restroom | Staff Restroom                  | Wall - Structural Glazed Tile | 1st floor inside office #137          | 6    | 170      | SF   | \$1,216  |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 1st floor girls along corridor at SE  | 6    | 265      | SF   | \$1,895  |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 1st floor girls along corridor at NE  | 6    | 265      | SF   | \$1,895  |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 1st floor girls along corridor at NW  | 6    | 265      | SF   | \$1,895  |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 2nd floor boys along corridor at SE   | 6    | 265      | SF   | \$1,895  |        |
| Staff Restroom | Locker/Shower Room              | Wall - Structural Glazed Tile | 1st floor girls                       | 6    | 1,575    | SF   | \$11,261 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile | 1st floor boys along corridor at NE   | 6    | 265      | SF   | \$1,895  |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 1st floor women's next to boiler room | 6    | 2        | EA   | \$744    |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 1st floor men's next to boiler room   | 6    | 1        | EA   | \$372    |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 1st floor inside principal office     | 6    | 1        | EA   | \$372    |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 1st floor inside office #137          | 6    | 2        | EA   | \$744    |        |
| Staff Restroom | Locker/Shower Room              | Water Closet                  | 1st floor employee inside kitchen     | 6    | 1        | EA   | \$372    |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 2nd floor boys along corridor at NE   | 6    | 2        | EA   | \$744    |        |
| Staff Restroom | Locker/Shower Room              | Water Closet                  | 1st floor girls                       | 6    | 5        | EA   | \$1,859  |        |
| Staff Restroom | Locker/Shower Room              | Water Closet                  | 1st floor boys                        | 6    | 3        | EA   | \$1,115  |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 1st floor inside nurses office        | 6    | 1        | EA   | \$372    |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 1st floor girls along corridor at SE  | 6    | 5        | EA   | \$1,859  |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 1st floor inside office in boys gym   | 6    | 1        | EA   | \$372    |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 1st floor boys along corridor at NW   | 6    | 2        | EA   | \$744    |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 1st floor inside office in girls gym  | 6    | 1        | EA   | \$372    |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 2nd floor NW                          | 6    | 1        | EA   | \$372    |        |

**Building: Main**  
**Category: INTERIOR**

| Group                     | Sub Group                       | Item                                | Location                             | Rank | Quantity | Unit | Cost               | Reason |
|---------------------------|---------------------------------|-------------------------------------|--------------------------------------|------|----------|------|--------------------|--------|
| Staff Restroom            | Locker/Shower Room              | Water Closet                        | Basement                             | 6    | 1        | EA   | \$372              |        |
| Staff Restroom            | Staff Restroom                  | Water Closet                        | 1st floor inside main office         | 6    | 1        | EA   | \$372              |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 2nd floor girls along corridor at SE | 6    | 5        | EA   | \$1,859            |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 1st floor boys along corridor at SE  | 6    | 2        | EA   | \$744              |        |
| Staff Restroom            | Staff Restroom                  | Water Closet                        | 1st floor unisex next to boiler room | 6    | 1        | EA   | \$372              |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 2nd floor boys along corridor at SE  | 6    | 2        | EA   | \$744              |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 2nd floor boys along corridor at NW  | 6    | 2        | EA   | \$744              |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 2nd floor girls along corridor at NE | 6    | 5        | EA   | \$1,859            |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 2nd floor girls along corridor at NW | 6    | 5        | EA   | \$1,859            |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 1st floor girls along corridor at NW | 6    | 5        | EA   | \$1,859            |        |
| Staff Restroom            | Staff Restroom                  | Water Closet                        | 1st floor next to lunch room         | 6    | 1        | EA   | \$372              |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 1st floor girls along corridor at NE | 6    | 5        | EA   | \$1,859            |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                        | 1st floor boys along corridor at NE  | 6    | 2        | EA   | \$744              |        |
| Theater                   | Auditorium - Dedicated          | Ceiling - Plaster/Drywall           | 1st Floor                            | 6    | 6,380    | SF   | \$54,558           |        |
| Theater                   | Auditorium - Dedicated          | Flooring - Concrete                 | 1st Floor                            | 6    | 6,380    | SF   | \$30,107           |        |
| Theater                   | Auditorium - Dedicated          | Lighting - Lay-In                   | 1st Floor                            | 6    | 52       | SF   | \$59               |        |
| Theater                   | Auditorium - Dedicated          | Wall - Plaster/Drywall              | 1st Floor                            | 6    | 7,050    | SF   | \$60,489           |        |
| Vertical Conveyance       |                                 | Elevator - Roped Holeless Hydraulic | Entire Building                      | 7    | 1        | EA   | \$0                |        |
| Vertical Conveyance       |                                 | Stage Lift                          | 1st floor inside Auditorium          | 7    | 1        | EA   | \$0                |        |
| Vocational Shop           | Classroom                       | Work Sink                           |                                      | 6    | 1        | EA   | \$386              |        |
| Vocational Shop           | Classroom                       | Work Sink                           |                                      | 6    | 3        | EA   | \$1,158            |        |
| Vocational Shop           | Classroom                       | Work Sink                           |                                      | 6    | 2        | EA   | \$772              |        |
| Vocational Shop           | Classroom                       | Work Sink                           |                                      | 6    | 10       | EA   | \$3,861            |        |
| Vocational Shop           | Classroom                       | Work Sink                           |                                      | 6    | 2        | EA   | \$772              |        |
| Vocational Shop           | Classroom                       | Work Sink                           |                                      | 4    | 1        | EA   | \$3,861            |        |
| Vocational Shop           | Classroom                       | Work Sink                           |                                      | 6    | 6        | EA   | \$2,317            |        |
| Vocational Shop           | Classroom                       | Work Sink                           |                                      | 6    | 1        | EA   | \$386              |        |
| <b>INTERIOR Sub Total</b> |                                 |                                     |                                      |      |          |      | <b>\$2,202,847</b> |        |



**Building: Main**  
**Category: ROOM**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

**Building: Main**  
**Category: ROOM**

| Group       | Sub Group                     | Item                        | Location                              | Rank | Quantity | Unit | Cost    | Reason |
|-------------|-------------------------------|-----------------------------|---------------------------------------|------|----------|------|---------|--------|
| ADMIN_FLOOR | Administrative Suites/Offices | Administrative Office Floor | 1st floor to north of Auditorium #135 | 6    | 183      | SF   | \$262   |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 6        | LF   | \$215   |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 61       | LF   | \$2,181 |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 92       | LF   | \$3,289 |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 6        | LF   | \$215   |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       | 5    | 6        | LF   | \$1,073 |        |
| Casework    | Classroom                     | Casework                    |                                       | 5    | 8        | LF   | \$1,430 |        |
| Casework    | Classroom                     | Casework                    |                                       | 5    | 8        | LF   | \$1,430 |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 33       | LF   | \$1,180 |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 33       | LF   | \$1,180 |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 45       | LF   | \$1,609 |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 173      | LF   | \$6,185 |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 79       | LF   | \$2,824 |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 6        | LF   | \$215   |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 52       | LF   | \$1,859 |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 41       | LF   | \$1,466 |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       | 6    | 9        | LF   | \$322   |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |
| Casework    | Classroom                     | Casework                    |                                       |      |          | LF   | \$0     |        |

**Building: Main**  
**Category: ROOM**

| Group    | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost    | Reason |
|----------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Casework | Classroom | Casework        |          |      |          | LF   | \$0     |        |
| Casework | Classroom | Casework        |          |      |          | LF   | \$0     |        |
| Casework | Classroom | Casework        |          |      |          | LF   | \$0     |        |
| Casework | Classroom | Casework        |          |      |          | LF   | \$0     |        |
| Ceiling  | Classroom | Lay-In/Drop     |          | 6    | 1,383    | SF   | \$2,967 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 727      | SF   | \$1,559 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 727      | SF   | \$1,559 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 7    | 619      | SF   | \$0     |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 619      | SF   | \$1,328 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 619      | SF   | \$1,328 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 912      | SF   | \$1,956 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 912      | SF   | \$1,956 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 912      | SF   | \$1,956 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 727      | SF   | \$1,559 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 831      | SF   | \$1,782 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 737      | SF   | \$1,581 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 725      | SF   | \$1,555 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 735      | SF   | \$1,577 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 671      | SF   | \$1,439 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,144    | SF   | \$2,454 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,014    | SF   | \$2,175 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,131    | SF   | \$2,426 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,043    | SF   | \$2,237 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,171    | SF   | \$2,512 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 581      | SF   | \$1,246 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,516    | SF   | \$3,252 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,430    | SF   | \$3,067 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 961      | SF   | \$2,061 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 924      | SF   | \$1,982 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 742      | SF   | \$1,592 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,014    | SF   | \$2,175 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 932      | SF   | \$1,999 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 1,782    | SF   | \$3,822 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 727      | SF   | \$1,559 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 727      | SF   | \$1,559 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 6    | 727      | SF   | \$1,559 |        |
| Ceiling  | Classroom | Splined Ceiling |          | 7    | 727      | SF   | \$0     |        |



**Building: Main**  
**Category: ROOM**

| Group       | Sub Group | Item                 | Location | Rank | Quantity | Unit | Cost     | Reason      |
|-------------|-----------|----------------------|----------|------|----------|------|----------|-------------|
| Chalk Board | Classroom | Chalk Board          |          | 4    |          | LF   |          |             |
| Chalk Board | Classroom | Chalk Board          |          | 4    |          | LF   |          |             |
| Chalk Board | Classroom | Chalk Board          |          | 4    | 16       | LF   | \$1,945  |             |
| Chalk Board | Classroom | Chalk Board          |          | 4    | 12       | LF   | \$1,459  |             |
| Chalk Board | Classroom | Chalk Board          |          | 4    | 18       | LF   | \$2,188  |             |
| Chalk Board | Classroom | Chalk Board          |          | 4    |          | LF   |          |             |
| CLASSROOM   | Classroom | Eye Wash Station     |          | 7    | 1        | EA   | \$0      |             |
| CLASSROOM   | Classroom | Science Lab Elements |          | 6    | 1        | SF   | \$23     |             |
| CLASSROOM   | Classroom | Science Lab Elements |          | 6    | 1        | SF   | \$23     |             |
| CLASSROOM   | Classroom | Science Lab Elements |          | 6    | 1        | SF   | \$23     |             |
| CLASSROOM   | Classroom | Science Lab Shower   |          | 7    | 1        | EA   | \$0      |             |
| CLASSROOM   | Classroom | Science Lab Shower   |          | 6    | 1        | EA   | \$4,648  | eyewash     |
| CLASSROOM   | Classroom | Science Lab Shower   |          | 6    | 1        | EA   | \$4,648  | eyewash     |
| CLASSROOM   | Classroom | Science Lab Shower   |          | 6    | 1        | EA   | \$4,648  | eyewash     |
| Floor       | Classroom | Carpet               |          | 5    | 1,014    | SF   | \$3,625  |             |
| Floor       | Classroom | Floor                |          | 6    | 727      | SF   | \$3,119  |             |
| Floor       | Classroom | Floor                |          | 5    | 727      | SF   | \$7,277  |             |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 727      | SF   | \$0      |             |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 1,383    | SF   | \$1,978  | Vinyl sheet |
| Floor       | Classroom | Tile/Sheet           |          | 4    | 742      | SF   | \$10,504 |             |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 1,431    | SF   | \$2,046  |             |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 891      | SF   | \$1,274  | Vinyl tile  |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 829      | SF   | \$1,185  | Vinyl tile  |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 619      | SF   | \$885    |             |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 727      | SF   | \$0      |             |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 912      | SF   | \$1,304  |             |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 727      | SF   | \$0      |             |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 912      | SF   | \$1,304  |             |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 727      | SF   | \$1,040  |             |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 727      | SF   | \$0      |             |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 912      | SF   | \$1,304  |             |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 727      | SF   | \$0      |             |
| Floor       | Classroom | Tile/Sheet           |          | 4    | 714      | SF   | \$10,108 | Vinyl tile  |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 619      | SF   | \$885    |             |
| Floor       | Classroom | Tile/Sheet           |          | 6    | 755      | SF   | \$1,080  | Vinyl tile  |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 727      | SF   | \$0      |             |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 727      | SF   | \$0      |             |

**Building: Main**  
**Category: ROOM**

| Group        | Sub Group | Item            | Location  | Rank | Quantity | Unit | Cost     | Reason      |
|--------------|-----------|-----------------|-----------|------|----------|------|----------|-------------|
| Floor        | Classroom | Tile/Sheet      |           | 6    | 619      | SF   | \$885    |             |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 1,131    | SF   | \$1,617  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 1,144    | SF   | \$1,636  |             |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 671      | SF   | \$960    | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 735      | SF   | \$1,051  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 725      | SF   | \$1,037  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 1,292    | SF   | \$1,848  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 1,171    | SF   | \$1,675  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 1,014    | SF   | \$1,450  | Vinyl sheet |
| Floor        | Classroom | Tile/Sheet      |           | 4    | 581      | SF   | \$8,225  |             |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 932      | SF   | \$1,333  |             |
| Floor        | Classroom | Tile/Sheet      |           | 7    | 961      | SF   | \$0      | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 1,043    | SF   | \$1,491  |             |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 924      | SF   | \$1,321  | Vinyl sheet |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 737      | SF   | \$1,054  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 737      | SF   | \$1,054  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 737      | SF   | \$1,054  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 1,782    | SF   | \$2,548  |             |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 818      | SF   | \$1,170  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 818      | SF   | \$1,170  | Vinyl tile  |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 831      | SF   | \$1,188  |             |
| Floor        | Classroom | Tile/Sheet      |           | 6    | 619      | SF   | \$885    |             |
| Floor        | Classroom | Wood            |           | 6    | 1,516    | SF   | \$11,446 | Vinyl sheet |
| Floor        | Classroom | Wood            |           | 6    | 1,430    | SF   | \$10,797 | Vinyl sheet |
| LIBRARY_WALL | Library   | Concrete Block  | 1st Floor | 6    | 4,932    | SF   | \$14,106 |             |
| Lighting     | Classroom | Lay-In          |           | 6    | 20       | EA   | \$1,430  |             |
| Lighting     | Classroom | Lighting        |           | 6    | 20       | EA   | \$1,859  |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 18       | EA   | \$1,287  |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 12       | EA   | \$858    |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 12       | EA   | \$858    |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 20       | EA   | \$1,430  |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 19       | EA   | \$1,359  |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 20       | EA   | \$1,430  |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 12       | EA   | \$858    |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 12       | EA   | \$858    |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 12       | EA   | \$858    |             |
| Lighting     | Classroom | Pendant/Surface |           | 6    | 24       | EA   | \$1,716  |             |



**Building: Main**  
**Category: ROOM**

| Group        | Sub Group | Item         | Location | Rank | Quantity | Unit | Cost    | Reason |
|--------------|-----------|--------------|----------|------|----------|------|---------|--------|
| Marker Board | Classroom | Marker Board |          | 7    | 9        | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 12       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 6    | 9        | LF   | \$257   |        |
| Marker Board | Classroom | Marker Board |          | 6    | 16       | LF   | \$458   |        |
| Marker Board | Classroom | Marker Board |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board |          | 7    | 12       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 5        | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 6    | 16       | LF   | \$458   |        |
| Marker Board | Classroom | Marker Board |          | 7    | 20       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board |          | 7    | 18       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 6    | 24       | LF   | \$686   |        |
| Marker Board | Classroom | Marker Board |          | 7    | 12       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board |          | 7    | 20       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 10       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 4    | 18       | LF   | \$2,188 |        |
| Marker Board | Classroom | Marker Board |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board |          | 6    | 32       | LF   | \$915   |        |
| Marker Board | Classroom | Marker Board |          | 6    | 15       | LF   | \$429   |        |
| Marker Board | Classroom | Marker Board |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 18       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 4    | 18       | LF   | \$2,188 |        |
| Marker Board | Classroom | Marker Board |          | 6    | 16       | LF   | \$458   |        |
| Marker Board | Classroom | Marker Board |          | 6    | 16       | LF   | \$458   |        |
| Marker Board | Classroom | Marker Board |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 4    | 16       | LF   | \$1,945 |        |
| Marker Board | Classroom | Marker Board |          | 6    | 12       | LF   | \$343   |        |
| Marker Board | Classroom | Marker Board |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board |          | 7    | 8        | LF   | \$0     |        |

**Building: Main**  
**Category: ROOM**

| Group            | Sub Group          | Item              | Location                              | Rank | Quantity | Unit | Cost    | Reason |
|------------------|--------------------|-------------------|---------------------------------------|------|----------|------|---------|--------|
| Marker Board     | Classroom          | Marker Board      |                                       | 7    | 24       | LF   | \$0     |        |
| Marker Board     | Classroom          | Marker Board      |                                       | 7    | 16       | LF   | \$0     |        |
| Marker Board     | Classroom          | Marker Board      |                                       | 6    | 16       | LF   | \$458   |        |
| Marker Board     | Classroom          | Marker Board      |                                       | 7    | 18       | LF   | \$0     |        |
| Marker Board     | Classroom          | Marker Board      |                                       | 7    | 18       | LF   | \$0     |        |
| Marker Board     | Classroom          | Marker Board      |                                       | 7    | 18       | LF   | \$0     |        |
| RESTROOM_CEILING | Staff Restroom     | Restroom Ceiling  | 1st floor inside nurses office        | 6    | 15       | SF   | \$42    |        |
| RESTROOM_CEILING | Locker/Shower Room | Restroom Ceiling  | 1st floor girls                       | 6    | 2,700    | SF   | \$7,645 |        |
| RESTROOM_LIGHT   | Staff Restroom     | Restroom Lighting | 1st floor women's next to boiler room | 6    | 2        | EA   | \$57    |        |
| RESTROOM_WALL    | Staff Restroom     | Restroom Walls    | 1st floor inside nurses office        | 6    | 130      | SF   | \$331   |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 980      | SF   | \$2,803 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 2,670    | SF   | \$7,636 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 2,360    | SF   | \$6,750 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 960      | SF   | \$2,746 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 925      | SF   | \$2,646 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 1,046    | SF   | \$2,992 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 820      | SF   | \$2,345 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 820      | SF   | \$2,345 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 820      | SF   | \$2,345 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 820      | SF   | \$2,345 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 1,565    | SF   | \$4,476 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 1,290    | SF   | \$3,689 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 674      | SF   | \$1,928 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 945      | SF   | \$2,703 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 830      | SF   | \$2,374 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 703      | SF   | \$2,011 |        |
| Wall             | Classroom          | Concrete Block    |                                       | 6    | 1,376    | SF   | \$3,935 |        |



**Building: Main**  
**Category: ROOM**

| Group                 | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost             | Reason                        |
|-----------------------|-----------|-----------------|----------|------|----------|------|------------------|-------------------------------|
| Wall                  | Classroom | Concrete Block  |          | 6    | 1,376    | SF   | \$3,935          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 846      | SF   | \$2,420          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 950      | SF   | \$2,717          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 1,133    | SF   | \$3,240          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 1,012    | SF   | \$2,894          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 1,105    | SF   | \$3,160          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 969      | SF   | \$2,771          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 1,027    | SF   | \$2,937          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 942      | SF   | \$2,694          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 893      | SF   | \$2,554          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 648      | SF   | \$1,853          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 969      | SF   | \$2,771          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 1,360    | SF   | \$3,890          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 1,340    | SF   | \$3,832          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 1,360    | SF   | \$3,890          |                               |
| Wall                  | Classroom | Concrete Block  |          | 4    | 53       | SF   | \$2,274          | Major cracks, stairstep crack |
| Wall                  | Classroom | Concrete Block  |          | 6    | 674      | SF   | \$1,928          |                               |
| Wall                  | Classroom | Concrete Block  |          | 6    | 648      | SF   | \$1,853          |                               |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 240      | SF   | \$566            |                               |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 235      | SF   | \$554            |                               |
| Wall                  | Classroom | Plaster/Drywall |          | 5    | 240      | SF   | \$1,133          | Base missing                  |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 235      | SF   | \$554            |                               |
| Wall                  | Classroom | Plaster/Drywall |          | 6    | 461      | SF   | \$1,088          |                               |
| Wall                  | Classroom | Wall            |          | 6    | 1,290    | SF   | \$3,044          |                               |
| Wall                  | Classroom | Wall            |          | 6    | 1,290    | SF   | \$3,044          |                               |
| Wall                  | Classroom | Wall            |          | 6    | 1,290    | SF   | \$3,044          |                               |
| <b>ROOM Sub Total</b> |           |                 |          |      |          |      | <b>\$478,953</b> |                               |

**Building Main Sub Total \$11,101,409**

**Building: Addition**  
**Category: EXTERIOR**

| Group       | Sub Group | Item                        | Location        | Rank | Quantity | Unit | Cost     | Reason |
|-------------|-----------|-----------------------------|-----------------|------|----------|------|----------|--------|
| Foundation  |           | Concrete Foundation         | Entire Building | 7    | 240      | LF   | \$0      |        |
| Parapet     |           | Coping - Metal              | Main Roof       | 7    | 140      | LF   | \$0      |        |
| Roof System |           | Asphalt Gravel Ballast Roof | Main Roof       | 6    | 8,660    | SF   | \$55,232 |        |

**Building: Addition**  
**Category: EXTERIOR**

| Group                     | Sub Group | Item                     | Location                      | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|-----------|--------------------------|-------------------------------|------|----------|------|------------------|--------|
| Roof System               |           | Interior Downspouts      | Main Roof                     | 7    | 24       | LF   | \$0              |        |
| Roof System               |           | Roof Structure: Concrete | Main Roof                     | 6    | 8,660    | SF   | \$183,899        |        |
| Superstructure            |           | Concrete                 | North west corner of property | 7    | 8,660    | SF   | \$0              |        |
| Walls                     |           | Brick                    | Entire Building               | 6    | 2,115    | SF   | \$13,973         |        |
| <b>EXTERIOR Sub Total</b> |           |                          |                               |      |          |      | <b>\$253,104</b> |        |

**Building: Addition**  
**Category: ELECTRICAL**

| Group                       | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost            | Reason |
|-----------------------------|-----------|--|-----------------|------|----------|------|-----------------|--------|
| Emergency System            |           | Emergency A/C power - Corridors and Stairs     | Corridor        | 6    | 1,575    | SF   | \$676           |        |
| Emergency System            |           | Emergency A/C power - Students Toilets         | Student Toilets | 6    | 335      | SF   | \$144           |        |
| Emergency System            |           | Emergency A/C power - Students Toilets         | Entire Building | 6    | 8,660    | SF   | \$3,715         |        |
| Emergency System            |           | Emergency Battery Packs - Corridors and Stairs | Corridors       | 6    | 1        | EA   | \$107           |        |
| Emergency System            |           | Public Announcement System                     | Entire Building | 6    | 8,660    | SF   | \$5,201         |        |
| Emergency System            |           | Security System - Intrusion detection          | Entire Building | 6    | 8,660    | SF   | \$8,049         |        |
| Power Distribution          |           | Lighting and power panels                      | Mechanical Room | 6    | 1        | EA   | \$715           |        |
| <b>ELECTRICAL Sub Total</b> |           |  |                 |      |          |      | <b>\$18,607</b> |        |

**Building: Addition**  
**Category: FIRE PROTECTION**

| Group                            | Sub Group | Item                     | Location        | Rank | Quantity | Unit | Cost           | Reason |
|----------------------------------|-----------|--------------------------|-----------------|------|----------|------|----------------|--------|
| Fire Alarm                       |           | Fire Alarm Strobe Lights | Entire Building | 6    | 8,660    | SF   | \$3,096        |        |
| <b>FIRE PROTECTION Sub Total</b> |           |                          |                 |      |          |      | <b>\$3,096</b> |        |

**Building: Addition**  
**Category: MECHANICAL**

| Group                | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost     | Reason  |
|----------------------|-----------|--|-----------------|------|----------|------|----------|---|
| Air Handling Systems |           | Air Handling Unit Package - Single Zone - Steam 4,000 to 8,000 cfm | Mechanical Room | 4    | 1        | EA   | \$50,050 | Unit is more than 30 years and the unit is operating however it cannot maintain the proper temperatures during severe weather condition dampers are not fully opened, valves are not operating properly |
| Air Handling Systems |           | Air intake for all Air Handling Units except built up AHU          | West Façade     | 6    | 1        | EA   | \$1,430  |   |

**Building: Addition**  
**Category: MECHANICAL**

| Group                       | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost             | Reason  |
|-----------------------------|-----------|--|-----------------|------|----------|------|------------------|---|
| Mechanical Plumbing         |           | Condensate Assembly - Pumps and Tank           | Mechanical Room | 6    | 2        | EA   | \$1,430          |   |
| Temperature Control         |           | Pneumatic System                               | Entire Building | 3    | 8,660    | SF   | \$61,919         | Controls are more than 30 years of age, damper and valve actuators are not working, not all sensors are responding, most dampers and valves are operating in manual mode, temperatures are not maintained). |
| Temperature Control         |           | Thermostats - Pneumatic                        | Entire Building | 4    | 1        | EA   | \$658            |   |
| Ventilation                 |           | Exhaust Fan - Indoor                           | Mechanical Room | 5    | 1        | EA   | \$1,859          |   |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof            | 6    | 1        | EA   | \$429            |   |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm   | Roof            | 6    | 2        | EA   | \$458            |   |
| Ventilation                 |           | Exhaust Fans - Roof mounted less than 500 CFM  | Roof            | 6    | 1        | EA   | \$157            |   |
| <b>MECHANICAL Sub Total</b> |           |  |                 |      |          |      | <b>\$118,390</b> |   |

**Building: Addition**  
**Category: PLUMBING**

| Group                     | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost             | Reason                               |
|---------------------------|-----------|--|-----------------|------|----------|------|------------------|--------------------------------------|
| Piping                    |           | Domestic Piping Cold Water Horizontal lines  | Entire Building | 4    | 8,660    | SF   | \$20,681         |                                      |
| Piping                    |           | Domestic Piping Hot Water Horizontal lines   | Entire Building | 4    | 8,660    | SF   | \$17,090         |                                      |
| Piping                    |           | Domestic Piping Hot Water Return Lines       | Entire Building | 4    | 8,660    | SF   | \$9,907          |                                      |
| Piping                    |           | Sanitary Piping                              | Entire Building | 3    | 8,660    | SF   | \$8,297          | Pool Deck Drains do not drain water. |
| Piping                    |           | Storm Piping                                 | Entire Building | 4    | 8,660    | SF   | \$6,192          |                                      |
| Piping                    |           | Vent Piping                                  | Entire Building | 4    | 8,660    | SF   | \$4,954          |                                      |
| Pool Systems              |           | Pool Drain Piping                            | Underground     | 3    | 100      | LF   | \$17,160         | Leaks - No liner in piping           |
| Pool Systems              |           | Pool Filtration System                       | Mechanical Room | 4    | 2        | EA   | \$434,720        |                                      |
| Pool Systems              |           | Pool Hot Water Heater - Gas Fired            | Mechanical Room | 6    | 1        | EA   | \$3,718          |                                      |
| Pool Systems              |           | Pool Hot Water Heater - Steam Heat Exchanger | Mechanical Room | 4    | 1        | EA   | \$13,013         |                                      |
| Pool Systems              |           | Pool Supply and Return Piping                | Mechanical Room | 7    | 150      | LF   | \$0              |                                      |
| Pumps                     |           | Ejector Pump                                 | Mechanical Room | 6    | 2        | EA   | \$6,006          |                                      |
| Pumps                     |           | Sump Pump                                    | Mechanical Room | 6    | 2        | EA   | \$2,717          |                                      |
| <b>PLUMBING Sub Total</b> |           |  |                 |      |          |      | <b>\$544,454</b> |                                      |

**Building: Addition**  
**Category: INTERIOR**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

**Building: Addition**  
**Category: INTERIOR**

| Group                    | Sub Group                       | Item                           | Location                                | Rank | Quantity | Unit | Cost     | Reason                                |
|--------------------------|---------------------------------|--------------------------------|---|------|----------|------|----------|---------------------------------------|
| Corridor                 |                                 | Ceiling - Splined              | 1st Floor                               | 6    | 1,575    | SF   | \$3,378  |                                       |
| Corridor                 |                                 | Flooring Tile/ Sheet           | 1st Floor                               | 6    | 1,575    | SF   | \$2,252  |                                       |
| Corridor                 |                                 | Lighting - Lay-In              | 1st Floor                               | 6    | 1,575    | SF   | \$1,126  |                                       |
| Corridor                 |                                 | Stair Handrails                | Basement                                | 6    | 30       | LF   | \$0      |                                       |
| Corridor                 |                                 | Stairs - Tile                  | Basement                                | 6    | 24       | LF   | \$181    |                                       |
| Corridor                 |                                 | Walls - Plaster/Drywall        | 1st Floor                               | 6    | 1,050    | SF   | \$2,477  |                                       |
| Corridor                 |                                 | Walls - Structural Glazed Tile | 1st Floor                               | 6    | 1,500    | SF   | \$10,725 |                                       |
| Doors                    |                                 | Interior Steel Doors incl hw   | Entire Building                         | 6    | 4        | EA   | \$1,133  |                                       |
| Doors                    |                                 | Interior Steel Doors incl hw   | Locker                                  | 5    | 1        | EA   | \$472    | Door off hinges, propped against wall |
| Doors                    |                                 | Interior Steel Doors incl hw   | Pool room                               | 7    | 5        | EA   | \$0      |                                       |
| Locker/Shower Room       | Adult Standard Student Restroom | Benches                        | 1st floor unisex open to pool           |      |          | LF   | \$0      |                                       |
| Locker/Shower Room       | Adult Standard Student Restroom | Lockers                        | 1st floor unisex open to pool           |      |          | EA   | \$0      |                                       |
| Locker/Shower Room       | Locker/Shower Room              | Lockers                        | 1st floor unisex locker inside pool     | 6    | 44       | EA   | \$2,159  |                                       |
| Locker/Shower Room       | Adult Standard Student Restroom | Showers                        | 1st floor unisex open to pool           | 6    | 1        | EA   | \$243    |                                       |
| Locker/Shower Room       | Locker/Shower Room              | Showers                        | 1st floor unisex locker inside pool     | 6    | 7        | EA   | \$1,702  |                                       |
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms       | Basement                                | 5    | 3,650    | SF   | \$41,338 |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 1st floor unisex open to pool           | 6    | 85       | SF   | \$656    |                                       |
| Staff Restroom           | Locker/Shower Room              | Accessories                    | 1st floor unisex locker inside pool     | 6    | 688      | SF   | \$5,313  |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 1st floor girls inside pool locker room | 6    | 136      | SF   | \$1,050  |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 1st floor boys inside pool locker room  | 6    | 114      | SF   | \$880    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Ceiling - Plaster/Drywall      | 1st floor boys inside pool locker room  | 6    | 114      | SF   | \$323    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Ceiling - Plaster/Drywall      | 1st floor unisex open to pool           | 6    | 85       | SF   | \$241    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Ceiling - Plaster/Drywall      | 1st floor girls inside pool locker room | 6    | 136      | SF   | \$385    |                                       |
| Staff Restroom           | Locker/Shower Room              | Ceiling - Plaster/Drywall      | 1st floor unisex locker inside pool     | 6    | 688      | SF   | \$1,948  |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Floor Drain                    | 1st floor girls inside pool locker room | 6    | 1        | EA   | \$300    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Floor Drain                    | 1st floor boys inside pool locker room  | 6    | 1        | EA   | \$300    |                                       |

**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                              | Location                                | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------------|---|------|----------|------|---------|--------|
| Staff Restroom | Locker/Shower Room              | Floor Drain                       | 1st floor unisex locker inside pool     | 6    | 4        | EA   | \$1,201 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st floor unisex open to pool           | 6    | 1        | EA   | \$300   |        |
| Staff Restroom | Locker/Shower Room              | Flooring - Concrete               | 1st floor unisex locker inside pool     | 6    | 688      | SF   | \$3,247 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor boys inside pool locker room  | 6    | 114      | SF   | \$290   |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor girls inside pool locker room | 6    | 136      | SF   | \$346   |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor unisex open to pool           | 6    | 85       | SF   | \$216   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st floor girls inside pool locker room | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Locker/Shower Room              | Hand Dryer                        | 1st floor unisex locker inside pool     | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st floor boys inside pool locker room  | 6    | 1        | EA   | \$217   |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st floor unisex open to pool           |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 1st floor girls inside pool locker room | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 1st floor boys inside pool locker room  | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 1st floor unisex open to pool           | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface       | 1st floor boys inside pool locker room  | 6    | 3        | SF   | \$2     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface       | 1st floor girls inside pool locker room | 6    | 3        | SF   | \$2     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface       | 1st floor unisex open to pool           | 6    | 2        | SF   | \$1     |        |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface       | 1st floor unisex locker inside pool     | 6    | 12       | SF   | \$9     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                        | 1st floor girls inside pool locker room | 6    | 3        | EA   | \$538   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                        | 1st floor unisex open to pool           |      |          | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                        | 1st floor boys inside pool locker room  | 6    | 3        | EA   | \$538   |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals                           | 1st floor boys inside pool locker room  | 6    | 2        | EA   | \$744   |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals                           | 1st floor unisex open to pool           | 6    | 1        | EA   | \$372   |        |

**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                             | Location                                | Rank | Quantity | Unit | Cost      | Reason |
|----------------|---------------------------------|----------------------------------|---|------|----------|------|-----------|--------|
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block            | 1st floor boys inside pool locker room  | 6    | 230      | SF   | \$658     |        |
| Staff Restroom | Locker/Shower Room              | Wall - Concrete Block            | 1st floor unisex locker inside pool     | 6    | 550      | SF   | \$1,573   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block            | 1st floor girls inside pool locker room | 6    | 250      | SF   | \$715     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile    | 1st floor girls inside pool locker room | 6    | 250      | SF   | \$1,788   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Structural Glazed Tile    | 1st floor boys inside pool locker room  | 6    | 230      | SF   | \$1,645   |        |
| Staff Restroom | Locker/Shower Room              | Wall - Structural Glazed Tile    | 1st floor unisex locker inside pool     | 6    | 550      | SF   | \$3,933   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Tile Ceramic/ Porcelain   | 1st floor unisex open to pool           | 6    | 417      | SF   | \$1,061   |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                     | 1st floor unisex open to pool           | 6    | 1        | EA   | \$372     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                     | 1st floor boys inside pool locker room  | 6    | 3        | EA   | \$1,115   |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                     | 1st floor girls inside pool locker room | 6    | 3        | EA   | \$1,115   |        |
| Swimming Pool  |                                 | Accessories                      | 1st Floor                               | 6    | 3,646    | SF   | \$28,154  |        |
| Swimming Pool  |                                 | Bleacher Seating/Plank seating   | 1st Floor                               | 6    | 26       | EA   | \$368     |        |
| Swimming Pool  |                                 | Floor Tile                       | 1st Floor                               | 6    | 3,646    | SF   | \$12,409  |        |
| Swimming Pool  |                                 | Lighting - Pendant/ Surface      | 1st Floor                               | 6    | 3,646    | SF   | \$3,910   |        |
| Swimming Pool  |                                 | Paint                            | 1st Floor                               | 6    | 3,646    | SF   | \$0       |        |
| Swimming Pool  |                                 | Pool Basin                       | 1st Floor                               | 5    | 1,625    | SF   | \$153,368 |        |
| Swimming Pool  |                                 | Pool Deck                        | 1st Floor                               | 6    | 2,021    | SF   | \$13,352  |        |
| Swimming Pool  |                                 | Pool deck drains                 | 1st Floor                               | 6    | 8        | EA   | \$2,974   |        |
| Swimming Pool  |                                 | Splined Ceiling including access | 1st Floor                               | 6    | 3,646    | SF   | \$39,103  |        |
| Swimming Pool  |                                 | Structural Glazed Tile           | 1st Floor                               | 6    | 2,140    | SF   | \$15,301  |        |
| Swimming Pool  |                                 | Wall Tile                        | 1st Floor                               | 6    | 2,140    | SF   | \$6,457   |        |

**INTERIOR Sub Total \$377,529**

**Building Addition Sub Total \$1,315,180**

**Building: Annex**  
**Category: EXTERIOR**

| Group | Sub Group | Item               | Location     | Rank | Quantity | Unit | Cost  | Reason |
|-------|-----------|--------------------|--------------|------|----------|------|-------|--------|
| Doors |           | Exterior Wood Door | North Façade | 6    | 3        | EA   | \$963 |        |

**Building: Annex**  
**Category: EXTERIOR**

| Group                     | Sub Group | Item                             | Location                       | Rank | Quantity | Unit | Cost             | Reason   |
|---------------------------|-----------|----------------------------------|--------------------------------|------|----------|------|------------------|--|
| Doors                     |           | Exterior Wood Door               | South Façade                   | 4    | 3        | EA   | \$9,627          |  |
| Entrance                  |           | Concrete Exterior Stairs         | South Façade                   | 5    | 48       | LF   | \$15,444         |  |
| Entrance                  |           | Entrance Controls - Audio        | North Façade                   | 3    | 1        | EA   | \$2,288          | System not operational                           |
| Entrance                  |           | Power Door Operator and Controls | North Façade                   | 3    | 3        | EA   | \$14,723         |  |
| Foundation                |           | Concrete Foundation              | Entire Building                | 6    | 516      | LF   | \$80,355         |  |
| Lighting                  |           | Exterior Lights - Wall Mounted   | East Façade                    | 6    | 3        | EA   | \$644            |  |
| Lighting                  |           | Exterior Lights - Wall Mounted   | Entire Building                | 5    | 5        | EA   | \$2,503          |  |
| Roof System               |           | Asphalt Shingle Roof             | Roof                           | 6    | 14,976   | SF   | \$59,321         |  |
| Roof System               |           | Exterior Downspouts              | East and west building facades | 6    | 526      | LF   | \$9,778          |  |
| Roof System               |           | Roof Structure: Heavy Timber     | Main Roof                      | 7    | 11,400   | SF   | \$0              |  |
| Superstructure            |           | Heavy Timber                     | Entire Building                | 7    | 11,400   | SF   | \$0              |  |
| Walls                     |           | Prefabricated Metal Panel Wall   | Entire Building                | 5    | 6,192    | SF   | \$177,091        |  |
| Windows                   |           | Window - Guards perforated       | Entire Building                | 4    | 1,095    | SF   | \$83,710         | System should be replaced with perforated gaurds |
| Windows                   |           | Windows - Sash Aluminum          | Entire Building                | 4    | 1,095    | SF   | \$145,718        |  |
| <b>EXTERIOR Sub Total</b> |           |                                  |                                |      |          |      | <b>\$602,165</b> |  |

**Building: Annex**  
**Category: ELECTRICAL**

| Group                       | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost            | Reason  |
|-----------------------------|-----------|--|-----------------|------|----------|------|-----------------|---|
| Emergency System            |           | Automatic Transfer switch                            | Mechanical Room | 4    | 1        | EA   | \$8,866         |   |
| Emergency System            |           | Exit Signs - Corridors and Stairs                    | Corridors       | 3    | 4        | EA   | \$3,718         | Exit signs are more than 20 years old and they are not provided with battery backup |
| Emergency System            |           | Independent Electrical Service for emergency power   | Entire Building | 5    | 1        | EA   | \$5,005         |   |
| Emergency System            |           | Security System - Intrusion detection                | Entire Building | 6    | 11,400   | SF   | \$10,596        |   |
| Main Service                |           | Main Electrical service 1000 A and below 120/208/3PH | Mechanical Room | 6    | 1        | EA   | \$6,435         |   |
| Power Distribution          |           | Lighting and power panels                            | Mechanical Room | 6    | 2        | EA   | \$1,430         |   |
| Power Distribution          |           | Main distribution panels above 600 amp               | Mechanical Room | 6    | 2        | EA   | \$4,290         |   |
| <b>ELECTRICAL Sub Total</b> |           |  |                 |      |          |      | <b>\$40,340</b> |   |

**Building: Annex**  
**Category: MECHANICAL**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

**Building: Annex**  
**Category: MECHANICAL**

| Group                       | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost             | Reason  |
|-----------------------------|-----------|--|-----------------|------|----------|------|------------------|---|
| Air Conditioning            |           | Condensing Unit - Roof Mounted less than 5 tons                | Roof            | 2    | 3        | EA   | \$25,740         | Condensing unit is not working and is more than 20 years of age (compressors not operating, condenser fans are not running, no refrigerant in the system) |
| Air Conditioning            |           | Window A/C Unit  | Entire Building | 5    | 9        | EA   | \$9,653          |   |
| Temperature Control         |           | Thermostats - Direct Digital Control (DDC)                     | Entire Building | 5    | 11       | EA   | \$6,135          |   |
| Unit Ventilation            |           | Unit Ventilators - Self Contained Electric Heating and Cooling | Entire Building | 4    | 11       | EA   | \$188,760        |   |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm                   | Roof            | 5    | 12       | EA   | \$15,444         |   |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm                   | Roof            | 3    | 1        | EA   | \$2,288          | cap is missing, Fan motor is not working  |
| <b>MECHANICAL Sub Total</b> |           |  |                 |      |          |      | <b>\$248,019</b> |   |

**Building: Annex**  
**Category: PLUMBING**

| Group                     | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost            | Reason |
|---------------------------|-----------|---|-----------------|------|----------|------|-----------------|--------|
| Hot Water                 |           | Hot Water Heater - Electric less than 50 KW | Mechanical Room | 4    | 1        | EA   | \$11,211        |        |
| Piping                    |           | Domestic Piping Cold Water Horizontal lines | Entire Building | 4    | 11,400   | SF   | \$27,224        |        |
| Piping                    |           | Domestic Piping Hot Water Horizontal lines  | East Courtyard  | 4    | 11,400   | SF   | \$22,497        |        |
| Piping                    |           | Sanitary Piping                             | Entire Building | 5    | 11,400   | SF   | \$7,010         |        |
| Piping                    |           | Storm Piping                                | East Courtyard  | 5    | 11,400   | SF   | \$5,380         |        |
| Piping                    |           | Vent Piping                                 | Entire Building | 5    | 11,400   | SF   | \$4,076         |        |
| <b>PLUMBING Sub Total</b> |           |   |                 |      |          |      | <b>\$77,397</b> |        |

**Building: Annex**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                       | Location          | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|----------------------------|-------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In           | main office suite | 6    | 580      | SF   | \$1,244 |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | main office suite | 7    | 580      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | main office suite | 6    | 8        | SF   | \$6     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall    | main office suite | 6    | 842      | SF   | \$1,987 |        |
| Corridor              |                               | Ceiling - Lay-In           | 1st Floor         | 6    | 2,499    | SF   | \$5,360 |        |
| Corridor              |                               | Flooring Tile/ Sheet       | 1st Floor         | 7    | 2,499    | SF   | \$0     |        |



**Building: Annex**  
**Category: INTERIOR**

| Group                    | Sub Group                       | Item                        | Location                           | Rank | Quantity | Unit | Cost     | Reason                                |
|--------------------------|---------------------------------|-----------------------------|------------------------------------|------|----------|------|----------|---------------------------------------|
| Corridor                 |                                 | Lighting - Lay-In           | 1st Floor                          | 6    | 2,499    | SF   | \$1,787  |                                       |
| Corridor                 |                                 | Student Lockers             | 1st Floor                          | 7    | 306      | EA   | \$0      |                                       |
| Corridor                 |                                 | Walls - Plaster/Drywall     | 1st Floor                          | 6    | 2,995    | SF   | \$7,067  |                                       |
| Doors                    |                                 | Interior Wood Doors incl hw | Entire Building                    | 6    | 39       | EA   | \$11,042 |                                       |
| Drinking Fountains       |                                 | Double Fountain             | 1st Floor                          | 6    | 1        | EA   | \$658    |                                       |
| Locker/Shower Room       | Adult Standard Student Restroom | Showers                     | Boys bathroom                      | 4    | 1        | EA   | \$2,431  | not operational                       |
| Mechanical/Service Rooms |                                 | Janitor's Closet            | First floor, west side of building | 6    | 1        | SF   | \$5      |                                       |
| Mechanical/Service Rooms |                                 | Storage Room                | North side of building             | 5    | 160      | SF   | \$1,812  |                                       |
| Mechanical/Service Rooms |                                 | Storage Room                | First floor, west side of building | 7    | 171      | SF   | \$0      |                                       |
| Mechanical/Service Rooms |                                 | Storage Room                | room 712, storage room             | 6    | 168      | SF   | \$793    |                                       |
| Mechanical/Service Rooms |                                 | Storage Room                | First floor, west side of building | 6    | 10       | SF   | \$47     |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                 | Boys bathroom                      | 6    | 183      | SF   | \$1,413  |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                 | Girls bathroom                     | 6    | 164      | SF   | \$1,266  |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                 | room 708 bathroom                  | 6    | 48       | SF   | \$371    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Ceiling - Lay-In            | room 708 bathroom                  | 6    | 48       | SF   | \$103    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Ceiling - Lay-In            | Boys bathroom                      | 6    | 183      | SF   | \$393    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Floor Drain                 | room 708 bathroom                  | 6    | 1        | EA   | \$300    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Floor Drain                 | Girls bathroom                     | 6    | 1        | EA   | \$300    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Floor Drain                 | Boys bathroom                      | 6    | 1        | EA   | \$300    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Flooring - Tile/Sheet       | room 708 bathroom                  | 6    | 48       | SF   | \$69     |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Flooring - Tile/Sheet       | Girls bathroom                     | 6    | 164      | SF   | \$235    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Flooring - Tile/Sheet       | Boys bathroom                      | 6    | 183      | SF   | \$262    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Lavatory                    | Girls bathroom                     | 6    | 2        | EA   | \$744    |                                       |
| Staff Restroom           | Adult Standard Student Restroom | Lavatory                    | room 708 bathroom                  | 2    | 1        | EA   | \$3,718  | broken off wall and needs replacement |
| Staff Restroom           | Adult Standard Student Restroom | Lavatory                    | Boys bathroom                      | 6    | 1        | EA   | \$372    |                                       |

**Building: Annex**  
**Category: INTERIOR**

| Group                     | Sub Group                       | Item                        | Location          | Rank | Quantity | Unit | Cost            | Reason |
|---------------------------|---------------------------------|-----------------------------|-------------------|------|----------|------|-----------------|--------|
| Staff Restroom            | Adult Standard Student Restroom | Lighting - Lay-In           | room 708 bathroom | 6    | 1        | SF   | \$1             |        |
| Staff Restroom            | Adult Standard Student Restroom | Lighting - Pendant/ Surface | Boys bathroom     | 6    | 2        | SF   | \$1             |        |
| Staff Restroom            | Adult Standard Student Restroom | Lighting - Pendant/ Surface | Girls bathroom    | 6    | 2        | SF   | \$1             |        |
| Staff Restroom            | Adult Standard Student Restroom | Partitions                  | room 708 bathroom | 6    | 1        | EA   | \$179           |        |
| Staff Restroom            | Adult Standard Student Restroom | Partitions                  | Girls bathroom    | 6    | 3        | EA   | \$538           |        |
| Staff Restroom            | Adult Standard Student Restroom | Partitions                  | Boys bathroom     | 6    | 2        | EA   | \$359           |        |
| Staff Restroom            | Adult Standard Student Restroom | Urinals                     | Boys bathroom     | 6    | 2        | EA   | \$744           |        |
| Staff Restroom            | Adult Standard Student Restroom | Wall - Plaster/Drywall      | Girls bathroom    | 6    | 420      | SF   | \$991           |        |
| Staff Restroom            | Adult Standard Student Restroom | Wall - Plaster/Drywall      | Boys bathroom     | 6    | 462      | SF   | \$1,090         |        |
| Staff Restroom            | Adult Standard Student Restroom | Wall - Plaster/Drywall      | room 708 bathroom | 6    | 154      | SF   | \$363           |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                | room 708 bathroom | 6    | 1        | EA   | \$372           |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                | Girls bathroom    | 6    | 3        | EA   | \$1,115         |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                | Boys bathroom     | 6    | 2        | EA   | \$744           |        |
| <b>INTERIOR Sub Total</b> |                                 |                             |                   |      |          |      | <b>\$50,582</b> |        |

**Building: Annex**  
**Category: ROOM**

| Group    | Sub Group | Item     | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|-----------|----------|----------|------|----------|------|------|--------|
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |
| Casework | Classroom | Casework |          |      |          | LF   | \$0  |        |

**Building: Annex**  
**Category: ROOM**

| Group       | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost    | Reason |
|-------------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 690      | SF   | \$1,480 |        |
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 520      | SF   | \$1,115 |        |
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 692      | SF   | \$1,484 |        |
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 690      | SF   | \$1,480 |        |
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 690      | SF   | \$1,480 |        |
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling     | Classroom | Lay-In/Drop     |          | 6    | 695      | SF   | \$1,491 |        |
| Ceiling     | Classroom | Plaster/Drywall |          | 6    | 528      | SF   | \$1,495 |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Chalk Board | Classroom | Chalk Board     |          | 4    |          | LF   |         |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 528      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 520      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 690      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 730      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 690      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 695      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 730      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 692      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 730      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet      |          | 7    | 690      | SF   | \$0     |        |
| Lighting    | Classroom | Lay-In          |          | 6    | 10       | EA   | \$715   |        |
| Lighting    | Classroom | Lay-In          |          | 6    | 8        | EA   | \$572   |        |
| Lighting    | Classroom | Lay-In          |          | 6    | 8        | EA   | \$572   |        |
| Lighting    | Classroom | Lay-In          |          | 6    | 12       | EA   | \$858   |        |
| Lighting    | Classroom | Lay-In          |          | 6    | 10       | EA   | \$715   |        |
| Lighting    | Classroom | Lay-In          |          | 6    | 10       | EA   | \$715   |        |
| Lighting    | Classroom | Lay-In          |          | 6    | 10       | EA   | \$715   |        |

**Building: Annex**  
**Category: ROOM**

| Group                 | Sub Group                       | Item                | Location       | Rank | Quantity | Unit | Cost            | Reason |
|-----------------------|---------------------------------|---------------------|----------------|------|----------|------|-----------------|--------|
| Lighting              | Classroom                       | Lay-In              |                | 6    | 12       | EA   | \$858           |        |
| Lighting              | Classroom                       | Lay-In              |                | 6    | 12       | EA   | \$858           |        |
| Lighting              | Classroom                       | Lay-In              |                | 6    | 10       | EA   | \$715           |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 6    | 16       | LF   | \$458           |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board        |                | 7    | 10       | LF   | \$0             |        |
| RESTROOM_CEILING      | Adult Standard Student Restroom | Restroom Ceiling    | Girls bathroom | 6    | 164      | SF   | \$464           |        |
| Wall                  | Classroom                       | Metal/Folding Panel |                | 6    | 178      | SF   | \$420           |        |
| Wall                  | Classroom                       | Metal/Folding Panel |                | 6    | 178      | SF   | \$420           |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 5    | 514      | SF   | \$2,426         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 794      | SF   | \$1,873         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 912      | SF   | \$2,152         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 912      | SF   | \$2,152         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 794      | SF   | \$1,873         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 794      | SF   | \$1,873         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 912      | SF   | \$2,152         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 692      | SF   | \$1,633         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 794      | SF   | \$1,873         |        |
| Wall                  | Classroom                       | Plaster/Drywall     |                | 6    | 620      | SF   | \$1,463         |        |
| <b>ROOM Sub Total</b> |                                 |                     |                |      |          |      | <b>\$43,249</b> |        |

**Building Annex Sub Total \$1,061,752**

**Building: SITE**  
**Category: SITE**

| Group          | Sub Group | Item         | Location        | Rank | Quantity | Unit | Cost  | Reason |
|----------------|-----------|--------------|-----------------|------|----------|------|-------|--------|
| Civil/Drainage |           | Site Drain   | Entire Building | 6    | 8        | EA   | \$892 |        |
| Civil/Drainage |           | Site Manhole | Entire Building | 7    | 5        | EA   | \$0   |        |
| Fencing        |           | Chain Link   | Chimney         | 6    | 54       | LF   | \$775 |        |

Building: SITE  
Category: SITE

| Group       | Sub Group | Item                        | Location                                      | Rank | Quantity | Unit | Cost     | Reason   |
|-------------|-----------|-----------------------------|---|------|----------|------|----------|--|
| Fencing     |           | Chain Link                  | Southeast corner                              | 6    | 32       | LF   | \$459    |  |
| Fencing     |           | Chain Link                  | Cellular equipment                            | 6    | 36       | LF   | \$516    |  |
| Fencing     |           | Ornamental Iron             | North of modular                              | 4    | 6        | LF   | \$1,133  | Replace damaged section                                |
| Fencing     |           | Ornamental Iron             | Entire site                                   | 6    | 802      | LF   | \$15,139 |  |
| Fencing     |           | Wood Fencing w/ Steel Frame | Cellular equipment                            | 5    | 36       | LF   | \$1,457  |  |
| Fencing     |           |                             | Cellular equipment                            | 5    | 36       | LF   | \$1,457  |  |
| Landscape   |           | Benches                     | North Courtyard                               | 6    | 3        | EA   | \$708    |  |
| Landscape   |           | Grass                       | North Courtyard                               | 6    | 5,992    | SF   | \$2,399  |  |
| Landscape   |           | Grass                       | Entire site                                   | 6    | 26,698   | SF   | \$10,690 |  |
| Landscape   |           | Grass                       | South grass surrounding parking lot           | 6    | 18,879   | SF   | \$7,559  |  |
| Landscape   |           | Grass                       | Northwest corner of building                  | 4    | 1,662    | SF   | \$6,583  | Vehicular damage, missing grass                        |
| Landscape   |           | Grass                       | South Courtyard                               | 6    | 3,134    | SF   | \$1,255  |  |
| Landscape   |           | Hardscape - Concrete        | South Courtyard                               | 7    | 5,618    | SF   | \$0      |  |
| Landscape   |           | Hardscape - Concrete        | North Courtyard                               | 7    | 6,068    | SF   | \$0      |  |
| Landscape   |           | Hardscape - Concrete        | Main Entrance                                 | 5    | 9,506    | SF   | \$59,268 | Minor spalling, some significant cracking              |
| Landscape   |           | Hardscape - Concrete        | East & West                                   | 5    | 259      | SF   | \$1,615  | Standing water after rain                              |
| Landscape   |           | Hardscape - Concrete        | Main Entrance                                 | 7    | 731      | SF   | \$0      |  |
| Landscape   |           | Hardscape - Pavers          | Main Entrance                                 | 5    | 82       | SF   | \$766    | Remove pavers, regrade, and replace pavers             |
| Landscape   |           | Parkway trees               | East side of the property along Michigan Ave. | 7    | 15       | EA   | \$0      |  |
| Landscape   |           | Planting Beds/ Areas        | Entire site                                   | 6    | 1,648    | SF   | \$0      |  |
| Landscape   |           | Planting Beds/ Areas        | South Courtyard                               | 7    | 543      | SF   | \$0      |  |
| Landscape   |           | Retaining Wall - Concrete   | Areaways                                      | 6    | 780      | SF   | \$18,404 |  |
| Landscape   |           | Retaining Wall - Concrete   | Southeast basement stair                      | 6    | 156      | SF   | \$3,681  |  |
| Parking Lot |           | Asphalt                     | South Parking lot, East of the Annex          | 6    | 62,054   | SF   | \$53,242 | Minor crack filling, seal coat, and stripe recommended |
| Parking Lot |           | Asphalt                     | South   | 5    | 600      | SF   | \$1,699  | Regrade, replace sunken asphalt sections               |
| Parking Lot |           | Concrete                    | Parking lot                                   | 6    | 155      | SF   | \$0      |  |
| Parking Lot |           | Concrete                    | Entire Building                               | 6    | 983      | SF   | \$0      |  |
| Parking Lot |           | Concrete                    | South, east edges of lot                      | 7    | 603      | SF   | \$0      |  |
| Parking Lot |           | Concrete Curbs              | North Courtyard                               | 7    | 174      | LF   | \$0      |  |
| Parking Lot |           | Concrete Curbs              | Southwest path                                | 7    | 84       | LF   | \$0      |  |
| Parking Lot |           | Concrete Curbs              | Parking lot                                   | 6    | 796      | LF   | \$4,804  |  |
| Parking Lot |           | Concrete Curbs              | South Courtyard                               | 7    | 138      | LF   | \$0      |  |
| Parking Lot |           | Trash Enclosure             | South   | 6    | 726      | SF   | \$7,786  |  |

**Building: SITE**  
**Category: SITE**

| Group                 | Sub Group | Item  | Location                                      | Rank | Quantity | Unit | Cost             | Reason |
|-----------------------|-----------|---|---|------|----------|------|------------------|--------|
| Parking Lot           |           | Vehicular Screening                         | Parking lot                                   | 6    | 454      | LF   | \$0              |        |
| Sidewalks             |           | Internal Walks                              | South Courtyard                               | 7    | 120      | LF   | \$0              |        |
| Sidewalks             |           | Internal Walks                              | West side of the property                     | 6    | 465      | LF   | \$4,389          |        |
| Sidewalks             |           | Internal Walks                              | North Courtyard                               | 7    | 122      | LF   | \$0              |        |
| Sidewalks             |           | Perimeter Sidewalks                         | East side of the proeprty along Michigan Ave. | 6    | 3,800    | SF   | \$7,173          |        |
| Signage               |           | Flag Pole                                   | Main Entrance                                 | 6    | 1        | EA   | \$0              |        |
| Signage               |           | Marquee - Free Standing Back Lighted w/ LED | Main Entrance                                 | 6    | 1        | EA   | \$0              |        |
| <b>SITE Sub Total</b> |           |   |   |      |          |      | <b>\$212,391</b> |        |
| <b>SITE Sub Total</b> |           |   |   |      |          |      | <b>\$212,391</b> |        |

**Total Campus Need <sup>2 3</sup> \$13,690,732**

<sup>1</sup> It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

<sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

**Room Summary**

| Room Number           | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-----------------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-----------|---------------|----------|
| <b>Building: Main</b> |           |              |             |              |             |                   |                      |                  |             |             |             |           |               |          |
| 104                   | 1014      | 2            | 3           | 42           | 53          | 271               | 130                  |                  | N           | N           | Y           | Classroom |               |          |
| 106                   | 1383      | 1            | 41          | 50           | 53          | 373               | 180                  |                  | N           | N           | Y           | Classroom |               |          |
| 107                   | 1043      | 0            | 1           | 40           | 40          | 176               | 173                  |                  | Y           | N           | N           | Classroom |               |          |
| 109                   | 932       | 1            | 8           | 18           | 40          | 160               | 158                  |                  | Y           | N           | N           | Classroom |               |          |
| 110                   | 924       | 1            | 3           | 60           | 53          | 255               | 125                  |                  | N           | N           | Y           | Classroom |               |          |
| 112                   | 961       | 0            | 39          | 78           | 56          | 278               | 136                  |                  | N           | N           | Y           | Classroom |               |          |
| 114                   | 1430      | 1            | 34          | 108          | 53          | 242               | 120                  |                  | N           | N           | Y           | Classroom |               |          |
| 115                   | 1144      | 2            | 32          | 66           | 40          | 176               | 158                  | 2                | Y           | Y           | N           | Classroom |               |          |
| 116                   | 1516      | 1            | 34          | 108          | 53          | 242               | 120                  |                  | N           | N           | Y           | Classroom |               |          |
| 120                   | 1014      | 1            | 17          | 48           | 40          | 160               | 158                  |                  | Y           | N           | N           | Classroom |               |          |
| 121                   | 581       | 1            | 8           | 18           | 40          | 97                | 95                   |                  | Y           | N           | N           | Classroom |               |          |
| 125                   | 831       | 1            | 8           | 20           | 40          | 144               | 142                  |                  | Y           | N           | N           | Classroom |               |          |
| 130                   | 714       | 1            | 8           | 18           | 40          | 91                | 72                   | 1                | N           | N           | N           | Classroom |               |          |
| 132                   | 755       | 1            | 8           | 22           | 40          | 98                | 72                   | 2                | Y           | N           | N           | Classroom |               |          |
| 133                   | 1431      | 1            | 8           | 22           | 40          | 149               | 147                  |                  | Y           | N           | N           | Classroom |               |          |
| 134                   | 1782      | 1            | 8           | 20           | 40          | 165               | 163                  |                  | Y           | N           | N           | Classroom |               |          |
| 138                   | 891       | 1            | 9           | 20           | 40          | 0                 | 0                    |                  | Y           | N           | N           | Classroom |               |          |
| 139                   | 829       | 1            | 8           | 18           | 40          | 104               | 102                  |                  | Y           | N           | N           | Classroom |               |          |
| 204                   | 671       | 1            | 6           | 14           | 53          | 170               | 39                   |                  | N           | N           | Y           | Classroom |               |          |
| 206                   | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom |               |          |
| 207                   | 737       | 1            | 10          | 20           | 50          | 210               | 100                  | 0                | N           | N           | Y           | Classroom |               |          |
| 208                   | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom |               |          |
| 209                   | 737       | 1            | 9           | 34           | 50          | 210               | 100                  | 0                | N           | N           | Y           | Classroom |               |          |
| 210                   | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom |               |          |
| 211                   | 737       | 1            | 9           | 20           | 50          | 210               | 100                  | 0                | N           | N           | N           | Classroom |               |          |
| 212                   | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom |               |          |
| 214                   | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom |               |          |
| 216                   | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom |               |          |
| 218                   | 912       | 1            | 31          | 78           | 40          | 255               | 125                  | 1                | N           | N           | N           | Classroom |               |          |
| 219                   | 1131      | 0            | 29          | 86           | 53          | 315               | 150                  | 0                | N           | N           | Y           | Classroom |               |          |
| 220                   | 912       | 1            | 31          | 78           | 40          | 255               | 125                  | 1                | N           | N           | N           | Classroom |               |          |
| 221                   | 1171      | 1            | 10          | 26           | 40          | 415               | 150                  | 0                | N           | N           | Y           | Classroom |               |          |
| 222                   | 912       | 1            | 31          | 78           | 40          | 255               | 125                  | 1                | N           | N           | N           | Classroom |               |          |
| 226                   | 619       | 1            | 8           | 18           | 40          | 98                | 84                   |                  | Y           | N           | N           | Classroom |               |          |
| 227                   | 1292      | 1            | 9           | 24           | 50          | 204               | 87                   | 1                | N           | N           | Y           | Classroom |               |          |
| 228                   | 619       | 1            | 8           | 18           | 40          | 98                | 84                   |                  | Y           | N           | N           | Classroom |               |          |

**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                   | Location                              |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|---------------------------------------|
| 229         | 725       | 0            | 7           | 20           | 40          | 208               | 100                  | 1                | N           | N           | Y           | Classroom                     |                                 |                                       |
| 230         | 619       | 1            | 8           | 18           | 40          | 98                | 84                   |                  | Y           | N           | N           | Classroom                     |                                 |                                       |
| 231         | 735       | 0            | 1           | 8            | 40          | 208               | 100                  |                  | N           | N           | N           | Classroom                     |                                 |                                       |
| 232         | 619       | 1            | 8           | 18           | 40          | 98                | 84                   |                  | Y           | N           | N           | Classroom                     |                                 |                                       |
| 234         | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom                     |                                 |                                       |
| 236         | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom                     |                                 |                                       |
| 238         | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom                     |                                 |                                       |
| 239         | 818       | 1            | 8           | 20           | 50          | 235               | 110                  | 0                | N           | N           | N           | Classroom                     |                                 |                                       |
| 240         | 727       | 1            | 8           | 18           | 40          | 124               | 96                   | 0                | Y           | N           | N           | Classroom                     |                                 |                                       |
| 241         | 818       | 1            | 9           | 22           | 50          | 235               | 110                  | 0                | N           | N           | Y           | Classroom                     |                                 |                                       |
| 242         | 742       | 1            | 8           | 16           | 40          | 98                | 84                   |                  | Y           | N           | N           | Classroom                     |                                 |                                       |
| Other       | 206       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd floor boys along corridor at NW   |
| Other       | 206       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd floor boys along corridor at NE   |
| Other       | 206       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd floor boys along corridor at SE   |
| Other       | 3360      |              |             |              |             |                   |                      |                  | N           | N           | N           | Library                       |                                 | 1st Floor                             |
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd floor girls along corridor at SE  |
| Other       | 1890      |              |             |              |             |                   |                      |                  | N           | N           | N           | Kitchen                       | Cooking Kitchen                 | 1st Floor                             |
| Other       | 288       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Locker/Shower Room              | 1st floor employee inside kitchen     |
| Other       | 3600      |              |             | 60           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor main office                 |
| Other       | 22        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor inside principal office     |
| Other       | 48        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor inside main office          |
| Other       | 183       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor to north of Auditorium #135 |
| Other       | 8325      |              |             |              |             |                   |                      |                  | N           | N           | N           | Lunch & Multipurpose Room     | Lunchroom                       | 1st Floor                             |
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd floor girls along corridor at NE  |
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd floor girls along corridor at NW  |
| Other       | 229       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st floor girls along corridor at NW  |
| Other       | 229       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st floor girls along corridor at SE  |
| Other       | 460       |              |             | 8            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor #123                        |
| Other       | 205       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st floor boys along corridor at SE   |
| Other       | 205       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st floor boys along corridor at NE   |
| Other       | 205       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st floor boys along corridor at NW   |
| Other       | 5476      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Standard Dedicated Gymnasium    | 1st floor girls gym                   |
| Other       | 2700      |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Locker/Shower Room              | 1st floor girls                       |
| Other       | 3150      |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Locker/Shower Room              | 1st floor boys                        |



**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                   | Location  |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|---|
| Other       | 1311      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Standard Dedicated Gymnasium    | 1st floor weight room to east of boys locker rm |
| Other       | 8743      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Standard Dedicated Gymnasium    | 1st floor boys                                  |
| Other       | 127       |              |             | 0            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 112A  |
| Other       | 229       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st floor girls along corridor at NE            |
| Other       | 1600      |              |             | 18           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor rm #118                               |
| Other       | 142       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor to north of Auditorium #136           |
| Other       | 140       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor to north of Auditorium #137           |
| Other       | 96        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor inside office #137                    |
| Other       | 1390      |              |             | 12           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor Rms 131 & 131B                        |
| Other       | 115       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor women's next to boiler room           |
| Other       | 65        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor unisex next to boiler room            |
| Other       | 15        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor inside nurses office                  |
| Other       | 204       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Basement engineer's office                      |
| Other       | 6380      |              |             |              |             |                   |                      |                  | N           | N           | N           | Auditorium & Theater          | Auditorium - Dedicated          | 1st Floor                                       |
| Other       | 293       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor next to lunch room                    |
| Other       | 293       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 2nd floor NW                                    |
| Other       | 300       |              |             | 12           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 2nd floor Rm. 218A                              |
| Other       | 2461      |              |             | 28           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor 3 offices #117, 117B & 119            |
| Other       | 235       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 2nd floor at SW                                 |
| Other       | 22        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor inside office in girls gym            |
| Other       | 96        |              |             | 4            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                 | First floor, room 133, vocal music office       |
| Other       | 110       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor inside girls gym                      |
| Other       | 22        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor inside office in boys gym             |
| Other       | 220       |              |             | 12           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor 2 offices inside boys gym             |
| Other       | 194       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st floor men's next to boiler room             |
| Other       | 150       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | 1st floor Rm113-Police office                   |
| Other       | 191       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Locker/Shower Room              | Basement  |

**Building: Addition**

|       |     |  |  |  |  |  |  |  |   |   |   |          |                                 |   |
|-------|-----|--|--|--|--|--|--|--|---|---|---|----------|---------------------------------|---|
| Other | 114 |  |  |  |  |  |  |  | N | N | N | Restroom | Adult Standard Student Restroom | 1st floor boys inside pool locker room  |
| Other | 688 |  |  |  |  |  |  |  | N | N | N | Restroom | Locker/Shower Room              | 1st floor unisex locker inside pool     |
| Other | 136 |  |  |  |  |  |  |  | N | N | N | Restroom | Adult Standard Student Restroom | 1st floor girls inside pool locker room |

**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type                   | Location                      |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-----------|---------------------------------|-------------------------------|
| Other       | 85        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom  | Adult Standard Student Restroom | 1st floor unisex open to pool |

**Building: Annex**

|       |     |   |   |    |    |    |   |   |   |   |   |                               |                                 |                   |
|-------|-----|---|---|----|----|----|---|---|---|---|---|-------------------------------|---------------------------------|-------------------|
| 701   | 690 | 0 | 0 | 9  | 40 | 98 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 702   | 690 | 1 | 1 | 9  | 40 | 82 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 703   | 692 | 1 | 1 | 8  | 40 | 98 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 704   | 695 | 1 | 1 | 9  | 40 | 82 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 705   | 730 | 2 | 1 | 8  | 40 | 98 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 706   | 520 | 1 | 1 | 8  | 40 | 82 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 707   | 730 | 2 | 1 | 8  | 40 | 98 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 708   | 730 | 2 | 1 | 8  | 40 | 75 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 710   | 690 | 0 | 0 | 9  | 40 | 98 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| 712   | 528 | 0 | 0 | 2  | 40 | 82 | 0 | 1 | N | N | N | Classroom                     |                                 |                   |
| Other | 183 |   |   |    |    |    |   |   | N | N | N | Restroom                      | Adult Standard Student Restroom | Boys bathroom     |
| Other | 164 |   |   |    |    |    |   |   | N | N | N | Restroom                      | Adult Standard Student Restroom | Girls bathroom    |
| Other | 48  |   |   |    |    |    |   |   | N | N | N | Restroom                      | Adult Standard Student Restroom | room 708 bathroom |
| Other | 580 |   |   | 20 |    |    |   |   | N | N | N | Administrative Suites/Offices |                                 | main office suite |