

## Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at [http://www.cps.edu/About\\_CPS/Policies\\_and\\_guidelines/Pages/facilitystandards.aspx](http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx).

### Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.<sup>1</sup>

### Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

### Building: Main Category: EXTERIOR

| Group       | Sub Group | Item                                   | Location               | Rank | Quantity | Unit | Cost      | Reason               |
|-------------|-----------|--|------------------------|------|----------|------|-----------|----------------------|
| Chimney     |           | Brick Chimney - Concrete/ Mortar Liner | Boiler Room            | 5    | 60       | LF   | \$107,250 | brick falling inside |
| Cornice     |           | Cornice - Masonry Projecting/Limestone | North Façade           | 7    | 202      | LF   | \$0       |                      |
| Doors       |           | Exterior Steel Door                    | throughout             | 7    | 15       | EA   | \$0       |                      |
| Doors       |           | Transom Lite                           | throughout             | 7    | 7        | EA   | \$0       |                      |
| Entrance    |           | Concrete Exterior Stairs               | throughout             | 6    | 48       | LF   | \$5,148   |                      |
| Entrance    |           | Concrete Exterior Stairs               | throughout             | 7    | 30       | LF   | \$0       |                      |
| Entrance    |           | Concrete Ramp                          | throughout             | 7    | 15       | LF   | \$0       |                      |
| Entrance    |           | Ramp Handrails                         | throughout             | 6    | 50       | LF   | \$0       |                      |
| Entrance    |           | Stair Handrails                        | throughout             | 6    | 8        | LF   | \$0       |                      |
| Fire Escape |           | Fire Escapes                           | courtyard, S elevation | 5    | 80       | LF   | \$25,483  |                      |
| Foundation  |           | Masonry Foundation                     | Entire Building        | 7    | 27,363   | SF   | \$0       |                      |
| Lighting    |           | Exterior Lights - Wall Mounted         | courtyard              | 6    | 4        | EA   | \$858     |                      |
| Lintels     |           | Lintels - Brick                        | N Auditorium elevation | 6    | 48       | LF   | \$0       |                      |

**Building: Main**  
**Category: EXTERIOR**

| Group          | Sub Group | Item                                      | Location                           | Rank | Quantity | Unit | Cost      | Reason                                |
|----------------|-----------|---|------------------------------------|------|----------|------|-----------|---------------------------------------|
| Lintels        |           | Lintels - Steel                           | throughout                         | 7    | 434      | LF   | \$0       |                                       |
| Lintels        |           | Lintels - Stone                           | throughout                         | 6    | 108      | LF   | \$0       |                                       |
| Parapet        |           | Coping - Metal                            | Roofs                              | 7    | 1,319    | LF   | \$0       |                                       |
| Parapet        |           | Coping - Stone                            | Roofs                              | 7    | 438      | LF   | \$0       |                                       |
| Parapet        |           | Coping - Terra Cotta                      | Roofs                              | 7    | 301      | LF   | \$0       |                                       |
| Parapet        |           | Parapet < 16" Height                      | mid boiler roof, SW elevation      | 5    | 20       | LF   | \$4,813   | mortar                                |
| Parapet        |           | Parapet < 16" Height                      | Roofs                              | 7    | 2,000    | LF   | \$0       |                                       |
| Parapet        |           | Parapet > 30" Height                      | above auditorium, S elevation      | 4    | 8        | LF   | \$7,951   |                                       |
| Parapet        |           | Parapet 16" to 30" Height                 | above Auditorium, S elevation      | 7    | 30       | LF   | \$0       |                                       |
| Roof System    |           | Asphalt Shingle Roof                      | auditorium                         | 7    | 4,860    | SF   | \$0       |                                       |
| Roof System    |           | Exterior Downspouts                       | Roofs                              | 7    | 148      | LF   | \$0       |                                       |
| Roof System    |           | Interior Downspouts                       | Roofs                              | 7    | 142      | LF   | \$0       |                                       |
| Roof System    |           | Metal Roof                                | auditorium roof                    | 7    | 1,380    | SF   | \$0       |                                       |
| Roof System    |           | Modified Bitumen Roof                     | Roofs                              | 6    | 25,651   | SF   | \$181,571 |                                       |
| Roof System    |           | Roof Structure: Heavy Timber              | SE roof                            | 7    | 2,900    | SF   | \$0       |                                       |
| Roof System    |           | Roof Structure: Steel with Clay Tile Arch | Roofs                              | 7    | 27,263   | SF   | \$0       |                                       |
| Superstructure |           | Steel with Clay Tile Arch                 | Entire Building                    | 7    | 82,233   | SF   | \$0       |                                       |
| Walls          |           | Brick                                     | Entire Building                    | 7    | 45,352   | SF   | \$0       |                                       |
| Walls          |           | Brick                                     | E auditorium at driveway           | 5    | 50       | SF   | \$1,133   | vertical cracks                       |
| Walls          |           | Brick                                     | SW corner of boiler house          | 4    | 10       | SF   | \$755     | shearing off                          |
| Walls          |           | Brick                                     | S & W boiler house                 | 5    | 250      | SF   | \$5,663   |                                       |
| Walls          |           | Brick                                     | W auditorium                       | 5    | 200      | SF   | \$4,530   | some minor bulging                    |
| Walls          |           | Prefabricated Metal Panel Wall            | Auditorium roof level, S elevation | 6    | 1,000    | SF   | \$8,494   |                                       |
| Walls          |           | Prefabricated Metal Panel Wall            | throughout                         | 6    | 880      | SF   | \$7,475   |                                       |
| Walls          |           | Stone - Cast                              | throughout                         | 6    | 3,280    | SF   | \$46,904  |                                       |
| Walls          |           | Stone - Cut                               | Roof - E elevation of Auditorium   | 5    | 40       | SF   | \$4,290   |                                       |
| Walls          |           | Stone - Cut                               | Courtyard                          | 6    | 480      | SF   | \$6,864   |                                       |
| Windows        |           | Skylite - Glass Double-Pane               | Roofs                              | 7    | 530      | SF   | \$0       |                                       |
| Windows        |           | Window - Guards wire guard                | interior gymnasium                 | 7    | 1,122    | SF   | \$0       |                                       |
| Windows        |           | Windows - Casement Aluminum               | Courtyard                          | 5    | 340      | SF   | \$7,541   | broken latches, many are screwed shut |
| Windows        |           | Windows - Casement Aluminum Double-pane   | throughout exterior                | 5    | 170      | SF   | \$3,914   | broken latches, many are screwed shut |
| Windows        |           | Windows - Decorative                      | N elevation                        | 7    | 43       | SF   | \$0       |                                       |
| Windows        |           | Windows - Decorative                      | SW corridor                        | 7    | 120      | SF   | \$0       |                                       |

**Building: Main**  
**Category: EXTERIOR**

| Group                     | Sub Group | Item                                | Location        | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|-----------|-------------------------------------|-----------------|------|----------|------|------------------|--------|
| Windows                   |           | Windows - Sash Aluminum             | Courtyard       | 7    | 2,414    | SF   | \$0              |        |
| Windows                   |           | Windows - Sash Aluminum Double-pane | outer perimeter | 7    | 2,176    | SF   | \$0              |        |
| <b>EXTERIOR Sub Total</b> |           |                                     |                 |      |          |      | <b>\$430,636</b> |        |

**Building: Main**  
**Category: ELECTRICAL**

| Group                       | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost             | Reason   |
|-----------------------------|-----------|---|-----------------|------|----------|------|------------------|--|
| Emergency System            |           | Emergency A/C power - Auditorium and aisle lighting | 1st Floor       | 7    | 12,719   | SF   | \$0              |  |
| Emergency System            |           | Emergency A/C power - Corridors and Stairs          | Entire Building | 7    | 26,788   | SF   | \$0              |  |
| Emergency System            |           | Emergency A/C power - Gym and Lunch rooms           | Basement        | 7    | 4,317    | SF   | \$0              |  |
| Emergency System            |           | Emergency generator 100 to 150 KW diesel - Outdoor  | North Façade    | 7    | 1        | EA   | \$0              |  |
| Emergency System            |           | Exit Signs - Auditorium                             | 1st Floor       | 4    | 10       | EA   | \$9,295          |  |
| Emergency System            |           | Exit Signs - Corridors and Stairs                   | Entire Building | 4    | 32       | EA   | \$29,744         |  |
| Emergency System            |           | Public Announcement System                          | Entire Building | 6    | 377,647  | SF   | \$226,815        |  |
| Emergency System            |           | Security System - Intrusion detection               | Entire Building | 6    | 377,647  | SF   | \$351,023        |  |
| Power Distribution          |           | Lighting and power panels                           | Entire Building | 6    | 9        | EA   | \$6,435          |  |
| Power Distribution          |           | Main distribution panels 400-600 amp                | Boiler Room     | 4    | 2        | EA   | \$24,310         | Distribution panel is greater than 40 years of age |
| Power Distribution          |           | Main distribution panels above 600 amp              | Boiler Room     | 4    | 2        | EA   | \$37,180         |  |
| <b>ELECTRICAL Sub Total</b> |           |   |                 |      |          |      | <b>\$684,802</b> |  |

**Building: Main**  
**Category: FIRE PROTECTION**

| Group                            | Sub Group | Item                     | Location        | Rank | Quantity | Unit | Cost             | Reason   |
|----------------------------------|-----------|--------------------------|-----------------|------|----------|------|------------------|--|
| Fire Alarm                       |           | Fire Alarm Strobe Lights | Entire Building | 3    | 82,233   | SF   | \$174,038        | Strobe lights are not provided or not located in all areas |
| Fire Alarm                       |           | Fire Alarm System        | Entire Building | 4    | 82,233   | SF   | \$290,455        |  |
| <b>FIRE PROTECTION Sub Total</b> |           |                          |                 |      |          |      | <b>\$464,493</b> |  |

**Building: Main**  
**Category: MECHANICAL**

| Group                | Sub Group | Item                                    | Location  | Rank | Quantity | Unit | Cost     | Reason |
|----------------------|-----------|---|-----------|------|----------|------|----------|--------|
| Air Conditioning     |           | Window A/C Unit                         | 3rd Floor | 4    | 2        | EA   | \$4,290  |        |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit | Basement  | 4    | 2        | EA   | \$52,338 |        |

**Building: Main**  
**Category: MECHANICAL**

| Group                       | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost               | Reason  |
|-----------------------------|-----------|---|-----------------|------|----------|------|--------------------|---|
| Air Handling Systems        |           | Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm              | Basement        | 4    | 1        | EA   | \$92,950           |   |
| Air Handling Systems        |           | Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm  | Basement        | 4    | 1        | EA   | \$32,890           |   |
| Air Handling Systems        |           | Return Duct Work - Indoor - Vertical Shaft and Ducts                            | Entire Building | 4    | 0        | LF   | \$0                |   |
| Air Handling Systems        |           | Single Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm             | Basement        | 4    | 1        | EA   | \$78,650           |   |
| Air Handling Systems        |           | Single Zone Built Up Air Handling Unit Auxiliaries - Steam 4,000 to 8,000 cfm   | Basement        | 2    | 1        | EA   | \$7,150            | Unit is more than 40 years of age and cannot maintain the proper temperatures during severe weather condition |
| Boiler Systems              |           | Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 76-100 HP           | Boiler Room     | 5    | 1        | EA   | \$57,200           |   |
| Boiler Systems              |           | Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler greater than 200 HP | Boiler Room     | 4    | 2        | EA   | \$597,740          |   |
| Boiler Systems              |           | Boiler Auxiliary - Steam Boiler 50-75 HP  | Boiler Room     | 5    | 1        | EA   | \$9,295            |   |
| Boiler Systems              |           | Boiler Auxiliary - Steam Boiler greater than 200 HP                             | Boiler Room     | 4    | 2        | EA   | \$65,780           |   |
| Boiler Systems              |           | Chemical Feed System (Steam Boilers)  | Basement        | 6    | 1        | EA   | \$2,145            |   |
| Boiler Systems              |           | Combustion Dampers  | Boiler Room     | 6    | 2        | EA   | \$572              |   |
| Boiler Systems              |           | Feed Water Pumps and Tank - Steam Boilers                                       | Boiler Room     | 4    | 1        | EA   | \$31,460           |   |
| Heating Devices             |           | Radiators - Steam   | Entire Building | 4    | 20       | EA   | \$28,028           |   |
| Mechanical Plumbing         |           | Condensate Assembly - Pumps and Tank  | Basement        | 5    | 2        | EA   | \$18,876           |   |
| Mechanical Plumbing         |           | Piping - Condensate - Steel or Galvanized                                       | Entire Building | 4    | 300      | LF   | \$29,387           |   |
| Mechanical Plumbing         |           | Piping - Steam - Steel or Galvanized  | Entire Building | 4    | 300      | LF   | \$35,929           |   |
| Temperature Control         |           | Pneumatic System  | Entire Building | 3    | 377,647  | SF   | \$2,700,176        | Controls are more than 30 years of age and only few of the controls work                                      |
| Temperature Control         |           | Thermostats - Pneumatic   | Entire Building | 4    | 20       | EA   | \$13,156           |   |
| Temperature Control         |           | Zone Dampers  | Entire Building | 3    | 17       | EA   | \$14,343           | Dampers opened manually by wood blocks, controls do not work  |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm                                    | Roof            | 5    | 3        | EA   | \$3,861            |   |
| <b>MECHANICAL Sub Total</b> |           |   |                 |      |          |      | <b>\$3,876,215</b> |   |

**Building: Main**  
**Category: PLUMBING**

| Group     | Sub Group | Item  | Location    | Rank | Quantity | Unit | Cost | Reason |
|-----------|-----------|---|-------------|------|----------|------|------|--------|
| Hot Water |           | Hot Water Heater - Gas more than 300,000 BTU/HR | Boiler Room | 7    | 3        | EA   | \$0  |        |

**Building: Main**  
**Category: PLUMBING**

| Group                     | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost             | Reason   |
|---------------------------|-----------|--|-----------------|------|----------|------|------------------|--|
| Hot Water                 |           | Storage Tank more than 500 gallons                   | Boiler Room     | 4    | 2        | EA   | \$57,200         |  |
| Piping                    |           | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 3    | 82,233   | SF   | \$27,046         | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Domestic Piping - Cold Water Risers                  | Entire Building | 3    | 82,233   | SF   | \$52,917         | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Domestic Piping - Hot Water from Riser to fixtures   | Entire Building | 3    | 82,233   | SF   | \$17,639         | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Domestic Piping - Hot Water Return Risers            | Entire Building | 3    | 82,233   | SF   | \$37,630         | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Domestic Piping - Hot Water Risers                   | Entire Building | 3    | 82,233   | SF   | \$44,685         | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Domestic Piping Cold Water Horizontal lines          | Entire Building | 3    | 82,233   | SF   | \$196,381        | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Domestic Piping Hot Water Horizontal lines           | Entire Building | 3    | 82,233   | SF   | \$162,279        | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Domestic Piping Hot Water Return Lines               | Entire Building | 3    | 82,233   | SF   | \$94,075         | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Sanitary Piping                                      | Entire Building | 5    | 82,233   | SF   | \$50,565         |  |
| Piping                    |           | Storm Piping   | Entire Building | 5    | 82,233   | SF   | \$38,806         |  |
| Piping                    |           | Vent Piping  | Entire Building | 5    | 82,233   | SF   | \$29,398         |  |
| Pumps                     |           | Domestic Booster Pump duplex                         | Basement        | 4    | 1        | EA   | \$31,460         |  |
| Pumps                     |           | Sump Pump  | Basement        | 6    | 1        | EA   | \$1,359          |  |
| <b>PLUMBING Sub Total</b> |           |  |                 |      |          |      | <b>\$841,439</b> |  |

**Building: Main**  
**Category: INTERIOR**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                              | Location               | Rank | Quantity | Unit | Cost  | Reason |
|-----------------------|-------------------------------|-----------------------------------|------------------------|------|----------|------|-------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | Room 218               | 7    | 950      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | Engineer's Office      | 6    | 291      | SF   | \$624 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | Maintenance Room       | 6    | 266      | SF   | \$571 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | Room 212               | 7    | 783      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | Room 214               | 7    | 848      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | Room 216               | 7    | 1,152    | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall         | Gym Office 012-3       | 7    | 390      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall         | Office in Room 110     | 7    | 696      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall         | Office in Room 210     | 7    | 696      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall         | Office in Room 310A    | 7    | 233      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall         | Office in Room 310     | 7    | 696      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall         | Room 133-1 Pool Office | 6    | 178      | SF   | \$504 |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile Ceramic/Porcelain | Room 133-1 Pool Office | 7    | 178      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | Room 216               | 7    | 1,152    | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | Room 214               | 7    | 848      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | Room 212               | 7    | 783      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | Maintenance Room       | 7    | 266      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | Engineer's Office      | 6    | 291      | SF   | \$416 |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood                   | Office in Room 310     | 7    | 696      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood                   | Office in Room 310A    | 7    | 233      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood                   | Office in Room 210     | 7    | 696      | SF   | \$0   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood                   | Room 218               | 7    | 950      | SF   | \$0   |        |

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                       | Location               | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|----------------------------|------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood            | Office in Room 110     | 7    | 696      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood            | Gym Office 012-3       | 7    | 390      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Office in Room 310A    | 7    | 4        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 212               | 7    | 12       | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Office in Room 110     | 7    | 9        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 216               | 7    | 18       | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 214               | 7    | 15       | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 218               | 7    | 12       | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Maintenance Room       | 7    | 2        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Office in Room 210     | 7    | 9        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Office in Room 310     | 7    | 9        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Engineer's Office      | 7    | 2        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Gym Office 012-3       | 7    | 6        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Room 133-1 Pool Office | 6    | 2        | SF   | \$1     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | Room 133-1 Pool Office | 7    | 655      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | Maintenance Room       | 6    | 645      | SF   | \$1,845 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall    | Engineer's Office      | 6    | 728      | SF   | \$1,718 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall    | Gym Office 012-3       | 7    | 538      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall    | Office in Room 110     | 7    | 1,164    | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall    | Room 212               | 6    | 1,100    | SF   | \$2,595 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall    | Room 214               | 6    | 1,084    | SF   | \$2,558 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall    | Room 218               | 6    | 1,184    | SF   | \$2,794 |        |

**Building: Main**  
**Category: INTERIOR**

| Group                  | Sub Group                     | Item                                 | Location            | Rank | Quantity | Unit | Cost     | Reason |
|------------------------|-------------------------------|--------------------------------------|---------------------|------|----------|------|----------|--------|
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall              | Room 216            | 6    | 1,126    | SF   | \$2,657  |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall              | Office in Room 210  | 7    | 1,164    | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall              | Office in Room 310A | 6    | 757      | SF   | \$1,786  |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall              | Office in Room 310  | 7    | 1,164    | SF   | \$0      |        |
| Administrative Suites  | Administrative Suites/Offices | Walls - Structural Glazed Tile       | Gym Office 012-3    | 7    | 538      | SF   | \$0      |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Balcony Seating                      | 1st Floor           | 7    | 1,080    | EA   | \$0      |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Main Floor Seating                   | 1st Floor           | 7    | 650      | EA   | \$0      |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Sound System                         | 1st Floor           | 7    | 1        | EA   | \$0      |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Stage Curtains                       | 1st Floor           | 7    | 8        | EA   | \$0      |        |
| Auditorium - Dedicated | Auditorium - Dedicated        | Stage Lighting System                | 1st Floor           | 7    | 3        | EA   | \$0      |        |
| Corridor               |                               | Ceiling - Lay-In                     | Entire Building     | 6    | 25,020   | SF   | \$53,668 |        |
| Corridor               |                               | Flooring Terrazzo                    | Entire Building     | 7    | 1,768    | SF   | \$0      |        |
| Corridor               |                               | Flooring Tile/ Sheet                 | Entire Building     | 7    | 25,020   | SF   | \$0      |        |
| Corridor               |                               | Lighting - Lay-In                    | Entire Building     | 7    | 767      | SF   | \$0      |        |
| Corridor               |                               | Stair Handrails                      | Entire Building     | 7    | 778      | LF   | \$0      |        |
| Corridor               |                               | Stairs - Terrazzo                    | Entire Building     | 7    | 376      | LF   | \$0      |        |
| Corridor               |                               | Student Lockers                      | Entire Building     | 7    | 1,415    | EA   | \$0      |        |
| Corridor               |                               | Walls - Plaster/Drywall              | Entire Building     | 7    | 21,586   | SF   | \$0      |        |
| Corridor               |                               | Walls - Structural Glazed Tile       | Entire Building     | 7    | 32,379   | SF   | \$0      |        |
| Doors                  |                               | Interior Steel Doors incl hw         | throughout          | 7    | 6        | EA   | \$0      |        |
| Doors                  |                               | Interior Wood Doors incl hw          | throughout          | 6    | 5        | EA   | \$1,416  |        |
| Doors                  |                               | Interior Wood Doors incl hw          | throughout          | 7    | 36       | EA   | \$0      |        |
| Doors                  |                               | Side-lite                            | throughout          | 7    | 12       | SF   | \$0      |        |
| Doors                  |                               | Transom Window                       | throughout          | 7    | 48       | SF   | \$0      |        |
| Drinking Fountains     |                               | Single Fountain                      | Entire Building     | 7    | 6        | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Ceiling - Exposed                    | Room 012            | 6    | 4,317    | SF   | \$32,842 |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Flooring - Wood                      | Room 012            | 7    | 4,317    | SF   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Lighting - Metal Halide/Sodium Vapor | Room 012            | 7    | 10       | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Lighting - Pendant/Surface           | Room 012            | 7    | 4        | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Scoreboards                          | Room 012            | 7    | 1        | EA   | \$0      |        |



**Building: Main**  
**Category: INTERIOR**

| Group                    | Sub Group                       | Item                           | Location                    | Rank | Quantity | Unit | Cost    | Reason |
|--------------------------|---------------------------------|--------------------------------|-----------------------------|------|----------|------|---------|--------|
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium    | Sound System                   | Room 012                    | 7    | 1        | EA   | \$0     |        |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium    | Walls - Plaster/Drywall        | Room 012                    | 7    | 3,770    | SF   | \$0     |        |
| Gymnasium / Auditorium   | Standard Dedicated Gymnasium    | Walls - Structural Glazed Tile | Room 012                    | 7    | 3,770    | SF   | \$0     |        |
| Locker/Shower Room       | Locker/Shower Room              | Benches                        | Room 05 next to Gym         | 7    | 18       | LF   | \$0     |        |
| Locker/Shower Room       | Staff Restroom                  | Lockers                        | Next to Boiler Room         | 6    | 32       | EA   | \$1,570 |        |
| Locker/Shower Room       | Locker/Shower Room              | Lockers                        | Room 05 next to Gym         | 7    | 42       | EA   | \$0     |        |
| Locker/Shower Room       | Locker/Shower Room              | Showers                        | Room 05 next to Gym         | 6    | 6        | EA   | \$1,459 |        |
| Mechanical/Service Rooms |                                 | Air Intake Plenums             | Basement                    | 7    | 678      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Boiler Room                    | Basement                    | 7    | 3,601    | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Janitor's Closet               | Entire Building             | 6    | 3        | SF   | \$14    |        |
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms       | Basement                    | 7    | 527      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms       | Basement                    | 7    | 815      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms       | Basement                    | 6    | 173      | SF   | \$816   |        |
| Mechanical/Service Rooms |                                 | Mechanical/Service Rooms       | Basement                    | 7    | 45       | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Storage Room                   | Room 012-2                  | 7    | 173      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Storage Room                   | Room 253A                   | 7    | 280      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Storage Room                   | Room 212A                   | 7    | 355      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Storage Room                   | Room 353A                   | 7    | 280      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Storage Room                   | Room 316-1                  | 7    | 64       | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Storage Room                   | Room 312A Book Storage Room | 7    | 414      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Storage Room                   | Behind the Stage            | 7    | 377      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                 | Storage Room                   | Behind the Stage            | 6    | 232      | SF   | \$1,095 |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 2nd Floor East Boy's Room   | 7    | 337      | SF   | \$0     |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 2nd Floor East Girl's Room  | 7    | 471      | SF   | \$0     |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 2nd Floor West Girl's Room  | 7    | 471      | SF   | \$0     |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 1st Floor West Boy's Room   | 7    | 337      | SF   | \$0     |        |
| Staff Restroom           | Locker/Shower Room              | Accessories                    | Room 05 next to Gym         | 7    | 739      | SF   | \$0     |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 1st Floor East Boy's Room   | 7    | 337      | SF   | \$0     |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 3rd Floor West Girl's Room  | 7    | 471      | SF   | \$0     |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories                    | 3rd Floor West Boy's Room   | 7    | 337      | SF   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                      | Location                   | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|---------------------------|----------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Accessories               | 1st Floor East Girl's Room | 7    | 471      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Accessories               | 2nd Floor West Boy's Room  | 7    | 337      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Accessories               | Next to Boiler Room        | 6    | 498      | SF   | \$3,846 |        |
| Staff Restroom | Staff Restroom                  | Accessories               | In Engineer's Office       | 7    | 29       | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Accessories               | 1st Floor West Girl's Room | 7    | 471      | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Ceiling - Exposed         | Room 05 next to Gym        | 6    | 739      | SF   | \$1,395 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Lay-In          | In Engineer's Office       | 6    | 29       | SF   | \$62    |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor East Girl's Room | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor East Boy's Room  | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor West Girl's Room | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Plaster/Drywall | Next to Boiler Room        | 6    | 498      | SF   | \$1,410 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor East Girl's Room | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor West Girl's Room | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor East Boy's Room  | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor West Boy's Room  | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor West Boy's Room  | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor West Girl's Room | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor West Boy's Room  | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Locker/Shower Room              | Floor Drain               | Room 05 next to Gym        | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 1st Floor West Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 2nd Floor West Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 1st Floor West Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 1st Floor East Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 3rd Floor West Boy's Room  | 7    | 1        | EA   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                              | Location                   | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------------|----------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 2nd Floor East Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 3rd Floor West Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 2nd Floor East Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st Floor East Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 2nd Floor West Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd Floor West Boy's Room  | 7    | 337      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor East Boy's Room  | 7    | 337      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | In Engineer's Office       | 6    | 29       | SF   | \$74    |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | Next to Boiler Room        | 6    | 498      | SF   | \$1,268 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor West Girl's Room | 7    | 471      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor East Boy's Room  | 7    | 337      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor East Girl's Room | 7    | 471      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor West Boy's Room  | 7    | 337      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor West Boy's Room  | 7    | 337      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd Floor West Girl's Room | 7    | 471      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor West Girl's Room | 7    | 471      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor East Girl's Room | 7    | 471      | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Flooring - Tile/Sheet             | Room 05 next to Gym        | 6    | 739      | SF   | \$1,057 |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 2nd Floor West Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st Floor East Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st Floor West Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 3rd Floor West Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 2nd Floor East Boy's Room  | 7    | 1        | EA   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item              | Location                   | Rank | Quantity | Unit | Cost | Reason |
|----------------|---------------------------------|-------------------|----------------------------|------|----------|------|------|--------|
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer        | 2nd Floor West Boy's Room  | 7    | 1        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer        | 2nd Floor East Girl's Room | 7    | 1        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer        | 1st Floor West Boy's Room  | 7    | 1        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer        | 1st Floor East Boy's Room  | 7    | 1        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer        | 3rd Floor West Girl's Room | 7    | 1        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 2nd Floor West Boy's Room  | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 2nd Floor East Girl's Room | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 1st Floor East Girl's Room | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Locker/Shower Room              | Lavatory          | Room 05 next to Gym        | 7    | 1        | EA   | \$0  |        |
| Staff Restroom | Staff Restroom                  | Lavatory          | Next to Boiler Room        | 7    | 1        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 3rd Floor West Boy's Room  | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 1st Floor East Boy's Room  | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 2nd Floor East Boy's Room  | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Staff Restroom                  | Lavatory          | In Engineer's Office       | 7    | 1        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 1st Floor West Girl's Room | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 3rd Floor West Girl's Room | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 1st Floor West Boy's Room  | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory          | 2nd Floor West Girl's Room | 7    | 4        | EA   | \$0  |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | 3rd Floor West Boy's Room  | 6    | 4        | SF   | \$3  |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | 1st Floor East Boy's Room  | 6    | 4        | SF   | \$3  |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | 1st Floor West Boy's Room  | 6    | 4        | SF   | \$3  |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | 2nd Floor West Boy's Room  | 6    | 4        | SF   | \$3  |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Lay-In | 2nd Floor East Boy's Room  | 6    | 4        | SF   | \$3  |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                        | Location                   | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------|----------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor East Girl's Room | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | Next to Boiler Room        | 6    | 3        | SF   | \$2     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor West Girl's Room | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor East Girl's Room | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor West Girl's Room | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 3rd Floor West Girl's Room | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface | Room 05 next to Gym        | 7    | 10       | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | In Engineer's Office       | 6    | 1        | SF   | \$1     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd Floor East Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st Floor East Boy's Room  | 6    | 3        | EA   | \$538   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd Floor East Boy's Room  | 6    | 3        | EA   | \$538   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 3rd Floor West Boy's Room  | 6    | 3        | EA   | \$538   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd Floor West Boy's Room  | 6    | 3        | EA   | \$538   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st Floor West Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd Floor West Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st Floor West Boy's Room  | 6    | 3        | EA   | \$538   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 3rd Floor West Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Locker/Shower Room              | Partitions                  | Room 05 next to Gym        | 6    | 2        | EA   | \$359   |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | Next to Boiler Room        | 6    | 2        | EA   | \$359   |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st Floor East Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Staff Restroom                  | Urinals                     | Next to Boiler Room        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals                     | 2nd Floor West Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Urinals                     | Room 05 next to Gym        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals                     | 2nd Floor East Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals                     | 1st Floor West Boy's Room  | 7    | 8        | EA   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                          | Location                   | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-------------------------------|----------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Urinals                       | 3rd Floor West Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals                       | 1st Floor East Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block         | Next to Boiler Room        | 6    | 1,256    | SF   | \$3,592 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 1st Floor East Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd Floor West Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 1st Floor West Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Wall - Concrete Block         | In Engineer's Office       | 6    | 195      | SF   | \$558   |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 3rd Floor West Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Wall - Concrete Block         | Room 05 next to Gym        | 7    | 591      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd Floor East Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Wall - Structural Glazed Tile | Room 05 next to Gym        | 7    | 591      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 1st Floor East Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 2nd Floor West Girl's Room | 7    | 11       | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 1st Floor West Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 2nd Floor East Girl's Room | 7    | 11       | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 3rd Floor West Girl's Room | 7    | 11       | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 2nd Floor West Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 2nd Floor East Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Water Closet                  | Room 05 next to Gym        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | In Engineer's Office       | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | Next to Boiler Room        | 6    | 2        | EA   | \$744   |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 3rd Floor West Boy's Room  | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 1st Floor East Girl's Room | 7    | 11       | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 1st Floor West Girl's Room | 7    | 11       | EA   | \$0     |        |
| Swimming Pool  |                                 | Pool deck drains              | 1st Floor                  | 7    | 10       | EA   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group                     | Sub Group              | Item                        | Location  | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|------------------------|-----------------------------|-----------|------|----------|------|------------------|--------|
| Swimming Pool             |                        | Structural Glazed Tile      | 1st Floor | 7    | 6,571    | SF   | \$0              |        |
| Theater                   | Auditorium - Dedicated | Ceiling - Plaster/Drywall   | 1st Floor | 7    | 12,719   | SF   | \$0              |        |
| Theater                   | Auditorium - Dedicated | Flooring - Tile/Sheet       | 1st Floor | 7    | 12,719   | SF   | \$0              |        |
| Theater                   | Auditorium - Dedicated | Lighting - Pendant/ Surface | 1st Floor | 7    | 30       | SF   | \$0              |        |
| Theater                   |                        | Stage Platform              | 1st Floor | 7    | 1,927    | SF   | \$0              |        |
| Theater                   | Auditorium - Dedicated | Wall - Plaster/Drywall      | 1st Floor | 6    | 22,528   | SF   | \$193,290        |        |
| Vocational Shop           | Classroom              | Work Sink                   |           | 7    | 2        | EA   | \$0              |        |
| <b>INTERIOR Sub Total</b> |                        |                             |           |      |          |      | <b>\$342,444</b> |        |

**Building: Main**  
**Category: ROOM**

| Group        | Sub Group | Item                 | Location | Rank | Quantity | Unit | Cost    | Reason |
|--------------|-----------|----------------------|----------|------|----------|------|---------|--------|
| Casework     | Classroom | Casework             |          | 6    | 8        | LF   | \$286   |        |
| Casework     | Classroom | Casework             |          | 6    | 8        | LF   | \$286   |        |
| Casework     | Classroom | Casework             |          | 6    | 8        | LF   | \$286   |        |
| Ceiling      | Classroom | Lay-In/Drop          |          | 6    | 950      | SF   | \$2,038 |        |
| Ceiling      | Classroom | Lay-In/Drop          |          | 6    | 950      | SF   | \$2,038 |        |
| Ceiling      | Classroom | Lay-In/Drop          |          | 7    | 848      | SF   | \$0     |        |
| Ceiling      | Classroom | Lay-In/Drop          |          | 6    | 1,152    | SF   | \$2,471 |        |
| Ceiling      | Classroom | Lay-In/Drop          |          | 6    | 950      | SF   | \$2,038 |        |
| Ceiling      | Classroom | Plaster/Drywall      |          | 7    | 760      | SF   | \$0     |        |
| Chalk Board  | Classroom | Chalk Board          |          | 4    | 16       | LF   | \$1,945 |        |
| CLASSROOM    | Classroom | Eye Wash Station     |          | 7    | 1        | EA   | \$0     |        |
| CLASSROOM    | Classroom | Science Lab Elements |          | 7    | 848      | SF   | \$0     |        |
| Floor        | Classroom | Tile/Sheet           |          | 7    | 848      | SF   | \$0     |        |
| Floor        | Classroom | Tile/Sheet           |          | 7    | 950      | SF   | \$0     |        |
| Floor        | Classroom | Tile/Sheet           |          | 7    | 950      | SF   | \$0     |        |
| Floor        | Classroom | Tile/Sheet           |          | 7    | 1,152    | SF   | \$0     |        |
| Floor        | Classroom | Tile/Sheet           |          | 7    | 760      | SF   | \$0     |        |
| Floor        | Classroom | Wood                 |          | 7    | 950      | SF   | \$0     |        |
| Lighting     | Classroom | Lay-In               |          | 7    | 9        | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In               |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In               |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In               |          | 7    | 15       | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In               |          | 7    | 12       | EA   | \$0     |        |
| Lighting     | Classroom | Lay-In               |          | 7    | 18       | EA   | \$0     |        |
| Marker Board | Classroom | Marker Board         |          | 7    | 20       | LF   | \$0     |        |

**Building: Main**  
**Category: ROOM**

| Group                 | Sub Group                       | Item                    | Location                   | Rank | Quantity | Unit | Cost            | Reason |
|-----------------------|---------------------------------|-------------------------|----------------------------|------|----------|------|-----------------|--------|
| Marker Board          | Classroom                       | Marker Board            |                            | 7    | 16       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board            |                            | 7    | 20       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board            |                            | 7    | 28       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board            |                            | 7    | 12       | LF   | \$0             |        |
| Marker Board          | Classroom                       | Marker Board            |                            | 7    | 18       | LF   | \$0             |        |
| RESTROOM_WALL         | Adult Standard Student Restroom | Restroom Walls Restroom | 3rd Floor West Girl's Room | 7    | 964      | SF   | \$0             |        |
| RESTROOM_WALL         | Adult Standard Student Restroom | Restroom Walls Restroom | 2nd Floor West Girl's Room | 7    | 964      | SF   | \$0             |        |
| RESTROOM_WALL         | Adult Standard Student Restroom | Restroom Walls Restroom | 2nd Floor East Girl's Room | 7    | 964      | SF   | \$0             |        |
| RESTROOM_WALL         | Adult Standard Student Restroom | Restroom Walls Restroom | 1st Floor East Girl's Room | 7    | 964      | SF   | \$0             |        |
| RESTROOM_WALL         | Adult Standard Student Restroom | Restroom Walls Restroom | 1st Floor West Girl's Room | 7    | 964      | SF   | \$0             |        |
| Wall                  | Classroom                       | Plaster/Drywall         |                            | 7    | 1,225    | SF   | \$0             |        |
| Wall                  | Classroom                       | Plaster/Drywall         |                            | 6    | 1,184    | SF   | \$2,794         |        |
| Wall                  | Classroom                       | Plaster/Drywall         |                            | 6    | 1,184    | SF   | \$2,794         |        |
| Wall                  | Classroom                       | Plaster/Drywall         |                            | 6    | 1,084    | SF   | \$2,558         |        |
| Wall                  | Classroom                       | Plaster/Drywall         |                            | 6    | 1,184    | SF   | \$2,794         |        |
| Wall                  | Classroom                       | Plaster/Drywall         |                            | 6    | 1,126    | SF   | \$2,657         |        |
| <b>ROOM Sub Total</b> |                                 |                         |                            |      |          |      | <b>\$24,983</b> |        |

**Building Main Sub Total \$6,665,012**

**Building: Addition**  
**Category: EXTERIOR**

| Group   | Sub Group | Item                                   | Location          | Rank | Quantity | Unit | Cost | Reason |
|---------|-----------|--|-------------------|------|----------|------|------|--------|
| Canopy  |           | Fabric Canopy                          | NE elevations     | 7    | 42       | SF   | \$0  |        |
| Chimney |           | Metal Flue                             | Kitchen roof      | 7    | 10       | LF   | \$0  |        |
| Chimney |           | Metal Flue                             | East Façade       | 7    | 30       | LF   | \$0  |        |
| Cornice |           | Cornice - Masonry Projecting/Limestone | Entire Building   | 7    | 923      | LF   | \$0  |        |
| Cornice |           | Cornice - Metal Projecting             | Entire Building   | 7    | 571      | LF   | \$0  |        |
| Doors   |           | Exterior FRP Door                      | throughout        | 7    | 4        | EA   | \$0  |        |
| Doors   |           | Exterior Steel Door                    | throughout        | 7    | 26       | EA   | \$0  |        |
| Doors   |           | Exterior Steel Door                    | Central Courtyard | 7    | 5        | EA   | \$0  |        |
| Doors   |           | Overhead Rolling / Garage Door         | throughout        | 7    | 1        | EA   | \$0  |        |
| Doors   |           | Side Lite                              | throughout        | 7    | 16       | EA   | \$0  |        |



**Building: Addition**  
**Category: EXTERIOR**

| Group          | Sub Group | Item                                      | Location                               | Rank | Quantity | Unit | Cost      | Reason                   |
|----------------|-----------|---|--|------|----------|------|-----------|--------------------------|
| Doors          |           | Transom Lite                              | throughout                             | 7    | 20       | EA   | \$0       |                          |
| Doors          |           | Transom Lite                              | Central Courtyard                      | 7    | 5        | EA   | \$0       |                          |
| Entrance       |           | Concrete Exterior Stairs                  | throughout                             | 6    | 42       | LF   | \$4,505   |                          |
| Entrance       |           | Concrete Exterior Stairs                  | throughout                             | 7    | 56       | LF   | \$0       |                          |
| Entrance       |           | Concrete Ramp                             | throughout                             | 7    | 60       | LF   | \$0       |                          |
| Entrance       |           | Entrance Controls - Audio and Video       | throughout                             | 7    | 4        | EA   | \$0       |                          |
| Entrance       |           | Power Door Operator and Controls          | throughout                             | 7    | 1        | EA   | \$0       |                          |
| Entrance       |           | Ramp Handrails                            | throughout                             | 6    | 200      | LF   | \$0       |                          |
| Entrance       |           | Stair Handrails                           | throughout                             | 6    | 28       | LF   | \$0       |                          |
| Entrance       |           | Stone Stairs                              | throughout                             | 7    | 42       | LF   | \$0       |                          |
| Fire Escape    |           | Fire Escapes                              | SE elevation                           | 5    | 45       | LF   | \$14,334  | repair lower support bar |
| Foundation     |           | Concrete Foundation                       | Entire Building                        | 7    | 1,537    | LF   | \$0       |                          |
| Lighting       |           | Exterior Lights - Wall Mounted            | throughout                             | 6    | 24       | EA   | \$5,148   |                          |
| Lintels        |           | Lintels - Brick                           | throughout                             | 6    | 208      | LF   | \$0       |                          |
| Lintels        |           | Lintels - Steel                           | throughout                             | 7    | 203      | LF   | \$0       |                          |
| Lintels        |           | Lintels - Stone                           | throughout                             | 7    | 190      | LF   | \$0       |                          |
| Parapet        |           | Coping - Metal                            | Roofs                                  | 7    | 651      | LF   | \$0       |                          |
| Parapet        |           | Coping - Stone                            | Roofs                                  | 7    | 1,268    | LF   | \$0       |                          |
| Parapet        |           | Parapet < 16" Height                      | Roofs                                  | 7    | 275      | LF   | \$0       |                          |
| Parapet        |           | Parapet > 30" Height                      | Roofs                                  | 7    | 240      | LF   | \$0       |                          |
| Parapet        |           | Parapet 16" to 30" Height                 | Roofs                                  | 7    | 1,404    | LF   | \$0       |                          |
| Roof System    |           | Asphalt Shingle Roof                      | NE elevation, over room<br>337 storage | 3    | 20       | SF   | \$264     | water intrusion          |
| Roof System    |           | Asphalt Shingle Roof                      | SW elevation, dormer                   | 4    | 2        | SF   | \$26      | missing shingles         |
| Roof System    |           | Asphalt Shingle Roof                      | Roofs                                  | 7    | 36,540   | SF   | \$0       |                          |
| Roof System    |           | Exterior Downspouts                       | Roofs                                  | 7    | 526      | LF   | \$0       |                          |
| Roof System    |           | Interior Downspouts                       | Roofs                                  | 6    | 765      | LF   | \$0       |                          |
| Roof System    |           | Modified Bitumen Roof                     | Roofs                                  | 6    | 55,259   | SF   | \$391,151 |                          |
| Roof System    |           | Modified Bitumen Roof                     | Lower Roofs                            | 5    | 800      | SF   | \$9,438   | water ponding            |
| Roof System    |           | Roof Structure: Steel with Clay Tile Arch | Roofs                                  | 7    | 83,894   | SF   | \$0       |                          |
| Superstructure |           | Steel with Clay Tile Arch                 | Entire Building                        | 7    | 295,414  | SF   | \$0       |                          |
| Walls          |           | Brick                                     | SW elevation                           | 5    | 20       | SF   | \$453     |                          |
| Walls          |           | Brick                                     | kitchen - W elevation                  | 5    | 150      | SF   | \$3,398   |                          |
| Walls          |           | Brick                                     | courtyard, S elevation                 | 5    | 150      | SF   | \$3,398   |                          |
| Walls          |           | Brick                                     | Entire Building                        | 7    | 66,449   | SF   | \$0       |                          |
| Walls          |           | Brick                                     | Penthouse                              | 5    | 50       | SF   | \$1,133   |                          |
| Walls          |           | Brick                                     | courtyard - SW elevation               | 5    | 50       | SF   | \$1,133   |                          |
| Walls          |           | Stone - Cast                              | throughout                             | 7    | 5,352    | SF   | \$0       |                          |

**Building: Addition**  
**Category: EXTERIOR**

| Group                     | Sub Group | Item                                    | Location                     | Rank | Quantity | Unit | Cost             | Reason  |
|---------------------------|-----------|---|------------------------------|------|----------|------|------------------|---|
| Walls                     |           | Stone - Cast                            | kitchen/courtyard            | 5    | 110      | SF   | \$7,865          |   |
| Windows                   |           | Skylite - Glass Double-Pane             | Roofs                        | 7    | 386      | SF   | \$0              |   |
| Windows                   |           | Window - Guards perforated              | throughout                   | 6    | 2,890    | SF   | \$0              |   |
| Windows                   |           | Window - Guards wire guard              | Courtyard                    | 6    | 204      | SF   | \$0              |   |
| Windows                   |           | Window - Guards wire guard              | interior gymnasia            | 7    | 1,836    | SF   | \$0              |   |
| Windows                   |           | Windows - Casement Aluminum             | Courtyard                    | 5    | 510      | SF   | \$11,311         | broken latches and many screwed shut              |
| Windows                   |           | Windows - Casement Aluminum             | SW exterior elevation        | 5    | 102      | SF   | \$2,262          | broken latches                                    |
| Windows                   |           | Windows - Casement Aluminum Double-pane | exterior elevation perimeter | 5    | 612      | SF   | \$14,090         | broken latches and many screwed shut              |
| Windows                   |           | Windows - Decorative                    | basement, courtyard, wells   | 4    | 408      | SF   | \$123,223        | water infiltration due to clogged drains in wells |
| Windows                   |           | Windows - Sash Aluminum                 | Courtyard                    | 7    | 8,704    | SF   | \$0              |   |
| Windows                   |           | Windows - Sash Aluminum                 | SW exterior elevation        | 7    | 816      | SF   | \$0              |   |
| Windows                   |           | Windows - Sash Aluminum Double-pane     | exterior perimeter           | 7    | 10,472   | SF   | \$0              |   |
| <b>EXTERIOR Sub Total</b> |           |   |                              |      |          |      | <b>\$593,131</b> |   |

**Building: Addition**  
**Category: ELECTRICAL**

| Group              | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost      | Reason   |
|--------------------|-----------|--|-----------------|------|----------|------|-----------|--|
| Emergency System   |           | Automatic Transfer switch                          | Basement        | 7    | 2        | EA   | \$0       |  |
| Emergency System   |           | Emergency A/C power - Corridors and Stairs         | Entire Building | 7    | 17,929   | SF   | \$0       |  |
| Emergency System   |           | Emergency A/C power - Gym and Lunch rooms          | 1st Floor       | 7    | 27,703   | SF   | \$0       |  |
| Emergency System   |           | Exit Signs - Corridors and Stairs                  | Entire Building | 4    | 24       | EA   | \$22,308  |  |
| Emergency System   |           | Exit Signs - Lunchroom - Gym - multipurpose rooms  | 1st Floor       | 4    | 16       | EA   | \$14,872  |  |
| Emergency System   |           | Independent Electrical Service for emergency power | Basement        | 7    | 1        | EA   | \$0       |  |
| Main Service       |           | Main Electrical service 1600 A 277/480/3PH         | Basement        | 4    | 1        | EA   | \$163,020 |  |
| Power Distribution |           | Lighting and power panels                          | Entire Building | 6    | 10       | EA   | \$7,150   |  |
| Power Distribution |           | Main distribution panels 400-600 amp               | Basement        | 7    | 2        | EA   | \$0       |  |
| Power Distribution |           | Main distribution panels 400-600 amp               | Basement        | 4    | 3        | EA   | \$36,465  | Distribution panel is greater than 40 years of age |
| Power Distribution |           | Main distribution panels above 600 amp             | Basement        | 7    | 3        | EA   | \$0       |  |
| Power Distribution |           | Main distribution panels above 600 amp             | Basement        | 4    | 1        | EA   | \$18,590  | Distribution panel is greater than 40 years of age |
| Power Distribution |           | Main distribution panels less than 400 amp         | Basement        | 4    | 2        | EA   | \$13,156  | Distribution panel is greater than 40 years of age |

**Building: Addition**  
**Category: ELECTRICAL**

| Group                       | Sub Group | Item                         | Location | Rank | Quantity | Unit | Cost             | Reason |
|-----------------------------|-----------|------------------------------|----------|------|----------|------|------------------|--------|
| Power Distribution          |           | Transformers 277/480-120/208 | Basement | 6    | 5        | EA   | \$5,720          |        |
| <b>ELECTRICAL Sub Total</b> |           |                              |          |      |          |      | <b>\$281,281</b> |        |

**Building: Addition**  
**Category: FIRE PROTECTION**

| Group                            | Sub Group | Item                     | Location        | Rank | Quantity | Unit | Cost             | Reason   |
|----------------------------------|-----------|--------------------------|-----------------|------|----------|------|------------------|--|
| Fire Alarm                       |           | Fire Alarm Strobe Lights | Entire Building | 3    | 295,414  | SF   | \$625,214        | Strobe lights are not provided or not located in all areas |
| <b>FIRE PROTECTION Sub Total</b> |           |                          |                 |      |          |      | <b>\$625,214</b> |  |

**Building: Addition**  
**Category: MECHANICAL**

| Group                | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost      | Reason  |
|----------------------|-----------|--|-----------------|------|----------|------|-----------|---|
| Air Conditioning     |           | Window A/C Unit  | Entire Building | 4    | 38       | EA   | \$81,510  |   |
| Air Conditioning     |           | Window A/C Unit  | Entire Building | 3    | 8        | EA   | \$17,160  | Unit is not working   |
| Air Handling Systems |           | Air Intake - Built Up Air Handling Unit  | Basement        | 5    | 5        | EA   | \$80,080  |   |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm             | Basement        | 4    | 3        | EA   | \$278,850 |   |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit - Steam 8,000 to 15,000 cfm              | Basement        | 4    | 1        | EA   | \$57,200  |   |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit - Steam above 35,000 cfm                 | Basement        | 4    | 2        | EA   | \$328,900 |   |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm | Basement        | 4    | 3        | EA   | \$98,670  |   |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 8,000 to 15,000 cfm  | Basement        | 4    | 1        | EA   | \$21,450  |   |
| Air Handling Systems |           | Multi Zone Built Up Air Handling Unit Auxiliaries - Steam above 35,000 cfm     | Basement        | 4    | 2        | EA   | \$88,660  |   |
| Air Handling Systems |           | Reheat Boxes With Steam Coils  | Basement        | 4    | 27       | EA   | \$281,853 |   |
| Air Handling Systems |           | Roof Top Unit - Multi Zone - Gas-Heating 10 to 20 tons                         | Roof            | 3    | 1        | EA   | \$50,050  | Unit is more than 30 years and the unit is operating however the proper temperatures during the summer cannot be maintained |
| Heating Devices      |           | Radiators - Steam  | Entire Building | 4    | 105      | EA   | \$147,147 |   |
| Mechanical Plumbing  |           | Condensate Assembly - Pumps and Tank   | Basement        | 4    | 6        | EA   | \$171,600 |   |
| Mechanical Plumbing  |           | Piping - Condensate - Steel or Galvanized                                      | Entire Building | 4    | 1,500    | LF   | \$146,933 |   |
| Mechanical Plumbing  |           | Piping - Steam - Steel or Galvanized   | Entire Building | 4    | 1,500    | LF   | \$179,644 |   |

**Building: Addition**  
**Category: MECHANICAL**

| Group                       | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost               | Reason |
|-----------------------------|-----------|--|-----------------|------|----------|------|--------------------|--------|
| Temperature Control         |           | Thermostats - Pneumatic  | Entire Building | 4    | 91       | EA   | \$59,860           |        |
| Temperature Control         |           | Zone Dampers   | Basement        | 4    | 91       | EA   | \$76,777           |        |
| Unit Ventilation            |           | Unit Ventilators - Self Contained Electric Heating and Cooling | 1st Floor       | 7    | 4        | EA   | \$0                |        |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm                 | Roof            | 5    | 8        | EA   | \$12,012           |        |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm                   | Roof            | 5    | 8        | EA   | \$10,296           |        |
| Ventilation                 |           | Lab Exhaust Hood   | 3rd Floor       | 4    | 2        | EA   | \$65,780           |        |
| Ventilation                 |           | Type I Exhaust Hood - Kitchen or Culinary Arts                 | 1st Floor       | 7    | 1        | EA   | \$0                |        |
| <b>MECHANICAL Sub Total</b> |           |  |                 |      |          |      | <b>\$2,254,431</b> |        |

**Building: Addition**  
**Category: PLUMBING**

| Group  | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost      | Reason   |
|--------|-----------|--|-----------------|------|----------|------|-----------|--|
| Piping |           | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 3    | 295,414  | SF   | \$97,162  | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping |           | Domestic Piping - Cold Water Risers                  | Entire Building | 3    | 295,414  | SF   | \$190,099 | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping |           | Domestic Piping - Hot Water from Riser to fixtures   | Entire Building | 3    | 295,414  | SF   | \$63,366  | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping |           | Domestic Piping - Hot Water Return Risers            | Entire Building | 3    | 295,414  | SF   | \$135,181 | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping |           | Domestic Piping - Hot Water Risers                   | Entire Building | 3    | 295,414  | SF   | \$160,528 | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping |           | Domestic Piping Cold Water Horizontal lines          | Entire Building | 3    | 295,414  | SF   | \$705,478 | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping |           | Domestic Piping Hot Water Horizontal lines           | Entire Building | 3    | 295,414  | SF   | \$582,970 | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |

**Building: Addition**  
**Category: PLUMBING**

| Group                     | Sub Group | Item                                   | Location        | Rank | Quantity | Unit | Cost               | Reason   |
|---------------------------|-----------|--|-----------------|------|----------|------|--------------------|--|
| Piping                    |           | Domestic Piping Hot Water Return Lines | Entire Building | 3    | 295,414  | SF   | \$337,954          | Pipes are galvanized, more than 40 years of age and there are many pipe clamps installed |
| Piping                    |           | Sanitary Piping                        | Entire Building | 5    | 295,414  | SF   | \$181,650          |  |
| Piping                    |           | Storm Piping                           | Entire Building | 5    | 295,414  | SF   | \$139,406          |  |
| Piping                    |           | Vent Piping                            | Entire Building | 5    | 295,414  | SF   | \$105,611          |  |
| Pool Systems              |           | Pool Drain Piping                      | Basement        | 4    | 500      | LF   | \$85,800           |  |
| Pool Systems              |           | Pool Filtration System                 | Basement        | 5    | 1        | EA   | \$122,980          | Hot water is more than 15 years of age and the heaters is not working                    |
| Pool Systems              |           | Pool Hot Water Heater - Gas Fired      | Basement        | 3    | 1        | EA   | \$37,180           |  |
| Pool Systems              |           | Pool Supply and Return Piping          | Basement        | 5    | 1,000    | LF   | \$78,650           |  |
| Pumps                     |           | Sump Pump                              | Basement        | 6    | 3        | EA   | \$4,076            |  |
| Pumps                     |           | Sump Pump                              | Basement        | 6    | 1        | EA   | \$1,359            |  |
| <b>PLUMBING Sub Total</b> |           |  |                 |      |          |      | <b>\$3,029,449</b> |  |

**Building: Addition**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item             | Location                      | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|------------------|-------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 141 Police Room          | 7    | 379      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 221                      | 6    | 716      | SF   | \$1,536 |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 137 Security Office      | 7    | 379      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 125 Main Office          | 7    | 798      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 125-2 Principal's Office | 7    | 235      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 235-4                    | 6    | 88       | SF   | \$189   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 127 Attendance Office    | 7    | 750      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 122                      | 7    | 235      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 235-2                    | 7    | 202      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Room 233-3                    | 7    | 391      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Records Room in Main Office   | 7    | 185      | SF   | \$0     |        |

**Building: Addition**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                      | Location                      | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|---------------------------|-------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In          | Room 141A                     | 7    | 498      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In          | Kitchen Manager's Office      | 6    | 105      | SF   | \$225   |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Office in Gym Room 235        | 7    | 156      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Room 344.2 Prep Room          | 7    | 153      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | Room 348.2 Prep Room          | 7    | 153      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | Room 134                      | 7    | 726      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Splined         | Room 233-5                    | 6    | 162      | SF   | \$347   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet         | Room 122                      | 7    | 235      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet         | Room 137 Security Office      | 6    | 379      | SF   | \$542   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet         | Room 125 Main Office          | 7    | 798      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet         | Room 125-2 Principal's Office | 7    | 235      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet         | Records Room in Main Office   | 7    | 185      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Terrazzo       | Kitchen Manager's Office      | 6    | 105      | SF   | \$595   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Office in Gym Room 235        | 6    | 156      | SF   | \$223   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Room 134                      | 6    | 726      | SF   | \$1,038 |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Room 132                      | 6    | 726      | SF   | \$1,038 |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Room 344.2 Prep Room          | 7    | 153      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Room 348.2 Prep Room          | 7    | 153      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Room 127 Attendance Office    | 7    | 750      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Room 233-3                    | 6    | 391      | SF   | \$559   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Room 233-5                    | 6    | 162      | SF   | \$232   |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet     | Room 235-2                    | 6    | 202      | SF   | \$289   |        |

**Building: Addition**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                       | Location                      | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|----------------------------|-------------------------------|------|----------|------|------|--------|
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet      | Room 235-4                    | 7    | 88       | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood            | Room 141A                     | 7    | 498      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood            | Room 141 Police Room          | 7    | 379      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Wood            | Room 221                      | 7    | 716      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 348.2 Prep Room          | 7    | 2        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Records Room in Main Office   | 7    | 4        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 125 Main Office          | 7    | 21       | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 141A                     | 7    | 9        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 141 Police Room          | 7    | 3        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 137 Security Office      | 7    | 6        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 127 Attendance Office    | 7    | 12       | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Kitchen Manager's Office      | 7    | 2        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 344.2 Prep Room          | 7    | 2        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 233-3                    | 7    | 4        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 125-2 Principal's Office | 7    | 6        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 233-5                    | 7    | 3        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 235-2                    | 7    | 2        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 235-4                    | 7    | 1        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 221                      | 7    | 12       | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Room 122                      | 7    | 6        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Room 132                      | 7    | 12       | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | Office in Gym Room 235        | 7    | 2        | SF   | \$0  |        |

**Building: Addition**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                        | Location                      | Rank | Quantity | Unit | Cost     | Reason |
|-----------------------|-------------------------------|-----------------------------|-------------------------------|------|----------|------|----------|--------|
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface  | Room 134                      | 7    | 12       | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 125 Main Office          | 6    | 720      | SF   | \$1,699  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 141A                     | 6    | 840      | SF   | \$1,982  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 134                      | 6    | 1,414    | SF   | \$3,336  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 132                      | 7    | 1,389    | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 344.2 Prep Room          | 7    | 525      | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 348.2 Prep Room          | 7    | 525      | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 122                      | 7    | 750      | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 125-2 Principal's Office | 7    | 750      | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 141 Police Room          | 6    | 720      | SF   | \$1,699  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 127 Attendance Office    | 6    | 1,060    | SF   | \$2,501  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 137 Security Office      | 6    | 720      | SF   | \$1,699  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 233-3                    | 6    | 873      | SF   | \$2,060  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 233-5                    | 7    | 545      | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 235-2                    | 7    | 572      | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Office in Gym Room 235        | 6    | 624      | SF   | \$1,472  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Room 221                      | 6    | 980      | SF   | \$2,312  |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Kitchen Manager's Office      | 7    | 435      | SF   | \$0      |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall     | Records Room in Main Office   | 6    | 500      | SF   | \$1,180  |        |
| Band Room             | Classroom                     | Instrument Storage Casework |                               | 7    | 30       | LF   | \$0      |        |
| Choral Room           | Classroom                     | Risers                      |                               | 7    | 475      | LF   | \$0      |        |
| Choral Room           | Classroom                     | Risers                      |                               | 7    | 125      | LF   | \$0      |        |
| Corridor              |                               | Ceiling - Lay-In            | Entire Building               | 6    | 16,680   | SF   | \$35,779 |        |
| Corridor              |                               | Flooring Terrazzo           | Entire Building               | 7    | 1,249    | SF   | \$0      |        |



**Building: Addition**  
**Category: INTERIOR**

| Group                  | Sub Group                    | Item                                 | Location        | Rank | Quantity | Unit | Cost     | Reason |
|------------------------|------------------------------|--------------------------------------|-----------------|------|----------|------|----------|--------|
| Corridor               |                              | Flooring Tile/ Sheet                 | Entire Building | 7    | 16,680   | SF   | \$0      |        |
| Corridor               |                              | Lighting - Lay-In                    | Entire Building | 7    | 511      | SF   | \$0      |        |
| Corridor               |                              | Stair Handrails                      | Entire Building | 7    | 518      | LF   | \$0      |        |
| Corridor               |                              | Stairs - Terrazzo                    | Entire Building | 7    | 251      | LF   | \$0      |        |
| Corridor               |                              | Student Lockers                      | Entire Building | 7    | 809      | EA   | \$0      |        |
| Corridor               |                              | Walls - Plaster/Drywall              | Entire Building | 7    | 14,390   | SF   | \$0      |        |
| Corridor               |                              | Walls - Structural Glazed Tile       | Entire Building | 7    | 21,586   | SF   | \$0      |        |
| Doors                  |                              | Interior Steel Doors incl hw         | throughout      | 7    | 40       | EA   | \$0      |        |
| Doors                  |                              | Interior Wood Doors incl hw          | throughout      | 7    | 159      | EA   | \$0      |        |
| Doors                  |                              | Interior Wood Doors incl hw          | throughout      | 5    | 10       | EA   | \$4,719  |        |
| Doors                  |                              | Interior Wood Doors incl hw          | throughout      | 6    | 15       | EA   | \$4,247  |        |
| Doors                  |                              | Side-lite                            | throughout      | 7    | 12       | SF   | \$0      |        |
| Doors                  |                              | Transom Window                       | throughout      | 7    | 465      | SF   | \$0      |        |
| Drinking Fountains     |                              | Single Fountain                      | Entire Building | 7    | 18       | EA   | \$0      |        |
| GreenHouse             |                              | Finishes                             | Room 246.3      | 7    | 540      | SF   | \$0      |        |
| GreenHouse             |                              | Glazing                              | Room 246.3      | 7    | 800      | SF   | \$0      |        |
| GreenHouse             |                              | Mechanical                           | Room 246.3      | 7    | 540      | SF   | \$0      |        |
| GreenHouse             |                              | Plumbing                             | Room 246.3      | 7    | 540      | SF   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium        | Bleacher Seating                     | Room 235 Boys   | 7    | 530      | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating                     | Room 231 Girls  | 7    | 100      | EA   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium        | Ceiling - Plaster/Drywall            | Room 235 Boys   | 7    | 8,146    | SF   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Splined                    | Room 231 Girls  | 6    | 4,288    | SF   | \$39,857 |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Splined                    | Room 233 Girls  | 6    | 4,288    | SF   | \$39,857 |        |
| Gymnasium / Auditorium | Competition Gymnasium        | Flooring - Wood                      | Room 235 Boys   | 7    | 8,146    | SF   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Wood                      | Room 231 Girls  | 7    | 4,288    | SF   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Wood                      | Room 233 Girls  | 7    | 4,288    | SF   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium        | Lighting - Metal Halide/Sodium Vapor | Room 235 Boys   | 7    | 27       | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Metal Halide/Sodium Vapor | Room 231 Girls  | 7    | 12       | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Metal Halide/Sodium Vapor | Room 233 Girls  | 7    | 12       | EA   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium        | Scoreboards                          | Room 235 Boys   | 7    | 1        | EA   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium        | Sound System                         | Room 235 Boys   | 7    | 1        | EA   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium        | Walls - Plaster/Drywall              | Room 235 Boys   | 7    | 2,467    | SF   | \$0      |        |

**Building: Addition**  
**Category: INTERIOR**

| Group                  | Sub Group                    | Item                           | Location                       | Rank | Quantity | Unit | Cost     | Reason |
|------------------------|------------------------------|--------------------------------|--------------------------------|------|----------|------|----------|--------|
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Plaster/Drywall        | Room 231 Girls                 | 7    | 1,770    | SF   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Plaster/Drywall        | Room 233 Girls                 | 7    | 1,770    | SF   | \$0      |        |
| Gymnasium / Auditorium | Competition Gymnasium        | Walls - Structural Glazed Tile | Room 235 Boys                  | 7    | 7,407    | SF   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Structural Glazed Tile | Room 231 Girls                 | 7    | 5,309    | SF   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Structural Glazed Tile | Room 233 Girls                 | 7    | 5,309    | SF   | \$0      |        |
| Kitchen                |                              | Ceiling - Lay-In               | Room 140 Servery               | 6    | 3,150    | SF   | \$9,009  |        |
| Kitchen                | Cooking Kitchen              | Ceiling - Plaster/Drywall      | 1st Floor                      | 7    | 1,205    | SF   | \$0      |        |
| Kitchen                |                              | Flooring - Terrazzo            | Room 140 Servery               | 6    | 3,150    | SF   | \$17,838 |        |
| Kitchen                | Cooking Kitchen              | Flooring - Terrazzo            | 1st Floor                      | 7    | 1,205    | SF   | \$0      |        |
| Kitchen                |                              | Lighting - Lay-In              | Room 140 Servery               | 7    | 160      | SF   | \$0      |        |
| Kitchen                | Cooking Kitchen              | Lighting - Pendant/Surface     | 1st Floor                      | 7    | 12       | SF   | \$0      |        |
| Kitchen                |                              | Wall - Plaster/Drywall         | Room 140 Servery               | 6    | 2,745    | SF   | \$6,477  |        |
| Kitchen                | Cooking Kitchen              | Wall - Structural Glazed Tile  | 1st Floor                      | 7    | 2,064    | SF   | \$0      |        |
| Kitchen                |                              | Wall - Structural Glazed Tile  | Room 140 Servery               | 7    | 2,745    | SF   | \$0      |        |
| Library                | Library                      | Flooring Carpet                | Room 229                       | 7    | 3,684    | SF   | \$0      |        |
| Library                | Library                      | Lighting - Lay-In              | Room 229                       | 7    | 48       | SF   | \$0      |        |
| Locker/Shower Room     | Locker/Shower Room           | Benches                        | Girls Locker Room              | 7    | 30       | LF   | \$0      |        |
| Locker/Shower Room     | Locker/Shower Room           | Benches                        | Boy's Locker Room 235          | 7    | 30       | LF   | \$0      |        |
| Locker/Shower Room     | Locker/Shower Room           | Lockers                        | Girls Locker Room              | 6    | 154      | EA   | \$7,558  |        |
| Locker/Shower Room     | Staff Restroom               | Lockers                        | In the Gym Office              | 7    | 4        | EA   | \$0      |        |
| Locker/Shower Room     | Locker/Shower Room           | Lockers                        | Boy's Locker Room 235          | 6    | 154      | EA   | \$7,558  |        |
| Locker/Shower Room     | Staff Restroom               | Lockers                        | In Kitchen Area                | 6    | 11       | EA   | \$540    |        |
| Locker/Shower Room     | Staff Restroom               | Lockers                        | In Room 233-3                  | 7    | 2        | EA   | \$0      |        |
| Locker/Shower Room     | Locker/Shower Room           | Showers                        | Boy's Locker Room 235          | 6    | 12       | EA   | \$2,917  |        |
| Locker/Shower Room     | Staff Restroom               | Showers                        | In the Gym Office              | 6    | 1        | EA   | \$243    |        |
| Locker/Shower Room     | Staff Restroom               | Showers                        | In Room 233-3                  | 6    | 1        | EA   | \$243    |        |
| Locker/Shower Room     | Locker/Shower Room           | Showers                        | Girls Locker Room              | 6    | 12       | EA   | \$2,917  |        |
| Lunchroom              | Lunchroom                    | Ceiling - Lay-In               | Room 142, Teacher's Lunch Room | 6    | 1,160    | SF   | \$2,488  |        |
| Lunchroom              | Lunchroom                    | Ceiling - Lay-In               | Room 138                       | 6    | 4,570    | SF   | \$9,803  |        |
| Lunchroom              | Lunchroom                    | Ceiling - Lay-In               | Room 141                       | 6    | 3,251    | SF   | \$6,973  |        |
| Lunchroom              | Lunchroom                    | Flooring - Tile/Sheet          | Room 141                       | 6    | 3,251    | SF   | \$4,649  |        |
| Lunchroom              | Lunchroom                    | Flooring - Tile/Sheet          | Room 138                       | 6    | 4,570    | SF   | \$6,535  |        |
| Lunchroom              | Lunchroom                    | Flooring - Tile/Sheet          | Room 142, Teacher's Lunch Room | 6    | 1,160    | SF   | \$1,659  |        |

**Building: Addition**  
**Category: INTERIOR**

| Group                    | Sub Group | Item                          | Location                       | Rank | Quantity | Unit | Cost    | Reason |
|--------------------------|-----------|-------------------------------|--------------------------------|------|----------|------|---------|--------|
| Lunchroom                | Lunchroom | Lighting - Lay-In             | Room 138                       | 7    | 12       | SF   | \$0     |        |
| Lunchroom                | Lunchroom | Lighting - Lay-In             | Room 141                       | 7    | 26       | SF   | \$0     |        |
| Lunchroom                | Lunchroom | Lighting - Pendant/Surface    | Room 142, Teacher's Lunch Room | 7    | 6        | SF   | \$0     |        |
| Lunchroom                | Lunchroom | Serving Line                  | Room 138                       | 7    | 144      | LF   | \$0     |        |
| Lunchroom                | Lunchroom | Serving Line                  | Room 142, Teacher's Lunch Room | 7    | 48       | LF   | \$0     |        |
| Lunchroom                | Lunchroom | Serving Line                  | Room 141                       | 7    | 48       | LF   | \$0     |        |
| Lunchroom                | Lunchroom | Wall - Plaster/Drywall        | Room 138                       | 7    | 1,543    | SF   | \$0     |        |
| Lunchroom                | Lunchroom | Wall - Plaster/Drywall        | Room 141                       | 6    | 2,625    | SF   | \$6,194 |        |
| Lunchroom                | Lunchroom | Wall - Plaster/Drywall        | Room 142, Teacher's Lunch Room | 6    | 917      | SF   | \$2,164 |        |
| Lunchroom                | Lunchroom | Wall - Structural Glazed Tile | Room 142, Teacher's Lunch Room | 7    | 918      | SF   | \$0     |        |
| Lunchroom                | Lunchroom | Wall - Structural Glazed Tile | Room 141                       | 7    | 2,625    | SF   | \$0     |        |
| Lunchroom                | Lunchroom | Wall - Structural Glazed Tile | Room 138                       | 7    | 1,543    | SF   | \$0     |        |
| MDF/IDF                  |           | Finishes                      | Room 244.2                     | 6    | 226      | SF   | \$769   |        |
| MDF/IDF                  |           | Finishes                      | Room 226                       | 7    | 268      | SF   | \$0     |        |
| MDF/IDF                  |           | Ventilation and Cooling       | Room 226                       | 7    | 1        | EA   | \$0     |        |
| MDF/IDF                  |           | Ventilation and Cooling       | Room 244.2                     | 6    | 1        | EA   | \$1,401 | warm   |
| Mechanical/Service Rooms |           | Janitor's Closet              | In Kitchen                     | 6    | 1        | SF   | \$5     |        |
| Mechanical/Service Rooms |           | Janitor's Closet              | Entire Building                | 6    | 6        | SF   | \$28    |        |
| Mechanical/Service Rooms |           | Mechanical/Service Rooms      | 3rd Floor                      | 7    | 15       | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 246.1 (246A)              | 7    | 540      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | In Kitchen                     | 7    | 168      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | In Boy's Locker Room           | 6    | 135      | SF   | \$637   |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 233-2                     | 7    | 235      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 235-5                     | 7    | 65       | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 337 Store Rooms           | 6    | 1,065    | SF   | \$5,026 |        |
| Mechanical/Service Rooms |           | Storage Room                  | Main Office 125                | 7    | 25       | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 341A                      | 7    | 365      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 344.1 Storage             | 7    | 115      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 235-1                     | 7    | 590      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | In Kitchen                     | 7    | 168      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 346                       | 6    | 540      | SF   | \$2,548 |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 253A                      | 7    | 280      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 323.1                     | 7    | 180      | SF   | \$0     |        |
| Mechanical/Service Rooms |           | Storage Room                  | Room 244.1                     | 7    | 115      | SF   | \$0     |        |

**Building: Addition**  
**Category: INTERIOR**

| Group                    | Sub Group                       | Item                      | Location                          | Rank | Quantity | Unit | Cost     | Reason |
|--------------------------|---------------------------------|---------------------------|-----------------------------------|------|----------|------|----------|--------|
| Mechanical/Service Rooms |                                 | Storage Room              | Room 348.1 Storage                | 7    | 115      | SF   | \$0      |        |
| Mechanical/Service Rooms |                                 | Vaults                    | Main Office 125                   | 7    | 100      | SF   | \$0      |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 3rd Floor East Girl's Room        | 7    | 471      | SF   | \$0      |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 3rd Floor West Girl's Room        | 7    | 471      | SF   | \$0      |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 2nd Floor East Girl's Room        | 7    | 471      | SF   | \$0      |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 2nd Floor West Girl's Room        | 7    | 471      | SF   | \$0      |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 1st Floor West Girl's Room        | 7    | 471      | SF   | \$0      |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 1st Floor East Girl's Room        | 7    | 471      | SF   | \$0      |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 3rd Floor West Boy's Room         | 6    | 337      | SF   | \$2,602  |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 3rd Floor East Boy's Room         | 6    | 337      | SF   | \$2,602  |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 2nd Floor East Boy's Room         | 6    | 337      | SF   | \$2,602  |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 2nd Floor West Boy's Room         | 6    | 337      | SF   | \$2,602  |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 1st Floor West Boy's Room         | 6    | 337      | SF   | \$2,602  |        |
| Staff Restroom           | Staff Restroom                  | Accessories               | In Room 233-3                     | 7    | 109      | SF   | \$0      |        |
| Staff Restroom           | Staff Restroom                  | Accessories               | In the Gym Office                 | 7    | 86       | SF   | \$0      |        |
| Staff Restroom           | Locker/Shower Room              | Accessories               | Boy's Locker Room 235             | 6    | 3,366    | SF   | \$25,992 |        |
| Staff Restroom           | Staff Restroom                  | Accessories               | In Kitchen Area                   | 7    | 145      | SF   | \$0      |        |
| Staff Restroom           | Staff Restroom                  | Accessories               | 2nd Floor Men's Faculty Rest Room | 7    | 268      | SF   | \$0      |        |
| Staff Restroom           | Staff Restroom                  | Accessories               | 3rd Floor Men's Faculty Rest Room | 7    | 268      | SF   | \$0      |        |
| Staff Restroom           | Locker/Shower Room              | Accessories               | Girls Locker Room                 | 6    | 3,366    | SF   | \$25,992 |        |
| Staff Restroom           | Adult Standard Student Restroom | Accessories               | 1st Floor East Boy's Room         | 6    | 337      | SF   | \$2,602  |        |
| Staff Restroom           | Staff Restroom                  | Accessories               | 1st Floor Men's Faculty Rest Room | 7    | 268      | SF   | \$0      |        |
| Staff Restroom           | Staff Restroom                  | Ceiling - Lay-In          | In the Gym Office                 | 6    | 86       | SF   | \$184    |        |
| Staff Restroom           | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor East Girl's Room        | 6    | 471      | SF   | \$1,334  |        |
| Staff Restroom           | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor West Girl's Room        | 6    | 471      | SF   | \$1,334  |        |

**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                      | Location                          | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|---------------------------|-----------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom                  | Ceiling - Plaster/Drywall | In Kitchen Area                   | 6    | 145      | SF   | \$411   |        |
| Staff Restroom | Locker/Shower Room              | Ceiling - Plaster/Drywall | Boy's Locker Room 235             | 6    | 3,366    | SF   | \$9,530 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Plaster/Drywall | In Room 233-3                     | 7    | 109      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor East Girl's Room        | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor East Girl's Room        | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Plaster/Drywall | 2nd Floor Men's Faculty Rest Room | 6    | 268      | SF   | \$759   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor West Girl's Room        | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Plaster/Drywall | 3rd Floor Men's Faculty Rest Room | 6    | 268      | SF   | \$759   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor West Boy's Room         | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd Floor East Boy's Room         | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor East Boy's Room         | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor West Boy's Room         | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor West Boy's Room         | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 1st Floor East Boy's Room         | 6    | 337      | SF   | \$954   |        |
| Staff Restroom | Adult Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor West Girl's Room        | 6    | 471      | SF   | \$1,334 |        |
| Staff Restroom | Locker/Shower Room              | Ceiling - Plaster/Drywall | Girls Locker Room                 | 6    | 3,295    | SF   | \$9,329 |        |
| Staff Restroom | Staff Restroom                  | Ceiling - Plaster/Drywall | 1st Floor Men's Faculty Rest Room | 6    | 268      | SF   | \$759   |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 2nd Floor East Girl's Room        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 1st Floor East Boy's Room         | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 1st Floor West Boy's Room         | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 2nd Floor West Boy's Room         | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 2nd Floor East Boy's Room         | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain               | 3rd Floor East Boy's Room         | 7    | 1        | EA   | \$0     |        |

**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                              | Location                          | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------------|-----------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 3rd Floor West Boy's Room         | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st Floor East Girl's Room        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 2nd Floor West Girl's Room        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Floor Drain                       | Girls Locker Room                 | 6    | 8        | EA   | \$2,402 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 3rd Floor East Girl's Room        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 3rd Floor West Girl's Room        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Floor Drain                       | In Room 233-3                     | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Floor Drain                       | In the Gym Office                 | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Floor Drain                       | Boy's Locker Room 235             | 6    | 8        | EA   | \$2,402 |        |
| Staff Restroom | Adult Standard Student Restroom | Floor Drain                       | 1st Floor West Girl's Room        | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor West Boy's Room         | 6    | 337      | SF   | \$858   |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd Floor East Girl's Room        | 6    | 471      | SF   | \$1,199 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd Floor East Boy's Room         | 6    | 337      | SF   | \$858   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 3rd Floor Men's Faculty Rest Room | 6    | 268      | SF   | \$682   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 2nd Floor Men's Faculty Rest Room | 6    | 268      | SF   | \$682   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | 1st Floor Men's Faculty Rest Room | 6    | 268      | SF   | \$682   |        |
| Staff Restroom | Locker/Shower Room              | Flooring - Tile Ceramic/Porcelain | Boy's Locker Room 235             | 6    | 3,366    | SF   | \$8,568 |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | In the Gym Office                 | 7    | 86       | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd Floor West Girl's Room        | 6    | 471      | SF   | \$1,199 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor East Girl's Room        | 6    | 471      | SF   | \$1,199 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor West Boy's Room         | 6    | 337      | SF   | \$858   |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile Ceramic/Porcelain | In Room 233-3                     | 7    | 109      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor East Boy's Room         | 6    | 337      | SF   | \$858   |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor West Girl's Room        | 6    | 471      | SF   | \$1,199 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor East Boy's Room         | 6    | 337      | SF   | \$858   |        |

**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                              | Location                   | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------------|----------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd Floor West Boy's Room  | 6    | 337      | SF   | \$858   |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor East Girl's Room | 6    | 471      | SF   | \$1,199 |        |
| Staff Restroom | Adult Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor West Girl's Room | 6    | 471      | SF   | \$1,199 |        |
| Staff Restroom | Locker/Shower Room              | Flooring - Tile Ceramic/Porcelain | Girls Locker Room          | 6    | 3,295    | SF   | \$8,387 |        |
| Staff Restroom | Staff Restroom                  | Flooring - Tile/Sheet             | In Kitchen Area            | 7    | 145      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 3rd Floor West Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st Floor East Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st Floor East Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st Floor West Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 2nd Floor West Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 2nd Floor East Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 3rd Floor East Boy's Room  | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 1st Floor West Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 2nd Floor West Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 2nd Floor East Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 3rd Floor East Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Hand Dryer                        | 3rd Floor West Girl's Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 2nd Floor West Boy's Room  | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 1st Floor West Girl's Room | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 1st Floor East Girl's Room | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 3rd Floor West Boy's Room  | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 2nd Floor East Girl's Room | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                          | 2nd Floor East Boy's Room  | 6    | 4        | EA   | \$1,487 |        |

**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                        | Location                          | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------|-----------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom                  | Lavatory                    | In Room 233-3                     | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                    | 1st Floor West Boy's Room         | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                    | 1st Floor East Boy's Room         | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                    | 3rd Floor East Boy's Room         | 6    | 4        | EA   | \$1,487 |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                    | 3rd Floor East Girl's Room        | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                    | 2nd Floor West Girl's Room        | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | In the Gym Office                 | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Lavatory                    | Boy's Locker Room 235             | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | In Kitchen Area                   | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 1st Floor Men's Faculty Rest Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 2nd Floor Men's Faculty Rest Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lavatory                    | 3rd Floor Men's Faculty Rest Room | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Lavatory                    | Girls Locker Room                 | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lavatory                    | 3rd Floor West Girl's Room        | 7    | 4        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 1st Floor Men's Faculty Rest Room | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 2nd Floor Men's Faculty Rest Room | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Lay-In           | 3rd Floor Men's Faculty Rest Room | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 3rd Floor East Girl's Room        | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor East Boy's Room         | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor West Girl's Room        | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor West Boy's Room         | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor West Boy's Room         | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | In the Gym Office                 | 7    | 1        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 3rd Floor West Girl's Room        | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface | Boy's Locker Room 235             | 6    | 39       | SF   | \$28    |        |



**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                        | Location                          | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------------|-----------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | In Kitchen Area                   | 7    | 2        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor East Boy's Room         | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Lighting - Pendant/ Surface | In Room 233-3                     | 7    | 1        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 2nd Floor East Girl's Room        | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 3rd Floor East Boy's Room         | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 3rd Floor West Boy's Room         | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor East Girl's Room        | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Lighting - Pendant/ Surface | 1st Floor West Girl's Room        | 7    | 4        | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Lighting - Pendant/ Surface | Girls Locker Room                 | 6    | 39       | SF   | \$28    |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | 3rd Floor Men's Faculty Rest Room | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | 2nd Floor Men's Faculty Rest Room | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | 1st Floor Men's Faculty Rest Room | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 3rd Floor East Boy's Room         | 7    | 3        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd Floor West Girl's Room        | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd Floor East Boy's Room         | 7    | 3        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd Floor West Boy's Room         | 7    | 3        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | In Room 233-3                     | 7    | 2        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | In the Gym Office                 | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Partitions                  | Boy's Locker Room 235             | 6    | 4        | EA   | \$717   |        |
| Staff Restroom | Staff Restroom                  | Partitions                  | In Kitchen Area                   | 6    | 1        | EA   | \$179   |        |
| Staff Restroom | Locker/Shower Room              | Partitions                  | Girls Locker Room                 | 6    | 6        | EA   | \$1,076 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st Floor East Boy's Room         | 7    | 3        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 3rd Floor West Boy's Room         | 7    | 3        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 1st Floor West Boy's Room         | 7    | 3        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions                  | 2nd Floor East Girl's Room        | 6    | 10       | EA   | \$1,793 |        |

**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                  | Location                   | Rank | Quantity | Unit | Cost    | Reason |
|----------------|---------------------------------|-----------------------|----------------------------|------|----------|------|---------|--------|
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 1st Floor West Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 1st Floor East Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 3rd Floor East Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Adult Standard Student Restroom | Partitions            | 3rd Floor West Girl's Room | 6    | 10       | EA   | \$1,793 |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 1st Floor West Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Urinals               | Boy's Locker Room 235      | 7    | 3        | EA   | \$0     |        |
| Staff Restroom | Staff Restroom                  | Urinals               | In the Gym Office          | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 1st Floor East Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 3rd Floor East Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 2nd Floor West Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 3rd Floor West Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Urinals               | 2nd Floor East Boy's Room  | 7    | 8        | EA   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 3rd Floor East Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room              | Wall - Concrete Block | Girls Locker Room          | 6    | 1,985    | SF   | \$5,677 |        |
| Staff Restroom | Locker/Shower Room              | Wall - Concrete Block | Boy's Locker Room 235      | 6    | 1,985    | SF   | \$5,677 |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 3rd Floor West Girl's Room | 7    | 964      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 1st Floor East Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 1st Floor West Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 2nd Floor East Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 3rd Floor West Boy's Room  | 7    | 473      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 1st Floor East Girl's Room | 7    | 964      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 1st Floor West Girl's Room | 7    | 964      | SF   | \$0     |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block | 3rd Floor East Girl's Room | 7    | 964      | SF   | \$0     |        |

**Building: Addition**  
**Category: INTERIOR**

| Group          | Sub Group                       | Item                          | Location                          | Rank | Quantity | Unit | Cost     | Reason |
|----------------|---------------------------------|-------------------------------|-----------------------------------|------|----------|------|----------|--------|
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd Floor East Girl's Room        | 7    | 964      | SF   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd Floor West Girl's Room        | 7    | 964      | SF   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom | Wall - Concrete Block         | 2nd Floor West Boy's Room         | 7    | 473      | SF   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Wall - Plaster/Drywall        | 3rd Floor Men's Faculty Rest Room | 7    | 770      | SF   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Wall - Plaster/Drywall        | In the Gym Office                 | 6    | 489      | SF   | \$1,154  |        |
| Staff Restroom | Staff Restroom                  | Wall - Plaster/Drywall        | In Kitchen Area                   | 6    | 355      | SF   | \$838    |        |
| Staff Restroom | Staff Restroom                  | Wall - Plaster/Drywall        | 1st Floor Men's Faculty Rest Room | 7    | 770      | SF   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Wall - Plaster/Drywall        | 2nd Floor Men's Faculty Rest Room | 7    | 770      | SF   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Wall - Plaster/Drywall        | In Room 233-3                     | 7    | 442      | SF   | \$0      |        |
| Staff Restroom | Locker/Shower Room              | Wall - Structural Glazed Tile | Girls Locker Room                 | 6    | 1,984    | SF   | \$14,186 |        |
| Staff Restroom | Locker/Shower Room              | Wall - Structural Glazed Tile | Boy's Locker Room 235             | 6    | 1,984    | SF   | \$14,186 |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 3rd Floor East Girl's Room        | 7    | 11       | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 3rd Floor Men's Faculty Rest Room | 7    | 2        | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 1st Floor Men's Faculty Rest Room | 7    | 2        | EA   | \$0      |        |
| Staff Restroom | Locker/Shower Room              | Water Closet                  | Boy's Locker Room 235             | 6    | 2        | EA   | \$744    |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 1st Floor West Girl's Room        | 7    | 11       | EA   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 2nd Floor East Girl's Room        | 7    | 11       | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | 2nd Floor Men's Faculty Rest Room | 7    | 2        | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | In the Gym Office                 | 7    | 1        | EA   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 3rd Floor West Girl's Room        | 7    | 11       | EA   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 2nd Floor West Girl's Room        | 7    | 11       | EA   | \$0      |        |
| Staff Restroom | Staff Restroom                  | Water Closet                  | In Room 233-3                     | 7    | 1        | EA   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 3rd Floor West Boy's Room         | 7    | 4        | EA   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 3rd Floor East Boy's Room         | 7    | 4        | EA   | \$0      |        |
| Staff Restroom | Adult Standard Student Restroom | Water Closet                  | 2nd Floor West Boy's Room         | 7    | 4        | EA   | \$0      |        |

**Building: Addition**  
**Category: INTERIOR**

| Group                     | Sub Group                       | Item                           | Location                   | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|---------------------------------|--------------------------------|----------------------------|------|----------|------|------------------|--------|
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                   | 1st Floor West Boy's Room  | 7    | 4        | EA   | \$0              |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                   | 1st Floor East Boy's Room  | 7    | 4        | EA   | \$0              |        |
| Staff Restroom            | Locker/Shower Room              | Water Closet                   | Girls Locker Room          | 6    | 6        | EA   | \$2,231          |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                   | 2nd Floor East Boy's Room  | 7    | 4        | EA   | \$0              |        |
| Staff Restroom            | Staff Restroom                  | Water Closet                   | In Kitchen Area            | 6    | 2        | EA   | \$744            |        |
| Staff Restroom            | Adult Standard Student Restroom | Water Closet                   | 1st Floor East Girl's Room | 7    | 11       | EA   | \$0              |        |
| Swimming Pool             |                                 | Accessories                    | Room 130                   | 7    | 4,570    | SF   | \$0              |        |
| Swimming Pool             |                                 | Bleacher Seating/Plank seating | Room 130                   | 6    | 120      | EA   | \$1,699          |        |
| Swimming Pool             |                                 | Lighting - Pendant/ Surface    | Room 130                   | 6    | 72       | SF   | \$77             |        |
| Swimming Pool             |                                 | Pool Basin                     | Room 130                   | 7    | 1,693    | SF   | \$0              |        |
| Swimming Pool             |                                 | Pool Deck                      | Room 130                   | 7    | 2,153    | SF   | \$0              |        |
| Swimming Pool             |                                 | Pool deck drains               | Room 130                   | 7    | 10       | EA   | \$0              |        |
| Swimming Pool             |                                 | Structural Glazed Tile         | Room 130                   | 6    | 6,571    | SF   | \$46,983         |        |
| Vocational Shop           | Classroom                       | Culinary Kitchen Equipment     |                            | 7    | 1,480    | EA   | \$0              |        |
| Vocational Shop           | Classroom                       | Work Sink                      |                            | 7    | 1        | EA   | \$0              |        |
| Vocational Shop           | Classroom                       | Work Sink                      |                            | 7    | 1        | EA   | \$0              |        |
| Vocational Shop           | Classroom                       | Work Sink                      |                            | 7    | 1        | EA   | \$0              |        |
| Vocational Shop           | Classroom                       | Work Sink                      |                            | 6    | 1        | EA   | \$386            |        |
| Vocational Shop           | Classroom                       | Work Sink                      |                            | 7    | 1        | EA   | \$0              |        |
| <b>INTERIOR Sub Total</b> |                                 |                                |                            |      |          |      | <b>\$512,884</b> |        |

**Building: Addition**  
**Category: ROOM**

| Group         | Sub Group                     | Item                          | Location   | Rank | Quantity | Unit | Cost    | Reason |
|---------------|-------------------------------|-------------------------------|------------|------|----------|------|---------|--------|
| ADMIN_CEILING | Administrative Suites/Offices | Administrative Office Ceiling | Room 132   | 6    | 726      | SF   | \$2,056 |        |
| ADMIN_WALL    | Administrative Suites/Offices | Administrative Office Walls   | Room 235-4 |      |          | SF   | \$0     |        |
| Casework      | Classroom                     | Casework                      |            | 6    | 8        | LF   | \$286   |        |
| Casework      | Classroom                     | Casework                      |            | 6    | 30       | LF   | \$1,073 |        |
| Casework      | Classroom                     | Casework                      |            | 6    | 8        | LF   | \$286   |        |
| Casework      | Classroom                     | Casework                      |            | 6    | 8        | LF   | \$286   |        |
| Casework      | Classroom                     | Casework                      |            | 6    | 8        | LF   | \$286   |        |
| Casework      | Classroom                     | Casework                      |            | 6    | 8        | LF   | \$286   |        |
| Casework      | Classroom                     | Casework                      |            | 6    | 8        | LF   | \$286   |        |

**Building: Addition**  
**Category: ROOM**

| Group    | Sub Group | Item        | Location | Rank | Quantity | Unit | Cost    | Reason |
|----------|-----------|-------------|----------|------|----------|------|---------|--------|
| Casework | Classroom | Casework    |          | 6    | 8        | LF   | \$286   |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 6    | 20       | LF   | \$715   |        |
| Casework | Classroom | Casework    |          | 6    | 8        | LF   | \$286   |        |
| Casework | Classroom | Casework    |          | 6    | 10       | LF   | \$358   |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 6    | 8        | LF   | \$286   |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 6    | 8        | LF   | \$286   |        |
| Casework | Classroom | Casework    |          | 6    | 8        | LF   | \$286   |        |
| Casework | Classroom | Casework    |          | 6    | 20       | LF   | \$715   |        |
| Casework | Classroom | Casework    |          | 6    | 30       | LF   | \$1,073 |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 6    | 8        | LF   | \$286   |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 6    | 8        | LF   | \$286   |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Casework | Classroom | Casework    |          | 6    | 20       | LF   | \$715   |        |
| Casework | Classroom | Casework    |          | 7    | 8        | LF   | \$0     |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |

**Building: Addition**  
**Category: ROOM**

| Group   | Sub Group | Item        | Location | Rank | Quantity | Unit | Cost    | Reason |
|---------|-----------|-------------|----------|------|----------|------|---------|--------|
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 975      | SF   | \$2,091 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 760      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 915      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 986      | SF   | \$2,115 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 915      | SF   | \$1,963 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 716      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 915      | SF   | \$1,963 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 986      | SF   | \$2,115 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 498      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 716      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 975      | SF   | \$2,091 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 1,480    | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 498      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 716      | SF   | \$1,536 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,089    | SF   | \$2,336 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 797      | SF   | \$1,710 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 1,480    | SF   | \$3,175 |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 716      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 716      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 716      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 716      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 7    | 716      | SF   | \$0     |        |
| Ceiling | Classroom | Lay-In/Drop |          | 6    | 2,282    | SF   | \$4,895 |        |

**Building: Addition**  
**Category: ROOM**

| Group       | Sub Group | Item                 | Location | Rank | Quantity | Unit | Cost    | Reason |
|-------------|-----------|----------------------|----------|------|----------|------|---------|--------|
| Ceiling     | Classroom | Lay-In/Drop          |          | 6    | 2,282    | SF   | \$4,895 |        |
| Ceiling     | Classroom | Lay-In/Drop          |          | 6    | 716      | SF   | \$1,536 |        |
| Ceiling     | Classroom | Lay-In/Drop          |          | 6    | 730      | SF   | \$1,566 |        |
| Ceiling     | Classroom | Plaster/Drywall      |          | 6    | 975      | SF   | \$2,761 |        |
| Ceiling     | Classroom | Plaster/Drywall      |          | 7    | 1,811    | SF   | \$0     |        |
| Ceiling     | Classroom | Plaster/Drywall      |          | 6    | 975      | SF   | \$2,761 |        |
| Ceiling     | Classroom | Plaster/Drywall      |          | 6    | 975      | SF   | \$2,761 |        |
| Ceiling     | Classroom | Plaster/Drywall      |          | 6    | 1,205    | SF   | \$3,412 |        |
| Ceiling     | Classroom | Plaster/Drywall      |          | 6    | 1,205    | SF   | \$3,412 |        |
| Ceiling     | Classroom | Splined Ceiling      |          | 6    | 1,092    | SF   | \$2,342 |        |
| Ceiling     | Classroom | Splined Ceiling      |          | 6    | 1,347    | SF   | \$2,889 |        |
| Chalk Board | Classroom | Chalk Board          |          | 4    | 24       | LF   | \$2,917 |        |
| Chalk Board | Classroom | Chalk Board          |          | 4    | 24       | LF   | \$2,917 |        |
| Chalk Board | Classroom | Chalk Board          |          | 4    | 24       | LF   | \$2,917 |        |
| Chalk Board | Classroom | Chalk Board          |          | 4    | 24       | LF   | \$2,917 |        |
| CLASSROOM   | Classroom | Eye Wash Station     |          | 7    | 1        | EA   | \$0     |        |
| CLASSROOM   | Classroom | Eye Wash Station     |          | 7    | 1        | EA   | \$0     |        |
| CLASSROOM   | Classroom | Eye Wash Station     |          | 7    | 1        | EA   | \$0     |        |
| CLASSROOM   | Classroom | Eye Wash Station     |          | 7    | 1        | EA   | \$0     |        |
| CLASSROOM   | Classroom | Eye Wash Station     |          | 7    | 1        | EA   | \$0     |        |
| CLASSROOM   | Classroom | Eye Wash Station     |          | 7    | 1        | EA   | \$0     |        |
| CLASSROOM   | Classroom | Science Lab Elements |          | 7    | 1,250    | SF   | \$0     |        |
| CLASSROOM   | Classroom | Science Lab Elements |          | 7    | 986      | SF   | \$0     |        |
| CLASSROOM   | Classroom | Science Lab Elements |          | 7    | 986      | SF   | \$0     |        |
| CLASSROOM   | Classroom | Science Lab Elements |          | 7    | 975      | SF   | \$0     |        |
| CLASSROOM   | Classroom | Science Lab Elements |          | 7    | 975      | SF   | \$0     |        |
| CLASSROOM   | Classroom | Science Lab Elements |          | 7    | 1,250    | SF   | \$0     |        |
| CLASSROOM   | Classroom | Science Lab Shower   |          | 7    | 1        | EA   | \$0     |        |
| CLASSROOM   | Classroom | Science Lab Shower   |          | 5    | 1        | EA   | \$9,295 |        |
| Floor       | Classroom | Carpet               |          | 7    | 1,811    | SF   | \$0     |        |
| Floor       | Classroom | Carpet               |          | 6    | 716      | SF   | \$1,024 |        |
| Floor       | Classroom | Concrete             |          | 7    | 1,092    | SF   | \$0     |        |
| Floor       | Classroom | Concrete             |          | 7    | 1,347    | SF   | \$0     |        |
| Floor       | Classroom | Floor                |          | 7    | 975      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 975      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 797      | SF   | \$0     |        |
| Floor       | Classroom | Tile/Sheet           |          | 7    | 1,480    | SF   | \$0     |        |

**Building: Addition**  
**Category: ROOM**

| Group | Sub Group | Item       | Location | Rank | Quantity | Unit | Cost    | Reason |
|-------|-----------|------------|----------|------|----------|------|---------|--------|
| Floor | Classroom | Tile/Sheet |          | 6    | 1,480    | SF   | \$2,116 |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 1,089    | SF   | \$0     |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 915      | SF   | \$0     |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 975      | SF   | \$0     |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 1,205    | SF   | \$0     |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 986      | SF   | \$0     |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 498      | SF   | \$0     |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 986      | SF   | \$0     |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 498      | SF   | \$0     |        |
| Floor | Classroom | Tile/Sheet |          | 7    | 1,205    | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 760      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 716      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 716      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 716      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 716      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 975      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 716      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 716      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 716      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 2,282    | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 2,282    | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 915      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 915      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 975      | SF   | \$0     |        |
| Floor | Classroom | Wood       |          | 7    | 730      | SF   | \$0     |        |





**Building: Addition**  
**Category: ROOM**

| Group        | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost  | Reason |
|--------------|-----------|-----------------|----------|------|----------|------|-------|--------|
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 15       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 15       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 15       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 30       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 36       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 36       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 18       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 16       | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 9        | EA   | \$0   |        |
| Lighting     | Classroom | Lay-In          |          | 7    | 12       | EA   | \$0   |        |
| Lighting     | Classroom | Pendant/Surface |          | 7    | 24       | EA   | \$0   |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 12       | EA   | \$858 |        |
| Lighting     | Classroom | Pendant/Surface |          | 6    | 6        | EA   | \$429 |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 18       | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0   |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0   |        |

**Building: Addition**  
**Category: ROOM**

| Group        | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost    | Reason |
|--------------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 16       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 36       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 36       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 4        | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 48       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 20       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 24       | LF   | \$0     |        |
| Marker Board | Classroom | Marker Board    |          | 7    | 8        | LF   | \$0     |        |
| Wall         | Classroom | Plaster/Drywall |          | 6    | 840      | SF   | \$1,982 |        |
| Wall         | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall         | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |

**Building: Addition**  
**Category: ROOM**

| Group | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost    | Reason |
|-------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,400    | SF   | \$3,303 |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,388    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,026    | SF   | \$2,421 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,090    | SF   | \$2,572 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,090    | SF   | \$2,572 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,090    | SF   | \$2,572 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,234    | SF   | \$2,912 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,920    | SF   | \$4,530 |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 906      | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 2,100    | SF   | \$4,955 |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 906      | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 840      | SF   | \$1,982 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,920    | SF   | \$4,530 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,490    | SF   | \$3,516 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 1,460    | SF   | \$3,445 |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,388    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 1,088    | SF   | \$0     |        |

**Building: Addition**  
**Category: ROOM**

| Group | Sub Group | Item                   | Location | Rank | Quantity | Unit | Cost    | Reason |
|-------|-----------|------------------------|----------|------|----------|------|---------|--------|
| Wall  | Classroom | Plaster/Drywall        |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall        |          | 6    | 1,400    | SF   | \$3,303 |        |
| Wall  | Classroom | Plaster/Drywall        |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall        |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall        |          | 6    | 980      | SF   | \$2,312 |        |
| Wall  | Classroom | Plaster/Drywall        |          | 7    | 1,088    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall        |          | 6    | 1,400    | SF   | \$3,303 |        |
| Wall  | Classroom | Plaster/Drywall        |          | 6    | 1,400    | SF   | \$3,303 |        |
| Wall  | Classroom | Plaster/Drywall        |          | 6    | 1,400    | SF   | \$3,303 |        |
| Wall  | Classroom | Plaster/Drywall        |          | 6    | 1,150    | SF   | \$2,713 |        |
| Wall  | Classroom | Structural Glazed Tile |          | 7    | 2,495    | SF   | \$0     |        |
| Wall  | Classroom | Structural Glazed Tile |          | 7    | 1,624    | SF   | \$0     |        |

**ROOM Sub Total \$204,251**

**Building Addition Sub Total \$7,500,640**

**Building: SITE**  
**Category: SITE**

| Group          | Sub Group | Item  | Location                  | Rank | Quantity | Unit | Cost      | Reason   |
|----------------|-----------|---|---------------------------|------|----------|------|-----------|--|
| Athletic       |           | Baseball - Natural                                      | Southwest                 | 6    | 66,456   | SF   | \$38,013  |  |
| Athletic       |           | Football/Soccer - Synthetic including exc and retention | W site                    | 7    | 80,452   | SF   | \$0       |  |
| Athletic       |           | Lighting  | throughout                | 6    | 27       | EA   | \$579,150 |  |
| Athletic       |           | Metal Bleachers   | W site                    | 7    | 3        | LF   | \$0       |  |
| Athletic       |           | Running Track Synthetic                                 | W site                    | 7    | 33,030   | SF   | \$0       |  |
| Civil/Drainage |           | Catch Basin   | throughout site           | 7    | 19       | EA   | \$0       |  |
| Civil/Drainage |           | Site Drain  | courtyard, basement level | 5    | 6        | EA   | \$6,006   | clogged drains producing water inside at glass block/fan units |
| Civil/Drainage |           | Site Manhole  | throughout site           | 7    | 33       | EA   | \$0       |  |
| Fencing        |           | Chain Link  | throughout site           | 7    | 884      | LF   | \$0       |  |
| Fencing        |           | Ornamental Iron   | throughout site           | 7    | 3,796    | LF   | \$0       |  |
| Fencing        |           | Wood Fencing w/ Steel Frame                             | S site                    | 7    | 699      | LF   | \$0       |  |
| Landscape      |           | Benches   | throughout site           | 7    | 20       | EA   | \$0       |  |
| Landscape      |           | Grass   | throughout site           | 6    | 167,879  | SF   | \$67,219  |  |
| Landscape      |           | Hardscape - Concrete                                    | throughout site           | 7    | 5,664    | SF   | \$0       |  |
| Landscape      |           | Hardscape - Pavers                                      | Courtyard                 | 6    | 816      | SF   | \$2,310   | weeds  |

Building: SITE  
Category: SITE

| Group                 | Sub Group | Item  | Location                  | Rank | Quantity | Unit | Cost             | Reason                       |
|-----------------------|-----------|---|---------------------------|------|----------|------|------------------|------------------------------|
| Landscape             |           | Hardscape - Pavers                          | Courtyard                 | 4    | 400      | SF   | \$8,466          | buckling                     |
| Landscape             |           | Irrigation                                  | throughout site           | 7    | 167,879  | SF   | \$0              |                              |
| Landscape             |           | Parkway trees                               | E site                    | 4    | 1        | EA   | \$2,454          | missing                      |
| Landscape             |           | Parkway trees                               | SW site                   | 4    | 1        | EA   | \$2,454          | knocked over                 |
| Landscape             |           | Parkway trees                               | throughout site perimeter | 7    | 25       | EA   | \$0              |                              |
| Landscape             |           | Planting Beds/ Areas                        | Courtyard                 | 6    | 6,225    | SF   | \$0              |                              |
| Landscape             |           | Planting Beds/ Areas                        | S site                    | 6    | 14,379   | SF   | \$0              |                              |
| Landscape             |           | Retaining Wall - Concrete                   | Courtyard                 | 5    | 1,960    | SF   | \$152,612        | surface cracks/chips         |
| Landscape             |           | Trash Receptacles                           | throughout site           | 7    | 6        | EA   | \$0              |                              |
| Landscape             |           | Walking Path - Crushed Stone                | Courtyard                 | 5    | 1,068    | SF   | \$0              | broken sections & vegetation |
| Landscape             |           | Walking Path - Crushed Stone                | SW site                   | 7    | 4,088    | SF   | \$0              |                              |
| Parking Lot           |           | Asphalt                                     | Courtyard                 | 5    | 3,327    | SF   | \$9,420          | cracks & potholes            |
| Parking Lot           |           | Asphalt                                     | S site                    | 7    | 14,447   | SF   | \$0              |                              |
| Parking Lot           |           | Asphalt                                     | N & S site                | 6    | 16,124   | SF   | \$13,834         |                              |
| Parking Lot           |           | Concrete                                    | Courtyard                 | 6    | 4,113    | SF   | \$0              |                              |
| Parking Lot           |           | Concrete Curbs                              | parking lots              | 7    | 2,708    | LF   | \$0              |                              |
| Parking Lot           |           | Lights, Pole Mounted                        | parking lots              | 6    | 20       | EA   | \$22,880         |                              |
| Parking Lot           |           | Parking lot interior plantings              | parking lots              | 7    | 1,065    | LF   | \$0              |                              |
| Parking Lot           |           | Vehicular Screening                         | parking lots              | 7    | 757      | LF   | \$0              |                              |
| Sidewalks             |           | Internal Walks                              | Courtyard                 | 4    | 100      | LF   | \$9,438          | broken, movement, poor pitch |
| Sidewalks             |           | Internal Walks                              | throughout site           | 7    | 2,496    | LF   | \$0              |                              |
| Sidewalks             |           | Perimeter Sidewalks                         | throughout site perimeter | 7    | 24,022   | SF   | \$0              |                              |
| Signage               |           | Flag Pole                                   | SE site                   | 6    | 1        | EA   | \$0              |                              |
| Signage               |           | Marquee - Free Standing Back Lighted w/ LED | SW site                   | 7    | 1        | EA   | \$0              |                              |
| <b>SITE Sub Total</b> |           |   |                           |      |          |      | <b>\$914,256</b> |                              |
| <b>SITE Sub Total</b> |           |   |                           |      |          |      | <b>\$914,256</b> |                              |

**Building: SITE**

**Category: SITE**

| Group                                   | Sub Group | Item | Location | Rank | Quantity | Unit | Cost                | Reason |
|---|-----------|------|----------|------|----------|------|---------------------|--------|
| <b>Total Campus Need <sup>2 3</sup></b> |           |      |          |      |          |      | <b>\$15,079,908</b> |        |

<sup>1</sup> It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

<sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

**Room Summary**

| Room Number           | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                   | Location                   |
|-----------------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|----------------------------|
| <b>Building: Main</b> |           |              |             |              |             |                   |                      |                  |             |             |             |                               |                                 |                            |
| 110                   | 950       | 1            | 8           | 18           | 40          | 184               | 36                   | 0                | N           | N           | N           | Classroom                     |                                 |                            |
| 118                   | 950       | 1            | 8           | 18           | 40          | 184               | 36                   | 0                | N           | N           | N           | Classroom                     |                                 |                            |
| 312                   | 760       | 1            | 28          | 40           | 40          | 102               | 27                   | 1                | N           | N           | Y           | Classroom                     |                                 |                            |
| 314                   | 848       | 2            | 5           | 10           | 40          | 230               | 45                   | 0                | N           | N           | N           | Classroom                     |                                 |                            |
| 316                   | 1152      | 1            | 10          | 30           | 40          | 368               | 72                   | 0                | N           | N           | N           | Classroom                     |                                 |                            |
| 318                   | 950       | 1            | 35          | 70           | 40          | 184               | 36                   | 1                | N           | N           | N           | Classroom                     |                                 |                            |
| Other                 | 739       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Locker/Shower Room              | Room 05 next to Gym        |
| Other                 | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd Floor West Boy's Room  |
| Other                 | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st Floor East Boy's Room  |
| Other                 | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st Floor West Boy's Room  |
| Other                 | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 3rd Floor West Girl's Room |
| Other                 | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd Floor West Girl's Room |
| Other                 | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd Floor East Girl's Room |
| Other                 | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st Floor East Girl's Room |
| Other                 | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st Floor West Girl's Room |
| Other                 | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd Floor East Boy's Room  |
| Other                 | 390       |              |             | 6            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                 | Gym Office 012-3           |
| Other                 | 266       |              |             | 4            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                 | Maintenance Room           |
| Other                 | 291       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Engineer's Office          |
| Other                 | 498       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | Next to Boiler Room        |
| Other                 | 12719     |              |             |              |             |                   |                      |                  | N           | N           | N           | Auditorium & Theater          | Auditorium - Dedicated          | 1st Floor                  |
| Other                 | 178       |              |             | 4            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 133-1 Pool Office     |
| Other                 | 696       |              |             | 10           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Office in Room 110         |
| Other                 | 696       |              |             | 10           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Office in Room 210         |
| Other                 | 4317      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Standard Dedicated Gymnasium    | Room 012                   |
| Other                 | 783       |              |             | 10           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 212                   |
| Other                 | 848       |              |             | 10           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 214                   |
| Other                 | 1152      |              |             | 8            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 216                   |
| Other                 | 950       |              |             | 8            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 218                   |
| Other                 | 29        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | In Engineer's Office       |
| Other                 | 233       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Office in Room 310A        |
| Other                 | 696       |              |             | 10           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Office in Room 310         |
| Other                 | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 3rd Floor West Boy's Room  |

**Building: Addition**

|     |     |   |   |    |    |     |    |   |   |   |   |           |  |  |
|-----|-----|---|---|----|----|-----|----|---|---|---|---|-----------|--|--|
| 136 | 730 | 1 | 6 | 20 | 40 | 204 | 54 | 1 | N | N | N | Classroom |  |  |
|-----|-----|---|---|----|----|-----|----|---|---|---|---|-----------|--|--|



**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-----------|---------------|----------|
| 143         | 1480      | 1            | 18          | 40           | 40          | 396               | 108                  | 1                | N           | N           | N           | Classroom |               |          |
| 147         | 1480      | 0            | 0           | 30           | 40          | 429               | 117                  | 2                | N           | N           | N           | Classroom |               |          |
| 151         | 797       | 1            | 16          | 40           | 40          | 132               | 36                   | 1                | N           | N           | Y           | Classroom |               |          |
| 223         | 716       | 1            | 35          | 70           | 40          | 198               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 224         | 975       | 1            | 4           | 20           | 40          | 272               | 72                   | 0                | N           | N           | Y           | Classroom |               |          |
| 225         | 716       | 1            | 2           | 10           | 40          | 198               | 54                   | 0                | N           | N           | Y           | Classroom |               |          |
| 228         | 975       | 1            | 4           | 20           | 40          | 272               | 72                   | 0                | N           | N           | Y           | Classroom |               |          |
| 232         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 233-1       | 1092      | 0            | 0           | 2            | 40          | 0                 | 0                    | 0                | N           | N           | N           | Classroom |               |          |
| 233-4       | 1347      | 0            | 0           | 4            | 40          | 0                 | 0                    | 0                | N           | N           | N           | Classroom |               |          |
| 234         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 236         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 237         | 1811      | 1            | 2           | 6            | 40          | 198               | 54                   | 0                | N           | N           | N           | Classroom |               |          |
| 238         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 241         | 716       | 1            | 2           | 10           | 40          | 198               | 54                   | 1                | N           | N           | N           | Classroom |               |          |
| 243         | 716       | 1            | 2           | 10           | 40          | 198               | 54                   | 1                | N           | N           | N           | Classroom |               |          |
| 244         | 1205      | 1            | 8           | 24           | 40          | 330               | 90                   | 0                | N           | N           | N           | Classroom |               |          |
| 245         | 716       | 1            | 2           | 10           | 40          | 198               | 54                   | 1                | N           | N           | N           | Classroom |               |          |
| 246         | 1205      | 1            | 8           | 24           | 40          | 330               | 90                   | 0                | N           | N           | N           | Classroom |               |          |
| 247         | 716       | 1            | 2           | 10           | 40          | 198               | 54                   | 1                | N           | N           | N           | Classroom |               |          |
| 248         | 975       | 1            | 8           | 24           | 40          | 330               | 90                   | 0                | N           | N           | N           | Classroom |               |          |
| 249         | 716       | 1            | 2           | 10           | 40          | 198               | 54                   | 1                | N           | N           | N           | Classroom |               |          |
| 250         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 251         | 716       | 1            | 2           | 10           | 40          | 198               | 54                   | 1                | N           | N           | N           | Classroom |               |          |
| 252         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 253         | 716       | 1            | 2           | 10           | 40          | 198               | 54                   | 1                | N           | N           | N           | Classroom |               |          |
| 254         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 321         | 498       | 0            | 0           | 16           | 40          | 132               | 36                   | 0                | N           | N           | N           | Classroom |               |          |
| 323         | 986       | 1            | 16          | 32           | 40          | 264               | 72                   | 0                | N           | N           | N           | Classroom |               |          |
| 324         | 730       | 1            | 2           | 10           | 40          | 204               | 54                   | 0                | N           | N           | Y           | Classroom |               |          |
| 325         | 498       | 1            | 2           | 18           | 40          | 132               | 36                   | 0                | N           | N           | N           | Classroom |               |          |
| 326         | 730       | 1            | 30          | 50           | 40          | 204               | 54                   | 0                | N           | N           | Y           | Classroom |               |          |
| 327         | 986       | 1            | 6           | 24           | 40          | 264               | 72                   | 0                | N           | N           | N           | Classroom |               |          |
| 328         | 730       | 1            | 7           | 50           | 40          | 204               | 54                   | 0                | N           | N           | Y           | Classroom |               |          |
| 329         | 2282      | 1            | 2           | 72           | 40          | 495               | 135                  | 3                | N           | N           | Y           | Classroom |               |          |
| 332         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |
| 334         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom |               |          |

**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                | Location                       |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|------------------------------|--------------------------------|
| 336         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom                     |                              |                                |
| 337         | 2282      | 1            | 2           | 10           | 40          | 495               | 135                  | 0                | N           | N           | N           | Classroom                     |                              |                                |
| 338         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom                     |                              |                                |
| 341         | 1089      | 1            | 2           | 10           | 40          | 297               | 81                   | 0                | N           | N           | N           | Classroom                     |                              |                                |
| 342         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom                     |                              |                                |
| 343         | 915       | 1            | 2           | 10           | 40          | 264               | 72                   | 0                | N           | N           | N           | Classroom                     |                              |                                |
| 344         | 975       | 1            | 8           | 24           | 40          | 297               | 90                   | 0                | N           | N           | N           | Classroom                     |                              |                                |
| 345         | 915       | 1            | 9           | 24           | 40          | 264               | 72                   | 0                | N           | N           | N           | Classroom                     |                              |                                |
| 347         | 915       | 1            | 9           | 24           | 40          | 264               | 72                   | 0                | N           | N           | N           | Classroom                     |                              |                                |
| 348         | 975       | 1            | 8           | 24           | 40          | 297               | 81                   | 0                | N           | N           | N           | Classroom                     |                              |                                |
| 349         | 760       | 1            | 2           | 10           | 40          | 198               | 54                   | 0                | N           | N           | N           | Classroom                     |                              |                                |
| 350         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom                     |                              |                                |
| 352         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom                     |                              |                                |
| 354         | 730       | 1            | 2           | 6            | 40          | 204               | 54                   | 1                | N           | N           | Y           | Classroom                     |                              |                                |
| Other       | 88        |              |             | 2            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Room 235-4                     |
| Other       | 105       |              |             | 4            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Kitchen Manager's Office       |
| Other       | 1205      |              |             |              |             |                   |                      |                  | N           | N           | N           | Kitchen                       | Cooking Kitchen              | 1st Floor                      |
| Other       | 145       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom               | In Kitchen Area                |
| Other       | 798       |              |             | 8            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Room 125 Main Office           |
| Other       | 185       |              |             | 4            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Records Room in Main Office    |
| Other       | 3366      |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Locker/Shower Room           | Boy's Locker Room 235          |
| Other       | 235       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Room 125-2 Principal's Office  |
| Other       | 235       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Room 122                       |
| Other       | 750       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Room 127 Attendance Office     |
| Other       | 153       |              |             | 2            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                              | Room 344.2 Prep Room           |
| Other       | 156       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Office in Gym Room 235         |
| Other       | 1160      |              |             |              |             |                   |                      |                  | N           | N           | N           | Lunch & Multipurpose Room     | Lunchroom                    | Room 142, Teacher's Lunch Room |
| Other       | 202       |              |             | 4            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Room 235-2                     |
| Other       | 86        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom               | In the Gym Office              |
| Other       | 4288      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Standard Dedicated Gymnasium | Room 231 Girls                 |
| Other       | 4288      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Standard Dedicated Gymnasium | Room 233 Girls                 |
| Other       | 162       |              |             | 4            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Room 233-5                     |
| Other       | 391       |              |             | 4            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                              | Room 233-3                     |
| Other       | 109       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom               | In Room 233-3                  |
| Other       | 3684      |              |             |              |             |                   |                      |                  | N           | N           | N           | Library                       |                              | Room 229                       |
| Other       | 3295      |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Locker/Shower Room           | Girls Locker Room              |
| Other       | 8146      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Competition Gymnasium        | Room 235 Boys                  |

**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                   | Location                          |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|---------------------------------|-----------------------------------|
| Other       | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st Floor East Girl's Room        |
| Other       | 268       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 2nd Floor Men's Faculty Rest Room |
| Other       | 268       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 1st Floor Men's Faculty Rest Room |
| Other       | 153       |              |             | 2            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                 | Room 348.2 Prep Room              |
| Other       | 716       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 221                          |
| Other       | 726       |              |             | 10           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 132                          |
| Other       | 726       |              |             | 10           |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 134                          |
| Other       | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 3rd Floor West Girl's Room        |
| Other       | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 3rd Floor East Girl's Room        |
| Other       | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd Floor East Girl's Room        |
| Other       | 498       |              |             | 8            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 141A                         |
| Other       | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st Floor West Girl's Room        |
| Other       | 379       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 141 Police Room              |
| Other       | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 3rd Floor West Boy's Room         |
| Other       | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 3rd Floor East Boy's Room         |
| Other       | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd Floor East Boy's Room         |
| Other       | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd Floor West Boy's Room         |
| Other       | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st Floor West Boy's Room         |
| Other       | 337       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 1st Floor East Boy's Room         |
| Other       | 4570      |              |             |              |             |                   |                      |                  | N           | N           | N           | Lunch & Multipurpose Room     | Lunchroom                       | Room 138                          |
| Other       | 3251      |              |             |              |             |                   |                      |                  | N           | N           | N           | Lunch & Multipurpose Room     | Lunchroom                       | Room 141                          |
| Other       | 379       |              |             | 6            |             |                   |                      |                  | N           | N           | Y           | Administrative Suites/Offices |                                 | Room 137 Security Office          |
| Other       | 268       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                  | 3rd Floor Men's Faculty Rest Room |
| Other       | 471       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Adult Standard Student Restroom | 2nd Floor West Girl's Room        |