

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

Rank 7: The item/system is new or in good condition and no work is required.

Rank 6: The item/system requires general cleaning and/or routine maintenance.

Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.

Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.

Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.

Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.

Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	North Entrances	6	36	SF	\$1,019	
Chimney		Brick Chimney - Concrete/ Mortar Liner	Entire Building	6	60	LF	\$30,030	
Chimney		Brick Chimney - Concrete/ Mortar Liner	upper portion	4	20	LF	\$110,110	
Doors		Exterior FRP Door	Entire Building	7	8	EA	\$0	
Doors		Exterior Steel Door	Entire Building	6	4	EA	\$1,321	
Doors		Side Lite	Entire Building	7	48	EA	\$0	
Doors		Transom Lite	Entire Building	7	54	EA	\$0	
Doors		Transom Lite	East Entrances	4	18	EA	\$50,965	
Entrance		Concrete Exterior Stairs	Entire Building	6	450	LF	\$48,263	
Entrance		Entrance Controls - Audio	north & west	7	2	EA	\$0	
Entrance		Entrance Controls - Audio and Video	Main Entrance	7	1	EA	\$0	
Entrance		Stair Handrails	Entire Building	6	18	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	25,720	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	4	8	EA	\$29,744	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	3	2	EA	\$7,436	
Lighting		Exterior Lights - Wall Mounted	Entire Building	5	12	EA	\$6,006	
Lintels		Lintels - Steel	Entire Building	7	850	LF	\$0	
Lintels		Lintels - Steel	1936 building; 3rd floor	6	200	LF	\$7,550	
Parapet		Coping - Metal	Entire Building	7	390	LF	\$0	
Parapet		Coping - Stone	Entire Building	5	710	LF	\$61,913	
Parapet		Parapet > 30" Height	Entire Building	6	240	LF	\$62,291	
Parapet		Parapet 16" to 30" Height	Entire Building	6	470	LF	\$97,589	
Roof System		Asphalt Gravel Ballast Roof	north wing	5	5,700	SF	\$72,625	
Roof System		Asphalt Gravel Ballast Roof	Entire Building	7	17,500	SF	\$0	
Roof System		Interior Downspouts	Entire Building	6	280	LF	\$0	
Roof System		Modified Bitumen Roof	Entire Building	7	2,520	SF	\$0	
Roof System		Roof Structure: Concrete	Entire Building	7	5,700	SF	\$0	
Roof System		Roof Structure: Steel with Clay Tile Arch	Entire Building	7	17,500	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Entire Building	7	2,520	SF	\$0	
Superstructure		Concrete	Entire Building	7	70,800	SF	\$0	
Walls		Brick	1936 building	5	18,000	SF	\$407,722	
Walls		Brick	Entire Building	7	9,700	SF	\$0	
Walls		Stone - Cut	1936 building	6	2,000	SF	\$28,600	
Windows		Window - Guards wire guard	Entire Building	7	3,100	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	6	8,800	SF	\$75,504	
EXTERIOR Sub Total							\$1,098,688	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Basement	6	1	EA	\$1,430	
Emergency System		Emergency A/C power - Auditorium and aisle lighting	1st Floor	6	2,450	SF	\$3,328	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	12,588	SF	\$5,400	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	3,889	SF	\$2,058	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	6	2,317	SF	\$994	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Basement	6	2	EA	\$215	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Boiler Room	6	2	EA	\$215	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Basement	6	1	EA	\$107	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Basement	6	2	EA	\$215	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	23	EA	\$2,467	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency Battery Packs - Corridors and Stairs	Pump Room	6	3	EA	\$322	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	1	EA	\$107	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	1	EA	\$107	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	2	EA	\$215	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	2	EA	\$215	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	1	EA	\$107	
Emergency System		Emergency Battery Packs - Toilets	1st Floor	6	3	EA	\$322	
Emergency System		Emergency Battery Packs - Toilets	3rd Floor	6	2	EA	\$215	
Emergency System		Exit Signs - Auditorium	1st Floor	6	4	EA	\$932	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	21	EA	\$4,895	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	1	EA	\$233	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	2	EA	\$466	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	2	EA	\$466	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	2	EA	\$466	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	8	EA	\$1,865	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Basement	5	2	EA	\$930	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	2nd Floor	6	2	EA	\$466	
Emergency System		Independent Electrical Service for emergency power	Basement	6	1	EA	\$1,430	
Emergency System		Public Announcement System	Entire Building	6	70,800	SF	\$42,522	
Emergency System		Security System - Intrusion detection	1st Floor	4	70,800	SF	\$283,483	
Main Service		Main Electrical service above 3000 A 120/208/3PH	Electrical Room	6	1	EA	\$35,750	
Power Distribution		Lighting and power panels	Entire Building	6	16	EA	\$11,440	
Power Distribution		Lighting and power panels	Entire Building	4	8	EA	\$43,472	
Power Distribution		Main distribution panels 400-600 amp	Pump Room	4	2	EA	\$24,310	
Power Distribution		Main distribution panels above 600 amp	Pump Room	6	1	EA	\$2,145	
Power Distribution		Transformers 120/240-120/208	Basement	6	1	EA	\$1,144	
ELECTRICAL Sub Total							\$474,452	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Pump Room	4	70,800	SF	\$250,073	
FIRE PROTECTION Sub Total							\$250,073	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Ground Mounted 5 to 10 tons	1st Floor	5	1	EA	\$9,295	
Air Conditioning		Condensing Unit - Roof Mounted 11 to 20 tons	Roof	5	1	EA	\$6,435	
Air Conditioning		Window A/C Unit	Entire Building	5	12	EA	\$12,870	
Air Conditioning		Window A/C Unit	Entire Building	4	6	EA	\$12,870	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Basement Wall	6	2	EA	\$2,860	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Basement	4	1	EA	\$128,700	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Basement	4	1	EA	\$40,040	
Air Handling Systems		Reheat Boxes With Steam Coils	Basement	4	7	EA	\$73,073	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	6	200	LF	\$12,584	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Roof	6	200	LF	\$12,584	
Air Handling Systems		Return Fans - Outdoor greater than 20,000 CFM	Roof	5	1	EA	\$21,450	
Air Handling Systems		Roof Top Unit - Multi Zone - Gas-Heating 21 to 30 tons	Roof	5	1	EA	\$40,040	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 8,001 to 15,000 cfm	Basement	4	1	EA	\$32,890	
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries- Steam 8,001 to 15,000 cfm	Basement	4	2	EA	\$28,600	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 50-75 HP	Boiler Room	6	2	EA	\$20,020	
Boiler Systems		Boiler Auxiliary - Steam Boiler 50-75 HP	Boiler Room	6	2	EA	\$3,718	
Boiler Systems		Chemical Feed System (Steam Boilers)	Pump room	6	1	EA	\$2,145	
Boiler Systems		Combustion Dampers	Boiler Room	6	1	EA	\$286	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	6	1	EA	\$8,437	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	5	9	EA	\$16,731	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	4	4	EA	\$16,588	
Heating Devices		Fin Tube Hot Water	Entire Building	3	8	LF	\$1,373	
Heating Devices		Fin Tube Hot Water	Entire Building	4	71	LF	\$12,184	
Heating Devices		Fin Tube Hot Water	Entire Building	5	14	LF	\$1,201	
Heating Devices		Radiators - Steam	Entire Building	4	15	EA	\$21,021	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	6	3	EA	\$2,145	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	4	200	LF	\$19,591	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	4	200	LF	\$23,953	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Pumps - Hot Water 11 to 20 HP	Pump Room	5	1	EA	\$10,725	
Mechanical Plumbing		Pumps - Vacuum	Boiler Room	6	3	EA	\$8,580	
Temperature Control		Direct Digital Control (DDC) System	Basement	6	70,800	SF	\$70,871	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	44	EA	\$6,292	
Unit Ventilation		Unit Ventilators - Steam	Entire Building	5	16	EA	\$125,840	
Ventilation		Exhaust Fan - Indoor	Boiler Room	6	1	EA	\$501	
Ventilation		Exhaust Fan - Indoor	Basement	5	1	EA	\$1,859	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	3	EA	\$1,287	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	4	1	EA	\$2,288	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	6	1	EA	\$1,716	
MECHANICAL Sub Total							\$813,870	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	5	1	EA	\$11,440	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	70,800	SF	\$23,286	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	70,800	SF	\$45,560	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	70,800	SF	\$15,187	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	70,800	SF	\$32,398	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	70,800	SF	\$38,473	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	70,800	SF	\$169,077	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	70,800	SF	\$139,717	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	70,800	SF	\$80,995	
Piping		Sanitary Piping	Entire Building	4	70,800	SF	\$67,833	
Piping		Storm Piping	Entire Building	4	70,800	SF	\$50,622	
Piping		Vent Piping	Entire Building	4	70,800	SF	\$40,498	
Pumps		Domestic Booster Pump simplex	Pump Room	5	1	EA	\$8,580	
Pumps		Sump Pump	Pump Room	4	2	EA	\$23,738	
PLUMBING Sub Total							\$747,404	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	next to main office part of 109	6	102	SF	\$289	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	2nd fl btwn 213/211- lounge	7	291	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	principals office	7	93	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	2nd fl btwn 213/211- lounge	7	291	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	across from 114	6	445	SF	\$1,260	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	rm 106	6	96	SF	\$272	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	rm 202	7	350	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	engineers office basement	7	96	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office 1st fl	7	292	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	rm 106	6	96	SF	\$453	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	principals office	7	93	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office 1st fl	7	292	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	next to main office part of 109	6	102	SF	\$146	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	2nd fl btwn 213/211- lounge	6	291	SF	\$416	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	2nd fl btwn 213/211- lounge	6	291	SF	\$416	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	engineers office basement	6	96	SF	\$137	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 202	6	350	SF	\$501	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	across from 114	6	445	SF	\$636	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd fl btwn 213/211- lounge	4	4	SF	\$26	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd fl btwn 213/211- lounge	4	4	SF	\$26	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	engineers office basement	4	2	SF	\$13	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	rm 202	6	4	SF	\$3	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	rm 106	4	1	SF	\$7	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	across from 114	4	10	SF	\$66	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	next to main office part of 109	4	1	SF	\$7	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	principals office	4	2	SF	\$13	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office 1st fl	4	4	SF	\$26	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	2nd fl btwn 213/211- lounge	6	571	SF	\$1,633	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	across from 114	6	636	SF	\$1,819	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	2nd fl btwn 213/211- lounge	6	571	SF	\$1,633	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd fl btwn 213/211- lounge	6	68	SF	\$160	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd fl btwn 213/211- lounge	6	68	SF	\$160	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	engineers office basement	7	220	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 202	6	780	SF	\$1,840	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	principals office	6	426	SF	\$1,005	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	next to main office part of 109	6	450	SF	\$1,062	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 106	6	510	SF	\$1,203	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office 1st fl	6	780	SF	\$1,840	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	6	268	EA	\$9,865	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor	7	1	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	7	2	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	6	1	EA	\$114,400	
Corridor		Stair Handrails	stairs at exits 2 & 8	6	154	LF	\$0	
Corridor		Stair Handrails	stairs in middle of corridor	6	40	LF	\$0	
Corridor		Stair Handrails	stairs at exit 3	6	68	LF	\$0	
Corridor		Stairs - Terrazzo	stairs at exit 3	7	76	LF	\$0	
Corridor		Stairs - Terrazzo	stairs at exits 2 & 8	7	164	LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridor		Stairs - Terrazzo	1st Floor	7	25	LF	\$0	
Corridor		Stairs - Terrazzo	stairs in middle of corridor	7	63	LF	\$0	
Corridor		Student Lockers	3rd Floor	5	158	EA	\$28,243	
Corridor		Student Lockers	1st Floor	6	146	EA	\$20,878	
Corridor		Student Lockers	2nd Floor	6	142	EA	\$20,306	
Doors		Interior Steel Doors incl hw	Entire Building	7	15	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	5	39	EA	\$18,404	
Doors		Interior Steel Doors incl hw	Entire Building	6	5	EA	\$1,416	
Doors		Interior Wood Doors incl hw	Entire Building	4	34	EA	\$109,103	
Doors		Interior Wood Doors incl hw	Entire Building	6	42	EA	\$11,892	
Doors		Interior Wood Doors incl hw	Entire Building	7	4	EA	\$0	
Doors		Transom Window	Entire Building	6	440	SF	\$8,180	
Drinking Fountains		Double Fountain	Entire Building	7	1	EA	\$0	
Drinking Fountains		Double Fountain	Entire Building	6	1	EA	\$658	
Drinking Fountains		Double Fountain	Entire Building	5	1	EA	\$3,289	
Drinking Fountains		Single Fountain	Entire Building	6	2	EA	\$772	
Drinking Fountains		Single Fountain	Entire Building	7	5	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	1st Floor	6	2,450	SF	\$20,951	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1st Floor	6	2,450	SF	\$18,498	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Lay-In	1st Floor	4	4	SF	\$19	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	1st Floor	4	16	EA	\$14,643	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	1st Floor	7	1,320	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	1st Floor	7	980	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Plaster/Drywall	1st Floor	6	625	SF	\$2,360	
Kitchen	Cooking Kitchen	Flooring - Tile Quarry	1st Floor	7	625	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	1st Floor	4	17	SF	\$112	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Kitchen	Cooking Kitchen	Wall - Concrete Block	1st Floor	6	575	SF	\$1,645	
Kitchen	Cooking Kitchen	Wall - Structural Glazed Tile	1st Floor	7	832	SF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in principals office			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in basement in engineers office			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	btwn 213/211			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor womens south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in office in 109			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor boys north			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor womens north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys north			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	111			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in office across from 114			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor girls north			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor unisex			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	kitchen staff locker and toilet room			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor womens south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in basement in engineers office			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor womens north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	kitchen staff locker and toilet room			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in office across from 114			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys south			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	111			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in office in 109			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in principals office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	btwn 213/211			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	btwn 213/211			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in office in 109			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor womens north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor womens south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	kitchen staff locker and toilet room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in office across from 114			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in principals office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor boys north			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	111			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Showers	2nd floor unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in basement in engineers office			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	1st Floor	6	1,435	SF	\$3,078	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	1,435	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	1st Floor	4	20	SF	\$93	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	14	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	6	1,154	SF	\$3,300	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	7	6,400	SF	\$0	
Mechanical/Service Rooms		Storage Room	111	7	50	SF	\$0	
Mechanical/Service Rooms		Storage Room	2nd floor unisex staff restroom	6	100	SF	\$472	
Mechanical/Service Rooms		Storage Room	in main office	6	86	SF	\$406	
Mechanical/Service Rooms		Storage Room	NEXT TO MAIN OFFICE	6	108	SF	\$510	
Mechanical/Service Rooms		Storage Room	across from 114	6	228	SF	\$1,076	
Mechanical/Service Rooms		Storage Room	105	6	96	SF	\$453	
Mechanical/Service Rooms		Storage Room	kitchen	7	80	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor unisex	7	120	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	btwn 213/211	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys south	7	260	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in basement in engineers office	7	28	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys north	7	280	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor womens north	6	40	SF	\$309	
Staff Restroom	Early Childhood Student Restroom	Accessories	111	6	27	SF	\$208	
Staff Restroom	Staff Restroom	Accessories	1st floor womens south	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys south	7	260	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys north	7	280	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls south	7	270	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	kitchen staff locker and toilet room	7	88	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor boys north	7	260	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor girls north	7	260	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in office across from 114	6	24	SF	\$185	
Staff Restroom	Staff Restroom	Accessories	in office in 109			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in principals office	7	23	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls south	7	420	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys north	5	260	SF	\$1,472	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys south	6	260	SF	\$736	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor womens north	5	40	SF	\$227	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	111	6	27	SF	\$76	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys south	6	260	SF	\$736	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor womens south	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls south	6	420	SF	\$1,189	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor unisex	7	120	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys north	5	280	SF	\$1,586	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	btwn 213/211	6	64	SF	\$181	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys north	6	280	SF	\$793	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	kitchen staff locker and toilet room	5	88	SF	\$498	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls north	5	260	SF	\$1,472	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in office across from 114	7	24	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in office in 109	6	25	SF	\$71	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in principals office	6	23	SF	\$65	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls south	6	270	SF	\$764	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys north	6	1	EA	\$300	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	111			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	btwn 213/211			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys south	6	1	EA	\$300	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Floor Drain	in basement in engineers office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor boys north	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys south	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor unisex			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in office in 109			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor girls north	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	in principals office			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	kitchen staff locker and toilet room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls south	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys north	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st floor womens north			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor womens south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls south	6	2	EA	\$601	
Staff Restroom	Staff Restroom	Floor Drain	in office across from 114			EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor womens south	6	40	SF	\$102	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in office in 109	6	25	SF	\$64	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor girls north	6	260	SF	\$662	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor boys north	6	260	SF	\$662	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls south	6	270	SF	\$687	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys north	6	280	SF	\$713	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys south	6	260	SF	\$662	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls south	6	420	SF	\$1,069	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor unisex	6	120	SF	\$305	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys south	6	260	SF	\$662	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in principals office	7	23	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys north	6	280	SF	\$713	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	kitchen staff locker and toilet room	7	88	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	btwn 213/211	6	64	SF	\$92	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in basement in engineers office	6	28	SF	\$40	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	111	6	27	SF	\$39	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor womens north	6	40	SF	\$57	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in office across from 114	7	24	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor girls north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in basement in engineers office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys north			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor unisex	5	1	EA	\$716	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor womens south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor womens north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	btwn 213/211			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys north			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	111			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in office across from 114			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in office in 109			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in principals office			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	kitchen staff locker and toilet room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys north			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor unisex	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls north	5	4	EA	\$7,436	
Staff Restroom	Staff Restroom	Lavatory	in office across from 114	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	in office in 109			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	in principals office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	kitchen staff locker and toilet room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	btwn 213/211	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor boys north	5	3	EA	\$5,577	
Staff Restroom	Staff Restroom	Lavatory	in basement in engineers office	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys north	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor womens south	6	1	EA	\$372	
Staff Restroom	Early Childhood Student Restroom	Lavatory	111			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor womens north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys north	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls south	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys south	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor boys north	4	3	SF	\$11	
Staff Restroom	Staff Restroom	Lighting - Lay-In	in office across from 114	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor girls north	4	3	SF	\$11	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor boys north	4	3	SF	\$11	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor womens north	4	1	SF	\$4	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	111	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	btwn 213/211	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd floor unisex	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in principals office	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys south	4	5	SF	\$21	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in basement in engineers office	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in office in 109	4	1	SF	\$4	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor womens south	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls south	4	5	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys south	4	5	SF	\$21	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	kitchen staff locker and toilet room	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls south	4	5	SF	\$21	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	in office across from 114	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	in principals office	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	btwn 213/211	4	2	EA	\$644	
Staff Restroom	Staff Restroom	Partitions	in office across from 114			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	111			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in principals office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor girls north	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor womens south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in office in 109			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	btwn 213/211	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls south	7	10	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls south	4	8	EA	\$14,346	
Staff Restroom	Staff Restroom	Partitions	2nd floor unisex	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in basement in engineers office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys south	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	kitchen staff locker and toilet room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor womens north	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Urinals	in basement in engineers office			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	kitchen staff locker and toilet room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys north	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in office across from 114			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in office in 109			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in principals office			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor womens south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys north	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	111			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys south	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys south	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	btwn 213/211			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor womens north			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	btwn 213/211	6	256	SF	\$732	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in office across from 114	6	130	SF	\$372	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	111	6	150	SF	\$429	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st floor womens north	6	190	SF	\$543	
Staff Restroom	Staff Restroom	Wall - Concrete Block	kitchen staff locker and toilet room	5	506	SF	\$3,821	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor girls south	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor womens south	6	225	SF	\$531	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor boys south	6	150	SF	\$354	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in office in 109	6	165	SF	\$389	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor girls south	6	150	SF	\$354	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd floor unisex	6	500	SF	\$1,180	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in basement in engineers office	7	28	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor boys south	6	150	SF	\$354	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in principals office	6	220	SF	\$519	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys north	6	540	SF	\$3,861	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys north	6	540	SF	\$3,861	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor boys north	6	507	SF	\$1,291	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor girls south	7	700	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor boys south	6	390	SF	\$993	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor boys south	6	390	SF	\$993	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor girls north	6	507	SF	\$1,291	
Staff Restroom	Staff Restroom	Water Closet	1st floor womens south	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	111	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor womens north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls south	7	8	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in principals office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	kitchen staff locker and toilet room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls south	7	10	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor unisex	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in basement in engineers office	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	btwn 213/211	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in office in 109	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls north	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in office across from 114	6	1	EA	\$372	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	1st Floor	6	2,450	SF	\$20,951	
Theater	Auditorium - Dedicated	Flooring - Concrete	1st Floor	7	2,450	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	4	24	SF	\$180	
Theater	Auditorium - Dedicated	Lighting - Wall Mounted	1st Floor	7	10	EA	\$0	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	1st Floor	6	2,960	SF	\$25,397	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
INTERIOR Sub Total							\$570,065	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	12	LF	\$429	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	43	LF	\$1,537	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	12	LF	\$429	
Casework	Classroom	Casework		6	26	LF	\$930	
Casework	Classroom	Casework		6	12	LF	\$429	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	12	LF	\$429	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	40	LF	\$1,430	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	2	LF	\$72	
Casework	Classroom	Casework		6	2	LF	\$72	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	5	LF	\$179	
Ceiling	Classroom	Ceiling		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	699	SF	\$1,979	
Ceiling	Classroom	Plaster/Drywall		7	899	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,030	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		6	699	SF	\$1,979	
Ceiling	Classroom	Plaster/Drywall		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		5	699	SF	\$3,958	
Ceiling	Classroom	Plaster/Drywall		7	740	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	690	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	31	LF	\$3,768	
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF		
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	28	LF	\$3,403	
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	46	LF	\$5,591	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	46	LF	\$5,591	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	33	LF	\$4,011	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Corridors	Corridors	Concrete Block	1st Floor	7	275	SF	\$0	
Corridors	Corridors	Concrete Block	stairs in middle of corridor	7	576	SF	\$0	
Corridors	Corridors	Concrete Block	stairs at exit 3	7	580	SF	\$0	
Corridors	Corridors	Concrete Block	3rd Floor	7	1,870	SF	\$0	
Corridors	Corridors	Concrete Block	3rd Floor	7	202	SF	\$0	
Corridors	Corridors	Concrete Block	2nd Floor	7	128	SF	\$0	
Corridors	Corridors	Concrete Block	2nd Floor	7	1,870	SF	\$0	
Corridors	Corridors	Lay-In	3rd Floor	4	566	EA	\$3,440	
Corridors	Corridors	Lay-In	2nd Floor	4	486	EA	\$2,954	
Corridors	Corridors	Lay-In	1st Floor	4	890	EA	\$5,409	
Corridors	Corridors	Pendant/Surface	2nd Floor	4	2,350	EA	\$22,851	
Corridors	Corridors	Pendant/Surface	1st Floor	4	3,361	EA	\$32,682	
Corridors	Corridors	Pendant/Surface	stairs at exits 2 & 8	4	1,256	EA	\$12,213	
Corridors	Corridors	Pendant/Surface	stairs at exit 3	4	478	EA	\$4,648	
Corridors	Corridors	Pendant/Surface	3rd Floor	4	2,330	EA	\$22,657	
Corridors	Corridors	Pendant/Surface	stairs in middle of corridor	4	540	EA	\$5,251	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	2,380	SF	\$5,616	
Corridors	Corridors	Plaster/Drywall	3rd Floor	6	1,530	SF	\$3,610	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	3,320	SF	\$7,834	
Corridors	Corridors	Plaster/Drywall	stairs at exits 2 & 8	6	2,764	SF	\$6,522	
Corridors	Corridors	Structural Glazed Tile	1st Floor	7	1,581	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	stairs at exit 3	7	870	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	stairs at exits 2 & 8	7	2,635	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	3rd Floor	7	445	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor	7	3,300	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	stairs in middle of corridor	7	864	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2nd Floor	7	390	SF	\$0	
Corridors	Corridors	Terrazzo	stairs in middle of corridor	7	540	SF	\$0	
Corridors	Corridors	Terrazzo	stairs at exit 3	7	478	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	7	2,896	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Wood		6	690	SF	\$5,210	
Floor	Classroom	Wood		5	690	SF	\$9,768	
Floor	Classroom	Wood		5	690	SF	\$9,768	
Floor	Classroom	Wood		5	690	SF	\$9,768	
Floor	Classroom	Wood		5	690	SF	\$9,768	
Floor	Classroom	Wood		5	690	SF	\$9,768	
GYM_WALL	Standard Dedicated Gymnasium	Gymnasia Walls	1st Floor	6	470	SF	\$4,033	
Lighting	Classroom	Lighting		6	18	EA	\$1,673	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		5	14	EA	\$2,002	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		4	15	EA	\$5,899	
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		4	16	EA	\$6,292	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Marker Board	Classroom	Marker Board		6	30	LF	\$858	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		6	20	LF	\$572	
Marker Board	Classroom	Marker Board		6	24	LF	\$686	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		6	20	LF	\$572	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		6	26	LF	\$744	
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		6	26	LF	\$744	
Marker Board	Classroom	Marker Board		6	28	LF	\$801	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	in basement in engineers office		28	SF	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2nd floor boys north	4	3	EA	\$965	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd floor girls south	6	740	SF	\$1,884	
THEATER_WALL	Auditorium - Dedicated	Auditorium Walls	1st Floor	7	414	SF	\$0	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		7	880	SF	\$0	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Concrete Block		6	792	SF	\$2,265	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	
Wall	Classroom	Plaster/Drywall		6	1,278	SF	\$3,015	
Wall	Classroom	Plaster/Drywall		6	1,030	SF	\$2,430	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ROOM Sub Total							\$698,770	
Building Main Sub Total							\$4,653,323	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Athletic		Baseball - Natural	Entire Building	4	25,970	SF	\$167,117	
Civil/Drainage		Catch Basin	Entire Building	7	7	EA	\$0	
Civil/Drainage		Site Manhole	Entire Building	7	7	EA	\$0	
Fencing		Chain Link	Entire Building	6	908	LF	\$13,023	
Fencing		Chain Link	parking lot	5	80	LF	\$2,860	
Fencing		Iron and Concrete Post	Entire Building	4	676	LF	\$116,002	
Fencing		Ornamental Iron	Entire Building	7	554	LF	\$0	
Landscape		Asphalt Play Area/Hardscape	Entire Building	6	12,800	SF	\$10,982	
Landscape		Grass	Entire Building	7	13,825	SF	\$0	
Landscape		Hardscape - Concrete	Entire Building	6	3,955	SF	\$7,465	
Landscape		Hardscape - Concrete	Entire Building	6	3,658	SF	\$6,905	
Landscape		Parkway trees	Entire Building	7	18	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Building	7	8,925	SF	\$0	
Landscape		Retaining Wall - Concrete	boiler room entrance	5	72	SF	\$5,606	
Parking Lot		Asphalt	Entire Building	6	13,514	SF	\$11,595	
Parking Lot		Concrete	Entire Building	4	4,764	SF	\$89,925	
Parking Lot		Trash Compactor	Entire Building	7	1	EA	\$0	
Parking Lot		Trash Enclosure	Entire Building	7	1,260	SF	\$0	
Playground		Playground Equipment - Combo 3-12	Entire Building	6	1	EA	\$0	
Playground		Playground Surfacing - Square Rubber Mats	Entire Building	6	3,500	SF	\$7,508	
Sidewalks		Internal Walks	Entire Building	4	10	LF	\$944	
Sidewalks		Internal Walks	Entire Building	7	80	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Building	4	500	SF	\$9,438	
Sidewalks		Perimeter Sidewalks	Entire Building	6	11,233	SF	\$21,203	
Signage		Marquee - Building Mounted Back Lighted	Entire Building	7	1	EA	\$0	
SITE Sub Total							\$470,574	
SITE Sub Total							\$470,574	

Building: SITE

Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Total Campus Need ^{2 3}							\$5,123,896	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
100	690			4	40	108	108		N	N	Y	Classroom		
101	690			4	40	108	108		N	N	Y	Classroom		
103	899		9	18	40	108	90		N	N	Y	Classroom		
109	740	1		10	40	126	63		N	N	Y	Classroom		
110	690	1	3	8	40	90	36	2	N	N	Y	Classroom		
111	1030	1		10	40	162	81		N	N	Y	Classroom		
112	699	1		4	40	99	45	1	N	N	Y	Classroom		
114	699	1		4	40	99	45	1	N	N	Y	Classroom		
200	690			4	40	108	108		N	N	Y	Classroom		
201	690		40	80	40	90	90	2	N	N	Y	Classroom		
203	690		40	80	40	90	90	2	N	N	Y	Classroom		
205	690			28	40	90	90		N	N	Y	Classroom		
207	690			4	40	108	108		N	N	Y	Classroom		
209	690			4	40	108	108		N	N	Y	Classroom		
210	690			4	40	108	108		N	N	Y	Classroom		
211	699			4	40	108	54		N	N	Y	Classroom		
212	699			4	40	108	54		N	N	Y	Classroom		
213	699			4	40	108	54		N	N	Y	Classroom		
214	699			4	40	108	54		N	N	Y	Classroom		
300	690			4	40	108	108		N	N	Y	Classroom		
301	690			6	40	108	108		N	N	Y	Classroom		
302	690			4	40	108	108		N	N	Y	Classroom		
303	690			4	40	108	108		N	N	Y	Classroom		
304	690			4	40	108	108		N	N	Y	Classroom		
305	690			6	40	110	46		N	N	Y	Classroom		
306	690			4	40	103	96	1	N	N	Y	Classroom		
307	690			4	40	108	108		N	Y	Y	Classroom		
308	690			4	40	108	108		N	N	Y	Classroom		
309	690			4	40	108	108		N	N	Y	Classroom		
310	690			4	40	108	108		N	N	Y	Classroom		
311	699			4	40	108	54		N	N	Y	Classroom		
312	699			4	40	108	54		N	N	Y	Classroom		
313	699			4	40	108	54		N	N	Y	Classroom		
314	699			4	40	108	54		N	N	Y	Classroom		
Other	270								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls south
Other	280								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys north

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	120								N	N	N	Restroom	Staff Restroom	2nd floor unisex
Other	40								N	N	N	Restroom	Staff Restroom	1st floor womens north
Other	40								N	N	N	Restroom	Staff Restroom	1st floor womens south
Other	260								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys south
Other	350			4					N	N	Y	Administrative Suites/Offices		rm 202
Other	540								N	N	N	Corridors		stairs in middle of corridor
Other	27								N	N	N	Restroom	Early Childhood Student Restroom	111
Other	478								N	N	N	Corridors		stairs at exit 3
Other	420								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls south
Other	292			14					N	N	Y	Administrative Suites/Offices		Main Office 1st fl
Other	1435								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	96			4					N	N	Y	Administrative Suites/Offices		rm 106
Other	24								N	N	N	Restroom	Staff Restroom	in office across from 114
Other	445			10					N	N	Y	Administrative Suites/Offices		across from 114
Other	260								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys south
Other	2450								N	N	N	Auditorium & Theater	Auditorium - Dedicated	1st Floor
Other	25								N	N	N	Restroom	Staff Restroom	in office in 109
Other	102								N	N	N	Administrative Suites/Offices		next to main office part of 109
Other	64								N	N	N	Restroom	Staff Restroom	btwn 213/211
Other	4582								N	N	N	Corridors		1st Floor
Other	260								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor girls north
Other	93			4					N	N	Y	Administrative Suites/Offices		principals office
Other	280								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys north
Other	2836								N	N	N	Corridors		2nd Floor
Other	291			6					N	N	Y	Administrative Suites/Offices		2nd fl btwn 213/211- lounge
Other	291			6					N	N	Y	Administrative Suites/Offices		2nd fl btwn 213/211- lounge
Other	2896								N	N	N	Corridors		3rd Floor
Other	1256								N	N	N	Corridors		stairs at exits 2 & 8
Other	2450								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	28								N	N	N	Restroom	Staff Restroom	in basement in engineers office
Other	625								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	96			8					N	N	Y	Administrative Suites/Offices		engineers office basement
Other	88								N	N	N	Restroom	Staff Restroom	kitchen staff locker and toilet room
Other	260								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor boys north
Other	23								N	N	N	Restroom	Staff Restroom	in principals office