

## Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at [http://www.cps.edu/About\\_CPS/Policies\\_and\\_guidelines/Pages/facilitystandards.aspx](http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx).

## Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.<sup>1</sup>

## Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

## Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	N & S entrances	7	862	SF	\$0	
Chimney		Brick Chimney - Concrete/ Mortar Liner	Boiler Room	7	85	LF	\$0	
Cornice		Cornice - Masonry Projecting/Limestone	Entire Building	6	542	LF	\$16,625	
Cornice		Cornice - Metal Projecting	Entire Building	6	615	LF	\$55,142	paint & some missing pieces
Doors		Exterior Steel Door	Entire Building	6	16	EA	\$5,285	
Doors		Transom Lite	Entire Building	7	64	EA	\$0	
Entrance		Concrete Exterior Stairs	Entire Building	7	120	LF	\$0	
Entrance		Concrete Ramp	Entire Building	7	50	LF	\$0	
Entrance		Entrance Controls - Audio and Video	Northwest Entrance 7	7	1	EA	\$0	
Entrance		Power Door Operator and Controls	Northwest Entrance 7	7	1	EA	\$0	
Entrance		Ramp Handrails	Entire Building	6	100	LF	\$0	
Entrance		Stair Handrails	Entire Building	6	80	LF	\$0	
Foundation		Masonry Foundation	Boiler Room	6	30	SF	\$2,973	efflorescence
Foundation		Masonry Foundation	Entire Building	7	469	SF	\$0	

**Building: Main**  
**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Parapet or Roof Mounted	Roofs	6	9	EA	\$4,505	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	8	EA	\$1,716	
Lintels		Lintels - Steel	Entire Building	6	803	LF	\$30,315	
Parapet		Coping - Metal	low E roof	7	69	LF	\$0	
Parapet		Coping - Stone	Roofs	6	793	LF	\$0	
Parapet		Parapet < 16" Height	upper roof	7	40	LF	\$0	
Parapet		Parapet > 30" Height	Main Roof	7	80	LF	\$0	
Parapet		Parapet 16" to 30" Height	low E roof	7	99	LF	\$0	
Parapet		Parapet 16" to 30" Height	Main Roofs	7	643	LF	\$0	
Roof System		Exterior Downspouts	Roofs	6	66	LF	\$1,227	
Roof System		Interior Downspouts	Roofs	6	408	LF	\$0	
Roof System		Metal Roof	auditorium roof	6	4,012	SF	\$30,292	
Roof System		Modified Bitumen Roof	Roofs	7	25,698	SF	\$0	
Roof System		Roof Structure: Steel with Clay Tile Arch	Roofs	7	29,042	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	61,724	SF	\$0	
Walls		Brick	Entire Building	6	33,756	SF	\$223,012	mortar
Walls		Prefabricated Metal Panel Wall	auditorium roof	6	756	SF	\$6,422	
Walls		Stone - Cast	Entire Building	6	2,994	SF	\$42,814	clean/seal joints
Windows		Curtain wall - Insulated panel	Entire Building	7	756	SF	\$0	
Windows		Skylite - Glass Single-Pane	Main Roof	7	191	SF	\$0	
Windows		Window - Guards wire guard	1st Floor	6	1,820	SF	\$0	
Windows		Windows - Sash Lexan	Entire Building	4	6,615	SF	\$1,142,512	approximately 80% have bad balances; no window stops
<b>EXTERIOR Sub Total</b>							<b>\$1,562,840</b>	

**Building: Main**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	4	1	EA	\$8,866	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	11,133	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	6,067	SF	\$3,210	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	4	4	EA	\$2,162	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	3	17	EA	\$15,802	Exit signs are more than 20 years old and they are not provided with battery backup and the appearance is poor
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	4	8	EA	\$7,436	

**Building: Main**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Independent Electrical Service for emergency power	Electrical Room	7	1	EA	\$0	
Emergency System		Security System - Intrusion detection	Mechanical Room	6	147,016	SF	\$136,651	
Main Service		Main Electrical service - Live Front - 1200 A 120/208/3PH	Electrical Room	4	1	EA	\$113,256	
Power Distribution		Lighting and power panels	Entire Building	7	3	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	4	8	EA	\$43,472	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	4	1	EA	\$12,155	
Power Distribution		Main distribution panels less than 400 amp	Electrical Room	4	1	EA	\$6,578	
<b>ELECTRICAL Sub Total</b>							<b>\$349,588</b>	

**Building: Main**  
**Category: FIRE PROTECTION**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Electrical Room	7	61,724	SF	\$0	
<b>FIRE PROTECTION Sub Total</b>							<b>\$0</b>	

**Building: Main**  
**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	6	12	EA	\$2,574	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	4	1	EA	\$26,169	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Mechanical Room	4	2	EA	\$185,900	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Mechanical Room	4	2	EA	\$65,780	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Roof	4	200	LF	\$529,100	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 8,001 to 15,000 cfm	Mechanical Room	4	1	EA	\$32,890	
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries- Steam 8,001 to 15,000 cfm	Mechanical Room	4	1	EA	\$14,300	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	5	2	EA	\$125,840	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	5	2	EA	\$22,880	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	6	1	EA	\$2,145	
Boiler Systems		Combustion Dampers	Boiler Room	4	2	EA	\$11,154	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	4	1	EA	\$31,460	
Heating Devices		Radiators - Steam	1st Floor	4	2	EA	\$2,803	

**Building: Main**  
**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices		Unit Heater - Electric	Entire Building	6	12	EA	\$17,160	
Heating Devices		Unit Heater - Gas	Boiler Room	6	1	EA	\$2,145	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Mechanical Room	6	3	EA	\$2,145	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	5	500	LF	\$16,266	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	500	LF	\$24,739	
Temperature Control		Pneumatic System	Mechanical Room	6	61,724	SF	\$22,066	
Temperature Control		Thermostats - Pneumatic	Mechanical Room	6	36	EA	\$5,148	
Temperature Control		Zone Dampers	Mechanical Room	4	36	EA	\$30,373	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	3	EA	\$686	
<b>MECHANICAL Sub Total</b>							<b>\$1,173,724</b>	

**Building: Main**  
**Category: PLUMBING**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	4	1	EA	\$22,880	
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	1	EA	\$4,147	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	61,724	SF	\$20,301	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	61,724	SF	\$39,719	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	61,724	SF	\$13,240	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	61,724	SF	\$28,245	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	61,724	SF	\$33,541	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	61,724	SF	\$147,403	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	61,724	SF	\$121,806	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	61,724	SF	\$70,612	
Piping		Sanitary Piping	Entire Building	5	61,724	SF	\$37,954	
Piping		Storm Piping	Entire Building	5	61,724	SF	\$29,128	
Piping		Vent Piping	Entire Building	5	61,724	SF	\$22,066	
Pumps		Domestic Booster Pump simplex	Boiler Room	6	1	EA	\$1,716	
Pumps		Sump Pump	Boiler Room	6	1	EA	\$1,359	
<b>PLUMBING Sub Total</b>							<b>\$594,117</b>	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 106	6	470	SF	\$1,008	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 211	6	415	SF	\$890	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 99	6	490	SF	\$1,051	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Gym Teacher's Office	7	124	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Engineer's Office	7	179	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Room 99	7	210	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Engineer's Office	7	179	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 106	7	470	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 99	6	280	SF	\$400	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 211	6	415	SF	\$593	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Gym Teacher's Office	6	124	SF	\$177	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 106	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 99	7	9	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 211	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Engineer's Office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Gym Teacher's Office	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Engineer's Office	7	650	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Gym Teacher's Office	7	468	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 99	6	730	SF	\$1,722	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 106	6	700	SF	\$1,652	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 211	6	930	SF	\$2,194	
Auditorium - Dedicated		Main Floor Seating	1st Floor	7	425	EA	\$0	
Auditorium - Dedicated		Stage Platform	1st Floor	7	436	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	7	EA	\$0	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Wood Doors incl hw	Entire Building	5	40	EA	\$18,876	
Doors		Interior Wood Doors incl hw	Entire Building	6	46	EA	\$13,024	
Doors		Side-lite	Entire Building	7	14	SF	\$0	
Doors		Transom Window	Entire Building	7	17	SF	\$0	
Doors		Transom Window	Entire Building	6	20	SF	\$372	
Drinking Fountains	Corridors	Double Fountain	1st Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Double Fountain	3rd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Double Fountain	2nd Floor	7	2	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Lay-In	1st Floor	7	3,033	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Plaster/Drywall	1st Floor	6	3,033	SF	\$25,936	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Wood	1st Floor	7	6,067	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Pendant/Surface	1st Floor	7	38	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	1st Floor	6	2	EA	\$18,876	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Concrete Block	1st Floor	7	3,164	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Concrete Block	1st Floor	7	3,164	SF	\$0	
Mechanical/Service Rooms		Boiler Room	1st Floor	7	1,516	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	3	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	In the Boiler Room Area	7	168	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	265	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Staff Lounge in Boiler Room	7	195	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	In the Boiler Room Area	7	167	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	779	SF	\$0	
Mechanical/Service Rooms		Storage Room	Yard Storage	7	220	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st Floor	7	38	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boy's Room	6	467	SF	\$3,606	
Staff Restroom	Staff Restroom	Accessories	In Boiler Room Area	7	16	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boy's Room	6	467	SF	\$3,606	
Staff Restroom	Staff Restroom	Accessories	1st Floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd Floor	7	50	SF	\$0	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 105	6	46	SF	\$355	
Staff Restroom	Staff Restroom	Accessories	In Room 99	6	37	SF	\$286	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Boy's Room	6	467	SF	\$3,606	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Boy's Room	6	467	SF	\$3,606	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Boy's Room	6	467	SF	\$1,322	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	In Room 105	6	46	SF	\$130	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st Floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd Floor	7	50	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	In Boiler Room Area	6	16	SF	\$45	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Boy's Room	6	467	SF	\$1,322	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd Floor Boy's Room	6	467	SF	\$1,322	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Boy's Room	6	467	SF	\$1,322	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	In Room 99	6	37	SF	\$105	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Girl's Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	In Boiler Room Area	6	16	SF	\$76	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Boy's Room	7	467	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor Boy's Room	7	467	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Boy's Room	7	467	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Girl's Room	7	468	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor	7	50	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor	7	50	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Boy's Room	7	467	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	In Room 99	6	37	SF	\$53	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	In Room 105	6	46	SF	\$66	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Girl's Room	7	2	EA	\$0	



**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 105	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	In Room 99	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor Girl's Room	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Boy's Room	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Boy's Room	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd Floor Boy's Room	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor Boy's Room	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	In Room 99	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd Floor Girl's Room	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Girl's Room	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd Floor	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st Floor	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Wall Mounted	In Room 105	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	In Boiler Room Area	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Girl's Room	7	6	EA	\$0	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boy's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd Floor Boy's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boy's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Boy's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor Girl's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd Floor Boy's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor Boy's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor Boy's Room	7	532	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	In Boiler Room Area	6	223	SF	\$638	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd Floor Girl's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	3rd Floor Boy's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	3rd Floor Girl's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd Floor Boy's Room	7	532	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st Floor	7	352	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd Floor	7	352	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor	7	352	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Girl's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor Girl's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd Floor Girl's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Boy's Room	7	532	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	In Room 105	6	340	SF	\$802	

**Building: Main**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor Boy's Room	7	532	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Boy's Room	7	532	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	In Room 99	6	340	SF	\$802	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Girl's Room	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Girl's Room	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Girl's Room	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In Boiler Room Area	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In Room 99	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 105	7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	

**INTERIOR Sub Total \$110,553**

**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	

**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	50	LF	\$1,788	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	50	LF	\$1,788	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	915	SF	\$1,963	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	415	SF	\$890	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	915	SF	\$1,963	
Ceiling	Classroom	Lay-In/Drop		7	533	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	533	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	415	SF	\$890	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	

**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	415	SF	\$890	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Ceiling	Classroom	Lay-In/Drop		6	815	SF	\$1,748	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
CLASSROOM	Classroom	Laptop Charging Station		7	1	EA	\$0	





**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	



**Building: Main**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	920	SF	\$2,171	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	930	SF	\$2,194	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	930	SF	\$2,194	
Wall	Classroom	Plaster/Drywall		6	930	SF	\$2,194	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
Wall	Classroom	Plaster/Drywall		6	920	SF	\$2,171	
Wall	Classroom	Plaster/Drywall		6	1,220	SF	\$2,879	
<b>ROOM Sub Total</b>							<b>\$435,493</b>	
<b>Building Main Sub Total</b>							<b>\$4,226,314</b>	

**Building: Addition 2**  
**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Metal Flue	Roof	7	60	LF	\$0	
Cornice		Cornice - Cast Stone	Entire Building	6	964	LF	\$51,860	
Doors		Exterior Steel Door	Entire Building	6	7	EA	\$2,312	
Doors		Side Lite	West Entrances	7	2	EA	\$0	
Doors		Store Front Door	Entire Building	7	12	EA	\$0	
Doors		Transom Lite	Entire Building	7	12	EA	\$0	
Entrance		Entrance Controls - Audio	South Entrance 1	7	1	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	628	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Building	6	20	EA	\$10,010	

**Building: Addition 2**  
**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	7	EA	\$1,502	
Lintels		Lintels - Steel	Entire Building	7	906	LF	\$0	
Parapet		Coping - Stone	Roofs	6	888	LF	\$0	
Parapet		Parapet > 30" Height	Main Roof	7	552	LF	\$0	
Parapet		Parapet 16" to 30" Height	Penthouse	7	336	LF	\$0	
Roof System		Interior Downspouts	Roofs	6	525	LF	\$0	
Roof System		Modified Bitumen Roof	Roofs	6	21,444	SF	\$151,791	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roofs	7	21,444	SF	\$0	
Superstructure		Steel	Entire Building	7	70,296	SF	\$0	
Walls		Brick	Entire Building	7	33,896	SF	\$0	
Walls		Concrete Block	chiller walls	7	1,168	SF	\$0	
Walls		Stone - Cast	Entire Building	6	6,834	SF	\$97,726	clean
Windows		Curtain wall - Louver	Penthouse	7	441	SF	\$0	
Windows		Window - Guards perforated	1st Floor	7	2,294	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	7,426	SF	\$0	
<b>EXTERIOR Sub Total</b>							<b>\$315,201</b>	

**Building: Addition 2**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room - Outside	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	20,380	SF	\$8,743	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	16	EA	\$1,716	
Emergency System		Emergency Battery Packs - Toilets	Entire Building	6	6	EA	\$644	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	29	EA	\$6,760	
Emergency System		Independent Electrical Service for emergency power	Electrical Room - Outside	7	1	EA	\$0	
Emergency System		Public Announcement System	1st Floor	6	147,016	SF	\$88,298	
Emergency System		Security System - CCTV	2nd Floor	7	147,016	SF	\$0	
Main Service		Main Electrical service 2000 A 277/480/3PH	Electrical Room - Outside	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	7	11	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room - Outside	7	2	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room - Outside	7	4	EA	\$0	
<b>ELECTRICAL Sub Total</b>							<b>\$106,160</b>	

**Building: Addition 2**

**Category: FIRE**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

**Building: Addition 2**

**Category: FIRE PROTECTION**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Electrical Room	7	70,296	SF	\$0	
Fire Alarm		Fire Alarm System	Electrical Room	7	70,296	SF	\$0	
Fire Alarm		Fire Pump Controller	Pump Room - Outside	7	1	EA	\$0	
Pump Room Assembly		Fire Pump 25-50hp	Pump Room - Outside	7	1	EA	\$0	
Pump Room Assembly		Jockey Pump	Pump Room - Outside	7	1	EA	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	7	70,296	SF	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	7	70,296	SF	\$0	

**FIRE PROTECTION Sub Total \$0**

**Building: Addition 2**

**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 201 to 300 tons	Roof	6	1	EA	\$60,060	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 20,001 to 30,000 cfm	Penthouse	6	1	EA	\$12,155	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water above 30,000 cfm	Penthouse	6	1	EA	\$21,450	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Exterior Facade	7	1	EA	\$0	
Air Handling Systems		Fan Power Box With Hot Water Coil	Entire Building	6	58	EA	\$22,394	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	7	200	LF	\$0	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	Penthouse	6	1	EA	\$2,431	
Air Handling Systems		Return Fans - Indoor greater than 20,000 CFM	Penthouse	6	1	EA	\$3,289	
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	Entire Building	6	13	EA	\$4,276	
Boiler Systems		Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler 1,001MBH-2,000 MBH	Penthouse	5	4	EA	\$157,300	
Boiler Systems		Boiler Auxiliary Non-Condensing Hot Water Boiler 1,001MBH-2,000 MBH	Penthouse	5	4	EA	\$100,100	
Boiler Systems		Chemical Pot Feeder - Hot Water	Penthouse	6	2	EA	\$601	
Boiler Systems		Gas Boosters	Pump room - Outside	6	1	EA	\$1,301	
Boiler Systems		Glycol Feed System	Penthouse	6	2	EA	\$2,174	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	6	8	EA	\$4,004	
Heating Devices		Radiators - Hot Water	Entire Building	7	6	EA	\$0	
Heating Devices		Unit Heater - Electric	Entire Building	6	1	EA	\$1,430	

**Building: Addition 2**  
**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices		Unit Heater - Hot Water	Penthouse	6	6	EA	\$8,580	
Heating Devices		Wall Heater - Electric	Electrical Room - Outside	7	1	EA	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Copper	Penthouse	7	450	LF	\$0	
Mechanical Plumbing		Pumps - Chilled Water 21-50 HP	Penthouse	6	2	EA	\$11,440	
Mechanical Plumbing		Pumps - Hot Water 11 to 20 HP	Penthouse	6	2	EA	\$5,148	
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	Mechanical Room	6	2	EA	\$2,860	
Temperature Control		Direct Digital Control (DDC) System	Mechanical Room	6	70,296	SF	\$70,366	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	77	EA	\$11,011	
Ventilation		Exhaust Fan - Indoor	2nd Floor	6	1	EA	\$501	
Ventilation		Exhaust Fan - Indoor	Penthouse	6	1	EA	\$501	
Ventilation		Exhaust Fan - Indoor	Electrical Room - Outside	6	1	EA	\$501	
<b>MECHANICAL Sub Total</b>							<b>\$503,871</b>	

**Building: Addition 2**  
**Category: PLUMBING**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Penthouse	6	2	EA	\$8,294	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	70,296	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	70,296	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	70,296	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	70,296	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	70,296	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	70,296	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	70,296	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	70,296	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	70,296	SF	\$0	
Piping		Storm Piping	Entire Building	7	70,296	SF	\$0	
Piping		Vent Piping	Entire Building	7	70,296	SF	\$0	
Pumps		Domestic Booster Pump duplex	Pump Room - Outside	7	1	EA	\$0	
<b>PLUMBING Sub Total</b>							<b>\$8,294</b>	

**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main Office & Principal's Office	7	1,540	SF	\$0	

**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Faculty Room, 1st Floor	7	476	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office & Principal's Office	7	1,300	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Terrazzo	Main Office & Principal's Office	7	240	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Faculty Room, 1st Floor	7	476	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Faculty Room, 1st Floor	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main Office & Principal's Office	7	18	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Main Office & Principal's Office	7	1,700	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Faculty Room, 1st Floor	7	928	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office & Principal's Office	7	520	SF	\$0	
Classrooms		Work Sink	In Main Office Vault and Library Storage	7	2	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	49	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	7	73	EA	\$0	
Doors		Side-lite	Entire Building	7	160	SF	\$0	
Doors		Store Front Door	1st Floor	7	2	EA	\$0	
Drinking Fountains		Single Fountain	Rooms 111, 113, 115	7	3	EA	\$0	
Drinking Fountains		Single Fountain	In Rooms 110, 112, 114 & 116	7	4	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	2	EA	\$0	
Library	Library	Casework	Room 222	7	200	LF	\$0	
Library	Library	Flooring Carpet	Room 222	7	1,595	SF	\$0	
Library	Library	Lighting - Lay-In	Room 222	7	18	SF	\$0	
MDF/IDF		Finishes	2nd Floor next to Room 220	7	148	SF	\$0	
MDF/IDF		Ventilation and Cooling	2nd Floor next to Room 220	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	3	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Entire Building	7	75	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor Electrical Room	7	200	SF	\$0	
Mechanical/Service Rooms		Storage Room	Rooms 111, 113, 115	7	150	SF	\$0	
Mechanical/Service Rooms		Storage Room	2nd Floor next to MDF Room	7	70	SF	\$0	

**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Storage Room	In Rooms 110, 112, 114 & 116	7	200	SF	\$0	
Mechanical/Service Rooms		Storage Room	In Library 222	7	170	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st Floor Pump Room	7	100	SF	\$0	
Mechanical/Service Rooms		Storage Room	2nd Floor next to Staff Restroom	7	173	SF	\$0	
Mechanical/Service Rooms		Storage Room	3rd Floor next to Staff Restroom	7	173	SF	\$0	
Mechanical/Service Rooms		Vaults	In Main Office	7	228	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Floor	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 110	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 115	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd Floor	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 116	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 114	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 112	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor	7	42	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 113	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	In Room 111	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	In Room 110	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	In Room 115	7	36	SF	\$0	

**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	In Room 111	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd Floor	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st Floor	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd Floor	7	42	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	In Room 116	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	In Room 114	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	In Room 112	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	In Room 113	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd Floor	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 114	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 112	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 110	7	1	EA	\$0	

**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 116	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 111	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 115	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	In Room 113	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	In Room 113	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	In Room 115	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st Floor Boy's Room	7	241	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd Floor	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	3rd Floor	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st Floor	7	42	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	In Room 111	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	In Room 110	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	In Room 112	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	In Room 114	7	36	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	In Room 116	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	3rd Floor Girl's Room	7	293	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Girl's Room	7	2	EA	\$0	



**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Girl's Room	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Floor	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 110	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 112	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 114	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 116	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Girl's Room	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 111	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 113	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	In Room 115	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Girl's Room	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Room 116	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd Floor Girl's Room	7	6	SF	\$0	

**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Room 110	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Room 112	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd Floor Girl's Room	7	6	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Room 114	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st Floor Girl's Room	7	6	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd Floor	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st Floor	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd Floor	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Room 111	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Room 113	7	1	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Lay-In	In Room 115	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd Floor Boy's Room	7	6	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st Floor Boy's Room	7	6	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd Floor Boy's Room	7	6	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd Floor Boy's Room	7	3	EA	\$0	

**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor Girl's Room	7	740	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	3rd Floor	7	213	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd Floor	7	213	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd Floor Girl's Room	7	740	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor Girl's Room	7	740	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd Floor Boy's Room	7	504	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor Boy's Room	7	504	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor Boy's Room	7	504	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st Floor	7	213	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	In Room 112	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	In Room 110	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	In Room 115	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	In Room 113	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	In Room 111	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	In Room 116	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	In Room 114	7	200	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 110	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 112	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 114	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 116	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 111	7	1	EA	\$0	

**Building: Addition 2**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Boy's Room	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 113	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Girl's Room	7	6	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	In Room 115	7	1	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
<b>INTERIOR Sub Total</b>							<b>\$0</b>	

**Building: Addition 2**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	28	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	

**Building: Addition 2**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	16	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	50	LF	\$0	
Casework	Classroom	Casework		7	12	LF	\$0	
Casework	Classroom	Casework		7	16	LF	\$0	
Casework	Classroom	Casework		7	26	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	16	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	16	LF	\$0	
Casework	Classroom	Casework		7	16	LF	\$0	
Casework	Classroom	Casework		7	28	LF	\$0	
Casework	Classroom	Casework		7	16	LF	\$0	
Casework	Classroom	Casework		7	16	LF	\$0	
Casework	Classroom	Casework		7	45	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	28	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		7	10	LF	\$0	
Casework	Classroom	Casework		7	45	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	40	LF	\$0	
Ceiling	Classroom	Ceiling			377	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	450	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,172	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,172	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	450	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	925	SF	\$0	

**Building: Addition 2**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,221	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	880	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	925	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	398	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,220	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,220	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,220	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,220	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,172	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	450	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	450	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,034	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	465	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	925	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	560	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	450	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	450	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,034	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	918	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	925	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	900	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	

**Building: Addition 2**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4		LF		
CLASSROOM	Classroom	Laptop Charging Station		7	4	EA	\$0	
Corridors	Corridors	Concrete Block	Stair Tower, Entire Building	7	8,397	SF	\$0	
Corridors	Corridors	Concrete Block	2nd Floor	7	7,636	SF	\$0	
Corridors	Corridors	Concrete Block	3rd Floor	7	7,636	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor	7	7,636	SF	\$0	
Corridors	Corridors	Drop/Lay-In	Stair Tower, Entire Building	7	3,439	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	5,647	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	5,647	SF	\$0	
Corridors	Corridors	Drop/Lay-In	3rd Floor	7	5,647	SF	\$0	
Corridors	Corridors	Lay-In	Stair Tower, Entire Building	7	3,439	EA	\$0	
Corridors	Corridors	Lay-In	3rd Floor	7	5,647	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	5,647	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	5,647	EA	\$0	
Corridors	Corridors	Stair Handrails	Stair Tower, Entire Building	7	620	LF	\$0	
Corridors	Corridors	Terrazzo	Stair Tower, Entire Building	7	3,439	SF	\$0	

**Building: Addition 2**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Terrazzo	3rd Floor	7	5,647	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	5,647	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	5,647	SF	\$0	
Stairs	Corridors	Terrazzo	Stair Tower, Entire Building	7	241	SF	\$0	
Floor	Classroom	Carpet		7	560	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,034	SF	\$0	
Floor	Classroom	Tile/Sheet		7	450	SF	\$0	
Floor	Classroom	Tile/Sheet		7	925	SF	\$0	
Floor	Classroom	Tile/Sheet		7	450	SF	\$0	
Floor	Classroom	Tile/Sheet		7	450	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,221	SF	\$0	
Floor	Classroom	Tile/Sheet		7	925	SF	\$0	
Floor	Classroom	Tile/Sheet		7	450	SF	\$0	
Floor	Classroom	Tile/Sheet		7	450	SF	\$0	
Floor	Classroom	Tile/Sheet		7	450	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,172	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,172	SF	\$0	
Floor	Classroom	Tile/Sheet		7	450	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,172	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	918	SF	\$0	
Floor	Classroom	Tile/Sheet		6	900	SF	\$1,287	
Floor	Classroom	Tile/Sheet		6	900	SF	\$1,287	
Floor	Classroom	Tile/Sheet		7	1,220	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	925	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	900	SF	\$0	
Floor	Classroom	Tile/Sheet		7	377	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,034	SF	\$0	
Floor	Classroom	Tile/Sheet		7	465	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,220	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,220	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,220	SF	\$0	
Floor	Classroom	Tile/Sheet		7	398	SF	\$0	







**Building: Addition 2**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	692	SF	\$0	
Wall	Classroom	Concrete Block		7	692	SF	\$0	
Wall	Classroom	Concrete Block		7	637	SF	\$0	
Wall	Classroom	Concrete Block		7	364	SF	\$0	
Wall	Classroom	Concrete Block		7	494	SF	\$0	
Wall	Classroom	Concrete Block		7	703	SF	\$0	
Wall	Classroom	Concrete Block		7	410	SF	\$0	
Wall	Classroom	Concrete Block		7	730	SF	\$0	
Wall	Classroom	Concrete Block		7	410	SF	\$0	
Wall	Classroom	Concrete Block		7	410	SF	\$0	
Wall	Classroom	Concrete Block		7	410	SF	\$0	
Wall	Classroom	Concrete Block		7	410	SF	\$0	
Wall	Classroom	Concrete Block		7	410	SF	\$0	
Wall	Classroom	Concrete Block		7	730	SF	\$0	
Wall	Classroom	Concrete Block		7	494	SF	\$0	
Wall	Classroom	Concrete Block		7	410	SF	\$0	
Wall	Classroom	Concrete Block		7	364	SF	\$0	
Wall	Classroom	Concrete Block		7	410	SF	\$0	
Wall	Classroom	Concrete Block		7	170	SF	\$0	
Wall	Classroom	Concrete Block		7	330	SF	\$0	
Wall	Classroom	Concrete Block		7	364	SF	\$0	
Wall	Classroom	Concrete Block		7	730	SF	\$0	
Wall	Classroom	Concrete Block		7	494	SF	\$0	
Wall	Classroom	Concrete Block		7	1,060	SF	\$0	
Wall	Classroom	Concrete Block		7	364	SF	\$0	
Wall	Classroom	Concrete Block		7	366	SF	\$0	
Wall	Classroom	Concrete Block		7	637	SF	\$0	
Wall	Classroom	Concrete Block		7	494	SF	\$0	
Wall	Classroom	Concrete Block		7	331	SF	\$0	
Wall	Classroom	Concrete Block		7	1,060	SF	\$0	
Wall	Classroom	Concrete Block		7	754	SF	\$0	
Wall	Classroom	Concrete Block		7	754	SF	\$0	
Wall	Classroom	Concrete Block		7	477	SF	\$0	
Wall	Classroom	Concrete Block		7	364	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	692	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	637	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	364	SF	\$0	

**Building: Addition 2**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		7	494	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	692	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	364	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	692	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	364	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	364	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	330	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	494	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	703	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	640	SF	\$1,510	
Wall	Classroom	Plaster/Drywall		6	320	SF	\$755	
Wall	Classroom	Plaster/Drywall		6	640	SF	\$1,510	
Wall	Classroom	Plaster/Drywall		6	640	SF	\$1,510	
Wall	Classroom	Plaster/Drywall		6	640	SF	\$1,510	
Wall	Classroom	Plaster/Drywall		6	640	SF	\$1,510	
Wall	Classroom	Plaster/Drywall		6	320	SF	\$755	
Wall	Classroom	Plaster/Drywall		6	320	SF	\$755	
Wall	Classroom	Plaster/Drywall		6	640	SF	\$1,510	
Wall	Classroom	Plaster/Drywall		6	640	SF	\$1,510	
Wall	Classroom	Plaster/Drywall		6	940	SF	\$2,218	
Wall	Classroom	Plaster/Drywall		6	306	SF	\$722	
Wall	Classroom	Plaster/Drywall		6	306	SF	\$722	
Wall	Classroom	Plaster/Drywall		7	364	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	364	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	494	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	637	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	477	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	494	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	640	SF	\$1,510	
Wall	Classroom	Plaster/Drywall		7	331	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	612	SF	\$1,444	
Wall	Classroom	Plaster/Drywall		6	612	SF	\$1,444	
<b>ROOM Sub Total</b>							<b>\$51,183</b>	
<b>Building Addition 2 Sub Total</b>							<b>\$984,709</b>	

**Building: Gymnasium**  
**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

**Building: Gymnasium**  
**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Exterior Steel Door	Entire Building	6	6	EA	\$1,982	
Doors		Side Lite	Entire Building	7	6	EA	\$0	
Doors		Transom Lite	Entire Building	7	6	EA	\$0	
Entrance		Concrete Exterior Stairs	South Entrances	7	30	LF	\$0	
Entrance		Stair Handrails	South Entrances	6	10	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	244	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	6	2	EA	\$1,001	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	4	EA	\$0	
Lintels		Lintels - Steel	Entire Building	7	98	LF	\$0	
Parapet		Coping - Metal	W roof	7	42	LF	\$0	
Parapet		Coping - Stone	Roof	6	256	LF	\$0	
Parapet		Parapet < 16" Height	Roof	7	298	LF	\$0	
Roof System		Exterior Downspouts	Roof	6	44	LF	\$818	
Roof System		Interior Downspouts	Roof	6	88	LF	\$0	
Roof System		Metal Roof	Roof	7	1,920	SF	\$0	
Roof System		Modified Bitumen Roof	Roof	7	3,679	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roofs	7	5,637	SF	\$0	
Superstructure		Steel	Entire Building	7	5,637	SF	\$0	
Walls		Brick	South Façade	6	682	SF	\$4,506	mortar & seal brick to foundation
Walls		Brick	Entire Building	7	5,654	SF	\$0	
Walls		Stone - Cast	Entire Building	6	244	SF	\$3,489	clean/seal joints
Windows		Curtain wall - Glazed Double Pane	S & W elevations	6	413	SF	\$3,898	reglaze
Windows		Windows - Decorative	Entire Building	7	715	SF	\$0	
Windows		Windows - Decorative	Entire Building	4	40	SF	\$12,081	
<b>EXTERIOR Sub Total</b>							<b>\$27,774</b>	

**Building: Gymnasium**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	758	SF	\$325	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Lunch Room / Multi Purpose Room	6	1,646	SF	\$871	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Corridors and Stairs	6	2	EA	\$215	

**Building: Gymnasium**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency Battery Packs - Lunchroom and Gym	Lunch Room / Multi Purpose Room	6	2	EA	\$215	
Emergency System		Exit Signs - Corridors and Stairs	Corridors and Stairs	6	2	EA	\$466	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Gym	6	2	EA	\$466	
Power Distribution		Lighting and power panels	Corridors	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	Entire Building	6	2	EA	\$1,430	
<b>ELECTRICAL Sub Total</b>							<b>\$9,421</b>	

**Building: Gymnasium**  
**Category: FIRE PROTECTION**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Electrical Room	7	5,637	SF	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	7	5,637	SF	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	7	5,637	SF	\$0	
<b>FIRE PROTECTION Sub Total</b>							<b>\$0</b>	

**Building: Gymnasium**  
**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	7	100	LF	\$0	
Air Handling Systems		Roof Top Unit - Single Zone - Gas-Heating 21 to 30 tons	Roof	3	1	EA	\$57,200	Unit is not operational
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	
<b>MECHANICAL Sub Total</b>							<b>\$57,429</b>	

**Building: Gymnasium**  
**Category: PLUMBING**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	5,637	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	5,637	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	5,637	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	5,637	SF	\$0	
Piping		Storm Piping	Entire Building	7	5,637	SF	\$0	
Piping		Vent Piping	Entire Building	7	5,637	SF	\$0	
<b>PLUMBING Sub Total</b>							<b>\$0</b>	

**Building: Gymnasium**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

**Building: Gymnasium**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Faculty Lounge	7	273	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 103A, Gym Teacher's Office	7	189	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Faculty Lounge	7	273	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 103A, Gym Teacher's Office	7	189	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Faculty Lounge	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 103A, Gym Teacher's Office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Faculty Lounge	7	614	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Room 103A, Gym Teacher's Office	7	451	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	5	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	7	3	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Exposed	1st Floor	7	1,646	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Sports Flooring	1st Floor	7	1,646	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	1st Floor	7	10	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	1st Floor	7	5,244	SF	\$0	
<b>INTERIOR Sub Total</b>							<b>\$0</b>	

**Building: Gymnasium**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Concrete Block	1st Floor	7	1,365	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	758	SF	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	758	EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	7	12	EA	\$0	

**Building: Gymnasium**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	758	SF	\$0	
<b>ROOM Sub Total</b>							<b>\$0</b>	
<b>Building Gymnasium Sub Total</b>							<b>\$94,625</b>	

**Building: Lunch room/Kitchen**  
**Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Metal Flue	Roof	7	36	LF	\$0	
Doors		Exterior Steel Door	Entire Building	6	7	EA	\$2,312	
Entrance		Concrete Exterior Stairs	East Entrances	7	15	LF	\$0	
Entrance		Concrete Ramp	Entire Building	7	60	LF	\$0	
Entrance		Ramp Handrails	Entire Building	6	120	LF	\$0	
Entrance		Stair Handrails	East Entrances	6	10	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	338	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	10	EA	\$2,145	
Lintels		Lintels - Steel	Entire Building	7	64	LF	\$0	
Parapet		Coping - Stone	Roofs	6	488	LF	\$0	
Parapet		Parapet > 30" Height	Lower Roof	7	50	LF	\$0	
Parapet		Parapet 16" to 30" Height	Main Roof	7	438	LF	\$0	
Roof System		Interior Downspouts	Roofs	6	150	LF	\$0	
Roof System		Modified Bitumen Roof	Roofs	6	9,359	SF	\$66,248	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roofs	7	9,359	SF	\$0	
Superstructure		Steel	Entire Building	7	9,359	SF	\$0	
Walls		Brick	E parking lot	7	550	SF	\$0	
Walls		Brick	Entire Building	7	8,630	SF	\$0	
Walls		Stone - Cast	Entire Building	6	2,704	SF	\$38,667	seal joints/clean
Windows		Windows - Decorative	Entire Building	7	336	SF	\$0	
<b>EXTERIOR Sub Total</b>							<b>\$109,372</b>	

**Building: Lunch room/Kitchen**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	1,341	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	5,733	SF	\$3,033	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	2	EA	\$215	



**Building: Lunch room/Kitchen**  
**Category: ELECTRICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	4	EA	\$429	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	3	EA	\$699	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	4	EA	\$932	
Power Distribution		Lighting and power panels	Electrical Room	7	2	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
<b>ELECTRICAL Sub Total</b>							<b>\$5,308</b>	

**Building: Lunch room/Kitchen**  
**Category: FIRE PROTECTION**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Electrical Room	7	9,359	SF	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	7	9,359	SF	\$0	
Sprinkler System		Wet Sprinkler System	Electrical Room	7	9,359	SF	\$0	
<b>FIRE PROTECTION Sub Total</b>							<b>\$0</b>	

**Building: Lunch room/Kitchen**  
**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 12,001 to 20,000 cfm	Mechanical Room	6	1	EA	\$7,579	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Roof	6	1	EA	\$1,430	
Air Handling Systems		Fan Power Box With Hot Water Coil	Mechanical Room	6	4	EA	\$1,544	
Air Handling Systems		Fan Power Box With Hot Water Coil	Entire Building	6	5	EA	\$1,931	
Air Handling Systems		Make Up Air Unit - Roof Mounted - Gas-Heating less than 6,000 cfm	Mechanical Room	6	1	EA	\$2,860	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	7	100	LF	\$0	
Air Handling Systems		Return Fans - Indoor 5,000 to 10,000 CFM	Mechanical Room	6	1	EA	\$1,716	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	6	2	EA	\$1,001	
Heating Devices		Unit Heater - Electric	Electrical Room	7	1	EA	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Copper	Mechanical Room	7	1,000	LF	\$0	
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	Mechanical Room	6	1	EA	\$1,430	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	6	9,359	SF	\$9,368	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	9	EA	\$1,287	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	

**Building: Lunch room/Kitchen**  
**Category: MECHANICAL**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	7	1	EA	\$0	
<b>MECHANICAL Sub Total</b>							<b>\$30,804</b>	

**Building: Lunch room/Kitchen**  
**Category: PLUMBING**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Mechanical Room	6	2	EA	\$8,294	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	9,359	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	9,359	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	9,359	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	9,359	SF	\$0	
Piping		Storm Piping	Entire Building	7	9,359	SF	\$0	
Piping		Vent Piping	Entire Building	7	9,359	SF	\$0	
<b>PLUMBING Sub Total</b>							<b>\$8,294</b>	

**Building: Lunch room/Kitchen**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Kitchen Manager's Office	7	66	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	Kitchen Manager's Office	7	66	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Kitchen Manager's Office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Kitchen Manager's Office	7	243	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	30	EA	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	1st Floor	7	407	SF	\$0	
Kitchen	Cooking Kitchen	Flooring - Concrete	1st Floor	7	407	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Lay-In	1st Floor	7	5	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Concrete Block	1st Floor	7	649	SF	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	In Kitchen Area	7	9	EA	\$0	
Lunchroom	Lunchroom	Ceiling - Exposed	1st Floor	7	5,733	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	5,733	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	1st Floor	7	12	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	8	SF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	45	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	7	8,902	SF	\$0	

**Building: Lunch room/Kitchen**  
**Category: INTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Janitor's Closet	In Kitchen	7	1	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	151	SF	\$0	
Mechanical/Service Rooms		Storage Room	In Kitchen	7	139	SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	In Kitchen Area	7	75	SF	\$0	
Staff Restroom	Locker/Shower Room	Ceiling - Lay-In	In Kitchen Area	7	75	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Concrete	In Kitchen Area	7	75	SF	\$0	
Staff Restroom	Locker/Shower Room	Lavatory	In Kitchen Area	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	In Kitchen Area	7	1	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	In Kitchen Area	7	345	SF	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	In Kitchen Area	7	1	EA	\$0	
<b>INTERIOR Sub Total</b>							<b>\$0</b>	

**Building: Lunch room/Kitchen**  
**Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Concrete Block	1st Floor	7	1,829	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	1,341	SF	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	1,341	EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	1,341	SF	\$0	
<b>ROOM Sub Total</b>							<b>\$0</b>	

**Building Lunch room/Kitchen Sub Total \$153,779**

**Building: SITE**  
**Category: SITE**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Building	7	7	EA	\$0	
Civil/Drainage		Site Drain	SE court yard	7	1	EA	\$0	
Civil/Drainage		Site Manhole	Entire Building	7	5	EA	\$0	
Fencing		Ornamental Iron	Entire Site	6	1,461	LF	\$27,578	
Landscape		Asphalt Play Area/Hardscape	Entire Site	6	23,003	SF	\$19,737	
Landscape		Benches	Entire Site	7	2	EA	\$0	
Landscape		Grass	Entire Site	6	10,827	SF	\$4,335	Winter mode
Landscape		Hardscape - Concrete	Entire Site	7	13,941	SF	\$0	
Landscape		Parkway trees	Entire Site	7	36	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	5,364	SF	\$0	

**Building: SITE**  
**Category: SITE**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Landscape		Retaining Wall - Concrete	Site ζ North	7	560	SF	\$0	
Landscape		Retaining Wall - Masonry	Site ζ North	6	60	SF	\$849	
Parking Lot		Asphalt	Parking Lot	6	17,951	SF	\$15,402	
Parking Lot		Concrete	Parking Lot	7	7,516	SF	\$0	
Parking Lot		Concrete Curbs	Parking Lot	7	525	LF	\$0	
Parking Lot		Lights, Pole Mounted	Entire Site	6	8	EA	\$9,152	
Parking Lot		Parking lot interior plantings	Parking Lot	7	60	LF	\$0	
Parking Lot		Trash Compactor	NE site	7	1	EA	\$0	
Parking Lot		Vehicular Screening	Parking Lot	7	375	LF	\$0	
Playground		Playground Equipment - Pre-K 3-5	Playground	7	1	EA	\$0	
Playground		Playground Surfacing - Square Rubber Mats	Playground	4	2,150	SF	\$47,655	
Sidewalks		Internal Walks	Entire Site	6	1,122	LF	\$10,589	
Sidewalks		Perimeter Sidewalks	Entire Site	6	13,749	SF	\$25,953	
Signage		Flag Pole	Site ζ South	7	1	EA	\$0	
Signage		Flag Pole	North Façade	7	1	EA	\$0	
Signage		Marquee - Building Mounted Back Lighted w/ LED	Main Entrance	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	NW site	6	1	EA	\$0	
Signage		Monument Sign - Lighted	Site ζ South	7	1	EA	\$0	
<b>SITE Sub Total</b>							<b>\$161,250</b>	
<b>SITE Sub Total</b>							<b>\$161,250</b>	

**Total Campus Need <sup>2 3</sup> \$5,620,677**

<sup>1</sup> It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

<sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

**Room Summary**

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
<b>Building: Main</b>														
100	915	1	0	10	50	132	66	2	N	Y	Y	Classroom		
101	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
102	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
103	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
104	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
105	915	1	0	10	50	132	66	0	N	Y	Y	Classroom		
200	415	1	0	8	50	66	33	1	N	N	Y	Classroom		
201	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
202	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
204	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
205	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
206	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
207	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
208	815	1	3	16	50	132	66	0	N	Y	Y	Classroom		
209	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
210	533	1	3	12	50	88	44	0	N	N	Y	Classroom		
300	415	1	0	8	50	66	33	2	N	N	Y	Classroom		
301	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
302	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
303	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
304	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
305	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
306	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
307	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
308	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
309	815	1	0	10	50	132	66	0	N	Y	Y	Classroom		
310	533	1	0	8	50	88	44	0	N	N	Y	Classroom		
311	415	1	0	8	50	66	33	2	N	N	Y	Classroom		
Other	3071								N	N	N	Corridors		3rd Floor
Other	50								N	N	N	Restroom	Staff Restroom	3rd Floor
Other	467								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Boy's Room
Other	468								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Girl's Room
Other	467								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Boy's Room
Other	3071								N	N	N	Corridors		1st Floor
Other	467								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Boy's Room
Other	3071								N	N	N	Corridors		2nd Floor

**Room Summary**

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	467								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Boy's Room
Other	468								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Girl's Room
Other	415			8					N	N	Y	Administrative Suites/Offices		Room 211
Other	490			12					N	N	Y	Administrative Suites/Offices		Room 99
Other	37								N	N	N	Restroom	Staff Restroom	In Room 99
Other	470			12					N	N	Y	Administrative Suites/Offices		Room 106
Other	46								N	N	N	Restroom	Early Childhood Student Restroom	In Room 105
Other	50								N	N	N	Restroom	Staff Restroom	1st Floor
Other	468								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Girl's Room
Other	1920								N	N	N	Corridors		Stair Tower, Entire Building
Other	50								N	N	N	Restroom	Staff Restroom	2nd Floor
Other	6067								N	N	N	Gymnasia	Gymnasium.Auditorium	1st Floor
Other	124			6					N	N	N	Administrative Suites/Offices		Gym Teacher's Office
Other	16								N	N	N	Restroom	Staff Restroom	In Boiler Room Area
Other	179			4					N	N	N	Administrative Suites/Offices		Engineer's Office

**Building: Addition 2**

110	1220	1	4	20	50	232	116	0	N	N	Y	Classroom		
111	1172	1	4	12	50	176	88	0	N	N	N	Classroom		
112	1220	1	4	20	50	232	116	0	N	N	Y	Classroom		
113	1172	1	4	12	50	176	88	0	N	N	N	Classroom		
114	1220	1	4	20	50	232	116	0	N	N	Y	Classroom		
115	1172	1	4	12	50	176	88	0	N	N	N	Classroom		
116	1220	1	4	20	50	232	116	0	N	N	Y	Classroom		
117	450	1	3	10	50	66	33	0	N	N	N	Classroom		
119	450	1	3	10	50	66	33	0	N	N	N	Classroom		
213	450	1	2	6	50	66	33	0	N	Y	Y	Classroom		
214	900	1	4	20	50	132	66	0	N	N	Y	Classroom		
215	925	1	2	10	50	132	66	0	N	Y	N	Classroom		
216	900	1	4	20	50	132	66	0	N	N	Y	Classroom		
217	450	1	2	6	50	66	33	0	N	Y	Y	Classroom		
218	900	1	4	20	50	132	66	0	N	N	Y	Classroom		
219	450	1	2	6	50	66	33	0	N	Y	Y	Classroom		
220	900	1	4	20	50	132	66	0	N	N	Y	Classroom		
221	1034	1	2	10	50	154	77	0	N	Y	Y	Classroom		
222	560	1	4	20	50	132	66	0	N	N	Y	Classroom		
222A	925	1	2	10	50	132	66	0	N	Y	N	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
223	1221	1	40	50	50	176	88	0	N	Y	Y	Classroom		
313	398	1	1	10	40	66	33	0	N	N	N	Classroom		
314/316	918	1	4	20	50	132	66	0	N	Y	Y	Classroom		
315	925	1	2	10	50	132	66	0	N	Y	N	Classroom		
317	880	1	2	12	50	132	66	0	N	Y	Y	Classroom		
318	900	1	4	20	50	132	66	0	N	Y	Y	Classroom		
319	377	1	2	10	50	66	33	0	N	N	N	Classroom		
320	900	1	4	20	50	132	66	0	N	Y	Y	Classroom		
321	1034	1	2	10	50	154	77	0	N	Y	Y	Classroom		
322	900	1	4	20	50	132	66	0	N	Y	Y	Classroom		
323	465	1	2	6	50	44	22	0	N	N	Y	Classroom		
324	900	1	4	20	50	132	66	0	N	Y	Y	Classroom		
325	925	1	2	10	50	132	66	0	N	Y	N	Classroom		
326	900	1	4	20	50	132	66	0	N	Y	Y	Classroom		
327	450	1	2	6	50	66	33	0	N	Y	Y	Classroom		
328	900	1	4	20	50	132	66	0	N	Y	Y	Classroom		
Other	42								N	N	N	Restroom	Staff Restroom	1st Floor
Other	241								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Boy's Room
Other	293								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Girl's Room
Other	293								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Girl's Room
Other	293								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Girl's Room
Other	42								N	N	N	Restroom	Staff Restroom	2nd Floor
Other	36								N	N	N	Restroom	Early Childhood Student Restroom	In Room 115
Other	476			8					N	N	Y	Administrative Suites/Offices		Faculty Room, 1st Floor
Other	3439								N	N	N	Corridors		Stair Tower, Entire Building
Other	5647								N	N	N	Corridors		3rd Floor
Other	5647								N	N	N	Corridors		2nd Floor
Other	5647								N	N	N	Corridors		1st Floor
Other	42								N	N	N	Restroom	Staff Restroom	3rd Floor
Other	36								N	N	N	Restroom	Early Childhood Student Restroom	In Room 110
Other	241								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Boy's Room
Other	1595								N	N	N	Library		Room 222
Other	241								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Boy's Room
Other	36								N	N	N	Restroom	Early Childhood Student Restroom	In Room 112
Other	36								N	N	N	Restroom	Early Childhood Student Restroom	In Room 114
Other	36								N	N	N	Restroom	Early Childhood Student Restroom	In Room 116
Other	1540			30					N	N	Y	Administrative Suites/Offices		Main Office & Principal's Office

**Room Summary**

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	36								N	N	N	Restroom	Early Childhood Student Restroom	In Room 111
Other	36								N	N	N	Restroom	Early Childhood Student Restroom	In Room 113

**Building: Gymnasium**

Other	273			6					N	N	N	Administrative Suites/Offices		Faculty Lounge
Other	1646								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	189			6					N	N	N	Administrative Suites/Offices		Room 103A, Gym Teacher's Office
Other	758								N	N	N	Corridors		1st Floor

**Building: Lunch room/Kitchen**

Other	5733								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	407								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	75								N	N	N	Restroom	Locker/Shower Room	In Kitchen Area
Other	66			6					N	N	N	Administrative Suites/Offices		Kitchen Manager's Office
Other	1341								N	N	N	Corridors		1st Floor