

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Stainless Steel Liner	Boiler Room	7	60	LF	\$0	
Cornice		Cornice - Masonry Projecting/Limestone	Boiler Room	7	210	LF	\$0	
Doors		Exterior Steel Door	throughout	7	16	EA	\$0	
Doors		Transom Lite	throughout	7	14	EA	\$0	
Entrance		Concrete Exterior Stairs	throughout	7	90	LF	\$0	
Entrance		Concrete Ramp	throughout	7	60	LF	\$0	
Entrance		Entrance Controls - Audio and Video	East Entrances	7	1	EA	\$0	
Entrance		Power Door Operator and Controls	throughout	7	1	EA	\$0	
Entrance		Ramp Handrails	throughout	7	120	LF	\$0	
Entrance		Stair Handrails	throughout	6	96	LF	\$0	
Entrance		Steel or Aluminum Stairs	throughout	6	3	LF	\$21	
Entrance		Stone Stairs	throughout	6	8	LF	\$1,430	
Foundation		Concrete Foundation	Entire Building	7	1,286	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Building	6	7	EA	\$3,504	clean lenses

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	8	EA	\$1,716	clean lenses
Lintels		Lintels - Stone	Entire Building	7	855	LF	\$0	
Parapet		Coping - Stone	Roofs	7	1,406	LF	\$0	
Parapet		Parapet > 30" Height	Roofs	7	110	LF	\$0	
Parapet		Parapet 16" to 30" Height	Roofs	7	1,296	LF	\$0	
Roof System		Asphalt Shingle Roof	W elevation	7	3,852	SF	\$0	
Roof System		Exterior Downspouts	Roofs	7	82	LF	\$0	
Roof System		Interior Downspouts	Roofs	3	36	LF	\$17,761	S elevation crawls space under gym - roof drain terminates in crawl producing water
Roof System		Interior Downspouts	Roofs	3	72	LF	\$35,521	produces water in rooms:212, 210, 208, 112, 110 & 108
Roof System		Interior Downspouts	Roofs	7	216	LF	\$0	
Roof System		Modified Bitumen Roof	elevator shaft roof	7	60	SF	\$0	
Roof System		PVC Membrane Roof	Roofs	7	28,538	SF	\$0	
Roof System		Roof Structure: Concrete	Roofs	7	28,598	SF	\$0	
Superstructure		Concrete	Entire Building	7	64,306	SF	\$0	
Walls		Brick	Entire Building	7	40,330	SF	\$0	
Walls		Stone - Cast	Entire Building	7	2,186	SF	\$0	
Windows		Skylite - Glass Single-Pane	Boiler Room	7	45	SF	\$0	
Windows		Window - Guards perforated	1st Floor	7	3,354	SF	\$0	
Windows		Windows - Decorative	stairwells	7	40	SF	\$0	
Windows		Windows - Sash Aluminum	basement E elevation	6	160	SF	\$1,373	repair glazing
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	6,552	SF	\$0	no window stops
EXTERIOR Sub Total							\$61,325	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Boiler Room	7	4	EA	\$0	
Emergency System		Emergency A/C power - Auditorium and aisle lighting	1st Floor	6	2,080	SF	\$2,826	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	6	EA	\$644	
Emergency System		Emergency generator 150 KW -200 KW natural gas - Outdoor	Outside Boiler Room	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	4	6	EA	\$5,577	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	4	16	EA	\$14,872	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Entire Building	4	8	EA	\$7,436	
Emergency System		Public Announcement System	Entire Building	6	64,000	SF	\$38,438	
Emergency System		Security System - Intrusion detection	Entire Building	6	64,000	SF	\$59,488	
Main Service		Main Electrical service 1600 A 120/208/3PH	Electrical Room Enclosure-Boiler Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	2nd Floor	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	Basement	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	1st Floor	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	Electrical Room Enclosure-Boiler Room	7	3	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room Enclosure-Boiler Room	7	3	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Boiler Room	7	2	EA	\$0	
ELECTRICAL Sub Total							\$161,885	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	64,000	SF	\$0	
Fire Alarm		Fire Alarm System	Entire Building	7	64,306	SF	\$0	
FIRE PROTECTION Sub Total							\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	4	23	EA	\$49,335	
Air Handling Systems		Make Up Air Unit - Roof Mounted - Electric 6,000 to 10,000 cfm	Roof	7	2	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Basement	7	2	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Basement	6	2	EA	\$5,720	
Air Handling Systems		Reheat Boxes With Steam Coils	Basement	6	13	EA	\$13,571	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 4,000 to 8,000 cfm	Basement	7	2	EA	\$0	
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries - Steam 4,000 to 8,000 cfm	Basement	7	2	EA	\$0	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 151 - 200 HP	Boiler Room	4	2	EA	\$331,760	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Boiler Systems		Boiler Auxiliary - Steam Boiler 151 - 200 HP	Boiler Room	6	2	EA	\$4,862	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	6	1	EA	\$2,145	
Boiler Systems		Combustion Dampers	Boiler Room	6	1	EA	\$286	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	4	1	EA	\$31,460	
Heating Devices		Radiators - Steam	Throughout the building	2	27	EA	\$37,838	Radiators are more than 30 years of age and is not working
Heating Devices		Radiators - Steam	Entire Building	7	8	EA	\$0	
Heating Devices		Wall Heater - Electric	Entire Building	3	12	EA	\$12,355	Wall heater is more than 10 years of age and is working, however the heater cannot maintain the proper heat in the area
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	6	2	EA	\$1,430	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	5	2,000	LF	\$65,065	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	2,000	LF	\$98,956	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	6	0	SF	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	30	EA	\$4,290	
Temperature Control		Zone Dampers	Basement	6	30	EA	\$4,290	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	1	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	2	EA	\$0	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	6	1	EA	\$157	
MECHANICAL Sub Total							\$663,520	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	1	EA	\$4,147	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	7	1	EA	\$0	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	4	1	EA	\$14,872	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	5	64,000	SF	\$10,982	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	64,000	SF	\$21,050	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	5	64,000	SF	\$73,216	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	64,000	SF	\$13,728	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	64,000	SF	\$16,474	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	64,000	SF	\$56,742	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	5	64,000	SF	\$33,862	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	64,000	SF	\$34,778	
Piping		Sanitary Piping	Entire Building	5	64,000	SF	\$39,354	
Piping		Storm Piping	Entire Building	5	64,000	SF	\$30,202	
Piping		Vent Piping	Entire Building	5	64,000	SF	\$22,880	
Pumps		Domestic Booster Pump duplex	Boiler Room	7	1	EA	\$0	
Pumps		Sump Pump	Basement	3	1	EA	\$11,869	
PLUMBING Sub Total							\$384,155	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Engineer's Office	6	78	SF	\$167	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Principal's Office	6	135	SF	\$290	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main Office	6	421	SF	\$903	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Gym Office	5	368	SF	\$2,084	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 232, Office	7	141	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Kitchen Office/Store Room	6	86	SF	\$244	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 206	6	468	SF	\$1,325	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Teacher's Lounge Room 124	6	390	SF	\$1,104	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 108 (Clinic)	6	468	SF	\$1,325	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	Engineer's Office	7	78	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile Ceramic/Porcelain	Gym Office	6	368	SF	\$937	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile Ceramic/Porcelain	Room 206	6	468	SF	\$1,191	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile Ceramic/Porcelain	Teacher's Lounge Room 124	6	390	SF	\$993	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Principal's Office	6	135	SF	\$193	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office	7	421	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Kitchen Office/Store Room	6	86	SF	\$123	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 232, Office	7	141	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Room 108 (Clinic)	7	468	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main Office	4	4	SF	\$19	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Principal's Office	4	2	SF	\$9	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Engineer's Office	4	1	SF	\$5	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Gym Office	4	3	SF	\$20	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 206	4	7	SF	\$46	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 232, Office	4	1	SF	\$7	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Teacher's Lounge Room 124	4	6	SF	\$39	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 108 (Clinic)	4	7	SF	\$46	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Kitchen Office/Store Room	4	2	SF	\$13	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 206	6	1,100	SF	\$2,595	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Kitchen Office/Store Room	6	247	SF	\$583	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Teacher's Lounge Room 124	6	1,100	SF	\$2,595	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principal's Office	7	397	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	6	809	SF	\$1,909	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 232, Office	7	435	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 108 (Clinic)	6	1,100	SF	\$2,595	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Engineer's Office	6	225	SF	\$531	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor	7	111	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	7	280	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	6	8	EA	\$90,605	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	7	1	EA	\$0	
Classrooms		Work Sink	Room 206	7	1	EA	\$0	
Corridor		Ceiling - Lay-In	Entire Building	6	10,379	SF	\$22,263	
Corridor		Flooring Terrazzo	Entire Building	7	1,556	SF	\$0	
Corridor		Flooring Tile/ Sheet	Entire Building	7	8,821	SF	\$0	
Corridor		Lighting - Pendant/ Surface	Entire Building	4	306	SF	\$2,976	
Corridor		Stair Handrails	Entire Building	7	600	LF	\$0	
Corridor		Stairs - Terrazzo	Entire Building	7	304	LF	\$0	
Corridor		Walls - Plaster/Drywall	Entire Building	6	23,712	SF	\$55,948	
Doors		Interior Steel Doors incl hw	throughout	7	22	EA	\$0	
Doors		Interior Wood Doors incl hw	throughout	6	12	EA	\$3,398	
Doors		Interior Wood Doors incl hw	throughout	7	63	EA	\$0	
Doors		Transom Window	throughout	7	34	SF	\$0	
Drinking Fountains		Single Fountain	Entire Building	7	12	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	1st Floor	6	2,791	SF	\$23,867	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1st Floor	7	2,791	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	1st Floor	4	32	EA	\$29,286	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	1st Floor	7	2,525	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	1st Floor	6	2,525	SF	\$21,665	
Kitchen	Warming Kitchen	Ceiling - Plaster/Drywall	1st Floor	6	424	SF	\$1,601	
Kitchen	Warming Kitchen	Flooring - Tile/Sheet	1st Floor	6	424	SF	\$606	
Kitchen	Warming Kitchen	Lighting - Pendant/Surface	1st Floor	4	7	SF	\$46	
Kitchen	Warming Kitchen	Wall - Plaster/Drywall	1st Floor	6	653	SF	\$1,541	
Library	Library	Ceiling - Splined	1st Floor	6	1,253	SF	\$2,688	
Library	Library	Flooring Tile/ Sheet	1st Floor	6	1,253	SF	\$1,792	
Library	Library	Lighting - Pendant/ Surface	1st Floor	4	28	SF	\$184	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	1st Floor- 114/116	6	1,357	SF	\$3,842	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor- 114/116	6	1,357	SF	\$1,941	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor- 114/116	4	16	SF	\$105	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Lunchroom	Serving Line	1st Floor- 114/116	7	6	LF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	1st Floor- 114/116	6	1,767	SF	\$4,169	
MDF/IDF		Finishes	2nd Floor	6	135	SF	\$459	
MDF/IDF		Ventilation and Cooling	2nd Floor	7	1	EA	\$0	
Mechanical/Service Rooms		Air Intake Plenums	Basement	7	496	SF	\$0	
Mechanical/Service Rooms		Air Tunnels	Basement	7	1,990	SF	\$0	
Mechanical/Service Rooms		Boiler Room	Basement	7	1,474	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	1st Floor	7	2	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	2nd Floor	7	2	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Boiler Room	6	58	SF	\$274	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	424	SF	\$2,001	
Mechanical/Service Rooms		Mechanical/Service Rooms	Boiler Room	7	160	SF	\$0	
Mechanical/Service Rooms		Storage Room	In Library	7	80	SF	\$0	
Mechanical/Service Rooms		Storage Room	Basement	7	285	SF	\$0	
Mechanical/Service Rooms		Storage Room	Main Office	7	164	SF	\$0	
Mechanical/Service Rooms		Storage Room	Next to Gym	7	70	SF	\$0	
Mechanical/Service Rooms		Storage Room	Formerly a shower room for Gym on mezzanine floor	6	523	SF	\$2,468	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor Unisex Staff Restroom	7	83	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Floor South Unisex Staff Restroom	7	83	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor South Girl's Room	7	304	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor South Girl's Room	7	304	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor North Girl's Room	7	304	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor North Girl's Room	7	304	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	In Engineer's Office	6	40	SF	\$309	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	In Engineer's Office	6	40	SF	\$86	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor North Boy's Room	6	276	SF	\$781	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor North Girl's Room	6	304	SF	\$861	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor North Girl's Room	6	304	SF	\$861	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor South Girl's Room	6	304	SF	\$861	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor South Girl's Room	6	304	SF	\$861	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor North Boy's Room	6	276	SF	\$781	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor South Boy's Room	6	276	SF	\$781	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st Floor South Unisex Staff Restroom	6	83	SF	\$235	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor South Boy's Room	6	276	SF	\$781	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor Unisex Staff Restroom	6	83	SF	\$235	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor North Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor North Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor North Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor North Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor South Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor South Girl's Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st Floor South Unisex Staff Restroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd Floor Unisex Staff Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor South Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor South Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor South Girl's Room	7	304	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor South Boy's Room	7	276	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor North Girl's Room	7	304	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor South Boy's Room	7	276	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Unisex Staff Restroom	7	83	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor South Unisex Staff Restroom	7	83	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor North Boy's Room	7	276	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor South Girl's Room	7	304	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor North Girl's Room	7	304	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	In Engineer's Office	6	40	SF	\$57	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor North Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor North Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor South Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor South Girl's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st Floor South Unisex Staff Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd Floor Unisex Staff Restroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Floor South Unisex Staff Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor South Girl's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	In Engineer's Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor North Boy's Room	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor Unisex Staff Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor North Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor North Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor South Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor North Boy's Room	4	5	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor North Boy's Room	4	5	SF	\$21	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	In Engineer's Office	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor North Girl's Room	4	5	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor South Boy's Room	4	5	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor North Girl's Room	4	5	SF	\$21	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor Unisex Staff Restroom	4	2	SF	\$9	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st Floor South Unisex Staff Restroom	4	2	SF	\$9	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor South Girl's Room	4	5	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor South Girl's Room	4	5	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor South Boy's Room	4	5	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor North Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor North Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor South Girl's Room	7	5	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor South Girl's Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor North Boy's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor South Boy's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor South Boy's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor North Boy's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd Floor North Boy's Room	7	475	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd Floor North Girl's Room	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor North Girl's Room	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor South Girl's Room	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st Floor South Unisex Staff Restroom	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	2nd Floor Unisex Staff Restroom	7	200	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd Floor South Boy's Room	7	475	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor South Boy's Room	7	475	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st Floor North Boy's Room	7	475	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd Floor South Girl's Room	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st Floor South Unisex Staff Restroom	6	200	SF	\$472	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor Unisex Staff Restroom	6	200	SF	\$472	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor South Boy's Room	6	476	SF	\$1,123	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor South Boy's Room	6	476	SF	\$1,123	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor North Boy's Room	6	476	SF	\$1,123	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	In Engineer's Office	6	145	SF	\$342	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor North Girl's Room	6	200	SF	\$472	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor South Girl's Room	6	200	SF	\$472	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor North Boy's Room	6	476	SF	\$1,123	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor South Girl's Room	6	200	SF	\$472	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor North Girl's Room	6	200	SF	\$472	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor North Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In Engineer's Office	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor South Girl's Room	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor Unisex Staff Restroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Floor South Unisex Staff Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor South Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor North Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor North Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor South Girl's Room	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor North Boy's Room	7	2	EA	\$0	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	1st Floor	5	2,080	SF	\$20,821	
Theater	Auditorium - Dedicated	Flooring - Concrete	1st Floor	7	2,080	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	4	8	SF	\$60	
Theater		Stage Platform	1st Floor	7	557	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	1st Floor	6	5,240	SF	\$44,959	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
INTERIOR Sub Total							\$379,107	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Gym Office	5	340	SF	\$1,604	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Gym Office	6	335	SF	\$790	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	40	LF	\$1,430	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Ceiling	Classroom	Lay-In/Drop		6	721	SF	\$1,547	
Ceiling	Classroom	Lay-In/Drop		6	721	SF	\$1,547	
Ceiling	Classroom	Lay-In/Drop		6	721	SF	\$1,547	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	1,156	SF	\$3,273	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		5	721	SF	\$4,083	
Ceiling	Classroom	Plaster/Drywall		5	721	SF	\$4,083	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Ceiling	Classroom	Plaster/Drywall		6	721	SF	\$2,041	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
CLASSROOM	Classroom	Eye Wash Station		7	1	EA	\$0	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	1,156	SF	\$8,728	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
Floor	Classroom	Wood		6	721	SF	\$5,444	
LIBRARY_WALL	Library	Plaster/Drywall	1st Floor	6	1,610		\$3,799	
Lighting	Classroom	Lay-In		4	12	EA	\$4,462	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	22	EA	\$8,652	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	46	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	10	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,608	SF	\$3,794	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	

**Building: Main
Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		5	1,218	SF	\$5,748	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
Wall	Classroom	Plaster/Drywall		6	1,218	SF	\$2,874	
ROOM Sub Total							\$320,218	
Building Main Sub Total							\$1,970,210	

**Building: Annex
Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Exterior Steel Door	throughout	7	7	EA	\$0	
Doors		Transom Lite	throughout	7	2	EA	\$0	
Entrance		Concrete Exterior Stairs	throughout	5	72	LF	\$23,166	
Entrance		Concrete Exterior Stairs	throughout	6	20	LF	\$2,145	
Entrance		Concrete Ramp	throughout	7	5	LF	\$0	
Entrance		Entrance Controls - Audio	throughout	7	1	EA	\$0	
Entrance		Entrance Controls - Audio and Video	throughout	7	1	EA	\$0	
Entrance		Stair Handrails	throughout	6	40	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	498	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	15	EA	\$3,218	clean lenses
Parapet		Coping - Metal	Roofs	6	546	LF	\$0	rust
Parapet		Parapet < 16" Height	Roofs	7	546	LF	\$0	
Roof System		Interior Downspouts	Roofs	7	123	LF	\$0	

Building: Annex
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Roof System		Modified Bitumen Roof	Roofs	3	12,990	SF	\$306,499	produces water inside, ponding, surface deterioration
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roofs	7	12,990	SF	\$0	
Superstructure		Concrete	rooms 501 & 508	5	500	SF	\$10,904	large gaps above window frames
Superstructure		Concrete	Entire Building	7	36,488	SF	\$0	
Walls		Precast Panel Wall	Entire Building	7	11,988	SF	\$0	
Walls		Precast Panel Wall	West elevation	5	5,220	SF	\$164,221	spalling, exposed steel, flaking paint, replace sealant
Windows		Skylite - Lexan	Roof	4	150	SF	\$31,995	
Windows		Windows - Casement Lexan	Entire Building	4	1,950	SF	\$224,530	30% are sealed shut due to inoperability
EXTERIOR Sub Total							\$766,677	

Building: Annex
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Entire Building	6	1	EA	\$1,430	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	Lower Level -Lunchroom	6	2	EA	\$215	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	4	12	EA	\$11,154	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Lower Level Lunchroom	4	8	EA	\$7,436	
Emergency System		Independent Electrical Service for emergency power	Entire Building	7	1	EA	\$0	
Emergency System		Public Announcement System	Entire Building	6	36,100	SF	\$21,682	
Emergency System		Security System - Intrusion detection	Entire Building	6	36,100	SF	\$33,555	
Main Service		Main Electrical service 1200 A 120/208/3PH	1st Floor	4	1	EA	\$113,256	
Power Distribution		Lighting and power panels	Entire Building	4	10	EA	\$54,340	
Power Distribution		Main distribution panels 400-600 amp	Entire Building	4	1	EA	\$12,155	
Power Distribution		Main distribution panels above 600 amp	Entire Building	4	1	EA	\$18,590	
ELECTRICAL Sub Total							\$273,812	

Building: Annex
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	3	36,100	SF	\$76,402	Strobe lights are not provided or not located in all areas

Building: Annex
Category: FIRE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Entire Building	4	36,988	SF	\$130,645	
FIRE PROTECTION Sub Total							\$207,047	

Building: Annex
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	2	3	EA	\$25,740	Condensing units are not working and are more than 20 years of age (compressors not operating, condenser fans are not running, no refrigerant in the system)
Air Conditioning		Window A/C Unit	Entire Building	4	1	EA	\$2,145	
Heating Devices		Wall Heater - Electric	Entire Building	3	20	EA	\$20,592	Wall heater is more than 10 years of age and is working, however the heater cannot maintain the proper heat in the area
Unit Ventilation		Unit Ventilators - Self Contained Electric Heating and Cooling	Entire Building	6	25	EA	\$42,900	
Unit Ventilation		Unit Ventilators - Self Contained Electric Heating and Cooling	Lower Level Lunchroom	2	1	EA	\$17,160	The unit ventilator is more than 25 years of age and is not working.
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	4	2	EA	\$4,576	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Roof	7	1	EA	\$0	
MECHANICAL Sub Total							\$113,542	

Building: Annex
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas less than 150,000 BTU/HR	2nd Floor	3	1	EA	\$14,872	Hot Water Heater is more than 15 years of age and the heater is not working, is leaking and is rusted
Hot Water		Hot Water Heater - Gas less than 150,000 BTU/HR	1st Floor	3	1	EA	\$14,872	Hot Water Heater is more than 15 years of age and the heater is not working, is leaking and is rusted

Building: Annex
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	36,100	SF	\$11,873	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	36,100	SF	\$23,230	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	36,100	SF	\$7,743	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	36,100	SF	\$16,519	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	36,100	SF	\$19,617	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	36,100	SF	\$86,210	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	36,100	SF	\$71,240	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	36,100	SF	\$41,298	
Piping		Sanitary Piping	Entire Building	4	36,100	SF	\$34,587	
Piping		Storm Piping	Entire Building	4	36,100	SF	\$25,812	
Piping		Vent Piping	Entire Building	4	36,100	SF	\$20,649	
PLUMBING Sub Total							\$388,524	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Principal's Office	6	219	SF	\$470	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main Office	6	469	SF	\$1,006	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Principal's Office	7	219	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office	7	469	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main Office	4	8	SF	\$37	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Principal's Office	4	4	SF	\$19	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principal's Office	6	545	SF	\$1,286	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	6	956	SF	\$2,256	
Corridor		Ceiling - Lay-In	Entire Building	6	9,564	SF	\$20,515	
Corridor		Flooring Tile/ Sheet	Entire Building	6	9,564	SF	\$13,677	
Corridor		Lighting - Lay-In	Entire Building	4	410	SF	\$2,492	
Corridor		Stair Handrails	Entire Building	7	504	LF	\$0	
Corridor		Stairs - Terrazzo	Entire Building	7	126	LF	\$0	
Corridor		Walls - Plaster/Drywall	Entire Building	6	14,566	SF	\$34,368	
Doors		Interior Steel Doors incl hw	throughout	7	63	EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Store Front Door	throughout	7	6	EA	\$0	
Drinking Fountains		Single Fountain	Entire Building	7	6	EA	\$0	
Kitchen	Warming Kitchen	Ceiling - Lay-In	1st Floor	6	475	SF	\$1,359	
Kitchen	Warming Kitchen	Flooring - Tile/Sheet	1st Floor	6	475	SF	\$679	
Kitchen	Warming Kitchen	Lighting - Lay-In	1st Floor	4	8	SF	\$37	
Kitchen	Warming Kitchen	Wall - Plaster/Drywall	1st Floor	6	948	SF	\$2,237	
Library	Library	Flooring Tile/ Sheet	2nd Floor	6	1,527	SF	\$2,184	
Library	Library	Lighting - Lay-In	2nd Floor	4	23	SF	\$107	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	1st Floor	6	2,435	SF	\$5,223	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	1st Floor	6	2,435	SF	\$3,482	
Lunchroom	Multipurpose Room	Lighting - Lay-In	1st Floor	4	12	SF	\$56	
Lunchroom	Multipurpose Room	Serving Line	1st Floor	7	12	LF	\$0	
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	1st Floor	6	5,325	SF	\$12,564	
MDF/IDF		Finishes	1st Floor	6	98	SF	\$334	
MDF/IDF		Ventilation and Cooling	1st Floor	7	1	EA	\$0	
Mechanical/Service Rooms		Storage Room	1st, 2nd, 3rd Floor East Side Storage Rooms-	7	729	SF	\$0	
Mechanical/Service Rooms		Storage Room	In Main Office	7	59	SF	\$0	
Mechanical/Service Rooms		Storage Room	In Main Office	7	27	SF	\$0	
Mechanical/Service Rooms		Storage Room	In Main Office	7	63	SF	\$0	
Mechanical/Service Rooms		Storage Room	3rd Floor	7	212	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Boy's Room	7	227	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Kindergarten Room 303	7	20	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Girl's Room	7	227	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Boy's Room	7	227	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd Floor	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boy's Room	7	227	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Kindergarten Room 301	7	20	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Girl's Room	7	227	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Floor	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	In Principal's Office	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor	7	42	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Girl's Room	7	227	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	3rd Floor Boy's Room	6	230	SF	\$493	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	2nd Floor Girl's Room	6	227	SF	\$487	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st Floor	6	42	SF	\$90	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd Floor	6	42	SF	\$90	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd Floor	6	42	SF	\$90	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	1st Floor Boy's Room	6	230	SF	\$493	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	2nd Floor Boy's Room	6	230	SF	\$493	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	1st Floor Girl's Room	6	227	SF	\$487	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	Kindergarten Room 303	6	20	SF	\$43	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	3rd Floor Girl's Room	6	227	SF	\$487	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Lay-In	Kindergarten Room 301	6	20	SF	\$43	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	In Principal's Office	6	25	SF	\$54	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Girl's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boy's Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Girl's Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Concrete	In Principal's Office	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Boy's Room	6	230	SF	\$585	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	Kindergarten Room 303	6	20	SF	\$51	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor	7	42	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Boy's Room	6	230	SF	\$585	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Girl's Room	6	227	SF	\$578	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Girl's Room	6	227	SF	\$578	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	Kindergarten Room 301	6	20	SF	\$51	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor Boy's Room	6	230	SF	\$585	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	In Principal's Office	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	Kindergarten Room 303	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	Kindergarten Room 301	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Girl's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st Floor Boy's Room	4	2	SF	\$7	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd Floor Girl's Room	4	2	SF	\$7	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd Floor Girl's Room	4	2	SF	\$7	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd Floor Boy's Room	4	2	SF	\$7	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd Floor Boy's Room	4	2	SF	\$7	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st Floor Girl's Room	4	2	SF	\$7	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor	4	1	SF	\$4	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd Floor	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st Floor	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Girl's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Girl's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Girl's Room	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd Floor Boy's Room	6	594	SF	\$1,402	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd Floor Girl's Room	6	594	SF	\$1,402	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Girl's Room	6	594	SF	\$1,402	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor Boy's Room	6	594	SF	\$1,402	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Boy's Room	6	594	SF	\$1,402	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor	6	189	SF	\$446	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd Floor	6	189	SF	\$446	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st Floor	6	189	SF	\$446	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	In Principal's Office	6	140	SF	\$330	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	Kindergarten Room 303	6	160	SF	\$378	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	Kindergarten Room 301	6	160	SF	\$378	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor Girl's Room	6	594	SF	\$1,402	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boy's Room	7	2	EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Water Closet	Kindergarten Room 303	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In Principal's Office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Girl's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Boy's Room	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	Kindergarten Room 301	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Girl's Room	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Girl's Room	7	4	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
INTERIOR Sub Total							\$121,638	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	18	LF	\$644	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	48	LF	\$1,716	
Ceiling	Classroom	Lay-In/Drop		4	735	SF	\$6,937	
Ceiling	Classroom	Lay-In/Drop		6	1,133	SF	\$2,430	
Ceiling	Classroom	Lay-In/Drop		6	735	SF	\$1,577	
Ceiling	Classroom	Lay-In/Drop		6	735	SF	\$1,577	
Ceiling	Classroom	Lay-In/Drop		6	735	SF	\$1,577	
Ceiling	Classroom	Lay-In/Drop		6	735	SF	\$1,577	
Ceiling	Classroom	Lay-In/Drop		6	782	SF	\$1,677	
Ceiling	Classroom	Lay-In/Drop		6	1,133	SF	\$2,430	
Ceiling	Classroom	Lay-In/Drop		6	735	SF	\$1,577	
Ceiling	Classroom	Lay-In/Drop		4	735	SF	\$6,937	
Ceiling	Classroom	Lay-In/Drop		6	782	SF	\$1,677	
Ceiling	Classroom	Lay-In/Drop		6	763	SF	\$1,637	
Ceiling	Classroom	Lay-In/Drop		6	763	SF	\$1,637	
Ceiling	Classroom	Lay-In/Drop		6	835	SF	\$1,791	
Ceiling	Classroom	Lay-In/Drop		6	777	SF	\$1,667	
Ceiling	Classroom	Lay-In/Drop		6	825	SF	\$1,770	
Ceiling	Classroom	Lay-In/Drop		6	801	SF	\$1,718	
Ceiling	Classroom	Lay-In/Drop		4	735	SF	\$6,937	
Ceiling	Classroom	Lay-In/Drop		4	735	SF	\$6,937	
Ceiling	Classroom	Lay-In/Drop		6	1,530	SF	\$3,282	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Floor	Classroom	Floor		6	1,133	SF	\$4,861	
Floor	Classroom	Floor		6	1,133	SF	\$4,861	
Floor	Classroom	Tile/Sheet		6	777	SF	\$1,111	
Floor	Classroom	Tile/Sheet		6	782	SF	\$1,118	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	835	SF	\$1,194	
Floor	Classroom	Tile/Sheet		6	763	SF	\$1,091	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
Floor	Classroom	Tile/Sheet		6	825	SF	\$1,180	
Floor	Classroom	Tile/Sheet		6	801	SF	\$1,145	
Floor	Classroom	Tile/Sheet		6	1,530	SF	\$2,188	
Floor	Classroom	Tile/Sheet		6	782	SF	\$1,118	
Floor	Classroom	Tile/Sheet		6	735	SF	\$1,051	
LIBRARY_CEILING	Library	Drop/Lay-In	2nd Floor	6	1,527	SF	\$3,275	
LIBRARY_WALL	Library	Plaster/Drywall	2nd Floor	6	1,749		\$4,127	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	13	EA	\$4,833	
Lighting	Classroom	Lay-In		4	13	EA	\$4,833	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Lighting	Classroom	Lay-In		4	12	EA	\$4,462	
Lighting	Classroom	Lay-In		4	12	EA	\$4,462	
Lighting	Classroom	Lay-In		4	12	EA	\$4,462	
Lighting	Classroom	Lay-In		4	12	EA	\$4,462	
Lighting	Classroom	Lay-In		4	20	EA	\$7,436	
Lighting	Classroom	Lay-In		4	10	EA	\$3,718	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
RESTROOM_FLOOR	Children's Standard Student Restroom	Restroom Floor	3rd Floor Girl's Room	6	227	SF	\$578	
RESTROOM_LIGHT	Early Childhood Student Restroom	Restroom Lighting	Kindergarten Room 303	4	1	EA	\$322	
RESTROOM_LIGHT	Early Childhood Student Restroom	Restroom Lighting	Kindergarten Room 301	4	1	EA	\$322	
RESTROOM_LIGHT	Staff Restroom	Restroom Lighting	In Principal's Office	4	1	EA	\$322	
Wall	Classroom	Concrete Block		6	274	SF	\$784	
Wall	Classroom	Concrete Block		6	135	SF	\$386	
Wall	Classroom	Concrete Block		6	308	SF	\$881	
Wall	Classroom	Concrete Block		6	284	SF	\$812	
Wall	Classroom	Concrete Block		6	499	SF	\$1,427	
Wall	Classroom	Concrete Block		6	284	SF	\$812	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		6	439	SF	\$1,256	
Wall	Classroom	Concrete Block		6	140	SF	\$400	
Wall	Classroom	Concrete Block		6	140	SF	\$400	
Wall	Classroom	Concrete Block		6	499	SF	\$1,427	
Wall	Classroom	Concrete Block		6	284	SF	\$812	
Wall	Classroom	Concrete Block		6	284	SF	\$812	
Wall	Classroom	Concrete Block		6	135	SF	\$386	
Wall	Classroom	Concrete Block		6	284	SF	\$812	
Wall	Classroom	Concrete Block		6	232	SF	\$664	
Wall	Classroom	Concrete Block		6	284	SF	\$812	
Wall	Classroom	Concrete Block		6	284	SF	\$812	
Wall	Classroom	Concrete Block		6	284	SF	\$812	
Wall	Classroom	Concrete Block		6	284	SF	\$812	
Wall	Classroom	Concrete Block		6	232	SF	\$664	
Wall	Classroom	Metal/Folding Panel		6	499	SF	\$1,177	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	992	SF	\$2,341	
Wall	Classroom	Metal/Folding Panel		6	745	SF	\$1,758	
Wall	Classroom	Metal/Folding Panel		6	395	SF	\$932	
Wall	Classroom	Metal/Folding Panel		6	854	SF	\$2,015	
Wall	Classroom	Metal/Folding Panel		6	991	SF	\$2,338	
Wall	Classroom	Metal/Folding Panel		6	991	SF	\$2,338	
Wall	Classroom	Metal/Folding Panel		6	499	SF	\$1,177	
Wall	Classroom	Metal/Folding Panel		6	889	SF	\$2,098	
Wall	Classroom	Metal/Folding Panel		6	889	SF	\$2,098	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Metal/Folding Panel		6	639	SF	\$1,508	
Wall	Classroom	Plaster/Drywall		6	205	SF	\$484	
Wall	Classroom	Plaster/Drywall		6	539	SF	\$1,272	
Wall	Classroom	Plaster/Drywall		6	212	SF	\$500	

ROOM Sub Total \$284,893

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Building Annex Sub Total							\$2,156,134	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	throughout site	7	4	EA	\$0	
Civil/Drainage		Site Drain	below grade at retention walls	7	3	EA	\$0	
Civil/Drainage		Site Manhole	throughout site	7	3	EA	\$0	
Fencing		Chain Link	throughout site	7	50	LF	\$0	
Fencing		Ornamental Iron	north gate	5	10	LF	\$623	bent gate
Fencing		Ornamental Iron	throughout site	6	2,112	LF	\$39,866	paint
Landscape		Asphalt Play Area/Hardscape	S site	6	17,724	SF	\$15,207	seal coat and cracks
Landscape		Grass	throughout site	7	32,418	SF	\$0	
Landscape		Grass	N grassy area	5	16	SF	\$21	repair sink hole
Landscape		Hardscape - Concrete	courtyard	7	5,274	SF	\$0	
Landscape		Hardscape - Concrete	E elevation	7	793	SF	\$0	
Landscape		Parkway trees	throughout site perimeter	7	29	EA	\$0	
Landscape		Planting Beds/ Areas	throughout site	7	3,300	SF	\$0	
Landscape		Retaining Wall - Concrete	throughout site	7	1,064	SF	\$0	
Landscape		Walking Path - Crushed Stone	S site	7	1,375	SF	\$0	
Parking Lot		Asphalt	N site	5	29,848	SF	\$84,512	repair cracks and seal coat
Parking Lot		Concrete Curbs	N site	7	187	LF	\$0	
Parking Lot		Lights, Pole Mounted	N site	7	4	EA	\$0	
Parking Lot		Lights, Pole Mounted	S site	7	4	EA	\$0	
Parking Lot		Parking lot interior plantings	N site	7	60	LF	\$0	
Parking Lot		Trash Enclosure	N site	7	952	SF	\$0	
Parking Lot		Vehicular Screening	N site	7	240	LF	\$0	
Playground		Playground - Swingset	S site	5	1	EA	\$0	missing swings
Playground		Playground Equipment - Pre-K 3-5	S & E site	7	2	EA	\$0	
Playground		Playground Equipment - School Age 5-12	S site	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	E site	7	1,581	SF	\$0	
Playground		Playground Surfacing - Wood Chips	S site play area	4	4,790	SF	\$30,824	
Sidewalks		Internal Walks	throughout site	7	405	LF	\$0	
Sidewalks		Perimeter Sidewalks	NE site perimeter	4	100	SF	\$1,888	
Sidewalks		Perimeter Sidewalks	throughout site perimeter	7	13,335	SF	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Signage		Flag Pole	E site	7	1	EA	\$0	
Signage		Flag Pole	W site	6	1	EA	\$0	paint
Signage		Marquee - Free Standing Back Lighted	SE site	7	1	EA	\$0	
SITE Sub Total							\$172,940	
SITE Sub Total							\$172,940	

Total Campus Need ^{2 3} \$4,299,284

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
110	721	0	0	4	50	136	42	2	N	Y	Y	Classroom		
112	721	0	0	4	50	136	42	2	N	Y	Y	Classroom		
117	721	0	4	6	50	170	70	2	N	N	Y	Classroom		
118	721	0	0	4	50	170	70	0	N	N	Y	Classroom		
119	721	0	0	4	50	170	70	1	N	N	Y	Classroom		
120	721	0	0	4	50	153	56	1	N	N	Y	Classroom		
122	721	0	0	4	50	153	56	1	N	N	Y	Classroom		
210	721	0	0	4	50	136	42	2	N	N	Y	Classroom		
211	721	1	16	44	50	170	70	2	N	N	Y	Classroom		
212	721	0	0	4	50	136	42	2	N	N	Y	Classroom		
213	721	1	16	40	50	136	56	2	N	N	Y	Classroom		
214	721	0	0	4	50	170	70	0	N	N	Y	Classroom		
215	721	1	0	4	50	170	70	0	N	N	N	Classroom		
216	721	0	0	4	50	170	70	0	N	N	Y	Classroom		
217	721	0	4	6	50	170	70		N	N	Y	Classroom		
218	721	0	0	4	50	170	70	0	N	N	Y	Classroom		
219	721	0	4	6	50	170	70		N	N	Y	Classroom		
220	721	0	0	4	50	170	70	0	N	N	Y	Classroom		
222/224	1156	0	0	14	50	204	70	0	N	N	Y	Classroom		
Other	468			6					N	N	Y	Administrative Suites/Offices		Room 206
Other	276								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor South Boy's Room
Other	1357								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor- 114/116
Other	2080								N	N	N	Auditorium & Theater	Auditorium - Dedicated	1st Floor
Other	135			6					N	N	N	Administrative Suites/Offices		Principal's Office
Other	421			6					N	N	N	Administrative Suites/Offices		Main Office
Other	86			4					N	N	N	Administrative Suites/Offices		Kitchen Office/Store Room
Other	424								N	N	N	Kitchen	Warming Kitchen	1st Floor
Other	368			2					N	N	Y	Administrative Suites/Offices		Gym Office
Other	468			6					N	N	Y	Administrative Suites/Offices		Room 108 (Clinic)
Other	276								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor North Boy's Room
Other	390			4					N	N	N	Administrative Suites/Offices		Teacher's Lounge Room 124
Other	276								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor South Boy's Room
Other	276								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor North Boy's Room
Other	83								N	N	N	Restroom	Staff Restroom	2nd Floor Unisex Staff Restroom
Other	83								N	N	N	Restroom	Staff Restroom	1st Floor South Unisex Staff Restroom

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	304								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor South Girl's Room
Other	304								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor South Girl's Room
Other	304								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor North Girl's Room
Other	304								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor North Girl's Room
Other	141			2					N	N	N	Administrative Suites/Offices		Room 232, Office
Other	1253								N	N	N	Library		1st Floor
Other	2791								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	78			4					N	N	Y	Administrative Suites/Offices		Engineer's Office
Other	40								N	N	N	Restroom	Staff Restroom	In Engineer's Office

Building: Annex

301	1133	0	0	8	50	75	0	0	N	N	Y	Classroom		
302	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
303	1133	0	0	8	50	75	0	0	N	N	Y	Classroom		
304	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
401	782	0	0	8	50	75	0	1	N	N	Y	Classroom		
403	763	0	0	8	50	75	0	0	N	N	Y	Classroom		
404	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
405	763	0	0	8	50	75	0	0	N	N	Y	Classroom		
406	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
407	835	0	0	8	50	100	0	0	N	N	Y	Classroom		
409	777	0	0	8	50	100	0	0	N	N	Y	Classroom		
501	782	0	0	8	50	75	0	1	N	N	Y	Classroom		
502	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
503/505	1530	0	32	92	50	150	0	0	N	N	Y	Classroom		
504	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
506	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
507	801	0	0	8	50	0	0	1	N	N	Y	Classroom		
508	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
509	825	0	0	8	50	25	0	0	N	N	Y	Classroom		
510	735	0	1	8	50	128	0	0	N	N	Y	Classroom		
Other	20								N	N	N	Restroom	Early Childhood Student Restroom	Kindergarten Room 303
Other	469			8					N	N	Y	Administrative Suites/Offices		Main Office
Other	227								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Girl's Room
Other	25								N	N	N	Restroom	Staff Restroom	In Principal's Office
Other	219			6					N	N	N	Administrative Suites/Offices		Principal's Office
Other	42								N	N	N	Restroom	Staff Restroom	1st Floor

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	42								N	N	N	Restroom	Staff Restroom	2nd Floor
Other	42								N	N	N	Restroom	Staff Restroom	3rd Floor
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Boy's Room
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Boy's Room
Other	230								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Boy's Room
Other	227								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Girl's Room
Other	1527								N	N	N	Library		2nd Floor
Other	475								N	N	N	Kitchen	Warming Kitchen	1st Floor
Other	2435								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	1st Floor
Other	20								N	N	N	Restroom	Early Childhood Student Restroom	Kindergarten Room 301
Other	227								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Girl's Room