

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

Rank 7: The item/system is new or in good condition and no work is required.

Rank 6: The item/system requires general cleaning and/or routine maintenance.

Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.

Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.

Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.

Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.

Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main

Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	West Façade	6	100	LF	\$50,050	
Chimney		Brick Chimney - Concrete/ Mortar Liner	West Façade	5	45	LF	\$80,438	
Cornice		Cornice - Masonry Projecting/Limestone	Entire Building	6	780	LF	\$23,925	
Cornice		Cornice - Metal Projecting	Entire Building	6	1,700	LF	\$152,424	
Doors		Exterior Steel Door	West #3	4	1	EA	\$3,303	
Doors		Exterior Steel Door	Entries 2, 6, 8	7	10	EA	\$0	
Doors		Exterior Steel Door	Entries 1, 4, 5, 7, 9	6	10	EA	\$3,303	
Doors		Transom Lite	Entries 2, 8	7	95	EA	\$0	
Doors		Transom Lite	Entries 1, 4	6	70	EA	\$19,820	
Doors		Transom Lite	West #3	4	25	EA	\$70,785	
Entrance		Concrete Exterior Stairs	Entire Building	6	150	LF	\$16,088	
Entrance		Concrete Exterior Stairs	East Assembly Door	5	20	LF	\$6,435	
Entrance		Entrance Controls - Audio and Video	East Main Door and West #5	7	2	EA	\$0	
Entrance		Stone Stairs	West Door #3	6	3	LF	\$536	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Escape		Fire Escapes	North Façade	6	2	LF	\$204	
Foundation		Masonry Foundation	Basement	7	26,000	SF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	9	EA	\$1,931	
Lintels		Lintels - Brick	Courtyards	7	32	LF	\$0	
Lintels		Lintels - Steel	Entire Building	6	950	LF	\$35,864	
Lintels		Lintels - Steel	West Elevation- center portion	4	125	LF	\$54,519	
Parapet		Coping - Metal	West Elevation and lower roofs	7	425	LF	\$0	
Parapet		Coping - Stone	Main Roofs	6	950	LF	\$0	
Parapet		Parapet > 30" Height	Roof A- Gym Roof	5	140	LF	\$56,156	
Parapet		Parapet 16" to 30" Height	Roofs E and F	7	205	LF	\$0	
Parapet		Parapet 16" to 30" Height	Lower Roofs	6	200	LF	\$41,527	
Parapet		Parapet 16" to 30" Height	Roofs B, C, D- Main Roof	5	800	LF	\$256,714	
Roof System		EPDM/ Synthetic Rubber Roof	Roofs	6	29,250	SF	\$146,396	
Roof System		Exterior Downspouts	Entire Building	6	100	LF	\$1,859	
Roof System		Interior Downspouts	Entire Building	6	220	LF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roofs	7	29,250	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	73,000	SF	\$0	
Walls		Brick	Entire Building	7	28,275	SF	\$0	
Walls		Brick	Boiler, West Engine Room over lintels, East Assembly Doors, and South East Doors	6	3,600	SF	\$23,784	
Walls		Brick	West Boiler windows and over West Lintels	5	400	SF	\$9,060	
Walls		Prefabricated Metal Panel Wall	Metal Signs at East Doors 1 and 2	5	60	SF	\$1,716	
Walls		Stone - Cut	Entire Building	6	2,900	SF	\$41,470	
Windows		Skylite - Glass Double-Pane	Main Roofs	7	208	SF	\$0	
Windows		Window - Guards perforated	Entire Building	6	4,570	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	6	11,775	SF	\$101,030	
EXTERIOR Sub Total							\$1,199,336	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Boiler Room	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	5	14,810	SF	\$18,637	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	5	7,656	SF	\$8,758	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	5	2,092	SF	\$2,992	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	17	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st & 2nd Floor	7	8	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	6	EA	\$0	
Emergency System		Public Announcement System	Entire Building	7	73,000	SF	\$0	
Emergency System		Security System - CCTV	Entire Building	5	73,000	SF	\$208,780	No working cameras inside. More cameras needed outside.
Emergency System		Security System - Intrusion detection	Entire Building	7	73,000	SF	\$0	
Emergency System		UPS 60 KW and above	Engineer's Office	2	1	EA	\$135,850	Batteries Removed.
Main Service		Main Electrical service 2000 A 120/208/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	2nd Floor	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	Boiler Room	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	1st Floor	7	8	EA	\$0	
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	
Power Distribution		Lighting and power panels	2nd Floor	7	2	EA	\$0	
Power Distribution		Lighting and power panels	3rd Floor	7	2	EA	\$0	
Power Distribution		Lighting and power panels	3rd Floor	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	1st Floor	4	3	EA	\$16,302	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	2	EA	\$0	

ELECTRICAL Sub Total \$419,204

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	1st Floor	7	73,000	SF	\$0	
Fire Alarm		Fire Alarm System	Boiler Room	6	73,900	SF	\$89,825	

FIRE PROTECTION Sub Total \$89,825

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	1st Floor	6	28	EA	\$6,006	
Air Conditioning		Window A/C Unit	2nd Floor	6	14	EA	\$3,003	
Air Conditioning		Window A/C Unit	1st Floor	4	1	EA	\$2,145	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	5	1	EA	\$16,016	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	4	1	EA	\$26,169	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	6	1	EA	\$1,430	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	1st Floor	3	3	EA	\$278,850	Pipe type coils. Motor>25 Years Old. Coils leak in winter. Control dampers won't work.
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	1st Floor	4	3	EA	\$98,670	Unit deteriorated. Control dampers not working. Pre-heat coil leaks in winter.
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	1st Floor	4	300	LF	\$536,250	Missing systems
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 151 - 200 HP	Boiler Room	4	2	EA	\$331,760	
Boiler Systems		Boiler Auxiliary - Steam Boiler 151 - 200 HP	Boiler Room	4	2	EA	\$48,620	Leaking
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	7	1	EA	\$0	
Boiler Systems		Combustion Dampers	Boiler Room	7	2	EA	\$0	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	5	1	EA	\$19,305	Tank shows signs of rust.
Heating Devices		Fin Tube Hot Water	2nd & 3rd Floors	5	40	LF	\$3,432	
Heating Devices		Fin Tube Hot Water	2nd Floor	5	20	LF	\$1,716	
Heating Devices		Radiators - Steam	1st Floor	4	1	EA	\$1,401	
Heating Devices		Radiators - Steam	2nd Floor	5	8	EA	\$5,262	
Heating Devices		Unit Heater - Gas	1st Floor	6	1	EA	\$2,145	
Heating Devices		Unit Heater - Gas	Boiler Room	6	1	EA	\$2,145	
Heating Devices		Wall Heater - Electric	Entire Building	6	13	EA	\$1,338	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	1st Floor	5	1	EA	\$9,438	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	1st Floor	6	2	EA	\$1,430	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	5	500	LF	\$16,266	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	500	LF	\$24,739	
Temperature Control		Pneumatic System	Boiler Room	4	73,000	SF	\$521,950	Lines and compressor in working order. Gauges at air handlers not connected. Control actuators not connected. Manually adjusted.
Temperature Control		Thermostats - Pneumatic	Entire Building	5	40	EA	\$22,308	
Temperature Control		Thermostats - Pneumatic	Boiler Room	7	1	EA	\$0	
Temperature Control		Zone Dampers	Entire Building	3	40	EA	\$33,748	Linkage not connected. Actuators failing.
Ventilation		Exhaust Fan - Indoor	1st Floor	6	3	EA	\$1,502	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	4	2	EA	\$8,580	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	4	1	EA	\$2,288	
MECHANICAL Sub Total							\$2,027,913	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	2	EA	\$8,294	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	73,000	SF	\$24,010	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	73,000	SF	\$46,976	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	73,000	SF	\$15,659	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	73,000	SF	\$33,405	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	73,000	SF	\$39,668	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	73,000	SF	\$174,331	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	73,000	SF	\$83,512	
Piping		Sanitary Piping	Entire Building	5	73,000	SF	\$44,888	
Piping		Storm Piping	Entire Building	5	73,000	SF	\$34,449	
Piping		Vent Piping	Entire Building	5	73,000	SF	\$26,098	
Pumps		Domestic Booster Pump simplex	Boiler Room	4	1	EA	\$17,160	>20 Years Old
PLUMBING Sub Total							\$548,448	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	kitchen staff office	6	222	SF	\$629	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	principals office in 109	6	294	SF	\$832	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	in 213 small kitchen	7	110	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	213 teachers lounge	7	595	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Assistant Principals office rm 113	7	494	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office rm109	7	540	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Engineers Office Rm 106	7	341	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office rm109	7	400	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	principals office in 109	6	294	SF	\$420	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office rm109	6	140	SF	\$200	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in 213 small kitchen	6	110	SF	\$157	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	kitchen staff office	6	222	SF	\$317	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Engineers Office Rm 106	7	341	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Assistant Principals office rm 113	7	494	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	213 teachers lounge	6	595	SF	\$4,492	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	kitchen staff office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Assistant Principals office rm 113	7	10	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office rm109	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	principals office in 109	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Engineers Office Rm 106	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	in 213 small kitchen	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	213 teachers lounge	7	13	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Engineers Office Rm 106	7	243	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Assistant Principals office rm 113	6	1,118	SF	\$2,638	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	kitchen staff office	6	936	SF	\$2,208	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office rm109	6	1,072	SF	\$2,529	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	in 213 small kitchen	6	595	SF	\$1,404	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Engineers Office Rm 106	6	884	SF	\$2,086	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	principals office in 109	6	942	SF	\$2,223	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	213 teachers lounge	6	1,155	SF	\$2,725	
Auditorium - Dedicated		Main Floor Seating	lunchroom/auditorium	5	197	EA	\$23,928	
Corridor		Stair Handrails	gym	6	45	LF	\$0	
Corridor		Stairs - Asphalt	gym	5	24	LF	\$1,201	
Doors		Interior Steel Doors incl hw	Entire Building	7	3	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	4	EA	\$1,133	
Doors		Interior Wood Doors incl hw	Entire Building	4	48	EA	\$154,028	
Doors		Interior Wood Doors incl hw	Entire Building	5	24	EA	\$11,326	
Doors		Interior Wood Doors incl hw	Entire Building	6	35	EA	\$9,910	
Doors		Interior Wood Doors incl hw	Entire Building	7	4	EA	\$0	
Doors		Side-lite	Entire Building	6	84	SF	\$1,562	
Doors		Transom Window	Entire Building	6	545	SF	\$10,132	
Drinking Fountains	Corridors	Double Fountain	3rd Floor	7	3	EA	\$0	
Drinking Fountains	Corridors	Double Fountain	1st Floor	7	9	EA	\$0	
Drinking Fountains	Corridors	Double Fountain	2nd Floor	7	3	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	2nd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	2nd Floor	6	2,945	SF	\$25,184	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	2nd Floor	6	2,865	SF	\$21,632	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	2nd Floor	7	9	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	2nd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	2nd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	2nd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	2nd Floor	5	3,930	SF	\$56,199	
Kitchen	Warming Kitchen	Ceiling - Plaster/Drywall	in lunchroom/ auditorium	6	660	SF	\$2,492	
Kitchen	Warming Kitchen	Flooring - Tile/Sheet	in lunchroom/ auditorium	6	660	SF	\$944	
Kitchen	Warming Kitchen	Lighting - Pendant/Surface	in lunchroom/ auditorium	7	7	SF	\$0	
Kitchen	Warming Kitchen	Wall - Plaster/Drywall	in lunchroom/ auditorium	6	1,625	SF	\$3,834	
Kitchen	Warming Kitchen	Wall - Structural Glazed Tile	in lunchroom/ auditorium	6	175	SF	\$1,251	
Locker/Shower Room	Staff Restroom	Benches	3rd floor ladies			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor mens			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in 110			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor staff			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Engineers Bathroom in Office 106			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in main office 109			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	kitchen staff			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor ladies			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor ladies			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	kitchen staff			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in main office 109			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Engineers Bathroom in Office 106			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor staff			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in 110			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor ladies			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor ladies			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in 110			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor staff			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Engineers Bathroom in Office 106			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in main office 109			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	kitchen staff			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor ladies			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys			EA	\$0	
Lunchroom	Multipurpose Room	Ceiling - Plaster/Drywall	Lunchroom/Auditorium	7	3,883	SF	\$0	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	Lunchroom/Auditorium	6	3,055	SF	\$4,369	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	Lunchroom/Auditorium	7	30	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	Lunchroom/Auditorium	6	30	SF	\$21	
Lunchroom	Multipurpose Room	Serving Line	Lunchroom/Auditorium			LF	\$0	
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	Lunchroom/Auditorium	6	2,773	SF	\$6,543	
MDF/IDF		Finishes	in Library-104	6	83	SF	\$282	
MDF/IDF		Ventilation and Cooling	in Library- 104	5	1	EA	\$7,007	
Mechanical/Service Rooms		Boiler Room	1st Floor	6	1,250	SF	\$5,899	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	4	SF	\$19	
Mechanical/Service Rooms		Mechanical/Service Rooms	in Main Office rm 109- water main/storage	5	20	SF	\$227	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	6	3,618	SF	\$17,073	
Mechanical/Service Rooms		Storage Room	1st Floor	7	318	SF	\$0	
Mechanical/Service Rooms		Storage Room	313	6	595	SF	\$2,808	
Mechanical/Service Rooms		Storage Room	in Library- 104	7	63	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor boys	6	360	SF	\$2,780	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys	6	360	SF	\$2,780	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Accessories	3rd floor ladies	7	110	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls	7	330	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor girls	7	330	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd floor mens	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor ladies	7	41	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	in 110	7	22	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys	6	360	SF	\$2,780	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls	7	330	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	kitchen staff	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor staff	7	110	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Engineers Bathroom in Office 106	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in main office 109	6	33	SF	\$255	
Staff Restroom	Staff Restroom	Ceiling - Exposed	3rd floor mens	6	36	SF	\$68	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Engineers Bathroom in Office 106	6	45	SF	\$127	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in main office 109	7	33	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys	6	360	SF	\$1,019	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor staff	6	110	SF	\$311	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls	5	330	SF	\$1,869	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	6	360	SF	\$1,019	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	6	360	SF	\$1,019	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	6	330	SF	\$934	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	in 110	6	22	SF	\$62	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd floor ladies	7	110	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	kitchen staff	6	60	SF	\$170	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor ladies	6	41	SF	\$116	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in 110			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys	6	1	EA	\$300	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor boys	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor staff			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor ladies			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor ladies			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	kitchen staff			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in main office 109			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Engineers Bathroom in Office 106			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor boys	7	360	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls	6	330	SF	\$840	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys	7	360	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys	7	360	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls	6	330	SF	\$840	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor girls	6	330	SF	\$840	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	in 110	7	22	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in main office 109	6	33	SF	\$47	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	kitchen staff	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in main office 109			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor ladies			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor mens			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in 110			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Engineers Bathroom in Office 106			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	kitchen staff			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor ladies			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor staff			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd floor ladies	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor ladies	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in 110	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	1st floor staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Engineers Bathroom in Office 106	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in main office 109	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	kitchen staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd floor ladies	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls	7	9	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys	6	9	SF	\$6	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys	6	9	SF	\$6	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd floor girls	6	9	SF	\$6	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd floor boys	6	9	SF	\$6	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls	6	9	SF	\$6	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor staff	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Engineers Bathroom in Office 106	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in main office 109	6	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	kitchen staff	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd floor ladies	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	3rd floor mens	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Partitions	3rd floor mens	6	1	EA	\$179	
Staff Restroom	Staff Restroom	Partitions	in main office 109	5	1	EA	\$572	
Staff Restroom	Staff Restroom	Partitions	3rd floor ladies	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor girls	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	7	6	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	in 110			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Engineers Bathroom in Office 106			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	kitchen staff			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd floor ladies	6	1	EA	\$179	
Staff Restroom	Staff Restroom	Partitions	1st floor staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor staff			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys	7	4	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd floor ladies			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in 110			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Engineers Bathroom in Office 106			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in main office 109			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	kitchen staff			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor ladies			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	3rd floor girls	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd floor boys	6	150	SF	\$429	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Engineers Bathroom in Office 106	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	3rd floor boys	7	150	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st floor girls	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd floor mens	5	435	SF	\$2,053	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd floor boys	6	865	SF	\$2,041	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd floor girls	6	1,055	SF	\$2,489	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor boys	6	865	SF	\$2,041	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor boys	6	1,015	SF	\$2,395	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor girls	6	1,055	SF	\$2,489	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd floor ladies	6	595	SF	\$1,404	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor staff	6	630	SF	\$1,486	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Engineers Bathroom in Office 106	6	210	SF	\$495	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in main office 109	6	258	SF	\$609	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	kitchen staff	6	415	SF	\$979	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd floor ladies	6	350	SF	\$826	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor girls	6	1,025	SF	\$2,418	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	in 110	6	75	SF	\$177	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	kitchen staff	6	50	SF	\$358	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	in 110	7	70	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	kitchen staff	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd floor mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	7	6	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in 110	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor staff	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd floor ladies	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Engineers Bathroom in Office 106	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in main office 109	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Water Closet	2nd floor ladies	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
INTERIOR Sub Total							\$437,791	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	45	LF	\$1,609	
Casework	Classroom	Casework		5	7	LF	\$1,251	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	24	LF	\$4,290	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	5	LF	\$894	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	10	LF	\$1,788	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	14	LF	\$2,503	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Ceiling	Classroom	Plaster/Drywall		6	860	SF	\$2,435	
Ceiling	Classroom	Plaster/Drywall		6	765	SF	\$2,166	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	816	SF	\$2,310	
Ceiling	Classroom	Plaster/Drywall		7	816	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	1,480	SF	\$4,190	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		7	810	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		7	810	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	765	SF	\$2,166	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		6	765	SF	\$2,166	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		7	765	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Ceiling	Classroom	Plaster/Drywall		7	810	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	810	SF	\$2,293	
Chalk Board	Classroom	Chalk Board		4	23	LF	\$2,796	
Chalk Board	Classroom	Chalk Board		4	28	LF	\$3,403	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	23	LF	\$2,796	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4	29	LF	\$3,525	
Chalk Board	Classroom	Chalk Board		4	23	LF	\$2,796	
Chalk Board	Classroom	Chalk Board		4	19	LF	\$2,309	
Chalk Board	Classroom	Chalk Board		4	7	LF	\$851	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Multipurpose Room	Chalk Board	Lunchroom/Auditorium	4		LF		
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Corridors	Corridors	Asphalt	2nd Floor	6	4,275	SF	\$6,113	
Corridors	Corridors	Asphalt	3rd Floor	5	4,075	SF	\$46,152	
Corridors	Corridors	Asphalt	1st floor vestibules	5	494	SF	\$5,595	
Corridors	Corridors	Drinking Fountains	1st floor vestibules			EA	\$0	
Corridors	Corridors	Drinking Fountains	stair 1			EA	\$0	
Corridors	Corridors	Drinking Fountains	stair 5			EA	\$0	
Corridors	Corridors	Drinking Fountains	stair 2			EA	\$0	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	4,075	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	4,236	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor vestibules	7	409	EA	\$0	
Corridors	Corridors	Pendant/Surface	3rd Floor	7	4,075	EA	\$0	
Corridors	Corridors	Pendant/Surface	stair 1	7	770	EA	\$0	
Corridors	Corridors	Pendant/Surface	stair 5	7	560	EA	\$0	
Corridors	Corridors	Pendant/Surface	stair 2	7	600	EA	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	5,730	SF	\$13,520	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	6,220	SF	\$14,676	
Corridors	Corridors	Plaster/Drywall	stair 2	6	2,545	SF	\$6,005	
Corridors	Corridors	Plaster/Drywall	stair 5	6	2,360	SF	\$5,568	
Corridors	Corridors	Plaster/Drywall	stair 1	6	2,910	SF	\$6,866	
Corridors	Corridors	Plaster/Drywall	3rd Floor	6	6,220	SF	\$14,676	
Corridors	Corridors	Plaster/Drywall	1st floor vestibules	5	535	SF	\$2,525	
Corridors	Corridors	Stair Handrails	1st floor vestibules			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	stair 1	6	96	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stair Handrails	stair 5	6	85	LF	\$0	
Corridors	Corridors	Stair Handrails	stair 2	6	81	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st floor vestibules			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor vestibules	6	552	SF	\$3,947	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	stair 2			EA	\$0	
Corridors	Corridors	Student Lockers	stair 5			EA	\$0	
Corridors	Corridors	Student Lockers	stair 1			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor vestibules			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	4,236	SF	\$6,057	
Corridors	Corridors	Tile/Sheet Flooring	stair 2	6	309	SF	\$442	
Corridors	Corridors	Tile/Sheet Flooring	stair 5	6	170	SF	\$243	
Corridors	Corridors	Tile/Sheet Flooring	stair 1	6	349	SF	\$499	
Corridors Ceiling	Corridors	Plaster/Drywall	1st floor vestibules	6	494	SF	\$1,399	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	6	4,075	SF	\$11,538	
Corridors Ceiling	Corridors	Plaster/Drywall	stair 1	6	770	SF	\$2,180	
Corridors Ceiling	Corridors	Plaster/Drywall	stair 5	6	560	SF	\$1,586	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	6	4,236	SF	\$11,994	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	6	4,075	SF	\$11,538	
Corridors Ceiling	Corridors	Plaster/Drywall	stair 2	6	600	SF	\$1,699	
Stairs	Corridors	Asphalt	stair 1	5	101	SF	\$5,055	
Stairs	Corridors	Asphalt	stair 5	5	92	SF	\$4,605	
Stairs	Corridors	Asphalt	stair 2	5	84	SF	\$4,204	
Floor	Classroom	Tile/Sheet		6	179	SF	\$256	
Floor	Classroom	Tile/Sheet		6	810	SF	\$1,158	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		7	810	SF	\$0	
Floor	Classroom	Wood		5	765	SF	\$10,830	
Floor	Classroom	Wood		5	765	SF	\$10,830	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		6	810	SF	\$6,116	
Floor	Classroom	Wood		5	765	SF	\$10,830	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		6	860	SF	\$6,493	
Floor	Classroom	Wood		6	765	SF	\$5,776	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		7	810	SF	\$0	
Floor	Classroom	Wood		7	1,480	SF	\$0	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		7	612	SF	\$0	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		6	810	SF	\$6,116	
Floor	Classroom	Wood		6	810	SF	\$6,116	
Floor	Classroom	Wood		6	810	SF	\$6,116	
Floor	Classroom	Wood		6	810	SF	\$6,116	
Floor	Classroom	Wood		5	810	SF	\$11,467	
Floor	Classroom	Wood		7	816	SF	\$0	
GYM_FLOOR	Standard Dedicated Gymnasium	Gymnasia Floor	2nd Floor	5	90	SF	\$1,444	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
LUNCH_FLOOR	Multipurpose Room	Lunchroom Floor	Lunchroom/Auditorium	5	828	SF	\$4,689	
LUNCH_LIGHT	Multipurpose Room	Lunchroom Lighting	Lunchroom/Auditorium	7	6	EA	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		6	22	LF	\$629	
Marker Board	Classroom	Marker Board		7	22	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	10	LF	\$0	
Marker Board	Multipurpose Room	Marker Board	Lunchroom/Auditorium			LF	\$0	
Marker Board	Classroom	Marker Board		7	21	LF	\$0	
Marker Board	Classroom	Marker Board		6	6	LF	\$172	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	
Marker Board	Classroom	Marker Board		7	50	LF	\$0	
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	1st floor girls	6	330	SF	\$934	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	3rd floor mens	5	36	SF	\$566	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	1st floor staff	5	110	SF	\$1,730	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	Engineers Bathroom in Office 106	6	45	SF	\$115	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	2nd floor ladies	6	41	SF	\$104	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	3rd floor ladies	5	110	SF	\$1,730	
RESTROOM_LIGHT	Early Childhood Student Restroom	Restroom Lighting	in 110			EA	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd floor girls	7	60	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,678	SF	\$3,959	
Wall	Classroom	Plaster/Drywall		6	1,320	SF	\$3,115	
Wall	Classroom	Plaster/Drywall		6	1,330	SF	\$3,138	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,440	SF	\$3,398	
Wall	Classroom	Plaster/Drywall		6	1,320	SF	\$3,115	
Wall	Classroom	Plaster/Drywall		6	1,345	SF	\$3,174	
Wall	Classroom	Plaster/Drywall		6	1,325	SF	\$3,126	
Wall	Classroom	Plaster/Drywall		6	1,310	SF	\$3,091	
Wall	Classroom	Plaster/Drywall		6	1,440	SF	\$3,398	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		5	1,350	SF	\$6,371	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,345	SF	\$3,174	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,310	SF	\$3,091	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,325	SF	\$3,126	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	
Wall	Classroom	Plaster/Drywall		6	1,445	SF	\$3,409	
Wall	Classroom	Plaster/Drywall		6	1,360	SF	\$3,209	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		5	1,360	SF	\$6,418	
Wall	Classroom	Plaster/Drywall		6	1,440	SF	\$3,398	
ROOM Sub Total							\$741,336	
Building Main Sub Total							\$5,463,854	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	2	EA	\$0	
Civil/Drainage		Site Drain	courtyards	7	2	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	7	EA	\$0	
Fencing		Chain Link	Fire Escape surround	5	36	LF	\$1,287	
Fencing		Chain Link	Door 5 and along alley at south site	6	60	LF	\$861	
Fencing		Ornamental Iron	Entire Site	6	357	LF	\$6,739	
Landscape		Asphalt Play Area/Hardscape	East Site	7	15,250	SF	\$0	
Landscape		Grass	Entire Site	7	450	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	1,698	SF	\$0	
Landscape		Parkway trees	Entire Site	7	9	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	1,450	SF	\$0	
Parking Lot		Asphalt	South lot of Building	4	50	SF	\$429	
Parking Lot		Asphalt	South West of Building	6	2,900	SF	\$2,488	
Parking Lot		Asphalt	West Lot	4	1,800	SF	\$15,444	
Playground		Playground Equipment - School Age 5-12	East Site	6	1	EA	\$0	
Playground		Playground Surfacing - Square Rubber Mats	East Site	4	2,200	SF	\$48,763	
Sidewalks		Perimeter Sidewalks	Entire Site	7	12,000	SF	\$0	
Signage		Flag Pole	East Façade	7	1	EA	\$0	
SITE Sub Total							\$76,011	
SITE Sub Total							\$76,011	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Total Campus Need ^{2 3}							\$5,539,864	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	810	2	3	12	40	140	72		N	N	Y	Classroom		
102	810	2	3	14	40	138	72		N	N	Y	Classroom		
103	810	2	3	14	40	120	60		N	N	Y	Classroom		
104	1480	1	13	40	40	265	102	4	N	N	N	Classroom		
110	816	2	1	12	40	126	60		N	N	Y	Classroom		
111	816	1	1	12	40	138	72		N	N	Y	Classroom		
112	810	2	4	16	40	118	59		N	N	N	Classroom		
201	810	2	3	16	40	105	34	2	N	N	Y	Classroom		
202	810	2	3	14	40	100	40	2	N	N	Y	Classroom		
203	810	2	3	14	40	100	40	2	N	N	Y	Classroom		
204	765	2	3	14	40	100	40	2	N	N	Y	Classroom		
205	765	1	9	20	40	120	60		N	N	Y	Classroom		
206	860	2	3	14	40	120	60		N	N	N	Classroom		
207	810	2	3	14	40	120	60		N	N	Y	Classroom		
208	810	2	3	14	40	120	60		N	N	Y	Classroom		
209	810	2	3	14	40	100	40	2	N	N	N	Classroom		
210	810	2	3	14	40	100	40	2	N	Y	Y	Classroom		
211	810	2	3	12	40	125	48	2	N	N	N	Classroom		
212	810	2	4	16	40	90	31	2	N	N	N	Classroom		
301	810	2	35	120	40	131	51	1	N	N	N	Classroom		
302	810	2	3	14	40	120	60		N	N	N	Classroom		
303	810	2	3	14	40	120	60		N	N	N	Classroom		
304	765	2	3	14	40	120	60		N	N	N	Classroom		
305	765	2	3	14	40	120	60		N	N	N	Classroom		
306	810	2	22	52	40	120	55	1	N	N	N	Classroom		
307	810	2	3	14	40	120	60		N	N	N	Classroom		
308	810	2	3	14	40	120	60		N	N	N	Classroom		
309	810	2	3	14	40	110	50	1	N	N	N	Classroom		
310	810	2	3	14	40	110	50	1	N	N	N	Classroom		
311	810	2	3	14	40	110	50	1	N	N	N	Classroom		
312	810	2	3	14	40	118	59		N	N	N	Classroom		
Other	595			14					N	N	N	Administrative Suites/Offices		213 teachers lounge
Other	330								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor girls
Other	560								N	N	N	Corridors		stair 5
Other	110								N	N	N	Restroom	Staff Restroom	3rd floor ladies
Other	360								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor boys

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	36								N	N	N	Restroom	Staff Restroom	3rd floor mens
Other	4075								N	N	N	Corridors		3rd Floor
Other	330								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls
Other	600								N	N	N	Corridors		stair 2
Other	41								N	N	N	Restroom	Staff Restroom	2nd floor ladies
Other	540			8					N	N	Y	Administrative Suites/Offices		Main Office rm109
Other	294			10					N	N	N	Administrative Suites/Offices		principals office in 109
Other	3883								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	Lunchroom/Auditorium
Other	45								N	N	N	Restroom	Staff Restroom	Engineers Bathroom in Office 106
Other	110								N	N	N	Restroom	Staff Restroom	1st floor staff
Other	660								N	N	N	Kitchen	Warming Kitchen	in lunchroom/ auditorium
Other	22								N	N	N	Restroom	Early Childhood Student Restroom	in 110
Other	222			4					N	N	Y	Administrative Suites/Offices		kitchen staff office
Other	2945								N	N	N	Gymnasia	Standard Dedicated Gymnasium	2nd Floor
Other	341			12					N	N	Y	Administrative Suites/Offices		Engineers Office Rm 106
Other	360								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys
Other	770								N	N	N	Corridors		stair 1
Other	494								N	N	N	Corridors		1st floor vestibules
Other	330								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls
Other	60								N	N	N	Restroom	Staff Restroom	kitchen staff
Other	4236								N	N	N	Corridors		1st Floor
Other	110			4					N	N	N	Administrative Suites/Offices		in 213 small kitchen
Other	33								N	N	N	Restroom	Staff Restroom	in main office 109
Other	4275								N	N	N	Corridors		2nd Floor
Other	360								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys
Other	494			3					N	N	Y	Administrative Suites/Offices		Assistant Principals office rm 113