

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	Top section	5	12	LF	\$21,450	
Chimney		Brick Chimney - Concrete/ Mortar Liner	Bottom section	6	36	LF	\$18,018	
Doors		Exterior Steel Door	Entire Building	6	7	EA	\$2,312	
Doors		Exterior Wood Door	Entire Building	3	10	EA	\$32,089	doors rotting and poor operation
Entrance		Concrete Exterior Stairs	Entire Building	6	780	LF	\$83,655	
Entrance		Concrete Exterior Stairs	Entrance 7	5	150	LF	\$48,263	
Entrance		Concrete Ramp	Entire Building	7	52	LF	\$0	
Entrance		Entrance Controls - Audio	East Entrances	6	1	EA	\$429	
Entrance		Stair Handrails	Entire Building	6	171	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	36,600	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	4	12	EA	\$44,616	
Lighting		Exterior Lights - Wall Mounted	Entire Building	5	13	EA	\$6,507	
Lintels		Lintels - Steel	2nd floor east and west, entrances to gyms	4	180	LF	\$78,507	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lintels		Lintels - Steel	Entire Building	6	960	LF	\$36,242	
Lintels		Lintels - Stone	Entire Building	7	24	LF	\$0	
Parapet		Coping - Stone	Entire Building	6	1,780	LF	\$0	
Parapet		Parapet < 16" Height	Entire Building	6	1,742	LF	\$271,276	
Parapet		Parapet > 30" Height	Entire Building	6	38	LF	\$9,863	
Roof System		Asphalt Gravel Ballast Roof	Entire Building	7	36,600	SF	\$0	
Roof System		Interior Downspouts	Entire Building	6	336	LF	\$0	
Roof System		Interior Downspouts	north gym	5	24	LF	\$2,574	
Roof System		Roof Structure: Concrete	Entire Building	7	5,400	SF	\$0	
Roof System		Roof Structure: Steel with Clay Tile Arch	Entire Building	7	28,400	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	south gym	7	2,800	SF	\$0	
Superstructure		Concrete	Entire Building	7	72,000	SF	\$0	
Walls		Brick	Entire Building	6	29,550	SF	\$195,225	
Walls		Brick	Courtyard	4	150	SF	\$11,326	
Walls		Stone - Cast	Courtyard	5	200	SF	\$14,300	
Walls		Stone - Cast	Entire Building	6	8,950	SF	\$127,985	
Windows		Window - Guards wire guard	Entire Building	4	456	SF	\$34,860	
Windows		Windows - Sash Lexan	Entire Building	4	9,180	SF	\$1,585,527	
Windows		Windows - Sash Lexan	221, 205	3	240	SF	\$41,452	
Windows		Windows - Sash Steel	Boiler Room	4	80	SF	\$32,844	
EXTERIOR Sub Total							\$2,699,320	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Basement	6	1	EA	\$1,430	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	4	14,780	SF	\$45,441	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	4	5,505	SF	\$9,840	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	23	EA	\$2,467	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	3	5	EA	\$2,703	not working
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	3	EA	\$322	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	2	EA	\$215	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	2	EA	\$215	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	8	EA	\$858	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	23	EA	\$5,361	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	8	EA	\$1,865	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	8	EA	\$1,865	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Lunchroom - 122	6	2	EA	\$466	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	2	EA	\$466	
Emergency System		Independent Electrical Service for emergency power	Basement	4	1	EA	\$17,160	
Emergency System		Public Announcement System	Entire Building	3	72,000	SF	\$255,341	not working
Emergency System		Security System - Intrusion detection	Entire Building	3	72,000	SF	\$288,288	not working
Emergency System		UPS 30 KW and below	Basement	2	1	EA	\$50,050	inoperative / batteries removed
Main Service		Main Electrical service 1600 A 120/208/3PH	Basement	6	1	EA	\$9,295	
Power Distribution		Lighting and power panels	Entire Building	6	12	EA	\$8,580	
Power Distribution		Lighting and power panels	Entire Building	6	2	EA	\$1,430	
Power Distribution		Main distribution panels 400-600 amp	Entire Building	4	2	EA	\$24,310	
ELECTRICAL Sub Total							\$727,966	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Basement	6	76,600	SF	\$93,107	
FIRE PROTECTION Sub Total							\$93,107	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	113; Principal's Office; 219; 218; 2nd Floor W. Teacher's Rest Room	6	5	EA	\$1,073	
Air Conditioning		Window A/C Unit	Entire Building	4	33	EA	\$70,785	
Air Conditioning		Window A/C Unit	213	3	1	EA	\$2,145	not working
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	4	1	EA	\$26,169	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	4	1	EA	\$26,169	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Basement	4	1	EA	\$92,950	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Basement	3	1	EA	\$128,700	not working
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Basement	2	1	EA	\$32,890	not working
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Basement	2	1	EA	\$40,040	not working

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	4	200	LF	\$357,500	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	4	2	EA	\$294,580	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	3	2	EA	\$45,760	not working
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	4	1	EA	\$10,296	
Boiler Systems		Combustion Dampers	Boiler Room	2	2	EA	\$11,154	not working
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	3	1	EA	\$31,460	not working
Heating Devices		Cabinet Heaters With Electric Coils	Basement	4	2	EA	\$8,294	not working
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	4	18	EA	\$74,646	
Heating Devices		Fin Tube Hot Water	Entire Building	4	122	LF	\$20,935	
Heating Devices		Radiators - Steam	Main Office	4	1	EA	\$1,401	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Basement	4	2	EA	\$57,200	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	4	200	LF	\$19,591	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	4	200	LF	\$23,953	
Temperature Control		Pneumatic System	Entire Building	2	72,000	SF	\$514,800	not working
Temperature Control		Thermostats - Pneumatic	Entire Building	3	30	EA	\$19,734	not working
Temperature Control		Thermostats - Pneumatic	Entire Building	2	16	EA	\$10,525	not working
Temperature Control		Thermostats - Pneumatic	Entire Building	5	6	EA	\$3,346	
Temperature Control		Zone Dampers	Basement	4	15	EA	\$12,656	not working
Temperature Control		Zone Dampers	Basement	4	31	EA	\$26,155	not working
Unit Ventilation		Unit Ventilators - Steam	Entire Building	3	17	EA	\$267,410	not working
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	6	EA	\$9,009	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Kitchen	4	1	EA	\$1,573	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Basement	2	1	EA	\$1,573	not working

MECHANICAL Sub Total \$2,244,471

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Basement	6	1	EA	\$4,147	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	72,000	SF	\$23,681	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	72,000	SF	\$46,332	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	72,000	SF	\$15,444	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	72,000	SF	\$32,947	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	72,000	SF	\$39,125	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	72,000	SF	\$171,943	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	72,000	SF	\$142,085	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	72,000	SF	\$82,368	
Piping		Sanitary Piping	Entire Building	5	72,000	SF	\$44,273	
Piping		Storm Piping	Entire Building	5	72,000	SF	\$33,977	
Piping		Vent Piping	Entire Building	5	72,000	SF	\$25,740	
Pumps		Sump Pump	Boiler Room	4	2	EA	\$23,738	
Pumps		Sump Pump	Basement	2	1	EA	\$11,869	not working
Pumps		Sump Pump	Basement	5	2	EA	\$10,296	
PLUMBING Sub Total							\$707,964	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	113B- principals office	6	382	SF	\$819	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office 1st fl	7	359	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	clerks office in main	7	146	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	207A	7	300	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	adjustment office 1st fl	7	266	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	2nd floor teachers LOCKED OUT OF ORDER	5	150	SF	\$849	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st floor small teachers lounge next to lunchroom	6	150	SF	\$425	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	gym office in 105	6	230	SF	\$651	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	basement custodian break room	6	175	SF	\$495	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	basement engineers office	6	112	SF	\$317	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	2nd floor teachers lounge	6	375	SF	\$1,062	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office 1st fl	6	359	SF	\$513	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	clerks office in main	6	146	SF	\$209	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	113B- principals office	6	382	SF	\$546	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	adjustment office 1st fl	6	266	SF	\$380	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	2nd floor teachers lounge	6	375	SF	\$536	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	basement engineers office	6	112	SF	\$529	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	basement custodian break room	6	175	SF	\$250	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	207A	7	300	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	2nd floor teachers LOCKED OUT OF ORDER	6	150	SF	\$215	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	gym office in 105	6	230	SF	\$329	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st floor small teachers lounge next to lunchroom	6	150	SF	\$215	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	113B- prinicipals office	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office 1st fl	7	7	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	basement custodian break room	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	gym office in 105	6	2	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st floor small teachers lounge next to lunchroom	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd floor teachers LOCKED OUT OF ORDER	6	3	SF	\$2	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd floor teachers lounge	7	10	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	adjustment office 1st fl	7	5	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	207A	6	4	SF	\$3	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	clerks office in main	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	basement engineers office	4	1	SF	\$7	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	basement engineers office	6	288	SF	\$824	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	adjustment office 1st fl	5	973	SF	\$4,592	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	clerks office in main	6	505	SF	\$1,192	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd floor teachers lounge	6	815	SF	\$1,923	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd floor teachers LOCKED OUT OF ORDER	6	665	SF	\$1,569	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor small teachers lounge next to lunchroom	7	515	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	gym office in 105	6	708	SF	\$1,671	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	basement custodian break room	6	450	SF	\$1,062	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	basement engineers office	6	108	SF	\$255	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	113B- prinicipals office	7	705	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	207A	5	865	SF	\$4,082	
Doors		Interior Steel Doors incl hw	Entire Building	7	2	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	5	7	EA	\$3,303	
Doors		Interior Steel Doors incl hw	Entire Building	7	5	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	73	EA	\$20,669	
Doors		Interior Wood Doors incl hw	Entire Building	4	11	EA	\$35,298	
Doors		Interior Wood Doors incl hw	Entire Building	5	46	EA	\$21,707	
Doors		Interior Wood Doors incl hw	Entire Building	7	3	EA	\$0	
Doors		Transom Window	Entire Building	6	660	SF	\$12,269	
Drinking Fountains		Single Fountain	Entire Building	7	16	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Exposed	1st Floor	7	2,400	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Plaster/Drywall	1st Floor	5	3,010	SF	\$30,130	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Wood	1st Floor	7	3,010	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1st Floor	7	2,400	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	1st Floor	6	12	EA	\$2,145	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Metal Halide/Sodium Vapor	1st Floor	7	12	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Lighting - Pendant/Surface	1st Floor	6	10	EA	\$1,216	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Scoreboards	1st Floor	6	1	EA	\$2,076	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	1st Floor	5	7	EA	\$330,330	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	1st Floor	7	2,965	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Plaster/Drywall	1st Floor	5	1,780	SF	\$25,454	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Structural Glazed Tile	1st Floor	5	2,929	SF	\$138,220	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	1st Floor	7	1,400	SF	\$0	
Kitchen	Warming Kitchen	Ceiling - Lay-In	1st Floor	6	725	SF	\$2,074	
Kitchen	Warming Kitchen	Flooring - Tile/Sheet	1st Floor	5	725	SF	\$4,106	
Kitchen	Warming Kitchen	Lighting - Lay-In	1st Floor	7	10	SF	\$0	
Kitchen	Warming Kitchen	Wall - Plaster/Drywall	1st Floor	6	1,000	SF	\$2,360	
Library	Library	Flooring Tile/ Sheet	219	6	1,046	SF	\$1,496	
Library	Library	Lighting - Pendant/ Surface	219	6	20	SF	\$14	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys next to lunchroom			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls center			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys center			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls next to upper gym			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls across from 105			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Custodians Toliet-Basement			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in adjustment office 1st fl			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	across from 203			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys next to 220			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	inside small 1st floor teachers lounge			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls next to lunchroom			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys center			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	unisex next to 107			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys next to 202			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys next to 102			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	117			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	basement engineer office toilet			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	in gym 105 mens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in gym 105 womens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in 119 womens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in 119 mens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls center			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	207A			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls across from 205			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in main office			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in adjustment office 1st fl			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls across from 105			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	unisex next to 107			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls center			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls next to lunchroom			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys next to lunchroom			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys next to 220			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls next to upper gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys center			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys next to 102			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Custodians Toliet-Basement			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys center			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls across from 205			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Lockers	across from 203			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys next to 202			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	207A			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in main office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls center			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	basement engineer office toilet			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	in gym 105 mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in gym 105 womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in 119 womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	inside small 1st floor teachers lounge			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in 119 mens			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	117			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	in gym 105 mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	inside small 1st floor teachers lounge			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys center			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls center			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	unisex next to 107			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls across from 105			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys next to lunchroom			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	117			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Custodians Toilet-Basement	6	1	EA	\$243	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls next to lunchroom			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in 119 womens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys next to 102			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys next to 220			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls next to upper gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls center			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in adjustment office 1st fl			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls across from 205			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	across from 203			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys next to 202			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	207A			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in main office			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in 119 mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in gym 105 womens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys center			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	basement engineer office toilet			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	121	6	1,070	SF	\$2,295	
Lunchroom	Lunchroom	Ceiling - Lay-In	122	5	1,425	SF	\$8,069	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	121	5	1,070	SF	\$6,059	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	122	6	1,425	SF	\$2,038	
Lunchroom	Lunchroom	Lighting - Lay-In	122	7	21	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	121	7	18	SF	\$0	
Lunchroom	Lunchroom	Serving Line	122			LF	\$0	
Lunchroom	Lunchroom	Serving Line	121	5	12	LF	\$2,574	
Lunchroom	Lunchroom	Serving Line	121	7	10	LF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	121	5	1,240	SF	\$5,852	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	122	5	1,485	SF	\$7,008	
MDF/IDF		Finishes	Entire Building	6	130	SF	\$442	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	2	SF	\$9	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	5	6,700	SF	\$75,882	
Mechanical/Service Rooms		Storage Room	in gym/ auditorium	6	100	SF	\$472	
Mechanical/Service Rooms		Storage Room	101	6	27	SF	\$127	
Mechanical/Service Rooms		Storage Room	gym	6	140	SF	\$661	
Mechanical/Service Rooms		Storage Room	216	6	330	SF	\$1,557	
Staff Restroom	Staff Restroom	Accessories	inside small 1st floor teachers lounge	6	35	SF	\$270	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys next to 220	5	120	SF	\$3,058	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys next to lunchroom	5	120	SF	\$3,058	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls next to upper gym	6	145	SF	\$1,120	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys center	6	245	SF	\$1,892	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls center	6	245	SF	\$1,892	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls next to lunchroom	6	145	SF	\$1,120	
Staff Restroom	Staff Restroom	Accessories	in adjustment office 1st fl	6	30	SF	\$232	
Staff Restroom	Early Childhood Student Restroom	Accessories	117	5	42	SF	\$1,070	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls across from 205	6	260	SF	\$2,008	
Staff Restroom	Staff Restroom	Accessories	across from 203	6	36	SF	\$278	
Staff Restroom	Staff Restroom	Accessories	Custodians Toilet-Basement	5	25	SF	\$637	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys center	6	245	SF	\$1,892	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls center	6	245	SF	\$1,892	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls across from 105	6	260	SF	\$2,008	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys next to 202	6	260	SF	\$2,008	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys next to 102	6	260	SF	\$2,008	
Staff Restroom	Staff Restroom	Accessories	in 119 mens	6	64	SF	\$494	
Staff Restroom	Staff Restroom	Accessories	basement engineer office toilet	6	45	SF	\$347	
Staff Restroom	Adult Standard Student Restroom	Accessories	in gym 105 mens	6	64	SF	\$494	
Staff Restroom	Staff Restroom	Accessories	in gym 105 womens	6	64	SF	\$494	
Staff Restroom	Staff Restroom	Accessories	in 119 womens	6	64	SF	\$494	
Staff Restroom	Staff Restroom	Accessories	207A	6	45	SF	\$347	
Staff Restroom	Staff Restroom	Accessories	in main office	6	30	SF	\$232	
Staff Restroom	Staff Restroom	Accessories	unisex next to 107	6	45	SF	\$347	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys center	6	245	SF	\$694	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys next to 220	6	120	SF	\$340	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in main office	7	30	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	207A	6	45	SF	\$127	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys next to 202	6	260	SF	\$736	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	across from 203	6	36	SF	\$102	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in adjustment office 1st fl	7	26	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Custodians Toliet-Basement	5	25	SF	\$142	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls center	6	245	SF	\$694	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	unisex next to 107	6	45	SF	\$127	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys center	6	245	SF	\$694	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in 119 mens	5	64	SF	\$362	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys next to lunchroom	6	120	SF	\$340	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	inside small 1st floor teachers lounge	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls next to lunchroom	6	145	SF	\$411	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls center	6	245	SF	\$694	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls across from 105	6	280	SF	\$793	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys next to 102	6	260	SF	\$736	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	117	6	42	SF	\$119	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	basement engineer office toilet	6	45	SF	\$127	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	in gym 105 mens	4	64	SF	\$846	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in gym 105 womens	5	64	SF	\$362	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in 119 womens	5	64	SF	\$362	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls next to upper gym	6	145	SF	\$411	
Staff Restroom	Staff Restroom	Floor Drain	in 119 mens			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in 119 womens			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in gym 105 womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys next to 220	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	in main office			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	in gym 105 mens			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Floor Drain	207A			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys next to 202	5	1	EA	\$1,502	
Staff Restroom	Staff Restroom	Floor Drain	across from 203			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls across from 205	5	1	EA	\$1,502	
Staff Restroom	Staff Restroom	Floor Drain	in adjustment office 1st fl			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Custodians Toliet-Basement	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls center	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys next to 102	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls next to upper gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys next to lunchroom	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	inside small 1st floor teachers lounge			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls next to lunchroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys center	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls center	5	1	EA	\$1,502	
Staff Restroom	Staff Restroom	Floor Drain	unisex next to 107			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls across from 105	5	1	EA	\$1,502	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	117			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	basement engineer office toilet			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys center	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Flooring - Concrete	basement engineer office toilet	6	45	SF	\$212	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys next to 102	7	260	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in 119 womens	6	64	SF	\$163	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls across from 105	7	280	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls next to lunchroom	6	145	SF	\$369	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys next to lunchroom	6	120	SF	\$305	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys next to 220	6	120	SF	\$305	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls next to upper gym	6	145	SF	\$369	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys center	6	245	SF	\$624	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in 119 mens	6	64	SF	\$163	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in gym 105 womens	6	64	SF	\$163	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	in gym 105 mens	6	64	SF	\$163	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys center	6	245	SF	\$624	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls center	6	245	SF	\$624	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys next to 202	7	260	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls center	6	245	SF	\$624	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls across from 205	7	280	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	117	6	42	SF	\$107	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in adjustment office 1st fl	7	26	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	unisex next to 107	6	45	SF	\$64	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	across from 203	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Custodians Toliet-Basement	5	25	SF	\$142	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	inside small 1st floor teachers lounge	6	35	SF	\$50	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in main office	7	30	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	207A	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in 119 womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls across from 205			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in adjustment office 1st fl			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in main office			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	207A			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	inside small 1st floor teachers lounge			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	in gym 105 mens			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls next to lunchroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls center	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	unisex next to 107			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls across from 105	5	1	EA	\$716	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys next to 102			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys next to 220	5	1	EA	\$716	
Staff Restroom	Staff Restroom	Hand Dryer	basement engineer office toilet			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Custodians Toliet-Basement			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in gym 105 womens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	across from 203			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys next to lunchroom	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys next to 202			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls next to upper gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls center	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	117			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in 119 mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls next to upper gym	6	1	EA	\$372	
Staff Restroom	Adult Standard Student Restroom	Lavatory	in gym 105 mens	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	basement engineer office toilet	6	1	EA	\$372	
Staff Restroom	Early Childhood Student Restroom	Lavatory	117	4	1	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys next to 102	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls across from 105	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Lavatory	unisex next to 107	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls center	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys center	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls next to lunchroom	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	inside small 1st floor teachers lounge	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	in 119 womens	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys next to 220	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	in 119 mens	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys center	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls center	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Custodians Toliet-Basement	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	in adjustment office 1st fl	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls across from 205	5	2	EA	\$3,718	
Staff Restroom	Staff Restroom	Lavatory	across from 203	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys next to 202	5	2	EA	\$3,718	
Staff Restroom	Staff Restroom	Lavatory	207A	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in main office	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys next to lunchroom	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	in gym 105 womens	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls next to lunchroom	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in gym 105 womens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in 119 womens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	basement engineer office toilet	4	1	SF	\$4	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	117	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl boys next to 102	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl girls across from 105	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls center	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys center	7	4	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	in gym 105 mens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	inside small 1st floor teachers lounge	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls center	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in main office	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in 119 mens	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl boys next to 202	6	3	SF	\$2	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls across from 205	6	3	SF	\$2	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Custodians Toliet-Basement	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys next to lunchroom	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys center	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls next to upper gym	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys next to 220	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in adjustment office 1st fl	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	unisex next to 107	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	207A	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	across from 203	6	1	EA	\$29	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	inside small 1st floor teachers lounge	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	inside small 1st floor teachers lounge	5	1	EA	\$572	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls next to lunchroom	5	3	EA	\$1,716	
Staff Restroom	Staff Restroom	Partitions	in main office			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	207A	5	1	EA	\$572	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys next to 202	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	across from 203	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls across from 205	6	5	EA	\$897	
Staff Restroom	Staff Restroom	Partitions	in adjustment office 1st fl			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Custodians Toliet-Basement			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls center	4	7	EA	\$12,553	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys center	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls next to upper gym	5	3	EA	\$1,716	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys next to 220	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys center	5	2	EA	\$1,144	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys next to lunchroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in 119 mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls center	6	6	EA	\$1,076	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls center	4	1	EA	\$1,793	
Staff Restroom	Staff Restroom	Partitions	unisex next to 107	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls across from 105	6	5	EA	\$897	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys next to 102	6	2	EA	\$359	
Staff Restroom	Early Childhood Student Restroom	Partitions	117	6	1	EA	\$179	
Staff Restroom	Staff Restroom	Partitions	basement engineer office toilet			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	in gym 105 mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in gym 105 womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in 119 womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys next to lunchroom	5	2	EA	\$3,718	
Staff Restroom	Staff Restroom	Urinals	207A			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	inside small 1st floor teachers lounge			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in main office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys next to 202	6	3	EA	\$1,115	
Staff Restroom	Staff Restroom	Urinals	across from 203			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in adjustment office 1st fl			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Custodians Toliet-Basement			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls center			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys center	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys center	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls next to upper gym			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys next to 220	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys next to 202	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys next to lunchroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys next to 102	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Urinals	in 119 womens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in gym 105 womens			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	in gym 105 mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys next to 220	6	1	EA	\$372	
Staff Restroom	Early Childhood Student Restroom	Urinals	117			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in 119 mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys next to 102	6	3	EA	\$1,115	
Staff Restroom	Staff Restroom	Urinals	unisex next to 107			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls center			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys center	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys center	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls next to lunchroom			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	basement engineer office toilet			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Custodians Toliet-Basement	6	128	SF	\$366	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Custodians Toliet-Basement	6	43	SF	\$101	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor boys next to 220	7	160	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl boys next to 102	6	359	SF	\$847	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl girls across from 105	6	377	SF	\$890	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	207A	5	196	SF	\$925	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	across from 203	6	204	SF	\$481	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls across from 205	6	377	SF	\$890	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in adjustment office 1st fl	6	234	SF	\$552	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	117	5	298	SF	\$1,406	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor girls next to upper gym	6	115	SF	\$271	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	unisex next to 107	5	225	SF	\$1,062	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor boys next to lunchroom	6	160	SF	\$378	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	inside small 1st floor teachers lounge	6	195	SF	\$460	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor girls next to lunchroom	6	115	SF	\$271	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor boys center	7	50	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor boys center	6	215	SF	\$507	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st floor girls center	6	215	SF	\$507	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd floor girls center	6	215	SF	\$507	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	in gym 105 mens	4	270	SF	\$2,548	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in gym 105 womens	5	270	SF	\$1,274	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in 119 womens	5	270	SF	\$1,274	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in 119 mens	5	270	SF	\$1,274	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in main office	6	234	SF	\$552	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl boys next to 202	6	359	SF	\$847	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	basement engineer office toilet	6	122	SF	\$288	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girls next to upper gym	7	380	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls across from 105	6	500	SF	\$3,575	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys next to 102	6	524	SF	\$3,747	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	basement engineer office toilet	6	122	SF	\$872	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls center	6	530	SF	\$3,790	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys center	6	695	SF	\$4,969	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys next to 220	6	490	SF	\$3,504	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys center	6	530	SF	\$3,790	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girls center	6	530	SF	\$3,790	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls across from 205	7	500	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys next to 202	6	524	SF	\$3,747	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls next to lunchroom	6	380	SF	\$2,717	
Staff Restroom	Staff Restroom	Water Closet	Custodians Toilet-Basement	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls across from 105	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in main office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	207A	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys next to 202	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	across from 203	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls across from 205	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in adjustment office 1st fl	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys next to 102	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in 119 mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in 119 womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in gym 105 womens	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	in gym 105 mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls center	7	7	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	117	4	1	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls center	6	6	EA	\$2,231	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls across from 105	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Water Closet	unisex next to 107	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys center	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls next to lunchroom	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	inside small 1st floor teachers lounge	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys next to lunchroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys next to 220	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls next to upper gym	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys center	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls center	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Water Closet	basement engineer office toilet	6	1	EA	\$372	
Vocational Shop	Classroom	Work Sink		6	4	EA	\$1,544	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	

INTERIOR Sub Total \$952,172

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Main Office 1st fl			SF	\$0	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		4	97	LF	\$45,081	
Casework	Classroom	Casework		6	28	LF	\$1,001	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	720	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	720	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4		LF		

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	44	LF	\$5,348	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	44	LF	\$5,348	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Lunchroom	Chalk Board	122	4	40	LF	\$4,862	
Chalk Board	Lunchroom	Chalk Board	121	4		LF		
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	13	LF	\$1,580	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Corridors	Corridors	Drinking Fountains	2nd Floor			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st Floor			EA	\$0	
Corridors	Corridors	Drinking Fountains	east stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	west stairs			EA	\$0	
Corridors	Corridors	Floors	1st Floor	5	6,864	SF	\$97,174	
Corridors	Corridors	Lay-In	1st Floor	7	1,416	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	5,448	EA	\$0	
Corridors	Corridors	Pendant/Surface	east stairs	6	1,040	EA	\$744	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	6,256	EA	\$0	
Corridors	Corridors	Pendant/Surface	west stairs	6	620	EA	\$443	
Corridors	Corridors	Plaster/Drywall	east stairs	6	2,177	SF	\$5,137	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	4,360	SF	\$10,287	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	6,667	SF	\$15,731	
Corridors	Corridors	Plaster/Drywall	west stairs	6	1,920	SF	\$4,530	
Corridors	Corridors	Stair Handrails	west stairs	6	66	LF	\$0	
Corridors	Corridors	Stair Handrails	east stairs	6	84	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,286	SF	\$3,034	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,106	SF	\$2,610	
Wall	Classroom	Plaster/Drywall		6	1,356	SF	\$3,199	

ROOM Sub Total \$845,115

Building Main Sub Total \$8,270,114

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Building	7	8	EA	\$0	
Civil/Drainage		Site Manhole	Entire Building	7	6	EA	\$0	
Fencing		Chain Link	Entire Building	6	1,350	LF	\$19,363	
Landscape		Asphalt Play Area/Hardscape	Entire Building	6	50,100	SF	\$42,986	
Landscape		Grass	Entire Building	7	13,100	SF	\$0	
Landscape		Hardscape - Concrete	Entire Building	7	3,240	SF	\$0	
Landscape		Parkway trees	Entire Building	7	28	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Building	7	1,340	SF	\$0	
Landscape		Retaining Wall - Concrete	basement stairs	5	650	SF	\$50,611	
Parking Lot		Asphalt	Entire Building	6	47,200	SF	\$40,498	
Playground		Playground Equipment - School Age 5-12	Entire Building	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Entire Building	7	2,500	SF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Building	7	16,245	SF	\$0	
Signage		Flag Pole	east	6	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	east and west	6	2	EA	\$0	

SITE Sub Total \$153,458

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
SITE Sub Total							\$153,458	
Total Campus Need ^{2 3}							\$8,423,572	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary														
Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	1037	1		32	40	182	56	1	N	N	Y	Classroom		
102	720	1		4	40	84	42	1	N	N	Y	Classroom		
103	1047		1	12	40	182	56	1	N	Y	Y	Classroom		
106	770			6	40	84	42	1	N	N	Y	Classroom		
107	720			4	40	84	42	1	N	Y	Y	Classroom		
108	720	1		4	40	84	42	1	N	Y	Y	Classroom		
109	720			12	40	84	42	1	N	Y	Y	Classroom		
110	720	1		4	40	84	42	1	N	Y	Y	Classroom		
112	720	1		4	40	84	42	1	N	Y	Y	Classroom		
114	720	1		4	40	84	42	1	N	Y	Y	Classroom		
115	720	1		4	40	84	42	1	N	Y	Y	Classroom		
116	720	1		4	40	84	42	1	N	Y	Y	Classroom		
117	875		2	8	40	140	36	2	N	Y	Y	Classroom		
118	720	1		6	40	84	42	1	N	Y	Y	Classroom		
201	720	1		8	40	84	42	1	N	N	Y	Classroom		
202	720	1		8	40	84	42	1	N	N	Y	Classroom		
203	720	1		8	40	84	42	1	N	N	Y	Classroom		
205	720	1		8	40	84	42	1	N	N	Y	Classroom		
206	770			52	40	84	42	1	N	Y	Y	Classroom		
207	720			4	40	84	42	1	N	Y	Y	Classroom		
208	720			4	40	84	42	1	N	Y	Y	Classroom		
209	720			4	40	84	42	1	N	Y	Y	Classroom		
210	720	1		4	40	84	42	1	N	Y	Y	Classroom		
211	720			20	40	84	42	1	N	Y	Y	Classroom		
212	720	1		6	40	84	42	1	N	Y	Y	Classroom		
213	720			14	40	84	42	1	N	Y	Y	Classroom		
214	720	1		4	40	84	42	1	N	Y	Y	Classroom		
215	720	1		4	40	84	42	1	N	Y	Y	Classroom		
217	720	1		4	40	84	42	1	N	Y	Y	Classroom		
218	1048	1		9	40	126	63	1	N	N	Y	Classroom		
220	720	1		4	40	84	42	1	N	N	Y	Classroom		
221	720	1		4	40	84	42	1	N	N	Y	Classroom		
221	720	1		8	40	84	42	1	N	N	Y	Classroom		
222	720	1		29	40	84	42	1	N	N	Y	Classroom		
223	720	1		29	40	84	42	1	N	N	Y	Classroom		
Other	280								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls across from 205

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	36								N	N	N	Restroom	Staff Restroom	across from 203
Other	120								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys next to 220
Other	260								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys next to 202
Other	150			6					N	N	N	Administrative Suites/Offices		2nd floor teachers LOCKED OUT OF ORDER
Other	375			10					N	N	Y	Administrative Suites/Offices		2nd floor teachers lounge
Other	145								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls next to upper gym
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls center
Other	1046								N	N	N	Library		219
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys center
Other	25								N	N	N	Restroom	Staff Restroom	Custodians Toliet-Basement
Other	35								N	N	N	Restroom	Staff Restroom	inside small 1st floor teachers lounge
Other	26								N	N	N	Restroom	Staff Restroom	in adjustment office 1st fl
Other	230								N	N	N	Administrative Suites/Offices		gym office in 105
Other	175								N	N	N	Administrative Suites/Offices		basement custodian break room
Other	2400								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	112			6					N	N	Y	Administrative Suites/Offices		basement engineers office
Other	3010								N	N	N	Gymnasia	Gymnasium.Auditorium	1st Floor
Other	45								N	N	N	Restroom	Staff Restroom	basement engineer office toilet
Other	266			4					N	N	Y	Administrative Suites/Offices		adjustment office 1st fl
Other	64								N	N	N	Restroom	Adult Standard Student Restroom	in gym 105 mens
Other	64								N	N	N	Restroom	Staff Restroom	in gym 105 womens
Other	6256								N	N	N	Corridors		2nd Floor
Other	6864								N	N	N	Corridors		1st Floor
Other	1040								N	N	N	Corridors		east stairs
Other	620								N	N	N	Corridors		west stairs
Other	64								N	N	N	Restroom	Staff Restroom	in 119 womens
Other	42								N	N	N	Restroom	Early Childhood Student Restroom	117
Other	280								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls across from 105
Other	150			6					N	N	Y	Administrative Suites/Offices		1st floor small teachers lounge next to lunchroom
Other	145								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls next to lunchroom
Other	64								N	N	N	Restroom	Staff Restroom	in 119 mens
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys center
Other	245								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls center
Other	45								N	N	N	Restroom	Staff Restroom	unisex next to 107
Other	1425								N	N	N	Lunch & Multipurpose Room	Lunchroom	122

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	146			6					N	N	Y	Administrative Suites/Offices		clerks office in main
Other	120								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys next to lunchroom
Other	30								N	N	N	Restroom	Staff Restroom	in main office
Other	260								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys next to 102
Other	382			6					N	N	Y	Administrative Suites/Offices		113B- principals office
Other	300			4					N	N	Y	Administrative Suites/Offices		207A
Other	45								N	N	N	Restroom	Staff Restroom	207A
Other	725								N	N	N	Kitchen	Warming Kitchen	1st Floor
Other	1070								N	N	N	Lunch & Multipurpose Room	Lunchroom	121
Other	359			17					N	N	Y	Administrative Suites/Offices		Main Office 1st fl