

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	Roof and Top	5	15	LF	\$26,813	straps and step cracking
Chimney		Brick Chimney - Concrete/ Mortar Liner	Roof - West	6	100	LF	\$50,050	straps
Cornice		Cornice - Masonry Projecting/Limestone	North and South roofs and Entry 100	4	100	LF	\$61,347	open joints and stones shifting
Cornice		Cornice - Masonry Projecting/Limestone	Entire Building	5	1,645	LF	\$333,022	worn, repoint
Cornice		Cornice - Metal Projecting	East and West 3 Story	5	4,500	LF	\$1,331,466	corroded, peeling point
Doors		Exterior AMP Door	Entire Building	6	12	EA	\$7,362	
Doors		Exterior AMP Door	Entrance 4	5	4	EA	\$8,098	Graffiti
Doors		Exterior Steel Door	Boiler and Northeast	7	2	EA	\$0	
Doors		Exterior Steel Door	North and Southeast	6	2	EA	\$661	
Doors		Overhead Rolling / Garage Door	West Entrances	6	1	EA	\$1,027	needs paint
Doors		Transom Lite	North and Southeast	4	8	EA	\$22,651	lexan
Entrance		Concrete Exterior Stairs	Entire Building	7	240	LF	\$0	
Entrance		Concrete Exterior Stairs	East Auditorium	4	100	LF	\$64,350	cracking and spalling, doors are infilled

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Concrete Exterior Stairs	Site - North and South	5	37	LF	\$11,905	South - crack, top step separating, North -stairs settling and not level
Entrance		Concrete Ramp	Southeast	7	50	LF	\$0	
Entrance		Entrance Controls - Audio and Video	Northeast	7	1	EA	\$0	
Entrance		Entrance Controls - Audio and Video	Southeast	5	1	EA	\$3,861	
Entrance		Power Door Operator and Controls	Southeast	7	1	EA	\$0	
Entrance		Ramp Handrails	Southeast	6	100	LF	\$0	needs paint
Entrance		Stair Handrails	Site - South and East	6	115	LF	\$0	needs paint
Entrance		Stair Handrails	Entire Building	6	115	LF	\$0	needs paint
Foundation		Masonry Foundation	West Boiler Building	6	140	SF	\$13,874	spalling and efflorescence and interior
Foundation		Masonry Foundation	Entire Building	7	685	SF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	7	14	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	6	EA	\$0	
Lintels		Lintels - Steel	Entire Building	6	885	LF	\$33,411	peeling paint
Lintels		Lintels - Steel	North entrance door	5	6	LF	\$1,716	open joint at mid span
Parapet		Coping - Metal	Raised area over auditorium	7	255	LF	\$0	
Parapet		Coping - Stone	West, Northeast, Southeast 1 story	5	255	LF	\$22,236	open joints
Parapet		Coping - Stone	Entire Building	6	970	LF	\$0	
Parapet		Parapet < 16" Height	Northeast, and Southeast 1 story additions	6	120	LF	\$18,687	
Parapet		Parapet > 30" Height	3 story roof	7	590	LF	\$0	
Parapet		Parapet 16" to 30" Height	1 story additions	7	515	LF	\$0	
Roof System		Asphalt Gravel Ballast Roof	Entire Building	4	30,075	SF	\$766,389	asphalt melting and running to roof drains
Roof System		Exterior Downspouts	West boiler room and East entry	6	45	LF	\$837	
Roof System		Interior Downspouts	1 story roofs	6	125	LF	\$0	
Roof System		Interior Downspouts	3 story roof	5	240	LF	\$25,740	tar melts into roof drains
Roof System		Metal Roof	East over auditorium	7	800	SF	\$0	
Roof System		Metal Roof	1 story East skylights	6	260	SF	\$1,963	
Roof System		Roof Structure: Steel with Clay Tile Arch	Entire Building	7	31,135	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	62,635	SF	\$0	
Walls		Brick	North and South parapets	5	2,100	SF	\$47,568	step cracks, bowing at corners
Walls		Brick	West Boiler Building	4	100	SF	\$7,550	cracks and displaced at windows and louvered openings

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Walls		Brick	Entire Building	6	18,900	SF	\$124,865	needs tuckpointing
Walls		Prefabricated Metal Panel Wall	Walls of raised roof over auditorium	5	1,135	SF	\$32,461	corroded, peeling paint
Walls		Stone - Cut	Entire Building	5	6,215	SF	\$666,559	spalls, open joints displaced
Walls		Stone - Cut	Base at West Boiler	4	890	SF	\$222,723	errrosion, spalling and graffiti
Walls		Stone - Cut	Columns	6	240	SF	\$3,432	
Windows		Window - Guards wire guard	Entire Building	6	1,265	SF	\$0	inconsistently installed
Windows		Windows - Sash Lexan	Entire Building	4	7,690	SF	\$1,328,181	sash falls out when opened
EXTERIOR Sub Total							\$5,240,803	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Boiler Room	4	1	EA	\$8,866	
Emergency System		Emergency A/C power - Auditorium and aisle lighting	Entire Building	7	2,800	SF	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	7,228	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	5,430	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	1,955	SF	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	8	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	3rd Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	6	EA	\$0	
Emergency System		Independent Electrical Service for emergency power	Electrical Room	5	1	EA	\$5,005	
Emergency System		Public Announcement System	1st Floor	6	62,635	SF	\$37,619	
Main Service		Main Electrical service 1600 A 120/208/3PH	Electrical Room	4	1	EA	\$130,416	
Power Distribution		Lighting and power panels	Boiler Room	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	Pump Room	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	1st Floor	6	4	EA	\$2,860	
Power Distribution		Lighting and power panels	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Boiler Room	6	1	EA	\$715	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	4	2	EA	\$37,180	
ELECTRICAL Sub Total							\$233,529	

Building: Main
Category: FIRE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	62,635	SF	\$0	
Fire Alarm		Fire Alarm System	Pump Room	4	62,635	SF	\$221,233	

FIRE PROTECTION Sub Total \$221,233

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	2nd Floor	4	2	EA	\$4,290	
Air Conditioning		Window A/C Unit	3rd Floor	7	21	EA	\$0	
Air Conditioning		Window A/C Unit	2nd Floor	7	20	EA	\$0	
Air Conditioning		Window A/C Unit	1st Floor	7	9	EA	\$0	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	6	1	EA	\$1,430	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Pump Room	5	2	EA	\$85,800	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 8,000 to 15,000 cfm	Pump Room	5	1	EA	\$28,600	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Pump Room	5	2	EA	\$34,320	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 8,000 to 15,000 cfm	Pump Room	5	1	EA	\$10,725	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	7	300	LF	\$0	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	5	2	EA	\$125,840	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	5	2	EA	\$22,880	
Boiler Systems		Chemical Feed System (Steam Boilers)	Pump Room	6	1	EA	\$2,145	
Boiler Systems		Combustion Dampers	Boiler Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Pump Room	5	1	EA	\$19,305	
Heating Devices		Unit Heater - Hot Water	Boiler Room	6	1	EA	\$1,430	
Heating Devices		Unit Heater - Hot Water	Electrical Room	4	1	EA	\$7,150	
Heating Devices		Wall Heater - Electric	2nd Floor	4	4	EA	\$4,118	
Heating Devices		Wall Heater - Electric	Electrical Room	4	1	EA	\$1,030	
Heating Devices		Wall Heater - Electric	1st Floor	4	4	EA	\$4,118	
Heating Devices		Wall Heater - Electric	1st Floor	6	1	EA	\$103	
Heating Devices		Wall Heater - Electric	3rd Floor	4	2	EA	\$2,059	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Pump Room	5	3	EA	\$28,314	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	6	300	LF	\$2,059	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	6	300	LF	\$2,660	
Temperature Control		Pneumatic System	Pump Room	5	62,635	SF	\$268,704	
Temperature Control		Thermostats - Pneumatic	2nd Floor	4	10	EA	\$6,578	
Temperature Control		Thermostats - Pneumatic	3rd Floor	4	10	EA	\$6,578	
Temperature Control		Thermostats - Pneumatic	1st Floor	4	8	EA	\$5,262	
Temperature Control		Zone Dampers	Pump Room	4	38	EA	\$32,061	
Ventilation		Exhaust Fan - Indoor	3rd Floor	4	1	EA	\$5,577	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	4	3	EA	\$6,864	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	4	3	EA	\$4,719	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	7	1	EA	\$0	
MECHANICAL Sub Total							\$725,721	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Boiler Room	5	2	EA	\$34,320	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	6	1	EA	\$1,859	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	62,635	SF	\$7,165	
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	62,635	SF	\$9,852	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	62,635	SF	\$9,852	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	6	62,635	SF	\$9,852	
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	62,635	SF	\$9,852	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	62,635	SF	\$14,331	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	62,635	SF	\$12,540	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	62,635	SF	\$9,852	
Piping		Sanitary Piping	Entire Building	7	62,635	SF	\$0	
Piping		Storm Piping	Entire Building	7	62,635	SF	\$0	
Piping		Vent Piping	Entire Building	7	62,635	SF	\$0	
Pumps		Domestic Booster Pump simplex	Pump Room	6	1	EA	\$1,716	
PLUMBING Sub Total							\$121,193	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st FL - Gym Office	6	100	SF	\$215	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st FL - Teachers Resource	7	250	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st FL - Copy	6	430	SF	\$1,218	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	206 A - Teachers Resource	6	405	SF	\$1,147	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office - Counselor's Office	7	200	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office	6	400	SF	\$1,133	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Clerk's Office	6	330	SF	\$934	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Basement Engineers office	6	640	SF	\$1,812	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Principals Office	6	330	SF	\$934	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Principals Office	6	330	SF	\$472	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st FL - Gym Office	5	100	SF	\$566	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	206 A - Teachers Resource	5	405	SF	\$2,293	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Basement Engineers office	6	640	SF	\$915	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st FL - Copy	4	430	SF	\$6,088	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st FL - Teachers Resource	5	250	SF	\$1,416	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Clerk's Office	7	330	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Main Office - Counselor's Office	7	200	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Main Office	7	400	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st FL - Gym Office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st FL - Teachers Resource	7	2	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st FL - Copy	6	7	SF	\$5	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Basement Engineers office	7	9	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	206 A - Teachers Resource	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office - Counselor's Office	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Clerk's Office	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Principals Office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office - Counselor's Office	7	815	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st FL - Gym Office	5	400	SF	\$1,888	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Basement Engineers office	5	2,076	SF	\$9,797	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	206 A - Teachers Resource	6	1,150	SF	\$2,713	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	6	900	SF	\$2,124	Step cracking
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st FL - Teachers Resource	6	890	SF	\$2,100	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Clerk's Office	6	1,092	SF	\$2,577	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principals Office	6	1,092	SF	\$2,577	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st FL - Copy	6	1,200	SF	\$2,831	
Auditorium - Dedicated	Auditorium & Theater	Balcony Seating	1st FL Music Room / Auditorium			EA	\$0	
Auditorium - Dedicated	Auditorium & Theater	Main Floor Seating	1st FL Music Room / Auditorium	6	201	EA	\$7,398	
Auditorium - Dedicated	Auditorium & Theater	Sound System	1st FL Music Room / Auditorium			EA	\$0	
Auditorium - Dedicated	Auditorium & Theater	Stage Curtains	1st FL Music Room / Auditorium			EA	\$0	
Auditorium - Dedicated	Auditorium & Theater	Stage Lighting System	1st FL Music Room / Auditorium			EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	9	EA	\$2,548	
Doors		Interior Steel Doors incl hw	Entire Building	5	4	EA	\$1,888	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Wood Doors incl hw	Entire Building	7	1	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	58	EA	\$16,422	
Doors		Interior Wood Doors incl hw	Entire Building	5	13	EA	\$6,135	
Doors		Transom Window	Entire Building	6	270	SF	\$5,019	
Drinking Fountains	Corridors	Double Fountain	1st Floor	6	1	EA	\$658	
Drinking Fountains	Corridors	Double Fountain	2nd Floor	6	2	EA	\$1,316	
Drinking Fountains	Corridors	Double Fountain	3rd Floor	6	2	EA	\$1,316	
Drinking Fountains	Corridors	Single Fountain	1st Floor	6	5	EA	\$1,931	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	1st Floor	5	3,450	SF	\$34,535	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1st Floor	6	3,450	SF	\$26,049	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	1st Floor	7	18	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	1st Floor	7	1,450	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	1st Floor	5	2,190	SF	\$31,317	
Library	Library	Casework	2nd Floor	6	40	LF	\$1,227	
Library	Library	Lighting - Lay-In	2nd Floor	7	14	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Boiler room			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd FL Girls Room			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st FL - Boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Principals Office			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Gym Office			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st FL Girls Room			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd FL Boys Room			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd FL - Located within Girls Restroom			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd FL Boys Room			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd FL - Located within Girls Restroom			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd FL Girls Room			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Gym Lockerroom			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Boiler room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd FL Boys Room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Gym Lockerroom			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Principals Office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st FL Girls Room			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd FL - Located within Girls Restroom			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd FL Girls Room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd FL Boys Room			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd FL - Located within Girls Restroom			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st FL - Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Gym Office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd FL Girls Room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd FL Girls Room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st FL - Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd FL Girls Room			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd FL - Located within Girls Restroom			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd FL Boys Room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd FL Boys Room			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd FL - Located within Girls Restroom			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Showers	Gym Office			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Boiler room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Gym Lockerroom	4	8	EA	\$19,448	
Locker/Shower Room	Staff Restroom	Showers	Principals Office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st FL Girls Room			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	1st Floor	6	1,980	SF	\$5,606	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	5	1,980	SF	\$11,212	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	28	SF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	20	LF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	1st Floor	6	3,200	SF	\$7,550	
Mechanical/Service Rooms		Boiler Room	Basement	6	1,760	SF	\$8,305	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	3	SF	\$14	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	5	542	SF	\$6,138	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	5	2,701	SF	\$30,590	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	2,205	SF	\$0	
Mechanical/Service Rooms		Storage Room	Entire School	6	1,940	SF	\$9,155	
Mechanical/Service Rooms		Storage Room	Basement	6	88	SF	\$415	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st FL Girls Room	7	380	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st FL - Boys			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Principals Office	4	25	SF	\$1,931	
Staff Restroom	Children's Standard Student Restroom	Accessories	Gym Lockerroom	4	900	SF	\$69,498	
Staff Restroom	Staff Restroom	Accessories	Gym Office	4	25	SF	\$1,931	
Staff Restroom	Staff Restroom	Accessories	Boiler room			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd FL Boys Room	7	380	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd FL Girls Room	7	380	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd FL Boys Room	7	380	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd FL - Located within Girls Restroom	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd FL Girls Room	7	380	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd FL - Located within Girls Restroom	7	100	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Exposed	Boiler room	5	16	SF	\$30	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Gym Office	5	25	SF	\$142	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Gym Lockerroom	6	900	SF	\$2,548	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd FL Boys Room	6	380	SF	\$1,076	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd FL - Located within Girls Restroom	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd FL Girls Room	6	380	SF	\$1,076	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd FL Boys Room	6	380	SF	\$1,076	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd FL - Located within Girls Restroom	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st FL - Boys	6	435	SF	\$1,232	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st FL Girls Room	6	380	SF	\$1,076	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Principals Office	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd FL Girls Room	6	380	SF	\$1,076	
Staff Restroom	Staff Restroom	Floor Drain	2nd FL - Located within Girls Restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st FL - Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd FL Girls Room	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	3rd FL - Located within Girls Restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd FL Girls Room	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	Principals Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd FL Boys Room	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	Boiler room			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Gym Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st FL Girls Room	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Gym Lockerroom	5	7	EA	\$10,511	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd FL Boys Room	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Flooring - Concrete	Boiler room	5	16	SF	\$76	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd FL Girls Room	6	380	SF	\$967	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd FL Boys Room	6	380	SF	\$967	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL Girls Room	6	380	SF	\$967	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL - Located within Girls Restroom	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Gym Lockerroom	5	900	SF	\$14,157	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd FL - Located within Girls Restroom	7	100	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st FL Girls Room	6	380	SF	\$967	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st FL - Boys	6	435	SF	\$1,107	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL Boys Room	6	380	SF	\$967	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Gym Office	5	25	SF	\$142	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Principals Office	5	25	SF	\$142	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st FL - Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd FL Girls Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd FL Boys Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd FL - Located within Girls Restroom			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Principals Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Gym Lockerroom	4	1	EA	\$2,171	
Staff Restroom	Staff Restroom	Hand Dryer	Gym Office			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Boiler room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd FL Boys Room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd FL - Located within Girls Restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd FL Girls Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st FL Girls Room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st FL Girls Room	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	Boiler room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd FL Boys Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Gym Lockerroom	4	2	EA	\$7,436	
Staff Restroom	Staff Restroom	Lavatory	Principals Office	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd FL Girls Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Gym Office	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd FL Boys Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd FL - Located within Girls Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd FL Girls Room	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd FL - Located within Girls Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st FL - Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st FL - Boys	7	6	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Principals Office	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Gym Lockerroom	5	19	SF	\$27	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Gym Office	6	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st FL Girls Room	7	7	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd FL Girls Room	7	7	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd FL Girls Room	7	7	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd FL - Located within Girls Restroom	6	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd FL - Located within Girls Restroom	6	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	Boiler room	5	1	EA	\$157	
Staff Restroom	Staff Restroom	Partitions	Principals Office			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Boiler room			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd FL - Located within Girls Restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Gym Lockerroom			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	1st FL Girls Room	6	6	EA	\$1,076	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd FL Girls Room	6	7	EA	\$1,255	
Staff Restroom	Staff Restroom	Partitions	Gym Office			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd FL - Located within Girls Restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd FL Girls Room	6	7	EA	\$1,255	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st FL - Boys	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd FL Boys Room	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd FL Boys Room	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Urinals	2nd FL - Located within Girls Restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st FL Girls Room			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Principals Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Gym Lockerroom			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Gym Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd FL Boys Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd FL Girls Room			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd FL - Located within Girls Restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd FL Girls Room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st FL - Boys	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Boiler room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd FL Boys Room	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Gym Lockerroom	5	500	SF	\$3,775	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Gym Lockerroom	5	200	SF	\$1,510	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Gym Office	5	160	SF	\$755	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd FL Boys Room	6	525	SF	\$1,239	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd FL - Located within Girls Restroom	6	560	SF	\$1,321	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd FL Girls Room	6	525	SF	\$1,239	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd FL Boys Room	6	525	SF	\$1,239	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd FL Girls Room	6	525	SF	\$1,239	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd FL - Located within Girls Restroom	6	560	SF	\$1,321	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st FL - Boys	6	600	SF	\$1,416	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st FL Girls Room	6	525	SF	\$1,239	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Principals Office	7	364	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	Gym Lockerroom	6	650	SF	\$1,534	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd FL Girls Room	6	500	SF	\$3,575	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd FL Boys Room	6	500	SF	\$3,575	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd FL Girls Room	6	500	SF	\$3,575	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd FL Boys Room	6	500	SF	\$3,575	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st FL Girls Room	6	500	SF	\$3,575	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	Gym Lockerroom	5	400	SF	\$6,292	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st FL - Boys	6	500	SF	\$1,273	
Staff Restroom	Staff Restroom	Water Closet	3rd FL - Located within Girls Restroom	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Boiler room	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Water Closet	Principals Office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Gym Lockerroom			EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Gym Office	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd FL Girls Room	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st FL Girls Room	7	6	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd FL Boys Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd FL Girls Room	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd FL - Located within Girls Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd FL Boys Room	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st FL - Boys	7	2	EA	\$0	
Theater	Auditorium & Theater	Ceiling - Lay-In	1st FL Music Room / Auditorium	6	2,800	SF	\$22,022	
Theater	Auditorium & Theater	Flooring - Tile/Sheet	1st FL Music Room / Auditorium	5	1,300	SF	\$7,362	
Theater	Auditorium & Theater	Flooring - Wood	1st FL Music Room / Auditorium	5	1,500	SF	\$21,236	
Theater	Auditorium & Theater	Lighting - Lay-In	1st FL Music Room / Auditorium	7	18	SF	\$0	
Theater	Auditorium & Theater	Stage	1st FL Music Room / Auditorium			SF	\$0	
Theater	Auditorium & Theater	Wall - Plaster/Drywall	1st FL Music Room / Auditorium	6	3,275	SF	\$28,100	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
INTERIOR Sub Total							\$539,558	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	12	LF	\$429	
Casework	Classroom	Casework		6	12	LF	\$429	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		5	17	LF	\$3,039	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	36	LF	\$1,287	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		7	35	LF	\$0	
Casework	Classroom	Casework		7	45	LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		7	40	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	905	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	850	SF	\$1,823	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	800	SF	\$4,530	
Ceiling	Classroom	Plaster/Drywall		5	905	SF	\$5,125	
Ceiling	Classroom	Plaster/Drywall		5	435	SF	\$2,463	
Ceiling	Classroom	Plaster/Drywall		6	905	SF	\$2,562	
Ceiling	Classroom	Plaster/Drywall		6	905	SF	\$2,562	
Ceiling	Classroom	Plaster/Drywall		5	300	SF	\$1,699	
Ceiling	Classroom	Plaster/Drywall		7	905	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	800	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	905	SF	\$2,562	
Ceiling	Classroom	Plaster/Drywall		6	800	SF	\$2,265	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		5	300	SF	\$1,699	
Ceiling	Classroom	Plaster/Drywall		6	800	SF	\$2,265	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	800	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	905	SF	\$2,562	
Ceiling	Classroom	Plaster/Drywall		6	800	SF	\$2,265	
Ceiling	Classroom	Plaster/Drywall		6	905	SF	\$2,562	
Ceiling	Classroom	Plaster/Drywall		6	800	SF	\$2,265	
Ceiling	Classroom	Plaster/Drywall		6	905	SF	\$2,562	
Ceiling	Classroom	Plaster/Drywall		6	905	SF	\$2,562	
Ceiling	Classroom	Plaster/Drywall		6	435	SF	\$1,232	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	5	LF	\$608	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4		LF		
CLASSROOM	Classroom	Science Lab Elements		7	2	SF	\$0	
Corridors	Corridors	Asphalt	North Stair	7	200	SF	\$0	
Corridors	Corridors	Asphalt	South Stair	7	200	SF	\$0	
Corridors	Corridors	Ceiling	3rd Floor		2,370	SF	\$0	
Corridors	Corridors	Ceiling	North and South Vestibules (Combined Total)	7	232	SF	\$0	
Corridors	Corridors	Ceiling	2nd Floor		2,370	SF	\$0	
Corridors	Corridors	Ceiling	Auditorium			SF	\$0	
Corridors	Corridors	Drinking Fountains	Southeast Vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	West Vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	Southwest Vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	Auditorium			EA	\$0	
Corridors	Corridors	Drinking Fountains	North and South Vestibules (Combined Total)			EA	\$0	
Corridors	Corridors	Drinking Fountains	North Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	South Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	East Vestibule			EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Floors	Auditorium			SF	\$0	
Corridors	Corridors	Lighting	Auditorium			EA	\$0	
Corridors	Corridors	Lighting	3rd Floor			EA	\$0	
Corridors	Corridors	Lighting	2nd Floor			EA	\$0	
Corridors	Corridors	Pendant/Surface	Southeast Vestibule	7	2	EA	\$0	
Corridors	Corridors	Pendant/Surface	Southwest Vestibule	7	2	EA	\$0	
Corridors	Corridors	Pendant/Surface	West Vestibule	7	2	EA	\$0	
Corridors	Corridors	Pendant/Surface	East Vestibule	7	2	EA	\$0	
Corridors	Corridors	Pendant/Surface	North and South Vestibules (Combined Total)	7	232	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	2,256	EA	\$0	
Corridors	Corridors	Pendant/Surface	North Stair	7	6	EA	\$0	
Corridors	Corridors	Pendant/Surface	South Stair	7	6	EA	\$0	
Corridors	Corridors	Plaster/Drywall	South Stair	6	3,510	SF	\$8,282	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	4,850	SF	\$11,444	
Corridors	Corridors	Plaster/Drywall	3rd Floor	6	4,850	SF	\$11,444	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	3,524	SF	\$8,315	
Corridors	Corridors	Plaster/Drywall	North Stair	6	3,510	SF	\$8,282	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	North Stair	7	78	LF	\$0	
Corridors	Corridors	Stair Handrails	North and South Vestibules (Combined Total)			LF	\$0	
Corridors	Corridors	Stair Handrails	Southwest Vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	South Stair	7	78	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Auditorium			LF	\$0	
Corridors	Corridors	Stair Handrails	East Vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	West Vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	Southeast Vestibule			LF	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Southeast Vestibule			EA	\$0	
Corridors	Corridors	Stairs	Auditorium			EA	\$0	
Corridors	Corridors	Stairs	East Vestibule			EA	\$0	
Corridors	Corridors	Stairs	West Vestibule			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	Southwest Vestibule			EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stairs	North and South Vestibules (Combined Total)			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	Southwest Vestibule	6	364	SF	\$2,603	
Corridors	Corridors	Structural Glazed Tile	North and South Vestibules (Combined Total)	6	640	SF	\$4,576	
Corridors	Corridors	Structural Glazed Tile	East Vestibule	6	364	SF	\$2,603	
Corridors	Corridors	Structural Glazed Tile	West Vestibule	6	364	SF	\$2,603	
Corridors	Corridors	Structural Glazed Tile	Southeast Vestibule	6	364	SF	\$2,603	
Corridors	Corridors	Student Lockers	Southeast Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	North and South Vestibules (Combined Total)			EA	\$0	
Corridors	Corridors	Student Lockers	Auditorium	7	111	EA	\$0	
Corridors	Corridors	Student Lockers	West Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	Southwest Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	East Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	North Stair			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	6	5	EA	\$715	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	South Stair			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	East Vestibule	7	150	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	West Vestibule	7	150	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	Southeast Vestibule	7	150	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	Southwest Vestibule	7	150	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	North and South Vestibules (Combined Total)	5	232	SF	\$3,649	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	5	2,370	SF	\$13,421	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	5	2,370	SF	\$13,421	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	2,256	SF	\$3,226	
Corridors	Corridors	Walls	Auditorium			SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	North Stair	6	680	SF	\$1,925	
Corridors Ceiling	Corridors	Plaster/Drywall	South Stair	6	680	SF	\$1,925	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	6	2,256	SF	\$6,388	
Corridors Ceiling	Corridors	Plaster/Drywall	East Vestibule	7	150	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	West Vestibule	7	150	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Southwest Vestibule	7	150	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Southeast Vestibule	7	150	SF	\$0	
Stairs	Corridors	Asphalt	North Stair	7	61	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Stairs	Corridors	Asphalt	South Stair	7	61	SF	\$0	
Floor	Classroom	Tile/Sheet		5	800	SF	\$4,530	
Floor	Classroom	Tile/Sheet		5	850	SF	\$4,813	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	800	SF	\$4,530	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		6	905	SF	\$1,294	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	435	SF	\$2,463	
Floor	Classroom	Tile/Sheet		5	800	SF	\$4,530	
Floor	Classroom	Tile/Sheet		5	800	SF	\$4,530	
Floor	Classroom	Tile/Sheet		5	800	SF	\$4,530	
Floor	Classroom	Tile/Sheet		5	850	SF	\$4,813	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	850	SF	\$4,813	
Floor	Classroom	Tile/Sheet		5	300	SF	\$1,699	
Floor	Classroom	Tile/Sheet		5	800	SF	\$4,530	
Floor	Classroom	Tile/Sheet		5	800	SF	\$4,530	
Floor	Classroom	Tile/Sheet		5	800	SF	\$4,530	
Floor	Classroom	Tile/Sheet		5	435	SF	\$2,463	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Tile/Sheet		5	905	SF	\$5,125	
Floor	Classroom	Wood		6	300	SF	\$2,265	
LIBRARY_CEILING	Library	Drop/Lay-In	2nd Floor	7	820	SF	\$0	
LIBRARY_FLOOR	Library	Library Floor	2nd Floor	6	820	SF	\$1,173	
LIBRARY_WALL	Library	Plaster/Drywall	2nd Floor	6	950		\$2,242	
Lighting	Classroom	Lay-In		7	13	EA	\$0	
Lighting	Classroom	Lay-In		7	21	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	8	EA	\$572	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	4	EA	\$286	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		7	6	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	6	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	5	LF	\$0	
Marker Board	Classroom	Marker Board		6	24	LF	\$686	
Marker Board	Classroom	Marker Board		7	42	LF	\$0	
Marker Board	Classroom	Marker Board		6	24	LF	\$686	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		6	24	LF	\$686	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		6	24	LF	\$686	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		6	15	LF	\$429	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		6	30	LF	\$858	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	54	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0	
Marker Board	Classroom	Marker Board		6	37	LF	\$1,058	
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
Marker Board	Classroom	Marker Board		7	45	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	3rd FL Boys Room	7	7	EA	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2nd FL Boys Room	7	7	EA	\$0	
RESTROOM_WALL	Staff Restroom	Restroom Walls	Boiler room	5	215	SF	\$3,382	
Wall	Classroom	Plaster/Drywall		6	1,475	SF	\$3,480	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,475	SF	\$3,480	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		5	720	SF	\$3,398	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	peeling paint
Wall	Classroom	Plaster/Drywall		6	1,100	SF	\$2,595	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,475	SF	\$3,480	
Wall	Classroom	Plaster/Drywall		6	1,475	SF	\$3,480	
Wall	Classroom	Plaster/Drywall		5	1,580	SF	\$7,456	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,475	SF	\$3,480	
Wall	Classroom	Plaster/Drywall		6	1,475	SF	\$3,480	
Wall	Classroom	Plaster/Drywall		6	1,200	SF	\$2,831	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,580	SF	\$3,728	
Wall	Classroom	Plaster/Drywall		6	1,475	SF	\$3,480	
Wall	Classroom	Plaster/Drywall		6	1,200	SF	\$2,831	
Wall	Classroom	Plaster/Drywall		5	400	SF	\$1,888	
Wall	Classroom	Plaster/Drywall		6	1,475	SF	\$3,480	
ROOM Sub Total							\$383,422	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Building Main Sub Total							\$7,465,459	

Building: Annex
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	East Façade	6	1,225	SF	\$29,482	peeling paint
Chimney		Metal Flue	Main Roof	7	5	LF	\$0	
Cornice		Cornice - Cast Stone	Entire Building	6	2,685	LF	\$144,444	
Doors		Exterior FRP Door	Entire Building	7	26	EA	\$0	
Doors		Exterior Steel Door	North and South Mechanical	6	4	EA	\$1,321	needs paint
Doors		Side Lite	East and Main Entrance	7	2	EA	\$0	
Doors		Transom Lite	North, South and Courtyard	7	26	EA	\$0	
Entrance		Entrance Controls - Audio	East Main Entry	7	1	EA	\$0	
Entrance		Power Door Operator and Controls	East Main Entry	7	1	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	684	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	15	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Courtyard	7	8	EA	\$0	
Lintels		Lintels - Steel	Entire Building	6	1,200	LF	\$45,302	needs paint
Lintels		Lintels - Steel	Entire Building	6	1,200	LF	\$45,302	paint
Parapet		Coping - Stone	Entire Building	7	1,075	LF	\$0	
Parapet		Coping - Stone	Trash Enclosure	7	116	LF	\$0	
Parapet		Parapet > 30" Height	Entire Building	6	1,075	LF	\$279,011	cracks in CMU and back side
Roof System		Interior Downspouts	Entire Building	6	612	LF	\$0	
Roof System		Metal Roof	East Canopy	6	1,225	SF	\$9,249	
Roof System		Modified Bitumen Roof	Entire Building	4	40,375	SF	\$952,648	cracked joints, bubbles, reported leaks
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Entire Building	7	40,375	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	75,380	SF	\$0	
Walls		Brick	Entire Building	7	22,600	SF	\$0	
Walls		Stone - Cut	Entire Building base and bands	6	4,300	SF	\$61,490	some repointing
Windows		Curtain wall - Glazed Double Pane	1st Floor Courtyard	7	550	SF	\$0	
Windows		Curtain wall - Insulated panel	1st Floor Courtyard	7	665	SF	\$0	
Windows		Curtain wall - Windows	1st Floor Courtyard	7	885	SF	\$0	
Windows		Window - Guards perforated	Entire Building	6	1,520	SF	\$0	peeling paint
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	5,656	SF	\$0	

Building: Annex
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
EXTERIOR Sub Total							\$1,568,250	

Building: Annex
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	12,683	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	6,055	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	1,600	SF	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	1st Floor	7	8	EA	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	2nd Floor	7	4	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	7	2	EA	\$0	
Emergency System		Emergency Battery Packs - Toilets	1st Floor	7	4	EA	\$0	
Emergency System		Emergency Battery Packs - Toilets	2nd Floor	7	4	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	25	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	13	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	2nd Floor	7	5	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	5	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	6	1	EA	\$233	
Emergency System		Independent Electrical Service for emergency power	Sprinkler Room	7	1	EA	\$0	
Emergency System		Independent Electrical Service for emergency power	Electrical Room	7	1	EA	\$0	
Emergency System		Public Announcement System	Main Office	7	75,380	SF	\$0	
Emergency System		Security System - Intrusion detection	Main Office	7	75,380	SF	\$0	
Main Service		Main Electrical service 1600 A 277/480/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	South Mech Room	7	3	EA	\$0	
Power Distribution		Lighting and power panels	North Mech Room	7	4	EA	\$0	
Power Distribution		Lighting and power panels	Electrical Room	7	5	EA	\$0	
Power Distribution		Lighting and power panels	1st Floor	7	8	EA	\$0	
Power Distribution		Lighting and power panels	2nd Floor	7	4	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	3	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	2	EA	\$0	
Power Distribution		Transformers 277/480-120/208	1st Floor	7	2	EA	\$0	
Power Distribution		Transformers 277/480-120/208	North Mech Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	2nd Floor	7	2	EA	\$0	
ELECTRICAL Sub Total							\$233	

Building: Annex
Category: FIRE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Annex
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	75,380	SF	\$0	
Fire Alarm		Fire Alarm System	Engineer's Office	7	75,380	SF	\$0	
Fire Alarm		Fire Pump Controller	Sprinkler Room	7	1	EA	\$0	
Pump Room Assembly		Fire Pump 25-50hp	Sprinkler Room	7	1	EA	\$0	
Pump Room Assembly		Jockey Pump	Sprinkler Room	7	1	EA	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	7	75,380	SF	\$0	
Sprinkler System		Wet Sprinkler System	Sprinkler Room	7	75,380	SF	\$0	
FIRE PROTECTION Sub Total							\$0	

Building: Annex
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 201 to 300 tons	Roof	6	1	EA	\$60,060	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm	North Mech Room	5	1	EA	\$57,200	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm	South Mech Room	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water less than 6,000 cfm	North Mech Room	7	1	EA	\$0	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water less than 6,000 cfm	South Mech Room	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	2nd Floor - West Wall	7	2	EA	\$0	
Air Handling Systems		Fan Coil Unit - Electric	2nd Floor	7	1	EA	\$0	
Air Handling Systems		Fan Power Box With Hot Water Coil	1st Floor	7	16	EA	\$0	
Air Handling Systems		Fan Power Box With Hot Water Coil	2nd Floor	7	27	EA	\$0	
Air Handling Systems		Make Up Air Unit - Roof Mounted - Gas-Heating less than 6,000 cfm	Roof	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor greater than 20,000 CFM	North Mech Room	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor greater than 20,000 CFM	South Mech Room	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor less than 5,000 CFM	South Mech Room	7	1	EA	\$0	
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	1st Floor	7	13	EA	\$0	
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	2nd Floor	7	10	EA	\$0	

Building: Annex
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Boiler Systems		Boiler Assembly - Non-Condensing Scotch Marine Hot Water Boiler 1,000MBH-2,000 MBH	Boiler Room	6	3	EA	\$42,900	
Boiler Systems		Boiler Auxiliary Non-Condensing Hot Water Boiler 1,001MBH-2,000 MBH	Boiler Room	7	3	EA	\$0	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	6	1	EA	\$300	
Boiler Systems		Chemical Pot Feeder - Hot Water	North Mech Room	6	1	EA	\$300	
Boiler Systems		Combustion Dampers	Boiler Room	7	8	EA	\$0	
Boiler Systems		Glycol Feed System	Boiler Room	6	1	EA	\$1,087	
Boiler Systems		Glycol Feed System	North Mech Room	6	1	EA	\$1,087	
Heating Devices		Cabinet Heaters With Hot Water Coils	1st Floor	7	14	EA	\$0	
Heating Devices		Fin Tube Hot Water	2nd Floor	7	160	LF	\$0	
Heating Devices		Fin Tube Hot Water	1st Floor	7	206	LF	\$0	
Heating Devices		Unit Heater - Hot Water	South Mech Room	7	1	EA	\$0	
Heating Devices		Unit Heater - Hot Water	North Mech Room	7	1	EA	\$0	
Heating Devices		Unit Heater - Hot Water	1st Floor	7	2	EA	\$0	
Heating Devices		Unit Heater - Hot Water	Boiler Room	7	1	EA	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Copper	Entire Building	7	400	LF	\$0	
Mechanical Plumbing		Pumps - Condenser Water 10 to 20 HP	North Mech Room	6	2	EA	\$5,148	
Mechanical Plumbing		Pumps - Hot Water 5 to 10 HP	Boiler Room	6	2	EA	\$4,004	
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	South Mech Room	7	2	EA	\$0	
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	North Mech Room	7	2	EA	\$0	
Temperature Control		Direct Digital Control (DDC) System	South Mech Room	5	75,380	SF	\$377,277	
Temperature Control		Thermostats - Direct Digital Control (DDC)	South Mech Room	7	1	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	North Mech Room	7	1	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	1st Floor	7	20	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	2nd Floor	7	24	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Boiler Room	7	1	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	7	EA	\$0	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	7	3	EA	\$0	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	7	1	EA	\$0	
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	7	1	EA	\$0	
MECHANICAL Sub Total							\$549,792	

Building: Annex
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Annex
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Boiler Room	7	2	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	75,380	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	75,380	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	75,380	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	75,380	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	75,380	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	75,380	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	75,380	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	75,380	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	75,380	SF	\$0	
Piping		Storm Piping	Entire Building	7	75,380	SF	\$0	
Piping		Vent Piping	Entire Building	7	75,380	SF	\$0	
Pumps		Domestic Booster Pump duplex	North Mech Room	7	1	EA	\$0	
PLUMBING Sub Total							\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	engineers office	7	143	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Counselor A	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	main office conference room	7	272	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	office in library- marked seminar, used as storage	7	205	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	kitchen managers office	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Asst. Princippal's office in main office	6	160	SF	\$343	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Student Services	7	126	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main Office	7	680	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Princippal's office in main office	6	160	SF	\$343	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	library workroom in library 2nd fl	7	176	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	faculty center next to 121	7	832	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Counselor B	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Counselor B	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Counselor A	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Prinicpal's office in main office	7	160	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Asst. Prinicpal's office in main office	7	160	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office	7	535	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	faculty center next to 121	7	832	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	office in library- marked seminar, used as storage	7	205	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	main office conference room	7	272	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	kitchen managers office	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Student Services	7	126	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	engineers office	7	143	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	library workroom in library 2nd fl	7	176	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office	7	145	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main Office	7	19	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	office in library- marked seminar, used as storage	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	main office conference room	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Asst. Prinicpal's office in main office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Counselor B	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	faculty center next to 121	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	library workroom in library 2nd fl	7	2	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	engineers office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	kitchen managers office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Student Services	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Counselor A	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Prinicpal's office in main office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Student Services	7	203	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	engineers office	7	460	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	main office conference room	5	270	SF	\$2,039	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Prinicpal's office in main office	7	80	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Asst. Prinicpal's office in main office	7	80	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Main Office	6	645	SF	\$1,845	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	office in library- marked seminar, used as storage	7	140	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	library workroom in library 2nd fl	7	265	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Counselor B	7	459	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Counselor A	7	459	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	faculty center next to 121	6	702	SF	\$2,008	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	kitchen managers office	7	350	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	library workroom in library 2nd fl	6	229	SF	\$540	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Student Services	6	225	SF	\$531	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	office in library- marked seminar, used as storage	6	400	SF	\$944	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	faculty center next to 121	6	280	SF	\$661	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	6	380	SF	\$897	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Prinicpal's office in main office	6	344	SF	\$812	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	main office conference room	6	290	SF	\$684	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Asst. Prinicipal's office in main office	6	344	SF	\$812	
Doors		Interior Steel Doors incl hw	Entire Building	7	11	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	13	EA	\$3,681	
Doors		Interior Steel Doors incl hw	Entire Building	5	2	EA	\$944	
Doors		Interior Wood Doors incl hw	Entire Building	7	94	EA	\$0	
Doors		Side-lite	Entire Building	7	350	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1st Floor	7	110	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Exposed	1st Floor	7	3,491	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Tile/Sheet	1st Floor	7	3,491	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	1st Floor	6	8	EA	\$1,430	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	1st Floor	7	8	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	1st Floor	6	6,855	SF	\$58,816	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	1st Floor	7	905	SF	\$0	
Kitchen	Cooking Kitchen	Flooring - Concrete	1st Floor	7	905	SF	\$0	
Kitchen	Cooking Kitchen	Lighting - Lay-In	1st Floor	7	11	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Concrete Block	1st Floor	7	1,390	SF	\$0	partially covered with stainless steel
Locker/Shower Room	Staff Restroom	Benches	1st fl unisex north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 125			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 127			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 131			LF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 130			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 132			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl in servery- men			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl in servery- women			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl unisex north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 134			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl kitchen staff shower-not used			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys north			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl unisex south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl in main office			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 123			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl mens next to gym			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl womens next to gym			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl unisex south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 130			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl unisex south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl in servery- women	7	12	EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl unisex north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl unisex south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys south			EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl in main office			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl kitchen staff shower-not used			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl womens next to gym			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl mens next to gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 123			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 127			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl in servery- men	7	12	EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl unisex north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 131			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 132			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 125			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 134			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl unisex south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl in main office			EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 134			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl in servery- men			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl unisex north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl unisex north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl unisex south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl womens next to gym			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl mens next to gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 123			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl kitchen staff shower- not used	7	1	EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 125			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl in servery- women			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 132			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 130			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 131			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 127			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Exposed	1st Floor	7	1,805	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	1st Floor	7	759	SF	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	dishwashing room- 1st fl in lunchroom	6	135	SF	\$290	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	copy/break room in main office	7	180	SF	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	1st Floor	7	1,836	SF	\$0	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	copy/break room in main office	7	180	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	2,564	SF	\$0	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	1st Floor	7	1,836	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Lunchroom	Lighting - Lay-In	1st Floor	7	12	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	copy/break room in main office	7	3	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	dishwashing room- 1st fl in lunchroom	7	2	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	1st Floor	7	21	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	3	SF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	1st Floor			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	copy/break room in main office			LF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor	6	32	LF	\$1,373	
Lunchroom	Multipurpose Room	Serving Line	dishwashing room- 1st fl in lunchroom			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	1st Floor			LF	\$0	
Lunchroom	Multipurpose Room	Wall - Concrete Block	1st Floor	7	1,200	SF	\$0	
Lunchroom	Multipurpose Room	Wall - Concrete Block	copy/break room in main office	7	555	SF	\$0	
Lunchroom	Multipurpose Room	Wall - Concrete Block	dishwashing room- 1st fl in lunchroom	7	450	SF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	1st Floor	6	3,847	SF	\$11,002	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	1st Floor	6	855	SF	\$2,017	
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	1st Floor	6	480	SF	\$1,133	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	5	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Entire Building	7	6,737	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 125	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl in servery- women	7	97	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl unisex south	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl unisex north	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 134	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys south	7	165	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl in servery- men	7	97	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 132	7	40	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 130	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 127	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 123	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl mens next to gym	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl womens next to gym	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl unisex south	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys north	7	165	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl kitchen staff shower-not used	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 131	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl in main office	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl unisex north	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 131	6	40	SF	\$86	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl unisex north	6	40	SF	\$86	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl unisex south	6	40	SF	\$86	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd fl unisex north	6	40	SF	\$86	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl in servery- women	6	97	SF	\$208	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl in servery- men	6	97	SF	\$208	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 130	6	40	SF	\$86	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 134	6	40	SF	\$86	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 127	6	40	SF	\$86	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 125	6	40	SF	\$86	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 123	6	40	SF	\$86	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl womens next to gym	6	40	SF	\$86	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd fl unisex south	6	40	SF	\$86	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl kitchen staff shower-not used	6	40	SF	\$86	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 132	6	40	SF	\$86	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl mens next to gym	6	40	SF	\$86	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl in main office	6	40	SF	\$86	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 131	5	1	EA	\$1,502	
Staff Restroom	Staff Restroom	Floor Drain	1st fl kitchen staff shower-not used	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys north	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls north	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl unisex south	5	1	EA	\$1,502	
Staff Restroom	Staff Restroom	Floor Drain	1st fl womens next to gym	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st fl mens next to gym	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 123	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 125	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 127	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 130	5	1	EA	\$1,502	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 132	5	1	EA	\$1,502	
Staff Restroom	Staff Restroom	Floor Drain	1st fl in servery- men	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st fl in servery- women	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl unisex north	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys south	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls south	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 134	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys north	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls north	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls south	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st fl in main office	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st fl unisex north	5	1	EA	\$1,502	
Staff Restroom	Staff Restroom	Floor Drain	1st fl unisex south	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys south	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl unisex north	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl in servery- women	7	97	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl kitchen staff shower- not used	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl in servery- men	7	97	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd fl unisex north	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd fl boys south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd fl girls south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in rm 134	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st fl girls north	7	165	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl unisex south	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st fl boys south	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st fl girls south	7	165	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl womens next to gym	7	40	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd fl boys north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd fl girls north	7	165	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st fl boys north	7	165	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd fl unisex south	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl in main office	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl mens next to gym	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in rm 123	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in rm 125	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in rm 127	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in rm 131	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in rm 130	7	40	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in rm 132	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl unisex north	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl unisex north	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl unisex south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls north	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys north	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 134	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 123	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys south	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl in servery- women			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys north	6	1	EA	\$217	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl unisex south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 125	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 127	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 131	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 130	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 132	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl in servery- men			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls north	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Lavatory	1st fl womens next to gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys south	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl unisex south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl unisex south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 123	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 134	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 125	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl in servery- women	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 127	7	1	EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	1st fl in main office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls south	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl in servery- men	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 132	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 130	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl mens next to gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 131	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 130	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 131	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl in servery- women	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl girls north	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 132	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 127	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl kitchen staff shower- not used	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 123	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl mens next to gym	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl womens next to gym	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl boys north	7	5	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl unisex south	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl in servery- men	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl boys south	7	5	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl in main office	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl girls south	7	5	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl unisex south	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl unisex north	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl girls north	7	5	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl boys north	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 134	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl girls south	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl boys south	7	5	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl unisex north	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in rm 125	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls south	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys south	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls south	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 134			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys north	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls north	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl unisex north			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl in main office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys south	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 130			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl kitchen staff shower-not used			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl mens next to gym			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls north	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl in servery- men	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl womens next to gym			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl in servery- women	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 123			EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 125			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 127			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 131			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys north	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 132			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 134			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl kitchen staff shower-not used			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl unisex south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 123			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl in servery- women			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 132			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 130			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 131			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 125			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys north	7	2	EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls north			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl womens next to gym			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl mens next to gym			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl in main office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 127			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl in servery- men			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl womens next to gym	7	231	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl unisex south	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys south	7	722	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl in servery- women	7	419	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls south	7	722	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl kitchen staff shower- not used	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys north	7	722	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl in main office	7	231	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd fl unisex south	7	231	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl unisex north	7	231	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl mens next to gym	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in rm 123	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in rm 125	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in rm 127	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in rm 131	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in rm 130	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in rm 132	7	231	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl in servery- men	7	419	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls north	7	722	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in rm 134	7	231	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls south	7	722	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys south	7	722	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd fl unisex north	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls north	7	722	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys north	7	722	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl in servery- men	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls south	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl unisex south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl unisex north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls north	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 131	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 123	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 127	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl in main office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl in servery- women	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 134	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 125	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl mens next to gym	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls north	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl unisex south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl womens next to gym	7	1	EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 132	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls south	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 130	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	2	EA	\$0	
INTERIOR Sub Total							\$122,436	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	15	LF	\$0	
Casework	Classroom	Casework		7	15	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	15	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	15	LF	\$0	
Casework	Classroom	Casework		7	34	LF	\$0	
Casework	Classroom	Casework		7	15	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	133	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		5	96	LF	\$17,160	
Casework	Classroom	Casework		7	45	LF	\$0	
Casework	Classroom	Casework		7	15	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	29	LF	\$0	
Casework	Classroom	Casework		7	15	LF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,052	SF	\$2,257	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,052	SF	\$2,257	
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,160	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	762	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,000	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Multipurpose Room	Chalk Board	1st Floor	4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF		
Chalk Board	Multipurpose Room	Chalk Board	dishwashing room- 1st fl in lunchroom	4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Multipurpose Room	Chalk Board	copy/break room in main office	4		LF		

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Concrete Block	Service Corridor	7	1,065	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	Service Corridor	7	385	SF	\$0	
Corridors	Corridors	Drinking Fountains	South West Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	Service Corridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	North East Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	South East Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	North West Stair			EA	\$0	
Corridors	Corridors	Drop/Lay-In	South West Stair	7	775	SF	\$0	
Corridors	Corridors	Drop/Lay-In	North East Stair	7	775	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	6,438	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	5,860	SF	\$0	
Corridors	Corridors	Drop/Lay-In	North West Stair	7	775	SF	\$0	
Corridors	Corridors	Drop/Lay-In	South East Stair	7	775	SF	\$0	
Corridors	Corridors	Exposed	Service Corridor	7	385	SF	\$0	
Corridors	Corridors	Lay-In	South West Stair	7	775	EA	\$0	
Corridors	Corridors	Lay-In	North East Stair	7	775	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	5,860	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	5,860	EA	\$0	
Corridors	Corridors	Lay-In	North West Stair	7	775	EA	\$0	
Corridors	Corridors	Lay-In	South East Stair	7	775	EA	\$0	
Corridors	Corridors	Pendant/Surface	Service Corridor	7	385	EA	\$0	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	4	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	4	EA	\$0	
Corridors	Corridors	Stair Handrails	North East Stair	7	26	LF	\$0	
Corridors	Corridors	Stair Handrails	South West Stair	7	26	LF	\$0	
Corridors	Corridors	Stair Handrails	Service Corridor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	South East Stair	7	26	LF	\$0	
Corridors	Corridors	Stair Handrails	North West Stair	7	26	LF	\$0	
Corridors	Corridors	Stairs	Service Corridor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Service Corridor			EA	\$0	
Corridors	Corridors	Student Lockers	South West Stair			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Student Lockers	South East Stair			EA	\$0	
Corridors	Corridors	Student Lockers	North West Stair			EA	\$0	
Corridors	Corridors	Student Lockers	North East Stair			EA	\$0	
Corridors	Corridors	Terrazzo	North East Stair	7	944	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	6,438	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	5,860	SF	\$0	
Corridors	Corridors	Terrazzo	South East Stair	7	944	SF	\$0	
Corridors	Corridors	Terrazzo	North West Stair	7	944	SF	\$0	
Corridors	Corridors	Terrazzo	South West Stair	7	944	SF	\$0	
Corridors	Corridors	Walls	North East Stair	7	2,274	SF	\$0	
Corridors	Corridors	Walls	North West Stair	7	2,274	SF	\$0	
Corridors	Corridors	Walls	South West Stair	7	2,274	SF	\$0	
Corridors	Corridors	Walls	South East Stair	7	2,144	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	11,860	SF	\$0	
Corridors	Corridors	Walls	1st Floor	7	12,280	SF	\$0	
Corridors	Corridors	Walls	South East Stair	5	130	SF	\$613	step cracking
Stairs	Corridors	Terrazzo	North East Stair	7	26	SF	\$0	
Stairs	Corridors	Terrazzo	South West Stair	7	26	SF	\$0	
Stairs	Corridors	Terrazzo	South East Stair	6	26	SF	\$294	Peeling paint on underside of stair
Stairs	Corridors	Terrazzo	North West Stair	7	26	SF	\$0	
Floor	Classroom	Carpet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,000	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Tile/Sheet		7	1,052	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,052	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,160	SF	\$0	
Floor	Classroom	Tile/Sheet		7	762	SF	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
LUNCH_FLOOR	Multipurpose Room	Lunchroom Floor	dishwashing room- 1st fl in lunchroom	7	135	SF	\$0	
LUNCH_LIGHT	Lunchroom	Lunchroom Lighting	1st Floor	7	6	EA	\$0	metal halide/sodium vapor
LUNCH_WALL	Multipurpose Room	Lunchroom Walls	1st Floor	7	300	SF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Multipurpose Room	Marker Board	1st Floor	7	32	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Multipurpose Room	Marker Board	copy/break room in main office			LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Multipurpose Room	Marker Board	dishwashing room- 1st fl in lunchroom			LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0	
Wall	Classroom	Concrete Block		7	539	SF	\$0	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	458	SF	\$1,310	
Wall	Classroom	Concrete Block		6	458	SF	\$1,310	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		7	785	SF	\$0	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		7	785	SF	\$0	
Wall	Classroom	Concrete Block		7	1,116	SF	\$0	
Wall	Classroom	Concrete Block		7	544	SF	\$0	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	458	SF	\$1,310	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		7	1,116	SF	\$0	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	Step cracking and open joint
Wall	Classroom	Concrete Block		7	785	SF	\$0	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	698	SF	\$1,996	
Wall	Classroom	Concrete Block		6	458	SF	\$1,310	
Wall	Classroom	Concrete Block		7	539	SF	\$0	
Wall	Classroom	Concrete Block		7	785	SF	\$0	
Wall	Classroom	Concrete Block		7	785	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	540	SF	\$1,274	
Wall	Classroom	Plaster/Drywall		6	480	SF	\$1,133	
Wall	Classroom	Plaster/Drywall		6	270	SF	\$637	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	

**Building: Annex
Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	246	SF	\$580	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	480	SF	\$1,133	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	246	SF	\$580	
Wall	Classroom	Plaster/Drywall		6	246	SF	\$580	
Wall	Classroom	Plaster/Drywall		6	246	SF	\$580	
Wall	Classroom	Plaster/Drywall		6	492	SF	\$1,161	
Wall	Classroom	Plaster/Drywall		6	492	SF	\$1,161	
Wall	Classroom	Plaster/Drywall		6	270	SF	\$637	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	480	SF	\$1,133	
Wall	Classroom	Plaster/Drywall		6	480	SF	\$1,133	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	240	SF	\$566	
Wall	Classroom	Plaster/Drywall		6	246	SF	\$580	
ROOM Sub Total							\$110,762	
Building Annex Sub Total							\$2,351,474	

**Building: SITE
Category: SITE**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Annex Courtyard	7	2	EA	\$0	
Civil/Drainage		Catch Basin	Entire Site	7	13	EA	\$0	
Civil/Drainage		Site Manhole	Entire Building	7	17	EA	\$0	
Civil/Drainage		Site Manhole	Site North	5	1	EA	\$1,216	manhole is sinking
Fencing		Chain Link	North Parking Lot	6	267	LF	\$3,830	
Fencing		Chain Link	South of Playlot and NE of main	6	115	LF	\$1,649	
Fencing		Chain Link	East of Asphalt play area	7	350	LF	\$0	
Fencing		Guard Rail	North Parking Lot	7	267	LF	\$0	
Fencing		Ornamental Iron	Entire Building	6	1,320	LF	\$24,916	peeling paint, corrosion

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fencing		Ornamental Iron	North Parking Lot	6	517	LF	\$9,759	
Landscape		Asphalt Play Area/Hardscape	Site - Northeast	5	175	SF	\$495	cracked, uneven
Landscape		Asphalt Play Area/Hardscape	Between Buildings	6	6,075	SF	\$5,212	
Landscape		Grass	East of Annex	4	1,615	SF	\$6,397	dirt - no sod
Landscape		Hardscape - Concrete	Entire Site	7	6,595	SF	\$0	
Landscape		Hardscape - Concrete	North and East of Main	5	6,950	SF	\$43,332	cracked and uneven
Landscape		Hardscape - Pavers	Annex Courtyard- Corners at Trees	5	1,200	SF	\$11,205	displaced
Landscape		Hardscape - Pavers	Annex Courtyard	7	3,900	SF	\$0	
Landscape		Parkway trees	Entire Site	7	25	EA	\$0	
Landscape		Planting Beds/ Areas	Annex Courtyard	7	2,332	SF	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	2,645	SF	\$0	
Landscape		Retaining Wall - Concrete	Entire Site	6	185	SF	\$4,365	
Landscape		Retaining Wall - Concrete	Courtyard Annex - Planting Bed	7	1,050	SF	\$0	
Parking Lot		Asphalt	Center lot and driveway	6	13,810	SF	\$11,849	
Parking Lot		Asphalt	West drive to dumpsters	5	100	SF	\$283	pothole
Parking Lot		Asphalt	Parking Lot North	6	33,375	SF	\$28,636	
Parking Lot		Concrete	West of boiler	5	2,760	SF	\$17,208	cracked uneven
Parking Lot		Concrete Curbs	West of boiler	7	1,777	LF	\$0	
Parking Lot		Parking lot interior plantings	Entire Site	7	17	LF	\$0	
Parking Lot		Trash Compactor	Site- Southwest	6	1	EA	\$3,575	seal is leaking and clogs drain
Parking Lot		Trash Enclosure	Site West - North/South of Annex	7	910	SF	\$0	
Parking Lot		Vehicular Screening	North parking lot and west of annex	7	692	LF	\$0	
Playground		Playground Equipment - School Age 5-12	Site- Southeast	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Site - Southeast	7	2,025	SF	\$0	
Sidewalks		Internal Walks	Entire Site	7	495	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	12,945	SF	\$0	
Signage		Flag Pole	Site - North	6	2	EA	\$0	
Signage		Flag Pole	East of Annex	5	1	EA	\$4,360	leaning
Signage		Monument Sign	Site- Southeast	6	1	EA	\$0	

SITE Sub Total \$178,288

SITE Sub Total \$178,288

Building: SITE

Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Total Campus Need ^{2 3}							\$9,995,221	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	850		6	20	40	144	48	2	N	N	N	Classroom		
110	850		6	20	40	144	48	2	N	N	N	Classroom		
200	435		2	12		72	24		N	Y	Y	Classroom		
201	800	0	8	20	40	144	48	2	N	N	Y	Classroom		
203	850		6	20	40	144	48	2	N	Y	Y	Classroom		
205	905	1	8	18	40	144	48	2	N	N	Y	Classroom		
205	905	1	8	20	40	144	48	2	N	N	Y	Classroom		
207	800	0	10	20	40	144	48	2	N	N	Y	Classroom		
208	905	1	8	22	40	144	48	2	N	N	Y	Classroom		
209	905	1	8	22	40	144	48	2	N	N	Y	Classroom		
210	800	0	8	20	40	144	48	2	N	N	Y	Classroom		
300	435		2	8		72	24		N	N	Y	Classroom		
301	905	1	6	28	40	144	48	2	N	N	Y	Classroom		
302	800	0	5	16	40	144	48	2	N	Y	Y	Classroom		
303	905		6	16	40	144	48	2	N	N	Y	Classroom		
304	800	0	5	16	40	144	48	2	N	Y	Y	Classroom		
305	905	1	8	18	40	144	48	2	N	N	Y	Classroom		
306	905	1	8	18	40	144	48	2	N	N	Y	Classroom		
307	800	0	4	20	40	144	48	2	N	N	Y	Classroom		
308	800	0	4	16	40	144	48	2	N	Y	Y	Classroom		
308	800	0	33	66	40	144	48	2	N	N	Y	Classroom		
309	905	1	8	22	40	144	48	2	N	N	Y	Classroom		
310	905	1	6	28	40	144	48	2	N	N	Y	Classroom		
401	300	1	4	6	40	48	16		N	N	Y	Classroom		
402	300	1	4	6	40	48	16		N	N	Y	Classroom		
Other	16								N	N	N	Restroom	Staff Restroom	Boiler room
Other	640			10					N	N	Y	Administrative Suites/Offices		Basement Engineers office
Other	430			8					N	N	Y	Administrative Suites/Offices		1st FL - Copy
Other	250			6					N	N	N	Administrative Suites/Offices		1st FL - Teachers Resource
Other	25								N	N	N	Restroom	Staff Restroom	Gym Office
Other	100			4					N	N	Y	Administrative Suites/Offices		1st FL - Gym Office
Other	820								N	N	N	Library		2nd Floor
Other	1980								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	2256								N	N	N	Corridors		1st Floor
Other	232								N	N	N	Corridors		North and South Vestibules (Combined Total)

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	900								N	N	N	Restroom	Children's Standard Student Restroom	Gym Lockerroom
Other	400			6					N	N	Y	Administrative Suites/Offices		Main Office
Other	330			8					N	N	Y	Administrative Suites/Offices		Clerk's Office
Other	435								N	N	N	Restroom	Children's Standard Student Restroom	1st FL - Boys
Other	330			8					N	N	Y	Administrative Suites/Offices		Principals Office
Other	150								N	N	N	Corridors		Southwest Vestibule
Other	150								N	N	N	Corridors		Southeast Vestibule
Other	150								N	N	N	Corridors		West Vestibule
Other	150								N	N	N	Corridors		East Vestibule
Other	380								N	N	N	Restroom	Children's Standard Student Restroom	1st FL Girls Room
Other									N	N	N	Corridors		Auditorium
Other	200			4					N	N	N	Administrative Suites/Offices		Main Office - Counselor's Office
Other	380								N	N	N	Restroom	Children's Standard Student Restroom	2nd FL Girls Room
Other	3450								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	100								N	N	N	Restroom	Staff Restroom	3rd FL - Located within Girls Restroom
Other	380								N	N	N	Restroom	Children's Standard Student Restroom	3rd FL Girls Room
Other									N	N	N	Corridors		North Stair
Other									N	N	N	Corridors		South Stair
Other	2800								N	N	N	Auditorium & Theater		1st FL Music Room / Auditorium
Other	2370								N	N	N	Corridors		2nd Floor
Other	2370								N	N	N	Corridors		3rd Floor
Other	100								N	N	N	Restroom	Staff Restroom	2nd FL - Located within Girls Restroom
Other	380								N	N	N	Restroom	Children's Standard Student Restroom	2nd FL Boys Room
Other	405			8					N	N	N	Administrative Suites/Offices		206 A - Teachers Resource
Other	380								N	N	N	Restroom	Children's Standard Student Restroom	3rd FL Boys Room
Other	25								N	N	N	Restroom	Staff Restroom	Principals Office

Building: Annex

121	762	1	9	36	40	96	48		Y	N	Y	Classroom		
122	762	1	9	36	40	96	48		Y	N	Y	Classroom		
123	1000	1	6	14	40	120	40		Y	N	Y	Classroom		
124	762	1	9	36	40	96	48		Y	N	Y	Classroom		
125	1000	1	6	14	40	120	40		Y	N	Y	Classroom		
126	762	1	9	36	40	96	48		Y	N	Y	Classroom		
127	1000	1	6	14	40	120	40		Y	N	Y	Classroom		
128	762	1	9	36	40	96	48		Y	N	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
130	1000	1	6	14	40	128	64		Y	N	Y	Classroom		
131	1000	1	6	14	40	128	64		Y	N	Y	Classroom		
132	1000	1	6	14	40	128	64		Y	N	Y	Classroom		
134	1000	1	6	14	40	128	64		Y	N	Y	Classroom		
221	762	1	9	36	40	96	48		Y	N	Y	Classroom		
222	762	1	9	36	40	96	48		Y	N	Y	Classroom		
223	762	1	9	36	40	96	48		Y	N	Y	Classroom		
224	762	1	9	36	40	96	48		Y	N	Y	Classroom		
225	762	1	9	36	40	96	48		Y	N	Y	Classroom		
226	762	1	9	36	40	96	48		Y	N	Y	Classroom		
227	762	1	9	36	40	96	48		Y	N	Y	Classroom		
228	762	1	9	36	40	96	48		Y	N	Y	Classroom		
229	762	1	9	36	40	96	48		Y	N	Y	Classroom		
230	762	1	9	36	40	96	48		Y	N	Y	Classroom		
232	762	1	9	36	40	96	48		Y	N	Y	Classroom		
234	762	1	9	36	40	96	48		Y	N	Y	Classroom		
236	762	1	9	36	40	96	48		Y	N	Y	Classroom		
Computer	1052	1	34	68	40	112	56		Y	N	Y	Classroom		
Music	1052	1	6	20	40	112	56		Y	N	Y	Classroom		
Other	40								N	N	N	Restroom	Children's Standard Student Restroom	in rm 123
Other	2564								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	97								N	N	N	Restroom	Staff Restroom	1st fl in servery- women
Other	97								N	N	N	Restroom	Staff Restroom	1st fl in servery- men
Other	135								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	dishwashing room- 1st fl in lunchroom
Other	3491								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	143			6					N	N	Y	Administrative Suites/Offices		engineers office
Other	1836								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	1st Floor
Other	40								N	N	N	Restroom	Children's Standard Student Restroom	in rm 132
Other	40								N	N	N	Restroom	Children's Standard Student Restroom	in rm 130
Other	40								N	N	N	Restroom	Children's Standard Student Restroom	in rm 131
Other	40								N	N	N	Restroom	Staff Restroom	2nd fl unisex south
Other	40								N	N	N	Restroom	Children's Standard Student Restroom	in rm 125
Other	832			8					N	N	Y	Administrative Suites/Offices		faculty center next to 121
Other	40								N	N	N	Restroom	Staff Restroom	1st fl mens next to gym
Other	40								N	N	N	Restroom	Staff Restroom	1st fl womens next to gym
Other									N	N	N	Corridors		South West Stair
Other									N	N	N	Corridors		North West Stair

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other									N	N	N	Corridors		South East Stair
Other									N	N	N	Corridors		North East Stair
Other	385								N	N	N	Corridors		Service Corridor
Other	5860								N	N	N	Corridors		2nd Floor
Other	6438								N	N	N	Corridors		1st Floor
Other	40								N	N	N	Restroom	Staff Restroom	1st fl kitchen staff shower- not used
Other	40								N	N	N	Restroom	Children's Standard Student Restroom	in rm 127
Other	40								N	N	N	Restroom	Staff Restroom	1st fl in main office
Other	165								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls north
Other	165								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys north
Other	165								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls south
Other	165								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys south
Other	40								N	N	N	Restroom	Staff Restroom	2nd fl unisex north
Other	176			4					N	N	N	Administrative Suites/Offices		library workroom in library 2nd fl
Other	205			4					N	N	N	Administrative Suites/Offices		office in library- marked seminar, used as storage
Other	135			8					N	N	Y	Administrative Suites/Offices		Counselor B
Other	135			8					N	N	Y	Administrative Suites/Offices		Counselor A
Other	126			4					N	N	N	Administrative Suites/Offices		Student Services
Other	905								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	160			6					N	N	Y	Administrative Suites/Offices		Prinicipal's office in main office
Other	100			4					N	N	Y	Administrative Suites/Offices		kitchen managers office
Other	180								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	copy/break room in main office
Other	160			6					N	N	Y	Administrative Suites/Offices		Asst. Principal's office in main office
Other	680			8					N	N	Y	Administrative Suites/Offices		Main Office
Other	165								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls south
Other	165								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys south
Other	40								N	N	N	Restroom	Staff Restroom	1st fl unisex south
Other	40								N	N	N	Restroom	Staff Restroom	1st fl unisex north
Other	165								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls north
Other	165								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys north
Other	40								N	N	N	Restroom	Children's Standard Student Restroom	in rm 134
Other	272			6					N	N	Y	Administrative Suites/Offices		main office conference room
Science	1160	1	6	76	40	126	64		Y	N	Y	Classroom		