

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Concrete/ Stucco Canopy	North and South	7	440	SF	\$0	
Chimney		Metal Flue	Main Roof	7	45	LF	\$0	Steel chimney
Doors		Exterior Steel Door	North Façade	6	2	EA	\$661	
Doors		Store Front Door	Entire Building	6	18	EA	\$9,344	
Entrance		Concrete Exterior Stairs	South Entrances	7	42	LF	\$0	
Entrance		Concrete Ramp	West, South, North	7	60	LF	\$0	
Entrance		Entrance Controls - Audio	North Entrances	4	1	EA	\$2,288	Does not work
Entrance		Entrance Controls - Audio and Video	Entire Building	7	3	EA	\$0	
Entrance		Power Door Operator and Controls	South Entrances	7	1	EA	\$0	
Foundation		Concrete Foundation	Entire Building	5	965	LF	\$430,793	Settlement throughout, leaks reported at both basements. Visible spalling of exterior exposed foundation at west and south.

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	5	EA	\$1,073	
Lintels		Lintels - Steel	North Entrances	5	8	LF	\$2,288	
Parapet		Coping - Metal	Entire Building	6	1,068	LF	\$0	Some open seams
Roof System		Asphalt Gravel Ballast Roof	Main Roof	5	31,210	SF	\$397,656	Ponding - no leaks reported
Roof System		Interior Downspouts	Entire Building	6	192	LF	\$0	
Roof System		Modified Bitumen Roof	Elevator Addition	7	290	SF	\$0	
Roof System		Roof Structure: Concrete	Entire Building	7	31,210	SF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Elevator Addition	7	290	SF	\$0	
Superstructure		Concrete	Entire Building	7	52,400	SF	\$0	
Superstructure		Concrete	Gym, first and second floor restrooms, Classrooms 110, 113, 114, 203, 206, 209, 214	5	9,000	SF	\$196,268	Settlement issues which are causing displacement and cracking of masonry walls above.
Superstructure		Concrete	West wall, room 213	5	2,000	SF	\$43,615	Cracks at pan joist/beam and columns/wall connections
Walls		Brick	North and West Gym Wall	4	200	SF	\$15,101	Bulging Brick masonry
Walls		Brick	Entire Building	7	5,290	SF	\$0	
Walls		Prefabricated Metal Panel Wall	4 corners of building	4	96	SF	\$7,248	Missing or not anchored. Steel column enclosures.
Walls		Prefabricated Metal Panel Wall	Entire Building	7	3,020	SF	\$0	
Windows		Clerestory - Glass Double-Pane	North Façade	6	470	SF	\$4,436	No leaks reported
Windows		Curtain wall - Glazed Double Pane	Entire Building	5	10,006	SF	\$661,056	Leaks reported @ both floors, braced at north and south of main entrance lobby due to settlement issues
Windows		Curtain wall - Insulated panel	Entire Building	5	5,299	SF	\$200,048	Leaks Reported
Windows		Curtain wall - Louver	Entire Building	6	72	SF	\$680	
Windows		Curtain wall - Windows	Entire Building	5	792	SF	\$52,324	
Windows		Storefront Windows	Doors 2-5,7	6	208	SF	\$1,190	
Windows		Window - Guards perforated	Entire Building	6	4,054	SF	\$0	
EXTERIOR Sub Total							\$2,026,067	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	6	1	EA	\$1,430	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	5	11,290	SF	\$14,207	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	5	5,738	SF	\$6,564	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	35	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	12	EA	\$0	
Emergency System		Public Announcement System	Entire Building	5	63,400	SF	\$90,662	
Emergency System		Security System - Intrusion detection	Entire Building	5	63,400	SF	\$104,261	
Emergency System		UPS 30 to 60 KW	Electrical Room	2	1	EA	\$81,510	Batteries disconnected, Unit is inoperative.
Main Service		Main Electrical service 2000 to 3000 A 277/480/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	2nd Floor	4	4	EA	\$21,736	
Power Distribution		Lighting and power panels	Mechanical Room	6	1	EA	\$715	
Power Distribution		Lighting and power panels	1st Floor	4	5	EA	\$27,170	
Power Distribution		Lighting and power panels	Mechanical Room	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	2nd Floor	7	6	EA	\$0	
Power Distribution		Lighting and power panels	Boiler Room	7	2	EA	\$0	
Power Distribution		Lighting and power panels	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Boiler Room	4	1	EA	\$5,434	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	2	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Boiler Room	4	2	EA	\$37,180	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Boiler Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Mechanical Room	7	2	EA	\$0	
ELECTRICAL Sub Total							\$396,304	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	63,400	SF	\$0	
Fire Alarm		Fire Alarm System	Boiler Room	7	62,600	SF	\$0	
FIRE PROTECTION Sub Total							\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Scroll type - Roof Mounted 50 to 100 tons	Roof	6	2	EA	\$37,180	
Air Conditioning		Chillers - Air Cooled - Scroll type - Roof Mounted less than 50 tons	Roof	6	1	EA	\$16,445	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	2nd Floor	6	1	EA	\$215	
Air Conditioning		Window A/C Unit	2nd Floor	4	1	EA	\$2,145	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 20,001 to 30,000 cfm	Mechanical Room	4	1	EA	\$121,550	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water above 30,000 cfm	Boiler Room	4	1	EA	\$200,200	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Roof	5	2	EA	\$11,440	
Air Handling Systems		Fan Coil Unit - Electric	2nd Floor	5	1	EA	\$5,935	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	Mechanical Room	4	1	EA	\$24,310	
Air Handling Systems		Return Fans - Indoor greater than 20,000 CFM	Boiler Room	4	1	EA	\$32,890	
Air Handling Systems		Variable Air Volume (VAV) Box With Hot Water Coil	Entire Building	5	40	EA	\$65,780	
Boiler Systems		Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler 2,001MBH-3,000 MBH	Boiler Room	7	2	EA	\$0	
Boiler Systems		Boiler Auxiliary Non-Condensing Hot Water Boiler 2,001MBH-3,000 MBH	Boiler Room	7	2	EA	\$0	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	6	1	EA	\$300	
Boiler Systems		Chemical Pot Feeder - Hot Water	Mechanical Room	6	1	EA	\$300	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	6	1	EA	\$300	
Boiler Systems		Combustion Dampers	Boiler Room	7	2	EA	\$0	
Boiler Systems		Glycol Feed System	Mechanical Room	7	1	EA	\$0	
Boiler Systems		Glycol Feed System	Boiler Room	7	1	EA	\$0	
Heat Exchangers		Heat Exchanger - Water to Water Plate Type	Mechanical Room	6	1	EA	\$5,577	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	6	19	EA	\$9,510	
Heating Devices		Unit Heater - Hot Water	2nd Floor	4	2	EA	\$14,300	
Heating Devices		Wall Heater - Electric	1st Floor	6	1	EA	\$103	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Copper	Entire Building	5	400	LF	\$27,170	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	6	48	LF	\$426	
Mechanical Plumbing		Pumps - Chilled Water less than 10 HP	Mechanical Room	6	4	EA	\$8,008	
Mechanical Plumbing		Pumps - Chilled Water less than 10 HP	Boiler Room	6	2	EA	\$4,004	
Mechanical Plumbing		Pumps - Hot Water 5 to 10 HP	Boiler Room	5	1	EA	\$8,580	
Mechanical Plumbing		Pumps - Hot Water 5 to 10 HP	Boiler Room	6	3	EA	\$6,006	
Mechanical Plumbing		Pumps - Hot Water 5 to 10 HP	Mechanical Room	6	2	EA	\$4,004	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	6	63,400	SF	\$63,463	
Temperature Control		Thermostats - Direct Digital Control (DDC)	1st Floor	4	1	EA	\$930	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	64	EA	\$9,152	
Unit Ventilation		Unit Ventilators - Hot Water and Chilled Water	Entire Building	6	8	EA	\$13,728	
Ventilation		Exhaust Fan - Indoor	Electrical Room	6	1	EA	\$501	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ventilation		Exhaust Fan - Indoor	1st Floor	6	1	EA	\$501	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	3	EA	\$1,287	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	4	EA	\$915	
MECHANICAL Sub Total							\$697,153	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	7	1	EA	\$0	
Hot Water		Storage Tank less than 500 gallons	Basement	6	2	EA	\$3,718	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	63,400	SF	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	63,400	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	63,400	SF	\$9,973	
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	63,400	SF	\$9,973	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	63,400	SF	\$14,506	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	63,400	SF	\$9,973	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	63,400	SF	\$9,973	
Piping		Sanitary Piping	Entire Building	6	63,400	SF	\$25,385	
Piping		Storm Piping	Entire Building	6	63,400	SF	\$13,599	
Piping		Vent Piping	Entire Building	6	63,400	SF	\$9,973	
Pumps		Ejector Pump	Mechanical Room	6	1	EA	\$3,003	
Pumps		Ejector Pump	Boiler Room	4	1	EA	\$30,030	
PLUMBING Sub Total							\$140,106	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Exposed	Adjustment and councilor office #112	7	442	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Exposed	main Office	7	357	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Exposed	Teachers lounge - 2ed floor	7	180	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Exposed	principals office	7	187	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Exposed	Councilors office/ Nurse	7	226	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	Parent /Teacher 2ed floor	7	238	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	main Office	7	102	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	principals office	7	187	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile Ceramic/Porcelain	main Office	7	255	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Councilors office/ Nurse	7	226	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Parent /Teacher 2ed floor	6	238	SF	\$340	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Teachers lounge - 2ed floor	7	180	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Adjustment and councilor office #112	7	442	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Parent /Teacher 2ed floor	4	6	SF	\$39	T12
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	main Office	4	8	SF	\$53	T12
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Teachers lounge - 2ed floor	4	3	SF	\$20	T12
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	principals office	4	4	SF	\$26	T12
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Adjustment and councilor office #112	4	8	SF	\$53	T12
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Councilors office/ Nurse	4	4	SF	\$26	T12
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	main Office	7	280	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Adjustment and councilor office #112	7	802	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Councilors office/ Nurse	7	634	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Teachers lounge - 2ed floor	7	541	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	principals office	7	476	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	Parent /Teacher 2ed floor	7	577	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	Parent /Teacher 2ed floor	7	41	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	Teachers lounge - 2ed floor	7	38	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	Councilors office/ Nurse	7	45	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	Adjustment and councilor office #112	7	57	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	principals office	7	34	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	main Office	7	530	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	8	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	7	89	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	29	EA	\$8,211	
Doors		Side-lite	Entire Building	7	1,361	SF	\$0	
Doors		Store Front Door	Entire Building	7	8	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	lobby	7	0	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2ed floor - corridor 5	7	0	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2ed floor - corridor 6	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2 ed Floor - corridor 2	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st floor - corridor 1	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2ed floor - corridor 1	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor - corridor 3	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st floor - corridor 4	7	0	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor - corridor 2	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st floor - corridor 5	7	0	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st floor - corridor 6	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2ed Floor - corridor 3	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2ed floor - corridor 4	7	0	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Ceiling - Exposed	1st Floor	7	4,004	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Flooring - Wood	1st Floor	6	4,004	SF	\$30,232	
Gymnasium / Auditorium	Gymnasium.Auditorium	Scoreboards	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Sound System	1st Floor	4	1	EA	\$42,900	it works but not well/ low tech per building engineer
Gymnasium / Auditorium	Gymnasium.Auditorium	Stage Curtain	1st Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Concrete Block	1st Floor	7	6,220	SF	\$0	
Gymnasium / Auditorium	Gymnasium.Auditorium	Walls - Structural Glazed Tile	1st Floor	7	160	SF	\$0	
Kitchen	Warming Kitchen	Ceiling - Splined	on plan - room 117	7	867	SF	\$0	
Kitchen	Warming Kitchen	Flooring - Tile/Sheet	on plan - room 117	6	867	SF	\$1,240	
Kitchen	Warming Kitchen	Lighting - Pendant/Surface	on plan - room 117	4	14	SF	\$92	T12
Kitchen	Warming Kitchen	Wall - Concrete Block	on plan - room 117	7	850	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Kitchen	Warming Kitchen	Wall - Structural Glazed Tile	on plan - room 117	7	80	SF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	Kindergarten 107			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in cooridor by gym (plan GT)			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Girls - 1st floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Boys - 1st floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Girl - 1st floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Boys - 1st floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Boys - 2ed floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Girl -2 ed floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Staff toilet off cooridor by office			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Girls 2ed floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Councilor Toilet			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Mens - 2ed floor by rm 201			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	womens - 2ed floor by rm 201			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	womens - 2ed floor by rm 213			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	Kindergarten 109			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	principals toilet			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Boys - 2ed floor			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Councilor Toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Mens - 2ed floor by rm 201			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Boys - 2ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Girls 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	womens - 2ed floor by rm 213			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	Kindergarten 109			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Early Childhood Student Restroom	Lockers	Kindergarten 107			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	principals toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Staff toilet off cooridor by office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Girl -2 ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in cooridor by gym (plan GT)			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Boys - 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	womens - 2ed floor by rm 201			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Boys - 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Girl - 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Boys - 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Girls - 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Boys - 2ed floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Mens - 2ed floor by rm 201			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Boys - 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Girl - 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Boys - 1st floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Boys - 2ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Girl -2 ed floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Girls - 1st floor			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Councilor Toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in cooridor by gym (plan GT)			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	womens - 2ed floor by rm 201			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	womens - 2ed floor by rm 213			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Early Childhood Student Restroom	Showers	Kindergarten 109			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	Kindergarten 107			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	principals toilet			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Staff toilet off cooridor by office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Girls 2ed floor			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Splined	on plan - Rooms 115 & 116	7	1,734	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	on plan - Rooms 115 & 116	6	1,734	SF	\$2,480	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	on plan - Rooms 115 & 116	4	16	SF	\$105	T12
Lunchroom	Lunchroom	Serving Line	on plan - Rooms 115 & 116			LF	\$0	
Lunchroom	Warming Kitchen	Serving Line	on plan - room 117	7	14	LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	on plan - Rooms 115 & 116	7	1,100	SF	\$0	
Lunchroom	Lunchroom	Wall - Structural Glazed Tile	on plan - Rooms 115 & 116	7	112	SF	\$0	
MDF/IDF		Finishes	Mechanical Room	7	208	SF	\$0	
MDF/IDF		Ventilation and Cooling	Mechanical Room	7	1	EA	\$0	
Mechanical/Service Rooms		Air Handling/ Mechanical Room	Basement	7	1,540	SF	\$0	
Mechanical/Service Rooms		Boiler Room	Basement	6	3,640	SF	\$17,177	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	4	SF	\$19	
Mechanical/Service Rooms		Storage Room	Entire Building	6	600	SF	\$2,831	
Mechanical/Service Rooms		Vaults	1st Floor	7	120	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in cooridor by gym (plan GT)	6	80	SF	\$618	
Staff Restroom	Staff Restroom	Accessories	womens - 2ed floor by rm 201	7	96	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Councilor Toilet	7	18	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Boys - 1st floor	6	144	SF	\$1,112	
Staff Restroom	Children's Standard Student Restroom	Accessories	Boys - 1st floor	6	246	SF	\$1,900	
Staff Restroom	Children's Standard Student Restroom	Accessories	Boys - 2ed floor	6	246	SF	\$1,900	
Staff Restroom	Children's Standard Student Restroom	Accessories	Girl -2 ed floor	6	144	SF	\$1,112	
Staff Restroom	Children's Standard Student Restroom	Accessories	Girls 2ed floor	6	364	SF	\$2,811	
Staff Restroom	Children's Standard Student Restroom	Accessories	Girl - 1st floor	6	144	SF	\$1,112	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Accessories	Staff toilet off cooridor by office	7	54	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	principals toilet	7	54	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Kindergarten 107	7	30	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	Kindergarten 109	7	30	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	womens - 2ed floor by rm 213	6	96	SF	\$741	
Staff Restroom	Staff Restroom	Accessories	Mens - 2ed floor by rm 201	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Girls - 1st floor	6	246	SF	\$1,900	
Staff Restroom	Children's Standard Student Restroom	Accessories	Boys - 2ed floor	6	144	SF	\$1,112	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Exposed	Boys - 2ed floor	7	246	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Exposed	Boys - 1st floor	7	246	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Exposed	Councilor Toilet	7	18	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Exposed	in cooridor by gym (plan GT)	7	80	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Exposed	Mens - 2ed floor by rm 201	7	54	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Exposed	womens - 2ed floor by rm 201	7	96	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Exposed	womens - 2ed floor by rm 213	7	96	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Exposed	Kindergarten 109	7	30	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Exposed	Kindergarten 107	7	30	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Exposed	principals toilet	7	54	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Exposed	Staff toilet off cooridor by office	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Exposed	Girls 2ed floor	7	364	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Exposed	Girls - 1st floor	7	246	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Splined	Boys - 2ed floor	7	144	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Splined	Girl -2 ed floor	7	144	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Splined	Boys - 1st floor	7	144	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Splined	Girl - 1st floor	7	144	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Boys - 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Girl - 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Boys - 2ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Boys - 1st floor	6	2	EA	\$601	Settling issue
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Girl -2 ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Boys - 2ed floor	6	2	EA	\$601	Settling issue
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Girls 2ed floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in cooridor by gym (plan GT)	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Mens - 2ed floor by rm 201	7	0	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	womens - 2ed floor by rm 201	7	0	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	womens - 2ed floor by rm 213	7	0	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	Kindergarten 109			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	principals toilet			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Staff toilet off cooridor by office			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Councilor Toilet			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	Kindergarten 107			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Girls - 1st floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Mens - 2ed floor by rm 201	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Boys - 2ed floor	7	144	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Girls - 1st floor	6	246	SF	\$626	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Boys - 1st floor	6	246	SF	\$626	some settling ocuring
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Girl - 1st floor	7	144	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Boys - 2ed floor	6	246	SF	\$626	some settling ocuring
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Girl -2 ed floor	7	144	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Staff toilet off cooridor by office	6	54	SF	\$137	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	principals toilet	6	54	SF	\$137	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	womens - 2ed floor by rm 201	7	96	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	womens - 2ed floor by rm 213	7	96	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Girls 2ed floor	7	364	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in cooridor by gym (plan GT)	7	80	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Councilor Toilet	7	18	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	Kindergarten 107	7	30	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	Kindergarten 109	7	30	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Girl -2 ed floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Girls - 1st floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Boys - 1st floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Girl - 1st floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Boys - 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Mens - 2ed floor by rm 201			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Boys - 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in cooridor by gym (plan GT)			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Councilor Toilet			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Staff toilet off cooridor by office			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	principals toilet			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	Kindergarten 107			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	Kindergarten 109			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Girls 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	womens - 2ed floor by rm 201			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Boys - 1st floor			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	womens - 2ed floor by rm 213			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Councilor Toilet	7	0	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Girls 2ed floor	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	in cooridor by gym (plan GT)	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	womens - 2ed floor by rm 201	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	Kindergarten 109	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	Kindergarten 107	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Staff toilet off cooridor by office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Mens - 2ed floor by rm 201	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Girls 2ed floor	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	principals toilet	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Boys - 1st floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Boys - 2ed floor	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	womens - 2ed floor by rm 213	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Boys - 1st floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Girl -2 ed floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Boys - 1st floor	5	1	EA	\$1,859	falling off wall
Staff Restroom	Children's Standard Student Restroom	Lavatory	Girls - 1st floor	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Boys - 2ed floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Girl - 1st floor	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Girl - 1st floor	4	1	SF	\$4	T12
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Girls 2ed floor	4	3	SF	\$13	T12
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Boys - 1st floor	4	2	SF	\$9	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Girls - 1st floor	4	2	SF	\$9	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	Kindergarten 109	4	1	SF	\$4	T12
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in cooridor by gym (plan GT)	4	2	SF	\$9	T12
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Boys - 1st floor	4	1	SF	\$4	T12
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Boys - 2ed floor	4	2	SF	\$9	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Girl -2 ed floor	4	1	SF	\$4	T12
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Boys - 2ed floor	4	1	SF	\$4	T12
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	principals toilet	4	1	SF	\$4	T12
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	Kindergarten 107	4	1	SF	\$4	T12
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Staff toilet off cooridor by office	4	1	SF	\$4	T12
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	womens - 2ed floor by rm 201	4	1	EA	\$322	incandescent
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	Mens - 2ed floor by rm 201	4	1	EA	\$322	incandescent
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	Councilor Toilet	4	1	EA	\$322	incandescent
Staff Restroom	Children's Standard Student Restroom	Partitions	Girls 2ed floor	6	8	EA	\$1,435	
Staff Restroom	Children's Standard Student Restroom	Partitions	Girls - 1st floor	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Boys - 1st floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Girl - 1st floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Boys - 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Boys - 2ed floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Boys - 2ed floor	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Partitions	in cooridor by gym (plan GT)			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Mens - 2ed floor by rm 201	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Councilor Toilet	7	0	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	Kindergarten 107			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	womens - 2ed floor by rm 213	7	0	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	womens - 2ed floor by rm 201	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Staff toilet off cooridor by office	6	1	EA	\$179	
Staff Restroom	Staff Restroom	Partitions	principls toilet			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	Kindergarten 109			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Girl -2 ed floor	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Boys - 2ed floor	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Girl -2 ed floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Boys - 2ed floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Girls 2ed floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in cooridor by gym (plan GT)			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Mens - 2ed floor by rm 201			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	womens - 2ed floor by rm 201			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	womens - 2ed floor by rm 213			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Boys - 1st floor	7	4	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	Kindergarten 109			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	Kindergarten 107			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Girl - 1st floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Staff toilet off cooridor by office			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Councilor Toilet			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	Boys - 1st floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Girls - 1st floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	principals toilet			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Boys - 2ed floor	7	190	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Girls - 1st floor	7	190	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Girls 2ed floor	5	240	SF	\$1,812	cracking and seperation ocuring
Staff Restroom	Staff Restroom	Wall - Concrete Block	in cooridor by gym (plan GT)	6	108	SF	\$309	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Mens - 2ed floor by rm 201	7	90	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	womens - 2ed floor by rm 201	7	120	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	Kindergarten 109	6	212	SF	\$606	
Staff Restroom	Early Childhood Student Restroom	Wall - Concrete Block	Kindergarten 107	6	212	SF	\$606	
Staff Restroom	Staff Restroom	Wall - Concrete Block	principals toilet	7	90	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Staff toilet off cooridor by office	7	90	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Councilor Toilet	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Boys - 1st floor	5	190	SF	\$1,435	walls are settling
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	in cooridor by gym (plan GT)	7	252	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	principals toilet	7	210	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Boys - 2ed floor	5	400	SF	\$18,876	settling issues
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Staff toilet off cooridor by office	7	210	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	Kindergarten 107	7	15	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	Kindergarten 109	7	15	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	womens - 2ed floor by rm 201	7	280	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Mens - 2ed floor by rm 201	7	210	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Girls 2ed floor	5	560	SF	\$26,426	cracking and seperation ocuring

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Girl -2 ed floor	5	400	SF	\$18,876	settling issues
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Boys - 2ed floor	7	441	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Boys - 1st floor	5	400	SF	\$18,876	settling issues
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Girl - 1st floor	5	400	SF	\$18,876	settling issues
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Boys - 1st floor	5	441	SF	\$20,811	walls are settling
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Councilor Toilet	7	126	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	Girls - 1st floor	7	441	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	Councilor Toilet	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Girl -2 ed floor	6	1	EA	\$372	loose and not stable
Staff Restroom	Children's Standard Student Restroom	Water Closet	Boys - 2ed floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Girls 2ed floor	7	8	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in cooridor by gym (plan GT)	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Mens - 2ed floor by rm 201	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	womens - 2ed floor by rm 201	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	womens - 2ed floor by rm 213	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Staff toilet off cooridor by office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Girl -2 ed floor	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	Kindergarten 109	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	Kindergarten 107	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Boys - 1st floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Girl - 1st floor	5	1	EA	\$1,859	loose and not stable
Staff Restroom	Children's Standard Student Restroom	Water Closet	Girl - 1st floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Boys - 1st floor	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	Girls - 1st floor	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	principals toilet	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Boys - 2ed floor	7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
INTERIOR Sub Total							\$261,579	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	32	LF	\$1,144	
Casework	Classroom	Casework		7	27	LF	\$0	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		7	27	LF	\$0	
Casework	Classroom	Casework		7	0	LF	\$0	
Casework	Classroom	Casework		6	32	LF	\$1,144	
Casework	Classroom	Casework		6	32	LF	\$1,144	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		7	86	LF	\$0	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		6	30	LF	\$1,073	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		6	0	LF	\$0	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		6	25	LF	\$894	
Casework	Classroom	Casework		6	14	LF	\$501	
Ceiling	Classroom	Exposed Ceiling		7	858	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	1,144	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	960	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	960	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	910	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	858	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	988	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	936	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	858	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	858	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	858	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	858	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	858	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	936	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	936	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	1,144	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	910	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	910	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	910	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	910	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	910	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	910	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	936	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	936	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	936	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	936	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	936	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	858	SF	\$0	
Ceiling	Classroom	Exposed Ceiling		7	910	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Splined Ceiling		6	884	SF	\$1,896	
Ceiling	Classroom	Splined Ceiling		6	884	SF	\$1,896	
Ceiling	Classroom	Splined Ceiling		6	884	SF	\$1,896	
Ceiling	Classroom	Splined Ceiling		6	884	SF	\$1,896	
Ceiling	Classroom	Splined Ceiling		6	884	SF	\$1,896	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Lunchroom	Chalk Board	on plan - Rooms 115 & 116	4		LF		
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	0	LF	\$0	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Asphalt	Stair 1	7	150	SF	\$0	
Corridors	Corridors	Concrete Block	Stair8	7	375	SF	\$0	
Corridors	Corridors	Concrete Block	Stair 7	7	770	SF	\$0	
Corridors	Corridors	Concrete Block	1st floor - corridor 5	7	32	SF	\$0	
Corridors	Corridors	Concrete Block	1st floor - corridor 6	7	288	SF	\$0	
Corridors	Corridors	Concrete Block	lobby	7	987	SF	\$0	
Corridors	Corridors	Concrete Block	Stair 2	7	462	SF	\$0	
Corridors	Corridors	Concrete Block	1st floor - corridor 5	7	525	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor - corridor 3	7	426	SF	\$0	
Corridors	Corridors	Concrete Block	1st floor - corridor 4	7	525	SF	\$0	
Corridors	Corridors	Concrete Block	Stair 3	7	462	SF	\$0	
Corridors	Corridors	Concrete Block	2ed floor - corridor 1	7	486	SF	\$0	
Corridors	Corridors	Concrete Block	2ed floor - corridor 4	7	32	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor - corridor 2	7	125	SF	\$0	
Corridors	Corridors	Concrete Block	1st floor - corridor 1	7	486	SF	\$0	
Corridors	Corridors	Concrete Block	Kindergarten vestibule	7	45	SF	\$0	
Corridors	Corridors	Concrete Block	1st floor - corridor 4	7	32	SF	\$0	
Corridors	Corridors	Concrete Block	2ed floor - corridor 4	7	525	SF	\$0	
Corridors	Corridors	Concrete Block	2ed floor - corridor 5	7	32	SF	\$0	
Corridors	Corridors	Concrete Block	2ed floor - corridor 5	7	525	SF	\$0	
Corridors	Corridors	Concrete Block	lobby	7	288	SF	\$0	
Corridors	Corridors	Concrete Block	2ed Floor - corridor 3	7	426	SF	\$0	
Corridors	Corridors	Concrete Block	2ed floor - corridor 6	7	288	SF	\$0	
Corridors	Corridors	Concrete Block	2 ed Floor - corridor 2	7	125	SF	\$0	
Corridors	Corridors	Drinking Fountains	Stair 3			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 2			EA	\$0	
Corridors	Corridors	Drinking Fountains	Kindergarten vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 1			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 7			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair8			EA	\$0	
Corridors	Corridors	Drop/Lay-In	Stair 7	7	480	SF	\$0	
Corridors	Corridors	Exposed	2ed floor - corridor 1	7	630	SF	\$0	
Corridors	Corridors	Exposed	Stair 1	7	624	SF	\$0	
Corridors	Corridors	Exposed	2ed floor - corridor 6	7	400	SF	\$0	
Corridors	Corridors	Exposed	2ed floor - corridor 5	7	824	SF	\$0	
Corridors	Corridors	Exposed	2ed floor - corridor 4	7	824	SF	\$0	
Corridors	Corridors	Exposed	1st floor - corridor 5	7	824	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Exposed	Stair 3	7	225	SF	\$0	
Corridors	Corridors	Exposed	Stair 2	7	225	SF	\$0	
Corridors	Corridors	Exposed	lobby	7	1,323	SF	\$0	
Corridors	Corridors	Exposed	Kindergarten vestibule	7	135	SF	\$0	
Corridors	Corridors	Exposed	1st floor - corridor 6	7	400	SF	\$0	
Corridors	Corridors	Exposed	1st floor - corridor 1	7	630	SF	\$0	
Corridors	Corridors	Exposed	2ed Floor - corridor 3	7	600	SF	\$0	
Corridors	Corridors	Exposed	1st Floor - corridor 3	7	600	SF	\$0	
Corridors	Corridors	Exposed	1st floor - corridor 4	7	824	SF	\$0	
Corridors	Corridors	Lay-In	Stair 7	7	480	EA	\$0	
Corridors	Corridors	Lighting	Stair 2	7	225	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor - corridor 5	7	824	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor - corridor 4	7	824	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor - corridor 2	7	642	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor - corridor 1	7	729	EA	\$0	
Corridors	Corridors	Pendant/Surface	Kindergarten vestibule	4	1	EA	\$10	T12
Corridors	Corridors	Pendant/Surface	1st Floor - corridor 3	7	600	EA	\$0	
Corridors	Corridors	Pendant/Surface	2ed floor - corridor 5	7	824	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor - corridor 6	7	400	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 1	7	624	EA	\$0	
Corridors	Corridors	Pendant/Surface	2ed floor - corridor 6	7	400	EA	\$0	
Corridors	Corridors	Pendant/Surface	2ed floor - corridor 4	7	824	EA	\$0	
Corridors	Corridors	Pendant/Surface	2ed Floor - corridor 3	7	600	EA	\$0	
Corridors	Corridors	Pendant/Surface	2 ed Floor - corridor 2	7	642	EA	\$0	
Corridors	Corridors	Pendant/Surface	2ed floor - corridor 1	7	729	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 3	7	225	EA	\$0	
Corridors	Corridors	Pendant/Surface	lobby	7	1,323	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair8	7	240	EA	\$0	
Corridors	Corridors	Plaster/Drywall	Stair 7	7	566	SF	\$0	
Corridors	Corridors	Splined	2 ed Floor - corridor 2	7	642	SF	\$0	
Corridors	Corridors	Splined	Stair8	7	240	SF	\$0	
Corridors	Corridors	Splined	1st floor - corridor 1	7	99	SF	\$0	
Corridors	Corridors	Splined	2ed floor - corridor 1	7	99	SF	\$0	
Corridors	Corridors	Splined	1st Floor - corridor 2	7	642	SF	\$0	
Corridors	Corridors	Stair Handrails	1st floor - corridor 5			LF	\$0	
Corridors	Corridors	Stair Handrails	2 ed Floor - corridor 2			LF	\$0	
Corridors	Corridors	Stair Handrails	2ed Floor - corridor 3			LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stair Handrails	2ed floor - corridor 4			LF	\$0	
Corridors	Corridors	Stair Handrails	2ed floor - corridor 5			LF	\$0	
Corridors	Corridors	Stair Handrails	2ed floor - corridor 6			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 1	7	105	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 7	7	25	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair8	7	25	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 3	7	14	LF	\$0	
Corridors	Corridors	Stair Handrails	lobby			LF	\$0	
Corridors	Corridors	Stair Handrails	Kindergarten vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor - corridor 4			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor - corridor 3			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor - corridor 2			LF	\$0	
Corridors	Corridors	Stair Handrails	2ed floor - corridor 1			LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor - corridor 6			LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor - corridor 1			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 2	7	25	LF	\$0	
Corridors	Corridors	Stairs	1st floor - corridor 1			EA	\$0	
Corridors	Corridors	Stairs	Kindergarten vestibule			EA	\$0	
Corridors	Corridors	Stairs	lobby			EA	\$0	
Corridors	Corridors	Stairs	1st Floor - corridor 2			EA	\$0	
Corridors	Corridors	Stairs	1st Floor - corridor 3			EA	\$0	
Corridors	Corridors	Stairs	1st floor - corridor 4			EA	\$0	
Corridors	Corridors	Stairs	1st floor - corridor 6			EA	\$0	
Corridors	Corridors	Stairs	2ed floor - corridor 1			EA	\$0	
Corridors	Corridors	Stairs	2 ed Floor - corridor 2			EA	\$0	
Corridors	Corridors	Stairs	2ed Floor - corridor 3			EA	\$0	
Corridors	Corridors	Stairs	2ed floor - corridor 4			EA	\$0	
Corridors	Corridors	Stairs	2ed floor - corridor 5			EA	\$0	
Corridors	Corridors	Stairs	2ed floor - corridor 6			EA	\$0	
Corridors	Corridors	Stairs	1st floor - corridor 5			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor - corridor 6	7	672	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor - corridor 6	7	672	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair8	7	922	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor - corridor 4	7	1,225	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 7	7	922	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor - corridor 5	7	1,225	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor - corridor 4	7	1,225	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Structural Glazed Tile	2ed Floor - corridor 3	7	994	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2 ed Floor - corridor 2	7	891	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2ed floor - corridor 1	7	1,134	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 3	7	682	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 2	7	682	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor - corridor 5	7	1,225	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor - corridor 2	7	891	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor - corridor 1	7	1,134	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Kindergarten vestibule	7	105	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor - corridor 3	7	994	SF	\$0	
Corridors	Corridors	Student Lockers	2ed floor - corridor 4			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor - corridor 1			EA	\$0	
Corridors	Corridors	Student Lockers	Kindergarten vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	lobby			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 2			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 3			EA	\$0	
Corridors	Corridors	Student Lockers	2 ed Floor - corridor 2			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor - corridor 2			EA	\$0	
Corridors	Corridors	Student Lockers	2ed Floor - corridor 3			EA	\$0	
Corridors	Corridors	Student Lockers	2ed floor - corridor 1			EA	\$0	
Corridors	Corridors	Student Lockers	2ed floor - corridor 5			EA	\$0	
Corridors	Corridors	Student Lockers	2ed floor - corridor 6			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 1			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 7			EA	\$0	
Corridors	Corridors	Student Lockers	Stair8			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor - corridor 6			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor - corridor 3			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor - corridor 4			EA	\$0	
Corridors	Corridors	Student Lockers	1st floor - corridor 5			EA	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	Stair8	7	140	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	Stair 7	7	257	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	Stair 3	7	187	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	Stair 2	7	187	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	lobby	7	1,323	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor - corridor 3	6	600	SF	\$858	
Corridors	Corridors	Tile/Sheet Flooring	Kindergarten vestibule	5	135	SF	\$764	floor settling
Corridors	Corridors	Tile/Sheet Flooring	1st floor - corridor 4	6	824	SF	\$1,178	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Tile/Sheet Flooring	1st floor - corridor 1	6	729	SF	\$1,042	
Corridors	Corridors	Tile/Sheet Flooring	Stair8	7	230	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair 7	7	350	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair 1	7	430	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Stair 3	7	170	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2ed floor - corridor 5	6	824	SF	\$1,178	
Corridors	Corridors	Tile/Sheet Flooring	1st floor - corridor 5	6	824	SF	\$1,178	
Corridors	Corridors	Tile/Sheet Flooring	2ed floor - corridor 4	6	824	SF	\$1,178	
Corridors	Corridors	Tile/Sheet Flooring	1st floor - corridor 6	6	400	SF	\$572	
Corridors	Corridors	Tile/Sheet Flooring	2ed Floor - corridor 3	6	600	SF	\$858	
Corridors	Corridors	Tile/Sheet Flooring	Stair 2	7	170	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2 ed Floor - corridor 2	6	642	SF	\$918	
Corridors	Corridors	Tile/Sheet Flooring	2ed floor - corridor 1	6	729	SF	\$1,042	
Corridors	Corridors	Tile/Sheet Flooring	2ed floor - corridor 6	6	400	SF	\$572	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor - corridor 2	6	642	SF	\$918	
Corridors	Corridors	Walls	Stair 1	7	0	SF	\$0	
Stairs	Corridors	Asphalt	Stair 1	7	19	SF	\$0	
Stairs	Corridors	Tile	Stair 7	7	19	SF	\$0	
Stairs	Corridors	Tile	Stair 2	7	19	SF	\$0	
Stairs	Corridors	Tile	Stair 3	7	19	SF	\$0	
Stairs	Corridors	Tile	Stair8	7	19	SF	\$0	
Floor	Classroom	Carpet		7	858	SF	\$0	
Floor	Classroom	Carpet		7	988	SF	\$0	
Floor	Classroom	Carpet		6	960	SF	\$1,373	
Floor	Classroom	Floor		6	936	SF	\$4,015	
Floor	Classroom	Floor		6	936	SF	\$4,015	
Floor	Classroom	Floor		6	936	SF	\$4,015	
Floor	Classroom	Floor		5	936	SF	\$9,369	Potential strcural repair along masonry wall
Floor	Classroom	Floor		6	936	SF	\$4,015	
Floor	Classroom	Tile/Sheet		6	936	SF	\$1,338	
Floor	Classroom	Tile/Sheet		6	960	SF	\$1,373	
Floor	Classroom	Tile/Sheet		7	884	SF	\$0	
Floor	Classroom	Tile/Sheet		7	910	SF	\$0	
Floor	Classroom	Tile/Sheet		6	936	SF	\$1,338	
Floor	Classroom	Tile/Sheet		6	858	SF	\$1,227	
Floor	Classroom	Tile/Sheet		6	858	SF	\$1,227	
Floor	Classroom	Tile/Sheet		6	858	SF	\$1,227	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Tile/Sheet		6	858	SF	\$1,227	
Floor	Classroom	Tile/Sheet		6	910	SF	\$1,301	
Floor	Classroom	Tile/Sheet		6	858	SF	\$1,227	
Floor	Classroom	Tile/Sheet		7	1,144	SF	\$0	
Floor	Classroom	Tile/Sheet		7	884	SF	\$0	
Floor	Classroom	Tile/Sheet		6	910	SF	\$1,301	
Floor	Classroom	Tile/Sheet		5	858	SF	\$4,859	many loose tile
Floor	Classroom	Tile/Sheet		6	910	SF	\$1,301	
Floor	Classroom	Tile/Sheet		7	1,144	SF	\$0	
Floor	Classroom	Tile/Sheet		7	884	SF	\$0	
Floor	Classroom	Tile/Sheet		7	884	SF	\$0	
Floor	Classroom	Tile/Sheet		7	884	SF	\$0	
Floor	Classroom	Tile/Sheet		6	910	SF	\$1,301	
Floor	Classroom	Tile/Sheet		6	910	SF	\$1,301	
Floor	Classroom	Tile/Sheet		6	910	SF	\$1,301	
GYM_LIGHT	Gymnasium.Auditorium	Gymnasia Lighting	1st Floor			EA	\$0	
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		7	22	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	22	EA	\$0	
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	24	EA	\$9,438	T12

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		4	24	EA	\$9,438	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	T12
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	T12
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	T12
Lighting	Classroom	Pendant/Surface		4	12	EA	\$4,719	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Lighting	Classroom	Pendant/Surface		4	21	EA	\$8,258	T12
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Lunchroom	Marker Board	on plan - Rooms 115 & 116			LF	\$0	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	0	LF	\$0	
RESTROOM_FLOOR	Children's Standard Student Restroom	Restroom Floor	Boys - 1st floor	6	144	SF	\$367	
RESTROOM_LIGHT	Staff Restroom	Restroom Lighting	womens - 2ed floor by rm 213	4	2	EA	\$644	T12
RESTROOM_WALL	Staff Restroom	Restroom Walls	womens - 2ed floor by rm 213	7	280	SF	\$0	
RESTROOM_WALL	Staff Restroom	Restroom Walls	womens - 2ed floor by rm 213	7	120	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	1,060	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		5	920	SF	\$6,946	multiple cracks and seperation
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	987	SF	\$0	
Wall	Classroom	Concrete Block		5	920	SF	\$6,946	Walls cracking in variuos locations
Wall	Classroom	Concrete Block		7	1,060	SF	\$0	
Wall	Classroom	Concrete Block		7	1,194	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	952	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		5	987	SF	\$7,452	cracks and seperation on various locations
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	702	SF	\$0	
Wall	Classroom	Concrete Block		7	702	SF	\$0	
Wall	Classroom	Concrete Block		7	702	SF	\$0	
Wall	Classroom	Concrete Block		7	702	SF	\$0	
Wall	Classroom	Concrete Block		5	920	SF	\$6,946	
Wall	Classroom	Plaster/Drywall		7	236	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	236	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	236	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	236	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	80	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	92	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	80	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	90	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	90	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	85	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	80	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		5	80	SF	\$3,775	cracking an dseparation occuring
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	92	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	80	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	80	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	80	SF	\$0	
Wall	Classroom	Structural Glazed Tile		6	80	SF	\$572	cracks developing
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	78	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	80	SF	\$0	
Wall	Classroom	Structural Glazed Tile		7	80	SF	\$0	
Wall	Classroom	Wall		5	920	SF	\$4,341	cracks and seperation in block walls
Wall	Classroom	Wall		6	920	SF	\$2,171	cracks developing
ROOM Sub Total							\$421,074	

Building Main Sub Total \$3,942,283

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Building	6	5	EA	\$2,717	Rod
Civil/Drainage		Site Manhole	Entire Building	7	5	EA	\$0	
Fencing		Chain Link	Entire Building	4	734	LF	\$78,722	Rusted, bent
Fencing		Chain Link	Trash Enclosure	6	84	LF	\$1,205	Missing slats
Fencing		Chain Link	Site & West	5	200	LF	\$7,150	Missing/broken posts and loose fence
Fencing		Guard Rail	Parking Lot	7	10	LF	\$0	
Fencing		Ornamental Iron	South Site	7	395	LF	\$0	
Landscape		Asphalt Play Area/Hardscape	Entire Building	5	9,230	SF	\$26,134	Patched, uneven
Landscape		Asphalt Play Area/Hardscape	South	6	672	SF	\$577	
Landscape		Benches	Central Courtyard	7	1	EA	\$0	
Landscape		Grass	Entire Building	7	11,450	SF	\$0	
Landscape		Hardscape - Concrete	Entire Building	7	1,920	SF	\$0	
Landscape		Hardscape - Pavers	Central Courtyard	6	972	SF	\$2,752	Shifting
Landscape		Parkway trees	East	4	2	EA	\$4,908	Broken at trunk
Landscape		Parkway trees	Entire Building	7	7	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Building	5	1,632	SF	\$0	Poorly maintained
Parking Lot		Asphalt	South	7	9,504	SF	\$0	
Parking Lot		Concrete Curbs	South	7	50	LF	\$0	
Parking Lot		Trash Enclosure	South	7	392	SF	\$0	
Parking Lot		Vehicular Screening	South	7	190	LF	\$0	
Playground		Playground Equipment - Pre-K 3-5	Southwest Corner	5	1	EA	\$0	
Playground		Playground Equipment - School Age 5-12	South	7	1	EA	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Playground		Playground Surfacing - Poured Surface	South	7	2,500	SF	\$0	
Playground		Playground Surfacing - Wood Chips	Southwest Corner	4	1,200	SF	\$7,722	
Sidewalks		Perimeter Sidewalks	Entire Building	7	10,863	SF	\$0	
Sidewalks		Perimeter Sidewalks	North	4	2,300	SF	\$43,415	Broken and displaced
Signage		Flag Pole	North	4	1	EA	\$13,213	Leaning, no rope
Signage		Marquee - Building Mounted Back Lighted w/ LED	Northwest Corner	7	1	EA	\$0	
SITE Sub Total							\$188,514	
SITE Sub Total							\$188,514	

Total Campus Need ^{2 3} \$4,130,797

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	858	0	0	10	40	219	10	0	N	N	Y	Classroom		
102	858	0	0	10	40	219	10	0	N	N	Y	Classroom		
103	858	0	0	10	40	219	10	0	N	N	Y	Classroom		
104	936	0	35	90	40	219	10	2	N	N	N	Classroom		
105	936	0	0	4	40	219	10	0	N	N	N	Classroom		
106	936	0	0	4	40	219	10	0	N	N	N	Classroom		
107	1144		2	4	40	281	10	2	N	N	Y	Classroom		
109	1144		2	4	40	281	10		N	N	Y	Classroom		
110	936	0	0	10	40	219	10	0	N	N	Y	Classroom		
111	936	0	0	10	40	219	10	0	N	N	Y	Classroom		
113	910	0	0	4	40	219	10	0	N	N	N	Classroom		
114	910	0	0	4	40	219	10	0	N	N	N	Classroom		
118	884				4	157	10		N	N	N	Classroom		
201	858	0	2	10	40	219	10		N	N	N	Classroom		
202	858	0	2	10	40	219	10		N	N	N	Classroom		
203	858	0	2	10	40	219	10		N	N	N	Classroom		
204	960		2	10	40	281	10		N	N	Y	Classroom		
205	936	2	0	10	40	219	10	0	N	N	N	Classroom		
206	960		2	10	40	281	10		N	N	Y	Classroom		
207	858	0	2	10	40	219	10		N	N	N	Classroom		
208	858	0	2	10	40	219	10		N	N	N	Classroom		
209	858	0	2	10	40	219	10		N	N	N	Classroom		
210	936	0	0	10	40	219	10	0	N	N	Y	Classroom		
211	988		8	16	40	281	10		N	N	N	Classroom		
212	858	0	36	52	40	219	10		N	N	N	Classroom		
213	910	0	40	124	40	219	10	2	N	N	N	Classroom		
214	910	0	3	8	40	219	10		N	N	N	Classroom		
215	884			12	4	157	10		N	N	Y	Classroom		
216	884			12	4	157	10		N	N	Y	Classroom		
217	884			12	4	157	10		N	N	Y	Classroom		
218	884			12	4	157	10		N	N	Y	Classroom		
Other	226			8					N	N	Y	Administrative Suites/Offices		Counselors office/ Nurse
Other	1734								N	N	N	Lunch & Multipurpose Room	Lunchroom	on plan - Rooms 115 & 116
Other	867								N	N	N	Kitchen	Warming Kitchen	on plan - room 117
Other	4004								N	N	N	Gymnasia	Gymnasium.Auditorium	1st Floor
Other	357			10					N	N	Y	Administrative Suites/Offices		main Office

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	187			6					N	N	Y	Administrative Suites/Offices		principals office
Other	238			4					N	N	N	Administrative Suites/Offices		Parent /Teacher 2ed floor
Other	600								N	N	N	Corridors		2ed Floor - corridor 3
Other	442			16					N	N	N	Administrative Suites/Offices		Adjustment and counselor office #112
Other	642								N	N	N	Corridors		1st Floor - corridor 2
Other	600								N	N	N	Corridors		1st Floor - corridor 3
Other	824								N	N	N	Corridors		1st floor - corridor 4
Other	824								N	N	N	Corridors		1st floor - corridor 5
Other	400								N	N	N	Corridors		1st floor - corridor 6
Other	1323								N	N	N	Corridors		lobby
Other	18								N	N	N	Restroom	Staff Restroom	Counselor Toilet
Other	642								N	N	N	Corridors		2 ed Floor - corridor 2
Other	54								N	N	N	Restroom	Staff Restroom	Staff toilet off cooridor by office
Other	824								N	N	N	Corridors		2ed floor - corridor 4
Other	824								N	N	N	Corridors		2ed floor - corridor 5
Other	400								N	N	N	Corridors		2ed floor - corridor 6
Other	624								N	N	N	Corridors		Stair 1
Other	225								N	N	N	Corridors		Stair 2
Other	225								N	N	N	Corridors		Stair 3
Other	480								N	N	N	Corridors		Stair 7
Other	729								N	N	N	Corridors		2ed floor - corridor 1
Other	80								N	N	N	Restroom	Staff Restroom	in cooridor by gym (plan GT)
Other	180			14					N	N	N	Administrative Suites/Offices		Teachers lounge - 2ed floor
Other	246								N	N	N	Restroom	Children's Standard Student Restroom	Girls - 1st floor
Other	246								N	N	N	Restroom	Children's Standard Student Restroom	Boys - 1st floor
Other	144								N	N	N	Restroom	Children's Standard Student Restroom	Girl - 1st floor
Other	144								N	N	N	Restroom	Children's Standard Student Restroom	Boys - 1st floor
Other	246								N	N	N	Restroom	Children's Standard Student Restroom	Boys - 2ed floor
Other	144								N	N	N	Restroom	Children's Standard Student Restroom	Girl -2 ed floor
Other	729								N	N	N	Corridors		1st floor - corridor 1
Other	364								N	N	N	Restroom	Children's Standard Student Restroom	Girls 2ed floor
Other	240								N	N	N	Corridors		Stair8
Other	54								N	N	N	Restroom	Staff Restroom	Mens - 2ed floor by rm 201
Other	96								N	N	N	Restroom	Staff Restroom	womens - 2ed floor by rm 201
Other	96								N	N	N	Restroom	Staff Restroom	womens - 2ed floor by rm 213
Other	30								N	N	N	Restroom	Early Childhood Student Restroom	Kindergarten 109
Other	30								N	N	N	Restroom	Early Childhood Student Restroom	Kindergarten 107

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	135								N	N	N	Corridors		Kindergarten vestibule
Other	54								N	N	N	Restroom	Staff Restroom	principals toilet
Other	144								N	N	N	Restroom	Children's Standard Student Restroom	Boys - 2ed floor