

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

Rank 7: The item/system is new or in good condition and no work is required.

Rank 6: The item/system requires general cleaning and/or routine maintenance.

Rank 5: The item/system requires repairs and has not reached the end of its serviceable life.

Rank 4: The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.

Rank 3: The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.

Rank 2: The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.

Rank 1: The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

Quantity means, for each item, the total number (or amount) of that item that exists and was evaluated.

Unit means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

Cost means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.

Total Campus Need also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	East Façade	6	100	LF	\$50,050	
Cornice		Cornice - Masonry Projecting/Limestone	West 1 story	6	355	LF	\$10,889	open joints
Doors		Exterior Steel Door	Entire Building	6	9	EA	\$2,973	
Doors		Exterior Steel Door	coal room	5	2	EA	\$2,180	
Doors		Store Front Door	Main Entrance	6	18	EA	\$9,344	
Doors		Transom Lite	South Entrances	5	2	EA	\$1,869	
Doors		Transom Lite	entrances	7	22	EA	\$0	
Entrance		Concrete Exterior Stairs	east at door	5	96	LF	\$30,888	
Entrance		Concrete Exterior Stairs	E, W, N entrances	7	211	LF	\$0	
Entrance		Concrete Exterior Stairs	west at door 8	4	24	LF	\$15,444	
Entrance		Concrete Ramp	north and SW entrances	7	92	LF	\$0	
Entrance		Entrance Controls - Audio	SW building	5	1	EA	\$858	not working
Entrance		Entrance Controls - Audio	South Entrances	7	1	EA	\$0	
Entrance		Power Door Operator and Controls	South Entrances	7	1	EA	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Ramp Handrails	North Entrances	6	110	LF	\$0	refinish
Entrance		Stair Handrails	north and lunch entrance	6	36	LF	\$0	
Fire Escape		Fire Escapes	North Façade	6	5	LF	\$510	rusty
Foundation		Concrete Foundation	Entire Building	7	1,015	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	23	EA	\$4,934	
Lighting		Exterior Lights - Wall Mounted	Entire Building	5	3	EA	\$1,502	
Lintels		Lintels - Steel	Entire Building	6	1,220	LF	\$46,057	rusty, peeling paint
Lintels		Lintels - Steel	west facade above entrances	5	36	LF	\$10,296	
Parapet		Coping - Clay Tile	main roof and boiler room roof	6	180	LF	\$0	
Parapet		Coping - Metal	west low roof and main roof at former skylights	7	340	LF	\$0	
Parapet		Coping - Stone	main and low roofs	7	1,197	LF	\$0	
Parapet		Parapet < 16" Height	main and low roofs	7	211	LF	\$0	
Parapet		Parapet < 16" Height	west low roof	5	61	LF	\$14,681	
Parapet		Parapet > 30" Height	high roofs	7	470	LF	\$0	
Parapet		Parapet > 30" Height	east low roof	5	30	LF	\$12,033	
Parapet		Parapet 16" to 30" Height	main and low roofs	7	418	LF	\$0	
Parapet		Parapet 16" to 30" Height	east and west low roofs	5	187	LF	\$60,007	
Roof System		Exterior Downspouts	pan at boiler room	5	20	LF	\$372	leaks reported
Roof System		Exterior Downspouts	Entire Building	7	82	LF	\$0	
Roof System		Exterior Downspouts	south at elev. room	6	18	LF	\$335	bent
Roof System		Interior Downspouts	Entire Building	6	260	LF	\$0	clean out
Roof System		Metal Roof	east and west low roofs	6	306	SF	\$2,310	
Roof System		Modified Bitumen Roof	Roof	6	35,900	SF	\$254,118	
Roof System		Roof Structure: Steel with Clay Tile Arch	Roof	7	35,900	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	80,800	SF	\$0	
Walls		Brick	Entire Building	7	32,964	SF	\$0	
Walls		Brick	NW corner of original bldg, SW corner at top, door 1	4	1,450	SF	\$109,481	
Walls		Stone - Cast	south facade of lunchroom	5	120	SF	\$8,580	
Walls		Stone - Cast	base, accent band, west entrance	6	6,807	SF	\$97,340	open joints
Windows		Window - Guards perforated	East Façade	6	2,396	SF	\$0	refinish
Windows		Windows - Sash Aluminum	Entire Building	6	12,689	SF	\$108,872	10% balance issues
EXTERIOR Sub Total							\$855,921	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Boiler Room	7	3	EA	\$0	
Emergency System		Emergency A/C power - Auditorium and aisle lighting	1st Floor	4	6,846	SF	\$47,480	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	4	12,641	SF	\$38,865	T12 lighting
Emergency System		Emergency A/C power - Gym and Lunch rooms	3rd Floor	4	4,055	SF	\$7,248	T12 lighting
Emergency System		Emergency A/C power - Students Toilets	Entire Building	4	2,540	SF	\$9,081	T12 lighting in boys girls restrooms
Emergency System		Emergency generator 60 to 100 KW natural gas - Outdoor	Outside boiler building	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	6	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	21	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	3rd Floor	6	4	EA	\$932	
Emergency System		Independent Electrical Service for emergency power	Electrical Room	7	1	EA	\$0	
Emergency System		Public Announcement System	1st Floor	6	80,800	SF	\$48,528	
Main Service		Main Electrical service 1200 A 120/208/3PH	Electrical Room	6	1	EA	\$7,150	Half of the switchgear was replaced
Power Distribution		Lighting and power panels	Entire Building	6	3	EA	\$2,145	
Power Distribution		Lighting and power panels	Entire Building	7	10	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	4	2	EA	\$10,868	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Boiler Room	7	1	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	1st Floor	7	1	EA	\$0	
ELECTRICAL Sub Total							\$172,298	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	80,800	SF	\$28,886	
Fire Alarm		Fire Alarm System	Mechanical Room	6	80,800	SF	\$98,212	
FIRE PROTECTION Sub Total							\$127,098	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	7	23	EA	\$0	
Air Conditioning		Window A/C Unit	Entire Building	5	10	EA	\$10,725	
Air Conditioning		Window A/C Unit	Entire Building	4	4	EA	\$8,580	
Air Conditioning		Window A/C Unit	Entire Building	6	2	EA	\$429	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	1 large outside air intake plenum chamber above AHU-1,2,3 in the mechanical room leading to up well up to roof	7	1	EA	\$0	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	1st floor, north wing, west wall air intake	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	1st Floor	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 8,000 to 15,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	1st Floor	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 8,000 to 15,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	7	80	LF	\$0	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	7	80	LF	\$0	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Entire Building	7	80	LF	\$0	
Air Handling Systems		Return Duct Work - Sheet Metal - Exterior Vertical Shaft and Ducts	Entire Building	7	100	LF	\$0	
Air Handling Systems		Return Fans - Outdoor 5,000 to 10,000 CFM	auditorium roof	7	1	EA	\$0	
Air Handling Systems		Return Fans - Outdoor greater than 20,000 CFM	Roof	7	1	EA	\$0	
Air Handling Systems		Return Fans - Outdoor 10,001 to 20,000 CFM	Roof	7	1	EA	\$0	
Air Handling Systems		Return Fans - Outdoor 10,001 to 20,000 CFM	Roof	7	1	EA	\$0	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 8,001 to 15,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries- Steam 8,001 to 15,000 cfm	Mechanical Room	7	1	EA	\$0	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 76-100 HP	Boiler Room	7	2	EA	\$0	
Boiler Systems		Boiler Auxiliary - Steam Boiler 76-100 HP	Boiler Room	7	2	EA	\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Boiler Systems		Chemical Feed System (Steam Boilers)	Mechanical Room	7	1	EA	\$0	
Boiler Systems		Combustion Dampers	Boiler Room	7	3	EA	\$0	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Mechanical Room	7	1	EA	\$0	
Heating Devices		Fin Tube Hot Water	1st Floor	7	40	LF	\$0	
Heating Devices		Radiators - Steam	Entire Building	6	3	EA	\$420	
Heating Devices		Unit Heater - Electric	Entire Building	7	15	EA	\$0	
Heating Devices		Unit Heater - Gas	Boiler Room	6	1	EA	\$2,145	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Mechanical Room	7	2	EA	\$0	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	4	400	LF	\$39,182	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	1st Floor	5	400	LF	\$19,791	
Temperature Control		Direct Digital Control (DDC) System	Mechanical Room	7	80,800	SF	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	42	EA	\$0	
Temperature Control		Zone Dampers	1st Floor	7	19	EA	\$0	
Temperature Control		Zone Dampers	Mechanical Room	7	17	EA	\$0	
Temperature Control		Zone Dampers	Mechanical Room	7	11	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	4	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	2	EA	\$0	
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	3	1	EA	\$6,149	no fire supression and serves a cooking stove
MECHANICAL Sub Total							\$87,422	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	7	2	EA	\$0	
Hot Water		Hot Water Heater - Gas less than 150,000 BTU/HR	1st Floor	6	1	EA	\$3,575	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	80,800	SF	\$26,575	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	80,800	SF	\$51,995	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	80,800	SF	\$17,332	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	80,800	SF	\$36,974	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	80,800	SF	\$43,907	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	80,800	SF	\$192,958	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	80,800	SF	\$159,451	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	80,800	SF	\$92,435	
Piping		Sanitary Piping	Entire Building	5	80,800	SF	\$49,684	
Piping		Storm Piping	Entire Building	5	80,800	SF	\$38,130	
Piping		Vent Piping	Entire Building	5	80,800	SF	\$28,886	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Pumps		Domestic Booster Pump duplex	Mechanical Room	7	1	EA	\$0	
Pumps		Sump Pump	Boiler Room	6	1	EA	\$1,359	
PLUMBING Sub Total							\$743,260	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Principals Office - In main office	6	193	SF	\$546	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office	7	272	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Copy Room - on stage	4	135	SF	\$1,784	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Assistant Principles Office - 1st Floor	6	362	SF	\$1,025	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	rm 314- gym teachers office	6	200	SF	\$566	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	110 Conference Room	6	175	SF	\$495	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	111 Administration	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	302A	6	280	SF	\$793	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	110 Conference Room	4	175	SF	\$2,477	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	302A	5	280	SF	\$1,586	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office	7	272	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Assistant Principles Office - 1st Floor	7	362	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 314- gym teachers office	6	200	SF	\$286	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Copy Room - on stage	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Principals Office - In main office	6	193	SF	\$1,457	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	111 Administration	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Copy Room - on stage	4	1	SF	\$7	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Assistant Principles Office - 1st Floor	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Principals Office - In main office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	110 Conference Room	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	111 Administration	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	302A	4	6	SF	\$39	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	rm 314- gym teachers office	4	1	SF	\$7	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	6	724	SF	\$1,708	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Assistant Principles Office - 1st Floor	6	962	SF	\$2,270	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Copy Room - on stage	6	647	SF	\$1,527	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principals Office - In main office	6	498	SF	\$1,175	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 314- gym teachers office	6	800	SF	\$1,888	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	110 Conference Room	6	692	SF	\$1,633	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	111 Administration	6	1,188	SF	\$2,803	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	302A	6	600	SF	\$1,416	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	6	825	EA	\$30,367	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor	6	1	EA	\$35,750	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	7	7	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	7	1	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	7	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	6	EA	\$1,699	
Doors		Interior Wood Doors incl hw	Entire Building	4	34	EA	\$109,103	
Doors		Interior Wood Doors incl hw	Entire Building	7	9	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	39	EA	\$11,042	
Doors		Interior Wood Doors incl hw	Entire Building	5	37	EA	\$17,460	
Doors		Transom Window	Entire Building	6	880	SF	\$16,359	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	6	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	5	2	EA	\$3,861	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	6	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	3rd Floor	6	4,055	SF	\$34,676	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	3rd Floor	7	4,055	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Lay-In	3rd Floor	7	12	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	3rd Floor	6	20	EA	\$3,575	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	3rd Floor	6	2,359	SF	\$20,240	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	3rd Floor	6	1,350	SF	\$9,653	
Kitchen	Cooking Kitchen	Ceiling - Plaster/Drywall	in lunchroom	5	478	SF	\$2,707	
Kitchen	Cooking Kitchen	Flooring - Tile/Sheet	in lunchroom	5	478	SF	\$2,707	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	in lunchroom	4	5	SF	\$33	
Kitchen	Cooking Kitchen	Wall - Plaster/Drywall	in lunchroom	5	1,364	SF	\$6,437	
Library	Library	Casework	212&214	6	7	LF	\$215	
Library	Library	Lighting - Pendant/ Surface	212&214	4	16	SF	\$105	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys West- used as storage			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys east			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl womens in girls rm			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls west			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Main office			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Conference Room			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	110			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys east			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in rm 101			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls east			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd fl womens in girls rm			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Conference Room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls east			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls west			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys West- used as storage			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Main office			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	110			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys east			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in rm 101			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys east			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd fl womens in girls rm			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl womens in girls rm			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	110			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Conference Room			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in rm 101			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys West- used as storage			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls west			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls east			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl womens in girls rm			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys east			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys east			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd fl womens in girls rm			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Main office			EA	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	5	3,233	SF	\$18,308	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	4	17	SF	\$112	
Lunchroom	Lunchroom	Serving Line	1st Floor	7	20	LF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	in lunchroom			LF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	1st Floor	6	1,810	SF	\$4,271	
MDF/IDF		Finishes	asst. Principles office	7	115	SF	\$0	
MDF/IDF		Ventilation and Cooling	asst. Principles office	7	1	EA	\$0	
Mechanical/Service Rooms		Boiler Room	1st Floor	6	1,440	SF	\$6,795	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	3	SF	\$14	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	6	5,443	SF	\$25,686	
Mechanical/Service Rooms		Storage Room	110	7	90	SF	\$0	
Mechanical/Service Rooms		Storage Room	lunchroom	6	170	SF	\$802	
Mechanical/Service Rooms		Storage Room	Main Office	7	142	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st Floor	6	108	SF	\$510	
Mechanical/Service Rooms		Storage Room	in gym	7	230	SF	\$0	
Mechanical/Service Rooms		Storage Room	rm 308A- unused staff bathroom inaccessible because of storage	5	303	SF	\$3,432	
Mechanical/Service Rooms		Storage Room	Auditorium	4	454	SF	\$12,855	
Staff Restroom	Staff Restroom	Accessories	Conference Room	5	55	SF	\$1,402	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls			SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys West- used as storage			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls	6	225	SF	\$1,737	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys			SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	in rm 101			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Main office	7	38	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	110	6	47	SF	\$363	
Staff Restroom	Staff Restroom	Accessories	In assistant principles office	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls west	6	345	SF	\$2,664	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls east			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl womens in girls rm	6	55	SF	\$425	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys east			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd fl womens in girls rm	6	55	SF	\$425	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys east			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls	6	225	SF	\$637	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls east	6	325	SF	\$920	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Conference Room	6	55	SF	\$156	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	110	7	47	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	In assistant principles office	6	35	SF	\$99	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys West- used as storage	6	345	SF	\$977	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	in rm 101	6	45	SF	\$127	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls west	6	345	SF	\$977	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl womens in girls rm	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys east	6	325	SF	\$920	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys east	6	325	SF	\$920	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd fl womens in girls rm	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls	6	325	SF	\$920	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Main office	6	38	SF	\$108	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys	6	325	SF	\$920	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	Conference Room			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Main office			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in rm 101			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys east	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	110			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys east	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls	5	1	EA	\$1,502	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl womens in girls rm			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls east	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls west	4	1	EA	\$3,003	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys West- used as storage			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd fl womens in girls rm			EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	In assistant principles office	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls east	7	325	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls west	6	345	SF	\$878	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls	6	225	SF	\$573	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys West- used as storage	6	345	SF	\$878	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys	7	325	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls	7	325	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys east	7	325	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	in rm 101	6	45	SF	\$115	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys east	7	325	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Conference Room	5	55	SF	\$865	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Main office	7	38	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd fl womens in girls rm	6	55	SF	\$79	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	110	4	47	SF	\$665	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	3rd fl womens in girls rm	6	55	SF	\$79	
Staff Restroom	Staff Restroom	Hand Dryer	Conference Room			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	110			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd fl womens in girls rm			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys east	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys east	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl womens in girls rm			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls east	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls west			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys West- used as storage			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in rm 101			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Main office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys West- used as storage	5	2	EA	\$3,718	
Staff Restroom	Staff Restroom	Lavatory	3rd fl womens in girls rm	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys east	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys east	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl womens in girls rm	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls east	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls west	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	110	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Conference Room			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Main office	6	1	EA	\$372	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in rm 101	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	In assistant principles office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	In assistant principles office	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl girls	4	3	SF	\$13	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl boys east	4	2	SF	\$9	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls east	4	3	SF	\$13	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls west	4	4	SF	\$17	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl boys West- used as storage	4	4	SF	\$17	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl girls	4	3	SF	\$13	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl boys	4	2	SF	\$9	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	in rm 101	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Main office	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl boys east	4	2	SF	\$9	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	110	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Conference Room	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	Main office	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	2nd fl womens in girls rm	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	3rd fl womens in girls rm	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Partitions	110			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys	6	1	EA	\$179	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Partitions	in rm 101			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Conference Room	5	2	EA	\$1,144	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys east	6	1	EA	\$179	
Staff Restroom	Staff Restroom	Partitions	In assistant principles office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls west	5	8	EA	\$4,576	no doors
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls east	6	3	EA	\$538	
Staff Restroom	Staff Restroom	Partitions	2nd fl womens in girls rm			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys east	6	3	EA	\$538	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys West- used as storage	5	2	EA	\$1,144	no doors
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls	6	7	EA	\$1,255	
Staff Restroom	Staff Restroom	Partitions	3rd fl womens in girls rm			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Main office	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys east	5	1	EA	\$1,859	water comes out of top
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys	5	1	EA	\$1,859	water comes out of top
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd fl womens in girls rm			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys east	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys east	7	8	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls east			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys West- used as storage	5	2	EA	\$3,718	off
Staff Restroom	Staff Restroom	Urinals	2nd fl womens in girls rm			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in rm 101			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Main office			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Conference Room			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	110			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Urinals	In assistant principles office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl girls	6	692	SF	\$1,633	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd fl womens in girls rm	6	356	SF	\$840	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl boys east	6	692	SF	\$1,633	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl boys east	6	692	SF	\$1,633	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd fl womens in girls rm	6	356	SF	\$840	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	In assistant principles office	6	336	SF	\$793	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	110	6	352	SF	\$831	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	in rm 101	6	387	SF	\$913	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl boys	6	692	SF	\$1,633	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl girls	6	483	SF	\$1,140	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls east	6	692	SF	\$1,633	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl boys West- used as storage	7	144	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls	7	145	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls west	7	144	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls east	7	173	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys east	7	173	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl boys east	7	173	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl girls	7	173	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys	7	173	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys east	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Main office	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Water Closet	in rm 101	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys West- used as storage	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys east	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd fl womens in girls rm	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl womens in girls rm	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls west	7	8	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	In assistant principles office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Conference Room	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls east	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	110	6	1	EA	\$372	
Theater	Auditorium - Dedicated	Flooring - Wood	1st Floor	4	5	SF	\$132	
Theater	Auditorium - Dedicated	Flooring - Wood	1st Floor	7	6,516	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	4	3	SF	\$23	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	7	38	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Wall Mounted	1st Floor	6	8	EA	\$229	
Theater	Auditorium - Dedicated	Stage	1st Floor	7	527	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Concrete Block	1st Floor	6	455	SF	\$3,904	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	1st Floor	6	4,849	SF	\$41,604	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	1st Floor	5	700	SF	\$10,010	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	6	1	EA	\$17,160	
Vertical Conveyance		Stage Lift	Auditorium	5	1	EA	\$12,334	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
INTERIOR Sub Total							\$561,714	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		5	8	LF	\$1,430	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		6	23	LF	\$822	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	790	SF	\$2,237	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	790	SF	\$2,237	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	914	SF	\$2,588	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	914	SF	\$2,588	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Ceiling	Classroom	Plaster/Drywall		6	850	SF	\$2,407	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	15	LF	\$1,823	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	35	LF	\$4,254	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Corridors	Corridors	Drinking Fountains	North Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	East stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	Center Stair			EA	\$0	
Corridors	Corridors	Floors	1st Floor	6	119	SF	\$898	
Corridors	Corridors	Pendant/Surface	1st Floor	7	5,671	EA	\$0	
Corridors	Corridors	Pendant/Surface	2nd Floor	6	3,485	EA	\$2,492	
Corridors	Corridors	Pendant/Surface	3rd Floor	6	3,485	EA	\$2,492	
Corridors	Corridors	Pendant/Surface	Center Stair	7	380	EA	\$0	
Corridors	Corridors	Pendant/Surface	East stair	7	824	EA	\$0	
Corridors	Corridors	Pendant/Surface	North Stair	7	455	EA	\$0	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	3,575	SF	\$8,435	
Corridors	Corridors	Plaster/Drywall	East stair	6	2,748	SF	\$6,484	
Corridors	Corridors	Plaster/Drywall	3rd Floor	6	3,575	SF	\$8,435	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	8,675	SF	\$20,469	
Corridors	Corridors	Plaster/Drywall	North Stair	6	1,482	SF	\$3,497	
Corridors	Corridors	Plaster/Drywall	Center Stair	6	5,446	SF	\$12,850	
Corridors	Corridors	Single Water Cooler	1st Floor	6	1	EA	\$615	
Corridors	Corridors	Single Water Cooler	1st Floor	7	1	EA	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	North Stair	6	41	LF	\$0	
Corridors	Corridors	Stair Handrails	Center Stair	6	244	LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	East stair	6	83	LF	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	East stair	6	153	SF	\$1,094	
Corridors	Corridors	Structural Glazed Tile	1st Floor	6	472	SF	\$3,375	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Structural Glazed Tile	North Stair	6	94	SF	\$672	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	North Stair			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Center Stair			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	East stair			EA	\$0	
Corridors	Corridors	Terrazzo	1st Floor	6	312	SF	\$1,767	
Corridors	Corridors	Tile Ceramic/Porcelain	East stair	6	88	SF	\$224	
Corridors	Corridors	Tile Ceramic/Porcelain	1st Floor	7	25	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	East stair	6	612	SF	\$875	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	6	3,485	SF	\$4,984	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	3,485	SF	\$4,984	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	5,215	SF	\$7,457	
Corridors	Corridors	Tile/Sheet Flooring	North Stair	6	77	SF	\$110	
Corridors	Corridors	Tile/Sheet Flooring	North Stair	6	376	SF	\$538	
Corridors	Corridors	Tile/Sheet Flooring	Center Stair	6	1,130	SF	\$1,616	
Corridors	Corridors	Wall Mounted	Center Stair	7	380	EA	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	East stair	6	824	SF	\$2,333	
Corridors Ceiling	Corridors	Plaster/Drywall	Center Stair	6	1,306	SF	\$3,698	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	6	3,485	SF	\$9,867	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	6	3,485	SF	\$9,867	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	6	5,671	SF	\$16,057	
Corridors Ceiling	Corridors	Plaster/Drywall	North Stair	6	455	SF	\$1,288	
Stairs	Corridors	Asphalt	East stair	5	51	SF	\$2,553	
Stairs	Corridors	Asphalt	Center Stair	5	162	SF	\$8,108	
Stairs	Corridors	Asphalt	North Stair	5	26	SF	\$1,301	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		6	850	SF	\$6,418	
Floor	Classroom	Wood		6	850	SF	\$6,418	
Floor	Classroom	Wood		6	850	SF	\$6,418	
Floor	Classroom	Wood		6	850	SF	\$6,418	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		6	850	SF	\$6,418	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Wood		6	850	SF	\$6,418	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	790	SF	\$11,184	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		6	850	SF	\$6,418	
Floor	Classroom	Wood		5	790	SF	\$11,184	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		6	914	SF	\$6,901	
Floor	Classroom	Wood		5	850	SF	\$12,033	
Floor	Classroom	Wood		6	914	SF	\$6,901	
LIBRARY_CEILING	Library	Plaster/Drywall	212&214	6	1,690	SF	\$4,785	
LIBRARY_FLOOR	Library	Library Floor	212&214	6	1,690	SF	\$2,417	
LIBRARY_WALL	Library	Plaster/Drywall	212&214	6	2,316		\$5,465	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	13	EA	\$5,112	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
Lighting	Classroom	Pendant/Surface		4	14	EA	\$5,506	
LUNCH_CEILING	Lunchroom	Lunchroom Ceiling	1st Floor	6	3,233	SF	\$9,154	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd fl boys east	6	212	SF	\$540	glazed brick- step cracking
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st fl girls	6	176	SF	\$448	
RESTROOM_WALL	Staff Restroom	Restroom Walls	Conference Room			SF	\$0	
RESTROOM_WALL	Staff Restroom	Restroom Walls	Main office			SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st fl boys	6	212	SF	\$540	glazed brick- step cracking
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st fl girls	6	176	SF	\$448	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd fl boys West- used as storage	4	100	SF	\$3,115	displaced
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd fl boys West- used as storage	7	965	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl girls west	4	100	SF	\$3,115	displaced
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl girls west	7	965	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl boys east	6	212	SF	\$540	glazed brick- step cracking
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd fl girls	6	196	SF	\$499	step cracking
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl girls east	6	196	SF	\$499	step cracking
THEATER_CEILING	Auditorium - Dedicated	Auditorium Ceiling	1st Floor	6	6,846	SF	\$58,543	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	
Wall	Classroom	Plaster/Drywall		6	1,323	SF	\$3,122	

ROOM Sub Total \$950,690

Building Main Sub Total \$3,498,403

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	6	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	12	EA	\$0	
Fencing		Chain Link	Entire Site	5	216	LF	\$7,722	
Fencing		Chain Link	trash enclosure and misc	7	339	LF	\$0	
Fencing		Iron and Concrete Post	Site 2 South	5	529	LF	\$26,476	
Fencing		Ornamental Iron	site west and north	6	720	LF	\$13,591	
Fencing		Ornamental Iron	Site - East	7	35	LF	\$0	
Landscape		Asphalt Play Area/Hardscape	site north and south	7	62,209	SF	\$0	
Landscape		Asphalt Play Area/Hardscape	east side of parking lot	4	1,070	SF	\$9,181	
Landscape		Grass	Site 2 West	7	6,770	SF	\$0	
Landscape		Hardscape - Concrete	site north and west-entrances	4	1,780	SF	\$33,599	
Landscape		Hardscape - Concrete	Entire Site	7	3,295	SF	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Landscape		Parkway trees	Entire Site	7	34	EA	\$0	
Landscape		Planting Beds/ Areas	Site ζ West	7	650	SF	\$0	
Landscape		Retaining Wall - Concrete	site east at boiler room	6	131	SF	\$3,091	
Parking Lot		Asphalt	site NW	7	36,485	SF	\$0	
Parking Lot		Asphalt	site- east at boiler room	5	721	SF	\$2,041	
Parking Lot		Concrete Curbs	site NW	6	203	LF	\$1,225	cracking/ damaged sections
Parking Lot		Trash Enclosure	Site ζ South	7	918	SF	\$0	
Playground		Playground Equipment - Combo 3-12	Site ζ North	5	1	EA	\$0	graffiti, missing rings, hole at slide
Playground		Playground Surfacing - Square Rubber Mats	Site ζ North	4	2,142	SF	\$47,477	
Sidewalks		Perimeter Sidewalks	Entire Site	7	11,496	SF	\$0	
Sidewalks		Perimeter Sidewalks	site- east at boiler	4	348	SF	\$6,569	
Signage		Flag Pole	Site ζ West	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	Site ζ South	6	1	EA	\$0	rusty
SITE Sub Total							\$150,973	
SITE Sub Total							\$150,973	

Total Campus Need ^{2 3} \$3,649,375

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	850	1		10	40	119	70	1	N	N	Y	Classroom		
102	790	1		10	40	102	60	1	N	N	Y	Classroom		
107	850			10	40	102	60	1	N	N	Y	Classroom		
109	850			10	40	102	60	1	N	N	Y	Classroom		
111	850	1		10	40	102	60	1	N	N	Y	Classroom		
112	790	1		10	40	85	50	1	N	N	Y	Classroom		
114	850	1		10	40	102	60	1	N	N	Y	Classroom		
201	850			10	40	102	60	1	N	N	Y	Classroom		
202	850			10	40	102	60	1	N	N	Y	Classroom		
203	850	1		10	40	102	60	1	N	N	Y	Classroom		
204	850	1		10	40	102	60	1	N	N	Y	Classroom		
205	850	1		10	40	102	60	1	N	N	Y	Classroom		
206	850	1		10	40	102	60	1	N	N	Y	Classroom		
207	914	1	39	78	40	102	60	2	N	N	Y	Classroom		
208	850	1		10	40	102	60	1	N	N	Y	Classroom		
209	850	1		10	40	102	60	1	N	N	Y	Classroom		
210	850	1		10	40	102	60	1	N	N	Y	Classroom		
211	850	1		10	40	102	60	1	N	N	Y	Classroom		
215	850	1		10	40	102	60	1	N	N	Y	Classroom		
301	850			10	40	102	60	1	N	N	Y	Classroom		
302	850			10	40	102	60	1	N	N	Y	Classroom		
303	850			10	40	102	60	1	N	N	Y	Classroom		
304	850			10	40	102	60	1	N	N	Y	Classroom		
305	914	1	39	78	40	102	60	2	N	N	Y	Classroom		
306	850			10	40	102	60	1	N	N	Y	Classroom		
307	850			10	40	102	60	1	N	N	Y	Classroom		
308	850			10	40	102	60	1	N	N	Y	Classroom		
309	850			10	40	102	60	1	N	N	Y	Classroom		
310	850			10	40	102	60	1	N	N	Y	Classroom		
Other									N	N	N	Corridors		Center Stair
Other	1690								N	N	N	Library		212&214
Other	3485								N	N	N	Corridors		3rd Floor
Other	325								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys east
Other	55								N	N	N	Restroom	Staff Restroom	3rd fl womens in girls rm
Other	325								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls
Other	200			6					N	N	Y	Administrative Suites/Offices		rm 314- gym teachers office

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	4055								N	N	N	Gymnasia	Standard Dedicated Gymnasium	3rd Floor
Other	5671								N	N	N	Corridors		1st Floor
Other	280			6					N	N	Y	Administrative Suites/Offices		302A
Other	345								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys West- used as storage
Other	478								N	N	N	Kitchen	Cooking Kitchen	in lunchroom
Other									N	N	N	Corridors		East stair
Other	193			16					N	N	N	Administrative Suites/Offices		Principals Office - In main office
Other	45								N	N	N	Restroom	Early Childhood Student Restroom	in rm 101
Other	135			10					N	N	Y	Administrative Suites/Offices		Copy Room - on stage
Other	325								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys
Other	225								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls
Other	362			8					N	N	Y	Administrative Suites/Offices		Assistant Principles Office - 1st Floor
Other	272			12					N	N	Y	Administrative Suites/Offices		Main Office
Other	6846								N	N	N	Auditorium & Theater	Auditorium - Dedicated	1st Floor
Other									N	N	N	Corridors		North Stair
Other	38								N	N	N	Restroom	Staff Restroom	Main office
Other	345								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls west
Other	455			8					N	N	Y	Administrative Suites/Offices		111 Administration
Other	55								N	N	N	Restroom	Staff Restroom	Conference Room
Other	325								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls east
Other	55								N	N	N	Restroom	Staff Restroom	2nd fl womens in girls rm
Other	175			4					N	N	Y	Administrative Suites/Offices		110 Conference Room
Other	47								N	N	N	Restroom	Staff Restroom	110
Other	3233								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	3485								N	N	N	Corridors		2nd Floor
Other	325								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys east
Other	35								N	N	N	Restroom	Staff Restroom	In assistant principles office