

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	West Façade	6	90	LF	\$45,045	
Doors		Exterior Steel Door	N or S Entrances	7	8	EA	\$0	
Doors		Exterior Steel Door	at Fire Escapes	4	4	EA	\$13,213	
Doors		Exterior Steel Door	Entire Building	6	7	EA	\$2,312	
Doors		Side Lite	N and S Doors	7	4	EA	\$0	
Doors		Side Lite	at Fire Escapes	4	2	EA	\$4,530	
Doors		Transom Lite	N and S Doors	7	8	EA	\$0	
Doors		Transom Lite	at Fire Escapes	4	3	EA	\$8,494	
Entrance		Concrete Exterior Stairs	Entire Building	7	84	LF	\$0	
Entrance		Concrete Ramp	South Door	7	15	LF	\$0	
Entrance		Entrance Controls - Audio and Video	South Door	4	1	EA	\$6,864	
Entrance		Ramp Handrails	South Door	7	30	LF	\$0	
Fire Escape		Fire Escapes	West Façade	6	5	LF	\$510	
Foundation		Masonry Foundation	Basement	7	837	SF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	6	EA	\$1,287	
Lighting		Exterior Lights - Wall Mounted	Entire Site	6	12	EA	\$2,574	
Lintels		Lintels - Brick	South Gym Facade	7	31	LF	\$0	
Lintels		Lintels - Steel	N&S Entrance and Gym Exit	4	36	LF	\$15,701	
Lintels		Lintels - Steel	1st fl and boiler room west/south facades	5	216	LF	\$61,776	
Lintels		Lintels - Steel	Entire Building	6	1,050	LF	\$39,640	
Parapet		Coping - Metal	Low Roof at Gym	6	50	LF	\$0	
Parapet		Coping - Stone	Boiler	5	160	LF	\$13,952	
Parapet		Coping - Stone	Low Roofs- Link and Gym Exit	6	63	LF	\$0	
Parapet		Coping - Terra Cotta	Main Roof and Gym	6	842	LF	\$0	
Parapet		Coping - Terra Cotta	at Main Roof and no parapet at gym exit	4	20	LF	\$5,285	
Parapet		Parapet < 16" Height	Boiler/Entrance Vestibules/ Main Roof	5	320	LF	\$77,014	
Parapet		Parapet > 30" Height	Main Roof and Gym	5	370	LF	\$148,413	
Parapet		Parapet 16" to 30" Height	Main Roof and Gym	5	422	LF	\$135,416	
Roof System		Exterior Downspouts	South Facade of Link	6	17	LF	\$316	
Roof System		Interior Downspouts	Entire Building	6	386	LF	\$0	
Roof System		Modified Bitumen Roof	Roofs	6	18,446	SF	\$130,570	
Roof System		Modified Bitumen Roof	Gym Low Roof	5	4,596	SF	\$54,221	
Roof System		Roof Structure: Steel with Clay Tile Arch	Roof	7	22,462	SF	\$0	
Roof System		Roof Structure: Steel with Clay Tile Arch	along West wall of Gym BLDG	5	580	SF	\$21,896	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	67,260	SF	\$0	
Walls		Brick	East facade of Gym	5	624	SF	\$14,134	
Walls		Brick	at South Door, East Facade @ Top of wall at N/S End, SE Corner of Gym, West Facade of Gym, and West Facade of Boiler Rm	4	1,512	SF	\$114,162	
Walls		Brick	Entire Building	6	26,850	SF	\$177,387	
Walls		Stone - Cut	All Facades- Base and 2 Bands	6	4,764	SF	\$68,125	
Windows		Window - Guards perforated	Entire Building	6	4,467	SF	\$0	
Windows		Windows - Sash Aluminum	West Facade at Low Roof and Stair Towers	4	2,692	SF	\$358,240	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	4	10,721	SF	\$1,851,682	
EXTERIOR Sub Total							\$3,372,761	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Entire Building	4	1	EA	\$8,866	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	5	8,567	SF	\$10,781	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	7	11	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	5	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	2	21	EA	\$19,520	no batteries installed, no generator or secondary source of emergency power provided.
Emergency System		Independent Electrical Service for emergency power	Electrical Room	5	1	EA	\$5,005	
Emergency System		Public Announcement System	main office	5	71,760	SF	\$102,617	
Emergency System		Security System - CCTV	MDF room	3	71,760	SF	\$513,084	System is non functional. No CCTV recording available.
Emergency System		Security System - Intrusion detection	MDF Room	5	71,760	SF	\$118,009	Serves both the addition and main building. Total areas added for each building
Main Service		Main Electrical service - Live Front - 1200 A 120/208/3PH	Electrical Room	5	1	EA	\$22,308	
Power Distribution		Lighting and power panels	Entire Building	6	7	EA	\$5,005	
Power Distribution		Lighting and power panels	Mechanical Room	6	2	EA	\$1,430	
Power Distribution		Lighting and power panels	Electrical Room	6	4	EA	\$2,860	
Power Distribution		Main distribution panels 400-600 amp	Mechanical Room	4	1	EA	\$12,155	
ELECTRICAL Sub Total							\$821,639	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Mechanical Room	4	62,200	SF	\$219,697	Feeds
FIRE PROTECTION Sub Total							\$219,697	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	7	1	EA	\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	7	20	EA	\$0	
Air Conditioning		Window A/C Unit	Entire Building	5	2	EA	\$2,145	
Air Conditioning		Window A/C Unit	Entire Building	6	1	EA	\$215	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	1st floor, west lower roof	4	2	EA	\$52,338	Dampers rusted shut, actuators not working.
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Mechanical Room	5	1	EA	\$42,900	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Mechanical Room	5	1	EA	\$42,900	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Mechanical Room	6	1	EA	\$3,575	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Mechanical Room	5	1	EA	\$17,160	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Mechanical Room	4	200	LF	\$529,100	Return ductwork not installed.
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Mechanical Room	5	2	EA	\$125,840	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	5	2	EA	\$22,880	
Boiler Systems		Chemical Feeder - Steam Boiler	Boiler Room	7	2	EA	\$0	
Boiler Systems		Combustion Dampers	Boiler Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	6	1	EA	\$8,437	
Heating Devices		Cabinet Heaters With Steam Coils	Entire Building	7	2	EA	\$0	
Heating Devices		Fin Tube Electric	Entire Building	6	20	LF	\$286	
Heating Devices		Fin Tube Hot Water	Entire Building	7	30	LF	\$0	
Heating Devices		Unit Heater - Electric	Entire Building	7	8	EA	\$0	
Heating Devices		Unit Heater - Electric	Entire Building	5	3	EA	\$7,722	
Heating Devices		Unit Heater - Gas	Boiler Room	7	1	EA	\$0	
Heating Devices		Unit Heater - Hot Water	Mechanical Room	6	1	EA	\$1,430	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Mechanical Room	6	1	EA	\$715	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	5	250	LF	\$8,133	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	250	LF	\$12,370	
Temperature Control		Hybrid Pneumatic/Direct Digital Control (DDC) System	Mechanical Room	3	71,760	SF	\$718,318	Allerton BAS front end is non functional. Building is controlled manually, no temperature control. The BAS system services both the main and addition. Both square footages have been added together.
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	38	EA	\$5,434	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Temperature Control		Zone Dampers	Mechanical Room	5	19	EA	\$7,064	
Temperature Control		Zone Dampers	Mechanical Room	5	21	EA	\$7,808	
Ventilation		Exhaust Fan - Indoor	MDF ROOM	6	1	EA	\$501	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	2	EA	\$458	
MECHANICAL Sub Total							\$1,618,299	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	1	EA	\$4,147	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	7	1	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	67,260	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	67,260	SF	\$43,282	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	67,260	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	67,260	SF	\$30,778	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	67,260	SF	\$36,549	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	67,260	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	67,260	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	67,260	SF	\$36,549	
Piping		Sanitary Piping	Entire Building	5	67,260	SF	\$41,358	
Piping		Storm Piping	Entire Building	5	67,260	SF	\$31,740	
Piping		Vent Piping	Entire Building	5	67,260	SF	\$24,045	
Pumps		Domestic Booster Pump simplex	Mechanical Room	6	1	EA	\$1,716	
PLUMBING Sub Total							\$250,165	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	principal office	7	305	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	counselor office	6	876	SF	\$1,879	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	main office	7	445	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	asst principal office	7	110	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	engineers office	6	236	SF	\$668	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	gym office	7	75	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	engineers office	6	236	SF	\$1,114	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	gym office	7	75	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	asst principal office	7	110	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	counselor office	6	876	SF	\$1,253	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	principal office	7	305	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	main office	6	445	SF	\$636	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	main office	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	counselor office	7	10	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	asst principal office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	principal office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	engineers office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	gym office	4	2	SF	\$13	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	principal office	7	622	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	engineers office	6	868	SF	\$2,048	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	gym office	6	182	SF	\$429	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	counselor office	6	309	SF	\$729	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	main office	7	840	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	asst principal office	7	320	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	gym office	6	162	SF	\$1,158	
Doors		Interior Steel Doors incl hw	Entire Building	6	6	EA	\$1,699	
Doors		Interior Steel Doors incl hw	classroom doors	4	32	EA	\$105,706	
Doors		Interior Wood Doors incl hw	Entire Building	6	34	EA	\$9,627	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Wood Doors incl hw	Entire Building	5	13	EA	\$6,135	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	5	2	EA	\$3,861	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	3	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	connecting corridor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	4	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	Ground Floor	6	1	EA	\$386	
Drinking Fountains	Corridors	Single Fountain	Ground Floor	5	3	EA	\$5,792	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	4	1	EA	\$3,861	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	ground floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Lay-In	ground floor	6	3,540	SF	\$27,842	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Tile/Sheet	ground floor	6	3,540	SF	\$5,062	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	ground floor	7	12	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	ground floor	7	1	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	ground floor	7	1	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	ground floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	ground floor	6	1,660	SF	\$14,243	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	ground floor	6	2,260	SF	\$16,159	
Locker/Shower Room	Children's Standard Student Restroom	Benches	ground floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor unisex north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	ground floor girls			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd floor girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	unisex in main office			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	001- used as storage			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor unisex south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor unisex south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor unisex north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor unisex north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor unisex north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor unisex south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor unisex south			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	001- used as storage			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	unisex in main office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	ground floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	ground floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor unisex north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	unisex in main office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor unisex north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor unisex south			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	001- used as storage			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Showers	2nd floor unisex south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	ground floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	ground floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys			EA	\$0	
MDF/IDF		Finishes	ground floor	7	95	SF	\$0	
MDF/IDF		Ventilation and Cooling	ground floor	7	1	EA	\$0	
Mechanical/Service Rooms		Boiler Room	ground floor	6	1,200	SF	\$5,663	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	8	SF	\$38	
Mechanical/Service Rooms		Mechanical/Service Rooms	ground floor	6	314	SF	\$1,482	
Mechanical/Service Rooms		Storage Room	ground floor	6	183	SF	\$864	
Mechanical/Service Rooms		Storage Room	book storage	7	280	SF	\$0	
Mechanical/Service Rooms		Storage Room	100	6	45	SF	\$212	
Mechanical/Service Rooms		Storage Room	gym storage	7	120	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor unisex south	6	37	SF	\$286	
Staff Restroom	Children's Standard Student Restroom	Accessories	ground floor boys	6	333	SF	\$2,571	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls	6	333	SF	\$2,571	
Staff Restroom	Staff Restroom	Accessories	2nd floor unisex north	6	37	SF	\$286	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys	6	333	SF	\$2,571	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls	6	333	SF	\$2,571	
Staff Restroom	Staff Restroom	Accessories	3rd floor unisex north	6	37	SF	\$286	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor boys	6	333	SF	\$2,571	
Staff Restroom	Children's Standard Student Restroom	Accessories	ground floor girls	6	333	SF	\$2,571	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys	6	333	SF	\$2,571	
Staff Restroom	Staff Restroom	Accessories	3rd floor unisex south	6	37	SF	\$286	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Accessories	001- used as storage	6	43	SF	\$332	
Staff Restroom	Staff Restroom	Accessories	unisex in main office	7	43	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd floor girls	6	333	SF	\$2,571	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	1st floor boys	5	333	SF	\$1,886	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	ground floor girls	5	333	SF	\$1,886	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	ground floor boys	5	333	SF	\$1,886	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	3rd floor boys	5	333	SF	\$1,886	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	2nd floor girls	6	333	SF	\$714	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	2nd floor boys	5	333	SF	\$1,886	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	3rd floor girls	6	333	SF	\$714	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	1st floor girls	6	333	SF	\$714	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd floor unisex north	6	37	SF	\$105	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	unisex in main office	7	43	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys	6	17	SF	\$48	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	6	17	SF	\$48	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor unisex north	6	37	SF	\$105	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	6	17	SF	\$48	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	6	17	SF	\$48	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	6	17	SF	\$48	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	6	17	SF	\$48	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor unisex south	6	37	SF	\$105	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls	6	17	SF	\$48	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	001- used as storage	5	43	SF	\$244	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys	6	17	SF	\$48	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	ground floor boys	6	34	SF	\$96	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	ground floor girls	6	34	SF	\$96	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	6	17	SF	\$48	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	6	17	SF	\$48	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	6	17	SF	\$48	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd floor unisex south	6	37	SF	\$105	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor girls	6	17	SF	\$48	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	ground floor girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	unisex in main office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	ground floor boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd floor boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor unisex south			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	001- used as storage			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls	5	1	EA	\$1,502	
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	ground floor girls	6	34	SF	\$160	
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	ground floor boys	6	34	SF	\$160	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	3rd floor boys	6	34	SF	\$160	
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	3rd floor girls	6	34	SF	\$160	
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	2nd floor girls	6	34	SF	\$160	
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	2nd floor boys	6	34	SF	\$160	
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	1st floor girls	6	34	SF	\$160	
Staff Restroom	Children's Standard Student Restroom	Flooring - Concrete	1st floor boys	6	34	SF	\$160	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	unisex in main office	7	43	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	001- used as storage	7	43	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd floor unisex south	6	37	SF	\$210	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	3rd floor unisex south	6	37	SF	\$210	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	3rd floor unisex north	6	37	SF	\$210	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd floor unisex north	6	37	SF	\$210	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	2nd floor girls	6	333	SF	\$476	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	ground floor boys	6	333	SF	\$476	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	ground floor girls	6	333	SF	\$476	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	3rd floor girls	6	333	SF	\$476	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	1st floor boys	6	333	SF	\$476	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	2nd floor boys	6	333	SF	\$476	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	1st floor girls	6	333	SF	\$476	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	3rd floor boys	6	333	SF	\$476	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	ground floor boys	6	2	EA	\$434	
Staff Restroom	Staff Restroom	Hand Dryer	unisex in main office			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor unisex north			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	001- used as storage			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	ground floor girls	6	2	EA	\$434	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls	6	2	EA	\$434	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor boys	4	1	EA	\$2,171	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd floor girls	6	2	EA	\$434	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls	6	2	EA	\$434	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys	6	2	EA	\$434	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys	6	2	EA	\$434	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor girls	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd floor boys	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	ground floor boys	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	ground floor girls	6	2	EA	\$744	
Staff Restroom	Early Childhood Student Restroom	Lavatory	001- used as storage	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Lavatory	3rd floor unisex north	6	1	EA	\$372	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	unisex in main office	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	3rd floor unisex south	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	2nd floor unisex south	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	ground floor girls	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	2nd floor unisex north	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor girls	4	6	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor boys	4	4	SF	\$14	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd floor girls	4	6	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor girls	4	6	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd floor boys	4	4	SF	\$14	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	ground floor boys	4	6	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st floor boys	4	4	SF	\$14	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	ground floor girls	4	6	SF	\$21	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	001- used as storage	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd floor unisex south	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd floor unisex south	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd floor unisex north	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd floor unisex north	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	unisex in main office	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	3rd floor boys	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	unisex in main office	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	2nd floor boys	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	3rd floor girls	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	1st floor girls	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	ground floor boys	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	ground floor girls	4	1	EA	\$322	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	1st floor boys	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Lighting - Wall Mounted	2nd floor girls	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	5	1	EA	\$572	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	6	7	EA	\$1,255	
Staff Restroom	Staff Restroom	Partitions	2nd floor unisex north	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys	6	3	EA	\$538	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor girls	6	8	EA	\$1,435	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd floor boys	6	3	EA	\$538	
Staff Restroom	Children's Standard Student Restroom	Partitions	ground floor boys	6	3	EA	\$538	
Staff Restroom	Children's Standard Student Restroom	Partitions	ground floor girls	7	8	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys	6	3	EA	\$538	
Staff Restroom	Staff Restroom	Partitions	3rd floor unisex north	6	1	EA	\$179	
Staff Restroom	Staff Restroom	Partitions	3rd floor unisex south	6	1	EA	\$179	
Staff Restroom	Staff Restroom	Partitions	2nd floor unisex south	6	1	EA	\$179	
Staff Restroom	Early Childhood Student Restroom	Partitions	001- used as storage	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	unisex in main office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	6	8	EA	\$1,435	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys	6	5	EA	\$1,859	
Staff Restroom	Staff Restroom	Urinals	unisex in main office			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	001- used as storage			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys	6	4	EA	\$1,487	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Urinals	ground floor boys	6	3	EA	\$1,115	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	ground floor boys	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Urinals	ground floor boys	4	1	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys	4	2	EA	\$7,436	
Staff Restroom	Staff Restroom	Urinals	3rd floor unisex south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor unisex north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd floor boys	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor boys	6	195	SF	\$1,394	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor girls	6	243	SF	\$1,737	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor girls	6	243	SF	\$1,737	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st floor girls	6	243	SF	\$1,737	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	unisex in main office	7	224	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Structural Glazed Tile	001- used as storage	6	224	SF	\$1,602	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys	4	1	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor girls	6	7	EA	\$2,603	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	6	5	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd floor boys	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	5	3	EA	\$5,577	
Staff Restroom	Staff Restroom	Water Closet	2nd floor unisex north	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls	6	8	EA	\$2,974	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	6	2	EA	\$744	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	ground floor boys	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Water Closet	ground floor boys	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	ground floor girls	5	3	EA	\$5,577	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Water Closet	3rd floor unisex north	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Water Closet	3rd floor unisex south	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Water Closet	2nd floor unisex south	6	1	EA	\$372	
Staff Restroom	Early Childhood Student Restroom	Water Closet	001- used as storage	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Water Closet	unisex in main office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	ground floor girls	6	5	EA	\$1,859	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
INTERIOR Sub Total							\$364,221	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	counselor office	7	1,584	SF	\$0	
Casework	Classroom	Casework		5	10	LF	\$1,788	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	24	LF	\$4,290	
Casework	Classroom	Casework		5	15	LF	\$2,681	
Casework	Classroom	Casework		5	15	LF	\$2,681	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	14	LF	\$2,503	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	51	LF	\$1,823	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	14	LF	\$2,503	
Casework	Classroom	Casework		5	7	LF	\$1,251	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		5	14	LF	\$2,503	
Casework	Classroom	Casework		5	14	LF	\$2,503	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	18	LF	\$3,218	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		6	7	LF	\$250	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		7	804	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		6	780	SF	\$1,673	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		7	804	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	756	SF	\$1,622	
Ceiling	Classroom	Lay-In/Drop		7	756	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	804	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		5	820	SF	\$4,643	grid collapsing over windows
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		5	820	SF	\$4,643	major sagging near windows
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		5	820	SF	\$4,643	major sagging and displacement near windows
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Ceiling	Classroom	Lay-In/Drop		7	820	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	820	SF	\$1,759	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	11	LF	\$1,337	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	34	LF	\$4,133	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Corridors	Corridors	Concrete Block	connecting corridor	7	35	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	South Stairs	5	1,889	SF	\$8,914	
Corridors	Corridors	Concrete Epoxy/Painted	gym exit vestibule	5	41	SF	\$193	
Corridors	Corridors	Concrete Epoxy/Painted	North Stairs	5	1,889	SF	\$8,914	
Corridors	Corridors	Concrete Epoxy/Painted	Ground Floor N and S Entry Vestibules	6	150	SF	\$708	
Corridors	Corridors	Drinking Fountains	gym exit vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	North Stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	Ground Floor N and S Entry Vestibules			EA	\$0	
Corridors	Corridors	Drinking Fountains	South Stairs			EA	\$0	
Corridors	Corridors	Drop/Lay-In	Ground Floor	6	1,530	SF	\$3,282	
Corridors	Corridors	Drop/Lay-In	connecting corridor	5	212	SF	\$1,201	
Corridors	Corridors	Lighting	1st Floor	4	2,080	EA	\$1,264,120	
Corridors	Corridors	Pendant/Surface	Ground Floor	4	1,530	EA	\$14,878	
Corridors	Corridors	Pendant/Surface	connecting corridor	4	647	EA	\$6,291	
Corridors	Corridors	Pendant/Surface	3rd Floor	4	2,080	EA	\$20,226	
Corridors	Corridors	Pendant/Surface	2nd Floor	4	2,080	EA	\$20,226	
Corridors	Corridors	Pendant/Surface	Ground Floor N and S Entry Vestibules	4	150	EA	\$1,459	
Corridors	Corridors	Pendant/Surface	South Stairs	4	835	EA	\$8,120	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Pendant/Surface	North Stairs	4	835	EA	\$8,120	
Corridors	Corridors	Pendant/Surface	gym exit vestibule	4	41	EA	\$399	
Corridors	Corridors	Plaster/Drywall	Ground Floor	6	2,880	SF	\$6,795	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	4,180	SF	\$9,863	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	4,180	SF	\$9,863	
Corridors	Corridors	Plaster/Drywall	connecting corridor	6	1,017	SF	\$2,400	
Corridors	Corridors	Plaster/Drywall	3rd Floor	6	4,180	SF	\$9,863	
Corridors	Corridors	Stair Handrails	gym exit vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	Ground Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	connecting corridor			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	North Stairs	6	333	LF	\$0	
Corridors	Corridors	Stair Handrails	South Stairs	6	333	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Ground Floor N and S Entry Vestibules			LF	\$0	
Corridors	Corridors	Stairs	gym exit vestibule			EA	\$0	
Corridors	Corridors	Stairs	connecting corridor			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	Ground Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Ground Floor N and S Entry Vestibules			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	connecting corridor	6	708	SF	\$5,062	
Corridors	Corridors	Structural Glazed Tile	gym exit vestibule	6	104	SF	\$744	
Corridors	Corridors	Student Lockers	South Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	gym exit vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	connecting corridor			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Ground Floor			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Ground Floor N and S Entry Vestibules			EA	\$0	
Corridors	Corridors	Student Lockers	North Stairs			EA	\$0	
Corridors	Corridors	Terrazzo	1st Floor	6	2,080	SF	\$11,779	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Terrazzo	2nd Floor	6	2,080	SF	\$11,779	
Corridors	Corridors	Terrazzo	3rd Floor	6	2,080	SF	\$11,779	
Corridors	Corridors	Tile/Sheet Flooring	Ground Floor	6	1,530	SF	\$2,188	
Corridors	Corridors	Tile/Sheet Flooring	connecting corridor	6	647	SF	\$925	
Corridors	Corridors	Walls	South Stairs	6	1,260	SF	\$2,973	
Corridors	Corridors	Walls	North Stairs	6	1,260	SF	\$2,973	
Corridors	Corridors	Walls	South Stairs	6	4,400	SF	\$10,382	
Corridors	Corridors	Walls	Ground Floor N and S Entry Vestibules	6	280	SF	\$661	
Corridors	Corridors	Walls	North Stairs	6	4,400	SF	\$10,382	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	6	2,080	SF	\$5,889	
Corridors Ceiling	Corridors	Plaster/Drywall	gym exit vestibule	6	41	SF	\$116	
Corridors Ceiling	Corridors	Plaster/Drywall	North Stairs	6	835	SF	\$2,364	
Corridors Ceiling	Corridors	Plaster/Drywall	North Stairs	6	504	SF	\$1,427	
Corridors Ceiling	Corridors	Plaster/Drywall	South Stairs	6	504	SF	\$1,427	
Corridors Ceiling	Corridors	Plaster/Drywall	South Stairs	6	835	SF	\$2,364	
Corridors Ceiling	Corridors	Plaster/Drywall	Ground Floor N and S Entry Vestibules	6	150	SF	\$425	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	6	2,080	SF	\$5,889	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	6	2,080	SF	\$5,889	
Corridors Ceiling	Corridors	Plaster/Drywall	connecting corridor	6	435	SF	\$1,232	
Stairs	Corridors	Asphalt	North Stairs	6	154	SF	\$1,101	
Stairs	Corridors	Asphalt	South Stairs	6	154	SF	\$1,101	
Floor	Classroom	Carpet		6	820	SF	\$1,173	
Floor	Classroom	Carpet		4	756	SF	\$7,849	
Floor	Classroom	Carpet		6	820	SF	\$1,173	
Floor	Classroom	Tile/Sheet		6	804	SF	\$1,150	
Floor	Classroom	Tile/Sheet		6	804	SF	\$1,150	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	804	SF	\$11,382	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	780	SF	\$11,042	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		6	756	SF	\$5,708	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		6	820	SF	\$6,191	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		5	820	SF	\$11,609	
Floor	Classroom	Wood		6	820	SF	\$6,191	
Floor	Classroom	Wood		6	820	SF	\$6,191	
Floor	Classroom	Wood		6	820	SF	\$6,191	
Floor	Classroom	Wood		6	820	SF	\$6,191	
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	fix missing cover
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		6	11	EA	\$787	replace bulbs
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	fix cracked cover, replace bulbs
Lighting	Classroom	Lay-In		6	12	EA	\$858	fix cracked cover, replace bulbs

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		6	12	EA	\$858	fix missing cover
Lighting	Classroom	Lay-In		6	12	EA	\$858	fix missing cover
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		6	12	EA	\$858	fix cracked cover, replace bulbs
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		6	12	EA	\$858	replace bulbs
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	14	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	3	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	10	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	11	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	ground floor boys	6	195	SF	\$496	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd floor boys	6	831	SF	\$2,115	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st floor girls	6	26	SF	\$66	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st floor girls	6	1,026	SF	\$2,612	
RESTROOM_WALL	Staff Restroom	Restroom Walls	2nd floor unisex north	6	24	SF	\$61	
RESTROOM_WALL	Staff Restroom	Restroom Walls	2nd floor unisex north	6	26	SF	\$66	
RESTROOM_WALL	Staff Restroom	Restroom Walls	2nd floor unisex north	6	343	SF	\$873	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd floor boys	6	26	SF	\$66	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd floor boys	6	195	SF	\$496	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd floor boys	6	831	SF	\$2,115	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd floor girls	6	26	SF	\$66	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd floor girls	6	1,026	SF	\$2,612	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd floor girls	6	26	SF	\$66	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	ground floor girls	6	753	SF	\$1,917	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd floor boys	6	26	SF	\$66	
RESTROOM_WALL	Staff Restroom	Restroom Walls	3rd floor unisex north	6	26	SF	\$66	
RESTROOM_WALL	Staff Restroom	Restroom Walls	2nd floor unisex south	6	26	SF	\$66	
RESTROOM_WALL	Staff Restroom	Restroom Walls	2nd floor unisex south	6	24	SF	\$61	
RESTROOM_WALL	Staff Restroom	Restroom Walls	3rd floor unisex south	6	343	SF	\$873	
RESTROOM_WALL	Staff Restroom	Restroom Walls	3rd floor unisex south	6	26	SF	\$66	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd floor girls	6	1,026	SF	\$2,612	
RESTROOM_WALL	Staff Restroom	Restroom Walls	3rd floor unisex north	6	343	SF	\$873	
RESTROOM_WALL	Staff Restroom	Restroom Walls	2nd floor unisex south	6	343	SF	\$873	
RESTROOM_WALL	Staff Restroom	Restroom Walls	3rd floor unisex north	6	24	SF	\$61	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st floor boys	6	831	SF	\$2,115	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st floor boys	6	195	SF	\$496	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st floor boys	6	26	SF	\$66	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	ground floor girls	6	195	SF	\$496	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	ground floor boys	6	558	SF	\$1,420	
RESTROOM_WALL	Staff Restroom	Restroom Walls	3rd floor unisex south	6	24	SF	\$61	
Wall	Classroom	Metal/Folding Panel		7	860	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	840	SF	\$1,982	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	840	SF	\$1,982	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	850	SF	\$2,006	
Wall	Classroom	Plaster/Drywall		6	840	SF	\$1,982	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	850	SF	\$2,006	
Wall	Classroom	Plaster/Drywall		6	840	SF	\$1,982	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	860	SF	\$2,029	
Wall	Classroom	Plaster/Drywall		6	810	SF	\$1,911	
Wall	Classroom	Plaster/Drywall		6	840	SF	\$1,982	
Wall	Classroom	Plaster/Drywall		6	810	SF	\$1,911	
Wall	Classroom	Plaster/Drywall		6	792	SF	\$1,869	
Wall	Classroom	Plaster/Drywall		6	840	SF	\$1,982	
Wall	Classroom	Plaster/Drywall		6	840	SF	\$1,982	
Wall	Classroom	Wall		7	860	SF	\$0	

ROOM Sub Total \$2,124,307

Building Main Sub Total \$8,771,088

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Exterior Steel Door	Entire Building	7	4	EA	\$0	
Doors		Transom Lite	Entire Building	7	2	EA	\$0	
Foundation		Masonry Foundation	Basement	7	260	SF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	3	EA	\$644	
Lintels		Lintels - Brick	North Façade	7	31	LF	\$0	
Lintels		Lintels - Steel	Entire Building	7	124	LF	\$0	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Coping - Stone	Roofs	6	326	LF	\$0	
Parapet		Parapet < 16" Height	Roofs	6	326	LF	\$50,767	
Roof System		EPDM/ Synthetic Rubber Roof	Lower Roofs	6	2,250	SF	\$11,261	
Roof System		Exterior Downspouts	Entire Building	6	58	LF	\$1,078	
Roof System		Interior Downspouts	Entire Building	6	68	LF	\$0	
Roof System		Modified Bitumen Roof	High Roof	6	2,250	SF	\$15,927	
Roof System		Roof Structure: Steel with Clay Tile Arch	Roofs	7	4,500	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	4,500	SF	\$0	
Walls		Brick	Entire Building	7	5,183	SF	\$0	
Windows		Window - Guards wire guard	Entire Building	6	894	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	4	1,038	SF	\$179,279	
EXTERIOR Sub Total							\$258,955	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	5	2,558	SF	\$2,926	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	7	2	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	Entire Building	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	2	4	EA	\$3,718	no batteries installed, no emergency source of power, no generator or ups
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	2	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	2	2	EA	\$1,859	no batteries, no emergency source of power, no generator, no ups
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Entire Building	2	3	EA	\$2,789	no batteries installed, no emergency source of power, no generator or ups
Power Distribution		Lighting and power panels	Entire Building	7	3	EA	\$0	
ELECTRICAL Sub Total							\$11,292	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Air Handling Unit Package - Single Zone - Steam 4,000 to 8,000 cfm	Interstitial Space of the lower roof	4	1	EA	\$50,050	Unit not operational per building engineer. Coil is blocked and dampers are rusted shut. Unit was manually controlled.
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Interstitial Space of the lower roof	5	1	EA	\$5,720	
Air Handling Systems		Make Up Air Unit - Roof Mounted - Gas-Heating 6,000 to 10,000 cfm	Roof	5	1	EA	\$21,450	
Heating Devices		Unit Heater - Electric	Entire Building	7	3	EA	\$0	
Heating Devices		Unit Heater - Gas	Entire Building	7	1	EA	\$0	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	5	400	LF	\$13,013	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	400	LF	\$19,791	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	4	EA	\$572	
Ventilation		Exhaust Fan - Indoor	Entire Building	6	1	EA	\$501	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	
MECHANICAL Sub Total							\$111,755	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas less than 150,000 BTU/HR	Kitchen staff locker room	6	1	EA	\$3,575	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	4,500	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	4,500	SF	\$708	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	4,500	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	6	4,500	SF	\$708	
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	4,500	SF	\$708	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	4,500	SF	\$1,030	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	4,500	SF	\$901	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	4,500	SF	\$708	
Piping		Sanitary Piping	Entire Building	6	4,500	SF	\$1,802	
Piping		Storm Piping	Entire Site	6	4,500	SF	\$965	
Piping		Vent Piping	Entire Building	6	4,500	SF	\$708	
PLUMBING Sub Total							\$11,812	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	ground floor	7	121	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	kitchen office	6	845	SF	\$1,813	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	kitchen office	7	845	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	ground floor	7	121	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	ground floor	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	kitchen office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	ground floor	7	186	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	kitchen office	7	214	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	ground floor	6	286	SF	\$675	
Doors		Interior Steel Doors incl hw	Entire Building	6	18	EA	\$5,097	
Kitchen	Warming Kitchen	Ceiling - Lay-In	ground floor	6	780	SF	\$2,231	
Kitchen	Warming Kitchen	Flooring - Tile/Sheet	ground floor	6	780	SF	\$1,115	
Kitchen	Warming Kitchen	Lighting - Lay-In	ground floor	7	10	SF	\$0	
Kitchen	Warming Kitchen	Wall - Concrete Block	ground floor	7	1,350	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	ground floor mens			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	kitchen locker room			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	ground floor womens			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	ground floor mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	ground floor womens			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	kitchen locker room	7	3	EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	ground floor mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	ground floor womens			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	kitchen locker room			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Exposed	Ground Floor	7	2,180	SF	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	servery	7	396	SF	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	Ground Floor	6	378	SF	\$811	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	servery	7	396	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Lunchroom	Flooring - Tile/Sheet	Ground Floor	7	2,558	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	servery	7	6	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Ground Floor	7	4	SF	\$0	
Lunchroom	Multipurpose Room	Serving Line	servery	7	26	LF	\$0	
Lunchroom	Lunchroom	Serving Line	Ground Floor			LF	\$0	
Lunchroom	Warming Kitchen	Serving Line	ground floor			LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	Ground Floor	7	1,978	SF	\$0	
Lunchroom	Multipurpose Room	Wall - Concrete Block	servery	7	587	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	cooler area	7	104	SF	\$0	
Mechanical/Service Rooms		Storage Room	kitchen	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	ground floor womens	6	33	SF	\$255	
Staff Restroom	Staff Restroom	Accessories	ground floor mens	7	33	SF	\$0	
Staff Restroom	Locker/Shower Room	Accessories	kitchen locker room	7	70	SF	\$0	
Staff Restroom	Locker/Shower Room	Ceiling - Lay-In	kitchen locker room	6	70	SF	\$150	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	ground floor womens	7	33	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	ground floor mens	7	33	SF	\$0	
Staff Restroom	Staff Restroom	Floor Drain	ground floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	ground floor mens			EA	\$0	
Staff Restroom	Locker/Shower Room	Floor Drain	kitchen locker room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	ground floor womens	7	33	SF	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Tile/Sheet	kitchen locker room	7	70	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	ground floor mens	7	33	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	ground floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	ground floor mens			EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	kitchen locker room			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	ground floor womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	ground floor mens	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Lavatory	kitchen locker room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	ground floor womens	7	1	SF	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Lay-In	kitchen locker room	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	ground floor mens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Partitions	ground floor womens			EA	\$0	
Staff Restroom	Locker/Shower Room	Partitions	kitchen locker room			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	ground floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	ground floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	ground floor womens			EA	\$0	
Staff Restroom	Locker/Shower Room	Urinals	kitchen locker room			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Locker/Shower Room	Wall - Concrete Block	kitchen locker room	7	387	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	ground floor mens	7	104	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	ground floor womens	7	163	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	ground floor womens	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	ground floor mens	7	104	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	ground floor womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	ground floor mens	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Water Closet	kitchen locker room	7	1	EA	\$0	

INTERIOR Sub Total \$12,146

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	kitchen office	7	108	SF	\$0	
Chalk Board	Lunchroom	Chalk Board	Ground Floor	4		LF		
Chalk Board	Multipurpose Room	Chalk Board	servery	4		LF		
LUNCH_LIGHT	Lunchroom	Lunchroom Lighting	Ground Floor	7	9	EA	\$0	
LUNCH_LIGHT	Lunchroom	Lunchroom Lighting	Ground Floor	6	1	EA	\$93	
LUNCH_WALL	Lunchroom	Lunchroom Walls	Ground Floor	7	1,069	SF	\$0	
Marker Board	Lunchroom	Marker Board	Ground Floor			LF	\$0	
Marker Board	Multipurpose Room	Marker Board	servery			LF	\$0	

ROOM Sub Total \$93

Building Addition Sub Total \$406,052

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	10	EA	\$0	
Civil/Drainage		Catch Basin	Site - East	6	1	EA	\$543	Rod catch at track, flooded site
Civil/Drainage		Site Manhole	Entire Building	7	11	EA	\$0	
Fencing		Chain Link	Trash Enclosure	7	103	LF	\$0	
Fencing		Ornamental Iron	Entire Site	7	1,243	LF	\$0	
Landscape		Grass	Entire Site	7	10,237	SF	\$0	
Landscape		Grass	SE Field	4	12,305	SF	\$48,741	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Landscape		Hardscape - Concrete	Entire Site	7	19,729	SF	\$0	
Landscape		Irrigation	Site SE and SW	5	22,151	SF	\$41,812	
Landscape		Parkway trees	Entire Site	7	31	EA	\$0	
Landscape		Planting Beds/ Areas	Site SW	7	2,261	SF	\$0	
Landscape		Trash Receptacles	Site- N and S	7	2	EA	\$0	
Landscape		Walking Path - Crushed Stone	Track at SE Playlot	4	400	SF	\$2,431	Portions flooded
Parking Lot		Asphalt	Site West and NE	7	17,473	SF	\$0	
Parking Lot		Concrete Curbs	Site NE	7	330	LF	\$0	
Parking Lot		Trash Compactor	Site z West	6	1	EA	\$3,575	
Parking Lot		Trash Enclosure	Site z West	7	1,809	SF	\$0	
Parking Lot		Vehicular Screening	Site NE	7	250	LF	\$0	
Playground		Playground Equipment - Pre-K 3-5	Site NW	4	1	EA	\$107,250	
Playground		Playground Equipment - School Age 5-12	Site South	6	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Site NW	4	900	SF	\$23,784	
Playground		Playground Surfacing - Poured Surface	Site South	6	2,294	SF	\$6,069	
Sidewalks		Internal Walks	Site- East BLDG Facade	7	78	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	8,472	SF	\$0	
Signage		Flag Pole	Site SW	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	Site SW	7	1	EA	\$0	
SITE Sub Total							\$234,206	
SITE Sub Total							\$234,206	

Total Campus Need ^{2 3} \$9,411,346

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
001	804	1	1	6	40	180	90		N	N	Y	Classroom		
002	804	1	2	8	40	180	90		N	N	Y	Classroom		
003	756	1	2	8	40	180	90		N	N	Y	Classroom		
007	756	1	36	74	40	150	60	2	N	N	Y	Classroom		
008	804	1	2	8	40	180	90		N	N	N	Classroom		
100	780	1	1	12	40	120	45	2	N	N	N	Classroom		
101	820	1	1	12	40	180	90		N	N	N	Classroom		
102	820	1	1	12	40	150	60		N	N	Y	Classroom		
103	820	1	1	12	40	180	90		N	N	Y	Classroom		
104	820	1	1	12	40	180	90		N	N	Y	Classroom		
105	820	1	1	12	40	180	90		N	N	N	Classroom		
106	820	1	1	12	40	180	90		N	N	Y	Classroom		
107	820	1	1	12	40	180	90		N	N	Y	Classroom		
108	820	1	1	12	40	180	90		N	N	N	Classroom		
109	820	1	1	12	40	180	90		N	N	N	Classroom		
109- 1	820	1	1	12	40	180	90		N	N	N	Classroom		
200	820	1	1	12	40	180	90		N	N	N	Classroom		
201	820	1	1	12	40	180	90		N	N	N	Classroom		
202	820	1	1	12	40	150	60		N	N	Y	Classroom		
203	820	1	1	12	40	180	90		N	N	Y	Classroom		
204	820	1	1	12	40	150	60	2	N	N	Y	Classroom		
205	820	1	1	12	40	180	90		N	N	Y	Classroom		
206	820	1	1	12	40	180	90		N	N	Y	Classroom		
207	820	1	1	12	40	180	90		N	N	N	Classroom		
208	820	1	1	12	40	180	90		N	N	Y	Classroom		
209	820	1	1	12	40	150	60	2	N	N	N	Classroom		
300	820	1	1	12	40	150	60	2	N	N	Y	Classroom		
301	820	1	1	12	40	150	60	2	N	N	Y	Classroom		
302	820	1	1	12	40	120	45	2	N	N	N	Classroom		
303	820	1	1	12	40	180	90		N	N	Y	Classroom		
304	820	1	1	12	40	180	90		N	N	N	Classroom		
305	820	1	1	12	40	150	60	2	N	N	N	Classroom		
306	820	1	1	12	40	180	90		N	N	Y	Classroom		
307	820	1	1	12	40	180	90		N	N	N	Classroom		
308	820	1	1	12	40	180	90		N	N	N	Classroom		
309	820	1	1	12	40	150	60	2	N	N	N	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	367								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls
Other	37								N	N	N	Restroom	Staff Restroom	2nd floor unisex south
Other	367								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor boys
Other	367								N	N	N	Restroom	Children's Standard Student Restroom	3rd floor girls
Other	305			12					N	N	Y	Administrative Suites/Offices		principal office
Other	41								N	N	N	Corridors		gym exit vestibule
Other	445			12					N	N	N	Administrative Suites/Offices		main office
Other	75			4					N	N	Y	Administrative Suites/Offices		gym office
Other	236			8					N	N	Y	Administrative Suites/Offices		engineers office
Other	3540								N	N	N	Gymnasia	Standard Dedicated Gymnasium	ground floor
Other	647								N	N	N	Corridors		connecting corridor
Other	43								N	N	N	Restroom	Early Childhood Student Restroom	001- used as storage
Other	37								N	N	N	Restroom	Staff Restroom	2nd floor unisex north
Other	876			10					N	N	Y	Administrative Suites/Offices		counselor office
Other	367								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys
Other	110			6					N	N	Y	Administrative Suites/Offices		asst principal office
Other									N	N	N	Corridors		North Stairs
Other	37								N	N	N	Restroom	Staff Restroom	3rd floor unisex north
Other	367								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls
Other	43								N	N	N	Restroom	Staff Restroom	unisex in main office
Other	37								N	N	N	Restroom	Staff Restroom	3rd floor unisex south
Other									N	N	N	Corridors		South Stairs
Other	2080								N	N	N	Corridors		3rd Floor
Other	2080								N	N	N	Corridors		2nd Floor
Other	1530								N	N	N	Corridors		Ground Floor
Other	2080								N	N	N	Corridors		1st Floor
Other	150								N	N	N	Corridors		Ground Floor N and S Entry Vestibules
Other	367								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys
Other	367								N	N	N	Restroom	Children's Standard Student Restroom	ground floor girls
Other	367								N	N	N	Restroom	Children's Standard Student Restroom	ground floor boys

Building: Addition

Other	2558								N	N	N	Lunch & Multipurpose Room	Lunchroom	Ground Floor
Other	845			2					N	N	N	Administrative Suites/Offices		kitchen office
Other	33								N	N	N	Restroom	Staff Restroom	ground floor womens
Other	33								N	N	N	Restroom	Staff Restroom	ground floor mens
Other	396								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	servery

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	121			6					N	N	Y	Administrative Suites/Offices		ground floor
Other	70								N	N	N	Restroom	Locker/Shower Room	kitchen locker room
Other	780								N	N	N	Kitchen	Warming Kitchen	ground floor