

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	North	6	85	LF	\$42,543	strapped, efflorescence
Chimney		Brick Chimney - Concrete/ Mortar Liner	West	6	65	LF	\$32,533	abandoned
Cornice		Cornice - Masonry Projecting/Limestone	S and E entries	5	395	LF	\$79,966	open joints
Cornice		Cornice - Metal Projecting	Entire Building	5	3,344	LF	\$989,427	corroded, holes, leaks, pigeon dung per engineer
Doors		Exterior FRP Door	S main and E	6	7	EA	\$3,898	
Doors		Exterior Steel Door	N- kitchen, mechanical, boiler	6	3	EA	\$991	
Doors		Side Lite	N kitchen and mechanical	6	2	EA	\$453	
Doors		Transom Lite	S main and E and boiler	6	8	EA	\$2,265	
Entrance		Concrete Exterior Stairs	N boiler	7	4	LF	\$0	
Entrance		Entrance Controls - Audio	East Entrances	6	1	EA	\$429	
Entrance		Entrance Controls - Audio and Video	S main	7	1	EA	\$0	
Entrance		Power Door Operator and Controls	S main	6	1	EA	\$0	per engineer: does not close

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Stone Stairs	East Entrances	6	9	LF	\$1,609	
Foundation		Masonry Foundation	coal room	6	66	SF	\$6,541	spalling, seepage
Foundation		Masonry Foundation	Entire Building	7	465	SF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	7	10	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	10	EA	\$2,145	
Lighting		Exterior Lights - Wall Mounted	Entire Building	4	1	EA	\$1,573	
Lintels		Lintels - Brick	2nd floor arches	7	120	LF	\$0	
Lintels		Lintels - Concrete	Entire Building	7	580	LF	\$0	
Lintels		Lintels - Stone	Ground Floor	7	175	LF	\$0	
Lintels		Lintels - Stone	East Façade	5	14	LF	\$3,003	Crack at door 2 lintel
Lintels		Lintels - Terra Cotta	S round windows	7	6	LF	\$0	
Parapet		Coping - Metal	N 3 story toilets	6	44	LF	\$0	
Parapet		Coping - Stone	S 4 story	7	270	LF	\$0	
Parapet		Coping - Stone	N and E 1 story	6	150	LF	\$0	
Parapet		Coping - Stone	S air intakes	5	44	LF	\$3,837	joints
Parapet		Coping - Terra Cotta	Entire Building	6	517	LF	\$0	
Parapet		Parapet > 30" Height	Entire Building	7	836	LF	\$0	
Parapet		Parapet 16" to 30" Height	E 1 story, NE 1 story, courtyards	7	90	LF	\$0	
Roof System		Exterior Downspouts	Entire Building	6	455	LF	\$8,458	per engineer: freeze in winter
Roof System		Modified Bitumen Roof	N 3 story toilets	4	234	SF	\$5,521	active leaks
Roof System		Modified Bitumen Roof	Roof	6	20,300	SF	\$143,694	
Roof System		Roof Structure: Heavy Timber	Roof	7	20,534	SF	\$0	
Superstructure		Heavy Timber	Entire Building	7	65,516	SF	\$0	
Walls		Brick	Entire Building	7	25,350	SF	\$0	
Walls		Brick	East Courtyard	5	130	SF	\$2,945	open joints to interior
Walls		Prefabricated Metal Panel Wall	S bay windows	5	125	SF	\$3,575	
Walls		Stone - Cut	E entry, E and NE base, S balustrade and entry, intakes	5	2,515	SF	\$269,734	Delaminated limestone
Walls		Stone - Cut	Entire Building	6	1,390	SF	\$19,877	
Walls		Terra Cotta	band, column caps, mullions	6	1,200	SF	\$34,320	
Windows		Window - Guards perforated	Entire Building	5	1,850	SF	\$46,667	bent, difficult to open, do not close
Windows		Windows - Sash Aluminum Double-pane	Entire Building	5	7,050	SF	\$243,468	upper sash balance problems

EXTERIOR Sub Total \$1,949,470

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	3	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	9,782	SF	\$0	T8 INSTALLED
Emergency System		Emergency generator 60 to 100 KW natural gas - Outdoor	Outside North of building	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	14	EA	\$0	
Emergency System		Independent Electrical Service for emergency power	Basement	7	1	EA	\$0	
Emergency System		Public Announcement System	1st Floor	5	121,358	SF	\$173,542	
Emergency System		Security System - CCTV	1st Floor	5	121,358	SF	\$347,084	
Emergency System		Security System - Intrusion detection	1st Floor	6	100,646	SF	\$93,550	
Main Service		Main Electrical service 2000 A 120/208/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	6	7	EA	\$5,005	
Power Distribution		Lighting and power panels	Entire Building	7	9	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	1st Floor	7	2	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	1st Floor	7	1	EA	\$0	

ELECTRICAL Sub Total \$619,181

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	65,516	SF	\$23,422	
Fire Alarm		Fire Alarm System	Basement	7	61,807	SF	\$0	
Fire Alarm		Fire Pump Controller	pump room	7	1	EA	\$0	
Pump Room Assembly		Fire Pump less than 25hp	pump room	6	1	EA	\$3,160	
Sprinkler System		Dry Sprinkler System	Entire Building	7	65,516	SF	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	6	65,516	SF	\$3,748	

FIRE PROTECTION Sub Total \$30,330

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Ground Mounted less than 5 tons	North Courtyard	7	1	EA	\$0	
Air Conditioning		Window A/C Unit	Entire Building	5	3	EA	\$3,218	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	7	3	EA	\$0	
Air Conditioning		Window A/C Unit	Entire Building	6	3	EA	\$644	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	South main entrance exterior walls next pillars.	7	2	EA	\$0	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	North Courtyard	7	2	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Mechanical Room	6	1	EA	\$2,860	
Air Handling Systems		Multi Zone Double Delivery Built Up Air Handling Unit - Steam 45,000 to 60,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Multi Zone Double Delivery Built Up Air Handling Unit Auxiliaries - Steam 45,001 to 60,000 cfm	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Return Duct Work - Sheet Metal - Exterior Vertical Shaft and Ducts	Entire Building	7	80	LF	\$0	
Air Handling Systems		Return Duct Work - Sheet Metal - Exterior Vertical Shaft and Ducts	Entire Building	7	80	LF	\$0	
Air Handling Systems		Return Duct Work - Sheet Metal - Exterior Vertical Shaft and Ducts	Entire Building	7	80	LF	\$0	
Air Handling Systems		Return Fans - Outdoor greater than 20,000 CFM	Roof	7	2	EA	\$0	
Air Handling Systems		Return Fans - Outdoor 10,001 to 20,000 CFM	Roof	7	1	EA	\$0	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 76-100 HP	Boiler Room	7	2	EA	\$0	
Boiler Systems		Boiler Auxiliary - Steam Boiler 76-100 HP	Boiler Room	7	2	EA	\$0	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	7	1	EA	\$0	
Boiler Systems		Combustion Dampers	Boiler Room	7	2	EA	\$0	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	7	1	EA	\$0	
Heating Devices		Fin Tube Hot Water	Entire Building	6	16	LF	\$275	
Heating Devices		Unit Heater - Electric	Entire Building	7	10	EA	\$0	
Heating Devices		Unit Heater - Gas	Boiler Room	7	1	EA	\$0	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	7	2	EA	\$0	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	4	500	LF	\$48,978	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	500	LF	\$24,739	
Temperature Control		Direct Digital Control (DDC) System	Basement	6	100,646	SF	\$100,747	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	36	EA	\$0	
Temperature Control		Zone Dampers	Basement	7	15	EA	\$0	
Temperature Control		Zone Dampers	Basement	7	20	EA	\$0	
Temperature Control		Zone Dampers	Basement	7	20	EA	\$0	
Ventilation		Exhaust Fan - Indoor	Entire Building	7	1	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	1	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	
MECHANICAL Sub Total							\$182,117	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	1	EA	\$4,147	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	7	1	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	65,516	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	65,516	SF	\$21,548	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	65,516	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	65,516	SF	\$14,053	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	65,516	SF	\$16,864	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	65,516	SF	\$0	
Piping		Sanitary Piping	Entire Building	5	65,516	SF	\$40,286	
Piping		Storm Piping	Entire Building	5	65,516	SF	\$30,917	
Piping		Vent Piping	Entire Building	5	65,516	SF	\$23,422	
PLUMBING Sub Total							\$151,237	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	engineers office- basement	6	495	SF	\$1,402	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	206	7	390	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	308B	7	162	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Principals office, 1st fl mezz	7	700	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office rm 111 FP#109	7	850	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	209A- Resource	7	550	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	003 counselors office	6	1,020	SF	\$2,888	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	209B- Various Staff Functions	7	550	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	206	7	390	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	003 counselors office	7	1,020	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	engineers office- basement	6	120	SF	\$566	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	209A- Resource	6	550	SF	\$787	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	308B	7	162	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Main Office rm 111 FP#109	7	850	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	engineers office- basement	5	375	SF	\$5,309	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	209B- Various Staff Functions	5	550	SF	\$7,786	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Principals office, 1st fl mezz	7	700	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	209A- Resource	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	206	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	003 counselors office	6	16	SF	\$11	no covers
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Principals office, 1st fl mezz	6	16	SF	\$11	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	308B	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	209B- Various Staff Functions	7	8	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	engineers office- basement	7	7	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office rm 111 FP#109	7	14	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	206	7	1,105	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	003 counselors office	6	955	SF	\$2,253	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principals office, 1st fl mezz	6	950	SF	\$2,242	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	209B- Various Staff Functions	6	1,250	SF	\$2,949	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	209A- Resource	6	1,250	SF	\$2,949	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	engineers office- basement	7	900	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	308B	6	750	SF	\$1,770	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office rm 111 FP#109	7	1,450	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	7	21	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	62	EA	\$17,555	
Doors		Interior Wood Doors incl hw	Entire Building	6	10	EA	\$2,831	
Doors		Interior Wood Doors incl hw	Entire Building	7	64	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	4	9	EA	\$28,880	
Doors		Interior Wood Doors incl hw	Entire Building	5	1	EA	\$472	
Doors		Transom Window	Entire Building	6	460	SF	\$8,551	
Drinking Fountains	Corridors	Double Fountain	1st fl including center stair to basement	5	2	EA	\$6,578	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	basement girls east			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor east unisex			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor west unisex			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor east unisex			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls east			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl unisex			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls east			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl mens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl unisex			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl principals			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls east			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Early Childhood Student Restroom	Benches	in 402			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor east unisex			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in 402			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls east			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor west unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor east unisex			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl principals			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls east			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls east			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	basement girls east			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls east			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	basement girls east			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls east			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls east			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor east unisex			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in 402			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Showers	1st fl unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor east unisex			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl principals			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl unisex			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor west unisex			EA	\$0	
MDF/IDF		Finishes	208B	6	110	SF	\$374	
MDF/IDF		Ventilation and Cooling	208B	5	1	EA	\$7,007	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	14,500	SF	\$68,426	
Mechanical/Service Rooms		Storage Room	3rd fl storage	6	936	SF	\$4,417	
Staff Restroom	Early Childhood Student Restroom	Accessories	in 402	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys	7	140	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor west unisex	7	104	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls	7	140	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys	7	170	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor east unisex	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl principals	6	45	SF	\$347	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls east	7	290	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor east unisex	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	basement girls east	7	330	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl unisex	7	262	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls east	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls east	7	290	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl unisex	7	262	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl mens	7	262	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl mens	7	262	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls east	7	290	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls east	7	290	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor west unisex	7	104	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls east	7	290	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st fl unisex	7	262	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl unisex	7	262	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	basement girls east	7	330	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st fl principals	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor east unisex	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	7	170	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor east unisex	7	25	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	in 402	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	7	140	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	7	140	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls east	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls east	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	basement girls east	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor east unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl principals			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls east	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor east unisex			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in 402	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor west unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls east	6	290	SF	\$738	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys	7	170	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls east	6	290	SF	\$738	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls east	6	290	SF	\$738	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	basement girls east	7	330	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl unisex	7	100	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl mens	7	100	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st fl unisex	7	100	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st fl unisex	6	162	SF	\$232	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd fl unisex	6	162	SF	\$232	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd fl mens	6	162	SF	\$232	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor east unisex	6	25	SF	\$36	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd floor east unisex	6	25	SF	\$36	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	in 402	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	1st floor girls	7	140	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	1st floor boys	7	140	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor west unisex	7	104	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls east	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor east unisex			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl unisex			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor west unisex	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in 402			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor east unisex			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl principals			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl mens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls east	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls east	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	basement girls east	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor east unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl principals	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	basement girls east	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls east	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls east	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls east	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor west unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor east unisex	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in 402	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	2nd fl mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor west unisex	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd floor east unisex	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor east unisex	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl girls east	6	6	SF	\$4	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	in 402	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st fl principals	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd fl mens	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st fl unisex	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl girls east	6	6	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls east	6	6	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	basement girls east	6	6	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd fl unisex	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls east	6	5	EA	\$897	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl mens			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl principals	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls east	6	5	EA	\$897	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	basement girls east	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls east	6	5	EA	\$897	
Staff Restroom	Staff Restroom	Partitions	2nd fl unisex			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl unisex			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor west unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in 402			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	basement girls east			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls east			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls east			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl unisex			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl principals			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl mens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor east unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor east unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl girls east			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	basement girls east	7	231	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd fl girls east	7	581	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st fl girls east	7	581	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	3rd fl girls east	7	581	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl girls east	7	600	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st fl unisex	7	937	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd fl unisex	7	937	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd fl mens	7	937	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st fl principals	7	354	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor east unisex	7	140	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd floor east unisex	7	140	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	in 402	7	140	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl girls east	7	600	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls east	7	600	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	basement girls east	7	224	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	basement girls east	7	183	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl unisex	7	238	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl mens	7	238	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor girls	7	436	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor boys	7	436	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor girls	7	400	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor boys	7	400	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st floor west unisex	7	420	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st fl unisex	7	238	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls east	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	basement girls east	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in 402	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls east	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor west unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor east unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	7	3	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor east unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl principals	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl unisex	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls east	7	5	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
INTERIOR Sub Total							\$182,422	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	003 counselors office	6	255	SF	\$602	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		5	8	LF	\$1,430	
Casework	Classroom	Casework		5	9	LF	\$1,609	
Ceiling	Classroom	Ceiling			1,095	SF	\$0	
Ceiling	Classroom	Ceiling			1,095	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	810	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	950	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	950	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	870	SF	\$2,463	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	770	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	850	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	815	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	27	LF	\$3,282	
Chalk Board	Classroom	Chalk Board		4	35	LF	\$4,254	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	42	LF	\$5,105	
Chalk Board	Classroom	Chalk Board		4	42	LF	\$5,105	
Chalk Board	Classroom	Chalk Board		4	25	LF	\$3,039	
Chalk Board	Classroom	Chalk Board		4	42	LF	\$5,105	
Chalk Board	Classroom	Chalk Board		4	36	LF	\$4,376	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	22	LF	\$2,674	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	27	LF	\$3,282	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	39	LF	\$4,740	
Chalk Board	Classroom	Chalk Board		4	13	LF	\$1,580	
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4	42	LF	\$5,105	
Chalk Board	Classroom	Chalk Board		4	25	LF	\$3,039	
Chalk Board	Classroom	Chalk Board		4	25	LF	\$3,039	
Chalk Board	Classroom	Chalk Board		4	40	LF	\$4,862	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	30	LF	\$3,647	
Corridors	Corridors	Asphalt	3rd Floor	6	1,005	SF	\$1,437	
Corridors	Corridors	Asphalt	1st fl including center stair to basement	5	114	SF	\$1,291	
Corridors	Corridors	Asphalt	1st fl including center stair to basement	6	3,215	SF	\$4,597	
Corridors	Corridors	Asphalt	East Vestibule	6	65	SF	\$93	
Corridors	Corridors	Asphalt	North Vestibule	6	100	SF	\$143	
Corridors	Corridors	Asphalt	West Stair	6	952	SF	\$1,361	
Corridors	Corridors	Asphalt	East Stair	6	952	SF	\$1,361	
Corridors	Corridors	Asphalt	2nd Floor	6	1,005	SF	\$1,437	
Corridors	Corridors	Drinking Fountains	North Vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	East Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	2nd Floor			EA	\$0	
Corridors	Corridors	Drinking Fountains	Center Vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	West Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	3rd Floor			EA	\$0	
Corridors	Corridors	Drinking Fountains	East Vestibule			EA	\$0	
Corridors	Corridors	Floors	2nd Floor	6	30	SF	\$227	
Corridors	Corridors	Floors	1st fl including center stair to basement	6	126	SF	\$951	
Corridors	Corridors	Floors	Center Vestibule	6	90	SF	\$680	
Corridors	Corridors	Floors	3rd Floor	6	30	SF	\$227	
Corridors	Corridors	Lighting	East Vestibule			EA	\$0	
Corridors	Corridors	Pendant/Surface	2nd Floor	6	2,575	EA	\$1,841	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Pendant/Surface	East Stair	7	993	EA	\$0	
Corridors	Corridors	Pendant/Surface	Center Vestibule	6	90	EA	\$64	
Corridors	Corridors	Pendant/Surface	West Stair	7	993	EA	\$0	
Corridors	Corridors	Pendant/Surface	Basement	7	1,162	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st fl including center stair to basement	6	2,575	EA	\$1,841	
Corridors	Corridors	Pendant/Surface	3rd Floor	6	2,575	EA	\$1,841	
Corridors	Corridors	Pendant/Surface	North Vestibule	6	100	EA	\$72	
Corridors	Corridors	Plaster/Drywall	East Vestibule	7	38	SF	\$0	
Corridors	Corridors	Plaster/Drywall	West Stair	6	3,137	SF	\$7,402	
Corridors	Corridors	Plaster/Drywall	Basement	6	600	SF	\$1,416	
Corridors	Corridors	Plaster/Drywall	3rd Floor	6	4,326	SF	\$10,207	
Corridors	Corridors	Plaster/Drywall	East Stair	6	3,137	SF	\$7,402	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	4,326	SF	\$10,207	
Corridors	Corridors	Plaster/Drywall	1st fl including center stair to basement	6	4,710	SF	\$11,113	
Corridors	Corridors	Plaster/Drywall	Center Vestibule	7	126	SF	\$0	
Corridors	Corridors	Single Water Cooler	Basement	7	3	EA	\$0	
Corridors	Corridors	Stair Handrails	East Vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	1st fl including center stair to basement	6	112	LF	\$0	
Corridors	Corridors	Stair Handrails	East Stair	6	150	LF	\$0	
Corridors	Corridors	Stair Handrails	Center Vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	West Stair	6	150	LF	\$0	
Corridors	Corridors	Stair Handrails	North Vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	Basement			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stairs	East Vestibule			EA	\$0	
Corridors	Corridors	Stairs	Basement			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	Center Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	East Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Basement			EA	\$0	
Corridors	Corridors	Student Lockers	North Vestibule			EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Student Lockers	West Stair			EA	\$0	
Corridors	Corridors	Student Lockers	Center Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	1st fl including center stair to basement			EA	\$0	
Corridors	Corridors	Student Lockers	East Stair			EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Basement	7	1,162	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	6	1,540	SF	\$2,202	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	1,540	SF	\$2,202	
Corridors	Corridors	Walls	Center Vestibule	6	70	SF	\$165	
Corridors	Corridors	Walls	North Vestibule	6	360	SF	\$849	
Corridors	Corridors	Walls	East Vestibule	7	98	SF	\$0	
Corridors	Corridors	Walls	Basement	6	840	SF	\$1,982	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	7	2,575	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	East Stair	7	993	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Center Vestibule	6	90	SF	\$255	
Corridors Ceiling	Corridors	Plaster/Drywall	North Vestibule	6	100	SF	\$283	
Corridors Ceiling	Corridors	Plaster/Drywall	1st fl including center stair to basement	7	3,215	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	7	2,575	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Basement	6	1,162	SF	\$3,290	
Corridors Ceiling	Corridors	Plaster/Drywall	East Vestibule	5	65	SF	\$368	
Corridors Ceiling	Corridors	Plaster/Drywall	West Stair	7	993	SF	\$0	
Stairs	Corridors	Asphalt	East Stair	6	77	SF	\$551	
Stairs	Corridors	Asphalt	West Stair	6	77	SF	\$551	
Stairs	Corridors	Asphalt	1st fl including center stair to basement	6	36	SF	\$257	
Stairs	Corridors	Asphalt	North Vestibule	6	3	SF	\$21	
Floor	Classroom	Tile/Sheet		6	815	SF	\$1,165	
Floor	Classroom	Tile/Sheet		6	770	SF	\$1,101	
Floor	Classroom	Tile/Sheet		7	810	SF	\$0	
Floor	Classroom	Tile/Sheet		7	870	SF	\$0	
Floor	Classroom	Tile/Sheet		6	815	SF	\$1,165	
Floor	Classroom	Tile/Sheet		6	850	SF	\$1,216	
Floor	Classroom	Tile/Sheet		6	815	SF	\$1,165	
Floor	Classroom	Tile/Sheet		6	815	SF	\$1,165	
Floor	Classroom	Tile/Sheet		6	815	SF	\$1,165	
Floor	Classroom	Tile/Sheet		6	850	SF	\$1,216	
Floor	Classroom	Tile/Sheet		6	815	SF	\$1,165	
Floor	Classroom	Tile/Sheet		6	815	SF	\$1,165	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	10	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	1st fl principals	6	45	SF	\$115	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	basement girls east	6	270	SF	\$687	efflorescence
Wall	Classroom	Masonry		6	450	SF	\$5,792	
Wall	Classroom	Masonry		6	450	SF	\$5,792	
Wall	Classroom	Masonry		6	525	SF	\$6,757	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,250	SF	\$2,949	
Wall	Classroom	Plaster/Drywall		7	600	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	540	SF	\$1,274	
Wall	Classroom	Plaster/Drywall		6	1,202	SF	\$2,836	
Wall	Classroom	Plaster/Drywall		6	1,250	SF	\$2,949	
Wall	Classroom	Plaster/Drywall		6	1,250	SF	\$2,949	
Wall	Classroom	Plaster/Drywall		6	1,202	SF	\$2,836	

**Building: Main
Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	1,250	SF	\$2,949	
Wall	Classroom	Plaster/Drywall		6	1,250	SF	\$2,949	
Wall	Classroom	Plaster/Drywall		7	1,290	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	600	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,250	SF	\$2,949	
Wall	Classroom	Plaster/Drywall		6	1,202	SF	\$2,836	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,202	SF	\$2,836	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,202	SF	\$2,836	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,605	SF	\$3,787	
Wall	Classroom	Plaster/Drywall		6	1,605	SF	\$3,787	
Wall	Classroom	Plaster/Drywall		6	1,180	SF	\$2,784	
Wall	Classroom	Plaster/Drywall		6	1,250	SF	\$2,949	
ROOM Sub Total							\$414,269	
Building Main Sub Total							\$3,529,025	

**Building: Addition
Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Cornice		Cornice - Masonry Projecting/Limestone	West Entrances	5	110	LF	\$22,269	worn, open joints
Cornice		Cornice - Masonry Projecting/Limestone	North Entrances	6	70	LF	\$2,147	
Cornice		Cornice - Metal Projecting	Entire Building	5	2,035	LF	\$602,118	corroded, holes, leaks, pigeon dung per engineer
Doors		Exterior FRP Door	Entire Building	6	14	EA	\$7,796	
Doors		Exterior Steel Door	NW fire escape	6	1	EA	\$330	
Doors		Transom Lite	Entire Building	6	15	EA	\$4,247	
Entrance		Entrance Controls - Audio and Video	North Entrances	7	1	EA	\$0	
Entrance		Power Door Operator and Controls	North Entrances	6	1	EA	\$0	per engineer- door does not fully close
Fire Escape		Fire Escapes	NW of gym	7	3	LF	\$0	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Foundation		Masonry Foundation	Entire Building	7	388	SF	\$0	
Lintels		Lintels - Brick	2nd floor S	7	42	LF	\$0	
Lintels		Lintels - Steel	Entire Building	7	395	LF	\$0	
Lintels		Lintels - Stone	Ground Floor	7	81	LF	\$0	
Lintels		Lintels - Terra Cotta	W auditorium	7	21	LF	\$0	
Parapet		Coping - Stone	W auditorium entrance	5	56	LF	\$4,883	open joints, worn
Parapet		Coping - Terra Cotta	Entire Building	6	521	LF	\$0	
Parapet		Parapet > 30" Height	Entire Building	7	521	LF	\$0	
Parapet		Parapet 16" to 30" Height	W auditorium entrance	5	56	LF	\$17,970	
Roof System		Exterior Downspouts	West Entrances	7	18	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	323	LF	\$0	
Roof System		Modified Bitumen Roof	Roof	6	12,472	SF	\$88,283	
Roof System		Roof Structure: Steel with Clay Tile Arch	Roof	7	12,472	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	35,130	SF	\$0	
Walls		Brick	Entire Building	7	17,000	SF	\$0	
Walls		Stone - Cut	W entrance and W wall S of auditorium	5	926	SF	\$99,314	spalled, worn, open joints
Walls		Stone - Cut	stone base	6	2,382	SF	\$34,063	
Walls		Terra Cotta	accent band, mullions, medallions	7	690	SF	\$0	
Windows		Window - Guards perforated	Entire Building	6	1,470	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	5	3,650	SF	\$126,051	upper sash balance problems
EXTERIOR Sub Total							\$1,009,471	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	1st Floor	7	1	EA	\$0	
Emergency System		Emergency A/C power - Auditorium and aisle lighting	1st Floor	7	4,608	SF	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	3,980	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	3rd Floor	7	5,031	SF	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	4	EA	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	4	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	6	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	6	10	EA	\$2,331	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	3rd Floor	4	1	EA	\$930	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	3rd Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	2	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	6	4	EA	\$2,860	
Power Distribution		Lighting and power panels	Entire Building	4	1	EA	\$5,434	
ELECTRICAL Sub Total							\$11,554	

Building: Addition
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	35,130	SF	\$0	
FIRE PROTECTION Sub Total							\$0	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	5	2	EA	\$2,145	
Heating Devices		Radiators - Steam	Entire Building	6	5	EA	\$701	
Heating Devices		Unit Heater - Electric	Entire Building	7	10	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	7	13	EA	\$0	
Ventilation		Exhaust Fan - Indoor	Entire Building	7	3	EA	\$0	
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	7	1	EA	\$0	
MECHANICAL Sub Total							\$2,846	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	35,130	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	35,130	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	35,130	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	35,130	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	35,130	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	35,130	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	35,130	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	35,130	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	35,130	SF	\$0	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Storm Piping	Entire Building	7	35,130	SF	\$0	
Piping		Vent Piping	Entire Building	7	35,130	SF	\$0	
PLUMBING Sub Total							\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	204A	7	99	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	lunchroom office	7	104	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	204A	7	99	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	lunchroom office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	204A	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	204A	7	535	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	lunchroom office	7	330	SF	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	Basement			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	Basement	7	410	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	Basement	7	1	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	Basement	7	7	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	Basement	5	1	EA	\$214,500	colored lights out due to wiring/ electrical issues
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	3	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	3	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	Lower Level Corridor	7	3	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	3rd Floor	7	5,031	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	3rd Floor	7	5,031	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	3rd Floor	6	20	EA	\$3,575	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	3rd Floor			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	3rd Floor	7	4,000	SF	\$0	
Library	Library	Casework	2nd Floor	7	65	LF	\$0	
Library	Library	Flooring Carpet	2nd Floor	7	1,644	SF	\$0	
Library	Library	Lighting - Pendant/ Surface	2nd Floor	7	30	SF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	basement boys			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	3rd floor boys			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	auditorium girls			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	auditorium boys			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	auditorium girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	3rd floor boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	auditorium boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	basement boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	auditorium girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	auditorium boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	1st floor boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	3rd floor boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd floor boys			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Adult Standard Student Restroom	Showers	basement boys			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	Basement	7	1,863	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Basement	7	24	SF	\$0	
Lunchroom	Lunchroom	Serving Line	Basement	7	14	LF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	4	SF	\$0	
Mechanical/Service Rooms		Storage Room	Entire Building	7	264	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	1st floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	3rd floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	auditorium boys	7	102	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	auditorium girls	7	63	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	basement boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	auditorium girls	7	63	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	basement boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	3rd floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	auditorium boys	7	102	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	auditorium boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	1st floor boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	auditorium girls	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	basement boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	3rd floor boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd floor boys	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	auditorium girls	7	63	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	auditorium boys	7	102	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile/Sheet	basement boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile/Sheet	1st floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile/Sheet	2nd floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile/Sheet	3rd floor boys	7	384	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	auditorium girls	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	auditorium boys			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	1st floor boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd floor boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	3rd floor boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	basement boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	basement boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	1st floor boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	3rd floor boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	auditorium girls	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	auditorium boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	auditorium girls	7	1	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	auditorium boys	7	2	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	3rd floor boys	7	5	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys	7	5	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys	7	5	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	basement boys	7	5	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	auditorium girls			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	auditorium boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	1st floor boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	basement boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	3rd floor boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	basement boys	7	5	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd floor boys	7	4	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	3rd floor boys	7	4	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	1st floor boys	7	5	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	auditorium boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	auditorium girls			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	2nd floor boys	7	590	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	3rd floor boys	7	590	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	basement boys	7	590	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	1st floor boys	7	590	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	auditorium boys	7	100	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	basement boys	7	208	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	2nd floor boys	7	208	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	1st floor boys	7	208	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	3rd floor boys	7	208	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	auditorium boys	7	350	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	auditorium girls	7	260	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	auditorium boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	1st floor boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	auditorium girls	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	3rd floor boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	basement boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd floor boys	7	2	EA	\$0	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	Basement	7	7,200	SF	\$0	
Theater	Auditorium - Dedicated	Flooring - Carpet	Basement	7	2,650	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	Basement	7	10	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Wall Mounted	Basement	7	14	EA	\$0	
Theater	Auditorium - Dedicated	Stage	Basement	6	950	SF	\$4,035	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	Basement	7	10,250	SF	\$0	
Vertical Conveyance		Stage Lift	auditorium	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total \$222,110

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_FLOOR	Administrative Suites/Offices	Administrative Office Floor	lunchroom office	7	104	SF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Ceiling	Classroom	Plaster/Drywall		7	1,065	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,065	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		7	967	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,065	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,065	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,092	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Lunchroom	Chalk Board	Basement	4		LF		
Chalk Board	Classroom	Chalk Board		4	19	LF	\$2,309	
Chalk Board	Classroom	Chalk Board		4	27	LF	\$3,282	
Chalk Board	Classroom	Chalk Board		4	19	LF	\$2,309	
Chalk Board	Classroom	Chalk Board		4	40	LF	\$4,862	
Chalk Board	Classroom	Chalk Board		4	19	LF	\$2,309	
Corridors	Corridors	Asphalt	Lower Level Corridor	7	2,200	SF	\$0	
Corridors	Corridors	Asphalt	1st Floor	7	870	SF	\$0	
Corridors	Corridors	Asphalt	North Stairs	7	1,200	SF	\$0	
Corridors	Corridors	Asphalt	West Stairs	7	1,200	SF	\$0	
Corridors	Corridors	Asphalt	auditorium lobby	6	100	SF	\$143	
Corridors	Corridors	Asphalt	3rd Floor	7	870	SF	\$0	
Corridors	Corridors	Drinking Fountains	West Stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	North Stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	auditorium vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st floor vestibules- N and W			EA	\$0	
Corridors	Corridors	Drinking Fountains	auditorium lobby			EA	\$0	
Corridors	Corridors	Floors	3rd Floor	7	100	SF	\$0	
Corridors	Corridors	Floors	1st Floor	7	100	SF	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	6	870	EA	\$622	
Corridors	Corridors	Pendant/Surface	3rd Floor	6	870	EA	\$622	
Corridors	Corridors	Pendant/Surface	Lower Level Corridor	7	2,200	EA	\$0	
Corridors	Corridors	Pendant/Surface	West Stairs	7	1,800	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st floor vestibules- N and W	7	168	EA	\$0	
Corridors	Corridors	Pendant/Surface	auditorium vestibule	7	192	EA	\$0	
Corridors	Corridors	Pendant/Surface	auditorium lobby	6	1	EA	\$1	
Corridors	Corridors	Pendant/Surface	North Stairs	7	1,800	EA	\$0	
Corridors	Corridors	Plaster/Drywall	auditorium vestibule	7	50	SF	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	7	1,900	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Lower Level Corridor	7	2,500	SF	\$0	
Corridors	Corridors	Plaster/Drywall	3rd Floor	7	1,900	SF	\$0	
Corridors	Corridors	Plaster/Drywall	1st floor vestibules- N and W	7	50	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Plaster/Drywall	North Stairs	7	3,800	SF	\$0	
Corridors	Corridors	Plaster/Drywall	auditorium lobby	6	620	SF	\$1,463	
Corridors	Corridors	Plaster/Drywall	West Stairs	7	3,800	SF	\$0	
Corridors	Corridors	Stair Handrails	auditorium lobby			LF	\$0	
Corridors	Corridors	Stair Handrails	North Stairs	7	80	LF	\$0	
Corridors	Corridors	Stair Handrails	auditorium vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	1st floor vestibules- N and W			LF	\$0	
Corridors	Corridors	Stair Handrails	West Stairs	7	80	LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Lower Level Corridor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	auditorium lobby			EA	\$0	
Corridors	Corridors	Stairs	auditorium vestibule			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	Lower Level Corridor			EA	\$0	
Corridors	Corridors	Stairs	1st floor vestibules- N and W			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	1st floor vestibules- N and W	6	260	SF	\$1,859	
Corridors	Corridors	Student Lockers	1st floor vestibules- N and W			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	West Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	auditorium lobby			EA	\$0	
Corridors	Corridors	Student Lockers	auditorium vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	North Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	Lower Level Corridor			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Terrazzo	auditorium lobby	6	550	SF	\$3,115	
Corridors	Corridors	Terrazzo	1st floor vestibules- N and W	6	168	SF	\$951	
Corridors	Corridors	Terrazzo	auditorium vestibule	6	200	SF	\$1,133	
Corridors	Corridors	Walls	auditorium vestibule	7	150	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	870	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Lower Level Corridor	7	2,200	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	7	870	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	West Stairs	7	1,800	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st floor vestibules- N and W	7	168	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	auditorium vestibule	7	192	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	North Stairs	7	1,500	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors Ceiling	Corridors	Plaster/Drywall	auditorium lobby	6	550	SF	\$1,557	
Stairs	Corridors	Asphalt	North Stairs	7	70	SF	\$0	
Stairs	Corridors	Asphalt	West Stairs	7	70	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,092	SF	\$0	
Floor	Classroom	Wood		6	1,065	SF	\$8,041	
Floor	Classroom	Wood		6	1,065	SF	\$8,041	
Floor	Classroom	Wood		6	1,065	SF	\$8,041	
Floor	Classroom	Wood		6	967	SF	\$7,301	
Floor	Classroom	Wood		6	1,065	SF	\$8,041	
LIBRARY_CEILING	Library	Plaster/Drywall	2nd Floor	7	1,644	SF	\$0	
LIBRARY_WALL	Library	Plaster/Drywall	2nd Floor	7	2,028		\$0	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	18	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	13	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	13	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	13	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	13	EA	\$0	
LUNCH_FLOOR	Lunchroom	Lunchroom Floor	Basement	6	1,863	SF	\$2,664	
LUNCH_WALL	Lunchroom	Lunchroom Walls	Basement	7	2,155	SF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Lunchroom	Marker Board	Basement			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
THEATER_FLOOR	Auditorium - Dedicated	Auditorium Floor	Basement	7	4,625	SF	\$0	
THEATER_LIGHT	Auditorium - Dedicated	Auditorium Lighting	Basement	7	18	EA	\$0	
Wall	Classroom	Plaster/Drywall		7	1,560	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,670	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,644	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,560	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,560	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,560	SF	\$0	
ROOM Sub Total							\$71,528	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Building Addition Sub Total							\$1,317,509	

Building: Annex
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Exterior FRP Door	Entire Building	6	10	EA	\$5,568	
Doors		Side Lite	Entire Building	6	12	EA	\$2,718	
Doors		Transom Lite	Entire Building	6	10	EA	\$2,831	
Entrance		Concrete Exterior Stairs	South Façade	6	228	LF	\$24,453	
Entrance		Concrete Ramp	SE entrance	6	21	LF	\$2,928	
Entrance		Entrance Controls - Audio and Video	SE entrance	7	1	EA	\$0	
Entrance		Power Door Operator and Controls	SE entrance	6	1	EA	\$0	adjust- does not close (per engineer)
Entrance		Ramp Handrails	SE entrance	6	42	LF	\$0	
Entrance		Stair Handrails	South Entrances	6	112	LF	\$0	
Entrance		Steel or Aluminum Stairs	North Entrances	7	60	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	478	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	6	EA	\$1,287	
Parapet		Coping - Metal	Entire Building	5	450	LF	\$12,613	corroded
Parapet		Coping - Metal	elevator tower	7	29	LF	\$0	
Roof System		Exterior Downspouts	elevator tower	7	28	LF	\$0	
Roof System		Interior Downspouts	Entire Building	5	96	LF	\$10,296	clog easily, cause water to flow over edge
Roof System		Modified Bitumen Roof	elevator tower	7	96	SF	\$0	
Roof System		Modified Bitumen Roof	Roof	4	10,260	SF	\$242,085	ponding, active leaks
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roof	7	10,356	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	20,712	SF	\$0	
Walls		Prefabricated Metal Panel Wall	Entire Building	5	8,020	SF	\$229,372	corroded
Walls		Prefabricated Metal Panel Wall	elevator tower	7	740	SF	\$0	
Windows		Windows - Casement Lexan	Entire Building	4	2,800	SF	\$322,402	
EXTERIOR Sub Total							\$856,553	

Building: Annex
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	6	1	EA	\$1,430	

Building: Annex
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	4	3,525	SF	\$10,838	T12 INSTALLED
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	4	1,800	SF	\$3,218	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	3	8	EA	\$7,436	+20 years, no battery pack, appearance is poor.
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	3	1	EA	\$930	+20 years, no battery pack, appearance is poor.
Emergency System		Independent Electrical Service for emergency power	1st Floor	5	1	EA	\$5,005	
Emergency System		Security System - Intrusion detection	Entire Building	6	20,712	SF	\$19,252	
Main Service		Main Electrical service 2000 A 120/208/3PH	Electrical Room	6	1	EA	\$12,155	
Power Distribution		Lighting and power panels	Electrical Room	6	5	EA	\$3,575	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	6	2	EA	\$4,290	
ELECTRICAL Sub Total							\$68,127	

Building: Annex
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	1st Floor	7	20,712	SF	\$0	
Fire Alarm		Fire Alarm System	1st Floor	7	21,308	SF	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	6	20,712	SF	\$11,847	
FIRE PROTECTION Sub Total							\$11,847	

Building: Annex
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	7	1	EA	\$0	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	7	1	EA	\$0	
Air Handling Systems		Fan Coil Unit - Electric	2nd Floor	7	1	EA	\$0	
Heating Devices		Unit Heater - Electric	Entire Building	6	8	EA	\$11,440	
Heating Devices		Unit Heater - Electric	Electrical Room	3	1	EA	\$5,720	NON OPERATIONAL
Heating Devices		Unit Heater - Electric	1st Floor	3	1	EA	\$5,720	non functional
Unit Ventilation		Unit Ventilators - Self Contained Electric Heating and Cooling	2nd Floor	4	1	EA	\$17,160	
Unit Ventilation		Unit Ventilators - Self Contained Electric Heating and Cooling	Entire Building	6	20	EA	\$34,320	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	3	3	EA	\$12,870	non functional
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	3	EA	\$1,287	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	1	EA	\$229	

Building: Annex
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
MECHANICAL Sub Total							\$88,746	

Building: Annex
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Electric less than 50 KW	1st Floor	4	1	EA	\$11,211	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	20,712	SF	\$2,369	
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	20,712	SF	\$3,258	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	20,712	SF	\$3,258	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	6	20,712	SF	\$3,258	
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	20,712	SF	\$3,258	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	20,712	SF	\$4,739	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	20,712	SF	\$4,147	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	20,712	SF	\$3,258	
Piping		Sanitary Piping	Entire Building	6	20,712	SF	\$8,293	
Piping		Storm Piping	Entire Building	6	20,712	SF	\$4,443	
Piping		Vent Piping	Entire Building	6	20,712	SF	\$3,258	
PLUMBING Sub Total							\$54,750	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	511 office	7	180	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	402A teachers lounge	7	143	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	416	7	400	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	413 - Teachers Resource	7	720	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	503 office	7	255	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	503 office	7	255	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	413 - Teachers Resource	7	720	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	416	7	400	SF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	511 office	7	180	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	402A teachers lounge	7	143	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	402A teachers lounge	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	416	7	5	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	413 - Teachers Resource	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	511 office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	503 office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	416	7	600	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	511 office	7	560	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	402A teachers lounge	7	400	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	503 office	7	500	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	413 - Teachers Resource	7	780	SF	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	4	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	4	EA	\$0	
Kitchen	Warming Kitchen	Ceiling - Plaster/Drywall	1st Floor	7	420	SF	\$0	
Kitchen	Warming Kitchen	Flooring - Tile Ceramic/Porcelain	1st Floor	7	420	SF	\$0	
Kitchen	Warming Kitchen	Lighting - Pendant/Surface	1st Floor	7	3	SF	\$0	
Kitchen	Warming Kitchen	Wall - Plaster/Drywall	1st Floor	7	750	SF	\$0	
Library	Library	Casework	408	7	30	LF	\$0	
Library	Library	Ceiling - Splined	408	6	900	SF	\$1,931	
Library	Library	Flooring Carpet	408	6	900	SF	\$1,287	
Library	Library	Lighting - Pendant/ Surface	408	7	6	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl West			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd Fl SouthWest			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st Fl SouthWest			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl West			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls			LF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in room 402			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd Fl SouthWest			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in room 402			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl West			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st Fl SouthWest			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl West			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl West			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl West			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd Fl SouthWest			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st Fl SouthWest			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in room 402			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	1st Floor	7	1,800	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	1,800	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	18	SF	\$0	
Lunchroom	Warming Kitchen	Serving Line	1st Floor			LF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor			LF	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Lunchroom	Wall - Plaster/Drywall	1st Floor	7	1,600	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	2	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Electrical Room	7	190	SF	\$0	
Mechanical/Service Rooms		Storage Room	Entire Building	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl West			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl West			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Fl SouthWest	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Fl SouthWest	7	25	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	in room 402			SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl West	7	104	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st Fl SouthWest	7	25	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st fl West	7	104	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Fl SouthWest	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in room 402			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl West	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st Fl SouthWest			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd Fl SouthWest			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl West	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys			EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st fl West	7	104	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl West	7	104	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd Fl SouthWest	6	25	SF	\$36	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st Fl SouthWest	6	25	SF	\$36	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Hand Dryer	2nd Fl SouthWest			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl West	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st Fl SouthWest			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in room 402			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl West	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st Fl SouthWest	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl West	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl West	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in room 402			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Fl SouthWest	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Fl SouthWest	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st Fl SouthWest	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st fl West	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd fl West	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	in room 402			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl West	7	1	EA	\$0	

Building: Annex
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Partitions	1st fl West	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st Fl SouthWest			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd Fl SouthWest			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd Fl SouthWest			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st Fl SouthWest			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl West			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl West			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in room 402			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st Fl SouthWest	7	140	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Fl SouthWest	7	140	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl West	7	420	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st fl West	7	420	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys			EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Fl SouthWest	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls			EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl West	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl West	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in room 402			EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st Fl SouthWest	7	1	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
INTERIOR Sub Total							\$3,675	

**Building: Annex
Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

**Building: Annex
Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		6	49	LF	\$1,752	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	35	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Casework	Classroom	Casework		7	30	LF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,200	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	720	SF	\$1,544	
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	evidence of leaks
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	staining
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	
Ceiling	Classroom	Splined Ceiling		6	980	SF	\$2,102	
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	evidence of leaks
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	staining
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	
Ceiling	Classroom	Splined Ceiling		6	900	SF	\$1,931	staining
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Lunchroom	Chalk Board	1st Floor	4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Corridors	Corridors	Asphalt	East Stair	7	250	SF	\$0	
Corridors	Corridors	Asphalt	West Stair	7	250	SF	\$0	
Corridors	Corridors	Concrete Block	West Stair	7	1,300	SF	\$0	
Corridors	Corridors	Concrete Block	East Stair	7	1,300	SF	\$0	
Corridors	Corridors	Drinking Fountains	West Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	East Stair			EA	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	6	1,375	SF	\$2,949	
Corridors	Corridors	Drop/Lay-In	1st Floor	6	2,150	SF	\$4,612	
Corridors	Corridors	Lay-In	1st Floor	6	2,150	EA	\$1,537	
Corridors	Corridors	Lay-In	2nd Floor	6	1,375	EA	\$983	
Corridors	Corridors	Pendant/Surface	East Stair	7	2	EA	\$0	
Corridors	Corridors	Pendant/Surface	West Stair	7	2	EA	\$0	
Corridors	Corridors	Plaster/Drywall	2nd Floor	7	2,350	SF	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	7	3,175	SF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	West Stair	7	25	LF	\$0	
Corridors	Corridors	Stair Handrails	East Stair	7	25	LF	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	East Stair			EA	\$0	
Corridors	Corridors	Student Lockers	West Stair			EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	East Stair	7	50	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	West Stair	7	50	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	2,150	SF	\$3,075	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	1,375	SF	\$1,966	
Corridors Ceiling	Corridors	Plaster/Drywall	West Stair	7	200	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	East Stair	7	200	SF	\$0	
Stairs	Corridors	Asphalt	West Stair	7	21	SF	\$0	
Stairs	Corridors	Asphalt	East Stair	7	21	SF	\$0	
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Carpet		6	900	SF	\$1,287	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Carpet		6	1,200	SF	\$1,716	
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Carpet		6	900	SF	\$1,287	
Floor	Classroom	Tile/Sheet		7	980	SF	\$0	
Floor	Classroom	Tile/Sheet		7	720	SF	\$0	
LIBRARY_WALL	Library	Plaster/Drywall	408	7	900		\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	6	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Lunchroom	Marker Board	1st Floor			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	1st fl girls		170	SF	\$0	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	1st fl boys		170	SF	\$0	
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	2nd fl boys		170	SF	\$0	
RESTROOM_CEILING	Early Childhood Student Restroom	Restroom Ceiling	in room 402		25	SF	\$0	
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	2nd fl girls		170	SF	\$0	
RESTROOM_FLOOR	Children's Standard Student Restroom	Restroom Floor	2nd fl girls		170	SF	\$0	
RESTROOM_FLOOR	Children's Standard Student Restroom	Restroom Floor	2nd fl boys		170	SF	\$0	
RESTROOM_FLOOR	Children's Standard Student Restroom	Restroom Floor	1st fl girls		170	SF	\$0	
RESTROOM_FLOOR	Children's Standard Student Restroom	Restroom Floor	1st fl boys		170	SF	\$0	
RESTROOM_FLOOR	Early Childhood Student Restroom	Restroom Floor	in room 402		25	SF	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	1st fl boys			EA	\$0	
RESTROOM_LIGHT	Early Childhood Student Restroom	Restroom Lighting	in room 402			EA	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	1st fl girls			EA	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2nd fl boys			EA	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2nd fl girls			EA	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl girls			SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st fl girls			SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st fl boys			SF	\$0	
RESTROOM_WALL	Early Childhood Student Restroom	Restroom Walls	in room 402			SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl boys			SF	\$0	
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	780	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	

Building: Annex
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	890	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	900	SF	\$0	

ROOM Sub Total \$73,802

Building Annex Sub Total \$1,157,501

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	6	EA	\$0	
Civil/Drainage		Catch Basin	NE and S site	6	3	EA	\$1,630	per engineer: NE lifting with heavy rains, S collapsing
Civil/Drainage		Site Manhole	Entire Site	7	15	EA	\$0	
Fencing		Chain Link	Entire Site	7	523	LF	\$0	
Fencing		Iron and Concrete Post	SW play area	5	111	LF	\$5,556	corroded, bent
Fencing		Ornamental Iron	Entire Site	6	1,063	LF	\$20,065	missing some caps and posts
Landscape		Asphalt Play Area/Hardscape	SW play area	6	2,576	SF	\$2,210	
Landscape		Benches	N of addition and SW playlot	7	7	EA	\$0	
Landscape		Grass	N of addition	6	2,678	SF	\$1,072	no grass
Landscape		Grass	Entire Building	7	11,180	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	14,544	SF	\$0	
Landscape		Hardscape - Concrete	N of main building	5	2,600	SF	\$16,210	cracked, uneven
Landscape		Hardscape - Pavers	S along grass areas	5	228	SF	\$2,129	cracked, broken
Landscape		Parkway trees	Entire Site	7	22	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	883	SF	\$0	
Landscape		Retaining Wall - Concrete	NW of annex and N of parking lot	6	918	SF	\$21,660	
Landscape		Trash Receptacles	N of addition and W of playlot	7	2	EA	\$0	
Parking Lot		Asphalt	site - NE	6	29,714	SF	\$25,495	
Parking Lot		Concrete	NE trash enclosure	7	682	SF	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Concrete Curbs	site - NE	6	253	LF	\$1,527	
Parking Lot		Parking lot interior plantings	site - NE	7	7	LF	\$0	
Parking Lot		Trash Enclosure	site - NE	7	682	SF	\$0	
Parking Lot		Vehicular Screening	Site - East	7	134	LF	\$0	
Playground		Playground Equipment - Pre-K 3-5	site SW	7	1	EA	\$0	
Playground		Playground Equipment - School Age 5-12	site SW	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	site SW	7	4,620	SF	\$0	
Sidewalks		Perimeter Sidewalks	E of building	5	2,490	SF	\$15,525	cracked, uneven
Sidewalks		Perimeter Sidewalks	Entire Site	7	6,747	SF	\$0	
Signage		Flag Pole	Entire Site	7	1	EA	\$0	
SITE Sub Total							\$113,079	
SITE Sub Total							\$113,079	

Total Campus Need ^{2 3} \$6,117,114

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
002	870			30	40	60	24	2	Y	N	N	Classroom		
013	1095			8	40	168	84		N	N	N	Classroom		
023	1095			8	40	168	84		N	N	N	Classroom		
105	850	1	6	20	40	96	54		N	N	Y	Classroom		
106	850	1	6	20	40	138	54		N	Y	Y	Classroom		
107	810	2	10		40	96	48	1	N	N	N	Classroom		
108	815	1	8	24	40	108	60		N	N	Y	Classroom		
110	770	1	8	28	40	108	60		Y	N	Y	Classroom		
112	815	1	8	20	40	142	54	1	N	N	Y	Classroom		
113	815	1	6	20	40	192	108		N	N	N	Classroom		
205	850	1	6	20	40	96	54		N	N	Y	Classroom		
206	850	1	6	20	40	138	54		N	Y	Y	Classroom		
207	770	1	8	28	40	108	60		Y	Y	Y	Classroom		
208	815	1	8	24	40	108	60		N	N	Y	Classroom		
210	770	1	8	28	40	108	60		Y	Y	Y	Classroom		
211	850	1	6	20	40	108	60		N	N	Y	Classroom		
212	815	1	40	62	40	142	54	1	N	Y	N	Classroom		
213	815	1	6	20	40	128	72		N	N	N	Classroom		
305	850	1	6	20	40	96	54		N	N	Y	Classroom		
306	850	1	6	20	40	138	54		N	Y	Y	Classroom		
307	950	1	8	28	40	130	75		N	Y	Y	Classroom		
308	815	1	8	24	40	108	60		N	N	Y	Classroom		
309	770	1	8	28	40	104	60		Y	Y	Y	Classroom		
310	770	1	8	28	40	108	60		Y	Y	Y	Classroom		
311	950	1	8	28	40	130	75		N	Y	Y	Classroom		
312	815	1	6	20	40	158	72		N	N	N	Classroom		
313	815	1	6	20	40	128	72		N	N	N	Classroom		
Other	25								N	N	N	Restroom	Staff Restroom	1st floor east unisex
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys
Other	65								N	N	N	Corridors		East Vestibule
Other									N	N	N	Corridors		West Stair
Other	25								N	N	N	Restroom	Early Childhood Student Restroom	in 402
Other	140								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys
Other	3215								N	N	N	Corridors		1st fl including center stair to basement

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	104								N	N	N	Restroom	Staff Restroom	1st floor west unisex
Other	25								N	N	N	Restroom	Staff Restroom	2nd floor east unisex
Other	290								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls east
Other	2575								N	N	N	Corridors		3rd Floor
Other	390			12					N	N	N	Administrative Suites/Offices		206
Other									N	N	N	Corridors		East Stair
Other	850			8					N	N	Y	Administrative Suites/Offices		Main Office rm 111 FP#109
Other	162			2					N	N	Y	Administrative Suites/Offices		308B
Other	45								N	N	N	Restroom	Staff Restroom	1st fl principals
Other	262			2					N	N	Y	Restroom	Staff Restroom	2nd fl mens
Other	140								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls
Other	700			12					N	N	Y	Administrative Suites/Offices		Principals office, 1st fl mezz
Other	2575								N	N	N	Corridors		2nd Floor
Other	290								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls east
Other	290								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls east
Other	90								N	N	N	Corridors		Center Vestibule
Other	1020			8					N	N	Y	Administrative Suites/Offices		003 counselors office
Other	495			6					N	N	Y	Administrative Suites/Offices		engineers office- basement
Other	100								N	N	N	Corridors		North Vestibule
Other	1162								N	N	N	Corridors		Basement
Other	262			2					N	N	Y	Restroom	Staff Restroom	2nd fl unisex
Other	550			8					N	N	Y	Administrative Suites/Offices		209B- Various Staff Functions
Other	550			10					N	N	Y	Administrative Suites/Offices		209A- Resource
Other	330								N	N	N	Restroom	Children's Standard Student Restroom	basement girls east
Other	262			2					N	N	Y	Restroom	Staff Restroom	1st fl unisex

Building: Addition

101	1065	1	1	6	40	96	48		N	N	Y	Classroom		
103	1065		7	2	40	96	48		N	N	N	Classroom		
204	967		1	10	40	96	48		N	N	Y	Classroom		
301	1065		7	2	40	96	48		N	N	N	Classroom		
303	1065		7	2	40	96	48		N	N	Y	Classroom		
304	1092		8	30	40	128	64		N	N	Y	Classroom		
Other	5031								N	N	N	Gymnasia	Standard Dedicated Gymnasium	3rd Floor
Other	870								N	N	N	Corridors		3rd Floor
Other	99			8					N	N	N	Administrative Suites/Offices		204A
Other	1644								N	N	N	Library		2nd Floor

Room Summary														
Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	384								N	N	N	Restroom	Adult Standard Student Restroom	3rd floor boys
Other	870								N	N	N	Corridors		1st Floor
Other	2200								N	N	N	Corridors		Lower Level Corridor
Other	550								N	N	N	Corridors		auditorium lobby
Other	384								N	N	N	Restroom	Adult Standard Student Restroom	basement boys
Other	192								N	N	N	Corridors		auditorium vestibule
Other	1863								N	N	N	Lunch & Multipurpose Room	Lunchroom	Basement
Other									N	N	N	Corridors		West Stairs
Other									N	N	N	Corridors		North Stairs
Other	4608								N	N	N	Auditorium & Theater	Auditorium - Dedicated	Basement
Other	63								N	N	N	Restroom	Adult Standard Student Restroom	auditorium girls
Other	102								N	N	N	Restroom	Adult Standard Student Restroom	auditorium boys
Other	384								N	N	N	Restroom	Adult Standard Student Restroom	1st floor boys
Other	384								N	N	N	Restroom	Adult Standard Student Restroom	2nd floor boys
Other	104			4					N	N	N	Administrative Suites/Offices		lunchroom office
Other	168								N	N	N	Corridors		1st floor vestibules- N and W

Building: Annex														
401	900			8	40	90			N	N	Y	Classroom		
402	1200			8	40	120	2	1	N	N	N	Classroom		
416	900			8	40	90			N	N	N	Classroom		
501	900			8	40	90			N	N	N	Classroom		
502	900			8	40	90			N	N	N	Classroom		
504	900			8	40	90			N	N	Y	Classroom		
505	900			8	40	90			N	N	Y	Classroom		
506	900			8	40	90	6		N	N	Y	Classroom		
507	900			8	40	90			N	N	Y	Classroom		
508	900			8	40	90			N	N	N	Classroom		
510	720			4	40	90	6		N	N	Y	Classroom		
514	980			12	40	150	8		N	N	Y	Classroom		
Other	400			6					N	N	N	Administrative Suites/Offices		416
Other	900								N	N	N	Library		408
Other	143			6					N	N	N	Administrative Suites/Offices		402A teachers lounge
Other	720			4					N	N	N	Administrative Suites/Offices		413 - Teachers Resource
Other	180			4					N	N	N	Administrative Suites/Offices		511 office
Other	255			4					N	N	N	Administrative Suites/Offices		503 office
Other	2150								N	N	N	Corridors		1st Floor

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	420								N	N	N	Kitchen	Warming Kitchen	1st Floor
Other	1800								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor
Other	25								N	N	N	Restroom	Staff Restroom	2nd Fl SouthWest
Other	104								N	N	N	Restroom	Staff Restroom	1st fl West
Other									N	N	N	Corridors		East Stair
Other	104								N	N	N	Restroom	Staff Restroom	2nd fl West
Other									N	N	N	Corridors		West Stair
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls
Other	170								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys
Other	25								N	N	N	Restroom	Early Childhood Student Restroom	in room 402
Other	1375								N	N	N	Corridors		2nd Floor
Other	25								N	N	N	Restroom	Staff Restroom	1st Fl SouthWest