

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	Entire Building	6	105	SF	\$2,527	
Chimney		Brick Chimney - Concrete/ Mortar Liner	Top section	5	15	LF	\$26,813	
Chimney		Brick Chimney - Concrete/ Mortar Liner	Bottom section	6	60	LF	\$30,030	
Cornice		Cornice - Cast Stone	east 1st story and west 3rd story	5	456	LF	\$80,956	
Cornice		Cornice - Masonry Projecting/Limestone	north elevation, 1st story	6	56	LF	\$1,718	
Cornice		Cornice - Metal Projecting	main entry and 1894 building	6	1,115	LF	\$99,972	
Doors		Exterior Steel Door	Entire Building	7	6	EA	\$0	
Doors		Exterior Wood Door	Entire Building	6	17	EA	\$5,455	
Doors		Transom Lite	Entire Building	6	300	EA	\$84,942	
Entrance		Concrete Exterior Stairs	Entire Building	6	85	LF	\$9,116	
Entrance		Entrance Controls - Audio and Video	Main Entrance	7	1	EA	\$0	
Entrance		Stair Handrails	Entire Building	6	18	LF	\$0	
Fire Escape		Fire Escapes	Entire Building	6	3	LF	\$306	
Foundation		Masonry Foundation	Entire Building	7	27,750	SF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Parapet or Roof Mounted	Parking Lot	5	6	EA	\$8,580	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	6	5	EA	\$2,503	
Lighting		Exterior Lights - Wall Mounted	Entire Building	4	2	EA	\$3,146	
Lighting		Exterior Lights - Wall Mounted	Entire Building	5	15	EA	\$7,508	
Lintels		Lintels - Brick	arches	6	100	LF	\$0	
Lintels		Lintels - Steel	Entire Building	6	450	LF	\$16,988	
Lintels		Lintels - Stone	Entire Building	6	390	LF	\$0	
Lintels		Lintels - Terra Cotta	East Façade	6	40	LF	\$0	
Parapet		Coping - Clay Tile	Entire Building	6	850	LF	\$0	
Parapet		Coping - Metal	north entry and gym at infilled skylight	6	150	LF	\$0	
Parapet		Coping - Stone	roofs b, c, e, f, g, h, i	6	500	LF	\$0	
Parapet		Parapet < 16" Height	east side of C	6	15	LF	\$2,336	
Parapet		Parapet > 30" Height	Entire Building	6	465	LF	\$120,688	
Parapet		Parapet 16" to 30" Height	g, h, i	5	200	LF	\$64,178	
Parapet		Parapet 16" to 30" Height	Entire Building	6	670	LF	\$139,116	
Roof System		Exterior Downspouts	Entire Building	7	420	LF	\$0	
Roof System		Exterior Downspouts	main entry and east 1st story at door 3	4	57	LF	\$10,189	
Roof System		Metal Roof	North Entrances	6	200	SF	\$1,510	
Roof System		Modified Bitumen Roof	Entire Building	5	27,550	SF	\$325,021	
Roof System		Roof Structure: Heavy Timber	Entire Building	7	27,750	SF	\$0	
Superstructure		Heavy Timber	Entire Building	7	75,825	SF	\$0	
Walls		Brick	Entire Building	6	33,250	SF	\$219,669	
Walls		Prefabricated Metal Panel Wall	auditorium skylight	6	900	SF	\$7,645	
Walls		Stone - Cut	Entire Building	6	5,770	SF	\$82,511	
Walls		Terra Cotta	East Façade	6	160	SF	\$4,576	
Windows		Window - Guards wire guard	Entire Building	6	3,040	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	5	9,185	SF	\$317,199	
EXTERIOR Sub Total							\$1,675,198	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Basement	6	1	EA	\$1,430	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	5	12,307	SF	\$15,487	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	5	4,675	SF	\$5,348	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	5	19	EA	\$6,521	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	5	2	EA	\$686	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	2	1	EA	\$541	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	5	3	EA	\$1,030	
Emergency System		Emergency Battery Packs - Toilets	Entire Building	5	7	EA	\$2,402	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	5	24	EA	\$11,154	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	lunchroom	5	2	EA	\$930	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	gym	5	3	EA	\$1,394	
Emergency System		Independent Electrical Service for emergency power	Basement	6	1	EA	\$1,430	
Emergency System		Public Announcement System	1st Floor	5	75,825	SF	\$108,430	
Emergency System		Security System - Intrusion detection	1st Floor	4	75,825	SF	\$303,603	
Main Service		Main Electrical service 2000 to 3000 A 120/208/3PH	Basement	6	1	EA	\$24,310	
Power Distribution		Lighting and power panels	Entire Building	4	14	EA	\$76,076	
Power Distribution		Lighting and power panels	Entire Building	6	4	EA	\$2,860	
Power Distribution		Main distribution panels 400-600 amp	Basement	6	2	EA	\$2,860	
Power Distribution		Main distribution panels 400-600 amp	Basement	4	2	EA	\$24,310	
Power Distribution		Main distribution panels above 600 amp	Basement	6	1	EA	\$2,145	

ELECTRICAL Sub Total \$592,947

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Basement	4	77,600	SF	\$274,091	
Fire Alarm		Fire Pump Controller	Basement	4	1	EA	\$18,590	
Pump Room Assembly		Fire Pump less than 25hp	Basement	4	1	EA	\$26,598	
Sprinkler System		Dry Sprinkler System	Entire Building	4	75,825	SF	\$542,149	
Sprinkler System		Sprinkler Heads	Entire Building	4	75,825	SF	\$37,950	

FIRE PROTECTION Sub Total \$899,378

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Ground Mounted less than 5 tons	MDF Room	5	1	EA	\$3,575	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Basement NE Classroom adjacent to Engineer's Office - 2 ea; 1st Floor - Main Office & Storage	4	4	EA	\$8,580	
Air Conditioning		Window A/C Unit	Entire Building	6	27	EA	\$5,792	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	4	3	EA	\$78,507	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Basement	4	1	EA	\$128,700	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 8,000 to 15,000 cfm	Basement	4	1	EA	\$57,200	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Basement	4	1	EA	\$40,040	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 8,000 to 15,000 cfm	Basement	5	1	EA	\$10,725	
Air Handling Systems		Multi Zone Double Delivery Built Up Air Handling Unit - Steam 15,000 to 30,000 cfm	Basement	4	1	EA	\$114,400	
Air Handling Systems		Multi Zone Double Delivery Built Up Air Handling Unit Auxiliaries - Hot Water or Dual Temperature Water 15,000 to 30,000 cfm	Basement	5	1	EA	\$18,590	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Basement	4	300	LF	\$793,650	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	4	2	EA	\$294,580	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	4	2	EA	\$45,760	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	4	1	EA	\$10,296	
Boiler Systems		Combustion Dampers	Boiler Room	4	2	EA	\$11,154	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	4	1	EA	\$31,460	
Heating Devices		Cabinet Heaters With Electric Coils	basement - teacher's rest room; boiler room; boy's toilet	3	3	EA	\$12,441	not working
Heating Devices		Cabinet Heaters With Electric Coils	MDF Room	2	2	EA	\$8,294	not working
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	6	6	EA	\$3,003	
Heating Devices		Radiators - Steam	Entire Building	4	4	EA	\$5,606	
Heating Devices		Unit Heater - Electric	Boiler Room	4	1	EA	\$5,720	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Basement	5	1	EA	\$9,438	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	4	300	LF	\$29,387	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	4	300	LF	\$35,929	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	1st Floor	4	300	LF	\$35,929	
Temperature Control		Direct Digital Control (DDC) System	Basement	4	75,825	SF	\$759,008	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	5	43	EA	\$23,981	
Temperature Control		Zone Dampers	Basement	5	15	EA	\$5,577	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Temperature Control		Zone Dampers	Basement	5	21	EA	\$7,808	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	2	EA	\$3,003	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	5	4	EA	\$5,148	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Electrical Room	5	1	EA	\$1,030	
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	5	1	EA	\$3,146	
MECHANICAL Sub Total							\$2,607,455	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Boiler Room	5	1	EA	\$17,160	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	4	75,825	SF	\$24,939	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	75,825	SF	\$48,793	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	4	75,825	SF	\$16,264	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	75,825	SF	\$34,698	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	76,825	SF	\$41,747	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	4	75,825	SF	\$181,078	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	4	76,825	SF	\$151,606	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	4	75,825	SF	\$86,744	
Piping		Sanitary Piping	Entire Building	4	75,825	SF	\$72,648	
Piping		Storm Piping	Entire Building	4	75,825	SF	\$54,215	
Piping		Vent Piping	Entire Building	4	75,825	SF	\$43,372	
Pumps		Domestic Booster Pump simplex	Boiler Room	4	1	EA	\$17,160	
Pumps		Sump Pump	Boiler Room	2	1	EA	\$11,869	MISSING SUMP PUMP BEHIND BOILERS
Pumps		Sump Pump	IN AHU-2 AND-3 FAN ROOM	5	1	EA	\$5,148	
PLUMBING Sub Total							\$807,441	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	office in main office	7	182	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Kitchen office/storage used to be mens toilet	7	256	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	1st fl main office	7	594	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	001-Parent Room	7	731	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	006	6	750	SF	\$2,124	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st fl main office	6	594	SF	\$849	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	006	6	750	SF	\$1,073	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	office in main office	7	182	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	001-Parent Room	6	731	SF	\$1,045	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Kitchen office/storage used to be mens tolliet	5	256	SF	\$3,624	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	office in main office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	001-Parent Room	6	14	SF	\$10	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	006	6	14	SF	\$10	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Kitchen office/storage used to be mens tolliet	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st fl main office	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	006	6	1,020	SF	\$2,917	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	office in main office	6	450	SF	\$1,062	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st fl main office	6	1,123	SF	\$2,650	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Kitchen office/storage used to be mens tolliet	6	980	SF	\$2,312	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	001-Parent Room	6	1,000	SF	\$2,360	
Doors		Interior Steel Doors incl hw	Entire Building	6	3	EA	\$849	
Doors		Interior Steel Doors incl hw	Entire Building	7	3	EA	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	5	3	EA	\$1,416	
Doors		Interior Wood Doors incl hw	Entire Building	4	31	EA	\$99,477	
Doors		Interior Wood Doors incl hw	Entire Building	5	38	EA	\$17,932	
Doors		Interior Wood Doors incl hw	Entire Building	6	54	EA	\$15,290	
Doors		Interior Wood Doors incl hw	Entire Building	7	8	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Transom Window	Entire Building	6	740	SF	\$13,757	
Drinking Fountains	Corridors	Double Fountain	1st fl 1911	6	2	EA	\$1,316	
Drinking Fountains	Corridors	Single Fountain	1911 building 2nd floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st fl 1911	6	1	EA	\$386	
Drinking Fountains	Corridors	Single Fountain	1894 bldg 2nd floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1911 building 3rd floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1894 bldg basement	7	2	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1894 bldg 1st floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	1894 bldg 1st floor	6	2,490	SF	\$21,293	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Tile/Sheet	1894 bldg 1st floor	6	2,094	SF	\$2,994	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1894 bldg 1st floor	6	396	SF	\$2,990	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	1894 bldg 1st floor	7	13	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	1894 bldg 1st floor	7	4	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1894 bldg 1st floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1894 bldg 1st floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1894 bldg 1st floor	6	1	EA	\$9,438	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	1894 bldg 1st floor	6	2,528	SF	\$21,690	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	1894 bldg 1st floor	7	371	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	1894 bldg 1st floor	6	1,058	SF	\$7,565	
Kitchen	Warming Kitchen	Ceiling - Lay-In	1st Floor	7	740	SF	\$0	
Kitchen	Warming Kitchen	Flooring - Tile/Sheet	1st Floor	7	740	SF	\$0	
Kitchen	Warming Kitchen	Lighting - Pendant/Surface	1st Floor	7	10	SF	\$0	
Kitchen	Warming Kitchen	Wall - Plaster/Drywall	1st Floor	7	1,370	SF	\$0	
Kitchen	Warming Kitchen	Wall - Structural Glazed Tile	1st Floor	7	100	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl men south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls north			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in 001			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Benches	mens in basement			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	womens locker rm in 006			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd fl ladies south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys south			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in 010- used as storage			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in room 102			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl men south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	womens locker rm in 006	6	23	EA	\$1,129	
Locker/Shower Room	Staff Restroom	Lockers	mens in basement			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in 001			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in 010- used as storage			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in room 102			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd fl ladies south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls south			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys south			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in 010- used as storage			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in room 102			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in 001			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd fl ladies south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl men south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	mens in basement			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	womens locker rm in 006			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls south			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	1st Floor	7	2,185	SF	\$0	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st Floor	7	2,185	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st Floor	7	44	SF	\$0	
Lunchroom	Lunchroom	Serving Line	1st Floor			LF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	1st Floor	6	2,346	SF	\$5,535	
Lunchroom	Lunchroom	Wall - Structural Glazed Tile	1st Floor	7	426	SF	\$0	
MDF/IDF		Finishes	next to boys bathroom 1st fl	6	295	SF	\$1,004	
MDF/IDF		Ventilation and Cooling	next to mens bathroom 1st fl	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	4	SF	\$19	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor 1911	6	3,928	SF	\$18,536	
Mechanical/Service Rooms		Storage Room	basement 1894	6	8,702	SF	\$41,065	
Mechanical/Service Rooms		Storage Room	3rd fl classroom storage	6	990	SF	\$4,672	
Mechanical/Service Rooms		Storage Room	2nd fl classroom storage 1894	6	910	SF	\$4,294	
Mechanical/Service Rooms		Storage Room	1st fl classroom storage 1894	6	615	SF	\$2,902	
Mechanical/Service Rooms		Storage Room	main office storage	7	100	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	womens locker rm in 006	6	500	SF	\$3,861	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Accessories	mens in basement	7	347	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys south	6	255	SF	\$1,969	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls south	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl men south	7	26	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls south	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	in room 102	7	32	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys north	6	140	SF	\$1,081	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls north	6	140	SF	\$1,081	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys south	6	255	SF	\$1,969	
Staff Restroom	Staff Restroom	Accessories	3rd fl ladies south	7	26	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	in 001	6	66	SF	\$510	
Staff Restroom	Early Childhood Student Restroom	Accessories	in 010- used as storage	6	61	SF	\$471	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls south	6	160	SF	\$1,236	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls south	6	160	SF	\$453	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	in 010- used as storage	6	61	SF	\$173	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys south	7	255	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls north	7	140	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys north	7	140	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in room 102	7	32	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls south	6	160	SF	\$453	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl men south	6	26	SF	\$74	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys south	7	255	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	in 001	6	66	SF	\$187	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	mens in basement	6	247	SF	\$699	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls south	6	160	SF	\$453	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd fl ladies south	6	26	SF	\$74	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	womens locker rm in 006	7	500	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls south	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in 010- used as storage	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys south	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in 001	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls north	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys north	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	3rd fl ladies south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in room 102	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl men south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	womens locker rm in 006	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	mens in basement	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	in 010- used as storage	6	61	SF	\$155	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys north	6	140	SF	\$356	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls south	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in room 102	7	32	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls north	6	140	SF	\$356	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys south	7	255	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys south	7	255	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl ladies south	7	26	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls south	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl men south	7	26	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls south	7	160	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	mens in basement	6	247	SF	\$629	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	womens locker rm in 006	6	500	SF	\$1,273	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile/Sheet	in 001	6	66	SF	\$94	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys south	6	2	EA	\$434	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in 001	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	mens in basement	5	1	EA	\$716	
Staff Restroom	Staff Restroom	Hand Dryer	womens locker rm in 006	6	2	EA	\$434	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls south	5	1	EA	\$716	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd fl ladies south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in room 102			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys north	5	2	EA	\$1,433	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls north			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl men south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	mens in basement	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in 010- used as storage			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	mens in basement	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	womens locker rm in 006	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl men south	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	3rd fl ladies south	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	in room 102	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls north	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys north	6	2	EA	\$744	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in 001	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls south	5	1	EA	\$1,859	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in 010- used as storage	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd fl men south	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	mens in basement	6	6	SF	\$4	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	in 001	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl boys south	6	5	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in room 102	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd fl ladies south	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl girls south	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl girls south	7	3	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	in 010- used as storage	6	2	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl boys south	6	5	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls north	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl boys north	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	womens locker rm in 006	6	10	SF	\$7	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls south	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys south	6	2	EA	\$359	
Staff Restroom	Early Childhood Student Restroom	Partitions	in 001			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Partitions	mens in basement	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	womens locker rm in 006	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls south	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl men south			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd fl ladies south			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	in 010- used as storage			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls south	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in room 102			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys south	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl girls south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd fl ladies south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls south			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in 010- used as storage			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys south	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls north			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in room 102			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys south	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	womens locker rm in 006			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	mens in basement	7	3	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in 001			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl men south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd fl men south	6	231	SF	\$545	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl girls south	7	306	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	in 010- used as storage	6	204	SF	\$481	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl boys south	6	339	SF	\$800	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in room 102	7	25	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls north	7	35	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	in 001	6	300	SF	\$708	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl boys north	7	35	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	3rd fl ladies south	6	231	SF	\$545	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls south	7	306	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	womens locker rm in 006	7	774	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	mens in basement	6	320	SF	\$755	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl boys south	6	486	SF	\$1,147	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl girls south	7	179	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl boys north	6	276	SF	\$703	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st fl girls south	6	383	SF	\$975	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl girls north	6	276	SF	\$703	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	in room 102	6	175	SF	\$445	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd fl boys south	6	420	SF	\$1,069	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd fl girls south	6	383	SF	\$975	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl girls south	6	383	SF	\$975	
Staff Restroom	Early Childhood Student Restroom	Wall - Tile Ceramic/ Porcelain	in 010- used as storage	6	238	SF	\$606	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	womens locker rm in 006	7	630	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	mens in basement	6	960	SF	\$2,444	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls south	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in room 102	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd fl ladies south	6	1	EA	\$372	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in 001	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls south	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys south	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in 010- used as storage	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls south	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	womens locker rm in 006	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	mens in basement	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl men south	6	1	EA	\$372	
INTERIOR Sub Total							\$363,963	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	7	LF	\$250	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework		6	5	LF	\$179	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Asphalt	1911 building 3rd floor	5	1,623	SF	\$18,381	
Corridors	Corridors	Asphalt	1911 building 2nd floor	5	1,570	SF	\$17,781	
Corridors	Corridors	Asphalt	1st fl 1911	5	2,704	SF	\$30,624	
Corridors	Corridors	Asphalt	1894 bldg basement	6	1,244	SF	\$1,779	
Corridors	Corridors	Drinking Fountains	1894 bldg stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair North 1911			EA	\$0	
Corridors	Corridors	Drinking Fountains	South 1911			EA	\$0	
Corridors	Corridors	Drinking Fountains	1894 bldg 1st floor			EA	\$0	
Corridors	Corridors	Drinking Fountains	1894 bldg third floor			EA	\$0	
Corridors	Corridors	Drop/Lay-In	1894 bldg 2nd floor	7	25	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1894 bldg 1st floor	6	630	SF	\$1,351	
Corridors	Corridors	Floors	1894 bldg 2nd floor	7	1,040	SF	\$0	
Corridors	Corridors	Floors	1894 bldg third floor	7	1,283	SF	\$0	
Corridors	Corridors	Floors	1894 bldg 1st floor	7	1,370	SF	\$0	
Corridors	Corridors	Pendant/Surface	Stair North 1911	7	288	EA	\$0	
Corridors	Corridors	Pendant/Surface	1894 bldg 2nd floor	6	1,040	EA	\$744	
Corridors	Corridors	Pendant/Surface	1894 bldg 1st floor	7	1,420	EA	\$0	
Corridors	Corridors	Pendant/Surface	1894 bldg third floor	6	1,283	EA	\$917	
Corridors	Corridors	Pendant/Surface	South 1911	7	330	EA	\$0	
Corridors	Corridors	Pendant/Surface	1911 building 2nd floor	7	1,570	EA	\$0	
Corridors	Corridors	Pendant/Surface	1911 building 3rd floor	7	1,623	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st fl 1911	7	2,704	EA	\$0	
Corridors	Corridors	Pendant/Surface	1894 bldg stairs	7	780	EA	\$0	
Corridors	Corridors	Pendant/Surface	1894 bldg basement	6	1,244	EA	\$889	
Corridors	Corridors	Plaster/Drywall	1894 bldg 1st floor	6	3,165	SF	\$7,468	
Corridors	Corridors	Plaster/Drywall	1911 building 3rd floor	6	3,687	SF	\$8,699	
Corridors	Corridors	Plaster/Drywall	Stair North 1911	6	2,460	SF	\$5,804	
Corridors	Corridors	Plaster/Drywall	South 1911	6	2,414	SF	\$5,696	
Corridors	Corridors	Plaster/Drywall	1894 bldg stairs	6	6,504	SF	\$15,346	
Corridors	Corridors	Plaster/Drywall	1st fl 1911	6	4,194	SF	\$9,896	
Corridors	Corridors	Plaster/Drywall	1894 bldg 2nd floor	6	2,590	SF	\$6,111	
Corridors	Corridors	Plaster/Drywall	1894 bldg third floor	6	2,540	SF	\$5,993	
Corridors	Corridors	Plaster/Drywall	1894 bldg basement	6	1,870	SF	\$4,412	
Corridors	Corridors	Plaster/Drywall	1911 building 2nd floor	6	3,980	SF	\$9,391	
Corridors	Corridors	Stair Handrails	Stair North 1911	6	97	LF	\$0	
Corridors	Corridors	Stair Handrails	1911 building 3rd floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st fl 1911			LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stair Handrails	1911 building 2nd floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1894 bldg stairs	6	172	LF	\$0	
Corridors	Corridors	Stair Handrails	1894 bldg 1st floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1894 bldg 2nd floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1894 bldg basement			LF	\$0	
Corridors	Corridors	Stair Handrails	1894 bldg third floor			LF	\$0	
Corridors	Corridors	Stair Handrails	South 1911	6	79	LF	\$0	
Corridors	Corridors	Stairs	1911 building 2nd floor			EA	\$0	
Corridors	Corridors	Stairs	1894 bldg third floor			EA	\$0	
Corridors	Corridors	Stairs	1894 bldg 2nd floor			EA	\$0	
Corridors	Corridors	Stairs	1st fl 1911			EA	\$0	
Corridors	Corridors	Stairs	1894 bldg basement			EA	\$0	
Corridors	Corridors	Stairs	1911 building 3rd floor			EA	\$0	
Corridors	Corridors	Stairs	1894 bldg 1st floor			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	1st fl 1911	6	980	SF	\$7,007	
Corridors	Corridors	Student Lockers	1894 bldg 1st floor			EA	\$0	
Corridors	Corridors	Student Lockers	1894 bldg 2nd floor			EA	\$0	
Corridors	Corridors	Student Lockers	1894 bldg third floor			EA	\$0	
Corridors	Corridors	Student Lockers	1894 bldg stairs			EA	\$0	
Corridors	Corridors	Student Lockers	1st fl 1911			EA	\$0	
Corridors	Corridors	Student Lockers	South 1911			EA	\$0	
Corridors	Corridors	Student Lockers	Stair North 1911			EA	\$0	
Corridors	Corridors	Student Lockers	1911 building 2nd floor			EA	\$0	
Corridors	Corridors	Student Lockers	1911 building 3rd floor			EA	\$0	
Corridors	Corridors	Student Lockers	1894 bldg basement			EA	\$0	
Corridors	Corridors	Walls	1894 bldg basement	6	785	SF	\$1,852	
Corridors Ceiling	Corridors	Plaster/Drywall	1894 bldg stairs	6	780	SF	\$2,208	
Corridors Ceiling	Corridors	Plaster/Drywall	1911 building 2nd floor	5	1,570	SF	\$8,891	
Corridors Ceiling	Corridors	Plaster/Drywall	1911 building 3rd floor	5	1,623	SF	\$9,191	
Corridors Ceiling	Corridors	Plaster/Drywall	1894 bldg basement	6	1,244	SF	\$3,522	
Corridors Ceiling	Corridors	Plaster/Drywall	1894 bldg third floor	5	1,283	SF	\$7,265	
Corridors Ceiling	Corridors	Plaster/Drywall	1894 bldg 2nd floor	6	1,040	SF	\$2,945	
Corridors Ceiling	Corridors	Plaster/Drywall	1894 bldg 1st floor	6	790	SF	\$2,237	
Corridors Ceiling	Corridors	Plaster/Drywall	1st fl 1911	6	2,704	SF	\$7,656	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair North 1911	6	288	SF	\$815	
Corridors Ceiling	Corridors	Plaster/Drywall	South 1911	6	330	SF	\$934	
Stairs	Corridors	Asphalt	1894 bldg stairs	6	260	SF	\$1,859	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Stairs	Corridors	Asphalt	Stair North 1911	5	79	SF	\$3,954	
Stairs	Corridors	Asphalt	South 1911	5	74	SF	\$3,704	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	813	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	813	SF	\$0	
Floor	Classroom	Tile/Sheet		7	813	SF	\$0	
Floor	Classroom	Tile/Sheet		7	813	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	813	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	674	SF	\$5,089	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	800	SF	\$6,040	
Floor	Classroom	Wood		6	800	SF	\$6,040	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	674	SF	\$5,089	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	813	SF	\$6,138	
Floor	Classroom	Wood		6	800	SF	\$6,040	
Floor	Classroom	Wood		6	800	SF	\$6,040	
Floor	Classroom	Wood		6	800	SF	\$6,040	
Floor	Classroom	Wood		6	800	SF	\$6,040	
Floor	Classroom	Wood		6	800	SF	\$6,040	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	21	EA	\$1,502	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Marker Board	Classroom	Marker Board		7	60	LF	\$0	
Marker Board	Classroom	Marker Board		7	60	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	40	LF	\$0	
Marker Board	Classroom	Marker Board		7	39	LF	\$0	
Marker Board	Classroom	Marker Board		7	39	LF	\$0	
Marker Board	Classroom	Marker Board		7	60	LF	\$0	
Marker Board	Classroom	Marker Board		7	39	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Lunchroom	Marker Board	1st Floor	7	6	LF	\$0	
Marker Board	Classroom	Marker Board		7	39	LF	\$0	
Marker Board	Classroom	Marker Board		7	39	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	45	LF	\$0	
Marker Board	Classroom	Marker Board		7	39	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		7	33	LF	\$0	
Marker Board	Classroom	Marker Board		7	41	LF	\$0	
Marker Board	Classroom	Marker Board		7	33	LF	\$0	
Marker Board	Classroom	Marker Board		7	60	LF	\$0	
Marker Board	Classroom	Marker Board		7	11	LF	\$0	
Marker Board	Classroom	Marker Board		7	19	LF	\$0	
Marker Board	Classroom	Marker Board		7	54	LF	\$0	
Marker Board	Classroom	Marker Board		7	17	LF	\$0	
Marker Board	Classroom	Marker Board		7	41	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	60	LF	\$0	
Marker Board	Classroom	Marker Board		7	60	LF	\$0	
Marker Board	Classroom	Marker Board		7	60	LF	\$0	
Marker Board	Classroom	Marker Board		7	60	LF	\$0	
Marker Board	Classroom	Marker Board		7	45	LF	\$0	
Marker Board	Classroom	Marker Board		7	44	LF	\$0	
Marker Board	Classroom	Marker Board		7	11	LF	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2nd fl girls south	7	3	EA	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl boys south	6	420	SF	\$1,069	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,230	SF	\$2,902	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	

**Building: Main
Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,230	SF	\$2,902	
Wall	Classroom	Plaster/Drywall		6	1,400	SF	\$3,303	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
Wall	Classroom	Plaster/Drywall		6	1,270	SF	\$2,997	
Wall	Classroom	Plaster/Drywall		6	1,338	SF	\$3,157	
ROOM Sub Total							\$492,209	
Building Main Sub Total							\$7,438,590	

**Building: Modular
Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	Entire Building	6	320	SF	\$7,701	
Doors		Exterior Steel Door	Entire Building	6	8	EA	\$2,643	
Doors		Side Lite	Entire Building	6	144	EA	\$32,618	
Doors		Transom Lite	Entire Building	6	48	EA	\$13,591	
Entrance		Concrete Exterior Stairs	Entire Building	6	200	LF	\$21,450	
Entrance		Concrete Ramp	Entire Building	7	21	LF	\$0	
Entrance		Ramp Handrails	Entire Building	6	49	LF	\$0	
Entrance		Stair Handrails	Entire Building	6	48	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	10,200	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	4	4	EA	\$6,292	
Parapet		Coping - Metal	Entire Building	6	578	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	100	LF	\$0	
Roof System		Modified Bitumen Roof	Entire Building	4	10,520	SF	\$248,219	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Entire Building	7	10,520	SF	\$0	

Building: Modular
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	20,400	SF	\$0	
Walls		Precast Panel Wall	Entire Building	6	7,920	SF	\$52,324	
Windows		Windows - Casement Lexan	Entire Building	4	3,580	SF	\$412,214	
EXTERIOR Sub Total							\$797,052	

Building: Modular
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	6	1	EA	\$1,430	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	4,055	SF	\$1,740	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	6	700	SF	\$300	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	2	8	EA	\$7,436	no battery back-up
Emergency System		Independent Electrical Service for emergency power	Electrical Room	6	1	EA	\$1,430	
Emergency System		Public Announcement System	1st Floor	6	20,400	SF	\$12,252	
Emergency System		Security System - Intrusion detection	1st Floor	5	20,400	SF	\$33,548	
Main Service		Main Electrical service - Live Front - 2000 A 120/208/3PH	Electrical Room	6	1	EA	\$12,155	
Power Distribution		Lighting and power panels	1st Floor	6	3	EA	\$2,145	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	6	1	EA	\$1,430	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	6	2	EA	\$4,290	
ELECTRICAL Sub Total							\$78,156	

Building: Modular
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Electrical Room	5	20,400	SF	\$44,341	
FIRE PROTECTION Sub Total							\$44,341	

Building: Modular
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	5	9	EA	\$16,731	
Unit Ventilation		Unit Ventilators - Self Contained Electric Heating and Cooling	Entire Building	5	17	EA	\$145,860	
Unit Ventilation		Unit Ventilators - Self Contained Electric Heating and Cooling	Entire Building	4	15	EA	\$257,400	

Building: Modular
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Unit Ventilation		Unit Ventilators - Self Contained Electric Heating and Cooling	2nd Floor - Rooms 509 & 510	3	2	EA	\$34,320	not working
Ventilation		Exhaust Fan - Indoor	Entire Building	4	3	EA	\$16,731	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	1	EA	\$1,502	
MECHANICAL Sub Total							\$472,544	

Building: Modular
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Electric less than 50 KW	1st Floor	5	1	EA	\$5,606	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	5	20,400	SF	\$3,501	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	20,400	SF	\$6,710	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	5	20,400	SF	\$23,338	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	20,400	SF	\$4,376	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	20,400	SF	\$5,251	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	20,400	SF	\$18,087	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	5	20,400	SF	\$10,794	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	20,400	SF	\$11,085	
Piping		Sanitary Piping	Entire Building	5	20,400	SF	\$12,544	
Piping		Storm Piping	Entire Building	5	20,400	SF	\$9,627	
Piping		Vent Piping	Entire Building	5	20,400	SF	\$7,293	
PLUMBING Sub Total							\$118,210	

Building: Modular
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	415	7	40	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	office #2 in 415	7	15	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	staff lounge 416	7	30	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	512	6	370	SF	\$1,048	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	514	7	370	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	office #2 in 415	7	127	SF	\$0	

Building: Modular
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	415	6	350	SF	\$751	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	staff lounge 416	7	245	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	415	7	390	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	514	7	370	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	office #2 in 415	7	142	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	staff lounge 416	7	275	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	512	5	370	SF	\$2,095	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	staff lounge 416	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	415	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	office #2 in 415	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	512	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	514	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	514	5	550	SF	\$2,595	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	415	6	560	SF	\$1,321	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	staff lounge 416	6	550	SF	\$1,298	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	512	6	550	SF	\$1,298	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	office #2 in 415	6	3,755	SF	\$8,860	
Doors		Interior Steel Doors incl hw	Entire Building	6	3	EA	\$849	
Doors		Interior Wood Doors incl hw	513 library	4	2	EA	\$6,418	
Doors		Interior Wood Doors incl hw	Entire Building	6	26	EA	\$7,362	
Doors		Side-lite	Entire Building	6	115	SF	\$2,138	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	6	1	EA	\$386	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	1	EA	\$0	
Library	Library	Ceiling - Splined	513	5	855	SF	\$4,842	

Building: Modular
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Library	Library	Flooring Carpet	513	7	955	SF	\$0	
Library	Library	Lighting - Pendant/ Surface	513	7	15	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor mens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor womens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st floor boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd floor boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor womens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd floor girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st floor boys			EA	\$0	
MDF/IDF		Finishes	417	7	70	SF	\$0	
MDF/IDF		Ventilation and Cooling	417	5	1	EA	\$7,007	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	2	SF	\$9	
Mechanical/Service Rooms		Mechanical/Service Rooms	409	7	50	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	mechanical room 410	7	185	SF	\$0	
Mechanical/Service Rooms		Storage Room	209	6	22	SF	\$104	
Mechanical/Service Rooms		Storage Room	415	7	40	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor womens	7	23	SF	\$0	

Building: Modular
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor boys	7	175	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor boys	7	175	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st floor girls	6	175	SF	\$1,351	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd floor girls	7	175	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor mens	7	23	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor boys	6	175	SF	\$495	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd floor girls	7	175	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor womens	7	23	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor mens	7	23	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor boys	7	175	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st floor girls	7	175	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor girls	7	175	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor boys	6	175	SF	\$445	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor boys	7	175	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st floor girls	6	175	SF	\$445	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor womens	6	23	SF	\$33	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st floor mens	7	23	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor boys			EA	\$0	

Building: Modular
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st floor boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd floor girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd floor boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor womens	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	1st floor mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st floor girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor girls	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor girls	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor womens	6	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st floor mens	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st floor boys	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd floor boys	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st floor girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor girls	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor boys	7	3	EA	\$0	

Building: Modular
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st floor girls	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor mens	7	152	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st floor womens	6	152	SF	\$359	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor boys	7	456	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st floor girls	6	456	SF	\$1,161	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor boys	7	456	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor girls	7	456	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st floor boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd floor girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor womens	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total \$53,046

Building: Modular
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Modular
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	21	LF	\$751	
Ceiling	Classroom	Plaster/Drywall		6	85	SF	\$241	
Ceiling	Classroom	Plaster/Drywall		7	50	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	85	SF	\$241	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	85	SF	\$241	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	85	SF	\$241	
Ceiling	Classroom	Plaster/Drywall		7	85	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	755	SF	\$1,619	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	770	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	

Building: Modular
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		6	406	SF	\$871	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Ceiling	Classroom	Splined Ceiling		7	755	SF	\$0	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Corridors	Corridors	Lay-In	2nd Floor	4	78	EA	\$474	
Corridors	Corridors	Lay-In	1st Floor	4	110	EA	\$669	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	1,393	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	2,164	EA	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	2,744	SF	\$6,474	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	2,635	SF	\$6,217	
Corridors	Corridors	Splined	2nd Floor	7	1,247	SF	\$0	
Corridors	Corridors	Splined	1st Floor	7	1,830	SF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor	6	60	LF	\$0	
Corridors	Corridors	Stairs	1st Floor	7	62	EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	7	1,407	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	2,369	SF	\$0	

Building: Modular
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	7	439	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	539	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	456	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
Floor	Classroom	Tile/Sheet		7	855	SF	\$0	
Floor	Classroom	Tile/Sheet		7	840	SF	\$0	
LIBRARY_CEILING	Library	Plaster/Drywall	513	7	100	SF	\$0	
LIBRARY_WALL	Library	Plaster/Drywall	513	6	836		\$1,973	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	8	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	8	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	4	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	8	EA	\$572	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		4	10	EA	\$3,933	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	9	EA	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Landscape		Asphalt Play Area/Hardscape	Entire Site	6	15,648	SF	\$13,426	
Landscape		Benches	playlot	6	1	EA	\$236	
Landscape		Grass	south of modular	7	2,300	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	4,330	SF	\$0	
Landscape		Parkway trees	Entire Site	7	26	EA	\$0	
Landscape		Trash Receptacles	north side	6	2	EA	\$415	
Parking Lot		Asphalt	SW corner of site	6	5,640	SF	\$4,839	
Parking Lot		Parking lot interior plantings	SW corner of site	7	2	LF	\$0	
Parking Lot		Trash Compactor	south side	6	1	EA	\$3,575	
Parking Lot		Trash Enclosure	south side	7	1,363	SF	\$0	
Playground		Playground Equipment - School Age 5-12	between main building and modular	6	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	between main building and modular	7	3,200	SF	\$0	
Sidewalks		Internal Walks	Entire Site	7	80	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	6	13,368	SF	\$25,233	
Signage		Flag Pole	North Façade	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	NE corner of site	6	1	EA	\$0	
SITE Sub Total							\$65,073	
SITE Sub Total							\$65,073	

Total Campus Need ^{2 3} \$9,126,577

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
010	813	1	8	16	40	121	110	1	N	N	Y	Classroom		
101	800	1	8	24	40	108	96	1	N	N	Y	Classroom		
102	800	1	8	20	40	108	96	1	N	N	Y	Classroom		
104	850	1	8	16	40	100	84	2	N	N	Y	Classroom		
105	800	1	8	24	40	84	72	1	N	N	N	Classroom		
106	674	1	8	21	40	100	86		N	N	N	Classroom		
201	800	1	8	24	40	108	96	1	N	N	Y	Classroom		
202	800	1	8	24	40	108	96	1	N	N	Y	Classroom		
203	800	1	8	20	40	72	48	2	N	N	Y	Classroom		
204	800	1	8	24	40	112	112		N	N	N	Classroom		
205	800	1	8	24	40	84	72	1	N	N	Y	Classroom		
206	674	1	8	21	40	100	86		N	N	N	Classroom		
207	813	1	8	23	40	121	110	1	N	N	Y	Classroom		
208	813	1	8	19	40	121	110	1	N	N	Y	Classroom		
209	813	1	8	23	40	121	110	1	N	N	Y	Classroom		
210	813	1	8	19	40	121	110	1	N	N	Y	Classroom		
211	813	1	8	19	40	121	110	1	N	N	Y	Classroom		
212	813	1	8	19	40	121	110	1	N	N	Y	Classroom		
301	800	1	8	24	40	108	96	1	N	N	Y	Classroom		
302	800	4	8	54	40	108	96	1	N	N	Y	Classroom		
303	800	1	8	20	40	72	48	2	N	N	Y	Classroom		
304	800	1	8	16	40	100	84		N	N	Y	Classroom		
305	800			12	40	84	72	1	N	N	N	Classroom		
306	800		1	10	40	108	96	1	N	N	Y	Classroom		
307	813	1	8	20	40	121	110	1	N	N	N	Classroom		
308	813	1	8	19	40	121	110	1	N	N	N	Classroom		
309	813	1	8	22	40	121	110	1	N	N	N	Classroom		
310	813	1	8	44	40	121	110	1	N	N	N	Classroom		
311	813	1	8	16	40	121	110	1	N	N	N	Classroom		
312	813	1	8	19	40	121	110	1	N	N	Y	Classroom		
Other	140								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys north
Other	32								N	N	N	Restroom	Staff Restroom	in room 102
Other	61								N	N	N	Restroom	Early Childhood Student Restroom	in 010- used as storage
Other	140								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls north
Other	182			6					N	N	Y	Administrative Suites/Offices		office in main office
Other	2185								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st Floor

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	256			4					N	N	Y	Administrative Suites/Offices		Kitchen office/storage used to be mens tolliet
Other	160								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls south
Other	255								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys south
Other	160								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls south
Other	26								N	N	N	Restroom	Staff Restroom	2nd fl men south
Other	26								N	N	N	Restroom	Staff Restroom	3rd fl ladies south
Other	160								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls south
Other	255								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys south
Other	740								N	N	N	Kitchen	Warming Kitchen	1st Floor
Other	1244								N	N	N	Corridors		1894 bldg basement
Other	594			10					N	N	Y	Administrative Suites/Offices		1st fl main office
Other	2704								N	N	N	Corridors		1st fl 1911
Other	330								N	N	N	Corridors		South 1911
Other	288								N	N	N	Corridors		Stair North 1911
Other	1570								N	N	N	Corridors		1911 building 2nd floor
Other	1623								N	N	N	Corridors		1911 building 3rd floor
Other	66								N	N	N	Restroom	Early Childhood Student Restroom	in 001
Other	780								N	N	N	Corridors		1894 bldg stairs
Other	1283								N	N	N	Corridors		1894 bldg third floor
Other	247								N	N	N	Restroom	Staff Restroom	mens in basement
Other	1040								N	N	N	Corridors		1894 bldg 2nd floor
Other	1370								N	N	N	Corridors		1894 bldg 1st floor
Other	2490								N	N	N	Gymnasia	Standard Dedicated Gymnasium	1st Floor
Other	500								N	N	N	Restroom	Staff Restroom	womens locker rm in 006
Other	750			9					N	N	Y	Administrative Suites/Offices		006
Other	731			6					N	N	Y	Administrative Suites/Offices		001-Parent Room

Building: Modular

401	855	1	1	6	40	150			N	N	Y	Classroom		
402	840	1	1	6	40	150			N	N	Y	Classroom		
403	840	1	1	6	40	150			N	N	Y	Classroom		
404	840	1	1	6	40	150			N	N	Y	Classroom		
411	456		1	6	40	100			N	N	N	Classroom		
413	840	1	1	6	40	150			N	N	Y	Classroom		
414	840	1	1	6	40	150			N	N	Y	Classroom		
501	840		1	6	40	150			N	N	Y	Classroom		
502	840		1	6	40	150			N	N	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
503	840		1	6	40	150			N	N	Y	Classroom		
504	840		1	6	40	150			N	N	Y	Classroom		
509	840		1	6	40	150			N	N	Y	Classroom		
510	840		1	6	40	150			N	N	Y	Classroom		
511	840		1	6	40	150			N	N	Y	Classroom		
Other	175								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor boys
Other	175								N	N	N	Restroom	Children's Standard Student Restroom	1st floor girls
Other	175								N	N	N	Restroom	Children's Standard Student Restroom	1st floor boys
Other	370			6					N	N	Y	Administrative Suites/Offices		512
Other	175								N	N	N	Restroom	Children's Standard Student Restroom	2nd floor girls
Other	23								N	N	N	Restroom	Staff Restroom	1st floor womens
Other	390			8					N	N	Y	Administrative Suites/Offices		415
Other	1407								N	N	N	Corridors		2nd Floor
Other	2369								N	N	N	Corridors		1st Floor
Other	370			6					N	N	Y	Administrative Suites/Offices		514
Other	955								N	N	N	Library		513
Other	142			6					N	N	Y	Administrative Suites/Offices		office #2 in 415
Other	23								N	N	N	Restroom	Staff Restroom	1st floor mens
Other	275			6					N	N	Y	Administrative Suites/Offices		staff lounge 416