

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------|-----------|-------------------------------------|-------------------------------|------|----------|------|---------|---|
| Canopy | | Concrete/ Stucco Canopy | door 1 - 3 | 7 | 1,051 | SF | \$0 | |
| Chimney | | Metal Flue | upper roof | 6 | 10 | LF | \$644 | corrosion |
| Doors | | Exterior Steel Door | Entire Building | 6 | 17 | EA | \$5,616 | |
| Doors | | Exterior Steel Door | S doors leading into basement | 4 | 2 | EA | \$6,607 | major corrosion and deterioration |
| Doors | | Side Lite | doors 1-6 | 6 | 7 | EA | \$1,586 | |
| Doors | | Transom Lite | doors 1-6, roof door, S door | 6 | 16 | EA | \$4,530 | |
| Entrance | | Concrete Exterior Stairs | S leading to basement | 6 | 52 | LF | \$5,577 | |
| Entrance | | Entrance Controls - Audio and Video | door 1 - North | 6 | 1 | EA | \$1,430 | per engineer: in colder temperatures it doesn't work well |
| Entrance | | Stair Handrails | S leading to basement | 6 | 50 | LF | \$0 | corroding and paint dripping |
| Foundation | | Concrete Foundation | Entire Building | 7 | 827 | LF | \$0 | |
| Lighting | | Exterior Lights - Wall Mounted | Entire Building | 7 | 4 | EA | \$0 | |

Building: Main
Category: EXTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------------------|-----------|---|-----------------------------------|------|----------|------|------------------|---|
| Lintels | | Lintels - Steel | Entire Building | 6 | 1,285 | LF | \$48,511 | |
| Parapet | | Coping - Metal | Entire Building | 7 | 1,163 | LF | \$0 | |
| Roof System | | EPDM/ Synthetic Rubber Roof | SE and SW corner, S lower roof | 5 | 75 | SF | \$644 | ponding |
| Roof System | | EPDM/ Synthetic Rubber Roof | Roof | 6 | 28,226 | SF | \$141,271 | leaks reported above boiler room and in room 302 |
| Roof System | | Interior Downspouts | Entire Building | 6 | 496 | LF | \$0 | |
| Roof System | | Roof Structure: Steel/Metal Deck/Concrete Topping | Roof | 7 | 28,722 | SF | \$0 | |
| Superstructure | | Metal Deck/Concrete Topping | Entire Building | 7 | 75,558 | SF | \$0 | |
| Walls | | Precast Panel Wall | Entire Building | 6 | 16,188 | SF | \$106,948 | |
| Walls | | Precast Panel Wall | entire building including columns | 6 | 6,502 | SF | \$42,956 | chipping paint and raised planting beds with minor hairline cracks throughout |
| Windows | | Curtain wall - Glazed Double Pane | Entire Building | 7 | 9,522 | SF | \$0 | |
| Windows | | Curtain wall - Glazed Double Pane | Entire Building | 7 | 1,017 | SF | \$0 | |
| Windows | | Windows - Decorative | West Façade | 7 | 100 | SF | \$0 | |
| EXTERIOR Sub Total | | | | | | | \$366,318 | |

Building: Main
Category: ELECTRICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------|-----------|--|-----------------|------|----------|------|-------|--------|
| Emergency System | | Automatic Transfer switch | Electrical Room | 7 | 1 | EA | \$0 | |
| Emergency System | | Emergency A/C power - Corridors and Stairs | Entire Building | 7 | 15,803 | SF | \$0 | |
| Emergency System | | Emergency A/C power - Gym and Lunch rooms | Entire Building | 7 | 9,591 | SF | \$0 | |
| Emergency System | | Emergency A/C power - Students Toilets | Entire Building | 7 | 1,803 | SF | \$0 | |
| Emergency System | | Emergency Battery Packs - Corridors and Stairs | 1st Floor | 7 | 4 | EA | \$0 | |
| Emergency System | | Emergency Battery Packs - Corridors and Stairs | 3rd Floor | 7 | 5 | EA | \$0 | |
| Emergency System | | Emergency Battery Packs - Corridors and Stairs | 2nd Floor | 7 | 7 | EA | \$0 | |
| Emergency System | | Emergency Battery Packs - Lunchroom and Gym | 2nd Floor | 7 | 4 | EA | \$0 | |
| Emergency System | | Emergency Battery Packs - Lunchroom and Gym | 1st Floor | 7 | 1 | EA | \$0 | |
| Emergency System | | Emergency Battery Packs - Toilets | 3rd Floor | 7 | 2 | EA | \$0 | |
| Emergency System | | Emergency Battery Packs - Toilets | 2nd Floor | 7 | 6 | EA | \$0 | |
| Emergency System | | Emergency Battery Packs - Toilets | 1st Floor | 7 | 4 | EA | \$0 | |
| Emergency System | | Exit Signs - Corridors and Stairs | 3rd Floor | 6 | 2 | EA | \$466 | |
| Emergency System | | Exit Signs - Corridors and Stairs | 3rd Floor | 7 | 2 | EA | \$0 | |
| Emergency System | | Exit Signs - Corridors and Stairs | 2nd Floor | 7 | 4 | EA | \$0 | |
| Emergency System | | Exit Signs - Corridors and Stairs | 1st Floor | 7 | 9 | EA | \$0 | |

Building: Main
Category: ELECTRICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------------|-----------|--|-----------------|------|----------|------|------------------|--------|
| Emergency System | | Exit Signs - Lunchroom - Gym - multipurpose rooms | 1st Floor | 7 | 2 | EA | \$0 | |
| Emergency System | | Exit Signs - Lunchroom - Gym - multipurpose rooms | 2nd Floor | 6 | 4 | EA | \$932 | |
| Emergency System | | Independent Electrical Service for emergency power | Electrical Room | 7 | 1 | EA | \$0 | |
| Emergency System | | Public Announcement System | Main Office | 6 | 75,558 | SF | \$45,380 | |
| Emergency System | | Security System - CCTV | Main Office | 4 | 75,558 | SF | \$540,240 | |
| Emergency System | | Security System - Intrusion detection | Main Office | 7 | 75,558 | SF | \$0 | |
| Main Service | | Main Electrical service 2000 to 3000 A 120/208/3PH | Electrical Room | 7 | 1 | EA | \$0 | |
| Power Distribution | | Lighting and power panels | 1st Floor | 7 | 1 | EA | \$0 | |
| Power Distribution | | Lighting and power panels | Boiler Room | 7 | 4 | EA | \$0 | |
| Power Distribution | | Lighting and power panels | Electrical Room | 7 | 3 | EA | \$0 | |
| Power Distribution | | Lighting and power panels | Fire Alarm Room | 7 | 4 | EA | \$0 | |
| Power Distribution | | Lighting and power panels | 2nd Floor | 7 | 6 | EA | \$0 | |
| Power Distribution | | Lighting and power panels | 3rd Floor | 7 | 3 | EA | \$0 | |
| Power Distribution | | Main distribution panels above 600 amp | Electrical Room | 7 | 4 | EA | \$0 | |
| ELECTRICAL Sub Total | | | | | | | \$587,018 | |

Building: Main
Category: FIRE PROTECTION

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------------------------|-----------|--------------------------|-----------------|------|----------|------|----------------|--------|
| Fire Alarm | | Fire Alarm Strobe Lights | Entire Building | 7 | 75,558 | SF | \$0 | |
| Fire Alarm | | Fire Alarm System | Fire Alarm Room | 7 | 75,558 | SF | \$0 | |
| Fire Alarm | | Fire Pump Controller | Basement | 7 | 1 | EA | \$0 | |
| Pump Room Assembly | | Fire Pump 25-50hp | Basement | 6 | 1 | EA | \$3,718 | |
| Sprinkler System | | Sprinkler Heads | Entire Building | 7 | 75,558 | SF | \$0 | |
| Sprinkler System | | Wet Sprinkler System | Basement | 7 | 75,558 | SF | \$0 | |
| FIRE PROTECTION Sub Total | | | | | | | \$3,718 | |

Building: Main
Category: MECHANICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------------|-----------|---|-----------|------|----------|------|----------|--------|
| Air Conditioning | | Condensing Unit - Roof Mounted greater than 50 tons | Roof | 5 | 1 | EA | \$28,600 | |
| Air Conditioning | | Condensing Unit - Roof Mounted greater than 50 tons | Roof | 5 | 2 | EA | \$57,200 | |
| Air Handling Systems | | Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm | Penthouse | 5 | 1 | EA | \$57,200 | |

Building: Main
Category: MECHANICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------------|-----------|--|----------------------|------|----------|------|-----------|--------|
| Air Handling Systems | | Air Handling Unit Package - Multi Zone - Hot Water above 30,000 cfm | Boiler Room | 5 | 1 | EA | \$100,100 | |
| Air Handling Systems | | Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm | Penthouse | 5 | 1 | EA | \$21,450 | |
| Air Handling Systems | | Air intake for all Air Handling Units except built up AHU | Penthouse Wall | 7 | 1 | EA | \$0 | |
| Air Handling Systems | | Air intake for all Air Handling Units except built up AHU | North 3rd Floor Wall | 7 | 1 | EA | \$0 | |
| Air Handling Systems | | Make Up Air Unit - Indoor Mounted - Hot Water less than 6000 cfm | Penthouse | 6 | 1 | EA | \$2,002 | |
| Air Handling Systems | | Roof Top Unit - Single Zone - Electric 11 to 20 tons | Roof | 6 | 2 | EA | \$8,580 | |
| Boiler Systems | | Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler 2,001MBH-3,000 MBH | Boiler Room | 5 | 2 | EA | \$102,960 | |
| Boiler Systems | | Boiler Auxiliary Non-Condensing Hot Water Boiler 2,001MBH-3,000 MBH | Boiler Room | 5 | 2 | EA | \$55,770 | |
| Boiler Systems | | Chemical Pot Feeder - Hot Water | Boiler Room | 6 | 1 | EA | \$300 | |
| Boiler Systems | | Combustion Dampers | Boiler Room | 7 | 1 | EA | \$0 | |
| Boiler Systems | | Glycol Feed System | Boiler Room | 6 | 1 | EA | \$1,087 | |
| Heating Devices | | Cabinet Heaters With Hot Water Coils | Basement | 6 | 6 | EA | \$3,003 | |
| Heating Devices | | Fin Tube Hot Water | Basement | 7 | 120 | LF | \$0 | |
| Heating Devices | | Fin Tube Hot Water | 3rd Floor | 6 | 68 | LF | \$1,167 | |
| Heating Devices | | Fin Tube Hot Water | 2nd Floor | 6 | 74 | LF | \$1,270 | |
| Heating Devices | | Fin Tube Hot Water | 1st Floor | 6 | 356 | LF | \$6,109 | |
| Heating Devices | | Fin Tube Hot Water | 2nd Floor | 7 | 36 | LF | \$0 | |
| Heating Devices | | Unit Heater - Hot Water | Penthouse | 6 | 1 | EA | \$1,430 | |
| Heating Devices | | Unit Heater - Hot Water | Basement | 6 | 1 | EA | \$1,430 | |
| Mechanical Plumbing | | Piping - Hydronic Supply and Return - Copper | Entire Building | 7 | 800 | LF | \$0 | |
| Mechanical Plumbing | | Pumps - Hot Water 11 to 20 HP | Boiler Room | 7 | 2 | EA | \$0 | |
| Mechanical Plumbing | | Pumps - Hot Water 5 to 10 HP | Boiler Room | 6 | 2 | EA | \$4,004 | |
| Mechanical Plumbing | | Pumps - Hot Water 5 to 10 HP | Penthouse | 5 | 2 | EA | \$17,160 | |
| Mechanical Plumbing | | Pumps - Hot Water 5 to 10 HP | Boiler Room | 5 | 1 | EA | \$8,580 | |
| Temperature Control | | Pneumatic System | Boiler Room | 5 | 75,558 | SF | \$324,144 | |
| Temperature Control | | Thermostats - Pneumatic | 1st Floor | 7 | 12 | EA | \$0 | |
| Temperature Control | | Thermostats - Pneumatic | 3rd Floor | 7 | 16 | EA | \$0 | |
| Temperature Control | | Thermostats - Pneumatic | 2nd Floor | 7 | 17 | EA | \$0 | |
| Temperature Control | | Thermostats - Pneumatic | Electrical Room | 7 | 1 | EA | \$0 | |
| Ventilation | | Exhaust Fan - Indoor | Penthouse | 5 | 3 | EA | \$5,577 | |
| Ventilation | | Exhaust Fan - Indoor | Boiler Room | 5 | 1 | EA | \$1,859 | |
| Ventilation | | Exhaust Fan - Indoor | Basement | 6 | 1 | EA | \$501 | |

Building: Main
Category: MECHANICAL

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------------|-----------|--|-----------|------|----------|------|------------------|--------|
| Ventilation | | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm | Roof | 5 | 3 | EA | \$4,505 | |
| Ventilation | | Type I Exhaust Hood - Kitchen or Culinary Arts | 1st Floor | 6 | 1 | EA | \$1,716 | |
| MECHANICAL Sub Total | | | | | | | \$817,703 | |

Building: Main
Category: PLUMBING

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------------------|-----------|--|-----------------|------|----------|------|-----------------|--------|
| Hot Water | | Hot Water Heater - Gas more than 300,000 BTU/HR | Basement | 6 | 2 | EA | \$13,442 | |
| Hot Water | | Storage Tank less than 500 gallons | Basement | 6 | 1 | EA | \$1,859 | |
| Piping | | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Domestic Piping - Cold Water Risers | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Domestic Piping - Hot Water from Riser to fixtures | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Domestic Piping - Hot Water Return Risers | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Domestic Piping - Hot Water Risers | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Domestic Piping Cold Water Horizontal lines | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Domestic Piping Hot Water Horizontal lines | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Domestic Piping Hot Water Return Lines | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Sanitary Piping | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Storm Piping | Entire Building | 7 | 75,558 | SF | \$0 | |
| Piping | | Vent Piping | Entire Building | 7 | 75,558 | SF | \$0 | |
| Pumps | | Domestic Booster Pump duplex | Basement | 5 | 1 | EA | \$15,730 | |
| Pumps | | Sump Pump | Basement | 6 | 5 | EA | \$6,793 | |
| PLUMBING Sub Total | | | | | | | \$37,824 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|------------------|---------------------------------------|------|----------|------|-------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Main Office Workroom | 6 | 220 | SF | \$472 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 305 language lab/office | 6 | 398 | SF | \$854 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 313 Science office | 6 | 214 | SF | \$459 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Main Office Conference Room | 6 | 177 | SF | \$380 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Engineer's Office | 6 | 194 | SF | \$416 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|---------------------------|--|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Assistant Principal's Office 1st Floor Room 161 | 6 | 161 | SF | \$345 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 205 language lab/office | 6 | 398 | SF | \$854 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Principal's Office | 6 | 172 | SF | \$369 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Faculty Lounge | 6 | 890 | SF | \$1,909 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Main Office | 6 | 743 | SF | \$1,594 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Assistant Principal's Office 1st Floor Room 161 | 6 | 161 | SF | \$345 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Parent Resource Room 1st Floor | 5 | 257 | SF | \$1,455 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 2nd Floor Gym Office | 5 | 163 | SF | \$923 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | CPS Support Office in Library | 6 | 327 | SF | \$701 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 2nd Floor Workroom 213 | 6 | 401 | SF | \$860 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | 1st Floor Counselor's Office Room 111 | 6 | 244 | SF | \$523 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 1st Floor Faculty Lounge | 6 | 134 | SF | \$379 | |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Plaster/Drywall | 1st Floor Kitchen Office | 6 | 136 | SF | \$385 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Principal's Office | 6 | 172 | SF | \$246 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 205 language lab/office | 6 | 398 | SF | \$569 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Faculty Lounge | 6 | 1,024 | SF | \$1,464 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Main Office Conference Room | 6 | 177 | SF | \$253 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Counselor's Office Room 111 | 6 | 244 | SF | \$349 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Main Office | 6 | 551 | SF | \$788 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | Assistant Principal's Office 1st Floor Room 161 | 6 | 161 | SF | \$230 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | Parent Resource Room 1st Floor | 6 | 257 | SF | \$368 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 1st Floor Engineer's Office | 6 | 194 | SF | \$277 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|-----------------------|--|------|----------|------|-------|--------|
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | 305 language lab/office | 7 | 398 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Carpet | Assistant Principal's Office 1st Floor Room 161 | 6 | 161 | SF | \$230 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 2nd Floor Gym Office | 6 | 163 | SF | \$233 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Kitchen Office | 6 | 136 | SF | \$194 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Main Office Workroom | 6 | 220 | SF | \$315 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 2nd Floor Workroom 213 | 6 | 401 | SF | \$573 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 1st Floor Main Office | 7 | 192 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | 313 Science office | 7 | 214 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet | CPS Support Office in Library | 7 | 327 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 313 Science office | 7 | 4 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Kitchen Office | 6 | 2 | SF | \$1 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Engineer's Office | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Main Office Conference Room | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Assistant Principal's Office 1st Floor Room 161 | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Faculty Lounge | 6 | 12 | SF | \$9 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Principal's Office | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Counselor's Office Room 111 | 6 | 4 | SF | \$3 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Main Office Workroom | 6 | 4 | SF | \$3 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 2nd Floor Workroom 213 | 6 | 6 | SF | \$4 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | CPS Support Office in Library | 6 | 4 | SF | \$3 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 2nd Floor Gym Office | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Parent Resource Room 1st Floor | 6 | 4 | SF | \$3 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|------------------------------|--|------|----------|------|----------|--------|
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | Assistant Principal's Office 1st Floor Room 161 | 6 | 3 | SF | \$2 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In | 1st Floor Main Office | 6 | 13 | SF | \$9 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 205 language lab/office | 7 | 6 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | 305 language lab/office | 7 | 6 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 305 language lab/office | 7 | 661 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Counselor's Office Room 111 | 6 | 491 | SF | \$1,159 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | CPS Support Office in Library | 6 | 605 | SF | \$1,427 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 2nd Floor Gym Office | 6 | 438 | SF | \$1,033 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Parent Resource Room 1st Floor | 6 | 575 | SF | \$1,357 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Assistant Principal's Office 1st Floor Room 161 | 6 | 380 | SF | \$897 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Main Office | 6 | 702 | SF | \$1,656 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Main Office Workroom | 6 | 512 | SF | \$1,208 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Main Office Conference Room | 6 | 283 | SF | \$668 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Faculty Lounge | 6 | 1,007 | SF | \$2,376 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Engineer's Office | 6 | 428 | SF | \$1,010 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 2nd Floor Workroom 213 | 6 | 549 | SF | \$1,295 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 313 Science office | 7 | 485 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Principal's Office | 6 | 417 | SF | \$984 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 205 language lab/office | 7 | 661 | SF | \$0 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | 1st Floor Kitchen Office | 6 | 374 | SF | \$882 | |
| Administrative Suites | Administrative Suites/Offices | Walls - Plaster/Drywall | Assistant Principal's Office 1st Floor Room 161 | 6 | 380 | SF | \$897 | |
| Doors | | Interior Steel Doors incl hw | Entire Building | 6 | 25 | EA | \$7,079 | |
| Doors | | Interior Wood Doors incl hw | Entire Building | 6 | 92 | EA | \$26,049 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|------------------------|--------------------------------------|-----------------------------------|--------------------------|------|----------|------|----------|--------|
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Bleacher Seating | 2nd Floor | 6 | 40 | EA | \$967 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Ceiling - Exposed | 2nd Floor | 6 | 5,188 | SF | \$39,468 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Flooring - Tile/Sheet | 2nd Floor | 6 | 5,188 | SF | \$7,419 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Lighting - Pendant/Surface | 2nd Floor | 6 | 10 | EA | \$1,216 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Scoreboards | 2nd Floor | 6 | 1 | EA | \$2,076 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Sound System | 2nd Floor | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Stage Curtain | 2nd Floor | | | EA | \$0 | |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium | Walls - Plaster/Drywall | 2nd Floor | 6 | 7,442 | SF | \$63,852 | |
| Kitchen | Warming Kitchen | Ceiling - Plaster/Drywall | Serving Room | 6 | 437 | SF | \$1,650 | |
| Kitchen | Cooking Kitchen | Ceiling - Plaster/Drywall | Dishwashing Room | 6 | 117 | SF | \$442 | |
| Kitchen | Cooking Kitchen | Ceiling - Plaster/Drywall | 1st Floor | 6 | 753 | SF | \$2,843 | |
| Kitchen | Cooking Kitchen | Flooring - Tile Ceramic/Porcelain | Dishwashing Room | 6 | 117 | SF | \$298 | |
| Kitchen | Cooking Kitchen | Flooring - Tile Ceramic/Porcelain | 1st Floor | 6 | 753 | SF | \$1,917 | |
| Kitchen | Warming Kitchen | Flooring - Tile Ceramic/Porcelain | Serving Room | 6 | 437 | SF | \$1,112 | |
| Kitchen | Cooking Kitchen | Lighting - Lay-In | 1st Floor | 6 | 12 | SF | \$9 | |
| Kitchen | Cooking Kitchen | Lighting - Lay-In | Dishwashing Room | 6 | 2 | SF | \$1 | |
| Kitchen | Warming Kitchen | Lighting - Lay-In | Serving Room | 6 | 6 | SF | \$4 | |
| Kitchen | Warming Kitchen | Wall - Plaster/Drywall | Serving Room | 6 | 460 | SF | \$1,085 | |
| Kitchen | Cooking Kitchen | Wall - Plaster/Drywall | Dishwashing Room | 6 | 349 | SF | \$823 | |
| Kitchen | Cooking Kitchen | Wall - Plaster/Drywall | 1st Floor | 6 | 783 | SF | \$1,847 | |
| Library | Library | Casework | 2nd Floor | 6 | 184 | LF | \$5,644 | |
| Library | Library | Flooring Carpet | 2nd Floor | 6 | 1,514 | SF | \$2,165 | |
| Library | Library | Flooring Tile/ Sheet | 2nd Floor | 7 | 598 | SF | \$0 | |
| Library | Library | Lighting - Lay-In | 2nd Floor | 6 | 30 | SF | \$21 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 3rd floor Girls | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 1st Floor in Main Office | | | LF | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Benches | In Room 119 | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 3rd floor Girls | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 1st Floor Women's | | | LF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------|--------------------------------------|---------|--------------------------------------|------|----------|------|------|--------|
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 2nd floor boys | | | LF | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Benches | 118 | | | LF | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Benches | 120 | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 2nd Floor Boys | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 3rd floor boys | | | LF | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Benches | In Room 117 | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 3rd floor Women | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 2nd Floor Women's Locker Room at Gym | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 2nd Floor Girls | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 1st Floor Women's Locker Room | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 1st Floor Men's Locker Room | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 1st Floor Shower at Locker Room | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 2nd Women's Student Locker | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 3rd floor Men | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Benches | 2nd Floor Men's Locker Room at Gym | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 1st Floor in Faculty Lounge | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 1st floor girls | | | LF | \$0 | |
| Locker/Shower Room | Staff Restroom | Benches | 1st Floor Mens | | | LF | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Benches | 1st floor boys | | | LF | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 2nd Floor Women's Locker Room at Gym | 7 | 33 | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 2nd Women's Student Locker | | | EA | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Lockers | In Room 117 | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 1st Floor in Main Office | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 1st Floor Women's Locker Room | 7 | 8 | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------|--------------------------------------|---------|------------------------------------|------|----------|------|------|--------|
| Locker/Shower Room | Early Childhood Student Restroom | Lockers | In Room 119 | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 1st Floor Shower at Locker Room | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 1st floor boys | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 2nd Floor Men's Locker Room at Gym | 7 | 33 | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 3rd floor Girls | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Lockers | 1st Floor Men's Locker Room | 7 | 8 | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 2nd floor boys | | | EA | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Lockers | 118 | | | EA | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Lockers | 120 | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 3rd floor Women | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 1st Floor in Faculty Lounge | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 1st floor girls | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 1st Floor Women's | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 2nd Floor Girls | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 2nd Floor Boys | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 1st Floor Mens | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 3rd floor boys | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Lockers | 3rd floor Girls | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Lockers | 3rd floor Men | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 1st Floor in Faculty Lounge | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 1st floor girls | | | EA | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Showers | 120 | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 3rd floor Girls | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 1st floor boys | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 3rd floor Men | | | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------|--------------------------------------|------------------------|--------------------------------------|------|----------|------|---------|--------|
| Locker/Shower Room | Locker/Shower Room | Showers | 1st Floor Shower at Locker Room | 6 | 1 | EA | \$243 | |
| Locker/Shower Room | Locker/Shower Room | Showers | 1st Floor Men's Locker Room | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Showers | 1st Floor Women's Locker Room | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 2nd floor boys | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 3rd floor Girls | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 3rd floor boys | | | EA | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Showers | 118 | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 1st Floor Mens | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 3rd floor Women | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Showers | 2nd Floor Women's Locker Room at Gym | 6 | 4 | EA | \$972 | |
| Locker/Shower Room | Early Childhood Student Restroom | Showers | In Room 119 | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 2nd Floor Girls | | | EA | \$0 | |
| Locker/Shower Room | Children's Standard Student Restroom | Showers | 2nd Floor Boys | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Showers | 2nd Women's Student Locker | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 1st Floor Women's | | | EA | \$0 | |
| Locker/Shower Room | Staff Restroom | Showers | 1st Floor in Main Office | | | EA | \$0 | |
| Locker/Shower Room | Early Childhood Student Restroom | Showers | In Room 117 | | | EA | \$0 | |
| Locker/Shower Room | Locker/Shower Room | Showers | 2nd Floor Men's Locker Room at Gym | 6 | 4 | EA | \$972 | |
| Lunchroom | Multipurpose Room | Ceiling - Lay-In | Rooms 114 and 116 | 6 | 4,403 | SF | \$9,444 | |
| Lunchroom | Multipurpose Room | Flooring - Wood | Rooms 114 and 116 | 6 | 441 | SF | \$3,330 | |
| Lunchroom | Multipurpose Room | Lighting - Lay-In | Rooms 114 and 116 | 6 | 63 | SF | \$45 | |
| Lunchroom | Cooking Kitchen | Serving Line | 1st Floor | | | LF | \$0 | |
| Lunchroom | Warming Kitchen | Serving Line | Serving Room | 7 | 48 | LF | \$0 | |
| Lunchroom | Cooking Kitchen | Serving Line | Dishwashing Room | | | LF | \$0 | |
| Lunchroom | Multipurpose Room | Serving Line | Rooms 114 and 116 | | | LF | \$0 | |
| Lunchroom | Multipurpose Room | Wall - Plaster/Drywall | Rooms 114 and 116 | 6 | 2,668 | SF | \$6,295 | |
| Lunchroom | Multipurpose Room | Wall - Plaster/Drywall | Rooms 114 and 116 | 6 | 2,668 | SF | \$6,295 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------------------|--------------------------------------|--------------------------|--------------------------------|------|----------|------|----------|--------|
| MDF/IDF | | Finishes | library | 6 | 243 | SF | \$827 | |
| MDF/IDF | | Ventilation and Cooling | Library | 5 | 1 | EA | \$7,007 | |
| Mechanical/Service Rooms | | Janitor's Closet | Entire Building | 6 | 4 | SF | \$19 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | 2nd Floor | 7 | 6 | SF | \$0 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | 3rd Floor | 6 | 2,184 | SF | \$10,306 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | Basement | 6 | 3,535 | SF | \$16,682 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | 3rd Floor | 7 | 6 | SF | \$0 | |
| Mechanical/Service Rooms | | Mechanical/Service Rooms | 4th Floor Mechanical Penthouse | 6 | 1,346 | SF | \$6,352 | |
| Mechanical/Service Rooms | | Storage Room | Storage in 119 | 6 | 66 | SF | \$311 | |
| Mechanical/Service Rooms | | Storage Room | 201 storage | 6 | 200 | SF | \$944 | |
| Mechanical/Service Rooms | | Storage Room | 2nd Floor | 6 | 215 | SF | \$1,015 | |
| Mechanical/Service Rooms | | Storage Room | 2nd Floor Bookroom | 6 | 110 | SF | \$519 | |
| Mechanical/Service Rooms | | Storage Room | Storage in 117 | 6 | 66 | SF | \$311 | |
| Mechanical/Service Rooms | | Storage Room | Storage in Gym | 5 | 38 | SF | \$430 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor | 6 | 54 | SF | \$255 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor Kitchen Storage | 6 | 182 | SF | \$859 | |
| Mechanical/Service Rooms | | Storage Room | Engineer's Storage | 5 | 155 | SF | \$1,755 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor | 6 | 88 | SF | \$415 | |
| Mechanical/Service Rooms | | Storage Room | 316 Storage | 7 | 15 | SF | \$0 | |
| Mechanical/Service Rooms | | Storage Room | 3rd Floor | 5 | 58 | SF | \$657 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor at Lobby | 6 | 61 | SF | \$288 | |
| Mechanical/Service Rooms | | Storage Room | 1st Floor | 6 | 62 | SF | \$293 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 3rd floor boys | 6 | 220 | SF | \$1,699 | |
| Staff Restroom | Staff Restroom | Accessories | 3rd floor Women | 7 | 25 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 1st floor boys | 6 | 155 | SF | \$1,197 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 3rd floor Girls | 7 | 290 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 2nd floor boys | 6 | 220 | SF | \$1,699 | |
| Staff Restroom | Staff Restroom | Accessories | 3rd floor Men | 7 | 25 | SF | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Accessories | 118 | | | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 1st floor girls | 6 | 155 | SF | \$1,197 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 3rd floor Girls | 7 | 290 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | 1st Floor Mens | 6 | 29 | SF | \$224 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|---------------------------|--------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Early Childhood Student Restroom | Accessories | 120 | | | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 2nd Floor Girls | 6 | 193 | SF | \$1,490 | |
| Staff Restroom | Early Childhood Student Restroom | Accessories | In Room 119 | 6 | 22 | SF | \$170 | |
| Staff Restroom | Locker/Shower Room | Accessories | 1st Floor Shower at Locker Room | | | SF | \$0 | |
| Staff Restroom | Staff Restroom | Accessories | 1st Floor in Faculty Lounge | 6 | 25 | SF | \$193 | |
| Staff Restroom | Children's Standard Student Restroom | Accessories | 2nd Floor Boys | 6 | 186 | SF | \$1,436 | |
| Staff Restroom | Locker/Shower Room | Accessories | 2nd Women's Student Locker | 6 | 19 | SF | \$147 | |
| Staff Restroom | Staff Restroom | Accessories | 1st Floor Women's | 6 | 29 | SF | \$224 | |
| Staff Restroom | Staff Restroom | Accessories | 1st Floor in Main Office | 6 | 25 | SF | \$193 | |
| Staff Restroom | Early Childhood Student Restroom | Accessories | In Room 117 | 6 | 22 | SF | \$170 | |
| Staff Restroom | Locker/Shower Room | Accessories | 2nd Floor Men's Locker Room at Gym | | | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Accessories | 2nd Floor Women's Locker Room at Gym | | | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Accessories | 1st Floor Men's Locker Room | | | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Accessories | 1st Floor Women's Locker Room | | | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd floor Girls | 7 | 290 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd floor Girls | 7 | 290 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 3rd floor boys | 6 | 220 | SF | \$623 | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 1st floor girls | 7 | 155 | SF | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Ceiling - Plaster/Drywall | 120 | 7 | 25 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 3rd floor Women | 7 | 25 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd floor boys | 6 | 220 | SF | \$623 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 3rd floor Men | 7 | 25 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 1st floor boys | 7 | 155 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 1st Floor Shower at Locker Room | 6 | 36 | SF | \$102 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|---------------------------|--------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 1st Floor Women's | 6 | 29 | SF | \$82 | |
| Staff Restroom | Early Childhood Student Restroom | Ceiling - Plaster/Drywall | 118 | 7 | 25 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 1st Floor Women's Locker Room | 7 | 67 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 2nd Floor Women's Locker Room at Gym | 6 | 386 | SF | \$1,093 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 2nd Floor Men's Locker Room at Gym | 6 | 386 | SF | \$1,093 | |
| Staff Restroom | Early Childhood Student Restroom | Ceiling - Plaster/Drywall | In Room 117 | 6 | 22 | SF | \$62 | |
| Staff Restroom | Early Childhood Student Restroom | Ceiling - Plaster/Drywall | In Room 119 | 6 | 22 | SF | \$62 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 1st Floor Mens | 6 | 29 | SF | \$82 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 2nd Women's Student Locker | 6 | 19 | SF | \$54 | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor Boys | 6 | 186 | SF | \$527 | |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Plaster/Drywall | 2nd Floor Girls | 6 | 193 | SF | \$546 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 1st Floor in Faculty Lounge | 6 | 25 | SF | \$71 | |
| Staff Restroom | Locker/Shower Room | Ceiling - Plaster/Drywall | 1st Floor Men's Locker Room | 7 | 67 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Ceiling - Plaster/Drywall | 1st Floor in Main Office | 6 | 25 | SF | \$71 | |
| Staff Restroom | Staff Restroom | Floor Drain | 1st Floor Women's | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Floor Drain | 1st Floor Shower at Locker Room | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 3rd floor Girls | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 3rd floor boys | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 1st floor girls | 7 | 1 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Floor Drain | 120 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Floor Drain | 118 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 2nd floor boys | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 3rd floor Girls | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 1st floor boys | 7 | 1 | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|-----------------------------------|--------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom | Floor Drain | 3rd floor Women | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 2nd Floor Boys | 5 | 1 | EA | \$1,502 | |
| Staff Restroom | Staff Restroom | Floor Drain | 1st Floor in Faculty Lounge | 6 | 1 | EA | \$300 | |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain | 2nd Floor Girls | 5 | 1 | EA | \$1,502 | |
| Staff Restroom | Locker/Shower Room | Floor Drain | 1st Floor Men's Locker Room | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Floor Drain | 1st Floor Women's Locker Room | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Floor Drain | 2nd Floor Women's Locker Room at Gym | 5 | 1 | EA | \$1,502 | |
| Staff Restroom | Locker/Shower Room | Floor Drain | 2nd Floor Men's Locker Room at Gym | 5 | 1 | EA | \$1,502 | |
| Staff Restroom | Early Childhood Student Restroom | Floor Drain | In Room 117 | 5 | 1 | EA | \$1,502 | |
| Staff Restroom | Early Childhood Student Restroom | Floor Drain | In Room 119 | 5 | 1 | EA | \$1,502 | |
| Staff Restroom | Staff Restroom | Floor Drain | 1st Floor in Main Office | 6 | 1 | EA | \$300 | |
| Staff Restroom | Staff Restroom | Floor Drain | 1st Floor Mens | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Floor Drain | 2nd Women's Student Locker | 6 | 1 | EA | \$300 | |
| Staff Restroom | Staff Restroom | Floor Drain | 3rd floor Men | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor boys | 6 | 220 | SF | \$560 | |
| Staff Restroom | Early Childhood Student Restroom | Flooring - Tile Ceramic/Porcelain | In Room 119 | 6 | 22 | SF | \$56 | |
| Staff Restroom | Early Childhood Student Restroom | Flooring - Tile Ceramic/Porcelain | In Room 117 | 6 | 22 | SF | \$56 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile Ceramic/Porcelain | 2nd Floor Men's Locker Room at Gym | 6 | 93 | SF | \$237 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile Ceramic/Porcelain | 2nd Floor Women's Locker Room at Gym | 6 | 93 | SF | \$237 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile Ceramic/Porcelain | 1st Floor Shower at Locker Room | 6 | 36 | SF | \$92 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 3rd floor Men | 6 | 25 | SF | \$64 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor in Main Office | 6 | 25 | SF | \$64 | |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd floor Girls | 7 | 290 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor in Faculty Lounge | 6 | 25 | SF | \$64 | |
| Staff Restroom | Early Childhood Student Restroom | Flooring - Tile Ceramic/Porcelain | 118 | 6 | 25 | SF | \$64 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|-----------------------------------|--------------------------------------|------|----------|------|-------|--------|
| Staff Restroom | Early Childhood Student Restroom | Flooring - Tile Ceramic/Porcelain | 120 | 6 | 25 | SF | \$64 | |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor girls | 7 | 155 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd floor boys | 6 | 220 | SF | \$560 | |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd floor Girls | 7 | 290 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor Boys | 6 | 186 | SF | \$473 | |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 1st floor boys | 7 | 155 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor Women's | 6 | 29 | SF | \$74 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile Ceramic/Porcelain | 2nd Women's Student Locker | 6 | 19 | SF | \$48 | |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd Floor Girls | 6 | 193 | SF | \$491 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 3rd floor Women | 7 | 25 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Flooring - Tile Ceramic/Porcelain | 1st Floor Mens | 6 | 29 | SF | \$74 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile/Sheet | 2nd Floor Men's Locker Room at Gym | 6 | 213 | SF | \$305 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile/Sheet | 1st Floor Men's Locker Room | 6 | 67 | SF | \$96 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile/Sheet | 1st Floor Women's Locker Room | 6 | 67 | SF | \$96 | |
| Staff Restroom | Locker/Shower Room | Flooring - Tile/Sheet | 2nd Floor Women's Locker Room at Gym | 6 | 213 | SF | \$305 | |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 1st Floor Women's Locker Room | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 3rd floor Girls | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 2nd Floor Men's Locker Room at Gym | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 2nd Floor Girls | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Hand Dryer | In Room 119 | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 1st Floor Men's Locker Room | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 1st Floor Mens | 6 | 1 | EA | \$217 | |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 1st floor girls | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 1st Floor Women's | 6 | 1 | EA | \$217 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|------------|--------------------------------------|------|----------|------|-------|--------|
| Staff Restroom | Locker/Shower Room | Hand Dryer | 2nd Women's Student Locker | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 1st Floor in Main Office | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 1st Floor Shower at Locker Room | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 1st Floor in Faculty Lounge | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 3rd floor Men | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 3rd floor boys | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Hand Dryer | 120 | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Hand Dryer | 118 | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 2nd floor boys | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 3rd floor Girls | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 1st floor boys | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer | 2nd Floor Boys | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Hand Dryer | In Room 117 | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Hand Dryer | 3rd floor Women | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Hand Dryer | 2nd Floor Women's Locker Room at Gym | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 3rd floor Girls | 7 | 4 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Lavatory | 2nd Floor Men's Locker Room at Gym | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Lavatory | 2nd Floor Women's Locker Room at Gym | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Lavatory | 1st Floor Women's Locker Room | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Lavatory | 1st Floor Men's Locker Room | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Lavatory | 1st Floor Shower at Locker Room | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 3rd floor Girls | 7 | 4 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 1st floor boys | 7 | 3 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Lavatory | 1st Floor in Faculty Lounge | 6 | 1 | EA | \$372 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|-------------------|--------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 2nd floor boys | 7 | 4 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Lavatory | 118 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Lavatory | 120 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 1st floor girls | 7 | 3 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 3rd floor boys | 7 | 4 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 2nd Floor Girls | 6 | 3 | EA | \$1,115 | |
| Staff Restroom | Staff Restroom | Lavatory | 3rd floor Men | 7 | 1 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Lavatory | In Room 119 | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Lavatory | 1st Floor in Main Office | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Lavatory | 1st Floor Mens | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Lavatory | 1st Floor Women's | 6 | 1 | EA | \$372 | |
| Staff Restroom | Locker/Shower Room | Lavatory | 2nd Women's Student Locker | 6 | 1 | EA | \$372 | |
| Staff Restroom | Children's Standard Student Restroom | Lavatory | 2nd Floor Boys | 6 | 3 | EA | \$1,115 | |
| Staff Restroom | Staff Restroom | Lavatory | 3rd floor Women | 7 | 1 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Lavatory | In Room 117 | 6 | 1 | EA | \$372 | |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Boys | 6 | 2 | SF | \$1 | |
| Staff Restroom | Locker/Shower Room | Lighting - Lay-In | 2nd Floor Men's Locker Room at Gym | 6 | 6 | SF | \$4 | |
| Staff Restroom | Early Childhood Student Restroom | Lighting - Lay-In | In Room 117 | 6 | 1 | SF | \$1 | |
| Staff Restroom | Early Childhood Student Restroom | Lighting - Lay-In | In Room 119 | 6 | 1 | SF | \$1 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 1st Floor in Main Office | 6 | 1 | SF | \$1 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 1st Floor Mens | 6 | 1 | SF | \$1 | |
| Staff Restroom | Locker/Shower Room | Lighting - Lay-In | 2nd Floor Women's Locker Room at Gym | 6 | 6 | SF | \$4 | |
| Staff Restroom | Locker/Shower Room | Lighting - Lay-In | 2nd Women's Student Locker | 6 | 1 | SF | \$1 | |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 1st floor girls | 7 | 3 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd floor Girls | 7 | 4 | SF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|-------------------|--------------------------------------|------|----------|------|------|--------|
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 1st Floor Women's | 6 | 1 | SF | \$1 | |
| Staff Restroom | Locker/Shower Room | Lighting - Lay-In | 1st Floor Women's Locker Room | 6 | 1 | SF | \$1 | |
| Staff Restroom | Locker/Shower Room | Lighting - Lay-In | 1st Floor Shower at Locker Room | 6 | 1 | SF | \$1 | |
| Staff Restroom | Locker/Shower Room | Lighting - Lay-In | 1st Floor Men's Locker Room | 6 | 1 | SF | \$1 | |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd floor boys | 7 | 4 | SF | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Lighting - Lay-In | 120 | 7 | 1 | SF | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Lighting - Lay-In | 118 | 7 | 1 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd floor boys | 7 | 4 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 3rd floor Girls | 7 | 4 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 1st floor boys | 7 | 3 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 1st Floor in Faculty Lounge | 6 | 1 | SF | \$1 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 3rd floor Women | 7 | 1 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Lighting - Lay-In | 3rd floor Men | 7 | 1 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In | 2nd Floor Girls | 6 | 2 | SF | \$1 | |
| Staff Restroom | Locker/Shower Room | Partitions | 1st Floor Shower at Locker Room | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | 2nd Women's Student Locker | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 1st Floor Women's | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 1st Floor Mens | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 1st Floor in Main Office | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 3rd floor Girls | 7 | 7 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Partitions | In Room 119 | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Partitions | In Room 117 | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | 2nd Floor Men's Locker Room at Gym | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | 2nd Floor Women's Locker Room at Gym | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Partitions | 1st Floor Men's Locker Room | | | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|------------|--------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Children's Standard Student Restroom | Partitions | 2nd Floor Girls | 6 | 3 | EA | \$538 | |
| Staff Restroom | Staff Restroom | Partitions | 1st Floor in Faculty Lounge | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 3rd floor Men | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Partitions | 3rd floor Women | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 1st floor boys | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 3rd floor Girls | 7 | 6 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 2nd floor boys | 5 | 2 | EA | \$1,144 | |
| Staff Restroom | Early Childhood Student Restroom | Partitions | 118 | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Partitions | 120 | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 1st floor girls | 6 | 3 | EA | \$538 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 3rd floor boys | 5 | 2 | EA | \$1,144 | |
| Staff Restroom | Locker/Shower Room | Partitions | 1st Floor Women's Locker Room | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Partitions | 2nd Floor Boys | 6 | 1 | EA | \$179 | |
| Staff Restroom | Locker/Shower Room | Urinals | 1st Floor Shower at Locker Room | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 2nd Floor Girls | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 2nd Floor Boys | 6 | 2 | EA | \$744 | |
| Staff Restroom | Locker/Shower Room | Urinals | 2nd Women's Student Locker | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 1st Floor Women's | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 1st Floor Mens | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 1st Floor in Main Office | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Urinals | In Room 119 | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Urinals | In Room 117 | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Urinals | 2nd Floor Men's Locker Room at Gym | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Urinals | 2nd Floor Women's Locker Room at Gym | | | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|------------------------|------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Children's Standard Student Restroom | Urinals | 3rd floor Girls | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Urinals | 1st Floor Men's Locker Room | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 1st Floor in Faculty Lounge | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 3rd floor Men | | | EA | \$0 | |
| Staff Restroom | Staff Restroom | Urinals | 3rd floor Women | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 1st floor boys | 7 | 2 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 3rd floor Girls | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 2nd floor boys | 7 | 3 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Urinals | 118 | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Urinals | 120 | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Urinals | 3rd floor boys | 7 | 5 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Urinals | 1st Floor Women's Locker Room | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Wall - Plaster/Drywall | 2nd Floor Men's Locker Room at Gym | 6 | 654 | SF | \$1,543 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 1st floor girls | 7 | 375 | SF | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Wall - Plaster/Drywall | In Room 119 | 6 | 136 | SF | \$321 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 2nd Floor Girls | 6 | 396 | SF | \$934 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 3rd floor boys | 6 | 498 | SF | \$1,175 | |
| Staff Restroom | Early Childhood Student Restroom | Wall - Plaster/Drywall | 120 | 6 | 140 | SF | \$330 | |
| Staff Restroom | Early Childhood Student Restroom | Wall - Plaster/Drywall | 118 | 6 | 140 | SF | \$330 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 2nd floor boys | 6 | 498 | SF | \$1,175 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 3rd floor Girls | 6 | 736 | SF | \$1,737 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 1st floor boys | 7 | 375 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | 3rd floor Women | 7 | 131 | SF | \$0 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | 3rd floor Men | 7 | 131 | SF | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|--------------------------------------|--------------------------------|--------------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | 1st Floor in Faculty Lounge | 6 | 149 | SF | \$352 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | 1st Floor Mens | 6 | 166 | SF | \$392 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 3rd floor Girls | 6 | 736 | SF | \$1,737 | |
| Staff Restroom | Locker/Shower Room | Wall - Plaster/Drywall | 2nd Women's Student Locker | 6 | 126 | SF | \$297 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | 1st Floor Women's | 6 | 166 | SF | \$392 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Plaster/Drywall | 2nd Floor Boys | 6 | 393 | SF | \$927 | |
| Staff Restroom | Staff Restroom | Wall - Plaster/Drywall | 1st Floor in Main Office | 6 | 147 | SF | \$347 | |
| Staff Restroom | Early Childhood Student Restroom | Wall - Plaster/Drywall | In Room 117 | 6 | 136 | SF | \$321 | |
| Staff Restroom | Locker/Shower Room | Wall - Plaster/Drywall | 2nd Floor Women's Locker Room at Gym | 6 | 654 | SF | \$1,543 | |
| Staff Restroom | Locker/Shower Room | Wall - Plaster/Drywall | 1st Floor Men's Locker Room | 7 | 305 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Wall - Plaster/Drywall | 1st Floor Shower at Locker Room | 6 | 161 | SF | \$380 | |
| Staff Restroom | Locker/Shower Room | Wall - Plaster/Drywall | 1st Floor Women's Locker Room | 7 | 305 | SF | \$0 | |
| Staff Restroom | Locker/Shower Room | Wall - Tile Ceramic/ Porcelain | 1st Floor Shower at Locker Room | 6 | 85 | SF | \$216 | |
| Staff Restroom | Locker/Shower Room | Wall - Tile Ceramic/ Porcelain | 2nd Floor Men's Locker Room at Gym | 6 | 207 | SF | \$527 | |
| Staff Restroom | Locker/Shower Room | Wall - Tile Ceramic/ Porcelain | 2nd Floor Women's Locker Room at Gym | 6 | 207 | SF | \$527 | |
| Staff Restroom | Children's Standard Student Restroom | Wall - Tile Ceramic/ Porcelain | 1st floor boys | 7 | 25 | SF | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 2nd Floor Boys | 6 | 1 | EA | \$372 | |
| Staff Restroom | Locker/Shower Room | Water Closet | 2nd Women's Student Locker | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Water Closet | 1st Floor Women's | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Water Closet | 1st Floor Mens | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Water Closet | 1st Floor in Main Office | 6 | 1 | EA | \$372 | |
| Staff Restroom | Early Childhood Student Restroom | Water Closet | In Room 119 | 6 | 1 | EA | \$372 | |
| Staff Restroom | Locker/Shower Room | Water Closet | 1st Floor Women's Locker Room | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Water Closet | 2nd Floor Men's Locker Room at Gym | | | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Water Closet | 2nd Floor Women's Locker Room at Gym | | | EA | \$0 | |

Building: Main
Category: INTERIOR

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------|--------------------------------------|--------------|---------------------------------|------|----------|------|---------|--------|
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 2nd Floor Girls | 6 | 3 | EA | \$1,115 | |
| Staff Restroom | Locker/Shower Room | Water Closet | 1st Floor Men's Locker Room | | | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Water Closet | In Room 117 | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Water Closet | 1st Floor in Faculty Lounge | 6 | 1 | EA | \$372 | |
| Staff Restroom | Staff Restroom | Water Closet | 3rd floor Men | 7 | 1 | EA | \$0 | |
| Staff Restroom | Staff Restroom | Water Closet | 3rd floor Women | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 1st floor boys | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 3rd floor Girls | 7 | 6 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Water Closet | 118 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 1st floor girls | 7 | 3 | EA | \$0 | |
| Staff Restroom | Early Childhood Student Restroom | Water Closet | 120 | 7 | 1 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 3rd floor Girls | 7 | 7 | EA | \$0 | |
| Staff Restroom | Locker/Shower Room | Water Closet | 1st Floor Shower at Locker Room | | | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 3rd floor boys | 7 | 3 | EA | \$0 | |
| Staff Restroom | Children's Standard Student Restroom | Water Closet | 2nd floor boys | 7 | 4 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 2 | EA | \$772 | |
| Vocational Shop | Classroom | Work Sink | | 6 | 2 | EA | \$772 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 3 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |
| Vocational Shop | Classroom | Work Sink | | 7 | 1 | EA | \$0 | |

INTERIOR Sub Total \$340,868

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|-----------|-------------|----------|------|----------|------|-------|--------|
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 12 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 120 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 30 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 20 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 34 | LF | \$0 | |
| Casework | Classroom | Casework | | 6 | 14 | LF | \$501 | |
| Casework | Classroom | Casework | | 6 | 14 | LF | \$501 | |
| Casework | Classroom | Casework | | 7 | 30 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 8 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 8 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 24 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 20 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 29 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Casework | Classroom | Casework | | 7 | 40 | LF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 604 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 460 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------|-------------------|-------------|-------------------|------|----------|------|---------|--------|
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,025 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,025 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,025 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 1,012 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,085 | SF | \$2,327 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 1,085 | SF | \$2,327 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 718 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 460 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 6 | 972 | SF | \$2,085 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Ceiling | Classroom | Lay-In/Drop | | 7 | 871 | SF | \$0 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 7 | LF | \$851 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 10 | LF | \$1,216 | |
| Chalk Board | Multipurpose Room | Chalk Board | Rooms 114 and 116 | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 40 | LF | \$4,862 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 20 | LF | \$2,431 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 40 | LF | \$4,862 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 54 | LF | \$6,564 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------|-----------|--------------------|------------------------|------|----------|------|----------|--------|
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 36 | LF | \$4,376 | |
| Chalk Board | Classroom | Chalk Board | | 4 | | LF | | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 18 | LF | \$2,188 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 12 | LF | \$1,459 | |
| Chalk Board | Classroom | Chalk Board | | 4 | 48 | LF | \$5,834 | |
| Corridors | Corridors | Asphalt | West Stairs | 6 | 273 | SF | \$390 | |
| Corridors | Corridors | Asphalt | East Stairs | 6 | 222 | SF | \$317 | |
| Corridors | Corridors | Asphalt | Center Stairs | 6 | 235 | SF | \$336 | |
| Corridors | Corridors | Drinking Fountains | East Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | West Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Center Stairs | | | EA | \$0 | |
| Corridors | Corridors | Drinking Fountains | Kindergarten Vestibule | | | EA | \$0 | |
| Corridors | Corridors | Drop/Lay-In | 2nd Floor | 6 | 2,976 | SF | \$6,384 | |
| Corridors | Corridors | Drop/Lay-In | 1st Floor | 6 | 4,781 | SF | \$10,255 | |
| Corridors | Corridors | Drop/Lay-In | 3rd Floor | 6 | 2,814 | SF | \$6,036 | |
| Corridors | Corridors | Lay-In | 3rd Floor | 6 | 2,814 | EA | \$2,012 | |
| Corridors | Corridors | Lay-In | Kindergarten Vestibule | 6 | 44 | EA | \$31 | |
| Corridors | Corridors | Lay-In | 1st Floor | 6 | 4,781 | EA | \$3,418 | |
| Corridors | Corridors | Lay-In | 2nd Floor | 6 | 2,976 | EA | \$2,128 | |
| Corridors | Corridors | Pendant/Surface | East Stairs | 7 | 475 | EA | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------------|-----------|------------------------|------------------------|------|----------|------|----------|--------|
| Corridors | Corridors | Pendant/Surface | West Stairs | 7 | 254 | EA | \$0 | |
| Corridors | Corridors | Pendant/Surface | Center Stairs | 7 | 516 | EA | \$0 | |
| Corridors | Corridors | Plaster/Drywall | 3rd Floor | 6 | 2,712 | SF | \$6,399 | |
| Corridors | Corridors | Plaster/Drywall | Center Stairs | 6 | 2,580 | SF | \$6,088 | |
| Corridors | Corridors | Plaster/Drywall | West Stairs | 6 | 1,760 | SF | \$4,153 | |
| Corridors | Corridors | Plaster/Drywall | 2nd Floor | 6 | 2,928 | SF | \$6,909 | |
| Corridors | Corridors | Plaster/Drywall | 1st Floor | 6 | 4,543 | SF | \$10,719 | |
| Corridors | Corridors | Plaster/Drywall | Kindergarten Vestibule | 6 | 154 | SF | \$363 | |
| Corridors | Corridors | Plaster/Drywall | East Stairs | 6 | 2,383 | SF | \$5,623 | |
| Corridors | Corridors | Single Water Cooler | 3rd Floor | 6 | 2 | EA | \$1,230 | |
| Corridors | Corridors | Single Water Cooler | 1st Floor | 6 | 2 | EA | \$1,230 | |
| Corridors | Corridors | Single Water Cooler | 2nd Floor | 6 | 2 | EA | \$1,230 | |
| Corridors | Corridors | Stair Handrails | West Stairs | 6 | 111 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 3rd Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Kindergarten Vestibule | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 2nd Floor | | | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | Center Stairs | 6 | 117 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | East Stairs | 6 | 140 | LF | \$0 | |
| Corridors | Corridors | Stair Handrails | 1st Floor | | | LF | \$0 | |
| Corridors | Corridors | Stairs | Kindergarten Vestibule | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 2nd Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 1st Floor | | | EA | \$0 | |
| Corridors | Corridors | Stairs | 3rd Floor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | East Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Kindergarten Vestibule | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 1st Floor | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 2nd Floor | 6 | 172 | EA | \$24,596 | |
| Corridors | Corridors | Student Lockers | West Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | Center Stairs | | | EA | \$0 | |
| Corridors | Corridors | Student Lockers | 3rd Floor | 5 | 146 | EA | \$26,098 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | 1st Floor | 6 | 4,781 | SF | \$12,170 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | Kindergarten Vestibule | 6 | 44 | SF | \$112 | |
| Corridors | Corridors | Tile Ceramic/Porcelain | East Stairs | 7 | 265 | SF | \$0 | |
| Corridors | Corridors | Tile/Sheet Flooring | 2nd Floor | 6 | 2,976 | SF | \$4,256 | |
| Corridors | Corridors | Tile/Sheet Flooring | 3rd Floor | 6 | 2,814 | SF | \$4,024 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | Center Stairs | 7 | 516 | SF | \$0 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | West Stairs | 7 | 254 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------------------|-----------|-----------------|------------------------|------|----------|------|---------|--------|
| Corridors Ceiling | Corridors | Plaster/Drywall | Kindergarten Vestibule | 6 | 44 | SF | \$125 | |
| Corridors Ceiling | Corridors | Plaster/Drywall | East Stairs | 6 | 475 | SF | \$1,345 | |
| Stairs | Corridors | Asphalt | Center Stairs | 6 | 36 | SF | \$257 | |
| Stairs | Corridors | Asphalt | West Stairs | 6 | 44 | SF | \$315 | |
| Stairs | Corridors | Asphalt | East Stairs | 6 | 44 | SF | \$315 | |
| Stairs | Corridors | Tile | Center Stairs | 7 | 8 | SF | \$0 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Carpet | | 6 | 731 | SF | \$1,045 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 871 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 718 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 460 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 972 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 871 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,025 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------|-----------|-----------------|-----------|------|----------|------|---------|--------|
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,012 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 6 | 1,085 | SF | \$1,552 | |
| Floor | Classroom | Tile/Sheet | | 6 | 1,085 | SF | \$1,552 | |
| Floor | Classroom | Tile/Sheet | | 7 | 604 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,025 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 460 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 1,025 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| Floor | Classroom | Tile/Sheet | | 7 | 140 | SF | \$0 | |
| LIBRARY_CEILING | Library | Drop/Lay-In | 2nd Floor | 6 | 2,112 | SF | \$4,530 | |
| LIBRARY_WALL | Library | Plaster/Drywall | 2nd Floor | 6 | 1,427 | | \$3,367 | |
| Lighting | Classroom | Lay-In | | 6 | 18 | EA | \$1,287 | |
| Lighting | Classroom | Lay-In | | 7 | 8 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 9 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 15 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 8 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 6 | 18 | EA | \$1,287 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 15 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------|-------------------|-----------------|-------------------|------|----------|------|----------|--------|
| Lighting | Classroom | Lay-In | | 7 | 6 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lay-In | | 7 | 12 | EA | \$0 | |
| Lighting | Classroom | Lighting | | 7 | 4 | EA | \$0 | |
| Lighting | Classroom | Lighting | | 7 | 4 | EA | \$0 | |
| Lighting | Classroom | Lighting | | 7 | 4 | EA | \$0 | |
| Lighting | Classroom | Lighting | | 7 | 4 | EA | \$0 | |
| Lighting | Classroom | Lighting | | 7 | 4 | EA | \$0 | |
| Lighting | Classroom | Lighting | | 7 | 4 | EA | \$0 | |
| Lighting | Classroom | Lighting | | 7 | 4 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 20 | EA | \$0 | |
| Lighting | Classroom | Pendant/Surface | | 7 | 20 | EA | \$0 | |
| LUNCH_FLOOR | Multipurpose Room | Lunchroom Floor | Rooms 114 and 116 | 5 | 4,403 | SF | \$24,933 | |
| Marker Board | Multipurpose Room | Marker Board | Rooms 114 and 116 | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 8 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 8 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 12 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 32 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 18 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 8 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 8 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|---------------|--------------------------------------|-----------------|-----------------|------|----------|------|---------|--------|
| Marker Board | Classroom | Marker Board | | 7 | 18 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 12 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 8 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 18 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 18 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 16 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | | | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 6 | LF | \$0 | |
| Marker Board | Classroom | Marker Board | | 7 | 6 | LF | \$0 | |
| RESTROOM_WALL | Children's Standard Student Restroom | Restroom Walls | 1st floor girls | 7 | 20 | SF | \$0 | |
| RESTROOM_WALL | Children's Standard Student Restroom | Restroom Walls | 1st floor boys | 7 | 20 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 700 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 700 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 948 | SF | \$2,237 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 700 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 900 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 540 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 501 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 602 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 700 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,018 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 6 | 732 | SF | \$1,727 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 570 | SF | \$0 | |

Building: Main
Category: ROOM

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|-----------------|----------|------|----------|------|------|--------|
| Wall | Classroom | Plaster/Drywall | | 7 | 882 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 501 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 1,018 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Plaster/Drywall | | 7 | 895 | SF | \$0 | |
| Wall | Classroom | Wall | | 7 | 240 | SF | \$0 | |

ROOM Sub Total \$340,048

Building Main Sub Total \$2,493,496

Building: SITE
Category: SITE

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|----------------|-----------|--------------------------------|--------------------------|------|----------|------|----------|---------------------------------------|
| Civil/Drainage | | Catch Basin | Entire Site | 7 | 2 | EA | \$0 | |
| Civil/Drainage | | Catch Basin | Site - East | 5 | 1 | EA | \$1,216 | backed up causing flooding at playlot |
| Civil/Drainage | | Site Manhole | Entire Site | 7 | 6 | EA | \$0 | |
| Fencing | | Chain Link | Entire Site | 6 | 388 | LF | \$5,565 | |
| Fencing | | Ornamental Iron | Entire Site | 6 | 861 | LF | \$16,252 | |
| Landscape | | Asphalt Play Area/Hardscape | Site - East | 6 | 9,954 | SF | \$8,541 | minor cracking throughout |
| Landscape | | Benches | site N and E | 7 | 5 | EA | \$0 | |
| Landscape | | Grass | site N and E | 7 | 2,090 | SF | \$0 | |
| Landscape | | Hardscape - Concrete | S basement door/ S entry | 5 | 70 | SF | \$436 | |
| Landscape | | Hardscape - Concrete | Entire Site | 6 | 5,188 | SF | \$9,793 | |
| Landscape | | Parkway trees | site N and W | 7 | 20 | EA | \$0 | |
| Landscape | | Planting Beds/ Areas | Site ∩ North | 6 | 92 | SF | \$0 | minor cracks throughout |
| Landscape | | Retaining Wall - Concrete | S leading to basement | 6 | 122 | SF | \$2,879 | |
| Parking Lot | | Asphalt | Site ∩ West | 6 | 14,503 | SF | \$12,444 | minor cracks throughout |
| Parking Lot | | Concrete Curbs | Site ∩ West | 6 | 469 | LF | \$2,830 | |
| Parking Lot | | Parking lot interior plantings | Site ∩ West | 7 | 4 | LF | \$0 | |
| Parking Lot | | Vehicular Screening | site W and N | 7 | 75 | LF | \$0 | |

Building: SITE
Category: SITE

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-----------|---|--------------|------|----------|------|------------------|---------------|
| Playground | | Playground Equipment - School Age 5-12 | Site - East | 6 | 1 | EA | \$0 | some graffiti |
| Playground | | Playground Surfacing - Square Rubber Mats | Site - East | 4 | 3,308 | SF | \$73,322 | |
| Sidewalks | | Perimeter Sidewalks | site N and W | 6 | 7,964 | SF | \$15,033 | |
| Signage | | Flag Pole | Site z North | 7 | 1 | EA | \$0 | |
| Signage | | Marquee - Free Standing Back Lighted | site NW | 6 | 1 | EA | \$0 | |
| SITE Sub Total | | | | | | | \$148,310 | |
| SITE Sub Total | | | | | | | \$148,310 | |

Total Campus Need ^{2 3} \$2,641,806

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-----------------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-----------|--------------------------------------|-----------------|
| Building: Main | | | | | | | | | | | | | | |
| 117 | 1085 | 1 | 6 | 18 | 40 | 135 | 11 | | N | N | Y | Classroom | | |
| 118 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 119 | 1085 | 1 | 6 | 18 | 40 | 351 | 21 | | N | N | N | Classroom | | |
| 120 | 871 | 1 | 6 | 16 | 40 | 408 | 56 | | N | N | Y | Classroom | | |
| 201 | 1025 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 202 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 203 | 604 | 1 | 4 | 10 | 40 | 136 | 5 | | N | N | Y | Classroom | | |
| 204 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 206 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 207 | 1012 | 1 | 4 | 16 | 40 | 238 | 15 | | N | N | Y | Classroom | | |
| 208 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 210 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 212 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 214 | 718 | 1 | 4 | 10 | 40 | 374 | 20 | | N | N | Y | Classroom | | |
| 215 | 972 | 1 | 6 | 10 | 40 | 408 | 20 | | N | N | Y | Classroom | | |
| 217 | 460 | 1 | 4 | 10 | 40 | 136 | 5 | | N | N | Y | Classroom | | |
| 301 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 302 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 303 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 304 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 306 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 307 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 308 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 309 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 310 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 311 | 1025 | 1 | 25 | 90 | 40 | 204 | 28 | 2 | N | N | N | Classroom | | |
| 312 | 871 | 1 | 6 | 16 | 40 | 204 | 28 | | N | N | Y | Classroom | | |
| 313 | 1025 | 1 | 9 | 32 | 40 | 204 | 28 | | N | N | N | Classroom | | |
| 314 | 871 | 1 | 6 | 16 | 40 | 408 | 56 | | N | N | Y | Classroom | | |
| 315 | 871 | 1 | 6 | 16 | 40 | 408 | 56 | | N | N | Y | Classroom | | |
| 316 | 460 | 1 | 4 | 10 | 40 | 136 | 5 | | N | N | Y | Classroom | | |
| Other | 25 | | | | | | | | N | N | N | Restroom | Early Childhood Student Restroom | 118 |
| Other | 25 | | | | | | | | N | N | N | Restroom | Early Childhood Student Restroom | 120 |
| Other | 155 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 1st floor girls |
| Other | 155 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 1st floor boys |
| Other | 290 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 3rd floor Girls |

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|--------------------------------------|---|
| Other | 220 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 2nd floor boys |
| Other | 214 | | | 4 | | | | | N | N | N | Administrative Suites/Offices | | 313 Science office |
| Other | 220 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 3rd floor boys |
| Other | 25 | | | | | | | | N | N | N | Restroom | Staff Restroom | 3rd floor Women |
| Other | 25 | | | | | | | | N | N | N | Restroom | Staff Restroom | 3rd floor Men |
| Other | 290 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 3rd floor Girls |
| Other | 398 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 305 language lab/office |
| Other | 398 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 205 language lab/office |
| Other | 172 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 1st Floor Principal's Office |
| Other | 29 | | | | | | | | N | N | N | Restroom | Staff Restroom | 1st Floor Mens |
| Other | 29 | | | | | | | | N | N | N | Restroom | Staff Restroom | 1st Floor Women's |
| Other | 19 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | 2nd Women's Student Locker |
| Other | 186 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 2nd Floor Boys |
| Other | 193 | | | | | | | | N | N | N | Restroom | Children's Standard Student Restroom | 2nd Floor Girls |
| Other | 25 | | | | | | | | N | N | N | Restroom | Staff Restroom | 1st Floor in Faculty Lounge |
| Other | 36 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | 1st Floor Shower at Locker Room |
| Other | | | | | | | | | N | N | N | Corridors | | East Stairs |
| Other | 177 | | | 8 | | | | | N | N | N | Administrative Suites/Offices | | 1st Floor Main Office Conference Room |
| Other | 22 | | | | | | | | N | N | N | Restroom | Early Childhood Student Restroom | In Room 117 |
| Other | 220 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 1st Floor Main Office Workroom |
| Other | 743 | | | 10 | | | | | N | N | Y | Administrative Suites/Offices | | 1st Floor Main Office |
| Other | 161 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | Assistant Principal's Office 1st Floor Room 161 |
| Other | 161 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 1st Floor |
| Other | 244 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 1st Floor Counselor's Office Room 111 |
| Other | 2814 | | | | | | | | N | N | N | Corridors | | 3rd Floor |
| Other | 2976 | | | | | | | | N | N | N | Corridors | | 2nd Floor |
| Other | 4781 | | | | | | | | N | N | N | Corridors | | 1st Floor |
| Other | 1024 | | | 16 | | | | | N | N | Y | Administrative Suites/Offices | | 1st Floor Faculty Lounge |
| Other | 67 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | 1st Floor Men's Locker Room |
| Other | 44 | | | | | | | | N | N | N | Corridors | | Kindergarten Vestibule |
| Other | | | | | | | | | N | N | N | Corridors | | West Stairs |
| Other | 5188 | | | | | | | | N | N | N | Gymnasia | Standard Dedicated Gymnasium | 2nd Floor |
| Other | 2112 | | | | | | | | N | N | N | Library | | 2nd Floor |
| Other | 4403 | | | | | | | | N | N | N | Lunch & Multipurpose Room | Multipurpose Room | Rooms 114 and 116 |
| Other | 437 | | | | | | | | N | N | N | Kitchen | Warming Kitchen | Serving Room |

Room Summary

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type | Location |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|----------------------------------|--------------------------------------|
| Other | 753 | | | | | | | | N | N | N | Kitchen | Cooking Kitchen | 1st Floor |
| Other | 117 | | | | | | | | N | N | N | Kitchen | Cooking Kitchen | Dishwashing Room |
| Other | 25 | | | | | | | | N | N | N | Restroom | Staff Restroom | 1st Floor in Main Office |
| Other | 194 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 1st Floor Engineer's Office |
| Other | 22 | | | | | | | | N | N | N | Restroom | Early Childhood Student Restroom | In Room 119 |
| Other | 67 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | 1st Floor Women's Locker Room |
| Other | 257 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | Parent Resource Room 1st Floor |
| Other | 163 | | | 6 | | | | | N | N | Y | Administrative Suites/Offices | | 2nd Floor Gym Office |
| Other | 386 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | 2nd Floor Women's Locker Room at Gym |
| Other | 327 | | | 16 | | | | | N | N | N | Administrative Suites/Offices | | CPS Support Office in Library |
| Other | 401 | | | 18 | | | | | N | N | Y | Administrative Suites/Offices | | 2nd Floor Workroom 213 |
| Other | 386 | | | | | | | | N | N | N | Restroom | Locker/Shower Room | 2nd Floor Men's Locker Room at Gym |
| Other | | | | | | | | | N | N | N | Corridors | | Center Stairs |
| Other | 136 | | | 8 | | | | | N | N | Y | Administrative Suites/Offices | | 1st Floor Kitchen Office |