

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Cornice		Cornice - Masonry Projecting/Limestone	West Entrance, Door 3	6	60	LF	\$1,840	
Cornice		Cornice - Terra Cotta	Entire Building	6	336	LF	\$10,306	
Doors		Exterior FRP Door	Doors 3 and 4	7	6	EA	\$0	
Doors		Exterior FRP Door	Fire Escape Doors	6	2	EA	\$1,114	
Doors		Transom Lite	Door 3	7	3	EA	\$0	
Entrance		Stone Stairs	Doors 3 and 4	6	30	LF	\$5,363	
Fire Escape		Fire Escapes	East	6	3	LF	\$306	
Foundation		Concrete Foundation	Entire Building	7	186	LF	\$0	
Lintels		Lintels - Brick	Entire Building	6	44	LF	\$0	
Lintels		Lintels - Steel	Above Fire Escape Doors and Window at Roof Level	6	9	LF	\$340	
Lintels		Lintels - Stone	Second Stay Windows	6	18	LF	\$0	
Parapet		Coping - Stone	West Lower Roof	6	18	LF	\$0	
Parapet		Coping - Terra Cotta	Entire Building	6	250	LF	\$0	
Parapet		Parapet < 16" Height	Lower Roof and South	6	67	LF	\$10,434	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Parapet 16" to 30" Height	Entire Building	6	201	LF	\$41,735	
Roof System		Asphalt Gravel Ballast Roof	Entire Building	7	4,650	SF	\$0	
Roof System		Interior Downspouts	North and Lower Roof	6	138	LF	\$0	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Entire Building	7	4,866	SF	\$0	
Roof System		Slate Shingle Roof	West, Lower Roof	6	216	SF	\$1,325	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	12,650	SF	\$0	
Walls		Brick	Entire Building	6	11,889	SF	\$78,546	
Walls		Stone - Cut	Entire Building	6	336	SF	\$4,805	
Windows		Window - Guards perforated	Entire Building	7	280	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	591	SF	\$0	
EXTERIOR Sub Total							\$156,113	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Auditorium and aisle lighting	Entire Building	6	2,026	SF	\$2,752	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	1,894	SF	\$813	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	6	2,734	SF	\$1,447	
Emergency System		Emergency Battery Packs - Corridors and Stairs	3rd Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	7	EA	\$0	
Emergency System		Exit Signs - Auditorium	2nd Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	3rd Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	6	1	EA	\$233	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	3rd Floor	7	1	EA	\$0	
Power Distribution		Lighting and power panels	1st Floor	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	1st Floor	7	1	EA	\$0	
Power Distribution		Lighting and power panels	3rd Floor	4	1	EA	\$5,434	
ELECTRICAL Sub Total							\$21,546	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices		Radiators - Steam	1st Floor	5	5	EA	\$3,289	
Heating Devices		Radiators - Steam	3rd Floor	5	11	EA	\$7,236	
Heating Devices		Wall Heater - Electric	1st Floor	4	2	EA	\$2,059	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Temperature Control		Thermostats - Pneumatic	1st Floor	4	1	EA	\$658	
Temperature Control		Thermostats - Pneumatic	3rd Floor	4	1	EA	\$658	
MECHANICAL Sub Total							\$13,900	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Gym Office	6	118	SF	\$334	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	2nd floor Main Office	6	375	SF	\$1,062	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	2nd floor Main Office	6	375	SF	\$536	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Gym Office	6	118	SF	\$891	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd floor Main Office	6	3	SF	\$2	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Gym Office	6	2	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	2nd floor Main Office	6	1,080	SF	\$2,548	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Gym Office	6	415	SF	\$979	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	Basement	6	124	EA	\$4,564	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	Basement	6	259	EA	\$9,533	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	Basement			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	Basement	6	6	EA	\$67,954	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	Basement	5	1	EA	\$214,500	
Doors		Interior Wood Doors incl hw	Entire Building	5	6	EA	\$2,831	
Doors		Interior Wood Doors incl hw	Entire Building	6	6	EA	\$1,699	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	2nd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Splined	2nd Floor	6	2,734	SF	\$25,413	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	2nd Floor	6	2,734	SF	\$20,643	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Pendant/Surface	2nd Floor	6	9	EA	\$1,094	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	2nd Floor			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	2nd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	2nd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	2nd Floor	6	1,440	SF	\$12,355	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	2nd Floor	6	1,440	SF	\$10,296	
Locker/Shower Room	Adult Standard Student Restroom	Benches	Men Assembly Lobby Basement			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	Women Assembly Lobby Basement			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	Men Assembly Lobby Basement			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	Women Assembly Lobby Basement			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	Men Assembly Lobby Basement			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	Women Assembly Lobby Basement			EA	\$0	
Mechanical/Service Rooms		Storage Room	Balcony	6	77	SF	\$363	
Mechanical/Service Rooms		Storage Room	2nd Floor	5	24	SF	\$272	
Staff Restroom	Adult Standard Student Restroom	Accessories	Men Assembly Lobby Basement	6	87	SF	\$672	
Staff Restroom	Adult Standard Student Restroom	Accessories	Women Assembly Lobby Basement	6	99	SF	\$764	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	Men Assembly Lobby Basement	6	87	SF	\$246	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	Women Assembly Lobby Basement	6	99	SF	\$280	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	Women Assembly Lobby Basement			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	Men Assembly Lobby Basement			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Men Assembly Lobby Basement	5	87	SF	\$1,369	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Women Assembly Lobby Basement	5	99	SF	\$1,557	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	Women Assembly Lobby Basement			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	Men Assembly Lobby Basement			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	Women Assembly Lobby Basement	6	1	EA	\$372	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Lavatory	Men Assembly Lobby Basement	6	1	EA	\$372	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	Women Assembly Lobby Basement	6	1	SF	\$1	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	Men Assembly Lobby Basement	6	1	SF	\$1	
Staff Restroom	Adult Standard Student Restroom	Partitions	Men Assembly Lobby Basement	6	1	EA	\$179	
Staff Restroom	Adult Standard Student Restroom	Partitions	Women Assembly Lobby Basement	6	2	EA	\$359	
Staff Restroom	Adult Standard Student Restroom	Urinals	Men Assembly Lobby Basement	6	1	EA	\$372	
Staff Restroom	Adult Standard Student Restroom	Urinals	Women Assembly Lobby Basement			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	Women Assembly Lobby Basement	4	370	SF	\$11,524	
Staff Restroom	Adult Standard Student Restroom	Water Closet	Women Assembly Lobby Basement	6	2	EA	\$744	
Staff Restroom	Adult Standard Student Restroom	Water Closet	Men Assembly Lobby Basement	6	1	EA	\$372	
Theater	Auditorium - Dedicated	Lighting - Wall Mounted	Basement	6	8	EA	\$229	
Theater	Auditorium - Dedicated	Stage	Basement	6	479	SF	\$2,034	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	Basement	6	6,107	SF	\$52,398	
INTERIOR Sub Total							\$451,715	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Concrete Epoxy/Painted	Basement	6	435	SF	\$2,053	
Corridors	Corridors	Drinking Fountains	Main Building Vestibules; e,w, Auditorium lobby			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair to Assembly			EA	\$0	
Corridors	Corridors	Drinking Fountains	Basement			EA	\$0	
Corridors	Corridors	Drinking Fountains	Main Stairs			EA	\$0	
Corridors	Corridors	Floors	Main Building Vestibules; e,w, Auditorium lobby	6	28	SF	\$211	
Corridors	Corridors	Pendant/Surface	1st Floor	7	353	EA	\$0	
Corridors	Corridors	Pendant/Surface	Basement	7	3	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair to Assembly	6	2	EA	\$1	
Corridors	Corridors	Pendant/Surface	Main Stairs	4	8	EA	\$78	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	528	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Pendant/Surface	Main Building Vestibules; e,w, Auditorium lobby	7	4	EA	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	790	SF	\$1,864	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	665	SF	\$1,569	
Corridors	Corridors	Plaster/Drywall	Basement	6	820	SF	\$1,935	
Corridors	Corridors	Plaster/Drywall	Stair to Assembly	6	312	SF	\$736	
Corridors	Corridors	Plaster/Drywall	Main Building Vestibules; e,w, Auditorium lobby	6	1,678	SF	\$3,959	
Corridors	Corridors	Plaster/Drywall	Main Stairs	6	3,142	SF	\$7,414	
Corridors	Corridors	Single Water Cooler	1st Floor	6	1	EA	\$615	
Corridors	Corridors	Single Water Cooler	2nd Floor	6	1	EA	\$615	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Basement			LF	\$0	
Corridors	Corridors	Stair Handrails	Main Building Vestibules; e,w, Auditorium lobby	6	30	LF	\$0	
Corridors	Corridors	Stair Handrails	Main Stairs	7	151	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor	6	26	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair to Assembly	6	32	LF	\$0	
Corridors	Corridors	Stairs	Basement			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	2nd Floor	6	443	SF	\$3,167	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Main Stairs			EA	\$0	
Corridors	Corridors	Student Lockers	Main Building Vestibules; e,w, Auditorium lobby			EA	\$0	
Corridors	Corridors	Student Lockers	Stair to Assembly			EA	\$0	
Corridors	Corridors	Student Lockers	Basement			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Terrazzo	Main Stairs	6	473	SF	\$2,679	
Corridors	Corridors	Terrazzo	Main Building Vestibules; e,w, Auditorium lobby	6	540	SF	\$3,058	
Corridors	Corridors	Terrazzo	Stair to Assembly	6	20	SF	\$113	
Corridors	Corridors	Terrazzo	2nd Floor	6	154	SF	\$872	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	374	SF	\$535	
Corridors	Corridors	Tile/Sheet Flooring	Main Stairs	6	68	SF	\$97	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	353	SF	\$505	
Corridors	Corridors	Wall Mounted	Main Stairs	4	2	EA	\$7,722	
Corridors	Corridors	Walls	Main Building Vestibules; e,w, Auditorium lobby	6	73	SF	\$172	

**Building: Main
Category: ROOM**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors Ceiling	Corridors	Plaster/Drywall	Basement	6	435	SF	\$1,232	
Corridors Ceiling	Corridors	Plaster/Drywall	Main Stairs	5	729	SF	\$4,128	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	6	528	SF	\$1,495	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	6	353	SF	\$999	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair to Assembly	6	38	SF	\$108	
Corridors Ceiling	Corridors	Plaster/Drywall	Main Building Vestibules; e,w, Auditorium lobby	6	540	SF	\$1,529	
Stairs	Corridors	Terrazzo	Main Stairs	6	72	SF	\$815	
Stairs	Corridors	Terrazzo	2nd Floor	6	16	SF	\$181	
Stairs	Corridors	Terrazzo	Stair to Assembly	6	21	SF	\$238	
Stairs	Corridors	Terrazzo	Main Building Vestibules; e,w, Auditorium lobby	6	12	SF	\$136	
GYM_WALL	Standard Dedicated Gymnasium	Gymnasia Walls	2nd Floor	6	1,440	SF	\$12,355	
RESTROOM_WALL	Adult Standard Student Restroom	Restroom Walls	Men Assembly Lobby Basement	4	348	SF	\$10,839	
THEATER_CEILING	Auditorium - Dedicated	Auditorium Ceiling	Basement	6	2,505	SF	\$21,421	
THEATER_FLOOR	Auditorium - Dedicated	Auditorium Floor	Basement		2,026	SF	\$0	
THEATER_LIGHT	Auditorium - Dedicated	Auditorium Lighting	Basement	6	6	EA	\$1,931	
THEATER_WALL	Auditorium - Dedicated	Auditorium Walls	Basement	6	491	SF	\$1,018	
ROOM Sub Total							\$98,395	
Building Main Sub Total							\$741,669	

**Building: Addition (1954/1961)
Category: EXTERIOR**

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	Along Ladder	5	20	LF	\$35,750	
Chimney		Brick Chimney - Concrete/ Mortar Liner	East	6	30	LF	\$15,015	
Doors		Exterior FRP Door	Entire Building	6	8	EA	\$4,455	
Doors		Exterior Steel Door	Door 6	6	2	EA	\$661	
Doors		Transom Lite	Doors 1 and 2	7	4	EA	\$0	
Entrance		Concrete Exterior Stairs	Door 6	6	9	LF	\$965	
Entrance		Concrete Ramp	Door 6	6	8	LF	\$1,115	
Entrance		Entrance Controls - Audio and Video	Door 2	7	1	EA	\$0	
Entrance		Ramp Handrails	Door 6	6	4	LF	\$0	
Entrance		Stair Handrails	Door 6	6	4	LF	\$0	

Building: Addition (1954/1961)

Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Stone Stairs	Doors 1 and 2	6	14	LF	\$2,503	
Foundation		Concrete Foundation	Entire Building	7	668	LF	\$0	
Foundation		Concrete Foundation	Boiler House Along East and West Walls	5	71	LF	\$31,696	
Lighting		Exterior Lights - Parapet or Roof Mounted	Roof	7	14	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	4	EA	\$0	
Lintels		Lintels - Steel	Entire Building	6	469	LF	\$17,706	
Lintels		Lintels - Stone	2nd Story Windows	6	341	LF	\$0	
Parapet		Coping - Metal	Southeast	6	20	LF	\$0	
Parapet		Coping - Stone	Entire Building	6	851	LF	\$0	
Parapet		Parapet < 16" Height	Southeast	6	20	LF	\$3,115	
Parapet		Parapet 16" to 30" Height	Entire Building	6	851	LF	\$176,698	
Roof System		Asphalt Gravel Ballast Roof	Entire Building	7	21,478	SF	\$0	
Roof System		Exterior Downspouts	Southeast	6	17	LF	\$316	
Roof System		Interior Downspouts	Northeast Drain	5	10	LF	\$1,073	
Roof System		Interior Downspouts	Entire Building	6	302	LF	\$0	
Roof System		Roof Structure: Concrete	Entire Building	7	21,478	SF	\$0	
Superstructure		Concrete	Entire Building	7	61,814	SF	\$0	
Walls		Brick	Entire Building	6	25,179	SF	\$166,348	
Walls		Stone - Cut	Entire Building	6	1,746	SF	\$24,968	
Windows		Window - Guards perforated	Entire Building	7	1,965	SF	\$0	
Windows		Windows - Decorative	West, Above Entrances	5	96	SF	\$9,568	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	5,274	SF	\$0	
EXTERIOR Sub Total							\$491,950	

Building: Addition (1954/1961)

Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	9,986	SF	\$4,284	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	6	1,588	SF	\$681	
Emergency System		Emergency Battery Packs - Corridors and Stairs	1st Floor	7	3	EA	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Basement	7	3	EA	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	2nd Floor	7	2	EA	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	3rd Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Basement	7	8	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	4	EA	\$0	

Building: Addition (1954/1961)
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Exit Signs - Corridors and Stairs	3rd Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	3	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Basement	7	2	EA	\$0	
Emergency System		Independent Electrical Service for emergency power	Electrical Room	7	1	EA	\$0	
Emergency System		Public Announcement System	1st Floor	7	74,464	SF	\$0	
Emergency System		Security System - Intrusion detection	1st Floor	4	74,464	SF	\$298,154	
Main Service		Main Electrical service - Live Front - 2000 to 3000 A 120/208/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Basement	4	3	EA	\$16,302	
Power Distribution		Lighting and power panels	2nd Floor	7	2	EA	\$0	
Power Distribution		Lighting and power panels	Basement	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Pump Room	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	Pump Room	7	2	EA	\$0	
Power Distribution		Lighting and power panels	2nd Floor	6	2	EA	\$1,430	
Power Distribution		Lighting and power panels	Electrical Room	7	4	EA	\$0	
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	
Power Distribution		Lighting and power panels	1st Floor	7	2	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	2	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	2	EA	\$0	
Power Distribution		Transformers 120/240-120/208	Electrical Room	7	1	EA	\$0	
ELECTRICAL Sub Total							\$332,434	

Building: Addition (1954/1961)
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Basement	4	61,814	SF	\$218,333	
FIRE PROTECTION Sub Total							\$218,333	

Building: Addition (1954/1961)
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	2nd Floor	6	17	EA	\$3,647	
Air Conditioning		Window A/C Unit	1st Floor	6	19	EA	\$4,076	
Air Conditioning		Window A/C Unit	MDF Room	7	1	EA	\$0	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	6	1	EA	\$1,430	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Southeast Area Well	6	1	EA	\$1,430	

Building: Addition (1954/1961)

Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Basement	5	1	EA	\$35,750	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Basement	4	1	EA	\$128,700	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Basement	5	1	EA	\$12,870	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Basement	5	1	EA	\$17,160	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Entire Building	4	200	LF	\$529,100	Missing System.
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	4	2	EA	\$294,580	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	4	2	EA	\$45,760	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	7	1	EA	\$0	
Boiler Systems		Combustion Dampers	Boiler Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	6	1	EA	\$8,437	
Boiler Systems		Gas Boosters	Boiler Room	6	2	EA	\$2,603	
Heating Devices		Cabinet Heaters With Steam Coils	2nd Floor	6	1	EA	\$501	
Heating Devices		Cabinet Heaters With Steam Coils	1st Floor	6	1	EA	\$501	
Heating Devices		Fin Tube Electric	3rd Floor	6	50	LF	\$715	
Heating Devices		Fin Tube Electric	2nd Floor	6	6	LF	\$86	
Heating Devices		Radiators - Steam	1st Floor	5	6	EA	\$3,947	
Heating Devices		Radiators - Steam	2nd Floor	5	6	EA	\$3,947	
Heating Devices		Radiators - Steam	Basement	5	7	EA	\$4,605	
Heating Devices		Unit Heater - Electric	MDF Room	7	1	EA	\$0	
Heating Devices		Unit Heater - Electric	Electrical Room	7	2	EA	\$0	
Heating Devices		Unit Heater - Gas	Boiler Room	4	1	EA	\$11,440	
Heating Devices		Wall Heater - Electric	1st Floor	4	3	EA	\$3,089	
Heating Devices		Wall Heater - Electric	Basement	4	5	EA	\$5,148	
Heating Devices		Wall Heater - Electric	2nd Floor	4	3	EA	\$3,089	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Basement	6	1	EA	\$715	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Pump Room	6	1	EA	\$715	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	5	200	LF	\$6,507	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	200	LF	\$9,896	
Mechanical Plumbing		Pumps - Vacuum	Basement	6	1	EA	\$2,860	
Temperature Control		Pneumatic System	Pump Room	4	74,464	SF	\$532,418	
Temperature Control		Thermostats - Pneumatic	2nd Floor	6	5	EA	\$715	
Temperature Control		Thermostats - Pneumatic	1st Floor	4	10	EA	\$6,578	
Temperature Control		Thermostats - Pneumatic	Basement	6	2	EA	\$286	

Building: Addition (1954/1961)

Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Temperature Control		Thermostats - Pneumatic	1st Floor	6	6	EA	\$858	
Temperature Control		Thermostats - Pneumatic	Basement	4	4	EA	\$2,631	
Temperature Control		Thermostats - Pneumatic	2nd Floor	4	11	EA	\$7,236	
Temperature Control		Zone Dampers	Basement	6	29	EA	\$4,147	
Temperature Control		Zone Dampers	Basement	4	2	EA	\$1,687	
Unit Ventilation		Unit Ventilators - Steam	1st Floor	4	6	EA	\$94,380	
Unit Ventilation		Unit Ventilators - Steam	Basement	4	2	EA	\$31,460	
Unit Ventilation		Unit Ventilators - Steam	2nd Floor	4	6	EA	\$94,380	
Ventilation		Exhaust Fan - Indoor	Electrical Room	6	2	EA	\$1,001	
Ventilation		Exhaust Fan - Indoor	Attic	5	2	EA	\$3,718	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	4	2	EA	\$8,580	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Basement	6	1	EA	\$1,716	
MECHANICAL Sub Total							\$1,935,662	

Building: Addition (1954/1961)

Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas less than 150,000 BTU/HR	Boiler Room	4	1	EA	\$14,872	
Hot Water		Storage Tank less than 500 gallons	Pump Room	7	1	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	5	61,814	SF	\$10,607	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	61,814	SF	\$20,331	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	5	61,814	SF	\$70,715	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	61,814	SF	\$13,259	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	61,814	SF	\$15,911	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	61,814	SF	\$54,804	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	5	61,814	SF	\$32,706	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	61,814	SF	\$33,590	
Piping		Sanitary Piping	Entire Building	5	61,814	SF	\$38,009	
Piping		Storm Piping	Entire Building	5	61,814	SF	\$29,170	
Piping		Vent Piping	Entire Building	5	61,814	SF	\$22,099	
Pumps		Domestic Booster Pump simplex	Pump Room	5	1	EA	\$8,580	
Pumps		Ejector Pump	Pump Room	6	1	EA	\$3,003	
Pumps		Sump Pump	Basement	6	1	EA	\$1,359	
PLUMBING Sub Total							\$369,014	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Copy Room	4	135	SF	\$1,784	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Library work room	7	214	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office	6	312	SF	\$883	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Conference Room in Main Office	6	142	SF	\$402	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Copy Room area Main Office	6	52	SF	\$147	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	104 Principals office	6	339	SF	\$960	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Custodial Break Room	6	173	SF	\$490	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Lunchroom Work Office	6	398	SF	\$1,127	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Basement Teachers lounge	6	501	SF	\$1,419	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Conference Room in Main Office	6	142	SF	\$203	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Copy Room area Main Office	6	52	SF	\$74	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	Custodial Break Room	5	173	SF	\$816	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Lunchroom Work Office	6	398	SF	\$569	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Library work room	7	214	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office	6	100	SF	\$143	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Basement Teachers lounge	6	501	SF	\$716	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	104 Principals office	6	339	SF	\$485	
Administrative Suites	Administrative Suites/Offices	Flooring - Wood	Copy Room	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Copy Room	4	1	SF	\$7	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Library work room	7	2	SF	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Copy Room area Main Office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	104 Principals office	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Custodial Break Room	6	1	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Basement Teachers lounge	6	8	SF	\$6	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Lunchroom Work Office	7	9	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Conference Room in Main Office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	6	953	SF	\$2,249	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Lunchroom Work Office	6	722	SF	\$1,704	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Conference Room in Main Office	6	629	SF	\$1,484	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Copy Room area Main Office	6	341	SF	\$805	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	104 Principals office	6	982	SF	\$2,317	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Custodial Break Room	6	711	SF	\$1,678	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Basement Teachers lounge	6	1,006	SF	\$2,374	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Copy Room	6	647	SF	\$1,527	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Library work room	6	728	SF	\$1,718	
Doors		Interior Steel Doors incl hw	Corridor - 1st Floor	6	9	EA	\$2,548	
Doors		Interior Wood Doors incl hw	NW Stair	6	2	EA	\$566	
Doors		Interior Wood Doors incl hw	Middle Stair	6	2	EA	\$566	
Doors		Interior Wood Doors incl hw	Entire Building	5	17	EA	\$8,022	
Doors		Interior Wood Doors incl hw	Entire Building	6	54	EA	\$15,290	
Doors		Transom Window	NW Stair	6	14	SF	\$260	
Drinking Fountains	Corridors	Single Fountain	1st Floor	6	2	EA	\$772	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	6	2	EA	\$772	
Library	Library	Casework	2nd Floor	6	7	LF	\$215	
Library	Library	Flooring Carpet	2nd Floor	7	1,213	SF	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Library	Library	Lighting - Pendant/ Surface	2nd Floor	7	32	SF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Basement Boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl. North Girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd Floor North			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd Floor Girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st Floor North			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd Fl. Teachers Library Restroom			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	101			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st Floor Boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st Floor Girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl. in copy room			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Main Office			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	Lunchroom office restroom			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl. North Girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd Floor Boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd Floor Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl. North Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st Floor Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st Floor Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd Floor North			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd Floor Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl. North Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	101			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Main Office			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd Fl. Teachers Library Restroom			EA	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Lockers	1st fl. in copy room			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Basement Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st Floor North			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	Lunchroom office restroom	5	5	EA	\$810	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl. North Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Basement Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl. in copy room			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Main Office			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	Lunchroom office restroom			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	101			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl. North Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st Floor North			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st Floor Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd Floor North			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd Floor Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd Floor Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd Fl. Teachers Library Restroom			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st Floor Girls			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	Multipurpose/PumpRoom	6	650	SF	\$1,840	
Lunchroom	Multipurpose Room	Ceiling - Plaster/Drywall	Basement	6	2,697	SF	\$7,636	
Lunchroom	Lunchroom	Ceiling - Plaster/Drywall	Lunch Room Servery/Play area	6	650	SF	\$1,840	
Lunchroom	Lunchroom	Ceiling - Splined	Basement	6	1,697	SF	\$3,640	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	Basement	6	1,697	SF	\$2,427	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	Basement	7	18	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Lunch Room Servery/Play area	7	4	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Basement	7	35	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Multipurpose/PumpRoom	7	4	SF	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Lunchroom	Serving Line	Basement			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	Basement			LF	\$0	
Lunchroom	Lunchroom	Serving Line	Multipurpose/PumpRoom			LF	\$0	
Lunchroom	Lunchroom	Serving Line	Lunch Room Servery/Play area			LF	\$0	
Lunchroom	Lunchroom	Wall - Concrete Block	Lunch Room Servery/Play area	6	350	SF	\$1,001	
Lunchroom	Multipurpose Room	Wall - Concrete Block	Basement	6	462	SF	\$1,321	
Lunchroom	Lunchroom	Wall - Concrete Block	Multipurpose/PumpRoom	6	350	SF	\$1,001	
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	Basement	6	925	SF	\$2,183	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	Basement	6	1,593	SF	\$3,759	
MDF/IDF		Finishes	1st Floor North End	6	233	SF	\$793	
MDF/IDF		Ventilation and Cooling	1st Floor North End	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	1st Floor South	6	1	SF	\$5	
Mechanical/Service Rooms		Janitor's Closet	2nd Fl. North	6	1	SF	\$5	
Mechanical/Service Rooms		Janitor's Closet	2nd Fl. South	6	1	SF	\$5	
Mechanical/Service Rooms		Janitor's Closet	1st Floor North	6	1	SF	\$5	
Mechanical/Service Rooms		Storage Room	1st Floor	5	64	SF	\$725	
Mechanical/Service Rooms		Storage Room	101	6	196	SF	\$925	
Mechanical/Service Rooms		Storage Room	Basement Lunchroom storage	6	96	SF	\$453	
Mechanical/Service Rooms		Storage Room	Library Work storage	6	29	SF	\$137	
Mechanical/Service Rooms		Storage Room	2nd fl. North End of Corridor	6	233	SF	\$1,100	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boys			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Basement Boys			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Main Office	6	38	SF	\$293	
Staff Restroom	Adult Standard Student Restroom	Accessories	Lunchroom office restroom	6	82	SF	\$633	
Staff Restroom	Children's Standard Student Restroom	Accessories	101	5	46	SF	\$1,172	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl. North Girls			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st Floor North			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Girls	7	251	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor North			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Boys			SF	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Girls	7	251	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Fl. Teachers Library Restroom			SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl. in copy room			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl. North Girls			SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	Lunchroom office restroom	6	82	SF	\$232	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor North	6	48	SF	\$136	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Boys	6	285	SF	\$807	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Girls	7	251	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	101	6	46	SF	\$130	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Fl. Teachers Library Restroom	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Boys	6	285	SF	\$807	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Basement Boys	6	285	SF	\$807	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st fl. in copy room	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl. North Girls	6	175	SF	\$495	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st Floor North	6	48	SF	\$136	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Girls	7	251	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl. North Girls	6	175	SF	\$495	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Main Office	6	38	SF	\$108	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Basement Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Main Office			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	Lunchroom office restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	101			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd Fl. Teachers Library Restroom			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st Floor North			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boys	7	2	EA	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Girls	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	2nd Floor North			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl. in copy room			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl. North Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl. North Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Girls	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Girls	6	251	SF	\$639	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Basement Boys	6	285	SF	\$725	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Lunchroom office restroom	6	16	SF	\$41	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	101	6	46	SF	\$117	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Boys	6	285	SF	\$725	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl. North Girls	6	175	SF	\$445	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Boys	6	285	SF	\$725	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Girls	6	251	SF	\$639	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl. North Girls	6	175	SF	\$445	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Main Office	6	38	SF	\$54	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st fl. in copy room	7	36	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile/Sheet	Lunchroom office restroom	5	82	SF	\$464	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st Floor North	7	48	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd Floor North	7	48	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd Fl. Teachers Library Restroom	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd Fl. Teachers Library Restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	101			EA	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl. North Girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st Floor North			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Boys			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd Floor North			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl. North Girls			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	Lunchroom office restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl. in copy room			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Main Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Basement Boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	101	6	1	EA	\$372	
Staff Restroom	Adult Standard Student Restroom	Lavatory	Lunchroom office restroom	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	1st Floor North	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Main Office	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Basement Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor North	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl. in copy room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl. North Girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Girls	4	1	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Boys	7	2	EA	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	2nd Fl. Teachers Library Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl. North Girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st Floor North	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd Floor North	4	1	SF	\$4	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	Lunchroom office restroom	6	2	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	101	6	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st fl. in copy room	5	1	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Basement Boys	4	6	SF	\$26	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl. North Girls	4	3	SF	\$13	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Boys	4	6	SF	\$26	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Girls	4	4	SF	\$17	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl. North Girls	4	3	SF	\$13	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor Boys	4	6	SF	\$26	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor Girls	4	4	SF	\$17	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Fl. Teachers Library Restroom	5	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Main Office	6	2	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	2nd Floor North	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	1st Floor North	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Partitions	1st Floor North	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	Lunchroom office restroom			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Main Office	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	101			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Basement Boys	6	4	EA	\$717	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boys	6	4	EA	\$717	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Girls	7	7	EA	\$0	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Partitions	2nd Floor North	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl. North Girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Boys	6	4	EA	\$717	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Girls	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd Fl. Teachers Library Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl. North Girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl. in copy room	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	101			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Basement Boys	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl. in copy room			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd Fl. Teachers Library Restroom			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	Lunchroom office restroom			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl. North Girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st Floor North			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd Floor North			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl. North Girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Main Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl. North Girls	6	273	SF	\$644	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	Basement Boys	6	147	SF	\$347	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st fl. in copy room	5	258	SF	\$1,218	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Main Office	6	116	SF	\$274	

Building: Addition (1954/1961)

Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	Lunchroom office restroom	6	517	SF	\$1,220	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	101	5	367	SF	\$1,732	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl. North Girls	6	273	SF	\$644	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	1st Floor North	6	250	SF	\$590	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Boys	6	147	SF	\$347	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor North	6	250	SF	\$590	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor Boys	6	147	SF	\$347	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd Floor Girls	6	156	SF	\$368	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Fl. Teachers Library Restroom	5	258	SF	\$1,218	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st Floor Girls	6	156	SF	\$368	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl. North Girls	6	408	SF	\$2,917	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor Girls	6	767	SF	\$5,484	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	Main Office	6	116	SF	\$829	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor Boys	6	834	SF	\$5,963	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor Girls	6	767	SF	\$5,484	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl. North Girls	6	408	SF	\$2,917	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor Boys	6	834	SF	\$5,963	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Basement Boys	6	834	SF	\$5,963	
Staff Restroom	Staff Restroom	Water Closet	1st fl. in copy room	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Main Office	6	1	EA	\$372	
Staff Restroom	Adult Standard Student Restroom	Water Closet	Lunchroom office restroom	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	101	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl. North Girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boys	7	4	EA	\$0	

Building: Addition (1954/1961)
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	2nd Floor North	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Basement Boys	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Boys	4	1	EA	\$3,718	
Staff Restroom	Staff Restroom	Water Closet	1st Floor North	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Girls	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Fl. Teachers Library Restroom	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl. North Girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Girls	7	7	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total \$156,808

Building: Addition (1954/1961)
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_FLOOR	Administrative Suites/Offices	Administrative Office Floor	Main Office	6	185	SF	\$265	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Lunchroom Work Office	6	180	SF	\$425	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	20	LF	\$715	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	46	LF	\$1,645	

Building: Addition (1954/1961)
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		6	1,181	SF	\$3,344	
Ceiling	Classroom	Plaster/Drywall		7	1,347	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	1,043	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	707	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	694	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	694	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	694	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	694	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	694	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	694	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	694	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	707	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	694	SF	\$0	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	Basement	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	Lunch Room Servery/Play area	4		LF		
Chalk Board	Multipurpose Room	Chalk Board	Basement	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		

Building: Addition (1954/1961)

Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	Multipurpose/PumpRoom	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Corridors	Corridors	Ceiling	1st Floor		2,415	SF	\$0	
Corridors	Corridors	Concrete Block	Main Stair Vestibule	6	314	SF	\$898	
Corridors	Corridors	Concrete Block	Multipurpose/Custodial Rm. Vestibules	6	195	SF	\$558	
Corridors	Corridors	Concrete Epoxy/Painted	Middle Stair	6	36	SF	\$170	
Corridors	Corridors	Concrete Epoxy/Painted	Multipurpose/Custodial Rm. Vestibules	5	165	SF	\$779	
Corridors	Corridors	Concrete Epoxy/Painted	Basement	6	2,413	SF	\$11,387	
Corridors	Corridors	Concrete Epoxy/Painted	NW Stair	6	32	SF	\$151	
Corridors	Corridors	Drinking Fountains	1st Floor			EA	\$0	
Corridors	Corridors	Drinking Fountains	Multipurpose/Custodial Rm. Vestibules			EA	\$0	
Corridors	Corridors	Drinking Fountains	Middle Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair - Door 8 Basement			EA	\$0	
Corridors	Corridors	Drinking Fountains	NW Stair			EA	\$0	
Corridors	Corridors	Drop/Lay-In	NW Stair	6	76	SF	\$163	
Corridors	Corridors	Floors	1st Floor		2,415	SF	\$0	
Corridors	Corridors	Lay-In	NW Stair	4	76	EA	\$462	
Corridors	Corridors	Lighting	1st Floor			EA	\$0	
Corridors	Corridors	Pendant/Surface	Multipurpose/Custodial Rm. Vestibules	6	3	EA	\$2	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	2,415	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	2,415	EA	\$0	
Corridors	Corridors	Pendant/Surface	Middle Stair	6	331	EA	\$237	
Corridors	Corridors	Pendant/Surface	Basement	7	2,413	EA	\$0	
Corridors	Corridors	Pendant/Surface	Door S Vestibule	6	1	EA	\$1	
Corridors	Corridors	Pendant/Surface	Stair - Door 8 Basement	7	1	EA	\$0	
Corridors	Corridors	Pendant/Surface	Main Stair Vestibule	4	1	EA	\$10	

Building: Addition (1954/1961)

Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Pendant/Surface	NW Stair	6	234	EA	\$167	
Corridors	Corridors	Plaster/Drywall	Door S Vestibule	6	25	SF	\$59	
Corridors	Corridors	Plaster/Drywall	Basement	6	1,411	SF	\$3,329	
Corridors	Corridors	Plaster/Drywall	NW Stair	6	1,653	SF	\$3,900	
Corridors	Corridors	Plaster/Drywall	Middle Stair	6	899	SF	\$2,121	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	2,185	SF	\$5,156	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	5,464	SF	\$12,892	
Corridors	Corridors	Single Water Cooler	Basement	6	2	EA	\$1,230	
Corridors	Corridors	Stair Handrails	Middle Stair	6	102	LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Stair - Door 8 Basement	6	69	LF	\$0	
Corridors	Corridors	Stair Handrails	Basement			LF	\$0	
Corridors	Corridors	Stair Handrails	Multipurpose/Custodial Rm. Vestibules			LF	\$0	
Corridors	Corridors	Stair Handrails	NW Stair	6	94	LF	\$0	
Corridors	Corridors	Stairs	Basement			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Multipurpose/Custodial Rm. Vestibules			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	Basement	6	2,117	SF	\$15,137	
Corridors	Corridors	Structural Glazed Tile	Door S Vestibule	7	25	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor	6	3,279	SF	\$23,445	
Corridors	Corridors	Structural Glazed Tile	NW Stair	7	370	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Middle Stair	7	615	SF	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	6	154	EA	\$22,022	
Corridors	Corridors	Student Lockers	Stair - Door 8 Basement			EA	\$0	
Corridors	Corridors	Student Lockers	Basement			EA	\$0	
Corridors	Corridors	Student Lockers	Multipurpose/Custodial Rm. Vestibules			EA	\$0	
Corridors	Corridors	Student Lockers	Middle Stair			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	6	133	EA	\$19,019	
Corridors	Corridors	Student Lockers	NW Stair			EA	\$0	
Corridors	Corridors	Terrazzo	NW Stair	6	262	SF	\$1,484	
Corridors	Corridors	Terrazzo	Middle Stair	6	310	SF	\$1,755	
Corridors	Corridors	Terrazzo	Door S Vestibule	6	58	SF	\$328	
Corridors	Corridors	Terrazzo	Main Stair Vestibule	6	105	SF	\$595	
Corridors	Corridors	Terrazzo	Stair - Door 8 Basement	6	206	SF	\$1,167	

Building: Addition (1954/1961)

Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Tile Ceramic/Porcelain	NW Stair	6	76	SF	\$193	
Corridors	Corridors	Tile Ceramic/Porcelain	Middle Stair	6	76	SF	\$193	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	2,415	SF	\$3,453	
Corridors	Corridors	Tile/Sheet Flooring	Middle Stair	6	30	SF	\$43	
Corridors	Corridors	Tile/Sheet Flooring	NW Stair	6	76	SF	\$109	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	2,415	SF	\$3,453	
Corridors	Corridors	Wall Mounted	NW Stair	4	84	EA	\$324,324	
Corridors	Corridors	Wall Mounted	Middle Stair	4	82	EA	\$316,602	
Corridors	Corridors	Wall Mounted	Stair - Door 8 Basement	7	3	EA	\$0	
Corridors	Corridors	Walls	Stair - Door 8 Basement			SF	\$0	
Corridors	Corridors	Walls	Multipurpose/Custodial Rm. Vestibules	6	715	SF	\$1,687	
Corridors	Corridors	Walls	1st Floor			SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Middle Stair	6	448	SF	\$1,268	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair - Door 8 Basement	6	304	SF	\$861	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	6	2,415	SF	\$6,838	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	6	2,415	SF	\$6,838	
Corridors Ceiling	Corridors	Plaster/Drywall	Main Stair Vestibule	6	105	SF	\$297	
Corridors Ceiling	Corridors	Plaster/Drywall	NW Stair	6	407	SF	\$1,152	
Corridors Ceiling	Corridors	Plaster/Drywall	Door S Vestibule	6	58	SF	\$164	
Corridors Ceiling	Corridors	Plaster/Drywall	Basement	6	2,413	SF	\$6,832	
Corridors Ceiling	Corridors	Plaster/Drywall	Multipurpose/Custodial Rm. Vestibules	5	165	SF	\$934	
Stairs	Corridors	Terrazzo	Stair - Door 8 Basement	6	37	SF	\$419	
Stairs	Corridors	Terrazzo	Middle Stair	6	49	SF	\$555	
Stairs	Corridors	Terrazzo	NW Stair	6	47	SF	\$532	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	707	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	
Floor	Classroom	Tile/Sheet		7	694	SF	\$0	

Building: Addition (1954/1961)

Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Multipurpose Room	Marker Board	Basement			LF	\$0	
Marker Board	Lunchroom	Marker Board	Multipurpose/PumpRoom			LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Lunchroom	Marker Board	Lunch Room Servery/Play area			LF	\$0	
Marker Board	Lunchroom	Marker Board	Basement			LF	\$0	
Marker Board	Classroom	Marker Board		6	4	LF	\$114	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Wall	Classroom	Masonry		6	1,627	SF	\$20,939	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,004	SF	\$2,369	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,004	SF	\$2,369	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		4	5	SF	\$47	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,004	SF	\$2,369	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,004	SF	\$0	

Building: Addition (1954/1961)
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		7	1,004	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,004	SF	\$2,369	
Wall	Classroom	Plaster/Drywall		6	1,004	SF	\$2,369	
Wall	Classroom	Plaster/Drywall		4	5	SF	\$47	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,179	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,518	SF	\$3,582	
Wall	Classroom	Plaster/Drywall		6	1,771	SF	\$4,179	
Wall	Classroom	Plaster/Drywall		6	1,004	SF	\$2,369	

ROOM Sub Total \$896,223

Building Addition (1954/1961) Sub Total \$4,400,425

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Athletic		Football/Soccer - Synthetic including exc and retention	Site - East	7	29,606	SF	\$0	
Civil/Drainage		Catch Basin	Entire Site	7	8	EA	\$0	
Civil/Drainage		Site Drain	Door 6	6	1	EA	\$112	
Civil/Drainage		Site Manhole	Entire Site	7	11	EA	\$0	
Fencing		Chain Link	Entire Site	6	394	LF	\$5,651	
Fencing		Chain Link	Around Fire Escape	5	35	LF	\$1,251	
Fencing		Ornamental Iron	Entire Site	6	1,255	LF	\$23,689	
Landscape		Benches	Entire Building	7	20	EA	\$0	
Landscape		Grass	Entire Site	7	7,361	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	11,561	SF	\$0	
Landscape		Hardscape - Pavers	Southeast	7	288	SF	\$0	
Landscape		Irrigation	Site - East	5	7,361	SF	\$13,895	
Landscape		Parkway trees	Entire Site	7	35	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	7,466	SF	\$0	
Landscape		Trash Receptacles	Entire Site	7	7	EA	\$0	
Parking Lot		Asphalt	Site ĳ North	7	29,257	SF	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Concrete Curbs	Site ζ North	7	1,120	LF	\$0	
Parking Lot		Parking lot interior plantings	Site ζ North	7	4	LF	\$0	
Parking Lot		Trash Enclosure	Site ζ North	7	1,525	SF	\$0	
Playground		Playground - Swingset	Site - East	7	1	EA	\$0	
Playground		Playground Equipment - School Age 5-12	Site - East	7	1	EA	\$0	
Playground		Playground Equipment - School Age 5-12	Site - East	5	1	EA	\$0	
Playground		Playground Surfacing - Wood Chips	Site - East	4	3,904	SF	\$25,122	
Sidewalks		Perimeter Sidewalks	Entire Site	6	11,248	SF	\$21,232	
Signage		Flag Pole	Site ζ West	7	1	EA	\$0	
Signage		Marquee - Building Mounted Back Lighted w/ LED	Southwest Corner	7	2	EA	\$0	
SITE Sub Total							\$90,952	
SITE Sub Total							\$90,952	

Total Campus Need ^{2 3} \$5,233,046

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
Other									N	N	N	Corridors		Main Stairs
Other	99								N	N	N	Restroom	Adult Standard Student Restroom	Women Assembly Lobby Basement
Other	528								N	N	N	Corridors		2nd Floor
Other	353								N	N	N	Corridors		1st Floor
Other	435								N	N	N	Corridors		Basement
Other	38								N	N	N	Corridors		Stair to Assembly
Other	375			8					N	N	N	Administrative Suites/Offices		2nd floor Main Office
Other	2026								N	N	N	Auditorium & Theater	Auditorium - Dedicated	Basement
Other	118			2					N	N	Y	Administrative Suites/Offices		Gym Office
Other	2734								N	N	N	Gymnasia	Standard Dedicated Gymnasium	2nd Floor
Other	87								N	N	N	Restroom	Adult Standard Student Restroom	Men Assembly Lobby Basement
Other	540								N	N	N	Corridors		Main Building Vestibules; e,w, Auditorium lobby

Building: Addition (1954/1961)

004	1347			10	40	96	37		N	N	Y	Classroom		
101	1181			16	40	220	72	2	N	N	Y	Classroom		
102	1043	1	2	10	40	180	90	2	N	N	Y	Classroom		
103	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
105	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
107	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
108	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
109	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
110	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
111	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
112	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
113	707	1	4	6	40	105	52	1	N	N	Y	Classroom		
114	707	1	4	6	40	105	52	1	N	N	Y	Classroom		
115	707	1	4	6	40	105	52	1	N	N	Y	Classroom		
116	707	1	4	6	40	105	52	1	N	N	Y	Classroom		
202	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
203	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
204	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
205	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
206	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
207	694	1	3	10	40	110	55	1	N	N	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
208	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
209	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
210	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
211	694	1	3	10	40	110	55	1	N	Y	Y	Classroom		
212	694	1	3	10	40	110	55	1	N	N	Y	Classroom		
213	707	1	4	6	40	105	52	1	N	N	Y	Classroom		
214	707	1	4	6	40	105	52	1	N	N	Y	Classroom		
215	707	1	4	6	40	105	52	1	N	N	Y	Classroom		
216	707	1	4	6	40	105	52	1	N	N	Y	Classroom		
Other	2415								N	N	N	Corridors		1st Floor
Other	48								N	N	N	Restroom	Staff Restroom	2nd Floor North
Other	36								N	N	N	Restroom	Staff Restroom	1st fl. in copy room
Other	175								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl. North Girls
Other	285								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Boys
Other	251								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Girls
Other	214			6					N	N	Y	Administrative Suites/Offices		Library work room
Other	36								N	N	N	Restroom	Staff Restroom	2nd Fl. Teachers Library Restroom
Other	2413								N	N	N	Corridors		Basement
Other	135			10					N	N	N	Administrative Suites/Offices		Copy Room
Other	1697								N	N	N	Lunch & Multipurpose Room	Lunchroom	Basement
Other	105								N	N	N	Corridors		Main Stair Vestibule
Other	2415								N	N	N	Corridors		1st Floor
Other	2415								N	N	N	Corridors		2nd Floor
Other	58								N	N	N	Corridors		Door S Vestibule
Other									N	N	N	Corridors		Stair - Door 8 Basement
Other	1213								N	N	N	Library		2nd Floor
Other	339			6					N	N	Y	Administrative Suites/Offices		104 Principals office
Other	46								N	N	N	Restroom	Children's Standard Student Restroom	101
Other	175								N	N	N	Restroom	Children's Standard Student Restroom	1st fl. North Girls
Other	48								N	N	N	Restroom	Staff Restroom	1st Floor North
Other	285								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Boys
Other	251								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Girls
Other	38								N	N	N	Restroom	Staff Restroom	Main Office
Other	285								N	N	N	Restroom	Children's Standard Student Restroom	Basement Boys
Other	312			8					N	N	Y	Administrative Suites/Offices		Main Office
Other	650								N	N	N	Lunch & Multipurpose Room	Lunchroom	Lunch Room Servery/Play area
Other	52			4					N	N	N	Administrative Suites/Offices		Copy Room area Main Office

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	165								N	N	N	Corridors		Multipurpose/Custodial Rm. Vestibules
Other									N	N	N	Corridors		NW Stair
Other	173			6					N	N	N	Administrative Suites/Offices		Custodial Break Room
Other									N	N	N	Corridors		Middle Stair
Other	501			6					N	N	Y	Administrative Suites/Offices		Basement Teachers lounge
Other	82								N	N	N	Restroom	Adult Standard Student Restroom	Lunchroom office restroom
Other	398			10					N	N	N	Administrative Suites/Offices		Lunchroom Work Office
Other	650								N	N	N	Lunch & Multipurpose Room	Lunchroom	Multipurpose/PumpRoom
Other	2697								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	Basement
Other	142			6					N	N	Y	Administrative Suites/Offices		Conference Room in Main Office