

## Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at [http://www.cps.edu/About\\_CPS/Policies\\_and\\_guidelines/Pages/facilitystandards.aspx](http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx).

## Condition Rankings and Descriptions

**Rank 7:** The item/system is new or in good condition and no work is required.

**Rank 6:** The item/system requires general cleaning and/or routine maintenance.

**Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.

**Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.

**Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.

**Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.

**Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.<sup>1</sup>

## Definitions

**Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.

**Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").

**Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.

**For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**

**Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

## Building: Main

### Category: EXTERIOR

| Group      | Sub Group | Item                                   | Location            | Rank | Quantity | Unit | Cost     | Reason |
|------------|-----------|--|---------------------|------|----------|------|----------|--------|
| Chimney    |           | Brick Chimney - Concrete/ Mortar Liner | Roof                | 6    | 45       | LF   | \$22,523 |        |
| Doors      |           | Exterior FRP Door                      | Entire Building     | 7    | 12       | EA   | \$0      |        |
| Doors      |           | Store Front Door                       | Main Entrance       | 6    | 4        | EA   | \$2,076  |        |
| Entrance   |           | Entrance Controls - Audio and Video    | Main Entrance       | 6    | 1        | EA   | \$1,430  |        |
| Entrance   |           | Power Door Operator and Controls       | Main Entrance       | 7    | 2        | EA   | \$0      |        |
| Foundation |           | Concrete Foundation                    | Entire Building     | 7    | 640      | LF   | \$0      |        |
| Lighting   |           | Exterior Lights - Wall Mounted         | North Façade        | 4    | 1        | EA   | \$1,573  |        |
| Lighting   |           | Exterior Lights - Wall Mounted         | Entire Building     | 6    | 11       | EA   | \$2,360  |        |
| Lighting   |           | Exterior Lights - Wall Mounted         | Main Entrance       | 6    | 8        | EA   | \$1,716  |        |
| Lighting   |           | Exterior Lights - Wall Mounted         | East Façade         | 6    | 3        | EA   | \$644    |        |
| Lintels    |           | Lintels - Steel                        | Entire Building     | 7    | 648      | LF   | \$0      |        |
| Parapet    |           | Coping - Metal                         | Roof                | 6    | 845      | LF   | \$0      |        |
| Parapet    |           | Coping - Stone                         | Areaway             | 6    | 27       | LF   | \$0      |        |
| Parapet    |           | Coping - Stone                         | Above main entrance | 6    | 18       | LF   | \$0      |        |

**Building: Main**  
**Category: EXTERIOR**

| Group                     | Sub Group | Item  | Location                  | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|-----------|---|---------------------------|------|----------|------|------------------|--------|
| Parapet                   |           | Parapet < 16" Height                              | Roof                      | 6    | 723      | LF   | \$112,591        |        |
| Parapet                   |           | Parapet 16" to 30" Height                         | Roof                      | 6    | 122      | LF   | \$25,332         |        |
| Roof System               |           | Exterior Downspouts                               | Roof                      | 6    | 27       | LF   | \$502            |        |
| Roof System               |           | Interior Downspouts                               | Roof                      | 6    | 304      | LF   | \$0              |        |
| Roof System               |           | Metal Roof  | Roof                      | 7    | 3,358    | SF   | \$0              |        |
| Roof System               |           | Modified Bitumen Roof                             | Roof                      | 6    | 23,055   | SF   | \$163,195        |        |
| Roof System               |           | Roof Structure: Steel/Metal Deck/Concrete Topping | Roof                      | 7    | 26,413   | SF   | \$0              |        |
| Superstructure            |           | Steel   | Entire Building           | 7    | 66,550   | SF   | \$0              |        |
| Walls                     |           | Brick   | Entire Building           | 6    | 27,437   | SF   | \$181,265        |        |
| Walls                     |           | Prefabricated Metal Panel Wall                    | Main entrance, clerestory | 6    | 808      | SF   | \$6,863          |        |
| Windows                   |           | Clerestory - Glass Double-Pane                    | Roof                      | 6    | 330      | SF   | \$3,115          |        |
| Windows                   |           | Curtain wall - Glazed Double Pane                 | Main Entrance             | 6    | 560      | SF   | \$5,285          |        |
| Windows                   |           | Window - Guards perforated                        | Entire Building           | 6    | 1,959    | SF   | \$0              |        |
| Windows                   |           | Window - Guards wire guard                        | North Façade              | 6    | 798      | SF   | \$0              |        |
| Windows                   |           | Windows - Casement Aluminum Double-pane           | Entire Building           | 6    | 3,840    | SF   | \$21,965         |        |
| <b>EXTERIOR Sub Total</b> |           |   |                           |      |          |      | <b>\$552,433</b> |        |

**Building: Main**  
**Category: ELECTRICAL**

| Group            | Sub Group | Item   | Location             | Rank | Quantity | Unit | Cost      | Reason                  |
|------------------|-----------|--|----------------------|------|----------|------|-----------|-------------------------|
| Emergency System |           | Automatic Transfer switch                          | Electrical Room      | 4    | 1        | EA   | \$8,866   |                         |
| Emergency System |           | Emergency A/C power - Corridors and Stairs         | Corridors and Stairs | 7    | 11,191   | SF   | \$0       |                         |
| Emergency System |           | Emergency A/C power - Gym and Lunch rooms          | Lunch Room           | 7    | 3,590    | SF   | \$0       |                         |
| Emergency System |           | Emergency Battery Packs - Corridors and Stairs     | Corridors and Stairs | 7    | 53       | EA   | \$0       |                         |
| Emergency System |           | Emergency Battery Packs - Lunchroom and Gym        | Multi Purpose Room   | 7    | 2        | EA   | \$0       |                         |
| Emergency System |           | Emergency Battery Packs - Lunchroom and Gym        | Lunch Room           | 7    | 9        | EA   | \$0       |                         |
| Emergency System |           | Emergency Battery Packs - Lunchroom and Gym        | Gym                  | 7    | 7        | EA   | \$0       |                         |
| Emergency System |           | Emergency Battery Packs - Toilets                  | Student Toilets      | 7    | 6        | EA   | \$0       |                         |
| Emergency System |           | Exit Signs - Corridors and Stairs                  | Corridors and Stairs | 7    | 34       | EA   | \$0       |                         |
| Emergency System |           | Exit Signs - Lunchroom - Gym - multipurpose rooms  | Lunch Room           | 7    | 6        | EA   | \$0       |                         |
| Emergency System |           | Exit Signs - Lunchroom - Gym - multipurpose rooms  | Gym                  | 7    | 3        | EA   | \$0       |                         |
| Emergency System |           | Exit Signs - Lunchroom - Gym - multipurpose rooms  | Multi Purpose Room   | 7    | 2        | EA   | \$0       |                         |
| Emergency System |           | Independent Electrical Service for emergency power | Entire Building      | 5    | 1        | EA   | \$5,005   |                         |
| Emergency System |           | Public Announcement System                         | Entire Building      | 6    | 66,550   | SF   | \$39,970  |                         |
| Emergency System |           | Security System - CCTV                             | Entire Building      | 5    | 66,550   | SF   | \$190,333 | 16 Cameras, one is down |
| Emergency System |           | Security System - Intrusion detection              | Electrical Room      | 6    | 66,550   | SF   | \$61,858  |                         |

**Building: Main**  
**Category: ELECTRICAL**

| Group                       | Sub Group | Item  | Location        | Rank | Quantity | Unit | Cost             | Reason |
|-----------------------------|-----------|---|-----------------|------|----------|------|------------------|--------|
| Main Service                |           | Main Electrical service - Live Front - 1200 A 277/480/3PH | Electrical Room | 6    | 1        | EA   | \$8,938          |        |
| Power Distribution          |           | Lighting and power panels                                 | Electrical Room | 4    | 1        | EA   | \$5,434          | Fuses  |
| Power Distribution          |           | Lighting and power panels                                 | Entire Building | 6    | 14       | EA   | \$10,010         |        |
| Power Distribution          |           | Main distribution panels above 600 amp                    | Electrical Room | 6    | 1        | EA   | \$2,145          |        |
| Power Distribution          |           | Main distribution panels above 600 amp                    | Electrical Room | 4    | 7        | EA   | \$130,130        |        |
| Power Distribution          |           | Transformers 277/480-120/208                              | Electrical Room | 6    | 2        | EA   | \$2,288          |        |
| <b>ELECTRICAL Sub Total</b> |           |   |                 |      |          |      | <b>\$464,977</b> |        |

**Building: Main**  
**Category: FIRE PROTECTION**

| Group                            | Sub Group | Item                     | Location        | Rank | Quantity | Unit | Cost             | Reason |
|----------------------------------|-----------|--------------------------|-----------------|------|----------|------|------------------|--------|
| Fire Alarm                       |           | Fire Alarm Strobe Lights | Entire Building | 6    | 66,550   | SF   | \$23,792         |        |
| Fire Alarm                       |           | Fire Alarm System        | Entire Building | 6    | 66,550   | SF   | \$80,892         |        |
| <b>FIRE PROTECTION Sub Total</b> |           |                          |                 |      |          |      | <b>\$104,683</b> |        |

**Building: Main**  
**Category: MECHANICAL**

| Group                | Sub Group | Item  | Location             | Rank | Quantity | Unit | Cost      | Reason                   |
|----------------------|-----------|---|----------------------|------|----------|------|-----------|--------------------------|
| Air Conditioning     |           | Chillers - Air Cooled - Rotary - Ground Mounted 50 to 100 tons          | Mechanical Room      | 4    | 2        | EA   | \$263,120 |                          |
| Air Conditioning     |           | Condensing Unit - Ground Mounted greater than 50 tons                   | Parking Lot          | 4    | 2        | EA   | \$100,100 |                          |
| Air Conditioning     |           | Condensing Unit - Ground Mounted less than 5 tons                       | MDF Room             | 2    | 1        | EA   | \$7,150   | Unit inoperative         |
| Air Conditioning     |           | Condensing Unit - Roof Mounted 5 to 10 tons                             | Roof                 | 4    | 1        | EA   | \$22,880  |                          |
| Air Conditioning     |           | Condensing Unit - Roof Mounted less than 5 tons                         | Roof / Area Way      | 7    | 5        | EA   | \$0       |                          |
| Air Conditioning     |           | Window A/C Unit   | Engineers Office     | 6    | 1        | EA   | \$215     |                          |
| Air Handling Systems |           | Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm | Gym                  | 4    | 1        | EA   | \$62,920  |                          |
| Air Handling Systems |           | Air Handling Unit Package - Single Zone - Hot Water less than 4,000 cfm | Above ceiling        | 4    | 1        | EA   | \$35,750  |                          |
| Air Handling Systems |           | Air intake for all Air Handling Units except built up AHU               | East Facade and Roof | 6    | 2        | EA   | \$2,860   |                          |
| Air Handling Systems |           | Fan Coil Unit - Hot Water-Heating                                       | Entire Building      | 5    | 7        | EA   | \$47,047  |                          |
| Air Handling Systems |           | Make Up Air Unit - Roof Mounted - Gas-Heating less than 6,000 cfm       | Roof                 | 4    | 1        | EA   | \$28,600  |                          |
| Air Handling Systems |           | Reheat Boxes With Hot Water Coils                                       | Gym & above ceilings | 5    | 7        | EA   | \$39,039  | Coil appears to be dirty |

**Building: Main**  
**Category: MECHANICAL**

| Group                       | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost               | Reason  |
|-----------------------------|-----------|--|-----------------|------|----------|------|--------------------|---|
| Air Handling Systems        |           | Roof Top Unit - Single Zone - Gas-Heating greater than 45 tons                     | Roof            | 4    | 1        | EA   | \$115,830          |   |
| Air Handling Systems        |           | Variable Air Volume (VAV) Box With Hot Water Coil                                  | Entire Building | 3    | 16       | EA   | \$52,624           | VAV box is more than 10 years of age and the controls are not working                           |
| Boiler Systems              |           | Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler 3,001MBH-4,000 MBH | Boiler Room     | 5    | 2        | EA   | \$130,130          |   |
| Boiler Systems              |           | Boiler Auxiliary Non-Condensing Hot Water Boiler 3,001MBH-4,000 MBH                | Boiler Room     | 5    | 2        | EA   | \$61,490           |   |
| Boiler Systems              |           | Chemical Feed System (Steam Boilers)   | Boiler Room     | 6    | 1        | EA   | \$2,145            |   |
| Boiler Systems              |           | Combustion Dampers   | Boiler Room     | 3    | 1        | EA   | \$5,577            | Damper does not open during burner operation  |
| Boiler Systems              |           | Combustion Dampers   | Boiler Room     | 5    | 2        | EA   | \$3,146            |   |
| Boiler Systems              |           | Glycol Feed System   | Boiler Room     | 3    | 1        | EA   | \$3,861            | Pump Ran continuously - Adjustment device was defective No Glyco in System - Coils unprotected. |
| Heating Devices             |           | Fin Tube Hot Water   | Entire Building | 5    | 40       | LF   | \$3,432            |   |
| Heating Devices             |           | Radiators - Hot Water  | Entire Building | 6    | 10       | EA   | \$1,258            |   |
| Heating Devices             |           | Unit Heater - Hot Water  | Entire Building | 6    | 3        | EA   | \$4,290            |   |
| Mechanical Plumbing         |           | Piping - Hydronic Supply and Return - Steel or Galvanized                          | Entire Building | 5    | 1,000    | LF   | \$49,478           |   |
| Mechanical Plumbing         |           | Pumps - Dual Temperature Water 11 to 20 HP   | Boiler Room     | 5    | 2        | EA   | \$21,450           |   |
| Mechanical Plumbing         |           | Pumps - Hot Water 5 to 10 HP   | Boiler Room     | 5    | 1        | EA   | \$8,580            |   |
| Temperature Control         |           | Pneumatic System   | Entire Building | 3    | 66,550   | SF   | \$475,833          | OA Dampers on Unit Vents are inoperative as are the DT isolation valving system.                |
| Temperature Control         |           | Thermostats - Pneumatic  | Entire Building | 4    | 27       | EA   | \$17,761           |   |
| Unit Ventilation            |           | Unit Ventilators - Hot Water and Chilled Water                                     | Entire Building | 4    | 33       | EA   | \$566,280          |   |
| Ventilation                 |           | Exhaust Fan - Indoor   | Entire Building | 6    | 3        | EA   | \$1,502            |   |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm                                     | Roof            | 7    | 6        | EA   | \$0                |   |
| Ventilation                 |           | Exhaust Fans - Roof Mounted 500 to 1,500 cfm                                       | Roof            | 7    | 2        | EA   | \$0                |   |
| Ventilation                 |           | Exhaust Fans - Roof mounted less than 500 CFM                                      | Roof            | 7    | 1        | EA   | \$0                |   |
| Ventilation                 |           | Type I Exhaust Hood - Kitchen or Culinary Arts                                     | Kitchen         | 6    | 1        | EA   | \$1,716            |   |
| <b>MECHANICAL Sub Total</b> |           |  |                 |      |          |      | <b>\$2,136,063</b> |   |

**Building: Main**  
**Category: PLUMBING**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

**Building: Main**  
**Category: PLUMBING**

| Group                     | Sub Group | Item   | Location        | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|-----------|--|-----------------|------|----------|------|------------------|--------|
| Hot Water                 |           | Hot Water Heater - Gas 150,000 -300,000 BTU/HR       | Boiler Room     | 4    | 2        | EA   | \$45,760         |        |
| Hot Water                 |           | Storage Tank less than 500 gallons                   | Boiler Room     | 4    | 1        | EA   | \$14,872         |        |
| Piping                    |           | Domestic Piping - Cold Water from Risers to Fixtures | Entire Building | 6    | 66,550   | SF   | \$7,613          |        |
| Piping                    |           | Domestic Piping - Cold Water Risers                  | Entire Building | 6    | 66,550   | SF   | \$10,468         |        |
| Piping                    |           | Domestic Piping - Hot Water from Riser to fixtures   | Entire Building | 6    | 66,550   | SF   | \$10,468         |        |
| Piping                    |           | Domestic Piping - Hot Water Return Risers            | Entire Building | 6    | 66,550   | SF   | \$10,468         |        |
| Piping                    |           | Domestic Piping - Hot Water Risers                   | Entire Building | 6    | 66,550   | SF   | \$10,468         |        |
| Piping                    |           | Domestic Piping Cold Water Horizontal lines          | Entire Building | 6    | 66,550   | SF   | \$15,227         |        |
| Piping                    |           | Domestic Piping Hot Water Horizontal lines           | Entire Building | 6    | 66,550   | SF   | \$13,323         |        |
| Piping                    |           | Domestic Piping Hot Water Return Lines               | Entire Building | 6    | 66,550   | SF   | \$10,468         |        |
| Piping                    |           | Sanitary Piping                                      | Entire Building | 7    | 66,550   | SF   | \$0              |        |
| Piping                    |           | Storm Piping   | Entire Building | 7    | 66,550   | SF   | \$0              |        |
| Piping                    |           | Vent Piping  | Entire Building | 7    | 66,550   | SF   | \$0              |        |
| Pumps                     |           | Domestic Booster Pump duplex                         | Mechanical Room | 6    | 1        | EA   | \$3,146          |        |
| Pumps                     |           | Ejector Pump   | Boiler Room     | 4    | 2        | EA   | \$60,060         |        |
| Pumps                     |           | Sump Pump  | Elevator Pit    | 5    | 1        | EA   | \$5,148          |        |
| <b>PLUMBING Sub Total</b> |           |  |                 |      |          |      | <b>\$217,491</b> |        |

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item             | Location                              | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|------------------|---------------------------------------|------|----------|------|------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | First floor, room 123                 | 7    | 516      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Office 340                            | 7    | 160      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | Office 300                            | 7    | 336      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | First floor,room 107                  | 7    | 160      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | First floor,room 106                  | 7    | 186      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | First floor, room 203, teacher lounge | 7    | 850      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | First floor, principal office         | 7    | 217      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | First floor, asst principal office    | 7    | 134      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In | First floor, main office              | 7    | 902      | SF   | \$0  |        |

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                              | Location                              | Rank | Quantity | Unit | Cost | Reason |
|-----------------------|-------------------------------|-----------------------------------|---------------------------------------|------|----------|------|------|--------|
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | First floor, room 119                 | 7    | 114      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | Basement, engineer office             | 7    | 365      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | First floor, kitchen office           | 7    | 86       | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Ceiling - Lay-In                  | First floor, work room office         | 7    | 180      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile Ceramic/Porcelain | First floor, kitchen office           | 7    | 86       | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, room 123                 | 7    | 516      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | Basement, engineer office             | 7    | 365      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, room 119                 | 7    | 114      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, main office              | 7    | 902      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, work room office         | 7    | 180      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, asst principal office    | 7    | 134      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, principal office         | 7    | 217      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, room 203, teacher lounge | 7    | 850      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, room 107                 | 7    | 160      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | Office 340                            | 7    | 160      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | Office 300                            | 7    | 336      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Flooring - Tile/Sheet             | First floor, room 106                 | 7    | 186      | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In                 | First floor, room 106                 | 7    | 3        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In                 | First floor, room 203, teacher lounge | 7    | 10       | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In                 | First floor, principal office         | 7    | 4        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In                 | Basement, engineer office             | 7    | 6        | SF   | \$0  |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In                 | First floor, room 119                 | 7    | 2        | SF   | \$0  |        |

**Building: Main**  
**Category: INTERIOR**

| Group                 | Sub Group                     | Item                       | Location                              | Rank | Quantity | Unit | Cost    | Reason |
|-----------------------|-------------------------------|----------------------------|---------------------------------------|------|----------|------|---------|--------|
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | First floor, main office              | 7    | 12       | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | First floor, work room office         | 7    | 4        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | First floor, asst principal office    | 7    | 2        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Office 300                            | 7    | 6        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | Office 340                            | 7    | 3        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | First floor, room 123                 | 7    | 8        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | First floor,room 107                  | 7    | 3        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Lay-In          | First floor, kitchen office           | 7    | 1        | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Lighting - Pendant/Surface | First floor, room 203, teacher lounge | 6    | 2        | SF   | \$1     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | Basement, engineer office             | 6    | 634      | SF   | \$1,813 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, room 119                 | 6    | 382      | SF   | \$1,093 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, kitchen office           | 6    | 306      | SF   | \$875   |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, work room office         | 6    | 345      | SF   | \$987   |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | Office 340                            | 7    | 430      | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, asst principal office    | 6    | 412      | SF   | \$1,178 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, principal office         | 6    | 528      | SF   | \$1,510 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, room 203, teacher lounge | 7    | 1,024    | SF   | \$0     |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor,room 106                  | 6    | 502      | SF   | \$1,436 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, main office              | 6    | 1,188    | SF   | \$3,398 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor,room 107                  | 6    | 476      | SF   | \$1,361 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | First floor, room 123                 | 6    | 850      | SF   | \$2,431 |        |
| Administrative Suites | Administrative Suites/Offices | Walls - Concrete Block     | Office 300                            | 7    | 770      | SF   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group                  | Sub Group                     | Item                                 | Location                                | Rank | Quantity | Unit | Cost     | Reason |
|------------------------|-------------------------------|--------------------------------------|---|------|----------|------|----------|--------|
| Administrative Suites  | Administrative Suites/Offices | Walls - Plaster/Drywall              | First floor, work room office           | 6    | 133      | SF   | \$314    |        |
| Doors                  |                               | Interior Steel Doors incl hw         | Entire Building                         | 7    | 33       | EA   | \$0      |        |
| Doors                  |                               | Interior Wood Doors incl hw          | Entire Building                         | 7    | 97       | EA   | \$0      |        |
| Drinking Fountains     | Corridors                     | Double Fountain                      | 1st Floor                               | 7    | 1        | EA   | \$0      |        |
| Drinking Fountains     | Corridors                     | Single Fountain                      | 1st Floor                               | 7    | 1        | EA   | \$0      |        |
| Drinking Fountains     | Corridors                     | Single Fountain                      | 2nd Floor                               | 7    | 2        | EA   | \$0      |        |
| Drinking Fountains     | Corridors                     | Single Fountain                      | 3rd Floor                               | 7    | 2        | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Ceiling - Lay-In                     | 1st Floor                               | 6    | 3,760    | SF   | \$29,572 |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Flooring - Tile/Sheet                | 1st Floor                               | 6    | 3,760    | SF   | \$5,377  |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Lighting - Metal Halide/Sodium Vapor | 1st Floor                               | 6    | 15       | EA   | \$2,681  |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Scoreboards                          | 1st Floor                               | 7    | 1        | EA   | \$0      |        |
| Gymnasium / Auditorium | Standard Dedicated Gymnasium  | Walls - Concrete Block               | 1st Floor                               | 6    | 5,922    | SF   | \$50,811 |        |
| Kitchen                | Cooking Kitchen               | Ceiling - Lay-In                     | 1st Floor                               | 6    | 945      | SF   | \$2,703  |        |
| Kitchen                | Cooking Kitchen               | Flooring - Tile Quarry               | 1st Floor                               | 6    | 945      | SF   | \$3,257  |        |
| Kitchen                | Cooking Kitchen               | Lighting - Pendant/Surface           | 1st Floor                               | 7    | 10       | SF   | \$0      |        |
| Kitchen                | Cooking Kitchen               | Wall - Concrete Block                | 1st Floor                               | 6    | 2,299    | SF   | \$6,575  |        |
| Library                | Library                       | Casework                             | Room 200                                | 7    | 160      | LF   | \$0      |        |
| Library                | Library                       | Flooring Tile/ Sheet                 | Room 200                                | 7    | 1,580    | SF   | \$0      |        |
| Library                | Library                       | Lighting - Lay-In                    | Room 200                                | 7    | 32       | SF   | \$0      |        |
| Locker/Shower Room     | Locker/Shower Room            | Lockers                              | Basement, janitor locker room           | 6    | 10       | EA   | \$491    |        |
| Locker/Shower Room     | Locker/Shower Room            | Showers                              | Basement, janitor locker room           | 6    | 1        | EA   | \$243    |        |
| Lunchroom              | Multipurpose Room             | Ceiling - Lay-In                     | First floor, room 113, used for storage | 6    | 1,778    | SF   | \$3,814  |        |
| Lunchroom              | Lunchroom                     | Ceiling - Lay-In                     | 1st Floor                               | 7    | 3,590    | SF   | \$0      |        |
| Lunchroom              | Multipurpose Room             | Flooring - Tile/Sheet                | First floor, room 113, used for storage | 6    | 1,778    | SF   | \$2,543  |        |
| Lunchroom              | Lunchroom                     | Flooring - Tile/Sheet                | 1st Floor                               | 6    | 3,590    | SF   | \$5,134  |        |
| Lunchroom              | Lunchroom                     | Lighting - Lay-In                    | 1st Floor                               | 6    | 48       | SF   | \$34     |        |
| Lunchroom              | Multipurpose Room             | Lighting - Lay-In                    | First floor, room 113, used for storage | 7    | 20       | SF   | \$0      |        |
| Lunchroom              | Lunchroom                     | Serving Line                         | 1st Floor                               | 7    | 29       | LF   | \$0      |        |
| Lunchroom              | Multipurpose Room             | Wall - Concrete Block                | First floor, room 113, used for storage | 6    | 1,498    | SF   | \$4,284  |        |



**Building: Main**  
**Category: INTERIOR**

| Group                    | Sub Group                            | Item                     | Location                                  | Rank | Quantity | Unit | Cost    | Reason |
|--------------------------|--------------------------------------|--------------------------|---|------|----------|------|---------|--------|
| Lunchroom                | Lunchroom                            | Wall - Concrete Block    | 1st Floor                                 | 6    | 2,486    | SF   | \$7,110 |        |
| MDF/IDF                  |                                      | Finishes                 | MDF 314A                                  | 7    | 108      | SF   | \$0     |        |
| MDF/IDF                  |                                      | Ventilation and Cooling  | MDF 314A                                  | 6    | 1        | EA   | \$1,401 |        |
| Mechanical/Service Rooms |                                      | Janitor's Closet         | Entire Building                           | 7    | 3        | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms | Basement electrical room 008              | 6    | 362      | SF   | \$1,708 |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms | Basement, room 009                        | 6    | 534      | SF   | \$2,520 |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms | Basement, Mech room 010                   | 6    | 807      | SF   | \$3,808 |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms | First floor, room 115                     | 6    | 90       | SF   | \$425   |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms | First floor, kitchen storage              | 7    | 100      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms | 2nd floor, Electrical Closet              | 7    | 17       | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms | 3rd floor, Electrical Closet              | 7    | 17       | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Mechanical/Service Rooms | Basement, elevator machine room           | 6    | 67       | SF   | \$316   |        |
| Mechanical/Service Rooms |                                      | Storage Room             | Library Workroom                          | 7    | 265      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Storage Room             | First floor, store room 118               | 7    | 412      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Storage Room             | First floor, room 116                     | 7    | 100      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Storage Room             | In Room 320                               | 7    | 57       | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Storage Room             | In Room 321                               | 7    | 143      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Storage Room             | In Room 328                               | 7    | 170      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Storage Room             | 2nd floor, next to library                | 7    | 200      | SF   | \$0     |        |
| Mechanical/Service Rooms |                                      | Storage Room             | First floor, yard storage                 | 6    | 322      | SF   | \$1,520 |        |
| Mechanical/Service Rooms |                                      | Storage Room             | First floor, room 108                     | 6    | 218      | SF   | \$1,029 |        |
| Mechanical/Service Rooms |                                      | Vaults                   | First floor, main office                  | 6    | 288      | SF   | \$1,359 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories              | 3rd floor, Boys'                          | 6    | 230      | SF   | \$1,776 |        |
| Staff Restroom           | Staff Restroom                       | Accessories              | 3rd floor, Men's                          | 7    | 44       | SF   | \$0     |        |
| Staff Restroom           | Staff Restroom                       | Accessories              | 3rd floor, Women's                        | 7    | 44       | SF   | \$0     |        |
| Staff Restroom           | Locker/Shower Room                   | Accessories              | Basement, janitor locker room             | 6    | 164      | SF   | \$1,266 |        |
| Staff Restroom           | Staff Restroom                       | Accessories              | 2nd floor, Men's                          | 7    | 44       | SF   | \$0     |        |
| Staff Restroom           | Staff Restroom                       | Accessories              | First floor, inside room 123              | 6    | 38       | SF   | \$293   |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories              | 2nd floor, Boys'                          | 6    | 230      | SF   | \$1,776 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories              | 3rd floor, Girls'                         | 6    | 230      | SF   | \$1,776 |        |
| Staff Restroom           | Children's Standard Student Restroom | Accessories              | 2nd floor, Girls'                         | 6    | 230      | SF   | \$1,776 |        |
| Staff Restroom           | Early Childhood Student Restroom     | Accessories              | First floor, inside Kindergarten Room 121 | 6    | 38       | SF   | \$293   |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item             | Location                                  | Rank | Quantity | Unit | Cost    | Reason |
|----------------|--------------------------------------|------------------|---|------|----------|------|---------|--------|
| Staff Restroom | Early Childhood Student Restroom     | Accessories      | First floor, inside Kindergarten Room 124 | 6    | 30       | SF   | \$232   |        |
| Staff Restroom | Staff Restroom                       | Accessories      | First floor, main office men              | 6    | 40       | SF   | \$309   |        |
| Staff Restroom | Staff Restroom                       | Accessories      | First floor, main office womens           | 6    | 40       | SF   | \$309   |        |
| Staff Restroom | Children's Standard Student Restroom | Accessories      | First floor, girls                        | 6    | 230      | SF   | \$1,776 |        |
| Staff Restroom | Children's Standard Student Restroom | Accessories      | First floor, boys                         | 6    | 230      | SF   | \$1,776 |        |
| Staff Restroom | Staff Restroom                       | Accessories      | First floor, kitchen bathroom             | 6    | 40       | SF   | \$309   |        |
| Staff Restroom | Staff Restroom                       | Accessories      | 2nd floor, Women's                        | 7    | 44       | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Lay-In | 3rd floor, Women's                        | 7    | 44       | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Lay-In | First floor, boys                         | 7    | 230      | SF   | \$0     |        |
| Staff Restroom | Locker/Shower Room                   | Ceiling - Lay-In | Basement, janitor locker room             | 6    | 164      | SF   | \$352   |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Lay-In | First floor, main office men              | 7    | 40       | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Lay-In | First floor, girls                        | 7    | 230      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Lay-In | 3rd floor, Men's                          | 7    | 44       | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Lay-In | First floor, kitchen bathroom             | 7    | 40       | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Lay-In | First floor, inside room 123              | 7    | 33       | SF   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Ceiling - Lay-In | First floor, inside Kindergarten Room 124 | 7    | 30       | SF   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Ceiling - Lay-In | First floor, inside Kindergarten Room 121 | 7    | 38       | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Lay-In | 2nd floor, Girls'                         | 7    | 230      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Lay-In | 3rd floor, Girls'                         | 7    | 230      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Lay-In | 2nd floor, Boys'                          | 7    | 230      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Lay-In | 2nd floor, Men's                          | 7    | 44       | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Lay-In | First floor, main office womens           | 7    | 40       | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Ceiling - Lay-In | 2nd floor, Women's                        | 7    | 44       | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Ceiling - Lay-In | 3rd floor, Boys'                          | 7    | 230      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Floor Drain      | 2nd floor, Men's                          | 7    | 1        | EA   | \$0     |        |
| Staff Restroom | Early Childhood Student Restroom     | Floor Drain      | First floor, inside Kindergarten Room 124 | 7    | 1        | EA   | \$0     |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                              | Location                                  | Rank | Quantity | Unit | Cost  | Reason |
|----------------|--------------------------------------|-----------------------------------|---|------|----------|------|-------|--------|
| Staff Restroom | Early Childhood Student Restroom     | Floor Drain                       | First floor, inside Kindergarten Room 121 | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain                       | 2nd floor, Girls'                         | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Floor Drain                       | 3rd floor, Men's                          | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain                       | 3rd floor, Girls'                         | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Floor Drain                       | 3rd floor, Women's                        | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Floor Drain                       | 2nd floor, Women's                        | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain                       | 3rd floor, Boys'                          | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Floor Drain                       | First floor, kitchen bathroom             | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain                       | 2nd floor, Boys'                          | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Locker/Shower Room                   | Floor Drain                       | Basement, janitor locker room             | 6    | 2        | EA   | \$601 |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain                       | First floor, boys                         | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Floor Drain                       | First floor, girls                        | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Floor Drain                       | First floor, main office womens           | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Floor Drain                       | First floor, inside room 123              | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Floor Drain                       | First floor, main office men              | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor, Girls'                         | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd floor, Boys'                          | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Locker/Shower Room                   | Flooring - Tile Ceramic/Porcelain | Basement, janitor locker room             | 6    | 164      | SF   | \$417 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 3rd floor, Girls'                         | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Early Childhood Student Restroom     | Flooring - Tile Ceramic/Porcelain | First floor, inside Kindergarten Room 124 | 6    | 30       | SF   | \$76  |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | First floor, boys                         | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | First floor, girls                        | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Children's Standard Student Restroom | Flooring - Tile Ceramic/Porcelain | 2nd floor, Boys'                          | 6    | 230      | SF   | \$585 |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet             | First floor, kitchen bathroom             | 6    | 40       | SF   | \$57  |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet             | 3rd floor, Men's                          | 7    | 44       | SF   | \$0   |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                  | Location                                  | Rank | Quantity | Unit | Cost  | Reason |
|----------------|--------------------------------------|-----------------------|---|------|----------|------|-------|--------|
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet | 3rd floor, Women's                        | 7    | 44       | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet | 2nd floor, Women's                        | 7    | 44       | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet | 2nd floor, Men's                          | 7    | 44       | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet | First floor, inside room 123              | 6    | 33       | SF   | \$47  |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet | First floor, main office womens           | 6    | 40       | SF   | \$57  |        |
| Staff Restroom | Staff Restroom                       | Flooring - Tile/Sheet | First floor, main office men              | 6    | 40       | SF   | \$57  |        |
| Staff Restroom | Early Childhood Student Restroom     | Flooring - Tile/Sheet | First floor, inside Kindergarten Room 121 | 6    | 38       | SF   | \$54  |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer            | First floor, girls                        | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer            | First floor, boys                         | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer            | 3rd floor, Girls'                         | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer            | 2nd floor, Girls'                         | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer            | 2nd floor, Boys'                          | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Hand Dryer            | 3rd floor, Boys'                          | 7    | 2        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lavatory              | First floor, kitchen bathroom             | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Locker/Shower Room                   | Lavatory              | Basement, janitor locker room             | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Staff Restroom                       | Lavatory              | First floor, main office men              | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Staff Restroom                       | Lavatory              | First floor, main office womens           | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory              | First floor, boys                         | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Staff Restroom                       | Lavatory              | First floor, inside room 123              | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Early Childhood Student Restroom     | Lavatory              | First floor, inside Kindergarten Room 124 | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Staff Restroom                       | Lavatory              | 2nd floor, Women's                        | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lavatory              | 3rd floor, Men's                          | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory              | First floor, girls                        | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Staff Restroom                       | Lavatory              | 3rd floor, Women's                        | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Early Childhood Student Restroom     | Lavatory              | First floor, inside Kindergarten Room 121 | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Staff Restroom                       | Lavatory              | 2nd floor, Men's                          | 7    | 1        | EA   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory              | 3rd floor, Boys'                          | 6    | 1        | EA   | \$372 |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                        | Location                                  | Rank | Quantity | Unit | Cost  | Reason |
|----------------|--------------------------------------|-----------------------------|---|------|----------|------|-------|--------|
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 2nd floor, Boys'                          | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 3rd floor, Girls'                         | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Children's Standard Student Restroom | Lavatory                    | 2nd floor, Girls'                         | 6    | 1        | EA   | \$372 |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In           | First floor, boys                         | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In           | First floor, girls                        | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Lay-In           | First floor, kitchen bathroom             | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Lay-In           | First floor, inside room 123              | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Early Childhood Student Restroom     | Lighting - Lay-In           | First floor, inside Kindergarten Room 124 | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Early Childhood Student Restroom     | Lighting - Lay-In           | First floor, inside Kindergarten Room 121 | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Lay-In           | First floor, main office men              | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In           | 3rd floor, Boys'                          | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Lay-In           | 3rd floor, Men's                          | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Lay-In           | 3rd floor, Women's                        | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In           | 2nd floor, Girls'                         | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Lay-In           | 2nd floor, Men's                          | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In           | 2nd floor, Boys'                          | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Children's Standard Student Restroom | Lighting - Lay-In           | 3rd floor, Girls'                         | 7    | 4        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Lay-In           | First floor, main office womens           | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Staff Restroom                       | Lighting - Lay-In           | 2nd floor, Women's                        | 7    | 1        | SF   | \$0   |        |
| Staff Restroom | Locker/Shower Room                   | Lighting - Pendant/ Surface | Basement, janitor locker room             | 6    | 2        | SF   | \$1   |        |
| Staff Restroom | Locker/Shower Room                   | Partitions                  | Basement, janitor locker room             | 6    | 1        | EA   | \$179 |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | First floor, boys                         | 6    | 2        | EA   | \$359 |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | First floor, girls                        | 6    | 5        | EA   | \$897 |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 2nd floor, Girls'                         | 6    | 5        | EA   | \$897 |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions                  | 3rd floor, Girls'                         | 6    | 5        | EA   | \$897 |        |

**Building: Main**  
**Category: INTERIOR**

| Group          | Sub Group                            | Item                  | Location                                  | Rank | Quantity | Unit | Cost    | Reason |
|----------------|--------------------------------------|-----------------------|---|------|----------|------|---------|--------|
| Staff Restroom | Children's Standard Student Restroom | Partitions            | 2nd floor, Boys'                          | 6    | 2        | EA   | \$359   |        |
| Staff Restroom | Children's Standard Student Restroom | Partitions            | 3rd floor, Boys'                          | 6    | 2        | EA   | \$359   |        |
| Staff Restroom | Children's Standard Student Restroom | Urinals               | First floor, boys                         | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Children's Standard Student Restroom | Urinals               | 3rd floor, Boys'                          | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Children's Standard Student Restroom | Urinals               | 2nd floor, Boys'                          | 6    | 3        | EA   | \$1,115 |        |
| Staff Restroom | Early Childhood Student Restroom     | Wall - Concrete Block | First floor, inside Kindergarten Room 124 | 6    | 173      | SF   | \$495   |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block | First floor, main office men              | 6    | 200      | SF   | \$572   |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block | First floor, main office womens           | 6    | 200      | SF   | \$572   |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | First floor, girls                        | 6    | 612      | SF   | \$1,750 |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | First floor, boys                         | 6    | 612      | SF   | \$1,750 |        |
| Staff Restroom | Early Childhood Student Restroom     | Wall - Concrete Block | First floor, inside Kindergarten Room 121 | 6    | 194      | SF   | \$555   |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block | First floor, kitchen bathroom             | 6    | 196      | SF   | \$561   |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block | First floor, inside room 123              | 6    | 173      | SF   | \$495   |        |
| Staff Restroom | Locker/Shower Room                   | Wall - Concrete Block | Basement, janitor locker room             | 6    | 408      | SF   | \$1,167 |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 3rd floor, Girls'                         | 6    | 612      | SF   | \$1,750 |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block | 3rd floor, Men's                          | 7    | 220      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block | 3rd floor, Women's                        | 7    | 220      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block | 2nd floor, Women's                        | 7    | 220      | SF   | \$0     |        |
| Staff Restroom | Staff Restroom                       | Wall - Concrete Block | 2nd floor, Men's                          | 7    | 220      | SF   | \$0     |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 2nd floor, Boys'                          | 6    | 612      | SF   | \$1,750 |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 2nd floor, Girls'                         | 6    | 612      | SF   | \$1,750 |        |
| Staff Restroom | Children's Standard Student Restroom | Wall - Concrete Block | 3rd floor, Boys'                          | 6    | 612      | SF   | \$1,750 |        |
| Staff Restroom | Staff Restroom                       | Water Closet          | 2nd floor, Men's                          | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Staff Restroom                       | Water Closet          | First floor, main office men              | 6    | 1        | EA   | \$372   |        |
| Staff Restroom | Locker/Shower Room                   | Water Closet          | Basement, janitor locker room             | 6    | 1        | EA   | \$372   |        |

**Building: Main**  
**Category: INTERIOR**

| Group                     | Sub Group                            | Item                                | Location                                  | Rank | Quantity | Unit | Cost             | Reason |
|---------------------------|--------------------------------------|-------------------------------------|---|------|----------|------|------------------|--------|
| Staff Restroom            | Children's Standard Student Restroom | Water Closet                        | First floor, girls                        | 6    | 5        | EA   | \$1,859          |        |
| Staff Restroom            | Staff Restroom                       | Water Closet                        | 3rd floor, Women's                        | 6    | 1        | EA   | \$372            |        |
| Staff Restroom            | Staff Restroom                       | Water Closet                        | 2nd floor, Women's                        | 6    | 1        | EA   | \$372            |        |
| Staff Restroom            | Children's Standard Student Restroom | Water Closet                        | 2nd floor, Boys'                          | 6    | 2        | EA   | \$744            |        |
| Staff Restroom            | Staff Restroom                       | Water Closet                        | 3rd floor, Men's                          | 6    | 1        | EA   | \$372            |        |
| Staff Restroom            | Children's Standard Student Restroom | Water Closet                        | 3rd floor, Boys'                          | 6    | 2        | EA   | \$744            |        |
| Staff Restroom            | Staff Restroom                       | Water Closet                        | First floor, main office womens           | 6    | 1        | EA   | \$372            |        |
| Staff Restroom            | Children's Standard Student Restroom | Water Closet                        | First floor, boys                         | 6    | 2        | EA   | \$744            |        |
| Staff Restroom            | Staff Restroom                       | Water Closet                        | First floor, kitchen bathroom             | 6    | 1        | EA   | \$372            |        |
| Staff Restroom            | Staff Restroom                       | Water Closet                        | First floor, inside room 123              | 6    | 1        | EA   | \$372            |        |
| Staff Restroom            | Early Childhood Student Restroom     | Water Closet                        | First floor, inside Kindergarten Room 124 | 6    | 1        | EA   | \$372            |        |
| Staff Restroom            | Early Childhood Student Restroom     | Water Closet                        | First floor, inside Kindergarten Room 121 | 6    | 1        | EA   | \$372            |        |
| Staff Restroom            | Children's Standard Student Restroom | Water Closet                        | 2nd floor, Girls'                         | 6    | 5        | EA   | \$1,859          |        |
| Staff Restroom            | Children's Standard Student Restroom | Water Closet                        | 3rd floor, Girls'                         | 6    | 5        | EA   | \$1,859          |        |
| Vertical Conveyance       |                                      | Elevator - Roped Holeless Hydraulic | Entire Building                           | 6    | 1        | EA   | \$17,160         |        |
| Vocational Shop           | Classroom                            | Work Sink                           |   | 6    | 2        | EA   | \$772            |        |
| Vocational Shop           | Classroom                            | Work Sink                           |   | 6    | 2        | EA   | \$772            |        |
| Vocational Shop           | Classroom                            | Work Sink                           |   | 6    | 1        | EA   | \$386            |        |
| <b>INTERIOR Sub Total</b> |                                      |                                     |   |      |          |      | <b>\$232,043</b> |        |

**Building: Main**  
**Category: ROOM**

| Group    | Sub Group | Item     | Location | Rank | Quantity | Unit | Cost | Reason |
|----------|-----------|----------|----------|------|----------|------|------|--------|
| Casework | Classroom | Casework |          | 7    | 60       | LF   | \$0  |        |
| Casework | Classroom | Casework |          | 7    | 60       | LF   | \$0  |        |
| Casework | Classroom | Casework |          | 7    | 60       | LF   | \$0  |        |
| Casework | Classroom | Casework |          | 7    | 30       | LF   | \$0  |        |
| Casework | Classroom | Casework |          | 7    | 60       | LF   | \$0  |        |
| Casework | Classroom | Casework |          | 7    | 60       | LF   | \$0  |        |
| Casework | Classroom | Casework |          | 7    | 60       | LF   | \$0  |        |
| Casework | Classroom | Casework |          | 7    | 20       | LF   | \$0  |        |

**Building: Main**  
**Category: ROOM**

| Group    | Sub Group | Item        | Location | Rank | Quantity | Unit | Cost  | Reason |
|----------|-----------|-------------|----------|------|----------|------|-------|--------|
| Casework | Classroom | Casework    |          | 7    | 30       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 6    | 12       | LF   | \$429 |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 20       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 6    | 12       | LF   | \$429 |        |
| Casework | Classroom | Casework    |          | 7    | 30       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 20       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Casework | Classroom | Casework    |          | 7    | 60       | LF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 900      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 760      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 860      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 990      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 880      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 860      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 860      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 1,255    | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 1,255    | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 870      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 870      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 900      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 480      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 860      | SF   | \$0   |        |
| Ceiling  | Classroom | Lay-In/Drop |          | 7    | 920      | SF   | \$0   |        |



**Building: Main**  
**Category: ROOM**

| Group     | Sub Group | Item                    | Location                | Rank | Quantity | Unit | Cost     | Reason |
|-----------|-----------|-------------------------|-------------------------|------|----------|------|----------|--------|
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 990      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 840      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 990      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 815      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 760      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 480      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 990      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 920      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 860      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 795      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 840      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 700      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 860      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 880      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 1,500    | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 700      | SF   | \$0      |        |
| Ceiling   | Classroom | Lay-In/Drop             |                         | 7    | 936      | SF   | \$0      |        |
| CLASSROOM | Classroom | Eye Wash Station        |                         | 7    | 1        | EA   | \$0      |        |
| CLASSROOM | Classroom | Laptop Charging Station |                         | 7    | 1        | EA   | \$0      |        |
| CLASSROOM | Classroom | Laptop Charging Station |                         | 7    | 1        | EA   | \$0      |        |
| CLASSROOM | Classroom | Science Lab Elements    |                         | 7    | 936      | SF   | \$0      |        |
| Corridors | Corridors | Concrete Block          | 2nd Floor               | 6    | 5,960    | SF   | \$17,046 |        |
| Corridors | Corridors | Concrete Block          | 3rd Floor               | 6    | 5,960    | SF   | \$17,046 |        |
| Corridors | Corridors | Concrete Block          | Entire building, stairs | 6    | 4,680    | SF   | \$13,385 |        |
| Corridors | Corridors | Concrete Block          | Basement                | 6    | 2,820    | SF   | \$8,065  |        |
| Corridors | Corridors | Concrete Block          | 1st Floor               | 6    | 5,650    | SF   | \$16,159 |        |
| Corridors | Corridors | Concrete Epoxy/Painted  | Basement                | 6    | 701      | SF   | \$3,308  |        |
| Corridors | Corridors | Drop/Lay-In             | 1st Floor               | 7    | 3,221    | SF   | \$0      |        |
| Corridors | Corridors | Drop/Lay-In             | 2nd Floor               | 7    | 3,052    | SF   | \$0      |        |
| Corridors | Corridors | Drop/Lay-In             | Entire building, stairs | 7    | 692      | SF   | \$0      |        |
| Corridors | Corridors | Drop/Lay-In             | 3rd Floor               | 7    | 3,052    | SF   | \$0      |        |
| Corridors | Corridors | Exposed                 | Basement                | 6    | 828      | SF   | \$1,563  |        |
| Corridors | Corridors | Lay-In                  | 2nd Floor               | 7    | 3,052    | EA   | \$0      |        |
| Corridors | Corridors | Lay-In                  | 3rd Floor               | 7    | 3,052    | EA   | \$0      |        |
| Corridors | Corridors | Lay-In                  | 1st Floor               | 6    | 3,221    | EA   | \$2,303  |        |
| Corridors | Corridors | Pendant/Surface         | Entire building, stairs | 6    | 1,780    | EA   | \$1,273  |        |
| Corridors | Corridors | Pendant/Surface         | Basement                | 6    | 828      | EA   | \$592    |        |

**Building: Main**  
**Category: ROOM**

| Group             | Sub Group | Item                | Location                | Rank | Quantity | Unit | Cost    | Reason |
|-------------------|-----------|---------------------|-------------------------|------|----------|------|---------|--------|
| Corridors         | Corridors | Single Water Cooler | 2nd Floor               | 7    | 1        | EA   | \$0     |        |
| Corridors         | Corridors | Single Water Cooler | 3rd Floor               | 7    | 1        | EA   | \$0     |        |
| Corridors         | Corridors | Stair Handrails     | Entire building, stairs | 6    | 216      | LF   | \$0     |        |
| Corridors         | Corridors | Tile/Sheet Flooring | 3rd Floor               | 6    | 3,052    | SF   | \$4,364 |        |
| Corridors         | Corridors | Tile/Sheet Flooring | 2nd Floor               | 6    | 3,052    | SF   | \$4,364 |        |
| Corridors         | Corridors | Tile/Sheet Flooring | Entire building, stairs | 6    | 1,300    | SF   | \$1,859 |        |
| Corridors         | Corridors | Tile/Sheet Flooring | 1st Floor               | 6    | 3,221    | SF   | \$4,606 |        |
| Corridors         | Corridors | Tile/Sheet Flooring | Basement                | 6    | 127      | SF   | \$182   |        |
| Corridors Ceiling | Corridors | Plaster/Drywall     | Entire building, stairs | 6    | 1,088    | SF   | \$3,081 |        |
| Stairs            | Corridors | Tile                | Entire building, stairs | 6    | 104      | SF   | \$785   |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 990      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 900      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 700      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 860      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 860      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 860      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 880      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 760      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 900      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 936      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 880      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 860      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 860      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 860      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 1,255    | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 1,255    | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 6    | 1,500    | SF   | \$2,145 |        |
| Floor             | Classroom | Tile/Sheet          |                         | 6    | 480      | SF   | \$686   |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 840      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 760      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 920      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 990      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 870      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 870      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 6    | 480      | SF   | \$686   |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 840      | SF   | \$0     |        |
| Floor             | Classroom | Tile/Sheet          |                         | 7    | 815      | SF   | \$0     |        |

**Building: Main**  
**Category: ROOM**

| Group           | Sub Group | Item           | Location | Rank | Quantity | Unit | Cost | Reason |
|-----------------|-----------|----------------|----------|------|----------|------|------|--------|
| Floor           | Classroom | Tile/Sheet     |          | 7    | 990      | SF   | \$0  |        |
| Floor           | Classroom | Tile/Sheet     |          | 7    | 920      | SF   | \$0  |        |
| Floor           | Classroom | Tile/Sheet     |          | 7    | 795      | SF   | \$0  |        |
| Floor           | Classroom | Tile/Sheet     |          | 7    | 700      | SF   | \$0  |        |
| Floor           | Classroom | Tile/Sheet     |          | 7    | 990      | SF   | \$0  |        |
| LIBRARY_CEILING | Library   | Drop/Lay-In    | Room 200 | 7    | 1,580    | SF   | \$0  |        |
| LIBRARY_WALL    | Library   | Concrete Block | Room 200 | 7    | 2,550    | SF   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 6        | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 5        | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 5        | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 10       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 10       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 11       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 13       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 11       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 10       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 10       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 14       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 14       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting        | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |

**Building: Main**  
**Category: ROOM**

| Group        | Sub Group | Item           | Location | Rank | Quantity | Unit | Cost | Reason |
|--------------|-----------|----------------|----------|------|----------|------|------|--------|
| Lighting     | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Lighting     | Classroom | Lay-In         |          | 7    | 12       | EA   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 40       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 20       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 14       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 14       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 20       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 40       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 10       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 10       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 10       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 40       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 10       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Marker Board | Classroom | Marker Board   |          | 7    | 30       | LF   | \$0  |        |
| Wall         | Classroom | Concrete Block |          | 7    | 924      | SF   | \$0  |        |
| Wall         | Classroom | Concrete Block |          | 7    | 980      | SF   | \$0  |        |
| Wall         | Classroom | Concrete Block |          | 7    | 815      | SF   | \$0  |        |

**Building: Main**  
**Category: ROOM**

| Group | Sub Group | Item            | Location | Rank | Quantity | Unit | Cost    | Reason |
|-------|-----------|-----------------|----------|------|----------|------|---------|--------|
| Wall  | Classroom | Concrete Block  |          | 7    | 944      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 944      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 944      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 960      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 910      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 910      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 960      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 944      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 944      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 1,143    | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 6    | 1,136    | SF   | \$3,249 |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 900      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 944      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 900      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 965      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 815      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 924      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 880      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 880      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 900      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 1,065    | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 935      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 935      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 900      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 170      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 170      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 625      | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 1,094    | SF   | \$0     |        |
| Wall  | Classroom | Concrete Block  |          | 7    | 1,094    | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 630      | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 430      | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 625      | SF   | \$0     |        |
| Wall  | Classroom | Plaster/Drywall |          | 7    | 630      | SF   | \$0     |        |

**ROOM Sub Total \$107,605**

**Building Main Sub Total \$3,815,294**

**Building: SITE**  
**Category: SITE**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

**Building: SITE**  
**Category: SITE**

| Group | Sub Group | Item | Location | Rank | Quantity | Unit | Cost | Reason |
|-------|-----------|------|----------|------|----------|------|------|--------|
|-------|-----------|------|----------|------|----------|------|------|--------|

|                |  |  |                                    |   |        |    |           |                             |
|----------------|--|--|------------------------------------|---|--------|----|-----------|-----------------------------|
| Civil/Drainage |  | Catch Basin                            | Entire Site                        | 6 | 4      | EA | \$2,174   |                             |
| Civil/Drainage |  | Site Drain                             | Basement stairs                    | 6 | 1      | EA | \$112     |                             |
| Civil/Drainage |  | Site Manhole                           | Entire Site                        | 7 | 5      | EA | \$0       |                             |
| Fencing        |  | Chain Link                             | Chillers, basement stairs          | 5 | 134    | LF | \$4,791   |                             |
| Fencing        |  | Chain Link                             | Between playground and parking lot | 7 | 88     | LF | \$0       |                             |
| Fencing        |  | Chain Link                             | South perimeter                    | 6 | 287    | LF | \$4,116   |                             |
| Fencing        |  | Guard Rail                             | Parking Lot                        | 6 | 28     | LF | \$793     |                             |
| Fencing        |  | Ornamental Iron                        | Entire Site                        | 6 | 459    | LF | \$8,664   |                             |
| Landscape      |  | Asphalt Play Area/Hardscape            | Entire Building                    | 6 | 6,257  | SF | \$5,369   |                             |
| Landscape      |  | Benches                                | Playground                         | 7 | 3      | EA | \$0       |                             |
| Landscape      |  | Grass                                  | Entire Building                    | 6 | 14,090 | SF | \$5,642   |                             |
| Landscape      |  | Hardscape - Concrete                   | Entire Site                        | 6 | 5,821  | SF | \$10,988  |                             |
| Landscape      |  | Parkway trees                          | Site ζ North                       | 6 | 9      | EA | \$2,574   |                             |
| Landscape      |  | Planting Beds/ Areas                   | Entire Building                    | 6 | 4,064  | SF | \$0       |                             |
| Parking Lot    |  | Asphalt                                | Parking Lot                        | 4 | 14,980 | SF | \$128,528 | Numerous Alligator cracking |
| Parking Lot    |  | Concrete                               | Parking Lot                        | 5 | 1,788  | SF | \$11,148  |                             |
| Parking Lot    |  | Concrete                               | Parking Lot                        | 7 | 1,134  | SF | \$0       |                             |
| Parking Lot    |  | Concrete Curbs                         | Parking Lot                        | 6 | 259    | LF | \$1,563   |                             |
| Parking Lot    |  | Trash Enclosure                        | Parking Lot                        | 7 | 720    | SF | \$0       |                             |
| Playground     |  | Playground Equipment - School Age 5-12 | Playground                         | 7 | 1      | EA | \$0       |                             |
| Playground     |  | Playground Surfacing - Poured Surface  | Playground                         | 7 | 2,304  | SF | \$0       |                             |
| Sidewalks      |  | Internal Walks                         | Entire Site                        | 6 | 361    | LF | \$3,407   |                             |
| Sidewalks      |  | Perimeter Sidewalks                    | Site ζ North                       | 6 | 5,035  | SF | \$9,504   |                             |
| Signage        |  | Flag Pole                              | Main Entrance                      | 6 | 1      | EA | \$0       |                             |

**SITE Sub Total \$199,371**

**SITE Sub Total \$199,371**

**Building: SITE**

**Category: SITE**

| Group                                   | Sub Group | Item | Location | Rank | Quantity | Unit | Cost               | Reason |
|---|-----------|------|----------|------|----------|------|--------------------|--------|
| <b>Total Campus Need <sup>2 3</sup></b> |           |      |          |      |          |      | <b>\$4,014,665</b> |        |

<sup>1</sup> It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

<sup>2</sup> As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

<sup>3</sup> The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

**Room Summary**

| Room Number           | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                | Location                     |
|-----------------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|------------------------------|------------------------------|
| <b>Building: Main</b> |           |              |             |              |             |                   |                      |                  |             |             |             |                               |                              |                              |
| 121                   | 1081      | 1            | 8           | 22           | 40          | 110               | 90                   | 0                | N           | N           | N           | Classroom                     |                              |                              |
| 124                   | 1255      | 1            | 8           | 22           | 40          | 88                | 32                   | 0                | N           | N           | N           | Classroom                     |                              |                              |
| 202                   | 990       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 203                   | 870       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 208                   | 900       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 209                   | 880       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 210                   | 860       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 211                   | 860       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 213                   | 860       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 214                   | 700       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 215                   | 840       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 220                   | 760       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 221                   | 760       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 223                   | 920       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 224                   | 990       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 302                   | 990       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 303                   | 870       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 308                   | 900       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 309                   | 880       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 310                   | 860       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 311                   | 860       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 313                   | 860       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 314                   | 700       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 315                   | 840       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 320                   | 936       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 321                   | 795       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 323                   | 920       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 324                   | 990       | 1            | 8           | 20           | 40          | 116               | 16                   | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 325                   | 480       | 0            | 0           | 6            | 40          | 0                 | 0                    | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 326                   | 1500      | 1            | 8           | 20           | 40          | 200               | 0                    | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 327                   | 480       | 0            | 0           | 6            | 40          | 0                 | 0                    | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| 328                   | 815       | 1            | 8           | 20           | 0           | 100               | 0                    | 0                | N           | N           | Y           | Classroom                     |                              |                              |
| Other                 | 33        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom               | First floor, inside room 123 |
| Other                 | 186       |              |             | 6            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                              | First floor,room 106         |
| Other                 | 160       |              |             | 4            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                              | First floor,room 107         |
| Other                 | 3760      |              |             |              |             |                   |                      |                  | N           | N           | N           | Gymnasia                      | Standard Dedicated Gymnasium | 1st Floor                    |



**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type                     | Room Sub Type                        | Location                                  |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-------------------------------|--------------------------------------|---|
| Other       | 40        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | First floor, kitchen bathroom             |
| Other       | 160       |              |             | 8            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | Office 340                                |
| Other       | 86        |              |             | 4            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | First floor, kitchen office               |
| Other       | 3590      |              |             |              |             |                   |                      |                  | N           | N           | N           | Lunch & Multipurpose Room     | Lunchroom                            | 1st Floor                                 |
| Other       | 38        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Early Childhood Student Restroom     | First floor, inside Kindergarten Room 121 |
| Other       | 336       |              |             | 8            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | Office 300                                |
| Other       | 516       |              |             | 6            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | First floor, room 123                     |
| Other       | 1778      |              |             |              |             |                   |                      |                  | N           | N           | N           | Lunch & Multipurpose Room     | Multipurpose Room                    | First floor, room 113, used for storage   |
| Other       | 30        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Early Childhood Student Restroom     | First floor, inside Kindergarten Room 124 |
| Other       | 134       |              |             | 8            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | First floor, asst principal office        |
| Other       | 945       |              |             |              |             |                   |                      |                  | N           | N           | N           | Kitchen                       | Cooking Kitchen                      | 1st Floor                                 |
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 2nd floor, Boys'                          |
| Other       | 3052      |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | 3rd Floor                                 |
| Other       | 1580      |              |             |              |             |                   |                      |                  | N           | N           | N           | Library                       |                                      | Room 200                                  |
| Other       | 828       |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | Basement                                  |
| Other       | 365       |              |             | 10           |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | Basement, engineer office                 |
| Other       | 164       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Locker/Shower Room                   | Basement, janitor locker room             |
| Other       | 3221      |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | 1st Floor                                 |
| Other       | 1038      |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | Entire building, stairs                   |
| Other       | 114       |              |             | 6            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | First floor, room 119                     |
| Other       | 902       |              |             | 22           |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | First floor, main office                  |
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 2nd floor, Girls'                         |
| Other       | 44        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | 2nd floor, Women's                        |
| Other       | 180       |              |             | 8            |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | First floor, work room office             |
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | First floor, boys                         |
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | 3rd floor, Boys'                          |
| Other       | 3052      |              |             |              |             |                   |                      |                  | N           | N           | N           | Corridors                     |                                      | 2nd Floor                                 |
| Other       | 44        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | 2nd floor, Men's                          |
| Other       | 44        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | 3rd floor, Women's                        |
| Other       | 217       |              |             | 12           |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | First floor, principal office             |
| Other       | 44        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | 3rd floor, Men's                          |
| Other       | 40        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | First floor, main office men              |
| Other       | 40        |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Staff Restroom                       | First floor, main office womens           |
| Other       | 850       |              |             | 14           |             |                   |                      |                  | N           | N           | N           | Administrative Suites/Offices |                                      | First floor, room 203, teacher lounge     |
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom                      | Children's Standard Student Restroom | First floor, girls                        |

**Room Summary**

| Room Number | Room Size | Voice Outlet | Data Outlet | Elect Outlet | Noise Level | Glaze Window Area | Operable Window Area | No. of Window AC | Window Stop | Smart Board | Power Strip | Room Type | Room Sub Type                        | Location          |
|-------------|-----------|--------------|-------------|--------------|-------------|-------------------|----------------------|------------------|-------------|-------------|-------------|-----------|--------------------------------------|-------------------|
| Other       | 230       |              |             |              |             |                   |                      |                  | N           | N           | N           | Restroom  | Children's Standard Student Restroom | 3rd floor, Girls' |