

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Exterior Wood Door	Entire Building	6	9	EA	\$2,888	
Doors		Exterior Wood Door	door 9 at west	4	2	EA	\$6,418	
Doors		Transom Lite	Entire Building	6	6	EA	\$1,699	
Entrance		Concrete Exterior Stairs	Entire Building	6	368	LF	\$39,468	
Entrance		Entrance Controls - Audio and Video	Main Entrance	7	1	EA	\$0	
Entrance		Stair Handrails	Entire Building	6	130	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	734	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	14	EA	\$3,003	
Lintels		Lintels - Steel	Entire Building	6	622	LF	\$23,482	
Lintels		Lintels - Steel	east and west facade	4	50	LF	\$21,808	
Lintels		Lintels - Terra Cotta	Entire Building	7	234	LF	\$0	
Lintels		Lintels - Terra Cotta	East Façade	4	60	LF	\$47,190	
Parapet		Coping - Metal	Entire Building	7	214	LF	\$0	
Parapet		Coping - Stone	south at trash	7	25	LF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parapet		Coping - Terra Cotta	west at north	6	420	LF	\$0	
Parapet		Coping - Terra Cotta	towers, north, south, and lower roof	5	394	LF	\$70,428	open joints and cracking
Parapet		Parapet < 16" Height	Lower Roof	6	136	LF	\$21,179	
Parapet		Parapet > 30" Height	towers	6	256	LF	\$66,444	
Parapet		Parapet 16" to 30" Height	Main Roof	6	302	LF	\$62,706	
Roof System		Asphalt Shingle Roof	east and south	7	1,640	SF	\$0	
Roof System		EPDM/ Synthetic Rubber Roof	Entire Building	6	17,717	SF	\$88,674	leaks have been repaired
Roof System		Exterior Downspouts	Entire Building	6	270	LF	\$5,019	
Roof System		Interior Downspouts	Entire Building	6	700	LF	\$0	
Roof System		Metal Roof	east and two towers	7	1,049	SF	\$0	
Roof System		Roof Structure: Steel with Clay Tile Arch	Entire Building	7	20,406	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	69,500	SF	\$0	
Walls		Brick	NE corner, north wall at roof, south facade, west facade	4	3,042	SF	\$229,683	
Walls		Brick	Entire Building	5	19,987	SF	\$452,730	
Walls		Concrete Block	south at trash	7	150	SF	\$0	
Walls		Stone - Cast	base	7	740	SF	\$0	
Walls		Terra Cotta	eats and west facade	4	10	SF	\$5,363	
Walls		Terra Cotta	entrances and vertical/ horizontal bands	6	3,624	SF	\$103,646	
Windows		Skylite - Glass Single-Pane	Main Roof	4	50	SF	\$14,157	
Windows		Window - Guards perforated	Entire Building	6	2,412	SF	\$0	
Windows		Windows - Casement Steel	Basement	4	135	SF	\$36,950	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	6	8,640	SF	\$74,131	
EXTERIOR Sub Total							\$1,377,063	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Basement	6	1	EA	\$1,430	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	12,995	SF	\$5,575	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	4	8	EA	\$4,324	Obsolete
Emergency System		Exit Signs - Auditorium	1st Floor	2	6	EA	\$5,577	No battery backup, UPS or Generator
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	2	14	EA	\$13,013	No battery backup, UPS or Generator

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	3rd Floor	2	2	EA	\$1,859	No battery backup, UPS or Generator
Emergency System		Independent Electrical Service for emergency power	Basement	6	1	EA	\$1,430	
Emergency System		Public Announcement System	1st Floor	5	69,500	SF	\$99,385	
Emergency System		Security System - CCTV	1st Floor	5	69,500	SF	\$198,770	
Main Service		Main Electrical service - Live Front - 1200 A 120/208/3PH	Basement	6	1	EA	\$7,150	
Power Distribution		Lighting and power panels	Entire Building	6	12	EA	\$8,580	Live front panel for electric heaters
Power Distribution		Lighting and power panels	Basement	4	1	EA	\$5,434	
Power Distribution		Main distribution panels 400-600 amp	Basement	6	2	EA	\$2,860	
ELECTRICAL Sub Total							\$355,387	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Basement	4	71,400	SF	\$252,192	
FIRE PROTECTION Sub Total							\$252,192	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	3rd Floor	4	1	EA	\$2,145	
Air Conditioning		Window A/C Unit	Entire Building	6	9	EA	\$1,931	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Main Roof	4	3	EA	\$78,507	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Basement	4	2	EA	\$185,900	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Basement	6	1	EA	\$12,870	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Basement	4	1	EA	\$32,890	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Basement	4	2	EA	\$65,780	
Air Handling Systems		Reheat Boxes With Steam Coils	Basement	4	10	EA	\$104,390	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Entire Building	5	300	LF	\$128,700	
Heating Devices		Radiators - Steam	Entire Building	4	14	EA	\$19,620	
Heating Devices		Wall Heater - Electric	Entire Building	4	16	EA	\$16,474	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Basement	6	1	EA	\$715	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Basement	4	300	LF	\$29,387	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Basement	4	300	LF	\$35,929	
Mechanical Plumbing		Pumps - Vacuum	Basement	4	1	EA	\$28,600	
Temperature Control		Pneumatic System	Basement	4	69,500	SF	\$496,925	
Temperature Control		Thermostats - Pneumatic	Entire Building	4	42	EA	\$27,628	
Temperature Control		Zone Dampers	Basement	4	45	EA	\$37,967	
Unit Ventilation		Unit Ventilators - Steam	Entire Building	4	6	EA	\$94,380	
Ventilation		Exhaust Fan - Indoor	Basement	4	1	EA	\$5,577	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Lower Roof	4	1	EA	\$2,288	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Lower Roof	4	2	EA	\$3,146	
MECHANICAL Sub Total							\$1,411,746	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Basement	6	1	EA	\$4,147	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	5	69,500	SF	\$11,926	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	69,500	SF	\$22,859	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	5	69,500	SF	\$79,508	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	69,500	SF	\$14,908	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	69,500	SF	\$17,889	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	69,500	SF	\$61,619	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	5	69,500	SF	\$36,772	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	69,500	SF	\$37,766	
Piping		Sanitary Piping	Entire Building	5	69,500	SF	\$42,736	
Piping		Storm Piping	Entire Building	5	69,500	SF	\$32,797	
Piping		Vent Piping	Entire Building	5	69,500	SF	\$24,846	
Pumps		Domestic Booster Pump simplex	Basement	4	1	EA	\$17,160	
PLUMBING Sub Total							\$404,933	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	principals office 1st fl	7	288	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office	7	400	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	3rd fl gym office/storage across from gym	7	376	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	between 315/314	7	240	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	205	7	376	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	principals office 1st fl	7	288	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	between 315/314	6	240	SF	\$343	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office	7	400	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	3rd fl gym office/storage across from gym	7	376	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	205	5	376	SF	\$2,129	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	principals office 1st fl	6	4	SF	\$3	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	205	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	between 315/314	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	3rd fl gym office/storage across from gym	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	principals office 1st fl	7	1,291	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	7	780	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	205	6	940	SF	\$2,218	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	3rd fl gym office/storage across from gym	6	940	SF	\$2,218	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	between 315/314	6	553	SF	\$1,305	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor	6	83	EA	\$3,055	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	6	250	EA	\$9,202	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	6	7	EA	\$79,279	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Steel Doors incl hw	Basement	7	3	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	5	3	EA	\$1,416	
Doors		Interior Wood Doors incl hw	Entire Building	4	111	EA	\$356,190	
Doors		Interior Wood Doors incl hw	Entire Building	6	5	EA	\$1,416	
Doors		Transom Window	Entire Building	6	738	SF	\$13,719	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	3rd Floor	6	2,718	SF	\$23,243	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	3rd Floor	7	2,718	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Lay-In	3rd Floor	7	10	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	3rd Floor	7	1	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	3rd Floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in principals office			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in 107			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in between 315/314			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Lockers	in principals office			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in 107			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in between 315/314			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in between 315/314			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls north			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in 107			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in principals office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys			EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	4	SF	\$19	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	5,237	SF	\$24,713	
Mechanical/Service Rooms		Storage Room	principals	6	285	SF	\$1,345	
Mechanical/Service Rooms		Storage Room	auditorium light room	7	72	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys	6	275	SF	\$2,124	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls south	6	275	SF	\$2,124	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls south	6	275	SF	\$2,124	
Staff Restroom	Early Childhood Student Restroom	Accessories	in 107	7	43	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls north	6	275	SF	\$2,124	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys	6	275	SF	\$2,124	
Staff Restroom	Staff Restroom	Accessories	in principals office	7	28	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls south	6	275	SF	\$2,124	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls north	6	275	SF	\$2,124	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys	6	275	SF	\$2,124	
Staff Restroom	Staff Restroom	Accessories	in between 315/314	6	50	SF	\$386	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls north	6	275	SF	\$2,124	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	in 107	7	43	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls south	5	275	SF	\$1,557	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls south	5	275	SF	\$1,557	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls north	7	275	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in between 315/314	7	50	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls south	5	275	SF	\$1,557	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls north	5	275	SF	\$1,557	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in principals office	7	28	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys	5	295	SF	\$1,671	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls north	5	275	SF	\$1,557	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in 107			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in principals office			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in between 315/314			EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	in principals office	7	28	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls south	6	275	SF	\$700	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls south	6	275	SF	\$700	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls north	6	275	SF	\$700	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	in 107	7	43	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys	6	295	SF	\$751	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls north	6	275	SF	\$700	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys	6	295	SF	\$751	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys	6	295	SF	\$751	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls north	6	275	SF	\$700	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls south	6	275	SF	\$700	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in between 315/314	7	50	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in 107			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys	4	1	EA	\$2,171	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys	4	1	EA	\$2,171	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in between 315/314			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls north	4	1	EA	\$2,171	
Staff Restroom	Staff Restroom	Hand Dryer	in principals office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in principals office	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in between 315/314	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls north	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in 107	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl boys	7	3	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	in 107	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl girls north	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl boys	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl boys	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl girls north	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in between 315/314	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls south	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls north	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl girls south	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in principals office	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl girls south	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	in between 315/314	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls north	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls south	5	1	EA	\$572	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls south	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls south	5	2	EA	\$1,144	
Staff Restroom	Staff Restroom	Partitions	in between 315/314			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls north	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in principals office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls south	7	6	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls south	5	1	EA	\$572	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls south	7	6	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	in 107	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls north	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl girls south			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in principals office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl girls north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl girls north			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in between 315/314			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl girls south			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in 107	4	1	EA	\$3,718	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in between 315/314	6	217	SF	\$512	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl boys	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl girls north	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl boys	7	55	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	in 107	7	374	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	in principals office	7	297	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl girls south	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls south	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl girls south	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl girls north	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls north	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl boys	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls south	6	5	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Water Closet	in principals office	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in 107	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls north	6	5	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls north	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls south	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls north	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls north	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in between 315/314	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls south	6	7	EA	\$2,603	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls south	6	7	EA	\$2,603	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	1st Floor	7	1,988	SF	\$0	
Theater	Auditorium - Dedicated	Ceiling - Splined	1st Floor	6	1,152	SF	\$9,060	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Theater	Auditorium - Dedicated	Flooring - Carpet	1st Floor	6	726	SF	\$1,038	
Theater	Auditorium - Dedicated	Flooring - Concrete	1st Floor	7	828	SF	\$0	
Theater	Auditorium - Dedicated	Flooring - Tile/Sheet	1st Floor	6	1,326	SF	\$1,896	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	6	11	SF	\$18	
Theater	Auditorium - Dedicated	Stage	1st Floor	7	360	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Concrete Block	1st Floor	7	1,575	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	1st Floor	7	3,468	SF	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
INTERIOR Sub Total							\$607,172	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	22	LF	\$787	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		7	20	LF	\$0	
Casework	Classroom	Casework		6	22	LF	\$787	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Ceiling	Classroom	Lay-In/Drop		6	730	SF	\$1,566	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		7	760	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	760	SF	\$4,304	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	760	SF	\$4,304	
Ceiling	Classroom	Plaster/Drywall		7	1,104	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	760	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	760	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	760	SF	\$4,304	
Ceiling	Classroom	Plaster/Drywall		5	730	SF	\$4,134	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		6	730	SF	\$2,067	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	730	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	56	LF	\$6,807	
Chalk Board	Classroom	Chalk Board		4	44	LF	\$5,348	
Chalk Board	Classroom	Chalk Board		4	56	LF	\$6,807	
Chalk Board	Classroom	Chalk Board		4	7	LF	\$851	
Chalk Board	Classroom	Chalk Board		4	40	LF	\$4,862	
Chalk Board	Classroom	Chalk Board		4	40	LF	\$4,862	
Chalk Board	Classroom	Chalk Board		4	46	LF	\$5,591	
Chalk Board	Classroom	Chalk Board		4	56	LF	\$6,807	
Chalk Board	Classroom	Chalk Board		4	48	LF	\$5,834	
Chalk Board	Classroom	Chalk Board		4	52	LF	\$6,321	
Chalk Board	Classroom	Chalk Board		4	51	LF	\$6,199	
Chalk Board	Classroom	Chalk Board		4	55	LF	\$6,685	
Chalk Board	Classroom	Chalk Board		4	55	LF	\$6,685	
Chalk Board	Classroom	Chalk Board		4	40	LF	\$4,862	
Chalk Board	Classroom	Chalk Board		4	56	LF	\$6,807	
Chalk Board	Classroom	Chalk Board		4	56	LF	\$6,807	
Chalk Board	Classroom	Chalk Board		4	35	LF	\$4,254	
Chalk Board	Classroom	Chalk Board		4	40	LF	\$4,862	
Chalk Board	Classroom	Chalk Board		4	50	LF	\$6,078	
Chalk Board	Classroom	Chalk Board		4	48	LF	\$5,834	
Chalk Board	Classroom	Chalk Board		4	334	LF	\$40,598	
Chalk Board	Classroom	Chalk Board		4	40	LF	\$4,862	
Chalk Board	Classroom	Chalk Board		4	43	LF	\$5,227	
Chalk Board	Classroom	Chalk Board		4	43	LF	\$5,227	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	55	LF	\$6,685	
Chalk Board	Classroom	Chalk Board		4	56	LF	\$6,807	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	56	LF	\$6,807	
Chalk Board	Classroom	Chalk Board		4	56	LF	\$6,807	
Chalk Board	Classroom	Chalk Board		4	48	LF	\$5,834	
Chalk Board	Classroom	Chalk Board		4	48	LF	\$5,834	
Chalk Board	Classroom	Chalk Board		4	48	LF	\$5,834	
Chalk Board	Classroom	Chalk Board		4	55	LF	\$6,685	
Corridors	Corridors	Ceiling	1st, 2nd, and 3rd fl corridor	7	10,174	SF	\$0	
Corridors	Corridors	Drinking Fountains	Center Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	North Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	South Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	vestibule at door 3			EA	\$0	
Corridors	Corridors	Drinking Fountains	1st, 2nd, and 3rd fl corridor			EA	\$0	
Corridors	Corridors	Drinking Fountains	1s fl vestibules			EA	\$0	
Corridors	Corridors	Pendant/Surface	Center Stair	7	725	EA	\$0	
Corridors	Corridors	Pendant/Surface	North Stair	7	725	EA	\$0	
Corridors	Corridors	Pendant/Surface	South Stair	7	725	EA	\$0	
Corridors	Corridors	Pendant/Surface	vestibule at door 3	6	1	EA	\$1	
Corridors	Corridors	Pendant/Surface	1st, 2nd, and 3rd fl corridor	7	10,174	EA	\$0	
Corridors	Corridors	Pendant/Surface	1s fl vestibules	7	6	EA	\$0	
Corridors	Corridors	Plaster/Drywall	vestibule at door 3	4	75	SF	\$708	
Corridors	Corridors	Plaster/Drywall	1st, 2nd, and 3rd fl corridor	6	13,699	SF	\$32,323	
Corridors	Corridors	Plaster/Drywall	North Stair	5	500	SF	\$2,360	
Corridors	Corridors	Plaster/Drywall	North Stair	7	1,500	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Center Stair	5	500	SF	\$2,360	
Corridors	Corridors	Plaster/Drywall	Center Stair	7	1,500	SF	\$0	
Corridors	Corridors	Plaster/Drywall	South Stair	7	1,500	SF	\$0	
Corridors	Corridors	Plaster/Drywall	South Stair	5	500	SF	\$2,360	
Corridors	Corridors	Plaster/Drywall	1s fl vestibules	6	1,847	SF	\$4,358	
Corridors	Corridors	Stair Handrails	North Stair	6	118	LF	\$0	
Corridors	Corridors	Stair Handrails	Center Stair	6	118	LF	\$0	
Corridors	Corridors	Stair Handrails	1s fl vestibules			LF	\$0	
Corridors	Corridors	Stair Handrails	1st, 2nd, and 3rd fl corridor			LF	\$0	
Corridors	Corridors	Stair Handrails	vestibule at door 3			LF	\$0	
Corridors	Corridors	Stair Handrails	South Stair	6	118	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Stairs	vestibule at door 3			EA	\$0	
Corridors	Corridors	Stairs	1st, 2nd, and 3rd fl corridor			EA	\$0	
Corridors	Corridors	Stairs	1s fl vestibules			EA	\$0	
Corridors	Corridors	Student Lockers	1st, 2nd, and 3rd fl corridor	5	531	EA	\$94,916	
Corridors	Corridors	Student Lockers	Center Stair			EA	\$0	
Corridors	Corridors	Student Lockers	vestibule at door 3			EA	\$0	
Corridors	Corridors	Student Lockers	North Stair			EA	\$0	
Corridors	Corridors	Student Lockers	1s fl vestibules			EA	\$0	
Corridors	Corridors	Student Lockers	South Stair			EA	\$0	
Corridors	Corridors	Terrazzo	North Stair	7	548	SF	\$0	
Corridors	Corridors	Terrazzo	1s fl vestibules	6	253	SF	\$1,433	
Corridors	Corridors	Terrazzo	Center Stair	7	548	SF	\$0	
Corridors	Corridors	Terrazzo	South Stair	7	548	SF	\$0	
Corridors	Corridors	Terrazzo	1st, 2nd, and 3rd fl corridor	7	1,568	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	Center Stair	7	198	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	vestibule at door 3	7	105	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1s fl vestibules	7	210	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	1st, 2nd, and 3rd fl corridor	7	8,606	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	South Stair	7	198	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	North Stair	7	198	SF	\$0	
Corridors	Corridors	Walls	South Stair	6	619	SF	\$1,461	
Corridors	Corridors	Walls	1st, 2nd, and 3rd fl corridor	6	8,093	SF	\$19,095	
Corridors	Corridors	Walls	South Stair	5	619	SF	\$2,921	
Corridors	Corridors	Walls	1s fl vestibules	6	408	SF	\$963	
Corridors	Corridors	Walls	North Stair	6	619	SF	\$1,461	
Corridors	Corridors	Walls	Center Stair	6	619	SF	\$1,461	
Corridors	Corridors	Walls	North Stair	5	619	SF	\$2,921	
Corridors	Corridors	Walls	vestibule at door 3	6	138	SF	\$326	
Corridors	Corridors	Walls	Center Stair	5	619	SF	\$2,921	
Corridors Ceiling	Corridors	Plaster/Drywall	North Stair	7	725	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1s fl vestibules	7	541	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	vestibule at door 3	4	105	SF	\$1,387	
Corridors Ceiling	Corridors	Plaster/Drywall	South Stair	7	725	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Center Stair	7	725	SF	\$0	
Stairs	Corridors	Terrazzo	Center Stair	6	58	SF	\$657	
Stairs	Corridors	Terrazzo	North Stair	6	58	SF	\$657	
Stairs	Corridors	Terrazzo	South Stair	6	58	SF	\$657	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl girls north	7	797	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	3rd fl girls south	7	797	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd fl girls south	7	797	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st fl girls south	7	797	SF	\$0	
THEATER_WALL	Auditorium - Dedicated	Auditorium Walls	1st Floor	7	465	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,275	SF	\$3,008	
Wall	Classroom	Plaster/Drywall		5	1,275	SF	\$6,017	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,170	SF	\$2,761	
Wall	Classroom	Plaster/Drywall		6	1,170	SF	\$2,761	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		5	1,794	SF	\$8,466	
Wall	Classroom	Plaster/Drywall		5	1,275	SF	\$6,017	
Wall	Classroom	Plaster/Drywall		6	1,275	SF	\$3,008	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,275	SF	\$3,008	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
Wall	Classroom	Plaster/Drywall		5	1,275	SF	\$6,017	
Wall	Classroom	Plaster/Drywall		6	1,215	SF	\$2,867	
ROOM Sub Total							\$734,237	
Building Main Sub Total							\$5,142,730	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Metal Flue	Entire Building	7	12	LF	\$0	
Doors		Exterior Steel Door	Entire Building	7	12	EA	\$0	
Doors		Side Lite	east and west entrances	7	4	EA	\$0	
Doors		Transom Lite	Entire Building	7	4	EA	\$0	
Entrance		Concrete Exterior Stairs	east and west entrances	7	68	LF	\$0	
Entrance		Concrete Ramp	east, west, south	7	141	LF	\$0	
Entrance		Power Door Operator and Controls	east entrance 5	4	1	EA	\$4,908	
Entrance		Ramp Handrails	east and west	7	117	LF	\$0	
Entrance		Stair Handrails	east and west	7	34	LF	\$0	
Foundation		Concrete Foundation	Entire Building	7	513	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	10	EA	\$2,145	
Lintels		Lintels - Steel	Entire Building	7	708	LF	\$0	
Parapet		Coping - Metal	Entire Building	7	514	LF	\$0	
Parapet		Parapet < 16" Height	Entire Building	7	514	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	600	LF	\$0	
Roof System		Modified Bitumen Roof	Entire Building	6	11,503	SF	\$81,424	
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Entire Building	7	11,503	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	34,100	SF	\$0	
Walls		Brick	Entire Building	7	15,478	SF	\$0	
Walls		Stone - Cast	east and west entrances and horizontal band	7	648	SF	\$0	
Windows		Curtain wall - Louver	masonry wall	7	260	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	1,144	SF	\$0	
Windows		Windows - Casement Aluminum Double-pane	Entire Building	7	4,904	SF	\$0	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
EXTERIOR Sub Total							\$88,477	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	6	6,624	SF	\$2,842	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	6	1,914	SF	\$1,013	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	6	1,128	SF	\$484	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	2	12	EA	\$11,154	No battery backup, UPS or Generator installed
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	2	2	EA	\$1,859	No battery backup, UPS or Generator installed
Emergency System		Independent Electrical Service for emergency power	Electrical Room	6	1	EA	\$1,430	
Emergency System		Public Announcement System	1st Floor	5	35,100	SF	\$50,193	Not working properly
Emergency System		Security System - CCTV	Electrical Room	5	35,100	SF	\$100,386	
Main Service		Main Electrical service - Live Front - 2000 to 3000 A 120/208/3PH	Electrical Room	6	1	EA	\$24,310	
Power Distribution		Lighting and power panels	Entire Building	6	8	EA	\$5,720	
Power Distribution		Main distribution panels above 600 amp	Mechanical Room	6	1	EA	\$2,145	
ELECTRICAL Sub Total							\$201,535	

Building: Addition
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	35,100	SF	\$0	
Fire Alarm		Fire Alarm System	Mechanical Room	7	35,100	SF	\$0	
Fire Alarm		Fire Pump Controller	Fire pump room	6	1	EA	\$2,145	
Pump Room Assembly		Fire Pump 25-50hp	Fire pump room	6	1	EA	\$3,718	Needs lubrication
Sprinkler System		Sprinkler Heads	Entire Building	7	35,100	SF	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	7	35,100	SF	\$0	
FIRE PROTECTION Sub Total							\$5,863	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 100 to 200 tons	Roof	5	1	EA	\$139,425	Controls not working properly
Air Conditioning		Heat Pump - Self Contained	MDF Room Ceiling	6	1	EA	\$844	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 4,000 to 8,000 cfm	Mechanical Room	5	1	EA	\$15,730	Control Issues
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 12,001 to 20,000 cfm	Mechanical Room	5	1	EA	\$24,310	Control Issues
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	Mechanical Room	5	1	EA	\$21,450	Control Issues
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	Mechanical Room	6	3	EA	\$4,290	
Air Handling Systems		Fan Power Box With Hot Water Coil	Entire Building	5	30	EA	\$57,915	Majority of FPB control valves are not working properly
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	Mechanical Room	6	1	EA	\$2,431	
Air Handling Systems		Return Fans - Indoor 5,000 to 10,000 CFM	Mechanical Room	6	1	EA	\$1,716	
Air Handling Systems		Return Fans - Indoor less than 5,000 CFM	Mechanical Room	6	1	EA	\$715	
Boiler Systems		Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler 1,001MBH-2,000 MBH	Mechanical Room	6	2	EA	\$15,730	
Boiler Systems		Boiler Auxiliary Non-Condensing Hot Water Boiler 1,001MBH-2,000 MBH	Mechanical Room	6	2	EA	\$10,010	
Boiler Systems		Chemical Pot Feeder - Hot Water	Mechanical Room	6	2	EA	\$601	
Boiler Systems		Combustion Dampers	Mechanical Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Mechanical Room	6	1	EA	\$8,437	
Boiler Systems		Glycol Feed System	Mechanical Room	6	1	EA	\$1,087	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	6	4	EA	\$2,002	
Heating Devices		Unit Heater - Hot Water	Entire Building	6	5	EA	\$7,150	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Mechanical Room	6	350	LF	\$3,103	
Mechanical Plumbing		Pumps - Chilled Water less than 10 HP	Mechanical Room	5	2	EA	\$17,160	Base deteriorated and it appears leaking
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	Mechanical Room	6	2	EA	\$2,860	Needs lubrication
Temperature Control		Direct Digital Control (DDC) System	Mechanical Room	5	35,100	SF	\$175,676	Not working properly
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	5	30	EA	\$16,731	Majority are not working properly
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	3	EA	\$1,287	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	6	2	EA	\$315	
MECHANICAL Sub Total							\$531,545	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas less than 150,000 BTU/HR	Mechanical Room	6	2	EA	\$7,150	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	35,100	SF	\$4,015	
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	35,100	SF	\$5,521	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	35,100	SF	\$5,521	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	6	35,100	SF	\$5,521	
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	35,100	SF	\$5,521	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	35,100	SF	\$8,031	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	35,100	SF	\$7,027	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	35,100	SF	\$5,521	
Piping		Sanitary Piping	Entire Building	7	35,100	SF	\$0	
Piping		Storm Piping	Entire Building	7	35,100	SF	\$0	
Piping		Vent Piping	Entire Building	7	35,100	SF	\$0	
Pumps		Domestic Booster Pump duplex	Fire pump room	6	1	EA	\$3,146	
Pumps		Sump Pump	1st Floor	6	1	EA	\$1,359	

PLUMBING Sub Total \$58,334

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	120B attendance/ copy room	6	204	SF	\$438	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	library office in 217	6	209	SF	\$448	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	117 teachers work room	7	642	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	kitchen office	6	105	SF	\$225	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	counselors conference room	7	205	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	counselors office	7	200	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st floor vacant office	7	180	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	counselors office	7	200	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	1st floor vacant office	7	180	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	kitchen office	6	105	SF	\$150	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	117 teachers work room	7	642	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	counselors conference room	7	205	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	library office in 217	7	209	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	120B attendance/ copy room	7	204	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	library office in 217	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	counselors conference room	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	counselors office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	1st floor vacant office	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	117 teachers work room	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	kitchen office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	120B attendance/ copy room	7	3	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	library office in 217	6	140	SF	\$400	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	counselors conference room	7	405	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	counselors office	7	455	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st floor vacant office	7	330	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	120B attendance/ copy room	7	385	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	117 teachers work room	7	615	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	kitchen office	7	410	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	library office in 217	6	440	SF	\$1,038	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	1st floor vacant office	6	290	SF	\$684	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	counselors office	6	295	SF	\$696	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	counselors conference room	7	205	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	120B attendance/ copy room	5	204	SF	\$963	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	117 teachers work room	5	265	SF	\$1,251	
Doors		Interior Steel Doors incl hw	Entire Building	6	20	EA	\$5,663	
Doors		Interior Wood Doors incl hw	Entire Building	7	11	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	40	EA	\$11,326	
Doors		Side-lite	Entire Building	6	825	SF	\$15,337	
Doors		Store Front Door	Entire Building	6	4	EA	\$944	
Kitchen	Warming Kitchen	Ceiling - Exposed	1st Floor	7	100	SF	\$0	
Kitchen	Warming Kitchen	Ceiling - Lay-In	1st Floor	7	24	SF	\$0	
Kitchen	Warming Kitchen	Ceiling - Plaster/Drywall	1st Floor	7	846	SF	\$0	
Kitchen	Warming Kitchen	Lighting - Lay-In	1st Floor	7	13	SF	\$0	
Kitchen	Warming Kitchen	Lighting - Pendant/Surface	1st Floor	6	2	SF	\$1	
Kitchen	Warming Kitchen	Wall - Concrete Block	1st Floor	7	1,550	SF	\$0	
Library	Library	Casework	217	6	69	LF	\$2,116	
Library	Library	Flooring Carpet	217	7	1,450	SF	\$0	
Library	Library	Lighting - Lay-In	217	6	20	SF	\$14	
Locker/Shower Room	Staff Restroom	Benches	2nd floor womens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor mens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st floor womens LOCKED			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor womens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd floor mens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd floor mens			LF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor womens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st floor womens LOCKED			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd floor mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor womens LOCKED			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd floor womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor womens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd floor mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st floor mens			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	119 and 121	6	1,914	SF	\$4,106	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	119 and 121	7	1,914	SF	\$0	
Lunchroom	Lunchroom	Lighting - Lay-In	119 and 121	7	28	SF	\$0	
Lunchroom	Warming Kitchen	Serving Line	1st Floor	7	12	LF	\$0	
Lunchroom	Lunchroom	Serving Line	119 and 121	7	8	LF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Lunchroom	Wall - Concrete Block	119 and 121	6	1,600	SF	\$4,576	
MDF/IDF		Finishes	2nd Floor	6	75	SF	\$255	
MDF/IDF		Ventilation and Cooling	2nd Floor	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	3	SF	\$14	
Mechanical/Service Rooms		Mechanical/Service Rooms	kitchen coolers	7	98	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st floor fire pump room	7	194	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	6	375	SF	\$1,770	
Mechanical/Service Rooms		Mechanical/Service Rooms	3rd Floor	6	1,653	SF	\$7,801	
Mechanical/Service Rooms		Storage Room	counselor office	7	75	SF	\$0	
Mechanical/Service Rooms		Storage Room	Entire Building	7	801	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys	6	188	SF	\$1,452	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys	6	188	SF	\$1,452	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls	6	188	SF	\$1,452	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls	6	188	SF	\$1,452	
Staff Restroom	Staff Restroom	Accessories	1st floor mens	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys	6	188	SF	\$1,452	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls	6	188	SF	\$1,452	
Staff Restroom	Staff Restroom	Accessories	3rd floor womens	6	45	SF	\$347	
Staff Restroom	Staff Restroom	Accessories	2nd floor womens	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st floor womens LOCKED	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd floor mens	7	42	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd floor mens	6	42	SF	\$324	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls	6	188	SF	\$532	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd floor mens	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls	6	188	SF	\$532	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	3rd floor womens	7	45	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys	6	188	SF	\$532	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor womens	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor womens LOCKED	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd floor mens	7	42	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls	6	188	SF	\$532	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st floor mens	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor womens LOCKED			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	3rd floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys	7	188	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls	7	188	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor mens	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls	7	188	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys	7	188	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor mens	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys	7	188	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd floor womens	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor womens	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st floor womens LOCKED	7	45	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd floor mens	7	42	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls	7	188	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls	6	1	EA	\$217	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st floor womens LOCKED			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	1st floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st floor womens LOCKED	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd floor womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd floor womens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	3rd floor mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd fl boys	7	3	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl girls	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl girls	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl boys	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor mens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd floor mens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st floor womens LOCKED	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd floor womens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd floor womens	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd floor mens	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	3rd fl girls	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor womens LOCKED			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd floor womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd floor womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor womens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd floor womens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor womens LOCKED			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd floor mens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st floor mens			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys	6	3	EA	\$1,115	
Staff Restroom	Staff Restroom	Urinals	3rd floor mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	3rd fl boys	6	64	SF	\$183	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	3rd fl girls	6	72	SF	\$206	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st fl boys	7	64	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd fl girls	6	72	SF	\$206	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	2nd fl boys	6	64	SF	\$183	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	1st fl girls	6	72	SF	\$206	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd fl boys	6	584	SF	\$1,487	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st fl girls	6	552	SF	\$1,405	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl girls	6	552	SF	\$1,405	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st fl boys	6	584	SF	\$1,487	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor womens	7	216	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor womens	7	216	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st floor womens LOCKED	7	216	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd floor mens	7	208	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	1st floor mens	7	208	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl boys	6	584	SF	\$1,487	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	3rd floor mens	7	208	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd fl girls	6	552	SF	\$1,405	
Staff Restroom	Staff Restroom	Water Closet	3rd floor mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd floor womens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor womens LOCKED	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor mens	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st floor mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd floor womens	7	1	EA	\$0	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	3	EA	\$1,158	
INTERIOR Sub Total							\$87,879	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	27	LF	\$965	
Casework	Classroom	Casework		5	72	LF	\$12,870	
Casework	Classroom	Casework		5	71	LF	\$12,691	
Casework	Classroom	Casework		6	36	LF	\$1,287	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		5	62	LF	\$11,083	
Casework	Classroom	Casework		5	71	LF	\$12,691	
Casework	Classroom	Casework		6	21	LF	\$751	
Casework	Classroom	Casework		6	83	LF	\$2,967	
Casework	Classroom	Casework		5	36	LF	\$6,435	
Casework	Classroom	Casework		5	71	LF	\$12,691	
Casework	Classroom	Casework		5	71	LF	\$12,691	
Casework	Classroom	Casework		5	71	LF	\$12,691	
Casework	Classroom	Casework		5	36	LF	\$6,435	
Casework	Classroom	Casework		5	71	LF	\$12,691	
Ceiling	Classroom	Lay-In/Drop		6	1,131	SF	\$2,426	
Ceiling	Classroom	Lay-In/Drop		6	1,102	SF	\$2,364	
Ceiling	Classroom	Lay-In/Drop		6	855	SF	\$1,834	
Ceiling	Classroom	Lay-In/Drop		7	885	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	1,131	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	855	SF	\$1,834	
Ceiling	Classroom	Lay-In/Drop		7	551	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		7	855	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,102	SF	\$2,364	
Ceiling	Classroom	Lay-In/Drop		6	855	SF	\$1,834	
Ceiling	Classroom	Lay-In/Drop		6	855	SF	\$1,834	
Ceiling	Classroom	Lay-In/Drop		7	855	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	361	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	885	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	551	SF	\$1,182	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Lunchroom	Chalk Board	119 and 121	4		LF		
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Corridors	Corridors	Carpet	connecting corridors	6	120	SF	\$172	
Corridors	Corridors	Concrete Block	2nd Floor	7	2,870	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor	6	2,870	SF	\$8,208	
Corridors	Corridors	Concrete Block	east and west stairs	6	2,204	SF	\$6,303	
Corridors	Corridors	Concrete Block	3rd Floor	7	2,380	SF	\$0	
Corridors	Corridors	Concrete Block	connecting corridors	6	1,468	SF	\$4,198	
Corridors	Corridors	Concrete Block	south stairs	6	1,720	SF	\$4,919	
Corridors	Corridors	Drinking Fountains	south stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	east and west stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	connecting corridors			EA	\$0	
Corridors	Corridors	Drinking Fountains	3rd Floor	7	1	EA	\$0	
Corridors	Corridors	Drinking Fountains	2nd Floor	7	1	EA	\$0	
Corridors	Corridors	Drop/Lay-In	south stairs	6	425	SF	\$912	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Drop/Lay-In	east and west stairs	6	720	SF	\$1,544	
Corridors	Corridors	Drop/Lay-In	connecting corridors	6	1,150	SF	\$2,467	
Corridors	Corridors	Drop/Lay-In	3rd Floor	7	1,148	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	1,436	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	6	1,460	SF	\$3,132	
Corridors	Corridors	Lay-In	1st Floor	7	1,460	EA	\$0	
Corridors	Corridors	Lay-In	3rd Floor	7	1,148	EA	\$0	
Corridors	Corridors	Lay-In	connecting corridors	7	1,150	EA	\$0	
Corridors	Corridors	Lay-In	east and west stairs	7	900	EA	\$0	
Corridors	Corridors	Lay-In	south stairs	7	530	EA	\$0	
Corridors	Corridors	Lighting	2nd Floor	7	1,436	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	2	EA	\$0	
Corridors	Corridors	Single Water Cooler	2nd Floor	6	1	EA	\$615	
Corridors	Corridors	Single Water Cooler	3rd Floor	6	1	EA	\$615	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	connecting corridors			LF	\$0	
Corridors	Corridors	Stair Handrails	east and west stairs	5	114	LF	\$1,506	
Corridors	Corridors	Stair Handrails	south stairs	6	31	LF	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	connecting corridors			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	east and west stairs			EA	\$0	
Corridors	Corridors	Student Lockers	south stairs			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	connecting corridors			EA	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	south stairs	6	300	SF	\$764	
Corridors	Corridors	Tile Ceramic/Porcelain	east and west stairs	6	480	SF	\$1,222	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	7	1,148	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	south stairs	5	225	SF	\$1,274	
Corridors	Corridors	Tile/Sheet Flooring	east and west stairs	5	550	SF	\$3,115	
Corridors	Corridors	Tile/Sheet Flooring	connecting corridors	6	1,030	SF	\$1,473	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	7	1,436	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	7	1,460	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	east and west stairs	7	180	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	south stairs	7	105	SF	\$0	
Stairs	Corridors	Tile	east and west stairs	5	88	SF	\$1,661	
Stairs	Corridors	Tile	south stairs	5	22	SF	\$415	
Floor	Classroom	Carpet		6	361	SF	\$516	
Floor	Classroom	Tile/Sheet		7	1,131	SF	\$0	
Floor	Classroom	Tile/Sheet		7	855	SF	\$0	
Floor	Classroom	Tile/Sheet		7	855	SF	\$0	
Floor	Classroom	Tile/Sheet		6	885	SF	\$1,266	
Floor	Classroom	Tile/Sheet		7	855	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,102	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,102	SF	\$0	
Floor	Classroom	Tile/Sheet		7	551	SF	\$0	
Floor	Classroom	Tile/Sheet		7	855	SF	\$0	
Floor	Classroom	Tile/Sheet		7	855	SF	\$0	
Floor	Classroom	Tile/Sheet		7	551	SF	\$0	
Floor	Classroom	Tile/Sheet		6	885	SF	\$1,266	
Floor	Classroom	Tile/Sheet		7	855	SF	\$0	
Floor	Classroom	Tile/Sheet		7	855	SF	\$0	
Floor	Classroom	Tile/Sheet		7	551	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,131	SF	\$0	
KITCHEN_FLOOR	Warming Kitchen	Kitchen Floor	1st Floor	5	970	SF	\$11,027	
LIBRARY_CEILING	Library	Drop/Lay-In	217	7	1,450	SF	\$0	
LIBRARY_WALL	Library	Concrete Block	217	7	750	SF	\$0	
LIBRARY_WALL	Library	Plaster/Drywall	217	5	580		\$2,737	
Lighting	Classroom	Lay-In		6	15	EA	\$1,073	
Lighting	Classroom	Lay-In		6	15	EA	\$1,073	
Lighting	Classroom	Lay-In		7	8	EA	\$0	
Lighting	Classroom	Lay-In		7	8	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	16	EA	\$1,144	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		6	16	EA	\$1,144	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	5	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Lunchroom	Marker Board	119 and 121			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	1st fl boys	6	188	SF	\$532	
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	2nd fl boys	5	188	SF	\$1,065	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2nd fl boys	7	3	EA	\$0	
Wall	Classroom	Concrete Block		7	990	SF	\$0	
Wall	Classroom	Concrete Block		7	280	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	
Wall	Classroom	Concrete Block		7	180	SF	\$0	
Wall	Classroom	Concrete Block		7	630	SF	\$0	
Wall	Classroom	Concrete Block		7	920	SF	\$0	
Wall	Classroom	Concrete Block		7	620	SF	\$0	
Wall	Classroom	Concrete Block		7	620	SF	\$0	
Wall	Classroom	Concrete Block		7	990	SF	\$0	
Wall	Classroom	Concrete Block		7	630	SF	\$0	
Wall	Classroom	Concrete Block		7	280	SF	\$0	
Wall	Classroom	Concrete Block		7	630	SF	\$0	
Wall	Classroom	Concrete Block		7	630	SF	\$0	
Wall	Classroom	Concrete Block		7	580	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		7	630	SF	\$0	
Wall	Classroom	Plaster/Drywall		5	290	SF	\$1,369	
Wall	Classroom	Plaster/Drywall		6	580	SF	\$1,369	
Wall	Classroom	Plaster/Drywall		6	580	SF	\$1,369	
Wall	Classroom	Plaster/Drywall		5	580	SF	\$2,737	
Wall	Classroom	Plaster/Drywall		5	290	SF	\$1,369	
Wall	Classroom	Plaster/Drywall		6	290	SF	\$684	
Wall	Classroom	Plaster/Drywall		6	290	SF	\$684	
Wall	Classroom	Plaster/Drywall		5	520	SF	\$2,454	
Wall	Classroom	Plaster/Drywall		5	520	SF	\$2,454	
Wall	Classroom	Plaster/Drywall		6	580	SF	\$1,369	
Wall	Classroom	Plaster/Drywall		6	290	SF	\$684	
Wall	Classroom	Plaster/Drywall		6	380	SF	\$897	
ROOM Sub Total							\$252,023	
Building Addition Sub Total							\$1,225,656	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	4	EA	\$0	
Civil/Drainage		Catch Basin	west parking lot	5	1	EA	\$1,216	displaced/ uneven
Civil/Drainage		Site Manhole	Entire Site	7	14	EA	\$0	
Fencing		Chain Link	site- east,west, south	5	698	LF	\$24,954	
Fencing		Chain Link	site- SW	4	55	LF	\$5,899	
Fencing		Chain Link	west at parking lot	7	183	LF	\$0	
Fencing		Iron and Concrete Post	Site ζ West	7	792	LF	\$0	
Landscape		Asphalt Play Area/Hardscape	Site - East	6	23,107	SF	\$19,826	
Landscape		Benches	East Courtyard	7	6	EA	\$0	
Landscape		Grass	site-south and east	7	14,888	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	2,340	SF	\$0	
Landscape		Parkway trees	Entire Site	7	32	EA	\$0	
Landscape		Planting Beds/ Areas	West Courtyard	7	600	SF	\$0	
Landscape		Retaining Wall - Concrete	Site ζ South	5	150	SF	\$11,680	
Landscape		Retaining Wall - Concrete	Site ζ West	7	824	SF	\$0	
Landscape		Trash Receptacles	Entire Site	7	3	EA	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Asphalt	site- NW	7	19,107	SF	\$0	
Parking Lot		Concrete Curbs	Site ζ North	7	300	LF	\$0	
Parking Lot		Concrete Curbs	north at parking east end	5	33	LF	\$658	
Parking Lot		Lights, Pole Mounted	Parking Lot	6	3	EA	\$3,432	
Parking Lot		Vehicular Screening	Site ζ West	7	241	LF	\$0	
Playground		Playground Equipment - Combo 3-12	Site ζ West	7	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Site ζ West	7	2,400	SF	\$0	
Sidewalks		Internal Walks	east and NW corner	7	120	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	17,175	SF	\$0	
Signage		Flag Pole	site- SE	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	site- SE	6	1	EA	\$0	
SITE Sub Total							\$67,663	
SITE Sub Total							\$67,663	

Total Campus Need ^{2 3} \$6,436,050

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
100	730	2	8	18	40	120	68		N	N	Y	Classroom		
101	730	2	8	18	40	120	68		N	N	Y	Classroom		
102	730	2	8	18	40	120	68		N	N	Y	Classroom		
107	1104		1	12	40	96	48		N	N	Y	Classroom		
110	730	1		10	40	120	68		N	N	Y	Classroom		
111	730	1		10	40	120	68		N	N	Y	Classroom		
112	730	1		10	40	120	68		N	N	Y	Classroom		
113	730	1		10	40	120	68		N	N	Y	Classroom		
114	760	2	8	18	40	120	68	1	N	N	Y	Classroom		
115	760	2	8	18	40	120	68	1	N	N	Y	Classroom		
200	730	2	8	18	40	120	68		N	N	Y	Classroom		
201	730	2	8	18	40	120	68		N	N	Y	Classroom		
202	730	2	8	18	40	120	68		N	N	Y	Classroom		
203	730	2	8	18	40	120	68		N	N	Y	Classroom		
207	730	2	8	18	40	90	34	2	N	N	Y	Classroom		
209	730	2	8	18	40	90	34	2	N	N	Y	Classroom		
210	730	2	8	18	40	120	68		N	N	Y	Classroom		
211	730	2	8	18	40	120	68		N	N	Y	Classroom		
212	730	2	8	18	40	120	68		N	N	Y	Classroom		
213	730	2	8	18	40	120	68		N	N	Y	Classroom		
214	760	2	8	18	40	120	68	1	N	N	Y	Classroom		
215	760	2	8	18	40	120	68		N	N	Y	Classroom		
300	730	2	8	18	40	120	68		N	N	Y	Classroom		
301	730	2	8	18	40	120	68		N	N	Y	Classroom		
302	730	2	8	18	40	120	68		N	N	Y	Classroom		
303	730	2	8	18	40	120	68		N	N	Y	Classroom		
307	730	2	8	18	40	120	68		N	N	Y	Classroom		
309	730	2	8	18	40	120	68		N	N	Y	Classroom		
310	730	2	8	18	40	120	68		N	N	Y	Classroom		
311	730	2	8	18	40	120	68		N	N	Y	Classroom		
312	730	2	8	18	40	120	68		N	N	Y	Classroom		
313	730	2	8	18	40	120	68		N	N	Y	Classroom		
314	760	2	8	18	40	105	51	1	N	N	Y	Classroom		
315	760	2	8	18	40	105	51	1	N	N	Y	Classroom		
Other	275								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls north
Other	275								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls south

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other									N	N	N	Corridors		South Stair
Other									N	N	N	Corridors		Center Stair
Other									N	N	N	Corridors		North Stair
Other	295								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys
Other	275								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls south
Other	376			4					N	N	Y	Administrative Suites/Offices		3rd fl gym office/storage across from gym
Other	50								N	N	N	Restroom	Staff Restroom	in between 315/314
Other	240			10					N	N	N	Administrative Suites/Offices		between 315/314
Other	376			8					N	N	Y	Administrative Suites/Offices		205
Other	288			13					N	N	Y	Administrative Suites/Offices		principals office 1st fl
Other	275								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls north
Other	295								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys
Other	275								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls north
Other	295								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys
Other	275								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls south
Other	2718								N	N	N	Gymnasia	Standard Dedicated Gymnasium	3rd Floor
Other	43								N	N	N	Restroom	Early Childhood Student Restroom	in 107
Other	28								N	N	N	Restroom	Staff Restroom	in principals office
Other	3056								N	N	N	Auditorium & Theater	Auditorium - Dedicated	1st Floor
Other	105								N	N	N	Corridors		vestibule at door 3
Other	10174								N	N	N	Corridors		1st, 2nd, and 3rd fl corridor
Other	541								N	N	N	Corridors		1s fl vestibules
Other	400			22					N	N	Y	Administrative Suites/Offices		Main Office

Building: Addition

120	1102		5	28	40	144	12		N	N	Y	Classroom		
122	855		6	24	40	108	9		N	N	Y	Classroom		
216	885		4	24	40	144	12		N	N	Y	Classroom		
217A	361		1	18	40	144	12		N	N	Y	Classroom		
219	551		4	22	40	72	6		N	N	Y	Classroom		
220	1102		4	28	40	144	12		N	N	Y	Classroom		
221	551		4	22	40	72	6		N	N	Y	Classroom		
222	855		6	26	40	108	9		N	Y	Y	Classroom		
223	855		6	22	40	108	9		N	N	Y	Classroom		
316	885		5	28	40	144	12		N	N	Y	Classroom		
317	855		4	20	40	180	14		N	N	Y	Classroom		
319	1131		46	98	40	144	12		N	N	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
321	1131		5	26	40	144	12		N	N	Y	Classroom		
323	855		5	24	40	108	9		N	N	Y	Classroom		
324	855		5	24	40	108	9		N	N	Y	Classroom		
Other	205			4					N	N	Y	Administrative Suites/Offices		counselors conference room
Other	204			10					N	N	N	Administrative Suites/Offices		120B attendance/ copy room
Other	642			14					N	N	N	Administrative Suites/Offices		117 teachers work room
Other	1460								N	N	N	Corridors		1st Floor
Other	1436								N	N	N	Corridors		2nd Floor
Other	1148								N	N	N	Corridors		3rd Floor
Other	1150								N	N	N	Corridors		connecting corridors
Other	720								N	N	N	Corridors		east and west stairs
Other	425								N	N	N	Corridors		south stairs
Other	970								N	N	N	Kitchen	Warming Kitchen	1st Floor
Other	1914								N	N	N	Lunch & Multipurpose Room	Lunchroom	119 and 121
Other	188								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys
Other	200			10					N	N	Y	Administrative Suites/Offices		counselors office
Other	105			8					N	N	Y	Administrative Suites/Offices		kitchen office
Other	209			8					N	N	Y	Administrative Suites/Offices		library office in 217
Other	1450								N	N	N	Library		217
Other	188								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls
Other	188								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys
Other	180			12					N	N	Y	Administrative Suites/Offices		1st floor vacant office
Other	42								N	N	N	Restroom	Staff Restroom	1st floor mens
Other	42								N	N	N	Restroom	Staff Restroom	2nd floor mens
Other	45								N	N	N	Restroom	Staff Restroom	1st floor womens LOCKED
Other	45								N	N	N	Restroom	Staff Restroom	2nd floor womens
Other	45								N	N	N	Restroom	Staff Restroom	3rd floor womens
Other	42								N	N	N	Restroom	Staff Restroom	3rd floor mens
Other	188								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls
Other	188								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys
Other	188								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls