

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	SW	6	104	LF	\$52,052	
Chimney		Brick Chimney - Concrete/ Mortar Liner	SW	5	20	LF	\$35,750	stepped cracks along ladder
Cornice		Cornice - Masonry Projecting/Limestone	Entire Building	6	1,389	LF	\$42,605	
Doors		Exterior FRP Door	Entire Building	7	11	EA	\$0	
Doors		Exterior Steel Door	fire escape and boiler room	7	4	EA	\$0	
Doors		Side Lite	fire escape doors	7	2	EA	\$0	
Doors		Transom Lite	door 1, courtyard door, fire escape door	7	7	EA	\$0	
Entrance		Concrete Exterior Stairs	south entrance 1	6	11	LF	\$1,180	
Entrance		Entrance Controls - Audio	south entrance - 1	7	1	EA	\$0	
Fire Escape		Fire Escapes	East Façade	6	4	LF	\$408	
Foundation		Masonry Foundation	Entire Building	7	489	SF	\$0	
Foundation		Masonry Foundation	Boiler Room	6	50	SF	\$4,955	seepage around perimeter
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	10	EA	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Wall Mounted	Entire Building	4	1	EA	\$1,573	
Lintels		Lintels - Brick	Entire Building	6	93	LF	\$0	
Lintels		Lintels - Steel	east door - boiler room	6	9	LF	\$340	
Lintels		Lintels - Stone	Entire Building	6	552	LF	\$0	
Parapet		Coping - Stone	1 story- east	6	96	LF	\$0	
Parapet		Coping - Terra Cotta	Entire Building	6	963	LF	\$0	open joints
Parapet		Parapet < 16" Height	1 story- east	5	10	LF	\$2,407	flashing bent, exposing brick parapet
Parapet		Parapet < 16" Height	Entire Building	6	646	LF	\$100,600	
Parapet		Parapet > 30" Height	Entire Building	6	326	LF	\$84,612	
Parapet		Parapet 16" to 30" Height	east- pitched metal roof	5	68	LF	\$21,821	step cracks
Roof System		Interior Downspouts	east side	6	459	LF	\$0	
Roof System		Metal Roof	east roof	7	1,450	SF	\$0	
Roof System		Modified Bitumen Roof	Main Roof	6	16,097	SF	\$113,943	
Roof System		Roof Structure: Concrete	Roof	7	17,547	SF	\$0	
Superstructure		Heavy Timber	Entire Building	7	63,279	SF	\$0	
Walls		Brick	Entire Building	6	28,979	SF	\$191,453	needs tuckpointing and cleaning
Walls		Concrete Block	east of building/ boiler room	6	72	SF	\$476	
Walls		Stone - Cut	South Façade	5	450	SF	\$48,263	ivy
Walls		Stone - Cut	Entire Building	6	4,327	SF	\$61,876	
Windows		Skylite - Glass Single-Pane	Roof	5	36	SF	\$2,175	putty failing, frame rusting
Windows		Window - Guards perforated	Entire Building	6	967	SF	\$0	
Windows		Window - Guards wire guard	East Façade	6	143	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	6	5,614	SF	\$48,168	

EXTERIOR Sub Total \$814,654

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Basement	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	10,681	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	1,706	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	969	SF	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Basement	7	5	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	3rd Floor	7	2	EA	\$0	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Exit Signs - Corridors and Stairs	Basement	7	3	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	3rd Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Basement	7	1	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Basement	7	1	EA	\$0	
Emergency System		Independent Electrical Service for emergency power	Electrical Room	7	1	EA	\$0	
Emergency System		Public Announcement System	Main Office	6	100,600	SF	\$60,420	
Emergency System		Security System - CCTV	Main Office	7	100,600	SF	\$0	
Emergency System		Security System - Intrusion detection	Main Office	7	100,600	SF	\$0	
Main Service		Main Electrical service 2000 to 3000 A 120/208/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Electrical Room	7	2	EA	\$0	
Power Distribution		Lighting and power panels	Basement	6	2	EA	\$1,430	
Power Distribution		Lighting and power panels	Basement	4	1	EA	\$5,434	
Power Distribution		Lighting and power panels	1st Floor	6	1	EA	\$715	
Power Distribution		Lighting and power panels	2nd Floor	6	1	EA	\$715	
Power Distribution		Lighting and power panels	Basement	7	1	EA	\$0	
Power Distribution		Lighting and power panels	2nd Floor	7	3	EA	\$0	
Power Distribution		Lighting and power panels	3rd Floor	7	2	EA	\$0	
Power Distribution		Lighting and power panels	1st Floor	7	2	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	3	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Basement	6	1	EA	\$1,144	

ELECTRICAL Sub Total \$69,858

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	63,279	SF	\$0	
Fire Alarm		Fire Alarm System	Basement	4	63,279	SF	\$223,508	
Fire Alarm		Fire Pump Controller	Fire Pump Room	4	1	EA	\$18,590	
Pump Room Assembly		Fire Pump less than 25hp	Fire Pump Room	5	1	EA	\$12,441	
Sprinkler System		Dry Sprinkler System	Entire Building	7	63,279	SF	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	5	63,279	SF	\$18,098	

FIRE PROTECTION Sub Total \$272,637

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Kitchen Office	4	1	EA	\$2,145	
Air Conditioning		Window A/C Unit	1st Floor	7	2	EA	\$0	
Air Conditioning		Window A/C Unit	1st Floor	6	6	EA	\$1,287	
Air Conditioning		Window A/C Unit	2nd Floor	6	6	EA	\$1,287	
Air Conditioning		Window A/C Unit	Room 206	4	1	EA	\$2,145	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Site z West	5	1	EA	\$16,016	
Air Handling Systems		Multi Zone Double Delivery Built Up Air Handling Unit - Steam 31,000 to 45,000 cfm	Basement	4	1	EA	\$143,000	
Air Handling Systems		Multi Zone Double Delivery Built Up Air Handling Unit Auxiliaries - Steam 30,001 to 45,000 cfm	Basement	5	1	EA	\$22,880	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Entire Building	4	200	LF	\$529,100	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler greater than 200 HP	Boiler Room	4	2	EA	\$597,740	
Boiler Systems		Boiler Auxiliary - Steam Boiler greater than 200 HP	Boiler Room	5	2	EA	\$32,890	
Boiler Systems		Chemical Feed System (Steam Boilers)	Tank Room	6	1	EA	\$2,145	
Boiler Systems		Combustion Dampers	Boiler Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Tank Room	4	1	EA	\$31,460	
Heating Devices		Radiators - Steam	1st Floor	5	4	EA	\$2,631	
Heating Devices		Radiators - Steam	2nd Floor	5	2	EA	\$1,316	
Heating Devices		Unit Heater - Electric	Electrical Room	6	1	EA	\$1,430	
Heating Devices		Unit Heater - Electric	Fire Pump Room	5	1	EA	\$2,574	
Heating Devices		Unit Heater - Gas	Boiler Room	7	1	EA	\$0	
Heating Devices		Wall Heater - Electric	Basement	7	2	EA	\$0	
Heating Devices		Wall Heater - Electric	Basement	6	8	EA	\$824	
Heating Devices		Wall Heater - Electric	2nd Floor	7	2	EA	\$0	
Heating Devices		Wall Heater - Electric	1st Floor	7	2	EA	\$0	
Heating Devices		Wall Heater - Electric	2nd Floor	6	1	EA	\$103	
Heating Devices		Wall Heater - Electric	1st Floor	6	1	EA	\$103	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	6	500	LF	\$3,432	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	6	500	LF	\$4,433	
Temperature Control		Pneumatic System	Tank Room	5	100,600	SF	\$431,574	
Temperature Control		Thermostats - Pneumatic	3rd Floor	7	9	EA	\$0	
Temperature Control		Thermostats - Pneumatic	2nd Floor	7	8	EA	\$0	
Temperature Control		Thermostats - Pneumatic	1st Floor	7	8	EA	\$0	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Temperature Control		Thermostats - Pneumatic	Basement	4	3	EA	\$1,973	
Temperature Control		Thermostats - Pneumatic	Basement	7	4	EA	\$0	
Temperature Control		Zone Dampers	Basement	6	29	EA	\$4,147	
Ventilation		Exhaust Fan - Indoor	2nd Floor	6	2	EA	\$1,001	
Ventilation		Exhaust Fan - Indoor	1st Floor	6	1	EA	\$501	
Ventilation		Exhaust Fan - Indoor	Electrical Room	6	1	EA	\$501	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	1	EA	\$1,502	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	6	1	EA	\$157	
Ventilation		Exhaust Fans - Roof mounted less than 500 CFM	Roof	4	1	EA	\$1,573	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Basement	7	1	EA	\$0	
MECHANICAL Sub Total							\$1,842,441	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	6	1	EA	\$4,147	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	6	1	EA	\$1,859	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	6	63,279	SF	\$7,239	
Piping		Domestic Piping - Cold Water Risers	Entire Building	6	63,279	SF	\$9,954	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	6	63,279	SF	\$9,954	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	6	63,279	SF	\$9,954	
Piping		Domestic Piping - Hot Water Risers	Entire Building	6	63,279	SF	\$9,954	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	6	63,279	SF	\$14,478	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	6	63,279	SF	\$12,668	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	6	63,279	SF	\$9,954	
Piping		Sanitary Piping	Entire Building	7	63,279	SF	\$0	
Piping		Storm Piping	Entire Building	7	63,279	SF	\$0	
Piping		Vent Piping	Entire Building	7	63,279	SF	\$0	
Pumps		Sump Pump	Fire Pump Room	7	1	EA	\$0	
Pumps		Sump Pump	Boiler Room	6	1	EA	\$1,359	
PLUMBING Sub Total							\$91,519	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Principals Office 103	6	470	SF	\$1,331	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Business Managers Office 1st fl	5	150	SF	\$849	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Main Office 1st fl	6	364	SF	\$1,031	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Engineers Office Basement	5	112	SF	\$634	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Kitchen Office Basement	5	128	SF	\$725	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Business Managers Office 1st fl	6	150	SF	\$215	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Principals Office 103	5	470	SF	\$1,680	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office 1st fl	6	298	SF	\$426	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Kitchen Office Basement	5	128	SF	\$725	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Engineers Office Basement	6	112	SF	\$160	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office 1st fl	6	66	SF	\$94	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Principals Office 103	7	5	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Kitchen Office Basement	6	2	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Engineers Office Basement	6	2	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Main Office 1st fl	7	5	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Business Managers Office 1st fl	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Kitchen Office Basement	6	315	SF	\$901	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Business Managers Office 1st fl	6	569	SF	\$1,343	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office 1st fl	6	922	SF	\$2,175	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principals Office 103	6	966	SF	\$2,279	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Engineers Office Basement	6	64	SF	\$151	
Doors		Interior Steel Doors incl hw	Entire Building	7	2	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	5	29	EA	\$13,685	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Wood Doors incl hw	Entire Building	6	74	EA	\$20,952	
Doors		Interior Wood Doors incl hw	Entire Building	7	20	EA	\$0	
Doors		Transom Window	Entire Building	6	639	SF	\$11,879	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	2	EA	\$0	
Drinking Fountains		Single Fountain	girls playroom	4	2	EA	\$7,722	
Drinking Fountains		Triple Fountain	lunchroom	4	1	EA	\$9,724	
Kitchen	Kitchen	Ceiling - Lay-In	Basement	6	832	SF	\$2,380	
Kitchen	Kitchen	Flooring - Tile/Sheet	Basement	6	832	SF	\$1,190	
Kitchen	Kitchen	Lighting - Pendant/Surface	Basement	6	12	SF	\$9	
Locker/Shower Room	Children's Standard Student Restroom	Benches	109			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	basement girls			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	Basement near Cafeteria Ladies			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Basement Near Cafeteria Boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd Floor Mens			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd Floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Basement Girls by cafeteria / includes Entrance space			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd Floor Mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	109			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Basement Girls by cafeteria / includes Entrance space			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	basement girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd Floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Basement Near Cafeteria Boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	Basement near Cafeteria Ladies			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	109			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	basement girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	Basement near Cafeteria Ladies			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Showers	Basement Near Cafeteria Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd Floor Mens			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd Floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Basement Girls by cafeteria / includes Entrance space			EA	\$0	
Lunchroom	Lunchroom	Ceiling - Lay-In	Basement 002	6	662	SF	\$1,420	
Lunchroom	Lunchroom	Ceiling - Lay-In	Basement	6	1,044	SF	\$2,239	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	Basement	6	1,044	SF	\$1,493	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	Basement 002	6	662	SF	\$947	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Basement	6	20	SF	\$14	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	Basement 002	7	15	SF	\$0	
Lunchroom	Lunchroom	Serving Line	Basement			LF	\$0	
Lunchroom	Kitchen	Serving Line	Basement			LF	\$0	
Lunchroom	Lunchroom	Serving Line	Basement 002			LF	\$0	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	Basement 002	6	846	SF	\$1,996	
Lunchroom	Lunchroom	Wall - Plaster/Drywall	Basement	6	1,296	SF	\$3,058	
Mechanical/Service Rooms		Boiler Room	Basement	5	350	SF	\$3,964	seepage around perimeter
Mechanical/Service Rooms		Boiler Room	Basement	6	1,200	SF	\$5,663	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	1,906	SF	\$8,994	
Mechanical/Service Rooms		Storage Room	Storage in 002, 204, 104	5	604	SF	\$6,841	
Mechanical/Service Rooms		Storage Room	Rooms: 202/206/207/208/209/303/307	5	1,161	SF	\$13,149	
Mechanical/Service Rooms		Storage Room	309	5	191	SF	\$2,163	
Mechanical/Service Rooms		Storage Room	in 101, 108	6	295	SF	\$1,392	
Mechanical/Service Rooms		Storage Room	in 102, 107	5	240	SF	\$2,718	
Staff Restroom	Children's Standard Student Restroom	Accessories	Basement Girls by cafeteria / includes Entrance space	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	basement girls	6	345	SF	\$2,664	
Staff Restroom	Adult Standard Student Restroom	Accessories	Basement near Cafeteria Ladies	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	Basement Near Cafeteria Boys	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor Mens	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	109	6	56	SF	\$432	
Staff Restroom	Staff Restroom	Accessories	2nd Floor	6	2	SF	\$15	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Basement Girls by cafeteria / includes Entrance space	6	316	SF	\$895	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor	7	144	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	basement girls	4	345	SF	\$4,559	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Basement Near Cafeteria Boys	6	134	SF	\$379	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	109	5	56	SF	\$317	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor Mens	5	125	SF	\$708	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Basement Girls by cafeteria / includes Entrance space	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	109			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	basement girls	5	2	EA	\$3,003	
Staff Restroom	Staff Restroom	Floor Drain	2nd Floor			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd Floor Mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Basement Near Cafeteria Boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	Basement near Cafeteria Ladies			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	109	5	56	SF	\$881	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	basement girls	6	345	SF	\$878	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Basement near Cafeteria Ladies	7	118	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Basement Near Cafeteria Boys	6	134	SF	\$341	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Mens	6	125	SF	\$318	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor	6	144	SF	\$367	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Basement Girls by cafeteria / includes Entrance space	7	316	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	basement girls			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd Floor Mens			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Basement Girls by cafeteria / includes Entrance space			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	109			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Basement Near Cafeteria Boys			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	Basement near Cafeteria Ladies			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	Basement near Cafeteria Ladies	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Basement Near Cafeteria Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	basement girls	5	3	EA	\$5,577	
Staff Restroom	Children's Standard Student Restroom	Lavatory	109	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Basement Girls by cafeteria / includes Entrance space	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor Mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Basement Near Cafeteria Boys	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Basement Girls by cafeteria / includes Entrance space	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	109	5	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor	7	2	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	Basement near Cafeteria Ladies	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor Mens	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	basement girls	7	4	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	109	5	1	EA	\$572	
Staff Restroom	Children's Standard Student Restroom	Partitions	Basement Girls by cafeteria / includes Entrance space	7	4	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd Floor	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	basement girls	6	3	EA	\$538	
Staff Restroom	Adult Standard Student Restroom	Partitions	Basement near Cafeteria Ladies	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Basement Near Cafeteria Boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd Floor Mens	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Basement Near Cafeteria Boys	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	Basement Girls by cafeteria / includes Entrance space			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	109			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	Basement near Cafeteria Ladies			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd Floor Mens			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	basement girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Basement Girls by cafeteria / includes Entrance space	7	247	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Concrete Block	Basement near Cafeteria Ladies	7	393	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	Basement Near Cafeteria Boys	7	83	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Concrete Block	basement girls	5	608	SF	\$4,591	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	109	5	329	SF	\$1,553	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor	6	702	SF	\$1,656	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor Mens	5	585	SF	\$2,761	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	basement girls	4	488	SF	\$4,606	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Basement Girls by cafeteria / includes Entrance space	7	742	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Structural Glazed Tile	Basement near Cafeteria Ladies	7	101	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	Basement Near Cafeteria Boys	7	206	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	Basement Girls by cafeteria / includes Entrance space	7	190	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	Basement Near Cafeteria Boys	7	84	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Basement Near Cafeteria Boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Basement Girls by cafeteria / includes Entrance space	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	109	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	basement girls	6	3	EA	\$1,115	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Water Closet	Basement near Cafeteria Ladies	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor Mens	7	2	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	

INTERIOR Sub Total \$181,919

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Engineers Office Basement	5	164	SF	\$774	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Kitchen Office Basement	5	168	SF	\$793	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		5	5	LF	\$894	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	46	LF	\$8,223	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		6	4	LF	\$143	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	4	LF	\$715	
Casework	Classroom	Casework		5	4	LF	\$715	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		5	6	LF	\$1,073	
Casework	Classroom	Casework		5	4	LF	\$715	
Ceiling	Classroom	Lay-In/Drop		6	864	SF	\$1,853	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		5	1,059	SF	\$5,997	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		5	1,092	SF	\$6,184	
Ceiling	Classroom	Plaster/Drywall		5	1,261	SF	\$7,141	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		5	1,059	SF	\$5,997	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		6	832	SF	\$2,356	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Ceiling	Classroom	Plaster/Drywall		6	1,059	SF	\$2,998	
Ceiling	Classroom	Plaster/Drywall		5	832	SF	\$4,711	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	Basement 002	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	26	LF	\$3,160	
Chalk Board	Classroom	Chalk Board		4		LF		

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	18	LF	\$2,188	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	26	LF	\$3,160	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Lunchroom	Chalk Board	Basement	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Corridors	Corridors	Asphalt	S stairs	6	480	SF	\$686	
Corridors	Corridors	Ceiling	S vestibule	5	120	SF	\$680	
Corridors	Corridors	Drinking Fountains	South @ Lunch Room			EA	\$0	
Corridors	Corridors	Drinking Fountains	Vestibule east Of Basement			EA	\$0	
Corridors	Corridors	Drinking Fountains	Basement			EA	\$0	
Corridors	Corridors	Drinking Fountains	S stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	S vestibule			EA	\$0	
Corridors	Corridors	Floors	South @ Lunch Room	5	36	SF	\$510	
Corridors	Corridors	Floors	Vestibule east Of Basement	6	36	SF	\$272	
Corridors	Corridors	Lighting	Vestibule east Of Basement			EA	\$0	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	2,691	EA	\$0	
Corridors	Corridors	Pendant/Surface	S vestibule	7	120	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	2,691	EA	\$0	
Corridors	Corridors	Pendant/Surface	3rd Floor	7	2,691	EA	\$0	
Corridors	Corridors	Pendant/Surface	Basement	7	95	EA	\$0	
Corridors	Corridors	Pendant/Surface	South @ Lunch Room	7	1	EA	\$0	
Corridors	Corridors	Pendant/Surface	S stairs	7	1,098	EA	\$0	
Corridors	Corridors	Plaster/Drywall	S stairs	6	3,620	SF	\$8,541	
Corridors	Corridors	Plaster/Drywall	Basement	6	1,849	SF	\$4,363	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	2,875	SF	\$6,784	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Plaster/Drywall	3rd Floor	6	2,875	SF	\$6,784	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	2,875	SF	\$6,784	
Corridors	Corridors	Stair Handrails	South @ Lunch Room			LF	\$0	
Corridors	Corridors	Stair Handrails	Basement			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	S vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	S stairs	6	239	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Vestibule east Of Basement			LF	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Vestibule east Of Basement			EA	\$0	
Corridors	Corridors	Stairs	South @ Lunch Room			EA	\$0	
Corridors	Corridors	Stairs	Basement			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	S vestibule			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Vestibule east Of Basement			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	South @ Lunch Room			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	S vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	S stairs			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Basement			EA	\$0	
Corridors	Corridors	Tile/Sheet Flooring	S stairs	6	762	SF	\$1,090	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	3,035	SF	\$4,340	
Corridors	Corridors	Tile/Sheet Flooring	S vestibule	6	120	SF	\$172	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	6	3,035	SF	\$4,340	
Corridors	Corridors	Tile/Sheet Flooring	Basement	6	1,384	SF	\$1,979	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	3,035	SF	\$4,340	
Corridors	Corridors	Walls	Vestibule east Of Basement	6	60	SF	\$142	
Corridors	Corridors	Walls	South @ Lunch Room	6	90	SF	\$212	
Corridors	Corridors	Walls	South @ Lunch Room	6	30	SF	\$71	
Corridors	Corridors	Walls	S vestibule	6	243	SF	\$573	
Corridors	Corridors	Walls	Vestibule east Of Basement	6	30	SF	\$71	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	6	3,035	SF	\$8,593	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	6	3,035	SF	\$8,593	
Corridors Ceiling	Corridors	Plaster/Drywall	Basement	6	1,384	SF	\$3,919	
Corridors Ceiling	Corridors	Plaster/Drywall	S stairs	6	618	SF	\$1,750	
Corridors Ceiling	Corridors	Plaster/Drywall	South @ Lunch Room	6	36	SF	\$102	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	6	3,035	SF	\$8,593	
Corridors Ceiling	Corridors	Plaster/Drywall	Vestibule east Of Basement	5	36	SF	\$204	
Stairs	Corridors	Asphalt	S stairs	6	80	SF	\$572	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		5	832	SF	\$4,711	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		5	832	SF	\$4,711	
Floor	Classroom	Tile/Sheet		6	1,059	SF	\$1,514	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		5	1,261	SF	\$7,141	
Floor	Classroom	Tile/Sheet		6	864	SF	\$1,236	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	1,092	SF	\$1,562	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	1,059	SF	\$1,514	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Tile/Sheet		6	832	SF	\$1,190	
Floor	Classroom	Wood		6	832	SF	\$6,282	
KITCHEN_WALL	Kitchen	Kitchen Walls	Basement	6	1,388	SF	\$3,533	
Lighting	Classroom	Lay-In		5	24	EA	\$3,432	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Pendant/Surface		5	15	EA	\$2,145	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Lighting	Classroom	Pendant/Surface		5	15	EA	\$2,145	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		5	15	EA	\$2,145	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		7	18	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	
Lighting	Classroom	Pendant/Surface		7	15	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	15	EA	\$1,073	
Marker Board	Classroom	Marker Board		6	21	LF	\$601	
Marker Board	Classroom	Marker Board		6	6	LF	\$172	
Marker Board	Lunchroom	Marker Board	Basement 002			LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	10	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	21	LF	\$0	
Marker Board	Classroom	Marker Board		7	18	LF	\$0	
Marker Board	Classroom	Marker Board		6	21	LF	\$601	
Marker Board	Classroom	Marker Board		6	11	LF	\$315	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Lunchroom	Marker Board	Basement			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		6	6	LF	\$172	
Marker Board	Classroom	Marker Board		7	28	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		6	18	LF	\$515	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		6	21	LF	\$601	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		6	23	LF	\$658	
RESTROOM_CEILING	Adult Standard Student Restroom	Restroom Ceiling	Basement near Cafeteria Ladies	7	118	SF	\$0	
Wall	Classroom	Concrete Block		6	1,095	SF	\$3,132	
Wall	Classroom	Masonry		6	365	SF	\$4,698	
Wall	Classroom	Plaster/Drywall		5	1,354	SF	\$6,390	
Wall	Classroom	Plaster/Drywall		5	1,361	SF	\$6,423	
Wall	Classroom	Plaster/Drywall		5	1,361	SF	\$6,423	
Wall	Classroom	Plaster/Drywall		6	1,367	SF	\$3,225	
Wall	Classroom	Plaster/Drywall		6	1,378	SF	\$3,251	
Wall	Classroom	Plaster/Drywall		6	1,423	SF	\$3,358	
Wall	Classroom	Plaster/Drywall		5	1,366	SF	\$6,446	
Wall	Classroom	Plaster/Drywall		5	1,361	SF	\$6,423	
Wall	Classroom	Plaster/Drywall		5	1,354	SF	\$6,390	
Wall	Classroom	Plaster/Drywall		6	2,003	SF	\$4,726	
Wall	Classroom	Plaster/Drywall		5	1,354	SF	\$6,390	
Wall	Classroom	Plaster/Drywall		5	1,366	SF	\$6,446	
Wall	Classroom	Plaster/Drywall		5	1,378	SF	\$6,503	
Wall	Classroom	Plaster/Drywall		5	1,354	SF	\$6,390	
Wall	Classroom	Plaster/Drywall		6	1,378	SF	\$3,251	
Wall	Classroom	Plaster/Drywall		6	1,254	SF	\$2,959	
Wall	Classroom	Plaster/Drywall		5	1,092	SF	\$5,153	
Wall	Classroom	Plaster/Drywall		5	1,441	SF	\$6,800	
Wall	Classroom	Plaster/Drywall		5	1,441	SF	\$6,800	
Wall	Classroom	Plaster/Drywall		5	1,326	SF	\$6,257	
Wall	Classroom	Plaster/Drywall		5	1,326	SF	\$6,257	
Wall	Classroom	Plaster/Drywall		6	1,423	SF	\$3,358	
Wall	Classroom	Plaster/Drywall		6	1,367	SF	\$3,225	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	1,311	SF	\$3,093	
ROOM Sub Total							\$457,652	
Building Main Sub Total							\$3,730,679	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Cornice		Cornice - Masonry Projecting/Limestone	Entire Building	6	1,182	LF	\$36,256	
Doors		Exterior FRP Door	Entire Building	7	18	EA	\$0	
Doors		Transom Lite	Entire Building	7	18	EA	\$0	
Entrance		Concrete Exterior Stairs	east and west entrances	6	174	LF	\$18,662	
Foundation		Concrete Foundation	Entire Building	7	394	LF	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	6	EA	\$0	
Lintels		Lintels - Steel	Entire Building	6	186	LF	\$7,022	rusting
Lintels		Lintels - Stone	Entire Building	6	234	LF	\$0	
Lintels		Lintels - Stone	above 4 entrance windows	5	15	LF	\$3,218	
Parapet		Coping - Stone	1 story and entrances	6	87	LF	\$0	
Parapet		Coping - Terra Cotta	Entire Building	6	538	LF	\$0	open joints
Parapet		Parapet < 16" Height	Entire Building	6	625	LF	\$97,329	
Roof System		Interior Downspouts	Entire Building	6	444	LF	\$0	
Roof System		Modified Bitumen Roof	Roof	6	11,788	SF	\$83,441	
Roof System		Roof Structure: Steel with Clay Tile Arch	Entire Building	7	11,788	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	37,321	SF	\$0	
Walls		Brick	Entire Building	6	23,280	SF	\$153,802	
Walls		Stone - Cut	Entire Building	6	1,182	SF	\$16,903	
Windows		Window - Guards perforated	Entire Building	6	1,080	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	6	3,951	SF	\$33,900	
EXTERIOR Sub Total							\$450,532	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Auditorium and aisle lighting	Entire Building	7	5,916	SF	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	6,272	SF	\$0	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	5,916	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	2,088	SF	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	Basement	7	5	EA	\$0	
Emergency System		Exit Signs - Auditorium	Basement	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Basement	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Basement	7	4	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	1st Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	2nd Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	3rd Floor	7	2	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	3rd Floor	7	2	EA	\$0	
Power Distribution		Lighting and power panels	Mechanical Room	6	1	EA	\$715	
Power Distribution		Lighting and power panels	Basement	6	1	EA	\$715	
ELECTRICAL Sub Total							\$1,430	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	1st Floor	7	2	EA	\$0	
Air Conditioning		Window A/C Unit	3rd Floor	6	3	EA	\$644	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Site - East	5	2	EA	\$32,032	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Mechanical Room	4	1	EA	\$92,950	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Hot Water 15,000 to 25,000 cfm	Mechanical Room	5	1	EA	\$16,445	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Entire Building	4	200	LF	\$529,100	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 8,001 to 15,000 cfm	Mechanical Room	4	1	EA	\$32,890	
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries- Steam 8,001 to 15,000 cfm	Mechanical Room	5	1	EA	\$10,725	
Heating Devices		Radiators - Steam	1st Floor	5	2	EA	\$1,316	
Heating Devices		Radiators - Steam	Basement	5	2	EA	\$1,316	
Heating Devices		Radiators - Steam	3rd Floor	5	8	EA	\$5,262	
Heating Devices		Radiators - Steam	2nd Floor	5	2	EA	\$1,316	
Heating Devices		Wall Heater - Electric	Basement	7	1	EA	\$0	
Heating Devices		Wall Heater - Electric	3rd Floor	6	2	EA	\$206	
Heating Devices		Wall Heater - Electric	1st Floor	6	2	EA	\$206	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices		Wall Heater - Electric	Basement	6	1	EA	\$103	
Heating Devices		Wall Heater - Electric	2nd Floor	6	2	EA	\$206	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Mechanical Room	5	1	EA	\$9,438	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	6	200	LF	\$1,373	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	6	200	LF	\$1,773	
Temperature Control		Thermostats - Pneumatic	Mechanical Room	4	1	EA	\$658	
Temperature Control		Thermostats - Pneumatic	Basement	7	1	EA	\$0	
Temperature Control		Thermostats - Pneumatic	1st Floor	7	2	EA	\$0	
Temperature Control		Thermostats - Pneumatic	2nd Floor	7	2	EA	\$0	
Temperature Control		Thermostats - Pneumatic	3rd Floor	7	3	EA	\$0	
Temperature Control		Zone Dampers	Mechanical Room	6	8	EA	\$1,144	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	1	EA	\$429	
MECHANICAL Sub Total							\$739,530	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	5	37,321	SF	\$6,404	
Piping		Domestic Piping - Cold Water Risers	Entire Building	5	37,321	SF	\$12,275	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	5	37,321	SF	\$42,695	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	5	37,321	SF	\$8,005	
Piping		Domestic Piping - Hot Water Risers	Entire Building	5	37,321	SF	\$9,606	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	5	37,321	SF	\$33,089	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	5	37,321	SF	\$19,747	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	5	37,321	SF	\$20,280	
Piping		Sanitary Piping	Entire Building	5	37,321	SF	\$22,949	
Piping		Storm Piping	Entire Building	5	37,321	SF	\$17,612	
Piping		Vent Piping	Entire Building	5	37,321	SF	\$13,342	
PLUMBING Sub Total							\$206,004	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Office 211B	5	456	SF	\$2,582	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Office 211	5	456	SF	\$2,582	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Office 211B	6	456	SF	\$652	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Office 211	6	456	SF	\$652	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Office 211	7	7	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Office 211B	7	7	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Office 211B	6	1,072	SF	\$2,529	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Office 211	6	1,072	SF	\$2,529	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	Basement	6	307	EA	\$11,300	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	Basement	6	432	EA	\$15,901	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	Basement			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	Basement			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	Basement	5	1	EA	\$214,500	
Doors		Interior Wood Doors incl hw	Entire Building	5	2	EA	\$944	
Doors		Interior Wood Doors incl hw	Entire Building	6	35	EA	\$9,910	
Doors		Interior Wood Doors incl hw	Entire Building	7	9	EA	\$0	
Doors		Transom Window	Entire Building	6	225	SF	\$4,183	
Drinking Fountains	Corridors	Single Fountain	Basement	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	2	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	2	EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd Floor Girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd Floor Boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd Floor Boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st Floor Girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Basement near Assembly Hall			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Basement near Assembly			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd Floor Girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd Floor Mens			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st Floor Boys			LF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd Floor Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd Floor Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd Floor Mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st Floor Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Basement near Assembly			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Basement near Assembly Hall			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st Floor Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd Floor Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd Floor Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Basement near Assembly Hall			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st Floor Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd Floor Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd Floor Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Basement near Assembly			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd Floor Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd Floor Mens			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd Floor Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st Floor Boys			EA	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	1,730	SF	\$8,164	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Girls	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor Mens	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Girls	7	3	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd Floor Boys	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd Floor Boys	7	2	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Girls	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Basement near Assembly	7	2	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Basement near Assembly Hall	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st Floor Boys	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd Floor Girls	7	385	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Girls	6	385	SF	\$1,090	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd Floor Boys	6	311	SF	\$881	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor Mens	5	125	SF	\$708	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd Floor Boys	7	311	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st Floor Boys	6	311	SF	\$881	
Staff Restroom	Staff Restroom	Floor Drain	Basement near Assembly			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Basement near Assembly Hall			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd Floor Boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd Floor Mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st Floor Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd Floor Boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Basement near Assembly Hall	6	99	SF	\$252	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Girls	7	385	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Mens	6	125	SF	\$318	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor Boys	6	311	SF	\$792	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st Floor Boys	6	311	SF	\$792	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Girls	7	385	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd Floor Girls	7	385	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Basement near Assembly	6	160	SF	\$407	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor Boys	6	311	SF	\$792	
Staff Restroom	Staff Restroom	Hand Dryer	Basement near Assembly Hall			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Basement near Assembly			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd Floor Mens			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd Floor Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd Floor Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st Floor Boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Basement near Assembly	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Basement near Assembly Hall	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Boys	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd Floor Girls	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor Mens	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st Floor Boys	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Boys	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd Floor Girls	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Girls	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor Mens	7	2	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor Girls	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Basement near Assembly Hall	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Basement near Assembly	7	2	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st Floor Boys	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd Floor Boys	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd Floor Boys	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd Floor Girls	7	4	SF	\$0	
Staff Restroom	Staff Restroom	Partitions	Basement near Assembly Hall	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	Basement near Assembly	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Girls	7	9	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st Floor Boys	6	3	EA	\$538	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Boys	6	3	EA	\$538	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd Floor Girls	7	9	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd Floor Mens	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Boys	6	3	EA	\$538	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd Floor Girls	7	9	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Boys	7	7	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd Floor Boys	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Basement near Assembly Hall			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd Floor Girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st Floor Girls			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Basement near Assembly			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd Floor Boys	7	7	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd Floor Mens			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Basement near Assembly	7	100	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor Mens	5	585	SF	\$2,761	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Basement near Assembly	6	230	SF	\$543	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Basement near Assembly Hall	6	320	SF	\$755	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor Boys	7	831	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd Floor Girls	7	893	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd Floor Boys	7	769	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd Floor Girls	7	813	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor Boys	7	831	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st Floor Girls	7	893	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st Floor Boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd Floor Boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd Floor Boys	7	245	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd Floor Girls	7	175	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Boys	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Girls	7	9	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd Floor Boys	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd Floor Girls	7	9	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Boys	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st Floor Girls	7	9	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Basement near Assembly Hall	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Water Closet	Basement near Assembly	7	2	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	2nd Floor Mens	7	2	EA	\$0	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	Basement	6	5,916	SF	\$50,590	
Theater	Auditorium - Dedicated	Flooring - Concrete	Basement	6	2,220	SF	\$10,476	
Theater	Auditorium - Dedicated	Flooring - Tile/Sheet	Basement	5	3,420	SF	\$19,367	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	Basement	6	11	SF	\$18	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	Basement	6	6	SF	\$10	
Theater	Auditorium - Dedicated	Stage	Basement	5	1,176	SF	\$32,961	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	Basement	5	9,442	SF	\$135,021	

INTERIOR Sub Total \$544,121

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		5	12	LF	\$2,145	
Casework	Classroom	Casework		5	12	LF	\$2,145	
Casework	Classroom	Casework		5	12	LF	\$2,145	
Casework	Classroom	Casework				LF	\$0	
Ceiling	Classroom	Plaster/Drywall		5	912	SF	\$5,164	
Ceiling	Classroom	Plaster/Drywall		5	864	SF	\$4,893	
Ceiling	Classroom	Plaster/Drywall		5	864	SF	\$4,893	
Ceiling	Classroom	Plaster/Drywall		5	864	SF	\$4,893	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Corridors	Corridors	Concrete Block	Auditorium Vestibule	7	656	SF	\$0	
Corridors	Corridors	Concrete Epoxy/Painted	Side of Auditorium	7	137	SF	\$0	
Corridors	Corridors	Drinking Fountains	Side of Auditorium			EA	\$0	
Corridors	Corridors	Drinking Fountains	stairs to balcony			EA	\$0	
Corridors	Corridors	Drinking Fountains	Auditorium Vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	north stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	center stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	center vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	south vestibule			EA	\$0	
Corridors	Corridors	Pendant/Surface	stairs to balcony	5	100	EA	\$322	
Corridors	Corridors	Pendant/Surface	2nd Floor	7	1,197	EA	\$0	
Corridors	Corridors	Pendant/Surface	Side of Auditorium	7	1	EA	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Pendant/Surface	3rd Floor	7	1,197	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	1,197	EA	\$0	
Corridors	Corridors	Pendant/Surface	Auditorium Vestibule	7	3	EA	\$0	
Corridors	Corridors	Pendant/Surface	north stairs	6	910	EA	\$651	
Corridors	Corridors	Pendant/Surface	center stairs	7	695	EA	\$0	
Corridors	Corridors	Pendant/Surface	center vestibule	7	75	EA	\$0	
Corridors	Corridors	Pendant/Surface	south vestibule	7	75	EA	\$0	
Corridors	Corridors	Pendant/Surface	Basement	7	1,197	EA	\$0	
Corridors	Corridors	Plaster/Drywall	Basement	6	3,080	SF	\$7,267	
Corridors	Corridors	Plaster/Drywall	3rd Floor	6	2,645	SF	\$6,241	
Corridors	Corridors	Plaster/Drywall	Side of Auditorium	6	153	SF	\$361	
Corridors	Corridors	Plaster/Drywall	Auditorium Vestibule	7	430	SF	\$0	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	2,645	SF	\$6,241	
Corridors	Corridors	Plaster/Drywall	center stairs	6	3,104	SF	\$7,324	
Corridors	Corridors	Plaster/Drywall	north stairs	6	3,460	SF	\$8,164	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	2,645	SF	\$6,241	
Corridors	Corridors	Plaster/Drywall	stairs to balcony	5	350	SF	\$1,652	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Auditorium Vestibule	7	50	LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Side of Auditorium	7	4	LF	\$0	
Corridors	Corridors	Stair Handrails	center vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	north stairs	6	175	LF	\$0	
Corridors	Corridors	Stair Handrails	center stairs	6	161	LF	\$0	
Corridors	Corridors	Stair Handrails	south vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	stairs to balcony	6	23	LF	\$0	
Corridors	Corridors	Stair Handrails	Basement			LF	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	Basement			EA	\$0	
Corridors	Corridors	Stairs	center vestibule			EA	\$0	
Corridors	Corridors	Stairs	south vestibule			EA	\$0	
Corridors	Corridors	Stairs	stairs to balcony			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	south vestibule	7	198	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Side of Auditorium	5	179	SF	\$8,447	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Structural Glazed Tile	center vestibule	7	198	SF	\$0	
Corridors	Corridors	Student Lockers	stairs to balcony			EA	\$0	
Corridors	Corridors	Student Lockers	Auditorium Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	Side of Auditorium			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	Basement	6	35	EA	\$5,005	
Corridors	Corridors	Student Lockers	center vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	center stairs			EA	\$0	
Corridors	Corridors	Student Lockers	south vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	north stairs			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor			EA	\$0	
Corridors	Corridors	Terrazzo	stairs to balcony	5	150	SF	\$2,804	
Corridors	Corridors	Terrazzo	Auditorium Vestibule	6	417	SF	\$2,361	
Corridors	Corridors	Terrazzo	center stairs	6	338	SF	\$1,914	
Corridors	Corridors	Terrazzo	north stairs	6	479	SF	\$2,712	
Corridors	Corridors	Tile Ceramic/Porcelain	north stairs	6	161	SF	\$410	
Corridors	Corridors	Tile Ceramic/Porcelain	center stairs	6	130	SF	\$331	
Corridors	Corridors	Tile Ceramic/Porcelain	center vestibule	6	75	SF	\$191	
Corridors	Corridors	Tile Ceramic/Porcelain	south vestibule	6	75	SF	\$191	
Corridors	Corridors	Tile/Sheet Flooring	Basement	6	1,977	SF	\$2,827	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	1,197	SF	\$1,712	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	6	1,197	SF	\$1,712	
Corridors	Corridors	Tile/Sheet Flooring	center stairs	6	130	SF	\$186	
Corridors	Corridors	Tile/Sheet Flooring	north stairs	6	287	SF	\$410	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	1,197	SF	\$1,712	
Corridors Ceiling	Corridors	Plaster/Drywall	center vestibule	6	75	SF	\$212	
Corridors Ceiling	Corridors	Plaster/Drywall	2nd Floor	6	1,197	SF	\$3,389	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	6	1,197	SF	\$3,389	
Corridors Ceiling	Corridors	Plaster/Drywall	Basement	6	1,977	SF	\$5,598	
Corridors Ceiling	Corridors	Plaster/Drywall	3rd Floor	6	1,197	SF	\$3,389	
Corridors Ceiling	Corridors	Plaster/Drywall	south vestibule	6	75	SF	\$212	
Corridors Ceiling	Corridors	Plaster/Drywall	center stairs	6	695	SF	\$1,968	
Corridors Ceiling	Corridors	Plaster/Drywall	north stairs	6	910	SF	\$2,577	
Corridors Ceiling	Corridors	Plaster/Drywall	Side of Auditorium	6	137	SF	\$388	
Corridors Ceiling	Corridors	Plaster/Drywall	stairs to balcony	6	100	SF	\$283	
Corridors Ceiling	Corridors	Plaster/Drywall	Auditorium Vestibule	7	417	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Stairs	Corridors	Asphalt	Side of Auditorium	7	3	SF	\$0	
Stairs	Corridors	Terrazzo	north stairs	6	79	SF	\$895	
Stairs	Corridors	Terrazzo	center stairs	6	59	SF	\$668	
Stairs	Corridors	Terrazzo	Auditorium Vestibule	7	27	SF	\$0	
Floor	Classroom	Tile/Sheet		6	864	SF	\$1,236	
Floor	Classroom	Tile/Sheet		6	864	SF	\$1,236	
Floor	Classroom	Tile/Sheet		6	864	SF	\$1,236	
Floor	Classroom	Tile/Sheet		6	912	SF	\$1,304	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Lighting	Classroom	Pendant/Surface		6	12	EA	\$858	
Lighting	Classroom	Pendant/Surface		6	14	EA	\$1,001	
Marker Board	Classroom	Marker Board		6	12	LF	\$343	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
Marker Board	Classroom	Marker Board		6	16	LF	\$458	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	2nd Floor Girls	6	385	SF	\$1,090	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	Basement near Assembly		160	SF	\$0	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	Basement near Assembly Hall		99	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd Floor Girls	7	175	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st Floor Girls	7	175	SF	\$0	
THEATER_WALL	Auditorium - Dedicated	Auditorium Walls	Basement	6	306	SF	\$634	
Wall	Classroom	Masonry		5	1,156	SF	\$43,641	
Wall	Classroom	Plaster/Drywall		5	1,398	SF	\$6,597	
Wall	Classroom	Plaster/Drywall		5	1,398	SF	\$6,597	
Wall	Classroom	Plaster/Drywall		5	1,398	SF	\$6,597	
ROOM Sub Total							\$201,463	
Building Addition Sub Total							\$2,143,080	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Athletic		Basketball - Asphalt	Site ζ North	7	20,352	SF	\$0	
Civil/Drainage		Catch Basin	Entire Site	7	3	EA	\$0	
Civil/Drainage		Site Drain	Site - East	7	1	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	13	EA	\$0	
Fencing		Chain Link	Entire Site	6	1,229	LF	\$17,627	rust
Fencing		Ornamental Iron	Entire Site	6	959	LF	\$18,102	
Landscape		Asphalt Play Area/Hardscape	site- NE	7	3,018	SF	\$0	
Landscape		Benches	Entire Site	7	22	EA	\$0	
Landscape		Grass	Entire Site	7	19,484	SF	\$0	
Landscape		Grass	Entire Site	6	54,462	SF	\$21,807	holes, divets, uneven ground
Landscape		Hardscape - Concrete	Entire Building	7	5,050	SF	\$0	
Landscape		Hardscape - Pavers	Site ζ West	6	200	SF	\$566	
Landscape		Parkway trees	Entire Site	7	18	EA	\$0	
Landscape		Planting Beds/ Areas	Entire Site	7	300	SF	\$0	
Landscape		Trash Receptacles	Entire Site	7	3	EA	\$0	
Parking Lot		Asphalt	Site - East	7	11,309	SF	\$0	
Playground		Playground - Swingset	Site - East	7	1	EA	\$0	
Playground		Playground Equipment - School Age 5-12	Site - East	6	1	EA	\$0	slide cracking
Playground		Playground Surfacing - Wood Chips	Site - East	7	5,328	SF	\$0	
Sidewalks		Internal Walks	Site - East	7	181	LF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	22,690	SF	\$0	
Signage		Flag Pole	Site ζ South	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted w/ LED	Site ζ South	7	1	EA	\$0	
SITE Sub Total							\$58,102	
SITE Sub Total							\$58,102	

Building: SITE

Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Total Campus Need ^{2 3}							\$5,931,862	

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
006	1092	1	8	26	40	60	30		N	N	Y	Classroom		
101	832	1	9	25	40	122	46	1	N	N	N	Classroom		
102	832	1	10	32	40	122	61		N	N	N	Classroom		
104	832	2	9	22	40	77	38	2	N	Y	Y	Classroom		
106	832	1	7	15	40	102	51		N	N	N	Classroom		
107	832	1	6	18	40	102	51		N	N	N	Classroom		
108	832		6	25	40	102	51		N	N	Y	Classroom		
109	1059				40	106	31	1	N	N	N	Classroom		
201	832	1	9	25	40	122	46	1	N	N	N	Classroom		
202	832	1	10	32	40	122	61		N	N	N	Classroom		
203	832	1	9	32	40	108	43		N	N	N	Classroom		
204	832	1	6	22	40	77	38	2	N	N	N	Classroom		
206	832	1	18	42	40	102	51	2	N	Y	N	Classroom		
207	832	1	8	28	40	102	38		N	N	N	Classroom		
208	832	1	7	26	40	0			N	N	Y	Classroom		
209	1059	1	9	30	40	118	47		N	N	N	Classroom		
301	832	1	9	25	40	122	46	1	N	N	N	Classroom		
303	832	1	9	32	40	108	43		N	N	N	Classroom		
304	832	1	6	22	40	77	38	2	N	N	N	Classroom		
306	832	1	18	42	40	102	51	2	N	Y	N	Classroom		
307	832	1	8	28	40	102	38		N	N	N	Classroom		
308	832		6	25	40	102	51		N	N	Y	Classroom		
309	1059	1	9	30	40	118	47		N	N	N	Classroom		
311	864	1	19	121	40	121	60	3	N	N	N	Classroom		
girls playground	1261	1	8	22	40	17	9		N	N	N	Classroom		
Other	316								N	N	N	Restroom	Children's Standard Student Restroom	Basement Girls by cafeteria / includes Entrance space
Other	3035								N	N	N	Corridors		2nd Floor
Other	3035								N	N	N	Corridors		3rd Floor
Other	128			2					N	N	Y	Administrative Suites/Offices		Kitchen Office Basement
Other	470			26					N	N	Y	Administrative Suites/Offices		Principals Office 103
Other	150			6					N	N	N	Administrative Suites/Offices		Business Managers Office 1st fl
Other	36								N	N	N	Corridors		South @ Lunch Room
Other	364			8					N	N	Y	Administrative Suites/Offices		Main Office 1st fl
Other	112			6					N	N	Y	Administrative Suites/Offices		Engineers Office Basement
Other	36								N	N	N	Corridors		Vestibule east Of Basement

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	3035								N	N	N	Corridors		1st Floor
Other	56								N	N	N	Restroom	Children's Standard Student Restroom	109
Other	118								N	N	N	Restroom	Adult Standard Student Restroom	Basement near Cafeteria Ladies
Other	134								N	N	N	Restroom	Children's Standard Student Restroom	Basement Near Cafeteria Boys
Other	144								N	N	N	Restroom	Staff Restroom	2nd Floor
Other									N	N	N	Corridors		S stairs
Other	120								N	N	N	Corridors		S vestibule
Other	1044								N	N	N	Lunch & Multipurpose Room	Lunchroom	Basement
Other	832								N	N	N	Kitchen		Basement
Other	662								N	N	N	Lunch & Multipurpose Room	Lunchroom	Basement 002
Other	125								N	N	N	Restroom	Staff Restroom	2nd Floor Mens
Other	1384								N	N	N	Corridors		Basement
Other	345								N	N	N	Restroom	Children's Standard Student Restroom	basement girls

Building: Addition

008	912	1	9	25	40	60	12		N	N	N	Classroom		
110	864		7	17	40	162	66	1	N	N	Y	Classroom		
111	864		7	17	40	162	66	1	N	N	Y	Classroom		
210	864		7	17	40	162	66	1	N	N	Y	Classroom		
Other	1197								N	N	N	Corridors		2nd Floor
Other	456			17					N	N	Y	Administrative Suites/Offices		Office 211
Other	385								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Girls
Other	75								N	N	N	Corridors		south vestibule
Other	75								N	N	N	Corridors		center vestibule
Other	160								N	N	N	Restroom	Staff Restroom	Basement near Assembly
Other	99								N	N	N	Restroom	Staff Restroom	Basement near Assembly Hall
Other	385								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Girls
Other	311								N	N	N	Restroom	Children's Standard Student Restroom	1st Floor Boys
Other	125								N	N	N	Restroom	Staff Restroom	2nd Floor Mens
Other	311								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Boys
Other	1977								N	N	N	Corridors		Basement
Other	311								N	N	N	Restroom	Children's Standard Student Restroom	3rd Floor Boys
Other	1197								N	N	N	Corridors		1st Floor
Other									N	N	N	Corridors		north stairs
Other	5916								N	N	N	Auditorium & Theater	Auditorium - Dedicated	Basement
Other	456			17					N	N	Y	Administrative Suites/Offices		Office 211B
Other	417								N	N	N	Corridors		Auditorium Vestibule

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other									N	N	N	Corridors		stairs to balcony
Other	137								N	N	N	Corridors		Side of Auditorium
Other	1197								N	N	N	Corridors		3rd Floor
Other									N	N	N	Corridors		center stairs
Other	385								N	N	N	Restroom	Children's Standard Student Restroom	2nd Floor Girls