

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	West	6	80	LF	\$40,040	
Chimney		Brick Chimney - Concrete/ Mortar Liner	West- Top of Chimney	5	20	LF	\$35,750	
Cornice		Cornice - Terra Cotta	Gabled Roofs - East and South	7	745	LF	\$0	
Doors		Exterior FRP Door	Doors 5,6,9 and East Boiler Building	7	8	EA	\$0	
Doors		Exterior Steel Door	Entry 12	7	2	EA	\$0	
Doors		Exterior Steel Door	Entire Building	6	8	EA	\$2,643	
Doors		Transom Lite	Doors 5,6,9 and East Boiler Building	7	8	EA	\$0	
Doors		Transom Lite	Entire Building	6	8	EA	\$2,265	
Entrance		Concrete Exterior Stairs	Entire Building	7	332	LF	\$0	
Entrance		Concrete Ramp	SE Entry #8	6	54	LF	\$7,529	cracks
Entrance		Ramp Handrails	SE Entry #8	6	108	LF	\$0	peeling paint
Entrance		Stair Handrails	South East Entrance #8	6	21	LF	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Stair Handrails	Entire Building	7	88	LF	\$0	
Entrance		Stone Stairs	West Entrances	6	57	LF	\$10,189	
Foundation		Concrete Foundation	Boiler Tunnel and Basement	6	20	LF	\$3,115	
Foundation		Concrete Foundation	South Wing	6	120	LF	\$18,687	
Foundation		Concrete Foundation	Entire Building	7	983	LF	\$0	
Foundation		Concrete Foundation	North and West Boiler House	6	77	LF	\$11,991	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Building	7	8	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	10	EA	\$2,145	
Lighting		Exterior Lights - Wall Mounted	Entire Building	5	3	EA	\$1,502	
Lintels		Lintels - Steel	Entire Building	7	936	LF	\$0	
Lintels		Lintels - Terra Cotta	Entire Building	7	150	LF	\$0	
Parapet		Coping - Metal	Gabled Roof Peaks	7	360	LF	\$0	
Parapet		Coping - Terra Cotta	Entire Building	5	1,080	LF	\$193,050	
Parapet		Parapet < 16" Height	Roof- West	7	730	LF	\$0	
Parapet		Parapet > 30" Height	Roof-NE and SE	7	350	LF	\$0	
Roof System		Asphalt Gravel Ballast Roof	Roof-Boiler Building	6	2,800	SF	\$17,858	
Roof System		Interior Downspouts	Entire Building	6	400	LF	\$0	
Roof System		Modified Bitumen Roof	Entire Building	7	27,860	SF	\$0	
Roof System		Modified Bitumen Roof	Roof- East 1 story	4	180	SF	\$4,247	
Roof System		Roof Structure: Concrete	Main Roofs	7	35,510	SF	\$0	
Roof System		Slate Shingle Roof	Roof-East and South Gables	7	4,670	SF	\$0	
Superstructure		Concrete	Entire Building	7	71,880	SF	\$0	
Walls		Brick	West Recessed Slots	6	360	SF	\$2,378	
Walls		Brick	West Boiler Building	6	3,100	SF	\$20,480	
Walls		Brick	Entire Building	7	22,665	SF	\$0	
Walls		Prefabricated Metal Panel Wall	Roof- Backside of Roof Gables	7	1,720	SF	\$0	
Walls		Stone - Cut	Entire Building	6	3,010	SF	\$43,043	
Walls		Stone - Cut	West Boiler Building	5	635	SF	\$68,104	
Walls		Terra Cotta	Entire Building	7	5,440	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	4,900	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	10,550	SF	\$0	

EXTERIOR Sub Total \$485,015

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	3	EA	\$0	
Emergency System		Emergency A/C power - Auditorium and aisle lighting	1st Floor	7	2,360	SF	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	12,150	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	7	2,785	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	1,212	SF	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	7	9	EA	\$0	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	7	1	EA	\$0	
Emergency System		Emergency generator 150 KW -200 KW natural gas - Outdoor	Courtyard	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	1st Floor	7	7	EA	\$0	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	23	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	3	EA	\$0	
Main Service		Main Electrical service 2000 to 3000 A 120/208/3PH	Entire Building	6	1	EA	\$24,310	
Power Distribution		Lighting and power panels	Entire Building	6	8	EA	\$5,720	
Power Distribution		Lighting and power panels	Entire Building	7	9	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Boiler Room	6	1	EA	\$1,430	
Power Distribution		Main distribution panels 400-600 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Boiler Room	7	2	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	CHILLER ROOM	7	1	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Boiler Room	6	1	EA	\$2,145	
Power Distribution		Main distribution panels less than 400 amp	Entire Building	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
ELECTRICAL Sub Total							\$33,605	

Building: Main
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	6	71,880	SF	\$25,697	
Fire Alarm		Fire Alarm System	Basement	7	71,880	SF	\$0	
FIRE PROTECTION Sub Total							\$25,697	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Water Cooled - Centrifugal 201-300 tons	Boiler Room	6	1	EA	\$23,309	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Ground Mounted less than 5 tons	Basement	7	1	EA	\$0	
Air Conditioning		Condensing Unit - Roof Mounted less than 5 tons	Roof	5	1	EA	\$4,290	
Air Conditioning		Cooling Tower - Spray Type - 201 to 300 tons	BOILER ROOM ROOF	6	1	EA	\$4,719	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	GROUND LEVEL WELL ON WEST FACING WALL OF MAIN BUILDING	7	1	EA	\$0	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	GROUND LEVEL WELL ON WEST FACING WALL OF MAIN BUILDING	7	1	EA	\$0	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	GROUND LEVEL WELL ON WEST FACING WALL OF MAIN BUILDING	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	GROUND LEVEL WELL ON WEST FACING WALL OF MAIN BUILDING	7	1	EA	\$0	
Air Handling Systems		Fan Coil Unit - Electric	1st Floor	7	1	EA	\$0	
Air Handling Systems		Fan Coil Unit - Electric	2nd Floor	5	1	EA	\$5,935	
Air Handling Systems		Fan Coil Unit - Hot Water and Chilled Water	Entire Building	6	28	EA	\$40,040	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Basement	6	1	EA	\$11,297	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Basement	6	1	EA	\$12,870	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Basement	7	1	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Basement	7	1	EA	\$0	
Air Handling Systems		Reheat Boxes With Steam Coils	Basement	6	17	EA	\$17,746	
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Basement	4	100	LF	\$264,550	MISSING SYSTEM
Air Handling Systems		Return Duct Work - Masonry and Ducts - Existing or Missing Exterior Shaft	Basement	4	100	LF	\$264,550	MISSING SYSTEM
Air Handling Systems		Return Duct Work - Sheet Metal - Exterior Vertical Shaft and Ducts	Entire Building	7	100	LF	\$0	
Air Handling Systems		Return Duct Work - Sheet Metal - Exterior Vertical Shaft and Ducts	Entire Building	7	100	LF	\$0	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	Roof	6	2	EA	\$4,862	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 4,000 to 8,000 cfm	Basement	6	1	EA	\$5,005	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 4,000 to 8,000 cfm	Basement	6	1	EA	\$5,005	
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries - Steam 4,000 to 8,000 cfm	Basement	6	1	EA	\$2,145	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries - Steam 4,000 to 8,000 cfm	Basement	6	1	EA	\$2,145	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 101-150 HP	Boiler Room	6	1	EA	\$14,729	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler 76-100 HP	Boiler Room	6	1	EA	\$11,869	
Boiler Systems		Boiler Auxiliary - Steam Boiler 101-150 HP	Boiler Room	7	1	EA	\$0	
Boiler Systems		Boiler Auxiliary - Steam Boiler 76-100 HP	Boiler Room	7	1	EA	\$0	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	7	1	EA	\$0	
Boiler Systems		Chemical Pot Feeder - Hot Water	Boiler Room	6	2	EA	\$601	
Boiler Systems		Combustion Dampers	Boiler Room	7	2	EA	\$0	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	6	1	EA	\$8,437	
Boiler Systems		Glycol Feed System	Boiler Room	7	1	EA	\$0	
Heat Exchangers		Heat Exchanger - Steam to Hot Water Shell Type	Boiler Room	5	1	EA	\$12,441	
Heating Devices		Fin Tube Hot Water	Entire Building	6	56	LF	\$961	
Heating Devices		Fin Tube Hot Water	Entire Building	7	56	LF	\$0	
Heating Devices		Radiators - Steam	Entire Building	6	15	EA	\$2,102	
Heating Devices		Unit Heater - Electric	Entire Building	5	4	EA	\$10,296	
Heating Devices		Unit Heater - Electric	Entire Building	7	2	EA	\$0	
Heating Devices		Unit Heater - Gas	Boiler Room	5	1	EA	\$4,290	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Boiler Room	7	1	EA	\$0	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	4	600	LF	\$58,773	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	7	400	LF	\$0	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	600	LF	\$29,687	
Mechanical Plumbing		Pumps - Chilled Water 10 to 20 HP	Boiler Room	7	4	EA	\$0	
Mechanical Plumbing		Pumps - Condenser Water 10 to 20 HP	Boiler Room	7	2	EA	\$0	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	41	EA	\$5,863	
Temperature Control		Zone Dampers	Basement	7	37	EA	\$0	
Ventilation		Exhaust Fan - Indoor	Electrical Room	6	1	EA	\$501	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	2	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	7	1	EA	\$0	
MECHANICAL Sub Total							\$829,017	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas 150,000 -300,000 BTU/HR	Boiler Room	7	1	EA	\$0	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	71,880	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	4	71,880	SF	\$46,255	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	71,880	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	4	71,880	SF	\$32,892	
Piping		Domestic Piping - Hot Water Risers	Entire Building	4	71,880	SF	\$39,060	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	71,880	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	71,880	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	71,880	SF	\$0	
Piping		Sanitary Piping	Entire Building	6	71,880	SF	\$28,781	
Piping		Storm Piping	Entire Building	6	71,880	SF	\$15,418	
Piping		Vent Piping	Entire Building	6	71,880	SF	\$11,307	
Pumps		Domestic Booster Pump duplex	Boiler Room	7	1	EA	\$0	
Pumps		Sump Pump	Boiler Room	6	1	EA	\$1,359	
PLUMBING Sub Total							\$175,071	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Gym Office	6	345	SF	\$740	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Room 110-A	6	305	SF	\$654	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	110-B	6	120	SF	\$257	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	Room 132-A	6	140	SF	\$396	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	110-B	6	120	SF	\$172	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile Ceramic/Porcelain	Gym Office	6	345	SF	\$878	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 132-A	6	140	SF	\$200	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Room 110-A	6	305	SF	\$436	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Gym Office	7	5	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	110-B	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Room 110-A	7	6	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Room 132-A	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Gym Office	6	140	SF	\$330	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 110-A	7	800	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	110-B	6	400	SF	\$944	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Room 132-A	6	200	SF	\$472	
Doors		Interior Steel Doors incl hw	Entire Building	7	14	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	81	EA	\$22,934	
Doors		Interior Wood Doors incl hw	Entire Building	5	7	EA	\$3,303	
Doors		Interior Wood Doors incl hw	Entire Building	7	8	EA	\$0	
Doors		Transom Window	Entire Building	7	370	SF	\$0	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	7	3	EA	\$0	
Drinking Fountains	Corridors	Single Fountain	1st Floor	7	7	EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	1st Floor	7	2,785	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	1st Floor	6	2,785	SF	\$21,028	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	1st Floor	6	12	EA	\$2,145	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	1st Floor	7	4,000	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Room 199			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st FL (South) - Boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	Auditorium - Boys			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	2nd FL (South) - Boys			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	1st FL (North) - Boys			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd FL (North) - Boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd FL (South) - Girls			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd FL (North) - Girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Gym Office			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	2nd FL (South) - Boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st FL (South) - Girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd Floor			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	107			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	Room 110-A			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	1st FL (North) - Girls			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd FL (North) - Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	Auditorium - Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st FL (South) - Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Room 110-A			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	107			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd Floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st FL (South) - Girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd FL (South) - Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Gym Office			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	2nd FL (North) - Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd FL (South) - Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	Room 199			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	1st FL (North) - Girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	1st FL (North) - Boys			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	2nd FL (South) - Boys			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Showers	Gym Office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st FL (South) - Boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Room 110-A			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd Floor			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	107			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd FL (South) - Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	Auditorium - Boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd FL (North) - Girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	Room 199			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	2nd FL (North) - Boys			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	1st FL (North) - Girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	1st FL (North) - Boys			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	2nd FL (South) - Boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd FL (South) - Girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st FL (South) - Girls			EA	\$0	
MDF/IDF		Finishes	Room 206-A	7	300	SF	\$0	
MDF/IDF		Ventilation and Cooling	Room 206-A	7	1	EA	\$0	
Mechanical/Service Rooms		Boiler Room	Basement	7	2,550	SF	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	6	SF	\$28	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	7	8,250	SF	\$0	
Mechanical/Service Rooms		Storage Room	Entire Building	7	970	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd Floor	7	80	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Room 110-A	6	20	SF	\$154	
Staff Restroom	Children's Standard Student Restroom	Accessories	Auditorium - Boys	5	132	SF	\$3,364	
Staff Restroom	Early Childhood Student Restroom	Accessories	2nd FL (South) - Boys	7	260	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	1st FL (North) - Boys	7	260	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	1st FL (North) - Girls	7	310	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd FL (North) - Boys	7	260	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Room 199	7	20	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd FL (South) - Girls	7	310	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd FL (North) - Girls	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	Gym Office	7	20	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st FL (South) - Girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	107			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st FL (South) - Boys	7	260	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	2nd FL (South) - Boys	7	260	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Room 199	6	20	SF	\$43	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	Gym Office	6	20	SF	\$43	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	107	6	200	SF	\$566	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd Floor	7	80	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	2nd FL (South) - Boys	6	260	SF	\$736	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	2nd FL (North) - Boys	6	260	SF	\$736	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	1st FL (North) - Boys	6	260	SF	\$736	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	2nd FL (South) - Boys	6	260	SF	\$736	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	Auditorium - Boys	6	132	SF	\$374	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	Room 110-A	6	20	SF	\$57	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st FL (South) - Boys	6	260	SF	\$736	
Staff Restroom	Staff Restroom	Floor Drain	Room 110-A			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd FL (South) - Boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st FL (South) - Girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Gym Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st FL (South) - Boys	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	Auditorium - Boys			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	107			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd FL (North) - Girls	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	2nd FL (South) - Boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	1st FL (North) - Boys	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	1st FL (North) - Girls	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	2nd FL (North) - Boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	Room 199			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd FL (South) - Girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	107	7	115	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL (North) - Girls	7	310	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL (South) - Boys	7	260	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	Auditorium - Boys	5	132	SF	\$2,076	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st FL (North) - Boys	7	260	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL (North) - Boys	7	260	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL (South) - Girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st FL (South) - Boys	7	260	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	Room 110-A	6	20	SF	\$51	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st FL (South) - Girls	7	310	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	107	6	52	SF	\$132	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd Floor	7	80	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd FL (South) - Boys	7	260	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Adult Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st FL (North) - Girls	7	310	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Gym Office	4	20	SF	\$283	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	Room 199	6	20	SF	\$29	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd FL (North) - Girls	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	1st FL (North) - Girls	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	Auditorium - Boys			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	1st FL (North) - Boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	2nd FL (North) - Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Room 199			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd FL (South) - Girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Gym Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st FL (South) - Girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	107			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	Room 110-A			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	2nd FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Room 110-A	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Room 199	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	1st FL (North) - Girls	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	1st FL (North) - Boys	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	2nd FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	2nd FL (North) - Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	Auditorium - Boys	6	1	EA	\$372	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd FL (South) - Girls	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	2nd FL (North) - Girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	Gym Office	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	2nd FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st FL (South) - Girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	107	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd Floor	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st FL (South) - Boys	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	Auditorium - Boys	6	1	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd Floor	6	2	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd FL (South) - Girls	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st FL (South) - Girls	7	5	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	2nd FL (South) - Boys	7	5	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Gym Office	7	1	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	2nd FL (North) - Girls	7	5	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	Room 199	7	1	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	2nd FL (North) - Boys	7	5	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	1st FL (North) - Girls	7	5	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	1st FL (North) - Boys	7	5	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	2nd FL (South) - Boys	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	107	7	3	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	Room 110-A	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Gym Office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st FL (South) - Boys	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Partitions	Room 110-A			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd Floor			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	107	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd FL (North) - Girls	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd FL (South) - Girls	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	Room 199			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	2nd FL (North) - Boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	1st FL (North) - Girls	7	6	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Partitions	1st FL (North) - Boys	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Partitions	2nd FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	Auditorium - Boys	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st FL (South) - Girls	7	6	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd FL (North) - Girls			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	2nd FL (South) - Boys	7	3	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	1st FL (North) - Boys	7	3	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	1st FL (North) - Girls			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd FL (North) - Boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st FL (South) - Boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Room 199			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Gym Office			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	2nd FL (South) - Boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st FL (South) - Girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	107			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Urinals	2nd Floor			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	Room 110-A			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd FL (South) - Girls			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	Auditorium - Boys			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Room 199	7	55	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	Gym Office	7	55	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	Auditorium - Boys	6	220	SF	\$519	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	2nd FL (North) - Boys	7	190	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	2nd FL (North) - Girls	7	582	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	2nd FL (South) - Boys	7	190	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st FL (South) - Girls	7	582	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	1st FL (North) - Girls	7	582	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd FL (South) - Girls	7	582	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	2nd FL (South) - Boys	7	190	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	107	6	730	SF	\$1,722	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	2nd Floor	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	Room 110-A	6	200	SF	\$472	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st FL (South) - Boys	7	190	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	1st FL (North) - Boys	7	190	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	2nd Floor	7	200	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	Room 199	6	90	SF	\$229	
Staff Restroom	Staff Restroom	Wall - Tile Ceramic/ Porcelain	Gym Office	6	90	SF	\$229	
Staff Restroom	Adult Standard Student Restroom	Water Closet	1st FL (North) - Girls	7	6	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Water Closet	2nd FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Gym Office	7	1	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	1st FL (North) - Boys	7	2	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st FL (South) - Girls	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd FL (South) - Girls	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Room 110-A	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd Floor	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	Room 199	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	107	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st FL (South) - Boys	7	2	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd FL (North) - Boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	Auditorium - Boys	5	1	EA	\$1,859	
Staff Restroom	Adult Standard Student Restroom	Water Closet	2nd FL (North) - Girls	7	6	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	

INTERIOR Sub Total \$74,030

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Room 132-A	6	280	SF	\$661	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	Gym Office	6	550	SF	\$1,298	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		6	16	LF	\$572	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		6	3	LF	\$107	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	5	LF	\$179	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	17	LF	\$608	
Casework	Classroom	Casework		6	35	LF	\$1,251	
Casework	Classroom	Casework		7	9	LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	15	LF	\$536	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Ceiling	Classroom	Ceiling			950	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	730	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	730	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	730	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	465	SF	\$997	
Ceiling	Classroom	Lay-In/Drop		7	730	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	475	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	15	LF	\$1,823	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	9	LF	\$1,094	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	5	LF	\$608	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Corridors	Corridors	Drinking Fountains	Northeast Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	Southeast Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	West Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	Northeast Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	Southeast Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	Entire Building - Vestibules			EA	\$0	
Corridors	Corridors	Drop/Lay-In	Southeast Stair	7	410	SF	\$0	
Corridors	Corridors	Drop/Lay-In	Northeast Stair	7	410	SF	\$0	
Corridors	Corridors	Drop/Lay-In	West Stair	7	470	SF	\$0	
Corridors	Corridors	Drop/Lay-In	Northeast Stair	7	410	SF	\$0	
Corridors	Corridors	Drop/Lay-In	Southeast Stair	7	410	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	5,850	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	5,850	SF	\$0	
Corridors	Corridors	Lay-In	Southeast Stair	7	3	EA	\$0	
Corridors	Corridors	Lay-In	Northeast Stair	7	3	EA	\$0	
Corridors	Corridors	Lay-In	West Stair	7	4	EA	\$0	
Corridors	Corridors	Lay-In	Southeast Stair	7	3	EA	\$0	
Corridors	Corridors	Lay-In	Northeast Stair	7	3	EA	\$0	
Corridors	Corridors	Lighting	2nd Floor			EA	\$0	
Corridors	Corridors	Lighting	1st Floor			EA	\$0	
Corridors	Corridors	Pendant/Surface	West Stair	7	2	EA	\$0	
Corridors	Corridors	Pendant/Surface	Southeast Stair	7	1	EA	\$0	
Corridors	Corridors	Pendant/Surface	Northeast Stair	7	1	EA	\$0	
Corridors	Corridors	Pendant/Surface	Southeast Stair	7	1	EA	\$0	
Corridors	Corridors	Pendant/Surface	Entire Building - Vestibules	7	5	EA	\$0	
Corridors	Corridors	Pendant/Surface	Northeast Stair	7	1	EA	\$0	
Corridors	Corridors	Plaster/Drywall	West Stair	7	2,200	SF	\$0	
Corridors	Corridors	Plaster/Drywall	2nd Floor	6	10,208	SF	\$24,086	
Corridors	Corridors	Plaster/Drywall	Entire Building - Vestibules	6	600	SF	\$1,416	
Corridors	Corridors	Plaster/Drywall	1st Floor	6	10,208	SF	\$24,086	
Corridors	Corridors	Plaster/Drywall	Northeast Stair	7	2,240	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Southeast Stair	7	2,240	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Southeast Stair	7	2,240	SF	\$0	
Corridors	Corridors	Plaster/Drywall	Northeast Stair	7	2,240	SF	\$0	
Corridors	Corridors	Stair Handrails	Northeast Stair	7	36	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Entire Building - Vestibules			LF	\$0	
Corridors	Corridors	Stair Handrails	Northeast Stair	7	31	LF	\$0	
Corridors	Corridors	Stair Handrails	West Stair	7	34	LF	\$0	
Corridors	Corridors	Stair Handrails	Southeast Stair	7	31	LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	Southeast Stair	7	36	LF	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	Entire Building - Vestibules			EA	\$0	
Corridors	Corridors	Student Lockers	Northeast Stair			EA	\$0	
Corridors	Corridors	Student Lockers	Northeast Stair			EA	\$0	
Corridors	Corridors	Student Lockers	West Stair			EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor	6	347	EA	\$49,621	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Student Lockers	Entire Building - Vestibules			EA	\$0	
Corridors	Corridors	Student Lockers	Southeast Stair			EA	\$0	
Corridors	Corridors	Student Lockers	Southeast Stair			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	6	279	EA	\$39,897	
Corridors	Corridors	Terrazzo	Entire Building - Vestibules	7	450	SF	\$0	
Corridors	Corridors	Terrazzo	Northeast Stair	7	770	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	5,850	SF	\$0	
Corridors	Corridors	Terrazzo	Southeast Stair	7	745	SF	\$0	
Corridors	Corridors	Terrazzo	Northeast Stair	7	745	SF	\$0	
Corridors	Corridors	Terrazzo	West Stair	7	690	SF	\$0	
Corridors	Corridors	Terrazzo	Southeast Stair	7	770	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	1,170	SF	\$0	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	4,680	SF	\$6,692	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	5,850	SF	\$8,366	
Corridors	Corridors	Walls	Entire Building - Vestibules	7	925	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Entire Building - Vestibules	6	450	SF	\$1,274	
Stairs	Corridors	Terrazzo	Southeast Stair	7	30	SF	\$0	
Stairs	Corridors	Terrazzo	Southeast Stair	7	27	SF	\$0	
Stairs	Corridors	Terrazzo	Northeast Stair	7	27	SF	\$0	
Stairs	Corridors	Terrazzo	West Stair	7	30	SF	\$0	
Stairs	Corridors	Terrazzo	Northeast Stair	7	30	SF	\$0	
Floor	Classroom	Tile/Sheet		6	800	SF	\$1,144	
Floor	Classroom	Tile/Sheet		6	800	SF	\$1,144	
Floor	Classroom	Tile/Sheet		6	800	SF	\$1,144	
Floor	Classroom	Tile/Sheet		6	800	SF	\$1,144	
Floor	Classroom	Tile/Sheet		6	380	SF	\$543	
Floor	Classroom	Tile/Sheet		6	730	SF	\$1,044	
Floor	Classroom	Tile/Sheet		6	730	SF	\$1,044	
Floor	Classroom	Tile/Sheet		5	730	SF	\$4,134	
Floor	Classroom	Tile/Sheet		6	350	SF	\$501	
Floor	Classroom	Tile/Sheet		7	475	SF	\$0	
Floor	Classroom	Tile/Sheet		6	730	SF	\$1,044	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	950	SF	\$7,173	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	465	SF	\$3,511	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	710	SF	\$5,361	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	350	SF	\$2,643	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	730	SF	\$5,512	
Floor	Classroom	Wood		6	465	SF	\$3,511	
GYM_WALL	Standard Dedicated Gymnasium	Gymnasia Walls	1st Floor	7	1,720	SF	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	16	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	8	EA	\$572	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	16	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	16	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	16	EA	\$0	
Lighting	Classroom	Lay-In		7	10	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	8	EA	\$572	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	7	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	3	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	3	EA	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	8	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		6	5	LF	\$143	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
RESTROOM_WALL	Adult Standard Student Restroom	Restroom Walls	1st FL (North) - Boys	7	750	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	2nd FL (South) - Girls	7	390	SF	\$0	
RESTROOM_WALL	Early Childhood Student Restroom	Restroom Walls	2nd FL (South) - Boys	7	750	SF	\$0	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	1st FL (South) - Girls	7	390	SF	\$0	
RESTROOM_WALL	Adult Standard Student Restroom	Restroom Walls	2nd FL (North) - Girls	7	390	SF	\$0	
Wall	Classroom	Metal/Folding Panel		6	831	SF	\$1,961	
Wall	Classroom	Metal/Folding Panel		6	831	SF	\$1,961	
Wall	Classroom	Metal/Folding Panel		6	831	SF	\$1,961	
Wall	Classroom	Metal/Folding Panel		6	831	SF	\$1,961	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	910	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	975	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	970	SF	\$2,289	
Wall	Classroom	Plaster/Drywall		7	600	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		7	600	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	840	SF	\$1,982	
Wall	Classroom	Plaster/Drywall		6	1,250	SF	\$2,949	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	970	SF	\$2,289	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
Wall	Classroom	Plaster/Drywall		7	1,000	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,000	SF	\$2,360	
ROOM Sub Total							\$409,286	
Building Main Sub Total							\$2,031,721	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Metal Flue	Upper Roof	7	10	LF	\$0	
Doors		Exterior FRP Door	Doors 1, 2 and 3	6	6	EA	\$3,341	
Doors		Exterior Steel Door	East Service Entracne	5	1	EA	\$1,090	dented, needs paint
Doors		Exterior Steel Door	Doors 4,13,14	6	6	EA	\$1,982	peeling paint
Doors		Side Lite	West Main Entry	7	2	EA	\$0	
Doors		Transom Lite	Doors 1,2,3	7	6	EA	\$0	
Entrance		Entrance Controls - Audio and Video	West Main Entry	7	1	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	890	LF	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Site	7	3	EA	\$0	
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Building	7	11	EA	\$0	
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	9	EA	\$1,931	
Lintels		Lintels - Steel	South door to Gym #14	6	6	LF	\$227	
Lintels		Lintels - Steel	Entire Building	7	600	LF	\$0	
Parapet		Coping - Stone	Entire Building	7	1,075	LF	\$0	
Parapet		Parapet > 30" Height	Entire Building	7	1,075	LF	\$0	
Roof System		Interior Downspouts	Entire Building	6	423	LF	\$0	
Roof System		Modified Bitumen Roof	Entire Building	5	29,220	SF	\$344,723	cracking and leaks reported
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Entire Building	7	29,220	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	Entire Building	7	56,750	SF	\$0	
Walls		Brick	Northeast	6	120	SF	\$793	graffiti

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Walls		Brick	Entire Building	7	23,200	SF	\$0	
Walls		Brick	Southeast Gym Parapet	5	5	SF	\$113	step crack
Walls		Stone - Cast	Entire Building	7	7,185	SF	\$0	
Windows		Window - Guards perforated	Entire Building	7	2,230	SF	\$0	
Windows		Windows - Sash Aluminum Double-pane	Entire Building	7	4,600	SF	\$0	
EXTERIOR Sub Total							\$354,199	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	pump room	7	1	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	10,139	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	1st Floor	7	4,062	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	7	880	SF	\$0	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	14	EA	\$1,502	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	4	1	EA	\$541	
Emergency System		Emergency Battery Packs - Lunchroom and Gym	1st Floor	6	1	EA	\$107	
Emergency System		Emergency Battery Packs - Toilets	Entire Building	6	4	EA	\$429	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	7	17	EA	\$0	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	1st Floor	7	3	EA	\$0	
Emergency System		Public Announcement System	1st Floor	7	128,630	SF	\$0	
Emergency System		Security System - CCTV	1st Floor	6	128,630	SF	\$183,941	
Emergency System		Security System - Intrusion detection	1st Floor	6	128,630	SF	\$119,562	
Main Service		Main Electrical service 1600 A 277/480/3PH	Electrical Room	7	1	EA	\$0	
Power Distribution		Lighting and power panels	Entire Building	7	14	EA	\$0	
Power Distribution		Main distribution panels 400-600 amp	Entire Building	7	1	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Main distribution panels less than 400 amp	Electrical Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
Power Distribution		Transformers 277/480-120/208	Electrical Room	7	1	EA	\$0	
ELECTRICAL Sub Total							\$306,081	

Building: Addition
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm Strobe Lights	Entire Building	7	56,750	SF	\$0	
Fire Alarm		Fire Pump Controller	pump room	7	1	EA	\$0	

Building: Addition
Category: FIRE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Pump Room Assembly		Fire Pump 25-50hp	pump room	6	1	EA	\$3,718	
Pump Room Assembly		Jockey Pump	pump room	7	1	EA	\$0	
Sprinkler System		Sprinkler Heads	Entire Building	7	56,750	SF	\$0	
Sprinkler System		Wet Sprinkler System	Entire Building	7	56,750	SF	\$0	
FIRE PROTECTION Sub Total							\$3,718	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Chillers - Air Cooled - Rotary/Screw type - Roof Mounted 100 to 200 tons	Roof	6	1	EA	\$27,885	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm	Mechanical Room	6	1	EA	\$14,014	
Air Handling Systems		Air Handling Unit Package - Multi Zone - Hot Water above 20,001 to 30,000 cfm	MECHANICAL PENTHOUSE	6	1	EA	\$14,014	
Air Handling Systems		Air Handling Unit Package - Single Zone - Hot Water 8,001 to 12,000 cfm	Mechanical Room	6	1	EA	\$6,292	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	WEST EXTERIOR WALL OF MECHANICAL PENTHOUSE	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	WEST EXTERIOR WALL OF MECHANICAL PENTHOUSE	7	1	EA	\$0	
Air Handling Systems		Air intake for all Air Handling Units except built up AHU	WEST EXTERIOR WALL OF MECHANICAL PENTHOUSE	7	1	EA	\$0	
Air Handling Systems		Fan Coil Unit - Hot Water-Heating	Entire Building	6	36	EA	\$48,391	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	PENTHOUSE MECH ROOM	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor 10,001 to 20,000 CFM	Mechanical Room	7	1	EA	\$0	
Air Handling Systems		Return Fans - Indoor 5,000 to 10,000 CFM	Mechanical Room	7	1	EA	\$0	
Boiler Systems		Boiler Assembly - Non-Condensing Flexible Tube Hot Water Boiler 1,001MBH-2,000 MBH	PENTHOUSE MECH ROOM	6	3	EA	\$23,595	
Boiler Systems		Boiler Auxiliary Non-Condensing Hot Water Boiler 1,001MBH-2,000 MBH	PENTHOUSE MECH ROOM	6	3	EA	\$15,015	
Boiler Systems		Chemical Pot Feeder - Hot Water	PENTHOUSE MECH ROOM	7	2	EA	\$0	
Boiler Systems		Combustion Dampers	PENTHOUSE MECH ROOM	7	2	EA	\$0	
Boiler Systems		Glycol Feed System	PENTHOUSE MECH ROOM	6	2	EA	\$2,174	
Heating Devices		Cabinet Heaters With Hot Water Coils	Entire Building	7	8	EA	\$0	
Heating Devices		Unit Heater - Hot Water	Entire Building	7	4	EA	\$0	
Mechanical Plumbing		Piping - Hydronic Supply and Return - Steel or Galvanized	Entire Building	7	700	LF	\$0	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical Plumbing		Pumps - Chilled Water 10 to 20 HP	PENTHOUSE MECH ROOM	6	2	EA	\$5,148	
Mechanical Plumbing		Pumps - Hot Water 5 to 10 HP	PENTHOUSE MECH ROOM	6	2	EA	\$4,004	
Temperature Control		Direct Digital Control (DDC) System	2nd Floor	5	128,630	SF	\$643,793	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	33	EA	\$4,719	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	4	5	EA	\$4,648	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	7	4	EA	\$0	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	1st Floor	7	1	EA	\$0	
Ventilation		Type II Exhaust Hood - Warming Kitchen	1st Floor	7	2	EA	\$0	
MECHANICAL Sub Total							\$813,691	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas less than 150,000 BTU/HR	PENTHOUSE MECH ROOM	2	1	EA	\$14,872	NON FUNCTIONAL
Hot Water		Hot Water Heater - Gas less than 150,000 BTU/HR	PENTHOUSE MECH ROOM	7	1	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	56,750	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	56,750	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	56,750	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	56,750	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	56,750	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	56,750	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	56,750	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	56,750	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	56,750	SF	\$0	
Piping		Storm Piping	Entire Building	7	56,750	SF	\$0	
Piping		Vent Piping	Entire Building	7	56,750	SF	\$0	
Pumps		Domestic Booster Pump duplex	pump room	7	1	EA	\$0	
PLUMBING Sub Total							\$14,872	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 321	6	138	SF	\$296	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Principals office in main	7	166	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Work Room- in main office	6	165	SF	\$354	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 320 faculty lounge in main office	7	460	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Main Office	7	712	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 325	6	71	SF	\$152	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Kitchen Staff Managers office in kitchen	6	59	SF	\$127	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 421 Speech Office	6	121	SF	\$260	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	library workroom 412	6	138	SF	\$296	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	rm 321	7	138	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	rm 320 faculty lounge in main office	7	360	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Main Office	7	520	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	Principals office in main	7	166	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Concrete	Kitchen Staff Managers office in kitchen	6	59	SF	\$278	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Main Office	7	192	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 421 Speech Office	7	121	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 325	7	71	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 320 faculty lounge in main office	7	100	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Work Room- in main office	7	165	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	library workroom 412	7	138	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	library workroom 412	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Work Room- in main office	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Kitchen Staff Managers office in kitchen	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Principals office in main	7	2	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 320 faculty lounge in main office	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	Main Office	7	12	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 325	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 421 Speech Office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 321	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	library workroom 412	7	175	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 325	6	319	SF	\$912	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 321	7	287	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Work Room- in main office	7	618	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Main Office	7	800	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 320 faculty lounge in main office	7	273	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 421 Speech Office	6	490	SF	\$1,401	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Kitchen Staff Managers office in kitchen	6	285	SF	\$815	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principals office in main	7	135	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 320 faculty lounge in main office	7	723	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	library workroom 412	6	228	SF	\$538	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 321	6	288	SF	\$680	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Main Office	7	940	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	Principals office in main	6	382	SF	\$901	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor	6	80	EA	\$2,945	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	6	288	EA	\$10,601	
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor			EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	6	6	EA	\$67,954	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Doors		Interior Steel Doors incl hw	Entire Building	6	30	EA	\$8,494	
Doors		Interior Steel Doors incl hw	Entire Building	7	16	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	17	EA	\$4,813	
Doors		Interior Wood Doors incl hw	Entire Building	7	31	EA	\$0	
Doors		Side-lite	Entire Building	7	220	SF	\$0	
Drinking Fountains		Single Water Cooler	in 302, 303, 304, 305, 305	5	5	EA	\$15,373	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Bleacher Seating	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Ceiling - Exposed	1st Floor	7	4,062	SF	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Flooring - Tile/Sheet	1st Floor	7	4,062	SF	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Lighting - Metal Halide/Sodium Vapor	1st Floor	7	9	EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Scoreboards	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Sound System	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Stage Curtain	1st Floor			EA	\$0	
Gymnasium / Auditorium	Gymnasium/Cafeteria	Walls - Concrete Block	1st Floor	7	7,580	SF	\$0	
Kitchen	Cooking Kitchen	Ceiling - Lay-In	1st Floor	6	1,280	SF	\$3,661	
Kitchen	Cooking Kitchen	Flooring - Concrete	1st Floor	6	1,280	SF	\$6,040	
Kitchen	Cooking Kitchen	Lighting - Lay-In	1st Floor	7	13	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Concrete Block	1st Floor	6	1,775	SF	\$5,077	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in room 303			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl unisex			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in room 304			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in room 306			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in room 305			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl unisex			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in kitchen unisex			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in room 302			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in kitchen unisex			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in room 303			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl unisex			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in room 306			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in room 302			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in room 304			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in room 305			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in room 306			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in room 304			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in room 303			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in kitchen unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl unisex			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in room 305			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in room 302			EA	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	Servery	6	916	SF	\$1,965	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	dishwashing 1st fl	6	144	SF	\$309	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	Servery	7	916	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	dishwashing 1st fl	7	2	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	Servery	7	12	SF	\$0	
Lunchroom	Cooking Kitchen	Serving Line				LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	dishwashing 1st fl			LF	\$0	
Lunchroom	Cooking Kitchen	Serving Line	1st Floor			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	Servery	6	60	LF	\$2,574	
Lunchroom	Multipurpose Room	Wall - Concrete Block	Servery	6	1,329	SF	\$3,801	
Lunchroom	Multipurpose Room	Wall - Concrete Block	dishwashing 1st fl	6	565	SF	\$1,616	
MDF/IDF		Finishes	2nd Floor	6	202	SF	\$687	
MDF/IDF		Ventilation and Cooling	2nd Floor	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	7	1	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st Floor	7	898	SF	\$0	
Mechanical/Service Rooms		Mechanical/Service Rooms	2nd Floor	7	2,831	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st fl classroom storage	7	220	SF	\$0	
Mechanical/Service Rooms		Storage Room	2nd Floor	7	401	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	1st fl unisex	6	54	SF	\$417	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in room 302	6	36	SF	\$278	
Staff Restroom	Staff Restroom	Accessories	in kitchen unisex	6	41	SF	\$317	
Staff Restroom	Staff Restroom	Accessories	2nd fl unisex	6	54	SF	\$417	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in room 305	6	36	SF	\$278	
Staff Restroom	Children's Standard Student Restroom	Accessories	in room 306	6	36	SF	\$278	
Staff Restroom	Children's Standard Student Restroom	Accessories	in room 303	6	36	SF	\$278	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in room 304	6	36	SF	\$278	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in room 305	6	36	SF	\$77	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in room 303	6	36	SF	\$77	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in room 304	6	36	SF	\$77	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in room 306	6	36	SF	\$77	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	in kitchen unisex	6	41	SF	\$88	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in room 302	5	36	SF	\$204	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys	6	220	SF	\$623	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	1st fl unisex	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls	6	220	SF	\$623	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	2nd fl unisex	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in kitchen unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in room 302	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in room 306	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in room 304	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Floor Drain	1st fl unisex	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in room 305	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl unisex	6	1	EA	\$300	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in room 303	6	1	EA	\$300	
Staff Restroom	Staff Restroom	Flooring - Concrete	in kitchen unisex	6	41	SF	\$193	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in room 304	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in room 306	7	36	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Terrazzo	1st fl unisex	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st fl boys	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in room 303	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	1st fl girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd fl boys	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	2nd fl girls	7	220	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in room 302	7	36	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Terrazzo	2nd fl unisex	7	54	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Terrazzo	in room 305	7	36	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in room 303			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in room 304			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in room 306			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in room 305			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in room 302			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in kitchen unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in kitchen unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in room 305	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	in room 306	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in room 304	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl unisex	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in room 302	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl unisex	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in room 303	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl boys	6	5	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	in kitchen unisex	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl unisex	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl girls	6	5	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	2nd fl boys	6	5	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in room 305	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in room 306	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in room 304	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in room 303	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	1st fl girls	6	5	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl unisex	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Lay-In	in room 302	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in room 304			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	1st fl unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in room 306			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in room 303			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in room 302			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls	7	5	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in kitchen unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	in room 305			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in room 306			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys	7	3	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in room 302			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys	7	3	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	in kitchen unisex			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in room 305			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in room 304			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	in room 303			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	1st fl unisex			EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in kitchen unisex	7	265	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in room 302	7	195	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls	7	824	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys	7	692	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls	7	824	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	1st fl unisex	7	270	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in room 303	7	195	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in room 304	7	195	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in room 306	7	195	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys	7	692	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	2nd fl unisex	7	270	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	in room 305	7	195	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in room 306	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in kitchen unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in room 304	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in room 305	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls	7	5	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl unisex	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in room 303	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	in room 302	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys	7	2	EA	\$0	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	1st Floor	6	4,100	SF	\$35,061	
Theater	Auditorium - Dedicated	Flooring - Wood	1st Floor	6	600	SF	\$4,530	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	7	39	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Wall Mounted	1st Floor	7	9	EA	\$0	
Theater	Auditorium - Dedicated	Stage	1st Floor	7	1	SF	\$0	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	1st Floor	6	10,200	SF	\$87,516	
Vertical Conveyance		Elevator - Roped Holeless Hydraulic	Entire Building	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		6	3	EA	\$1,158	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	water is turned off because sink leaks
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	1	EA	\$386	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	
Vocational Shop	Classroom	Work Sink		6	2	EA	\$772	

INTERIOR Sub Total \$292,112

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		6	52	LF	\$1,859	
Casework	Classroom	Casework		6	52	LF	\$1,859	
Casework	Classroom	Casework		6	52	LF	\$1,859	
Casework	Classroom	Casework		6	52	LF	\$1,859	
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		6	52	LF	\$1,859	
Casework	Classroom	Casework		7	16	LF	\$0	
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	62	LF	\$2,217	
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	36	LF	\$1,287	
Casework	Classroom	Casework		7	38	LF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		7	38	LF	\$0	
Casework	Classroom	Casework		7	38	LF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,007	SF	\$2,160	
Ceiling	Classroom	Lay-In/Drop		7	431	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,230	SF	\$2,638	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,230	SF	\$2,638	
Ceiling	Classroom	Lay-In/Drop		6	1,230	SF	\$2,638	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,230	SF	\$2,638	
Ceiling	Classroom	Lay-In/Drop		6	1,209	SF	\$2,593	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	1,230	SF	\$2,638	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	431	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	728	SF	\$1,562	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	800	SF	\$0	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Multipurpose Room	Chalk Board	Servery	4		LF		
Chalk Board	Multipurpose Room	Chalk Board	dishwashing 1st fl	4		LF		
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	24	LF	\$2,917	
Corridors	Corridors	Drinking Fountains	Center Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	North East Stair			EA	\$0	
Corridors	Corridors	Drinking Fountains	South East Stair			EA	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	6	4,832	SF	\$10,365	
Corridors	Corridors	Drop/Lay-In	North East Stair	6	641	SF	\$1,375	
Corridors	Corridors	Drop/Lay-In	Center Stair	6	367	SF	\$787	
Corridors	Corridors	Drop/Lay-In	South East Stair	6	495	SF	\$1,062	
Corridors	Corridors	Drop/Lay-In	1st Floor	6	5,097	SF	\$10,933	
Corridors	Corridors	Lay-In	1st Floor	7	5,307	EA	\$0	
Corridors	Corridors	Lay-In	North East Stair	7	641	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	4,580	EA	\$0	
Corridors	Corridors	Lay-In	Center Stair	7	496	EA	\$0	
Corridors	Corridors	Lay-In	South East Stair	7	495	EA	\$0	
Corridors	Corridors	Plaster/Drywall	South East Stair	6	115	SF	\$271	
Corridors	Corridors	Plaster/Drywall	North East Stair	6	115	SF	\$271	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	2	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	2	EA	\$0	
Corridors	Corridors	Stair Handrails	1st Floor	7	20	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	North East Stair	6	72	LF	\$0	
Corridors	Corridors	Stair Handrails	South East Stair	6	72	LF	\$0	
Corridors	Corridors	Stair Handrails	Center Stair	6	68	LF	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Stairs	North East Stair	7	30	EA	\$0	
Corridors	Corridors	Stairs	South East Stair	7	30	EA	\$0	
Corridors	Corridors	Student Lockers	2nd Floor			EA	\$0	
Corridors	Corridors	Student Lockers	South East Stair			EA	\$0	
Corridors	Corridors	Student Lockers	North East Stair			EA	\$0	
Corridors	Corridors	Student Lockers	Center Stair			EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Terrazzo	1st Floor	7	5,307	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Terrazzo	Center Stair	7	565	SF	\$0	
Corridors	Corridors	Terrazzo	South East Stair	7	500	SF	\$0	
Corridors	Corridors	Terrazzo	North East Stair	7	591	SF	\$0	
Corridors	Corridors	Terrazzo	2nd Floor	7	4,832	SF	\$0	
Corridors	Corridors	Wall Mounted	South East Stair	7	500	EA	\$0	
Corridors	Corridors	Wall Mounted	North East Stair	7	591	EA	\$0	
Corridors	Corridors	Walls	Center Stair	7	1,972	SF	\$0	
Corridors	Corridors	Walls	North East Stair	7	2,457	SF	\$0	
Corridors	Corridors	Walls	2nd Floor	7	8,125	SF	\$0	
Corridors	Corridors	Walls	South East Stair	7	2,344	SF	\$0	
Corridors	Corridors	Walls	1st Floor	7	8,125	SF	\$0	
Corridors	Corridors	Walls	Center Stair	7	116	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	210	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Center Stair	6	129	SF	\$365	
Stairs	Corridors	Terrazzo	Center Stair	6	30	SF	\$340	
Stairs	Corridors	Terrazzo	1st Floor	7	4	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,230	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,007	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,230	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,230	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	431	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,230	SF	\$0	
Floor	Classroom	Tile/Sheet		7	431	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,230	SF	\$0	
Floor	Classroom	Tile/Sheet		7	800	SF	\$0	
Floor	Classroom	Tile/Sheet		6	1,209	SF	\$1,729	
Floor	Classroom	Tile/Sheet		7	728	SF	\$0	
KITCHEN_CEILING	Cooking Kitchen	Kitchen Ceiling				SF	\$0	
KITCHEN_FLOOR	Cooking Kitchen	Kitchen Floor				SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
KITCHEN_LIGHT	Cooking Kitchen	Kitchen Lighting				EA	\$0	
KITCHEN_WALL	Cooking Kitchen	Kitchen Walls				SF	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		7	12	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	15	EA	\$1,073	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	15	EA	\$0	
Lighting	Classroom	Lay-In		7	6	EA	\$0	
LUNCH_FLOOR	Multipurpose Room	Lunchroom Floor	dishwashing 1st fl	6	144	SF	\$206	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	4	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Multipurpose Room	Marker Board	Servery			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Multipurpose Room	Marker Board	dishwashing 1st fl			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
THEATER_FLOOR	Auditorium - Dedicated	Auditorium Floor	1st Floor	7	3,300	SF	\$0	
THEATER_FLOOR	Auditorium - Dedicated	Auditorium Floor	1st Floor	6	450	SF	\$2,124	
Wall	Classroom	Concrete Block		7	688	SF	\$0	
Wall	Classroom	Concrete Block		7	420	SF	\$0	
Wall	Classroom	Concrete Block		7	688	SF	\$0	
Wall	Classroom	Concrete Block		7	688	SF	\$0	
Wall	Classroom	Concrete Block		7	688	SF	\$0	
Wall	Classroom	Concrete Block		7	685	SF	\$0	
Wall	Classroom	Concrete Block		7	764	SF	\$0	
Wall	Classroom	Concrete Block		7	420	SF	\$0	
Wall	Classroom	Concrete Block		7	420	SF	\$0	
Wall	Classroom	Concrete Block		7	420	SF	\$0	
Wall	Classroom	Concrete Block		6	854	SF	\$2,442	some step cracking
Wall	Classroom	Concrete Block		7	809	SF	\$0	
Wall	Classroom	Concrete Block		7	420	SF	\$0	
Wall	Classroom	Concrete Block		7	690	SF	\$0	
Wall	Classroom	Concrete Block		7	690	SF	\$0	
Wall	Classroom	Concrete Block		7	690	SF	\$0	
Wall	Classroom	Concrete Block		7	688	SF	\$0	
Wall	Classroom	Concrete Block		7	420	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	540	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	312	SF	\$736	
Wall	Classroom	Plaster/Drywall		6	702	SF	\$1,656	
Wall	Classroom	Plaster/Drywall		6	756	SF	\$1,784	
Wall	Classroom	Plaster/Drywall		6	756	SF	\$1,784	
Wall	Classroom	Plaster/Drywall		6	756	SF	\$1,784	
Wall	Classroom	Plaster/Drywall		7	270	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	756	SF	\$1,784	
Wall	Classroom	Plaster/Drywall		7	213	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	540	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,704	SF	\$4,021	
Wall	Classroom	Plaster/Drywall		7	270	SF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	250	SF	\$590	
Wall	Classroom	Plaster/Drywall		7	270	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	540	SF	\$1,274	
Wall	Classroom	Plaster/Drywall		6	540	SF	\$1,274	
Wall	Classroom	Plaster/Drywall		6	540	SF	\$1,274	
Wall	Classroom	Plaster/Drywall		6	540	SF	\$1,274	
Wall	Classroom	Plaster/Drywall		6	756	SF	\$1,784	

ROOM Sub Total \$119,642

Building Addition Sub Total \$1,904,315

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	West of Boiler Building	5	1	EA	\$1,216	leaks in basement
Civil/Drainage		Catch Basin	West of Boiler Building	7	14	EA	\$0	
Civil/Drainage		Site Manhole	Entire Site	7	17	EA	\$0	
Fencing		Chain Link	Entire Site	7	265	LF	\$0	
Fencing		Ornamental Iron	Parking- Northeast	4	48	LF	\$9,060	bent/leaning
Fencing		Ornamental Iron	West	5	126	LF	\$7,849	rusty
Fencing		Ornamental Iron	Entire Site	6	2,286	LF	\$43,151	corrosion, peeling paint
Fencing		Ornamental Iron	Playground - NE	7	212	LF	\$0	
Landscape		Asphalt Play Area/Hardscape	Site ζ West	7	11,250	SF	\$0	
Landscape		Asphalt Play Area/Hardscape	Site Southwest and Northeast	6	21,250	SF	\$18,233	
Landscape		Benches	Playground Northeast and Southwest	7	2	EA	\$0	
Landscape		Grass	Entire Site	7	24,000	SF	\$0	
Landscape		Hardscape - Concrete	Entire Site	7	13,415	SF	\$0	
Landscape		Parkway trees	Entire Site	7	53	EA	\$0	
Landscape		Parkway trees	Site ζ West	2	1	EA	\$2,454	tree is cut down
Landscape		Planting Beds/ Areas	Entire Site	7	2,150	SF	\$0	
Modular		2-Classroom Modular Building	Site Southwest	5	1	EA	\$0	
Modular		4-Classroom Modular Building	Site Northeast	5	5	EA	\$0	
Parking Lot		Asphalt	Site North and West	6	26,900	SF	\$23,080	
Parking Lot		Concrete	Site West Near Trash Enclosure	7	1,540	SF	\$0	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Concrete Curbs	Site North and West	7	745	LF	\$0	
Parking Lot		Parking lot interior plantings	Site ζ North	7	4	LF	\$0	
Parking Lot		Trash Enclosure	Site ζ West	7	1,540	SF	\$0	
Parking Lot		Vehicular Screening	Site ζ West	7	100	LF	\$0	
Parking Lot		Vehicular Screening	Site - East	5	145	LF	\$0	no plantings
Playground		Playground Equipment - Pre-K 3-5	Site- Southwest	6	1	EA	\$0	
Playground		Playground Equipment - School Age 5-12	Site-Northeast	6	1	EA	\$0	
Playground		Playground Surfacing - Poured Surface	Playground Northeast and Southwest	7	4,020	SF	\$0	
Sidewalks		Perimeter Sidewalks	Entire Site	7	16,300	SF	\$0	
Signage		Flag Pole	Site ζ West	7	1	EA	\$0	
Signage		Marquee - Free Standing Back Lighted	Site ζ West	6	1	EA	\$0	
Signage		Monument Sign	Site - East	7	1	EA	\$0	
SITE Sub Total							\$105,042	
SITE Sub Total							\$105,042	

Total Campus Need ^{2 3} \$4,041,078

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
001	800	1		10	40	48	56		N	N	Y	Classroom		
002	800	1		10	40	48	56		N	N	Y	Classroom		
003	800	1		10	40	48	56		N	N	Y	Classroom		
004	800	1		10	40	48	56		N	N	Y	Classroom		
101	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
102	730	1	30	68	40	90	5		Y	Y	Y	Classroom		
103	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
104	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
105	950	1	2	14	40	90	6		Y	Y	N	Classroom		
106	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
107	380	1	1	16	40	54	3		Y	N	Y	Classroom		
108	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
109	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
111	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
112	730	1	4	18	40	90	5		Y	Y	Y	Classroom		
113	730	1	1	18	40	90	5		Y	N	Y	Classroom		
113-A	350	1	1	8	40	32	16		Y	N	Y	Classroom		
114	730	1	4	18	40	90	5		Y	Y	Y	Classroom		
115	730	1	2	14	40	90	5		Y	N	Y	Classroom		
198	465	1	2	24	40	45	3		Y	N	Y	Classroom		
200	710	1	2	14	40	90	5		Y	N	Y	Classroom		
201	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
202	730	1	1	18	40	90	5		Y	N	Y	Classroom		
203	730	1	1	18	40	90	5		Y	N	Y	Classroom		
204	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
205	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
206	465	1	2	8	40	48	3		Y	N	Y	Classroom		
207	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
208	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
209	730		1	14	40	90	5		Y	N	Y	Classroom		
210	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
211	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
211-A	475			16	40	36	2		Y	N	Y	Classroom		
212	730		1	14	40	90	5		Y	N	Y	Classroom		
213	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
213-A	350			10	40	32	16		Y	N	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
214	730	1	1	18	40	90	5		Y	Y	Y	Classroom		
215	730		1	14	40	90	5		Y	N	Y	Classroom		
Other									N	N	N	Corridors		Northeast Stair
Other	305			8					N	N	N	Administrative Suites/Offices		Room 110-A
Other	260								N	N	N	Restroom	Adult Standard Student Restroom	2nd FL (North) - Boys
Other	20								N	N	N	Restroom	Staff Restroom	Room 199
Other	120			4					N	N	Y	Administrative Suites/Offices		110-B
Other									N	N	N	Corridors		Southeast Stair
Other	260								N	N	N	Restroom	Early Childhood Student Restroom	2nd FL (South) - Boys
Other	345			6					N	N	Y	Administrative Suites/Offices		Gym Office
Other									N	N	N	Corridors		Northeast Stair
Other									N	N	N	Corridors		Southeast Stair
Other									N	N	N	Corridors		West Stair
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	1st FL (South) - Girls
Other	260								N	N	N	Restroom	Adult Standard Student Restroom	2nd FL (South) - Boys
Other	260								N	N	N	Restroom	Adult Standard Student Restroom	1st FL (North) - Boys
Other	310								N	N	N	Restroom	Adult Standard Student Restroom	1st FL (North) - Girls
Other	140			4					N	N	Y	Administrative Suites/Offices		Room 132-A
Other	2785								N	N	N	Gymnasias	Standard Dedicated Gymnasium	1st Floor
Other	310								N	N	N	Restroom	Children's Standard Student Restroom	2nd FL (South) - Girls
Other	20								N	N	N	Restroom	Staff Restroom	Gym Office
Other	200								N	N	N	Restroom	Children's Standard Student Restroom	107
Other	80								N	N	N	Restroom	Staff Restroom	2nd Floor
Other	20								N	N	N	Restroom	Staff Restroom	Room 110-A
Other	310								N	N	N	Restroom	Adult Standard Student Restroom	2nd FL (North) - Girls
Other	450								N	N	N	Corridors		Entire Building - Vestibules
Other	5850								N	N	N	Corridors		1st Floor
Other	5850								N	N	N	Corridors		2nd Floor
Other	132								N	N	N	Restroom	Children's Standard Student Restroom	Auditorium - Boys
Other	260								N	N	N	Restroom	Children's Standard Student Restroom	1st FL (South) - Boys

Building: Addition

300	728	2	5	16	40	156	4		Y	Y	Y	Classroom		
301	1209	2	6	18	40	208	16		Y	Y	Y	Classroom		
302	1230	2	4	18	40	208	16		Y	N	Y	Classroom		
303	1230	2	4	18	40	208	16		Y	Y	Y	Classroom		
304	1230	2	4	18	40	208	16		Y	Y	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
305	1230	2	4	18	40	208	16		Y	Y	Y	Classroom		
306	1230	2	4	18	40	208	16		Y	Y	Y	Classroom		
307	431	4	3	26	40	78	6		Y	N	Y	Classroom		
308	431	4		26	40	78	6		Y	N	Y	Classroom		
400	800	2	6	16	40	108	12		Y	Y	Y	Classroom		
401	800	2	6	16	40	108	12		Y	Y	Y	Classroom		
402	800	2	6	16	40	108	12		Y	Y	Y	Classroom		
403	800	2	6	16	40	108	12		Y	N	Y	Classroom		
404	800	2	6	16	40	108	12		Y	N	Y	Classroom		
405	800	2	6	16	40	108	12		Y	Y	Y	Classroom		
406	800	2	6	16	40	108	12		Y	Y	Y	Classroom		
407	800	2	6	16	40	108	12		Y	Y	Y	Classroom		
408	800	2	6	16	40	108	12		Y	Y	Y	Classroom		
409	1007	2	3	14	40	108	12		Y	Y	Y	Classroom		
Other	460			8					N	N	Y	Administrative Suites/Offices		rm 320 faculty lounge in main office
Other									N	N	N	Corridors		Center Stair
Other	5307								N	N	N	Corridors		1st Floor
Other	36								N	N	N	Restroom	Children's Standard Student Restroom	in room 305
Other	36								N	N	N	Restroom	Children's Standard Student Restroom	in room 306
Other	36								N	N	N	Restroom	Children's Standard Student Restroom	in room 304
Other	54								N	N	N	Restroom	Staff Restroom	1st fl unisex
Other	36								N	N	N	Restroom	Children's Standard Student Restroom	in room 303
Other	712			20					N	N	N	Administrative Suites/Offices		Main Office
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls
Other	166			16					N	N	Y	Administrative Suites/Offices		Principals office in main
Other	165			6					N	N	Y	Administrative Suites/Offices		Work Room- in main office
Other	138			6					N	N	Y	Administrative Suites/Offices		rm 321
Other	138			4					N	N	N	Administrative Suites/Offices		library workroom 412
Other	71								N	N	N	Administrative Suites/Offices		rm 325
Other	121			4					N	N	Y	Administrative Suites/Offices		rm 421 Speech Office
Other	2360								N	N	N	Auditorium & Theater	Auditorium - Dedicated	1st Floor
Other	4062								N	N	N	Gymnasia	Gymnasium/Cafeteria	1st Floor
Other	144								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	dishwashing 1st fl
Other	41								N	N	N	Restroom	Staff Restroom	in kitchen unisex
Other	59			4					N	N	Y	Administrative Suites/Offices		Kitchen Staff Managers office in kitchen
Other	916								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	Servery

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other									N	N	N	Corridors		North East Stair
Other	1280								N	N	N	Kitchen	Cooking Kitchen	1st Floor
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls
Other	54								N	N	N	Restroom	Staff Restroom	2nd fl unisex
Other	4832								N	N	N	Corridors		2nd Floor
Other									N	N	N	Corridors		South East Stair
Other	36								N	N	N	Restroom	Children's Standard Student Restroom	in room 302
Other									N	N	N	Kitchen	Cooking Kitchen	