

Facility Assessment Detail

This report contains the findings of a facility assessment completed on the date noted in the document footer below. Assessors rate each facility feature and system by visual observation only; they do not test operability or perform destructive testing inside walls, ceilings or floors. The rankings below reflect the assessors' visual evaluations of the property condition as of that date. For additional information, you may visit the Facilities Standards webpage under CPS Policies and Guidelines at http://www.cps.edu/About_CPS/Policies_and_guidelines/Pages/facilitystandards.aspx.

Condition Rankings and Descriptions

- Rank 7:** The item/system is new or in good condition and no work is required.
- Rank 6:** The item/system requires general cleaning and/or routine maintenance.
- Rank 5:** The item/system requires repairs and has not reached the end of its serviceable life.
- Rank 4:** The item/system has reached its expected useful life, but is still fully operational. CPS will maintain until replacement occurs.
- Rank 3:** The item/system has surpassed its expected useful life and has limited operability. CPS will maintain until replacement occurs.
- Rank 2:** The item/system has surpassed its expected useful life and has low operability. CPS will maintain until replacement occurs.
- Rank 1:** The item's/system's failure leads to an immediate life safety condition for occupants or to the potential of an uninhabitable facility.¹

Definitions

- Quantity** means, for each item, the total number (or amount) of that item that exists and was evaluated.
- Unit** means the generally accepted standard unit of measure for each item. Some items, like doors, are measured individually and use the unit of measurement "EA" for "each." Other items, like chimneys, are measured in terms of linear feet ("LF"). Still other items, like flooring, are generally measured in square feet ("SF").
- Cost** means a basic estimate for each item needing some level of repair or replacement. Cost does not include all expenses that would be necessary to complete a repair or replacement project. This is because, depending on the item and on the overall scope of a construction project, repair/replacement projects can include additional costs such as destructive testing, environmental needs, discovered conditions, and additional work triggered by building codes.
- For the same reason, the Total Campus Need listed at the end of this report reflects only a portion of what it would actually cost to repair/replace all of the listed features.**
- Total Campus Need** also does not reflect features that do not yet exist at a particular facility, such as: programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration, or construction to alleviate overcrowding; these are viewed as separate capital needs.

Building: Main Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chimney		Brick Chimney - Concrete/ Mortar Liner	Below Roof line	6	55	LF	\$27,528	
Chimney		Brick Chimney - Concrete/ Mortar Liner	above roof	4	26	LF	\$143,143	cracked terracotta, spalled masonry, cracked brick, strapped
Cornice		Cornice - Terra Cotta	main roof - lower cornice	3	205	LF	\$125,761	displaced units at corners
Cornice		Cornice - Terra Cotta	upper cornice- center bay N and S elevation	4	60	LF	\$36,808	cracked
Cornice		Cornice - Terra Cotta	main roof upper and lower cornice	5	2,590	LF	\$524,333	cracks, open joints
Doors		Exterior Steel Door	main east entry	6	5	EA	\$1,652	
Doors		Overhead Rolling / Garage Door	north courtyard garage	7	1	EA	\$0	
Doors		Side Lite	main east entry	6	1	EA	\$227	
Doors		Transom Lite	main east entry	6	6	EA	\$1,699	
Entrance		Concrete Exterior Stairs	main entry east	5	150	LF	\$48,263	cracks
Entrance		Entrance Controls - Audio and Video	main east entry	7	1	EA	\$0	

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Entrance		Power Door Operator and Controls	main east entry	7	1	EA	\$0	
Foundation		Concrete Foundation	Entire Building	7	850	LF	\$0	
Lintels		Lintels - Steel	east 2nd floor	5	120	LF	\$34,320	bowing
Lintels		Lintels - Steel	Entire Building	6	267	LF	\$10,080	
Lintels		Lintels - Stone	main east entry doors	7	18	LF	\$0	
Lintels		Lintels - Terra Cotta	1st Floor	4	25	LF	\$19,663	cracked
Lintels		Lintels - Terra Cotta	Entire Building	5	585	LF	\$230,051	cracks, spalls
Parapet		Coping - Clay Tile	Main Roof	5	112	LF	\$6,627	reseal
Parapet		Coping - Metal	west low roof	4	53	LF	\$4,502	based on roof rank
Parapet		Coping - Stone	Main Roof	3	360	LF	\$95,135	cracked or displaced
Parapet		Coping - Stone	Entire Building	5	855	LF	\$74,557	reseal copings
Parapet		Parapet > 30" Height	east	7	30	LF	\$0	
Parapet		Parapet > 30" Height	north and south of main roofs	3	60	LF	\$59,631	displaced masonry, leaning in
Parapet		Parapet 16" to 30" Height	Entire Building	6	1,270	LF	\$263,698	spot point
Roof System		Exterior Downspouts	north courtyard garage, west low roof, N elevation of S addition	6	118	LF	\$2,194	
Roof System		Interior Downspouts	Entire Building	6	955	LF	\$0	
Roof System		Metal Roof	north courtyard shed	6	120	SF	\$906	
Roof System		Modified Bitumen Roof	north courtyard garage	6	130	SF	\$920	
Roof System		Modified Bitumen Roof	west low roof	4	650	SF	\$15,337	ponding
Roof System		Modified Bitumen Roof	Roof	6	33,500	SF	\$237,130	
Roof System		Roof Structure: Steel with Clay Tile Arch	Roofs	7	34,150	SF	\$0	
Superstructure		Steel with Clay Tile Arch	Entire Building	7	106,700	SF	\$0	
Walls		Brick	west courtyard base and east at base	5	230	SF	\$5,210	open joints
Walls		Brick	upper roof light court	4	180	SF	\$13,591	bulging
Walls		Brick	Entire Building	6	33,950	SF	\$224,294	
Walls		Stone - Cut	entire school- base	6	3,060	SF	\$43,758	spalling, dirty
Walls		Stone - Cut	east and west columns	7	600	SF	\$0	
Walls		Stone - Cut	east entry door surrounds	5	100	SF	\$10,725	open joints
Walls		Stone - Cut	east cheek walls	4	125	SF	\$31,281	shifted, open joints
Walls		Terra Cotta	entire school- decorative bands	5	5,400	SF	\$1,351,350	cracks and spalls, open joints
Windows		Window - Guards perforated	Entire Building	6	1,616	SF	\$0	chipping paint
Windows		Windows - Sash Aluminum	Entire Building	5	9,830	SF	\$327,104	80% balance problems reported

Building: Main
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
EXTERIOR Sub Total							\$3,971,475	

Building: Main
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Emergency A/C power - Auditorium and aisle lighting	Entire Building	7	8,597	SF	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	22,123	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	5,373	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	4	4,802	SF	\$17,167	
Emergency System		Emergency Battery Packs - Corridors and Stairs	Entire Building	6	3	EA	\$322	
Emergency System		Emergency generator 100 to 150 KW natural gas - Outdoor	Parking Lot	7	1	EA	\$0	
Emergency System		Exit Signs - Auditorium	Entire Building	3	12	EA	\$11,154	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	3	14	EA	\$13,013	
Emergency System		Public Announcement System	Entire Building	7	106,700	SF	\$0	
Power Distribution		Lighting and power panels	Entire Building	6	6	EA	\$4,290	
Power Distribution		Lighting and power panels	Entire Building	5	2	EA	\$4,290	
Power Distribution		Lighting and power panels	Entire Building	7	7	EA	\$0	
Power Distribution		Lighting and power panels	Basement	4	2	EA	\$10,868	Fused Emergency Panels
Power Distribution		Main distribution panels 400-600 amp	Boiler Room	7	2	EA	\$0	
Power Distribution		Transformers 120/240-120/208	Boiler Room	5	1	EA	\$5,005	
ELECTRICAL Sub Total							\$66,109	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Window A/C Unit	Entire Building	3	1	EA	\$2,145	
Air Conditioning		Window A/C Unit	Entire Building	5	5	EA	\$5,363	
Air Conditioning		Window A/C Unit	Entire Building	6	8	EA	\$1,716	
Air Conditioning		Window A/C Unit	Entire Building	7	11	EA	\$0	
Air Handling Systems		Air Intake - Built Up Air Handling Unit	Roof	7	2	EA	\$0	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Basement	6	2	EA	\$22,594	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 15,001 to 25,000 cfm	Basement	6	2	EA	\$5,720	
Air Handling Systems		Reheat Boxes With Steam Coils	Basement	6	12	EA	\$12,527	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Basement	4	300	LF	\$536,250	
Air Handling Systems		Single Zone Built Up Air Handling Unit - Steam 15,001 to 25,000 cfm	Basement	3	1	EA	\$64,350	Shaft missing - fan non-operational
Air Handling Systems		Single Zone Built Up Air Handling Unit Auxiliaries- Steam 15,001 to 25,000 cfm	Basement	5	1	EA	\$12,155	
Boiler Systems		Boiler Assembly - Steam - Low Pressure Scotch Marine Boiler greater than 200 HP	Boiler Room	5	2	EA	\$200,200	
Boiler Systems		Boiler Auxiliary - Steam Boiler greater than 200 HP	Boiler Room	6	2	EA	\$6,578	
Boiler Systems		Chemical Feed System (Steam Boilers)	Boiler Room	7	1	EA	\$0	
Boiler Systems		Combustion Dampers	Boiler Room	6	2	EA	\$572	
Boiler Systems		Feed Water Pumps and Tank - Steam Boilers	Boiler Room	7	1	EA	\$0	
Boiler Systems		Gas Boosters	Boiler Room	7	2	EA	\$0	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	6	2	EA	\$1,001	
Heating Devices		Radiators - Steam	Entire Building	5	6	EA	\$3,947	
Heating Devices		Radiators - Steam	Entire Building	3	6	EA	\$8,408	
Heating Devices		Unit Heater - Electric	Entire Building	2	2	EA	\$11,440	No longer functional
Heating Devices		Unit Heater - Electric	Entire Building	3	4	EA	\$22,880	
Heating Devices		Unit Heater - Electric	Entire Building	4	2	EA	\$11,440	
Heating Devices		Unit Heater - Gas	Boiler Room	7	1	EA	\$0	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Basement	6	1	EA	\$715	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	4	500	LF	\$48,978	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	500	LF	\$24,739	
Mechanical Plumbing		Pumps - Hot Water less than 5 HP	Boiler Room	7	2	EA	\$0	
Temperature Control		Pneumatic System	Entire Building	3	106,700	SF	\$762,905	Engineer explained that the majority of the pneumatic lines were no longer functional. Noise from the compressor indicates repairs/maintenance are required.
Temperature Control		Thermostats - Pneumatic	Entire Building	6	25	EA	\$3,575	
Temperature Control		Thermostats - Pneumatic	Entire Building	4	7	EA	\$4,605	
Temperature Control		Zone Dampers	Basement	3	36	EA	\$30,373	Majority of zone dampers serving spaces in the main building are non-operational and propped open with sticks etc.
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	5	4	EA	\$5,148	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	4	1	EA	\$2,288	

Building: Main
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	6	2	EA	\$458	
Ventilation		Exhaust Fans - Roof Mounted above 8,000 cfm	Roof	5	2	EA	\$12,870	
MECHANICAL Sub Total							\$1,825,938	

Building: Main
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Hot Water		Hot Water Heater - Gas more than 300,000 BTU/HR	Boiler Room	7	2	EA	\$0	
Hot Water		Storage Tank less than 500 gallons	Boiler Room	7	3	EA	\$0	
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	106,700	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	106,700	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	106,700	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	106,700	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	106,700	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	106,700	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	106,700	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	106,700	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	106,700	SF	\$0	
Piping		Storm Piping	Entire Building	7	106,700	SF	\$0	
Piping		Vent Piping	Entire Building	7	106,700	SF	\$0	
Pumps		Domestic Booster Pump simplex	Boiler Room	5	1	EA	\$8,580	
PLUMBING Sub Total							\$8,580	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	main office- 1st fl	7	905	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	assistant principals office in 106	7	121	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	rm 109- principals office	7	494	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	rm 104	7	324	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	106C	7	202	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	in rm 303	6	84	SF	\$238	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	in rm 305	7	234	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	vacant office in rm 307	7	206	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	in rm 301	6	84	SF	\$238	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	vacant workroom in rm 307	7	110	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Plaster/Drywall	counselors office 106 D/E/F/G	7	280	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Splined	rm 114 (5 spaces) vacant	6	1,943	SF	\$4,168	
Administrative Suites	Administrative Suites/Offices	Flooring - Carpet	vacant office in rm 307	4	206	SF	\$2,139	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	106C	6	202	SF	\$289	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in rm 303	4	84	SF	\$1,189	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in rm 305	4	234	SF	\$3,313	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 114 (5 spaces) vacant	6	1,943	SF	\$2,778	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	assistant principals office in 106	7	121	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 104	7	324	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	counselors office 106 D/E/F/G	6	280	SF	\$400	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	in rm 301	4	84	SF	\$1,189	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	main office- 1st fl	7	905	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 109- principals office	6	494	SF	\$706	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	vacant workroom in rm 307	6	110	SF	\$157	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	106C	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	in rm 301	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	vacant office in rm 307	7	3	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	vacant workroom in rm 307	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	in rm 303	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	rm 109- principals office	7	9	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	in rm 305	7	6	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	counselors office 106 D/E/F/G	7	4	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	rm 104	4	7	SF	\$46	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	rm 114 (5 spaces) vacant	7	42	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	main office- 1st fl	7	19	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	assistant principals office in 106	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	counselors office 106 D/E/F/G	6	1,404	SF	\$3,313	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	106C	7	693	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	vacant office in rm 307	5	707	SF	\$3,336	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	vacant workroom in rm 307	6	378	SF	\$892	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	main office- 1st fl	7	2,293	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 114 (5 spaces) vacant	5	4,500	SF	\$21,236	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 109- principals office	6	1,155	SF	\$2,725	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	assistant principals office in 106	7	511	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	in rm 303	5	333	SF	\$1,571	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	in rm 301	5	333	SF	\$1,571	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	in rm 305	6	832	SF	\$1,963	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 104	6	922	SF	\$2,175	
Auditorium - Dedicated	Auditorium - Dedicated	Balcony Seating	1st Floor	6	227	EA	\$8,355	
Auditorium - Dedicated	Auditorium - Dedicated	Main Floor Seating	1st Floor	6	559	EA	\$20,576	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Auditorium - Dedicated	Auditorium - Dedicated	Sound System	1st Floor	7	1	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Curtains	1st Floor	5	9	EA	\$0	
Auditorium - Dedicated	Auditorium - Dedicated	Stage Lighting System	1st Floor	5	1	EA	\$214,500	
Corridor		Stair Handrails	Auditorium	6	38	LF	\$0	
Corridor		Stairs - Asphalt	Auditorium	5	34	LF	\$1,702	
Doors		Interior Steel Doors incl hw	Entire Building	6	22	EA	\$6,229	
Doors		Interior Steel Doors incl hw	Entire Building	7	2	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	53	EA	\$15,006	
Doors		Interior Wood Doors incl hw	Entire Building	7	14	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	5	36	EA	\$16,988	
Doors		Interior Wood Doors incl hw	Entire Building	4	29	EA	\$93,059	
Doors		Transom Window	Entire Building	6	890	SF	\$16,545	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	4	1	EA	\$3,861	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	5	1	EA	\$1,931	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	3rd Floor	6	5,373	SF	\$45,947	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	3rd Floor	6	5,373	SF	\$40,568	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	3rd Floor	6	24	EA	\$4,290	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	3rd Floor			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Plaster/Drywall	3rd Floor	5	6,030	SF	\$86,229	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	S Center Stairs- Flr 1.5 NOT USED			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	S Center Stairs- Flr 2.5 NOT USED			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	N Center Stairs- Flr 1.5 NOT USED			LF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Adult Standard Student Restroom	Benches	Men's in auditorium lobby (visitor use) storage			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	N Center Stairs- Flr 2.5 NOT USED			LF	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Benches	womens in auditorium lobby (visitor use) locked/storage			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	principals bathroom in 106			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	3rd fl locker room in gym			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	in rm 110			LF	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Benches	in rm 114			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	women's rm in 106			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	principals bathroom in 106			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	women's rm in 106			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Lockers	in rm 114			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	in rm 110			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	3rd fl locker room in gym			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	N Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys			EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Adult Standard Student Restroom	Lockers	womens in auditorium lobby (visitor use) locked/storage			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	N Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	S Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	S Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Lockers	Men's in auditorium lobby (visitor use) storage			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	S Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	3rd fl locker room in gym	5	13	EA	\$15,802	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	Men's in auditorium lobby (visitor use) storage			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	S Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	N Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Locker/Shower Room	Adult Standard Student Restroom	Showers	womens in auditorium lobby (visitor use) locked/storage			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	N Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	principals bathroom in 106			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	in rm 110			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	women's rm in 106			EA	\$0	
Locker/Shower Room	Early Childhood Student Restroom	Showers	in rm 114			EA	\$0	
MDF/IDF		Finishes	in rm 303/301	6	175	SF	\$596	
MDF/IDF		Ventilation and Cooling	in rm 303/301	6	1	EA	\$1,401	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Mechanical/Service Rooms		Boiler Room	Basement	6	1,555	SF	\$7,338	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	6	SF	\$28	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	14,445	SF	\$68,166	
Mechanical/Service Rooms		Storage Room	2nd Floor	6	286	SF	\$1,350	
Mechanical/Service Rooms		Storage Room	310, 307, 305, 304 and corridor	6	217	SF	\$1,024	
Mechanical/Service Rooms		Storage Room	2nd flr - Book Storage	6	573	SF	\$2,704	
Mechanical/Service Rooms		Storage Room	in 106	7	240	SF	\$0	
Mechanical/Service Rooms		Storage Room	1st fl/ in 104	6	527	SF	\$2,487	
Mechanical/Service Rooms		Storage Room	in gym	6	210	SF	\$991	
Mechanical/Service Rooms		Storage Room	in rms 204 & 205	6	40	SF	\$189	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys	7	583	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	N Center Stairs- Flr 1.5 NOT USED	6	72	SF	\$556	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys	7	583	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Accessories	womens in auditorium lobby (visitor use) locked/storage	5	170	SF	\$4,332	
Staff Restroom	Adult Standard Student Restroom	Accessories	Men's in auditorium lobby (visitor use) storage	5	115	SF	\$2,930	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls	7	583	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	S Center Stairs- Flr 1.5 NOT USED	6	72	SF	\$556	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls	7	583	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys	7	583	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	N Center Stairs- Flr 2.5 NOT USED	5	72	SF	\$1,835	
Staff Restroom	Locker/Shower Room	Accessories	3rd fl locker room in gym	4	1,204	SF	\$92,973	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls	7	583	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	in rm 110	7	38	SF	\$0	
Staff Restroom	Early Childhood Student Restroom	Accessories	in rm 114	5	62	SF	\$1,580	
Staff Restroom	Staff Restroom	Accessories	S Center Stairs- Flr 2.5 NOT USED	5	72	SF	\$1,835	
Staff Restroom	Staff Restroom	Accessories	women's rm in 106	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	principals bathroom in 106	7	38	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Ceiling - Lay-In	in rm 110	7	38	SF	\$0	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	3rd fl locker room in gym	5	1,204	SF	\$6,818	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	N Center Stairs- Flr 1.5 NOT USED	6	72	SF	\$204	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	womens in auditorium lobby (visitor use) locked/storage	6	170	SF	\$481	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls	7	583	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Ceiling - Plaster/Drywall	Men's in auditorium lobby (visitor use) storage	6	115	SF	\$326	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	principals bathroom in 106	7	38	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys	7	583	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys	7	583	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	S Center Stairs- Flr 2.5 NOT USED	6	72	SF	\$204	
Staff Restroom	Early Childhood Student Restroom	Ceiling - Plaster/Drywall	in rm 114	5	62	SF	\$351	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls	7	583	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls	6	583	SF	\$1,651	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	S Center Stairs- Flr 1.5 NOT USED	6	72	SF	\$204	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	N Center Stairs- Flr 2.5 NOT USED	6	72	SF	\$204	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	women's rm in 106	7	60	SF	\$0	
Staff Restroom	Locker/Shower Room	Floor Drain	3rd fl locker room in gym	5	2	EA	\$3,003	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	in rm 110	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Floor Drain	in rm 114			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	women's rm in 106			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	principals bathroom in 106			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	S Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	N Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls	7	1	EA	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys	6	1	EA	\$300	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	womens in auditorium lobby (visitor use) locked/storage			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Floor Drain	Men's in auditorium lobby (visitor use) storage			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	S Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	N Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Flooring - Concrete	3rd fl locker room in gym	5	968	SF	\$4,568	
Staff Restroom	Early Childhood Student Restroom	Flooring - Terrazzo	in rm 114	6	62	SF	\$351	
Staff Restroom	Adult Standard Student Restroom	Flooring - Terrazzo	Men's in auditorium lobby (visitor use) storage	5	115	SF	\$2,149	
Staff Restroom	Adult Standard Student Restroom	Flooring - Terrazzo	womens in auditorium lobby (visitor use) locked/storage	5	170	SF	\$3,177	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	N Center Stairs- Flr 1.5 NOT USED	6	72	SF	\$183	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	N Center Stairs- Flr 2.5 NOT USED	6	72	SF	\$183	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls	6	583	SF	\$1,484	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	S Center Stairs- Flr 1.5 NOT USED	6	72	SF	\$183	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	S Center Stairs- Flr 2.5 NOT USED	6	72	SF	\$183	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys	6	583	SF	\$1,484	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys	6	583	SF	\$1,484	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys	6	583	SF	\$1,484	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls	6	583	SF	\$1,484	
Staff Restroom	Locker/Shower Room	Flooring - Tile Ceramic/Porcelain	3rd fl locker room in gym	5	236	SF	\$3,712	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	women's rm in 106	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	principals bathroom in 106	7	38	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls	6	583	SF	\$1,484	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile/Sheet	in rm 110	6	38	SF	\$54	
Staff Restroom	Staff Restroom	Hand Dryer	N Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	womens in auditorium lobby (visitor use) locked/storage			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	women's rm in 106			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Hand Dryer	Men's in auditorium lobby (visitor use) storage			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	N Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls	7	2	EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	3rd fl locker room in gym	6	2	EA	\$434	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	in rm 110			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	S Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys	7	2	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Hand Dryer	in rm 114			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	principals bathroom in 106			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	S Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Lavatory	Men's in auditorium lobby (visitor use) storage	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	S Center Stairs- Flr 1.5 NOT USED	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	S Center Stairs- Flr 2.5 NOT USED	6	1	EA	\$372	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lavatory	N Center Stairs- Flr 1.5 NOT USED	5	1	EA	\$1,859	
Staff Restroom	Adult Standard Student Restroom	Lavatory	womens in auditorium lobby (visitor use) locked/storage	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys	5	2	EA	\$3,718	
Staff Restroom	Staff Restroom	Lavatory	N Center Stairs- Flr 2.5 NOT USED	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	principals bathroom in 106	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	women's rm in 106	7	1	EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Lavatory	in rm 114	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	in rm 110	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Lavatory	3rd fl locker room in gym	4	2	EA	\$7,436	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	in rm 110	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl boys	4	4	SF	\$17	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl boys	7	5	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	womens in auditorium lobby (visitor use) locked/storage	4	1	SF	\$4	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl girls	7	5	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl girls	4	5	SF	\$21	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl girls	7	5	SF	\$0	
Staff Restroom	Locker/Shower Room	Lighting - Pendant/ Surface	3rd fl locker room in gym	7	26	SF	\$0	
Staff Restroom	Adult Standard Student Restroom	Lighting - Pendant/ Surface	Men's in auditorium lobby (visitor use) storage	4	1	SF	\$4	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Early Childhood Student Restroom	Lighting - Pendant/ Surface	in rm 114	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	N Center Stairs- Flr 2.5 NOT USED	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	S Center Stairs- Flr 1.5 NOT USED	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	principals bathroom in 106	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	women's rm in 106	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl boys	7	5	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	S Center Stairs- Flr 2.5 NOT USED	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	N Center Stairs- Flr 1.5 NOT USED	4	1	SF	\$4	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	women's rm in 106	4	1	EA	\$322	
Staff Restroom	Staff Restroom	Lighting - Wall Mounted	principals bathroom in 106	4	1	EA	\$322	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	in rm 110			EA	\$0	
Staff Restroom	Locker/Shower Room	Partitions	3rd fl locker room in gym	5	2	EA	\$1,144	
Staff Restroom	Staff Restroom	Partitions	S Center Stairs- Flr 1.5 NOT USED	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls	6	6	EA	\$1,076	
Staff Restroom	Early Childhood Student Restroom	Partitions	in rm 114	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls	6	6	EA	\$1,076	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys	6	2	EA	\$359	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	women's rm in 106	6	2	EA	\$359	
Staff Restroom	Staff Restroom	Partitions	principals bathroom in 106			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	S Center Stairs- Flr 2.5 NOT USED	6	1	EA	\$179	
Staff Restroom	Staff Restroom	Partitions	N Center Stairs- Flr 2.5 NOT USED	6	1	EA	\$179	
Staff Restroom	Adult Standard Student Restroom	Partitions	womens in auditorium lobby (visitor use) locked/storage	6	2	EA	\$359	
Staff Restroom	Adult Standard Student Restroom	Partitions	Men's in auditorium lobby (visitor use) storage	6	1	EA	\$179	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Partitions	N Center Stairs- Flr 1.5 NOT USED	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls	6	6	EA	\$1,076	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys	6	6	EA	\$2,231	
Staff Restroom	Children's Standard Student Restroom	Urinals	in rm 110			EA	\$0	
Staff Restroom	Early Childhood Student Restroom	Urinals	in rm 114			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	women's rm in 106			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	principals bathroom in 106			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys	7	6	EA	\$0	
Staff Restroom	Locker/Shower Room	Urinals	3rd fl locker room in gym			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	womens in auditorium lobby (visitor use) locked/storage			EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Urinals	Men's in auditorium lobby (visitor use) storage	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	S Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	S Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	N Center Stairs- Flr 1.5 NOT USED			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	N Center Stairs- Flr 2.5 NOT USED			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl girls	7	263	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	N Center Stairs- Flr 2.5 NOT USED	6	335	SF	\$790	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	S Center Stairs- Flr 2.5 NOT USED	6	335	SF	\$790	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	N Center Stairs- Flr 1.5 NOT USED	6	360	SF	\$849	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	Men's in auditorium lobby (visitor use) storage	6	370	SF	\$873	
Staff Restroom	Adult Standard Student Restroom	Wall - Plaster/Drywall	womens in auditorium lobby (visitor use) locked/storage	6	535	SF	\$1,262	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl boys	7	263	SF	\$0	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl boys	5	263	SF	\$1,241	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	3rd fl girls	6	263	SF	\$621	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	1st fl girls	7	263	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Plaster/Drywall	3rd fl locker room in gym	6	2,132	SF	\$5,030	
Staff Restroom	Early Childhood Student Restroom	Wall - Plaster/Drywall	in rm 114	4	382	SF	\$3,605	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	women's rm in 106	7	340	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Plaster/Drywall	principals bathroom in 106	7	275	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Plaster/Drywall	2nd fl boys	7	263	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls	6	385	SF	\$2,753	
Staff Restroom	Locker/Shower Room	Wall - Structural Glazed Tile	3rd fl locker room in gym	6	1,312	SF	\$9,381	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl girls	6	385	SF	\$2,753	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls	6	385	SF	\$2,753	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys	6	385	SF	\$2,753	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl boys	6	385	SF	\$2,753	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys	6	385	SF	\$2,753	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl boys	7	224	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd fl boys	6	224	SF	\$570	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st fl boys	7	224	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	2nd fl girls	7	224	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	3rd fl girls	6	224	SF	\$570	
Staff Restroom	Children's Standard Student Restroom	Wall - Tile Ceramic/ Porcelain	1st fl girls	6	224	SF	\$570	
Staff Restroom	Adult Standard Student Restroom	Water Closet	Men's in auditorium lobby (visitor use) storage	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Water Closet	N Center Stairs- Flr 1.5 NOT USED	6	1	EA	\$372	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Water Closet	in rm 110	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	N Center Stairs- Flr 2.5 NOT USED	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls	6	6	EA	\$2,231	
Staff Restroom	Early Childhood Student Restroom	Water Closet	in rm 114	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Water Closet	women's rm in 106	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	principals bathroom in 106	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	S Center Stairs- Flr 1.5 NOT USED	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls	7	6	EA	\$0	
Staff Restroom	Adult Standard Student Restroom	Water Closet	womens in auditorium lobby (visitor use) locked/storage	5	2	EA	\$3,718	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	S Center Stairs- Flr 2.5 NOT USED	4	1	EA	\$3,718	
Staff Restroom	Locker/Shower Room	Water Closet	3rd fl locker room in gym	5	2	EA	\$3,718	
Theater	Auditorium - Dedicated	Ceiling - Lay-In	1st Floor	6	622	SF	\$4,892	
Theater	Auditorium - Dedicated	Ceiling - Plaster/Drywall	1st Floor	6	8,013	SF	\$68,522	
Theater	Auditorium - Dedicated	Flooring - Tile/Sheet	1st Floor	7	1,015	SF	\$0	
Theater	Auditorium - Dedicated	Flooring - Wood	1st Floor	5	3,160	SF	\$44,736	
Theater	Auditorium - Dedicated	Lighting - Lay-In	1st Floor	7	6	SF	\$0	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	6	54	SF	\$89	
Theater	Auditorium - Dedicated	Lighting - Pendant/ Surface	1st Floor	5	4	SF	\$17	
Theater	Auditorium - Dedicated	Stage	1st Floor	6	1,182	SF	\$5,020	
Theater	Auditorium - Dedicated	Wall - Plaster/Drywall	1st Floor	6	13,488	SF	\$115,727	
Vocational Shop	Classroom	Work Sink		4	2	EA	\$7,722	
Vocational Shop	Classroom	Work Sink		4	1	EA	\$3,861	
Vocational Shop	Classroom	Work Sink		4	2	EA	\$7,722	
Vocational Shop	Classroom	Work Sink		4	2	EA	\$7,722	
Vocational Shop	Classroom	Work Sink		4	1	EA	\$3,861	

Building: Main
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Vocational Shop	Classroom	Work Sink		7	1	EA	\$0	
INTERIOR Sub Total							\$1,246,783	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		5	30	LF	\$5,363	
Casework	Classroom	Casework		6	3	LF	\$107	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		5	36	LF	\$6,435	
Casework	Classroom	Casework		7	11	LF	\$0	
Casework	Classroom	Casework		6	9	LF	\$322	
Casework	Classroom	Casework		6	6	LF	\$215	
Casework	Classroom	Casework		4	9	LF	\$4,183	
Casework	Classroom	Casework		5	58	LF	\$10,368	
Casework	Classroom	Casework		5	18	LF	\$3,218	
Casework	Classroom	Casework		4	9	LF	\$4,183	
Casework	Classroom	Casework		5	66	LF	\$11,798	
Casework	Classroom	Casework		5	68	LF	\$12,155	
Casework	Classroom	Casework		6	9	LF	\$322	
Ceiling	Classroom	Plaster/Drywall		7	756	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		6	562	SF	\$1,591	
Ceiling	Classroom	Plaster/Drywall		6	1,058	SF	\$2,996	
Ceiling	Classroom	Plaster/Drywall		6	756	SF	\$2,141	
Ceiling	Classroom	Plaster/Drywall		7	868	SF	\$0	
Ceiling	Classroom	Plaster/Drywall		7	756	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	25	LF	\$3,039	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4		LF		
CLASSROOM	Classroom	Science Lab Elements		4	1	SF	\$93	
Corridors	Corridors	Asphalt	center stairs	5	1,842	SF	\$20,862	
Corridors	Corridors	Asphalt	end stairs	5	960	SF	\$10,873	
Corridors	Corridors	Asphalt	2nd Floor	5	3,885	SF	\$44,000	
Corridors	Corridors	Asphalt	3rd Floor	4	3,885	SF	\$102,667	
Corridors	Corridors	Drinking Fountains	corridor in 106			EA	\$0	
Corridors	Corridors	Drinking Fountains	end stairs			EA	\$0	
Corridors	Corridors	Drinking Fountains	center stairs			EA	\$0	
Corridors	Corridors	Drop/Lay-In	end stairs	7	1,148	SF	\$0	
Corridors	Corridors	Drop/Lay-In	center stairs	7	926	SF	\$0	
Corridors	Corridors	Drop/Lay-In	1st Floor	7	2,835	SF	\$0	
Corridors	Corridors	Drop/Lay-In	2nd Floor	7	3,885	SF	\$0	
Corridors	Corridors	Drop/Lay-In	3rd Floor	5	3,885	SF	\$22,000	
Corridors	Corridors	Lay-In	center stairs	7	926	EA	\$0	
Corridors	Corridors	Lay-In	3rd Floor	6	3,885	EA	\$2,778	
Corridors	Corridors	Lay-In	end stairs	7	1,148	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	2,835	EA	\$0	
Corridors	Corridors	Lay-In	2nd Floor	7	3,885	EA	\$0	
Corridors	Corridors	Pendant/Surface	corridor in 106	7	438	EA	\$0	
Corridors	Corridors	Pendant/Surface	center stairs	7	1,924	EA	\$0	
Corridors	Corridors	Pendant/Surface	1st Floor	7	2,500	EA	\$0	
Corridors	Corridors	Pendant/Surface	end stairs	7	540	EA	\$0	
Corridors	Corridors	Plaster/Drywall	center stairs	6	9,405	SF	\$22,191	
Corridors	Corridors	Plaster/Drywall	corridor in 106	7	1,793	SF	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Plaster/Drywall	1st Floor	6	7,600	SF	\$17,932	
Corridors	Corridors	Plaster/Drywall	2nd Floor	7	6,376	SF	\$0	
Corridors	Corridors	Plaster/Drywall	3rd Floor	5	6,376	SF	\$30,088	
Corridors	Corridors	Plaster/Drywall	end stairs	6	6,368	SF	\$15,025	
Corridors	Corridors	Single Water Cooler	1st Floor	5	3	EA	\$9,224	
Corridors	Corridors	Single Water Cooler	1st Floor	7	4	EA	\$0	
Corridors	Corridors	Single Water Cooler	2nd Floor	5	3	EA	\$9,224	
Corridors	Corridors	Single Water Cooler	2nd Floor	7	3	EA	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	corridor in 106			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	1st Floor			LF	\$0	
Corridors	Corridors	Stair Handrails	center stairs	5	194	LF	\$2,563	
Corridors	Corridors	Stair Handrails	end stairs	6	148	LF	\$0	
Corridors	Corridors	Stairs	3rd Floor			EA	\$0	
Corridors	Corridors	Stairs	corridor in 106			EA	\$0	
Corridors	Corridors	Stairs	1st Floor			EA	\$0	
Corridors	Corridors	Stairs	2nd Floor			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	center stairs	6	740	SF	\$5,291	
Corridors	Corridors	Student Lockers	center stairs			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor	4	315	EA	\$148,649	
Corridors	Corridors	Student Lockers	1st Floor			EA	\$0	
Corridors	Corridors	Student Lockers	end stairs			EA	\$0	
Corridors	Corridors	Student Lockers	corridor in 106			EA	\$0	
Corridors	Corridors	Terrazzo	end stairs	7	576	SF	\$0	
Corridors	Corridors	Terrazzo	center stairs	7	1,000	SF	\$0	
Corridors	Corridors	Terrazzo	1st Floor	6	5,320	SF	\$30,126	
Corridors	Corridors	Tile/Sheet Flooring	corridor in 106	6	438	SF	\$626	
Corridors	Corridors	Walls	end stairs	6	228	SF	\$538	
Corridors Ceiling	Corridors	Plaster/Drywall	end stairs	6	540	SF	\$1,529	
Corridors Ceiling	Corridors	Plaster/Drywall	1st Floor	7	2,500	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	center stairs	6	1,924	SF	\$5,448	
Corridors Ceiling	Corridors	Plaster/Drywall	corridor in 106	7	438	SF	\$0	
Stairs	Corridors	Asphalt	center stairs	5	8	SF	\$400	
Stairs	Corridors	Asphalt	end stairs	5	102	SF	\$5,105	
Stairs	Corridors	Tile	center stairs	5	118	SF	\$2,227	
Floor	Classroom	Carpet		4	1,315	SF	\$13,652	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Tile/Sheet		5	868	SF	\$4,915	
Floor	Classroom	Tile/Sheet		7	756	SF	\$0	
Floor	Classroom	Tile/Sheet		6	1,155	SF	\$1,652	
Floor	Classroom	Tile/Sheet		7	756	SF	\$0	
Floor	Classroom	Tile/Sheet		7	756	SF	\$0	
Floor	Classroom	Tile/Sheet		4	1,058	SF	\$14,978	
Floor	Classroom	Tile/Sheet		5	562	SF	\$3,182	
Floor	Classroom	Tile/Sheet		4	1,058	SF	\$14,978	
Floor	Classroom	Tile/Sheet		4	1,145	SF	\$16,210	
Floor	Classroom	Tile/Sheet		4	756	SF	\$10,703	
Floor	Classroom	Tile/Sheet		7	756	SF	\$0	
Floor	Classroom	Tile/Sheet		6	756	SF	\$1,081	
Floor	Classroom	Tile/Sheet		5	868	SF	\$4,915	
Floor	Classroom	Tile/Sheet		7	756	SF	\$0	
Floor	Classroom	Tile/Sheet		7	756	SF	\$0	
Floor	Classroom	Tile/Sheet		6	420	SF	\$601	
Floor	Classroom	Tile/Sheet		5	1,128	SF	\$6,388	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		5	756	SF	\$10,703	
Floor	Classroom	Wood		5	756	SF	\$10,703	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		7	756	SF	\$0	
Floor	Classroom	Wood		7	756	SF	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	18	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	32	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	20	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	27	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	24	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	8	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	25	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	14	EA	\$0	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	34	LF	\$0	
Marker Board	Classroom	Marker Board		7	23	LF	\$0	
Marker Board	Classroom	Marker Board		7	27	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	6	LF	\$0	
RESTROOM_CEILING	Children's Standard Student Restroom	Restroom Ceiling	3rd fl boys	5	583	SF	\$3,301	
RESTROOM_WALL	Staff Restroom	Restroom Walls	S Center Stairs- Flr 1.5 NOT USED	6	360	SF	\$916	
RESTROOM_WALL	Adult Standard Student Restroom	Restroom Walls	Men's in auditorium lobby (visitor use) storage	6	144	SF	\$367	
RESTROOM_WALL	Adult Standard Student Restroom	Restroom Walls	womens in auditorium lobby (visitor use) locked/storage	6	204	SF	\$519	
RESTROOM_WALL	Children's Standard Student Restroom	Restroom Walls	in rm 110	7	188	SF	\$0	
THEATER_CEILING	Auditorium - Dedicated	Auditorium Ceiling	1st Floor	7	68	SF	\$0	
THEATER_FLOOR	Auditorium - Dedicated	Auditorium Floor	1st Floor	7	690	SF	\$0	
THEATER_FLOOR	Auditorium - Dedicated	Auditorium Floor	1st Floor	6	377	SF	\$1,779	
THEATER_FLOOR	Auditorium - Dedicated	Auditorium Floor	1st Floor	5	3,355	SF	\$15,832	
THEATER_WALL	Auditorium - Dedicated	Auditorium Walls	1st Floor	6	1,152	SF	\$2,389	
THEATER_WALL	Auditorium - Dedicated	Auditorium Walls	1st Floor	7	162	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,344	SF	\$3,171	
Wall	Classroom	Plaster/Drywall		5	1,067	SF	\$5,035	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	1,673	SF	\$3,947	
Wall	Classroom	Plaster/Drywall		6	1,344	SF	\$3,171	
Wall	Classroom	Plaster/Drywall		6	1,067	SF	\$2,518	
Wall	Classroom	Plaster/Drywall		6	2,032	SF	\$4,795	

Building: Main
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	763	SF	\$1,800	
Wall	Classroom	Plaster/Drywall		5	1,900	SF	\$8,966	
Wall	Classroom	Plaster/Drywall		5	1,344	SF	\$6,342	
Wall	Classroom	Plaster/Drywall		5	1,062	SF	\$5,012	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,750	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,750	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,344	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	1,743	SF	\$0	
ROOM Sub Total							\$797,185	

Building Main Sub Total \$7,916,071

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Canopy		Metal Canopy	east and west elevation	4	120	SF	\$19,254	dented and loose fascia
Doors		Exterior FRP Door	Courtyard	7	5	EA	\$0	
Doors		Exterior Steel Door	west connector	7	6	EA	\$0	
Doors		Exterior Steel Door	SW entry	5	3	EA	\$3,270	dented
Doors		Exterior Steel Door	Entire Building	6	7	EA	\$2,312	
Doors		Overhead Rolling / Garage Door	North Courtyard Garage	7	1	EA	\$0	
Doors		Transom Lite	Entire Building	7	21	EA	\$0	
Entrance		Concrete Exterior Stairs	N, S, W elevations	5	239	LF	\$76,898	cracked, spalled
Entrance		Concrete Ramp	North Entrances	6	6	LF	\$837	steep, no rails
Entrance		Entrance Controls - Audio and Video	west connector	7	1	EA	\$0	
Entrance		Power Door Operator and Controls	west connector	7	1	EA	\$0	
Entrance		Stair Handrails	west connector	6	28	LF	\$0	
Entrance		Stone Stairs	N and S elevation, S courtyard	6	34	LF	\$6,078	steep, no rails
Foundation		Concrete Foundation	Entire Building	6	1,220	LF	\$189,987	spalls at base of perimeter
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Site	6	22	EA	\$11,011	

Building: Addition
Category: EXTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting		Exterior Lights - Parapet or Roof Mounted	Entire Site	3	2	EA	\$7,436	Missing lens/bulb
Lighting		Exterior Lights - Wall Mounted	Entire Building	6	1	EA	\$215	
Lighting		Exterior Lights - Wall Mounted	Entire Building	7	3	EA	\$0	
Lintels		Lintels - Steel	N side of S addition, N and S side of N addition	5	200	LF	\$57,200	brick shifted, exposing cores
Lintels		Lintels - Steel	Entire Building	7	2,190	LF	\$0	
Lintels		Lintels - Stone	W, SW, NW windows	7	240	LF	\$0	
Parapet		Coping - Metal	Entire Building	3	1,250	LF	\$106,178	based on roof rank
Roof System		Asphalt Gravel Ballast Roof	Roof	3	37,000	SF	\$942,856	splits, active leaks (north wing), bubbling, visible ponding, crumbling membrane, visible felt
Roof System		Exterior Downspouts	north elevation, south wing	6	108	LF	\$2,008	
Roof System		Interior Downspouts	Entire Building	6	200	LF	\$0	
Roof System		Interior Downspouts	north wing	5	66	LF	\$7,079	adjacent to active leak
Roof System		Roof Structure: Steel/Metal Deck/Concrete Topping	Roof	7	37,000	SF	\$0	
Superstructure		Concrete	1st floor and basement	7	44,100	SF	\$0	
Superstructure		Metal Deck/Concrete Topping	2nd and 3rd floor	7	68,100	SF	\$0	
Walls		Brick	S side of S addition	6	240	SF	\$1,586	efflorescence at top of wall
Walls		Brick	SW corner of N addition, NW corner of S addition	5	80	SF	\$1,812	cracks at pipes
Walls		Brick	Entire Building	7	28,975	SF	\$0	
Walls		Stone - Cut	NW and SW entry and W elevation	6	1,872	SF	\$26,770	
Windows		Window - Guards perforated	Entire Building	6	4,400	SF	\$0	paint chipping
Windows		Windows - Sash Aluminum	Entire Building	6	15,510	SF	\$133,076	
EXTERIOR Sub Total							\$1,595,860	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Automatic Transfer switch	Electrical Room	7	3	EA	\$0	
Emergency System		Emergency A/C power - Corridors and Stairs	Entire Building	7	23,410	SF	\$0	
Emergency System		Emergency A/C power - Gym and Lunch rooms	Entire Building	7	6,664	SF	\$0	
Emergency System		Emergency A/C power - Students Toilets	Entire Building	4	2,860	SF	\$10,225	
Emergency System		Exit Signs - Corridors and Stairs	Entire Building	3	19	EA	\$17,661	
Emergency System		Exit Signs - Lunchroom - Gym - multipurpose rooms	Entire Building	3	16	EA	\$14,872	

Building: Addition
Category: ELECTRICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Emergency System		Independent Electrical Service for emergency power	Electrical Room	7	1	EA	\$0	
Emergency System		Public Announcement System	Entire Building	7	112,200	SF	\$0	
Main Service		Main Electrical service - Live Front - 2000 to 3000 A 120/208/3PH	Electrical Room	4	1	EA	\$257,400	
Power Distribution		Lighting and power panels	Entire Building	5	12	EA	\$25,740	
Power Distribution		Lighting and power panels	Entire Building	6	4	EA	\$2,860	
Power Distribution		Lighting and power panels	Entire Building	4	2	EA	\$10,868	
Power Distribution		Lighting and power panels	Entire Building	7	10	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	7	2	EA	\$0	
Power Distribution		Main distribution panels above 600 amp	Electrical Room	4	3	EA	\$55,770	
ELECTRICAL Sub Total							\$395,395	

Building: Addition
Category: FIRE PROTECTION

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Fire Alarm		Fire Alarm System	Electrical Room	4	112,200	SF	\$396,302	
FIRE PROTECTION Sub Total							\$396,302	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Air Conditioning		Condensing Unit - Roof Mounted 5 to 10 tons	MDF	2	1	EA	\$22,880	Appeared to be partially disassembled and not operational
Air Conditioning		Window A/C Unit	Entire Building	5	2	EA	\$2,145	
Air Conditioning		Window A/C Unit	Entire Building	3	2	EA	\$4,290	
Air Conditioning		Window A/C Unit	Entire Building	7	8	EA	\$0	
Air Conditioning		Window A/C Unit	Entire Building	6	21	EA	\$4,505	
Air Handling Systems		Multi Zone Built Up Air Handling Unit - Steam 25,001 to 35,000 cfm	Basement	6	1	EA	\$12,870	
Air Handling Systems		Multi Zone Built Up Air Handling Unit Auxiliaries - Steam 25,001 to 35,000 cfm	Basement	5	2	EA	\$34,320	
Air Handling Systems		Reheat Boxes With Steam Coils	Basement	7	44	EA	\$0	
Air Handling Systems		Return Duct Work - Indoor - Vertical Shaft and Ducts	Basement	4	200	LF	\$357,500	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	5	3	EA	\$5,577	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	3	1	EA	\$4,147	
Heating Devices		Cabinet Heaters With Electric Coils	Entire Building	6	3	EA	\$1,502	

Building: Addition
Category: MECHANICAL

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Heating Devices		Fin Tube Hot Water	Entire Building	6	354	LF	\$6,075	
Heating Devices		Fin Tube Hot Water	Entire Building	5	540	LF	\$46,332	
Mechanical Plumbing		Condensate Assembly - Pumps and Tank	Basement	6	2	EA	\$1,430	
Mechanical Plumbing		Piping - Condensate - Steel or Galvanized	Entire Building	4	500	LF	\$48,978	
Mechanical Plumbing		Piping - Steam - Steel or Galvanized	Entire Building	5	500	LF	\$24,739	
Temperature Control		Direct Digital Control (DDC) System	Entire Building	5	112,200	SF	\$561,561	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	6	28	EA	\$4,004	
Temperature Control		Thermostats - Direct Digital Control (DDC)	Entire Building	4	28	EA	\$26,026	
Ventilation		Exhaust Fan - Indoor	Kitchen	5	1	EA	\$1,859	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	6	3	EA	\$1,287	
Ventilation		Exhaust Fans - Roof Mounted 1,501 to 8,000 cfm	Roof	5	2	EA	\$3,003	
Ventilation		Exhaust Fans - Roof Mounted 500 to 1,500 cfm	Roof	5	3	EA	\$3,861	
Ventilation		Exhaust Fans - Roof Mounted above 8,000 cfm	Roof	7	2	EA	\$0	
Ventilation		Exhaust Fans - Roof Mounted above 8,000 cfm	Roof	5	1	EA	\$6,435	
Ventilation		Type I Exhaust Hood - Kitchen or Culinary Arts	Kitchen	6	2	EA	\$3,432	
MECHANICAL Sub Total							\$1,188,756	

Building: Addition
Category: PLUMBING

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Piping		Domestic Piping - Cold Water from Risers to Fixtures	Entire Building	7	112,200	SF	\$0	
Piping		Domestic Piping - Cold Water Risers	Entire Building	7	112,200	SF	\$0	
Piping		Domestic Piping - Hot Water from Riser to fixtures	Entire Building	7	112,200	SF	\$0	
Piping		Domestic Piping - Hot Water Return Risers	Entire Building	7	112,200	SF	\$0	
Piping		Domestic Piping - Hot Water Risers	Entire Building	7	112,200	SF	\$0	
Piping		Domestic Piping Cold Water Horizontal lines	Entire Building	7	112,200	SF	\$0	
Piping		Domestic Piping Hot Water Horizontal lines	Entire Building	7	112,200	SF	\$0	
Piping		Domestic Piping Hot Water Return Lines	Entire Building	7	112,200	SF	\$0	
Piping		Sanitary Piping	Entire Building	7	112,200	SF	\$0	
Piping		Storm Piping	Entire Building	7	112,200	SF	\$0	
Piping		Vent Piping	Entire Building	7	112,200	SF	\$0	
Pumps		Ejector Pump	Basement	3	2	EA	\$60,060	Not functioning
Pumps		Sump Pump	Basement	6	2	EA	\$2,717	
PLUMBING Sub Total							\$62,777	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
-------	-----------	------	----------	------	----------	------	------	--------

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	engineers office	7	122	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	1st fl south- womens lounge	6	136	SF	\$292	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	2nd fl south- womens lounge	6	136	SF	\$292	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	3rd fl south- womens lounge	5	136	SF	\$770	water damage
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	3rd fl south- mens lounge	6	136	SF	\$292	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	Rm 114-Addition Teacher Resource Rm	6	1,510	SF	\$3,239	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	319A- in 319	6	92	SF	\$197	water damage
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 223A- resource	6	350	SF	\$751	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	asst engineers office	6	62	SF	\$133	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	kitchen managers office in kitchen	7	87	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	gym office in gym 2nd fl south	7	85	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	228- office suite	6	690	SF	\$1,480	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	328- office suite	6	690	SF	\$1,480	
Administrative Suites	Administrative Suites/Offices	Ceiling - Lay-In	rm 323A- vacant	6	364	SF	\$781	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	1st fl south- womens lounge	6	136	SF	\$194	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	319A- in 319	6	92	SF	\$132	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	228- office suite	7	690	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	328- office suite	7	690	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	engineers office	6	122	SF	\$174	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	gym office in gym 2nd fl south	7	85	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	asst engineers office	6	62	SF	\$89	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	kitchen managers office in kitchen	6	87	SF	\$124	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	3rd fl south- womens lounge	6	136	SF	\$194	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	3rd fl south- mens lounge	6	136	SF	\$194	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	2nd fl south- womens lounge	6	136	SF	\$194	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 223A- resource	6	350	SF	\$501	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	Rm 114-Addition Teacher Resource Rm	7	1,510	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Flooring - Tile/Sheet	rm 323A- vacant	6	364	SF	\$521	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 223A- resource	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	228- office suite	6	12	SF	\$9	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	328- office suite	6	12	SF	\$9	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	rm 323A- vacant	6	6	SF	\$4	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	engineers office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Lay-In	asst engineers office	7	1	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	2nd fl south- womens lounge	6	2	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	gym office in gym 2nd fl south	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	kitchen managers office in kitchen	7	2	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	Rm 114-Addition Teacher Resource Rm	7	36	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	3rd fl south- womens lounge	6	2	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	1st fl south- womens lounge	6	2	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	3rd fl south- mens lounge	6	2	SF	\$1	
Administrative Suites	Administrative Suites/Offices	Lighting - Pendant/Surface	319A- in 319	7	2	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	228- office suite	6	845	SF	\$2,417	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	engineers office	6	290	SF	\$829	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	kitchen managers office in kitchen	6	274	SF	\$784	cracking
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 323A- vacant	6	394	SF	\$1,127	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	328- office suite	6	845	SF	\$2,417	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	rm 223A- resource	6	600	SF	\$1,716	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	asst engineers office	6	267	SF	\$764	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	2nd fl south- womens lounge	6	280	SF	\$801	cracking
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	3rd fl south- mens lounge	6	280	SF	\$801	cracking
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	3rd fl south- womens lounge	6	280	SF	\$801	cracking
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	Rm 114-Addition Teacher Resource Rm	6	1,045	SF	\$2,989	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	319A- in 319	6	175	SF	\$501	
Administrative Suites	Administrative Suites/Offices	Walls - Concrete Block	1st fl south- womens lounge	6	280	SF	\$801	cracking
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	rm 323A- vacant	6	216	SF	\$510	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	328- office suite	5	100	SF	\$472	
Administrative Suites	Administrative Suites/Offices	Walls - Plaster/Drywall	228- office suite	7	50	SF	\$0	
Administrative Suites	Administrative Suites/Offices	Walls - Structural Glazed Tile	gym office in gym 2nd fl south	7	275	SF	\$0	
Doors		Interior Steel Doors incl hw	Entire Building	6	16	EA	\$4,530	
Doors		Interior Steel Doors incl hw	Entire Building	5	4	EA	\$1,888	
Doors		Interior Wood Doors incl hw	Entire Building	4	49	EA	\$157,237	
Doors		Interior Wood Doors incl hw	Entire Building	7	24	EA	\$0	
Doors		Interior Wood Doors incl hw	Entire Building	6	4	EA	\$1,133	
Doors		Interior Wood Doors incl hw	Entire Building	5	51	EA	\$24,067	
Drinking Fountains	Corridors	Single Fountain	3rd Floor	6	2	EA	\$772	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	5	6	EA	\$11,583	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Drinking Fountains	Corridors	Single Fountain	3rd Floor	5	2	EA	\$3,861	
Drinking Fountains	Corridors	Single Fountain	2nd Floor	6	2	EA	\$772	
Drinking Fountains	Corridors	Single Fountain	1st Floor	5	4	EA	\$7,722	
Drinking Fountains	Corridors	Single Fountain	1st Floor	6	2	EA	\$772	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Bleacher Seating	2nd fl south			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Ceiling - Plaster/Drywall	2nd fl south	7	5,950	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Flooring - Wood	2nd fl south	7	5,950	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Lighting - Metal Halide/Sodium Vapor	2nd fl south	6	21	EA	\$3,754	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Scoreboards	2nd fl south	5	1	EA	\$6,852	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Sound System	2nd fl south			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Stage Curtain	2nd fl south			EA	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Concrete Block	2nd fl south	7	3,538	SF	\$0	
Gymnasium / Auditorium	Standard Dedicated Gymnasium	Walls - Structural Glazed Tile	2nd fl south	6	2,051	SF	\$14,665	
Kitchen	Cooking Kitchen	Ceiling - Plaster/Drywall	1st fl south	7	1,050	SF	\$0	
Kitchen	Cooking Kitchen	Flooring - Tile Quarry	1st fl south	6	1,050	SF	\$3,619	
Kitchen	Cooking Kitchen	Lighting - Pendant/Surface	1st fl south	7	23	SF	\$0	
Kitchen	Cooking Kitchen	Wall - Structural Glazed Tile	1st fl south	7	1,730	SF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd fl womens south-inaccessible			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in asst. engineers office			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in rm 122 inaccessible not finished			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd fl mens south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl girls south			LF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl boys south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in engineers breakroom-inaccessible			LF	\$0	
Locker/Shower Room	Locker/Shower Room	Benches	in kitchen			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl womens north			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl mens south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	2nd fl womans south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	2nd fl girls south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl womens south			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl boys north			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	1st fl girls north			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	1st fl mens south			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	3rd fl mens north-inaccessible			LF	\$0	
Locker/Shower Room	Staff Restroom	Benches	in kitchen			LF	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Benches	3rd fl boys north			LF	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd fl mens south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in rm 122 inaccessible not finished			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl womens north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	3rd fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd fl mens north-inaccessible			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl mens south			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys north			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Lockers	in kitchen			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	1st fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in kitchen			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	3rd fl womens south-inaccessible			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl mens south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	2nd fl womans south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Lockers	2nd fl girls south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in asst. engineers office			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	1st fl womens south			EA	\$0	
Locker/Shower Room	Staff Restroom	Lockers	in engineers breakroom-inaccessible			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in kitchen			EA	\$0	
Locker/Shower Room	Locker/Shower Room	Showers	in kitchen			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl mens south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd fl womens south-inaccessible			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	1st fl mens south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in engineers breakroom-inaccessible			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Locker/Shower Room	Staff Restroom	Showers	1st fl womens south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl womans south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd fl mens south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in rm 122 inaccessible not finished			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	2nd fl womens north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys north			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls north			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	in asst. engineers office			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	1st fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl girls south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	2nd fl boys south			EA	\$0	
Locker/Shower Room	Children's Standard Student Restroom	Showers	3rd fl boys south			EA	\$0	
Locker/Shower Room	Staff Restroom	Showers	3rd fl mens north-inaccessible			EA	\$0	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	engineers breakroom	6	85	SF	\$182	
Lunchroom	Lunchroom	Ceiling - Lay-In	kitchen staff lunch room in kitchen	6	330	SF	\$708	
Lunchroom	Multipurpose Room	Ceiling - Lay-In	5 practice rooms in rm 319 (combined total)	6	250	SF	\$536	
Lunchroom	Multipurpose Room	Ceiling - Plaster/Drywall	dishing washing room 1st fl south	6	230	SF	\$651	
Lunchroom	Multipurpose Room	Ceiling - Plaster/Drywall	servery	6	1,007	SF	\$2,851	
Lunchroom	Lunchroom	Ceiling - Splined	1st fl south	6	4,762	SF	\$10,214	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	5 practice rooms in rm 319 (combined total)	6	250	SF	\$358	
Lunchroom	Multipurpose Room	Flooring - Tile/Sheet	engineers breakroom	6	85	SF	\$122	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	kitchen staff lunch room in kitchen	6	330	SF	\$472	
Lunchroom	Lunchroom	Flooring - Tile/Sheet	1st fl south	7	4,762	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Lay-In	5 practice rooms in rm 319 (combined total)	6	5	SF	\$4	
Lunchroom	Multipurpose Room	Lighting - Lay-In	engineers breakroom	7	1	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	servery	6	20	SF	\$14	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	servery	7	30	SF	\$0	
Lunchroom	Multipurpose Room	Lighting - Pendant/Surface	dishing washing room 1st fl south	7	4	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	1st fl south	7	96	SF	\$0	
Lunchroom	Lunchroom	Lighting - Pendant/Surface	kitchen staff lunch room in kitchen	7	6	SF	\$0	
Lunchroom	Lunchroom	Serving Line	1st fl south	7	13	LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	5 practice rooms in rm 319 (combined total)			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	engineers breakroom	6	10	LF	\$429	
Lunchroom	Cooking Kitchen	Serving Line	1st fl south			LF	\$0	
Lunchroom	Lunchroom	Serving Line	kitchen staff lunch room in kitchen			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	dishing washing room 1st fl south			LF	\$0	
Lunchroom	Multipurpose Room	Serving Line	servery	7	70	LF	\$0	
Lunchroom	Multipurpose Room	Wall - Concrete Block	engineers breakroom	6	220	SF	\$629	
Lunchroom	Lunchroom	Wall - Concrete Block	kitchen staff lunch room in kitchen	6	626	SF	\$1,790	cracking
Lunchroom	Lunchroom	Wall - Concrete Block	1st fl south	7	500	SF	\$0	
Lunchroom	Multipurpose Room	Wall - Plaster/Drywall	5 practice rooms in rm 319 (combined total)	6	965	SF	\$2,277	
Lunchroom	Multipurpose Room	Wall - Structural Glazed Tile	servery	7	851	SF	\$0	
Lunchroom	Lunchroom	Wall - Structural Glazed Tile	1st fl south	6	1,540	SF	\$11,011	
Lunchroom	Multipurpose Room	Wall - Structural Glazed Tile	dishing washing room 1st fl south	7	153	SF	\$0	
MDF/IDF		Finishes	in 320	6	165	SF	\$562	
MDF/IDF		Ventilation and Cooling	in 320	7	1	EA	\$0	
Mechanical/Service Rooms		Janitor's Closet	Entire Building	6	6	SF	\$28	
Mechanical/Service Rooms		Mechanical/Service Rooms	Basement	6	7,100	SF	\$33,505	
Mechanical/Service Rooms		Mechanical/Service Rooms	1st fl rm 128	6	690	SF	\$3,256	
Mechanical/Service Rooms		Storage Room	rm 114- marked lounge-storage	6	1,521	SF	\$7,178	
Mechanical/Service Rooms		Storage Room	all storage rooms off hallways, in kitchen, and classrooms	6	3,299	SF	\$15,568	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys south	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Accessories	3rd fl womens south-inaccessible	6	84	SF	\$649	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl boys north	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Accessories	2nd fl womens north	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls north	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Accessories	3rd fl mens south	5	84	SF	\$2,141	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys south	6	220	SF	\$1,699	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl girls south	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Accessories	in rm 122 inaccessible not finished			SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys south	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Accessories	in kitchen	6	35	SF	\$270	
Staff Restroom	Locker/Shower Room	Accessories	in kitchen	6	35	SF	\$270	
Staff Restroom	Staff Restroom	Accessories	in asst. engineers office	6	62	SF	\$479	
Staff Restroom	Staff Restroom	Accessories	2nd fl mens south	7	84	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	2nd fl womans south	6	84	SF	\$649	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls north	6	220	SF	\$1,699	
Staff Restroom	Children's Standard Student Restroom	Accessories	2nd fl girls south	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Accessories	1st fl womens south	6	84	SF	\$649	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl boys north	6	220	SF	\$1,699	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls north	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Accessories	1st fl mens south	7	84	SF	\$0	
Staff Restroom	Staff Restroom	Accessories	3rd fl mens north-inaccessible	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Accessories	1st fl girls south	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Accessories	in engineers breakroom-inaccessible	6	62	SF	\$479	
Staff Restroom	Children's Standard Student Restroom	Accessories	3rd fl boys north	6	220	SF	\$1,699	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd fl womens north	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd fl mens south	6	84	SF	\$180	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd fl mens south	6	220	SF	\$472	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	2nd fl womans south	5	84	SF	\$476	water damage- moldy

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl womens south	6	84	SF	\$180	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd fl womens south-inaccessible	5	84	SF	\$476	water damage- moldy
Staff Restroom	Staff Restroom	Ceiling - Lay-In	1st fl mens south	6	220	SF	\$472	
Staff Restroom	Staff Restroom	Ceiling - Lay-In	3rd fl mens north-inaccessible	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys north	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys south	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls north	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls south	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl girls north	6	220	SF	\$623	
Staff Restroom	Locker/Shower Room	Ceiling - Plaster/Drywall	in kitchen	7	35	SF	\$0	
Staff Restroom	Staff Restroom	Ceiling - Plaster/Drywall	in kitchen	7	35	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys south	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	2nd fl boys north	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl boys north	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls north	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl girls south	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	1st fl boys south	6	220	SF	\$623	
Staff Restroom	Children's Standard Student Restroom	Ceiling - Plaster/Drywall	3rd fl girls south	6	220	SF	\$623	
Staff Restroom	Staff Restroom	Floor Drain	3rd fl womens south-inaccessible			EA	\$0	
Staff Restroom	Locker/Shower Room	Floor Drain	in kitchen			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in asst. engineers office			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl mens south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl womans south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl girls south	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl womens south			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in kitchen			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in engineers breakroom-inaccessible			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl boys south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd fl mens south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	in rm 122 inaccessible not finished			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	3rd fl girls north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	2nd fl boys north	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	2nd fl womens north			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	3rd fl mens north-inaccessible			EA	\$0	
Staff Restroom	Staff Restroom	Floor Drain	1st fl mens south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl girls south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Floor Drain	1st fl boys north	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls south	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys south	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls south	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl girls north	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys south	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys south	6	220	SF	\$560	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl womens north	7	60	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	2nd fl boys north	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl boys north	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl girls north	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls south	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl boys north	6	220	SF	\$560	
Staff Restroom	Children's Standard Student Restroom	Flooring - Tile Ceramic/Porcelain	1st fl girls north	6	220	SF	\$560	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	1st fl mens south	7	90	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile Ceramic/Porcelain	3rd fl mens north-inaccessible	7	60	SF	\$0	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd fl womans south	6	84	SF	\$120	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st fl mens south	6	130	SF	\$186	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	3rd fl womens south-inaccessible	6	84	SF	\$120	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	1st fl womens south	6	84	SF	\$120	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in asst. engineers office	6	62	SF	\$89	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	2nd fl mens south	6	220	SF	\$315	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	3rd fl mens south	6	84	SF	\$120	
Staff Restroom	Staff Restroom	Flooring - Tile/Sheet	in engineers breakroom-inaccessible	6	62	SF	\$89	
Staff Restroom	Staff Restroom	Hand Dryer	3rd fl mens north-inaccessible			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in asst. engineers office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd fl womens south-inaccessible			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	3rd fl mens south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl womens south			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in engineers breakroom-inaccessible			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls south	6	1	EA	\$217	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl girls north	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls south	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	1st fl mens south	7	1	EA	\$0	
Staff Restroom	Locker/Shower Room	Hand Dryer	in kitchen			EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in kitchen			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl boys south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys south	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl womens north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys south	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl womans south			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	2nd fl boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	2nd fl mens south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Hand Dryer	in rm 122 inaccessible not finished			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	1st fl girls south	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl girls north	6	1	EA	\$217	
Staff Restroom	Children's Standard Student Restroom	Hand Dryer	3rd fl boys north	6	1	EA	\$217	
Staff Restroom	Staff Restroom	Lavatory	in asst. engineers office	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys north	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	2nd fl mens south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl womans south	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	in kitchen	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys south	6	3	EA	\$1,115	
Staff Restroom	Staff Restroom	Lavatory	3rd fl mens south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls south	6	4	EA	\$1,487	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl girls north	6	4	EA	\$1,487	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys south	5	1	EA	\$1,859	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys south	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys south	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	in rm 122 inaccessible not finished			EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	2nd fl womens north	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys north	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys north	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys north	6	3	EA	\$1,115	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls south	6	4	EA	\$1,487	
Staff Restroom	Children's Standard Student Restroom	Lavatory	3rd fl boys south	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Lavatory	1st fl mens south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd fl mens north-inaccessible	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl boys north	7	4	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Lavatory	1st fl girls north	6	4	EA	\$1,487	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl boys south	6	3	EA	\$1,115	
Staff Restroom	Staff Restroom	Lavatory	3rd fl womens south-inaccessible	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	3rd fl womens south-inaccessible	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lavatory	1st fl womens south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	1st fl womens south	6	1	EA	\$372	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls south	6	4	EA	\$1,487	
Staff Restroom	Children's Standard Student Restroom	Lavatory	2nd fl girls north	6	4	EA	\$1,487	
Staff Restroom	Staff Restroom	Lavatory	2nd fl womans south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Lavatory	in engineers breakroom-inaccessible	6	1	EA	\$372	
Staff Restroom	Staff Restroom	Lighting - Lay-In	3rd fl mens north-inaccessible	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	1st fl womens south	6	2	SF	\$1	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Lighting - Lay-In	in engineers breakroom-inaccessible	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	in asst. engineers office	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Lay-In	2nd fl womens north	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	1st fl mens south	6	4	SF	\$3	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl girls north	6	2	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl boys north	4	2	SF	\$9	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd fl womans south	6	2	SF	\$1	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	2nd fl mens south	6	4	SF	\$3	
Staff Restroom	Locker/Shower Room	Lighting - Pendant/ Surface	in kitchen	7	1	SF	\$0	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	in kitchen	7	1	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	1st fl boys south	4	2	SF	\$9	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl boys south	4	2	SF	\$9	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl boys south	4	2	SF	\$9	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd fl mens south	6	2	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	3rd fl boys north	4	2	SF	\$9	
Staff Restroom	Children's Standard Student Restroom	Lighting - Pendant/ Surface	2nd fl boys north	4	2	SF	\$9	
Staff Restroom	Staff Restroom	Lighting - Pendant/ Surface	3rd fl womens south-inaccessible	6	2	SF	\$1	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls south	7	6	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in kitchen			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd fl mens south	6	1	EA	\$179	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl girls north	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd fl womens south-inaccessible	6	3	EA	\$538	
Staff Restroom	Staff Restroom	Partitions	1st fl womens south	6	3	EA	\$538	
Staff Restroom	Staff Restroom	Partitions	in engineers breakroom-inaccessible			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	in asst. engineers office			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls south	7	6	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl girls north	7	6	EA	\$0	
Staff Restroom	Locker/Shower Room	Partitions	in kitchen			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	1st fl boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl womens north			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	3rd fl mens north-inaccessible			EA	\$0	
Staff Restroom	Staff Restroom	Partitions	2nd fl womans south	6	3	EA	\$538	
Staff Restroom	Staff Restroom	Partitions	in rm 122 inaccessible not finished			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	2nd fl boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls north	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl girls south	7	6	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Partitions	3rd fl boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Urinals	2nd fl womans south	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Urinals	in kitchen			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys north	6	5	EA	\$1,859	
Staff Restroom	Staff Restroom	Urinals	3rd fl mens south	6	2	EA	\$744	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys south	6	5	EA	\$1,859	
Staff Restroom	Staff Restroom	Urinals	2nd fl womens north			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys south	6	5	EA	\$1,859	
Staff Restroom	Locker/Shower Room	Urinals	in kitchen			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	3rd fl boys north	6	5	EA	\$1,859	
Staff Restroom	Staff Restroom	Urinals	3rd fl womens south-inaccessible	6	2	EA	\$744	
Staff Restroom	Staff Restroom	Urinals	in rm 122 inaccessible not finished			EA	\$0	
Staff Restroom	Staff Restroom	Urinals	3rd fl mens north-inaccessible			EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Urinals	2nd fl boys south	6	5	EA	\$1,859	
Staff Restroom	Staff Restroom	Urinals	in engineers breakroom-inaccessible	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Urinals	1st fl boys north	6	5	EA	\$1,859	
Staff Restroom	Staff Restroom	Urinals	in asst. engineers office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st fl mens south	6	430	SF	\$1,230	
Staff Restroom	Staff Restroom	Wall - Concrete Block	3rd fl mens north-inaccessible	7	219	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	3rd fl womens south-inaccessible	6	330	SF	\$944	
Staff Restroom	Staff Restroom	Wall - Concrete Block	1st fl womens south	6	330	SF	\$944	
Staff Restroom	Staff Restroom	Wall - Concrete Block	2nd fl womans south	6	330	SF	\$944	
Staff Restroom	Staff Restroom	Wall - Concrete Block	2nd fl womens north	7	219	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in engineers breakroom-inaccessible	6	267	SF	\$764	
Staff Restroom	Staff Restroom	Wall - Concrete Block	in asst. engineers office	6	267	SF	\$764	
Staff Restroom	Staff Restroom	Wall - Concrete Block	3rd fl mens south	6	330	SF	\$944	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys south	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl boys north	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl boys north	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl girls north	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls south	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl girls north	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys south	7	520	SF	\$0	
Staff Restroom	Staff Restroom	Wall - Structural Glazed Tile	in kitchen	7	209	SF	\$0	
Staff Restroom	Locker/Shower Room	Wall - Structural Glazed Tile	in kitchen	7	209	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls north	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	2nd fl girls south	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	1st fl boys north	7	520	SF	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl boys south	7	520	SF	\$0	
Staff Restroom	Children's Standard Student Restroom	Wall - Structural Glazed Tile	3rd fl girls south	7	520	SF	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl mens south	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls south	6	6	EA	\$2,231	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl girls north	6	6	EA	\$2,231	
Staff Restroom	Staff Restroom	Water Closet	in kitchen	7	1	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls south	6	6	EA	\$2,231	
Staff Restroom	Staff Restroom	Water Closet	3rd fl mens south	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	3rd fl boys south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl womans south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys south	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls south	6	6	EA	\$2,231	
Staff Restroom	Staff Restroom	Water Closet	2nd fl womans south	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl girls north	6	6	EA	\$2,231	
Staff Restroom	Staff Restroom	Water Closet	in asst. engineers office	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	in engineers breakroom-inaccessible	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	1st fl womens south	5	1	EA	\$1,859	
Staff Restroom	Staff Restroom	Water Closet	1st fl womens south	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd fl womens south-inaccessible	5	1	EA	\$1,859	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl boys north	7	2	EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	1st fl girls north	6	6	EA	\$2,231	
Staff Restroom	Staff Restroom	Water Closet	1st fl mens south	7	1	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd fl mens north-inaccessible	7	1	EA	\$0	

Building: Addition
Category: INTERIOR

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Staff Restroom	Staff Restroom	Water Closet	in rm 122 inaccessible not finished			EA	\$0	
Staff Restroom	Children's Standard Student Restroom	Water Closet	2nd fl boys north	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	3rd fl womens south-inaccessible	7	2	EA	\$0	
Staff Restroom	Staff Restroom	Water Closet	2nd fl womens north	7	1	EA	\$0	
Vocational Shop	Classroom	Work Sink		5	1	EA	\$1,931	
Vocational Shop	Classroom	Work Sink		6	3	EA	\$1,158	
INTERIOR Sub Total							\$484,084	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	328- office suite	6	416	SF	\$982	
ADMIN_WALL	Administrative Suites/Offices	Administrative Office Walls	228- office suite	6	504	SF	\$1,189	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	24	LF	\$858	
Casework	Classroom	Casework		6	24	LF	\$858	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	31	LF	\$1,108	
Casework	Classroom	Casework		6	36	LF	\$1,287	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	36	LF	\$1,287	
Casework	Classroom	Casework		6	44	LF	\$1,573	
Casework	Classroom	Casework		6	18	LF	\$644	
Casework	Classroom	Casework		6	18	LF	\$644	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	8	LF	\$286	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	67	LF	\$2,395	
Casework	Classroom	Casework		6	55	LF	\$1,966	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	31	LF	\$1,108	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		7	28	LF	\$0	
Casework	Classroom	Casework				LF	\$0	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	10	LF	\$358	
Casework	Classroom	Casework		6	14	LF	\$501	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	30	LF	\$1,073	
Casework	Classroom	Casework		6	14	LF	\$501	
Ceiling	Classroom	Lay-In/Drop		6	1,077	SF	\$2,310	
Ceiling	Classroom	Lay-In/Drop		6	500	SF	\$1,073	
Ceiling	Classroom	Lay-In/Drop		6	1,077	SF	\$2,310	
Ceiling	Classroom	Lay-In/Drop		6	924	SF	\$1,982	
Ceiling	Classroom	Lay-In/Drop		6	1,610	SF	\$3,453	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	1,302	SF	\$2,793	
Ceiling	Classroom	Lay-In/Drop		6	1,610	SF	\$3,453	
Ceiling	Classroom	Lay-In/Drop		7	882	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	720	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		7	720	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	541	SF	\$1,160	
Ceiling	Classroom	Lay-In/Drop		6	541	SF	\$1,160	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	1,077	SF	\$2,310	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Ceiling	Classroom	Lay-In/Drop		6	1,610	SF	\$3,453	
Ceiling	Classroom	Lay-In/Drop		7	1,225	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	924	SF	\$1,982	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	1,077	SF	\$2,310	
Ceiling	Classroom	Lay-In/Drop		6	500	SF	\$1,073	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	1,077	SF	\$2,310	
Ceiling	Classroom	Lay-In/Drop		6	1,928	SF	\$4,136	
Ceiling	Classroom	Lay-In/Drop		7	720	SF	\$0	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	500	SF	\$1,073	
Ceiling	Classroom	Lay-In/Drop		6	360	SF	\$772	
Ceiling	Classroom	Lay-In/Drop		6	360	SF	\$772	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	1,077	SF	\$2,310	
Ceiling	Classroom	Lay-In/Drop		6	685	SF	\$1,469	
Ceiling	Classroom	Lay-In/Drop		6	685	SF	\$1,469	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Ceiling	Classroom	Lay-In/Drop		6	720	SF	\$1,544	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Multipurpose Room	Chalk Board	dishing washing room 1st fl south	4		LF		
Chalk Board	Multipurpose Room	Chalk Board	5 practice rooms in rm 319 (combined total)	4		LF		
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	10	LF	\$1,216	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	6	LF	\$729	
Chalk Board	Classroom	Chalk Board		4	4	LF	\$486	
Chalk Board	Classroom	Chalk Board		4	28	LF	\$3,403	
Chalk Board	Multipurpose Room	Chalk Board	engineers breakroom	4		LF		

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Chalk Board	Lunchroom	Chalk Board	kitchen staff lunch room in kitchen	4		LF		
Chalk Board	Multipurpose Room	Chalk Board	servery	4		LF		
Chalk Board	Classroom	Chalk Board		4		LF		
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	14	LF	\$1,702	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	16	LF	\$1,945	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	8	LF	\$972	
Chalk Board	Classroom	Chalk Board		4	32	LF	\$3,890	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Chalk Board	Classroom	Chalk Board		4	12	LF	\$1,459	
Chalk Board	Lunchroom	Chalk Board	1st fl south	4		LF		
Chalk Board	Classroom	Chalk Board		4	20	LF	\$2,431	
Corridors	Corridors	Concrete Block	Stair 1	7	510	SF	\$0	
Corridors	Corridors	Concrete Block	3rd Floor	6	2,300	SF	\$6,578	
Corridors	Corridors	Concrete Block	Stair 4	7	510	SF	\$0	
Corridors	Corridors	Concrete Block	1st Floor	6	2,300	SF	\$6,578	
Corridors	Corridors	Concrete Block	to boiler room	6	435	SF	\$1,244	
Corridors	Corridors	Concrete Block	2nd Floor	6	2,300	SF	\$6,578	
Corridors	Corridors	Drinking Fountains	Stair 3			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 2			EA	\$0	
Corridors	Corridors	Drinking Fountains	to boiler room			EA	\$0	
Corridors	Corridors	Drinking Fountains	NW Vestibule			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 1			EA	\$0	
Corridors	Corridors	Drinking Fountains	Stair 4			EA	\$0	
Corridors	Corridors	Drop/Lay-In	Stair 2	6	177	SF	\$380	
Corridors	Corridors	Drop/Lay-In	Stair 3	6	177	SF	\$380	
Corridors	Corridors	Drop/Lay-In	to boiler room	6	310	SF	\$665	
Corridors	Corridors	Drop/Lay-In	1st Floor	6	7,700	SF	\$16,517	
Corridors	Corridors	Drop/Lay-In	2nd Floor	6	7,700	SF	\$16,517	
Corridors	Corridors	Drop/Lay-In	3rd Floor	6	7,700	SF	\$16,517	
Corridors	Corridors	Drop/Lay-In	Stair 1	6	366	SF	\$785	
Corridors	Corridors	Drop/Lay-In	Stair 4	6	366	SF	\$785	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Lay-In	2nd Floor	7	7,700	EA	\$0	
Corridors	Corridors	Lay-In	to boiler room	6	310	EA	\$222	
Corridors	Corridors	Lay-In	3rd Floor	7	7,700	EA	\$0	
Corridors	Corridors	Lay-In	1st Floor	7	7,700	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 2	7	289	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 4	7	355	EA	\$0	
Corridors	Corridors	Pendant/Surface	NW Vestibule	7	83	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 1	7	355	EA	\$0	
Corridors	Corridors	Pendant/Surface	Stair 3	7	289	EA	\$0	
Corridors	Corridors	Single Water Cooler	1st Floor	7	2	EA	\$0	
Corridors	Corridors	Stair Handrails	1st Floor	6	30	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 1	6	107	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 4	6	107	LF	\$0	
Corridors	Corridors	Stair Handrails	2nd Floor	6	30	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 2	6	103	LF	\$0	
Corridors	Corridors	Stair Handrails	Stair 3	6	103	LF	\$0	
Corridors	Corridors	Stair Handrails	to boiler room			LF	\$0	
Corridors	Corridors	Stair Handrails	NW Vestibule			LF	\$0	
Corridors	Corridors	Stair Handrails	3rd Floor	6	30	LF	\$0	
Corridors	Corridors	Stairs	NW Vestibule			EA	\$0	
Corridors	Corridors	Stairs	Stair 1	6	40	EA	\$286	
Corridors	Corridors	Stairs	Stair 4	6	40	EA	\$286	
Corridors	Corridors	Stairs	to boiler room			EA	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 2	7	950	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 4	7	1,190	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	1st Floor	7	5,860	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	2nd Floor	7	5,860	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	3rd Floor	7	5,860	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	NW Vestibule	7	80	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 1	7	1,190	SF	\$0	
Corridors	Corridors	Structural Glazed Tile	Stair 3	7	950	SF	\$0	
Corridors	Corridors	Student Lockers	Stair 1			EA	\$0	
Corridors	Corridors	Student Lockers	NW Vestibule			EA	\$0	
Corridors	Corridors	Student Lockers	3rd Floor	5	624	EA	\$111,540	
Corridors	Corridors	Student Lockers	2nd Floor	7	410	EA	\$0	
Corridors	Corridors	Student Lockers	1st Floor	7	440	EA	\$0	
Corridors	Corridors	Student Lockers	Stair 4			EA	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Corridors	Corridors	Student Lockers	Stair 2			EA	\$0	
Corridors	Corridors	Student Lockers	Stair 3			EA	\$0	
Corridors	Corridors	Student Lockers	to boiler room			EA	\$0	
Corridors	Corridors	Terrazzo	Stair 1	6	547	SF	\$3,098	
Corridors	Corridors	Terrazzo	Stair 2	7	166	SF	\$0	
Corridors	Corridors	Terrazzo	Stair 4	6	547	SF	\$3,098	
Corridors	Corridors	Terrazzo	Stair 3	7	166	SF	\$0	
Corridors	Corridors	Tile Ceramic/Porcelain	NW Vestibule	6	83	SF	\$211	
Corridors	Corridors	Tile/Sheet Flooring	1st Floor	6	7,700	SF	\$11,011	
Corridors	Corridors	Tile/Sheet Flooring	3rd Floor	6	7,700	SF	\$11,011	
Corridors	Corridors	Tile/Sheet Flooring	2nd Floor	6	7,700	SF	\$11,011	
Corridors	Corridors	Tile/Sheet Flooring	to boiler room	6	310	SF	\$443	
Corridors	Corridors	Walls	to boiler room	6	96	SF	\$227	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 2	6	122	SF	\$345	
Corridors Ceiling	Corridors	Plaster/Drywall	NW Vestibule	7	83	SF	\$0	
Corridors Ceiling	Corridors	Plaster/Drywall	Stair 3	6	122	SF	\$345	
Stairs	Corridors	Terrazzo	Stair 3	7	41	SF	\$0	
Stairs	Corridors	Terrazzo	Stair 2	7	41	SF	\$0	
Stairs	Corridors	Terrazzo	2nd Floor	6	12	SF	\$136	
Stairs	Corridors	Terrazzo	3rd Floor	6	12	SF	\$136	
Stairs	Corridors	Terrazzo	1st Floor	6	12	SF	\$136	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	924	SF	\$1,321	
Floor	Classroom	Tile/Sheet		6	1,610	SF	\$2,302	
Floor	Classroom	Tile/Sheet		6	1,077	SF	\$1,540	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	541	SF	\$774	
Floor	Classroom	Tile/Sheet		6	541	SF	\$774	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		7	720	SF	\$0	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		7	1,928	SF	\$0	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	360	SF	\$515	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Floor	Classroom	Tile/Sheet		6	360	SF	\$515	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	1,302	SF	\$1,862	
Floor	Classroom	Tile/Sheet		6	500	SF	\$715	
Floor	Classroom	Tile/Sheet		6	685	SF	\$980	
Floor	Classroom	Tile/Sheet		7	1,225	SF	\$0	
Floor	Classroom	Tile/Sheet		7	882	SF	\$0	
Floor	Classroom	Tile/Sheet		6	1,077	SF	\$1,540	
Floor	Classroom	Tile/Sheet		7	720	SF	\$0	
Floor	Classroom	Tile/Sheet		6	685	SF	\$980	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		7	1,077	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,610	SF	\$0	
Floor	Classroom	Tile/Sheet		6	1,077	SF	\$1,540	
Floor	Classroom	Tile/Sheet		7	720	SF	\$0	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	500	SF	\$715	
Floor	Classroom	Tile/Sheet		7	720	SF	\$0	
Floor	Classroom	Tile/Sheet		7	1,610	SF	\$0	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	1,077	SF	\$1,540	
Floor	Classroom	Tile/Sheet		6	1,077	SF	\$1,540	
Floor	Classroom	Tile/Sheet		6	500	SF	\$715	
Floor	Classroom	Tile/Sheet		6	720	SF	\$1,030	
Floor	Classroom	Tile/Sheet		6	924	SF	\$1,321	
Lighting	Classroom	Lay-In		6	25	EA	\$1,788	
Lighting	Classroom	Lay-In		7	9	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	24	EA	\$1,716	
Lighting	Classroom	Lay-In		6	16	EA	\$1,144	
Lighting	Classroom	Lay-In		6	28	EA	\$2,002	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	16	EA	\$1,144	
Lighting	Classroom	Lay-In		6	24	EA	\$1,716	
Lighting	Classroom	Lay-In		7	9	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Lighting	Classroom	Lay-In		7	9	EA	\$0	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	9	EA	\$644	
Lighting	Classroom	Lay-In		6	9	EA	\$644	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lay-In		6	24	EA	\$1,716	
Lighting	Classroom	Lay-In		6	12	EA	\$858	
Lighting	Classroom	Lighting		6	12	EA	\$1,115	
Lighting	Classroom	Lighting		6	12	EA	\$1,115	
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287	
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287	
Lighting	Classroom	Pendant/Surface		6	20	EA	\$1,430	
Lighting	Classroom	Pendant/Surface		6	9	EA	\$644	
Lighting	Classroom	Pendant/Surface		6	9	EA	\$644	
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287	
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287	
Lighting	Classroom	Pendant/Surface		6	44	EA	\$3,146	
Lighting	Classroom	Pendant/Surface		6	20	EA	\$1,430	
Lighting	Classroom	Pendant/Surface		6	16	EA	\$1,144	
Lighting	Classroom	Pendant/Surface		7	35	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	33	EA	\$0	
Lighting	Classroom	Pendant/Surface		7	21	EA	\$0	
Lighting	Classroom	Pendant/Surface		6	30	EA	\$2,145	
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287	
Lighting	Classroom	Pendant/Surface		6	18	EA	\$1,287	
LUNCH_FLOOR	Multipurpose Room	Lunchroom Floor	servery	7	1,007	SF	\$0	
LUNCH_FLOOR	Multipurpose Room	Lunchroom Floor	dishing washing room 1st fl south	7	230	SF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Multipurpose Room	Marker Board	5 practice rooms in rm 319 (combined total)			LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	4	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Multipurpose Room	Marker Board	engineers breakroom			LF	\$0	
Marker Board	Classroom	Marker Board		7	30	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Lunchroom	Marker Board	kitchen staff lunch room in kitchen			LF	\$0	
Marker Board	Multipurpose Room	Marker Board	servery			LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Multipurpose Room	Marker Board	dishing washing room 1st fl south			LF	\$0	
Marker Board	Lunchroom	Marker Board	1st fl south			LF	\$0	
Marker Board	Classroom	Marker Board		7	12	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	32	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	20	LF	\$0	
Marker Board	Classroom	Marker Board		7	16	LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	
Marker Board	Classroom	Marker Board				LF	\$0	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Marker Board	Classroom	Marker Board		7	26	LF	\$0	
Marker Board	Classroom	Marker Board		7	24	LF	\$0	
Marker Board	Classroom	Marker Board		7	32	LF	\$0	
Marker Board	Classroom	Marker Board		7	36	LF	\$0	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	in rm 122 inaccessible not finished		35	SF	\$0	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	in engineers breakroom-inaccessible		62	SF	\$0	
RESTROOM_CEILING	Staff Restroom	Restroom Ceiling	in asst. engineers office		62	SF	\$0	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	in rm 122 inaccessible not finished		35	SF	\$0	
RESTROOM_FLOOR	Staff Restroom	Restroom Floor	in kitchen	7	35	SF	\$0	
RESTROOM_FLOOR	Locker/Shower Room	Restroom Floor	in kitchen	7	35	SF	\$0	
RESTROOM_LIGHT	Staff Restroom	Restroom Lighting	in rm 122 inaccessible not finished			EA	\$0	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	3rd fl girls north	6	2	EA	\$57	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	1st fl girls south	6	2	EA	\$57	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	3rd fl girls south	6	2	EA	\$57	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2nd fl girls north	6	2	EA	\$57	
RESTROOM_LIGHT	Children's Standard Student Restroom	Restroom Lighting	2nd fl girls south	6	2	EA	\$57	
RESTROOM_WALL	Staff Restroom	Restroom Walls	in rm 122 inaccessible not finished			SF	\$0	
RESTROOM_WALL	Staff Restroom	Restroom Walls	2nd fl mens south	6	430	SF	\$1,095	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	551	SF	\$1,576	
Wall	Classroom	Concrete Block		7	947	SF	\$0	
Wall	Classroom	Concrete Block		7	1,090	SF	\$0	
Wall	Classroom	Concrete Block		6	680	SF	\$1,945	
Wall	Classroom	Concrete Block		6	435	SF	\$1,244	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	966	SF	\$2,763	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		7	777	SF	\$0	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Concrete Block		6	435	SF	\$1,244	
Wall	Classroom	Concrete Block		6	551	SF	\$1,576	
Wall	Classroom	Concrete Block		6	1,355	SF	\$3,875	
Wall	Classroom	Concrete Block		6	551	SF	\$1,576	
Wall	Classroom	Concrete Block		6	375	SF	\$1,073	
Wall	Classroom	Concrete Block		6	617	SF	\$1,765	
Wall	Classroom	Concrete Block		5	150	SF	\$1,133	cracking
Wall	Classroom	Concrete Block		6	375	SF	\$1,073	
Wall	Classroom	Concrete Block		6	551	SF	\$1,576	
Wall	Classroom	Concrete Block		6	435	SF	\$1,244	
Wall	Classroom	Concrete Block		6	966	SF	\$2,763	
Wall	Classroom	Concrete Block		6	966	SF	\$2,763	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	966	SF	\$2,763	
Wall	Classroom	Concrete Block		6	836	SF	\$2,391	
Wall	Classroom	Concrete Block		6	702	SF	\$2,008	
Wall	Classroom	Concrete Block		6	1,126	SF	\$3,220	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	702	SF	\$2,008	
Wall	Classroom	Concrete Block		6	468	SF	\$1,338	
Wall	Classroom	Concrete Block		6	966	SF	\$2,763	
Wall	Classroom	Concrete Block		6	1,126	SF	\$3,220	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	468	SF	\$1,338	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Concrete Block		6	966	SF	\$2,763	
Wall	Classroom	Concrete Block		6	551	SF	\$1,576	
Wall	Classroom	Concrete Block		6	767	SF	\$2,194	
Wall	Classroom	Metal/Folding Panel		6	120	SF	\$283	
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	
Wall	Classroom	Plaster/Drywall		7	290	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	216	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	

Building: Addition
Category: ROOM

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	
Wall	Classroom	Plaster/Drywall		7	216	SF	\$0	
Wall	Classroom	Plaster/Drywall		7	216	SF	\$0	
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	
Wall	Classroom	Plaster/Drywall		6	100	SF	\$236	
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	
Wall	Classroom	Plaster/Drywall		6	216	SF	\$510	
Wall	Classroom	Structural Glazed Tile		7	29	SF	\$0	
ROOM Sub Total							\$532,034	
Building Addition Sub Total							\$4,655,207	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Civil/Drainage		Catch Basin	Entire Site	7	7	EA	\$0	
Civil/Drainage		Catch Basin	North Courtyard	5	1	EA	\$1,216	backs up
Civil/Drainage		Site Drain	Entire Site	7	13	EA	\$0	
Fencing		Chain Link	trash enclosure and S of parking lot	7	619	LF	\$0	
Fencing		Ornamental Iron	S sidewalk	4	8	LF	\$1,510	missing gate
Fencing		Ornamental Iron	Entire Site	5	1,092	LF	\$68,022	rusty, peeling paint, post caps missing
Landscape		Asphalt Play Area/Hardscape	Site - East	6	5,000	SF	\$4,290	cracks
Landscape		Benches	S of playlot	5	1	EA	\$779	melted, missing slats
Landscape		Benches	Entire Site	7	7	EA	\$0	
Landscape		Grass	site- SW	7	32,515	SF	\$0	
Landscape		Hardscape - Concrete	Courtyard	5	2,930	SF	\$18,268	cracks, uneven
Landscape		Hardscape - Concrete	E and W site	6	6,030	SF	\$11,382	
Landscape		Hardscape - Concrete	W of S addition	5	50	SF	\$312	uneven
Landscape		Irrigation	SW grass field	5	26,625	SF	\$50,257	heads broken
Landscape		Parkway trees	Entire Site	7	52	EA	\$0	
Landscape		Planting Beds/ Areas	SW of trash enclosure	6	955	SF	\$0	missing plants
Landscape		Planting Beds/ Areas	Site - East	5	3,549	SF	\$0	railroad ties shifting
Landscape		Retaining Wall - Concrete	W of trash enclosure	7	87	SF	\$0	
Landscape		Trash Receptacles	Site i North	6	1	EA	\$208	

Building: SITE
Category: SITE

Group	Sub Group	Item	Location	Rank	Quantity	Unit	Cost	Reason
Parking Lot		Asphalt	E and W lots	6	18,650	SF	\$16,002	cracks
Parking Lot		Concrete	middle parking lot	7	7,971	SF	\$0	
Parking Lot		Concrete Curbs	Site 2 West	5	58	LF	\$1,156	cracking, crumbling
Parking Lot		Concrete Curbs	Entire Building	7	359	LF	\$0	
Parking Lot		Parking lot interior plantings	site- NW	7	6	LF	\$0	
Parking Lot		Trash Enclosure	SW of parking lot	6	646	SF	\$6,928	
Parking Lot		Vehicular Screening	N of parking lot	7	207	LF	\$0	
Playground		Playground Equipment - Pre-K 3-5	site- NE	5	1	EA	\$0	missing components
Playground		Playground Surfacing - Poured Surface	site- NE	6	1,519	SF	\$4,019	patched areas at removed equipment
Sidewalks		Perimeter Sidewalks	NW corner of building and N driveway	4	210	SF	\$3,964	cracked, crumbling
Sidewalks		Perimeter Sidewalks	Entire Building	7	13,100	SF	\$0	
Signage		Flag Pole	east main entry	6	1	EA	\$0	building mounted
Signage		Marquee - Free Standing Back Lighted w/ LED	east main entry	7	1	EA	\$0	
SITE Sub Total							\$188,311	
SITE Sub Total							\$188,311	

Total Campus Need ^{2 3} \$12,759,590

¹ It is very rare for an assessor to find a feature in this condition. If they do, they are required to report it immediately to CPS, and CPS addresses it immediately. Thus, no features will be ranked "1" in summary reports; by the time the report is compiled, they have been resolved.

² As stated above, Total Assessed Campus Need does not include the addition of features not already in a particular facility, such as programmatic improvements, school-wide ADA compliance, air conditioning, space reconfiguration or construction to alleviate overcrowding; these items are treated as separate capital needs. The Total Assessed Campus Need includes current deficiencies and is based on current unit cost estimates; it does not reflect a complete project cost.

³ The overall condition of different items can change after an assessment date due to many variables, including newly occurring deficiencies, renovation or repairs and cost changes. These dollar figures in this report are estimates only and are based solely on the data that was collected as of the assessment date in the footer below.

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Building: Main														
101	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
102	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
103	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
110	1155	2	2	28	40	150	72	2	N	Y	Y	Classroom		
111	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
112	756	1	2	17	40	100	48	1	N	N	Y	Classroom		
201	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
202	756	1	2	14	40	100	48	1	N	Y	Y	Classroom		
203	756	1	22	52	40	100	48	1	N	Y	Y	Classroom		
204	868	1	2	13	40	100	48	1	N	Y	Y	Classroom		
205	868	1	2	13	40	100	48	1	N	Y	Y	Classroom		
206	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
207	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
208	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
209	756	1	2	24	40	100	48	1	N	Y	Y	Classroom		
210	756	1	2	17	40	100	48	1	N	Y	Y	Classroom		
211	756	1	2	17	40	100	48		N	Y	Y	Classroom		
212	756	1	2	17	40	100	48		N	Y	Y	Classroom		
301	1058	1	2	20	40	125	60	1	N	N	N	Classroom		
303	1058	1	2	32	40	125	60	1	N	N	N	Classroom		
304	562		2	14	40	50	24		N	N	N	Classroom		
305	1145	1	2	16	40	175	72		Y	N	N	Classroom		
306 & 307	1315	1	11	28	40	150	72		N	N	N	Classroom		
308	756	1	2	14	40	100	48		N	N	N	Classroom		
309	420	0	0	48	40	50	24	1	N	N	N	Classroom		
310	1128	1	40	92	40	150	72		N	N	N	Classroom		
311	756	1	2	13	40	100	48	1	N	N	N	Classroom		
312	756	1	2	13	40	100	48	1	N	N	N	Classroom		
Other	121			6					N	N	Y	Administrative Suites/Offices		assistant principals office in 106
Other	110			4					N	N	N	Administrative Suites/Offices		vacant workroom in rm 307
Other	72								N	N	N	Restroom	Staff Restroom	S Center Stairs- Flr 1.5 NOT USED
Other	38								N	N	N	Restroom	Staff Restroom	principals bathroom in 106
Other	8597								N	N	N	Auditorium & Theater	Auditorium - Dedicated	1st Floor
Other	84			4					N	N	N	Administrative Suites/Offices		in rm 303
Other	72								N	N	N	Restroom	Staff Restroom	N Center Stairs- Flr 1.5 NOT USED

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	234			8					N	N	N	Administrative Suites/Offices		in rm 305
Other	72								N	N	N	Restroom	Staff Restroom	S Center Stairs- Flr 2.5 NOT USED
Other	62								N	N	N	Restroom	Early Childhood Student Restroom	in rm 114
Other	206			22					N	N	N	Administrative Suites/Offices		vacant office in rm 307
Other	583								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls
Other	3885								N	N	N	Corridors		2nd Floor
Other	38								N	N	N	Restroom	Children's Standard Student Restroom	in rm 110
Other	3885								N	N	N	Corridors		3rd Floor
Other	1204								N	N	N	Restroom	Locker/Shower Room	3rd fl locker room in gym
Other	84			4					N	N	N	Administrative Suites/Offices		in rm 301
Other	583								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls
Other	72								N	N	N	Restroom	Staff Restroom	N Center Stairs- Flr 2.5 NOT USED
Other	583								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys
Other	583								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys
Other	583								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys
Other	170								N	N	N	Restroom	Adult Standard Student Restroom	womens in auditorium lobby (visitor use) locked/storage
Other	436								N	N	N	Corridors		corridor in 106
Other									N	N	N	Corridors		end stairs
Other	583								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls
Other	60								N	N	N	Restroom	Staff Restroom	women's rm in 106
Other									N	N	N	Corridors		center stairs
Other	494			18					N	N	Y	Administrative Suites/Offices		rm 109- principals office
Other	202			6					N	N	Y	Administrative Suites/Offices		106C
Other	115								N	N	N	Restroom	Adult Standard Student Restroom	Men's in auditorium lobby (visitor use) storage
Other	5373								N	N	N	Gymnasia	Standard Dedicated Gymnasium	3rd Floor
Other	280			8					N	N	Y	Administrative Suites/Offices		counselors office 106 D/E/F/G
Other	5320								N	N	N	Corridors		1st Floor
Other	324			6					N	N	N	Administrative Suites/Offices		rm 104
Other	1943			38					N	N	N	Administrative Suites/Offices		rm 114 (5 spaces) vacant
Other	905			22					N	N	Y	Administrative Suites/Offices		main office- 1st fl

Building: Addition

115	1302	1	4	34	40	240	112		Y	N	Y	Classroom		
118	1225	1	4	42	40	210	98		Y	N	N	Classroom		
120	1625	1	30	60	40	215	91	3	Y	Y	Y	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
121	720	1	25	54	40	102	49	1	Y	N	N	Classroom		
122	685	1	25	54	40	77	42		Y	N	Y	Classroom		
124	1077	1	33	70	40	171	77	1	Y	Y	Y	Classroom		
125	1077	1	33	70	40	190	84		Y	Y	Y	Classroom		
126	1077	1	33	70	40	164	70	2	Y	Y	Y	Classroom		
127	720	1	25	54	40	120	84	1	Y	N	N	Classroom		
129	685	1	25	54	40	156	70	1	Y	N	Y	Classroom		
213	720	1	25	54	40	147	70	1	Y	Y	Y	Classroom		
214	500	1	16	32	40	14	2	1	Y	Y	Y	Classroom		
215	720	1	25	54	40	120	56		Y	N	N	Classroom		
216	1077	1			40	180	84		Y	N	N	Classroom		
218	882			8	40	150	70		Y	Y	N	Classroom		
220	1785	1	30	60	40	222	98	2	Y	N	Y	Classroom		
221	720	1	25	54	40	120	63		Y	Y	Y	Classroom		
222	720	1	25	54	40	111	56	1	Y	Y	Y	Classroom		
224	1077	1	33	70	40	171	77	1	Y	Y	Y	Classroom		
224	720	1	25	54	40	111	56	1	Y	Y	Y	Classroom		
226A	500	1	16	32	40	81	35	1	Y	Y	N	Classroom		
226B	500	1	16	32	40	90	42		Y	N	N	Classroom		
227	720	1	25	54	40	102	49	2	Y	N	N	Classroom		
229	924	1	20	44	40	156	70	1	Y	N	N	Classroom		
313	720	1	3	10	40	210	98	1	Y	N	N	Classroom		
314	720	1	3	10	40	90	42	1	Y	N	N	Classroom		
315	720	1	25	54	40	120	72		Y	N	N	Classroom		
316	720	1	3	6	40	120	56	1	Y	N	N	Classroom		
317	360			4	40	60	28		Y	N	N	Classroom		
317A	360			4	40	60	28		Y	N	N	Classroom		
318	720	1	3	6	40	210	56	1	Y	N	N	Classroom		
319	1928	1	11	26	40	105	49		N	N	N	Classroom		
320	1610	1	30	60	40	222	98	2	Y	Y	N	Classroom		
321	720	1	25	54	40	111	56	1	Y	N	N	Classroom		
322	720	1	25	54	40	111	56	1	Y	N	N	Classroom		
323	720	1	25	54	40	111	56	1	Y	N	N	Classroom		
324	1077	1	33	70	40	171	77	1	Y	N	N	Classroom		
326	541	1	17	38	40	90	42		Y	N	N	Classroom		
327	720	1	25	54	40	111	56	1	Y	N	N	Classroom		
329	924	1	20	44	40	222	98	2	Y	N	N	Classroom		

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
331	541	1	17	38	40	90	42		Y	N	N	Classroom		
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls south
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl girls north
Other	220								N	N	N	Restroom	Staff Restroom	2nd fl mens south
Other	84								N	N	N	Restroom	Staff Restroom	2nd fl womans south
Other	350			22					N	N	N	Administrative Suites/Offices		rm 223A- resource
Other	690			32					N	N	N	Administrative Suites/Offices		228- office suite
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys north
Other	60								N	N	N	Restroom	Staff Restroom	2nd fl womens north
Other	364			22					N	N	N	Administrative Suites/Offices		rm 323A- vacant
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls south
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys south
Other	84								N	N	N	Restroom	Staff Restroom	3rd fl mens south
Other									N	N	N	Corridors		Stair 1
Other	690			32					N	N	N	Administrative Suites/Offices		328- office suite
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl girls north
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	3rd fl boys north
Other	136			2					N	N	N	Administrative Suites/Offices		1st fl south- womens lounge
Other	83								N	N	N	Corridors		NW Vestibule
Other	136			2					N	N	N	Administrative Suites/Offices		2nd fl south- womens lounge
Other	136			2					N	N	N	Administrative Suites/Offices		3rd fl south- womens lounge
Other	84								N	N	N	Restroom	Staff Restroom	3rd fl womens south- inaccessible
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys north
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls north
Other	220								N	N	N	Restroom	Staff Restroom	1st fl mens south
Other	7700								N	N	N	Corridors		3rd Floor
Other	7700								N	N	N	Corridors		2nd Floor
Other	62			4					N	N	Y	Administrative Suites/Offices		asst engineers office
Other	136			2					N	N	N	Administrative Suites/Offices		3rd fl south- mens lounge
Other	62								N	N	N	Restroom	Staff Restroom	in engineers breakroom- inaccessible
Other	92			4					N	N	N	Administrative Suites/Offices		319A- in 319
Other	250								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	5 practice rooms in rm 319 (combined total)
Other									N	N	N	Corridors		Stair 4
Other									N	N	N	Corridors		Stair 2
Other									N	N	N	Corridors		Stair 3
Other	310								N	N	N	Corridors		to boiler room

Room Summary

Room Number	Room Size	Voice Outlet	Data Outlet	Elect Outlet	Noise Level	Glaze Window Area	Operable Window Area	No. of Window AC	Window Stop	Smart Board	Power Strip	Room Type	Room Sub Type	Location
Other	60								N	N	N	Restroom	Staff Restroom	3rd fl mens north- inaccessible
Other	7700								N	N	N	Corridors		1st Floor
Other	87			4					N	N	Y	Administrative Suites/Offices		kitchen managers office in kitchen
Other	85			4					N	N	Y	Administrative Suites/Offices		gym office in gym 2nd fl south
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	1st fl girls south
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	2nd fl boys south
Other	220								N	N	N	Restroom	Children's Standard Student Restroom	1st fl boys south
Other	4762								N	N	N	Lunch & Multipurpose Room	Lunchroom	1st fl south
Other	230								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	dishing washing room 1st fl south
Other	1007								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	servery
Other	84								N	N	N	Restroom	Staff Restroom	1st fl womens south
Other	35								N	N	N	Restroom	Locker/Shower Room	in kitchen
Other	5950								N	N	N	Gymnasia	Standard Dedicated Gymnasium	2nd fl south
Other	330								N	N	N	Lunch & Multipurpose Room	Lunchroom	kitchen staff lunch room in kitchen
Other	1050								N	N	N	Kitchen	Cooking Kitchen	1st fl south
Other	35								N	N	N	Restroom	Staff Restroom	in rm 122 inaccessible not finished
Other	1510			4					N	N	N	Administrative Suites/Offices		Rm 114-Addition Teacher Resource Rm
Other	122			4					N	N	Y	Administrative Suites/Offices		engineers office
Other	85								N	N	N	Lunch & Multipurpose Room	Multipurpose Room	engineers breakroom
Other	62								N	N	N	Restroom	Staff Restroom	in asst. engineers office
Other	35								N	N	N	Restroom	Staff Restroom	in kitchen